

**Table I.2 Design Calculation of C2+E1 WWTP (1/11)**

## **1 BASIC CONDITIONS**

### **1-1 Basic Items**

- (1) Name : **C2+E1 WWTP**
- (2) Land Area : Approximately      xxxx      ha
- (3) Ground Level (Elevation) : +      4.00      m (Plan)
- (4) Inlet Pipe Invert Level : -      15.82      m
- (5) Pipe Diameter :      3,200      mm
- (6) Land Use :      —
- (7) Collection System : ~~Combined System~~      **Separate System**
- (8) Treatment Process : Conventional Activated Sludge Process
- (9) Effluent Point : Ngamoeyeik Creek
- (10) Water Level at the Effluent Point :  
         High water level =      3.70      m  
         Low water level =      —      m
- (11) Target Year :      2020 (F/S Stage)  
                              2040 (M/P Stage)

### **1-2 Service Area and Design Population**

- (1) Service Area : 11,286 ha
- (2) Design Population

| Item              |        | Year 2020 | Year 2040 |
|-------------------|--------|-----------|-----------|
| Design Population | person | -         | 1,902,000 |

**Table I.2 Design Calculation of C2+E1 WWTP (2/11)**

**1-3 Design Sewage Flow**

**(Year 2020)**

| Item                | m <sup>3</sup> /day | m <sup>3</sup> /hr | m <sup>3</sup> /min | m <sup>3</sup> /sec |
|---------------------|---------------------|--------------------|---------------------|---------------------|
| Maximum Daily Flow  |                     | 0.0                | 0.00                | 0.000               |
| Maximum Hourly Flow | 0                   | 0.0                | 0.00                | 0.000               |


**(Year 2040)**

| Item                | m <sup>3</sup> /day | m <sup>3</sup> /hr | m <sup>3</sup> /min | m <sup>3</sup> /sec |
|---------------------|---------------------|--------------------|---------------------|---------------------|
| Maximum Daily Flow  | 744,000             | 31,000.0           | 516.67              | 8.611               |
| Maximum Hourly Flow | 1,116,000           | 46,500.0           | 775.00              | 12.917              |

**1-4 Design Sewage Quality**

| Item     | BOD<br>(mg/l) | SS<br>(mg/l) | T-N<br>(mg/l) | Coli-group<br>(MPN/cm <sup>3</sup> ) | Oil&Grease<br>(mg/l) |
|----------|---------------|--------------|---------------|--------------------------------------|----------------------|
| Influent | 200           | 180          | -             | -                                    | -                    |
| Effluent | 20            | 30           | -             | 3,000                                | 5                    |

**1-5 Process Flow Diagram**



**Table I.2 Design Calculation of C2+E1 WWTP (3/11)**

**1.6 Design Criteria**

| ITEMS  | UNIT                                | Formula or Value | Application |
|--|-------------------------------------|------------------|-------------|
| <b>1</b> Grit Chamber (For Maximum Hourly Flow)              |                                     |                  |             |
| (1) Hydraulic Load   | m <sup>3</sup> /m <sup>2</sup> /day | 1,800            | 1,800       |
| (2) Average Velocity   | m/sec                               | 0.3              | 0.3         |
| <b>2</b> Primary Sedimentation Tank (For Maximum Daily Flow) |                                     |                  |             |
| (1) Hydraulic Load   | m <sup>3</sup> /m <sup>2</sup> /day | 35.0-70.0        | 50          |
| (2) Settling Time (Ref.)                                     | hour                                | 1.5              | 1.5         |
| (3) Water Depth  | m                                   | 2.5-4.0          | 3.5         |
| (4) Weir Loading   | m <sup>3</sup> /m/day               | 250              | 250         |
| <b>3</b> Aeration Tank (For Maximum Daily Flow)              |                                     |                  |             |
| (1) Hydraulic Retention Time (HRT)                           | hour                                | 6 - 8            | 6.0         |
| (2) MLSS Concentration                                       | mg/l                                | 1,500 -2,000     | 2,000       |
| (3) BOD-SS Load (Reference only)                             | kg/kg/day                           | 0.2 - 0.4        | -           |
| <b>4</b> Final Sedimentation Tank (For Maximum Daily Flow)   |                                     |                  |             |
| (1) Hydraulic Load   | m <sup>3</sup> /m <sup>2</sup> /day | 20.0-30.0        | 25          |
| (2) Settling Time (Ref.)                                     | hour                                | 3.0-4.0          | -           |
| (3) Water Depth  | m                                   | 2.5-4.0          | 3.5         |
| (4) Weir Loading   | m <sup>3</sup> /m/day               | 150              | 150         |
| <b>5</b> Disinfection Tank (For Maximum Daily Flow)          |                                     |                  |             |
| (1) Retention (Chlorination) Time                            | min                                 | 15               | 15          |
| <b>6</b> Gravity Thickener (For Maximum Daily Flow)          |                                     |                  |             |
| (1) Solids Loading   | kg/m <sup>2</sup> /day              | 60-90            | 75          |
| (2) Water Depth  | m                                   |                  | 4.0         |
|  |                                     |                  |             |

**Table I.2 Design Calculation of C2+E1 WWTP (4/11)**

## 2 CAPACITY CALCULATION

### 2-1 Grit Chamber

| Item                     | Sign | Unit                                | Calculation        | F/S | M/P         |
|--------------------------|------|-------------------------------------|--------------------|-----|-------------|
| Type                     | -    | -                                   | Parallel Flow Type |     |             |
| Design Sewage Flow       | Q1   | m <sup>3</sup> /day                 |                    |     | 1,116,000   |
| (Maximum Hourly Flow)    | Q2   | m <sup>3</sup> /sec                 |                    |     | 12.917      |
| Water Surface Load       | WSL  | m <sup>3</sup> /m <sup>2</sup> /day |                    |     | 1,800       |
| Required Surface Area    | RSA  | m <sup>2</sup>                      | Q1/WSL             |     | 620.00      |
| Basin Number             | BN   | basin                               |                    |     | 16          |
| Average Velocity         | AV   | m/sec                               |                    |     | 0.3         |
| Depth                    | H    | m                                   |                    |     | 1           |
| Width                    | W1   | m                                   | Q2/(AV×H×BN)       |     | 2.69        |
| <i>Therefore</i>         | W2   | m                                   |                    |     | 3.0         |
| Length                   | L1   | m                                   | RSA/(W2×BN)        |     | 12.92       |
| <i>Therefore</i>         | L2   | m                                   |                    |     | 13.0        |
| <b>Dimension (Width)</b> | W    | m                                   |                    |     | <b>3.0</b>  |
| <b>(Length)</b>          | L    | m                                   | L2                 |     | <b>13.0</b> |
| <b>(Depth)</b>           | H    | m                                   | H                  |     | <b>1.0</b>  |
| <b>(Basin Number)</b>    | N    | basin                               |                    |     | <b>16</b>   |
| <b>(Check)</b>           |      |                                     |                    |     |             |
| Water Surface Load       |      | m <sup>3</sup> /m <sup>2</sup> /day | Q1/(W×L×N)         |     | 1,788       |
| Average Velocity         |      | m/sec                               | Q2/(W×H×N)         |     | 0.269       |
|                          |      |                                     |                    |     |             |

### 2-2 Lift Pump Station

| Item                        | Sign | Unit                | Calculation                                | F/S | M/P       |
|-----------------------------|------|---------------------|--|-----|-----------|
| Type                        | -    | -                   | Vertical shaft Volute type mixed flow pump |     |           |
| Design Sewage Flow          | Q1   | m <sup>3</sup> /min | Peak Flow/4Nos                             |     | 193.75    |
|                             |      |                     |  |     |           |
| Pump Unit -1 Number         | UN1  | unit                |  |     | 2         |
| Discharge per Unit          | DU1  | m <sup>3</sup> /min | 1/10×Q1                                    |     | 19.38     |
| Pump Diameter(V=1.5~3.0m/s) | D1   | mm                  | 146×(DU1/1.5~3.0) <sup>0.5</sup>           |     | 371 ~525  |
| <i>Therefore</i>            | D1   | mm                  |  |     | 450       |
|                             |      |                     |  |     |           |
| Pump Unit -2 Number         | UN2  | unit                |  |     | 2         |
| Discharge per Unit          | DU2  | m <sup>3</sup> /min | 2/10×Q1                                    |     | 38.75     |
| Pump Diameter(V=1.5~3.0m/s) | D2   | mm                  | 146×(DU2/1.5~3.0) <sup>0.5</sup>           |     | 525 ~742  |
| <i>Therefore</i>            | D2   | mm                  |  |     | 600       |
|                             |      |                     |  |     |           |
| Pump Unit -3 Number         | UN3  | unit                | including 1 stand-by                       |     | 2         |
| Discharge per Unit          | DU3  | m <sup>3</sup> /min | 4/10×Q1                                    |     | 77.50     |
| Pump Diameter(V=1.5~3.0m/s) | D3   | mm                  | 146×(DU3/1.5~3.0) <sup>0.5</sup>           |     | 742 ##### |
| <i>Therefore</i>            | D3   | mm                  |  |     | 900       |



**Table I.2 Design Calculation of C2+E1 WWTP (5/11)**

### 2-3 Primary Sedimentation Tank

[illegible]

**Table I.2 Design Calculation of C2+E1 WWTP (6/11)**

**2-4 Aeration Tank**

| Item  | Sign             | Unit                  | Calculation   | F/S  | M/P      |      |      |  |  |
|---|------------------|-----------------------|---|--|----------|------|------|--|--|
| Type  | -                | -                     | Multi-tank Complete mixing Type   |  |          |      |      |  |  |
| Design Sewage Flow  | Q1               | m <sup>3</sup> /day   |   |  | 744,000  |      |      |  |  |
| (Maximum Daily Flow)  | Q2               | m <sup>3</sup> /hr    |   |  | 31,000.0 |      |      |  |  |
| Hydraulic Retention Time                                    | HRT              | hr                    |   |  | 6.0      |      |      |  |  |
| Basin Number  | BN               | basin                 |   |  | 32       |      |      |  |  |
| Required Volume per basin                                   | RV               | m <sup>3</sup> /basin | Q2×RT/BN  |  | 5,813    |      |      |  |  |
| Width   | W                | m                     | 1~2H  |  | 10.5     |      |      |  |  |
| Water Depth   | H                | m                     | Deep Aeration Tank  |  | 10.0     |      |      |  |  |
| Length  | L1               | m                     | RV/(W×H)  |  | 55.4     |      |      |  |  |
| Therefore   | L2               | m                     |   |  | 56.0     |      |      |  |  |
| Dimension (Width)   | W                | m                     |   |  | 10.5     |      |      |  |  |
| (Depth)   | H                | m                     |   |  | 10.0     |      |      |  |  |
| (Length)  | L                | m                     |   |  | 56.0     |      |      |  |  |
| (Basin Number)  | N                | basin                 |   |  | 32       |      |      |  |  |
|   |                  |                       |   |  |          |      |      |  |  |
| (Check)   |                  |                       |   |  |          |      |      |  |  |
| Hydraulic Retention Time                                    | HRT              | hour                  | W×H×L×N/Q2  |  | 6.1      |      |      |  |  |
| BOD-SS load   | BSS <sub>L</sub> | kgBOD/kgSS/d          | (Q1×BOD <sub>in</sub> )/(W×H×L×N×X <sub>a</sub> )   |  | 0.24     |      |      |  |  |
| BOD <sub>in</sub> : Inflow BOD Concentration                |                  |                       | 120 mg/L  | (Removal Rate in PST : 40%)                |          |      |      |  |  |
| X <sub>a</sub> : MLSS Concentration                         |                  |                       | 2,000 mg/L  |  |          |      |      |  |  |
| Aerobic Sludge Retention Time                               | ASRT             | day                   | HRT/24×X <sub>a</sub> / (a×S-BOD <sub>in</sub> + b×SS <sub>in</sub> - c×HRT/24×X <sub>a</sub> ) = |  |          |      |      |  |  |
|   |                  |                       |   |  | 4.805    |      |      |  |  |
| S-BOD <sub>ir</sub> : Inflow S-BOD Concentration            |                  |                       | 80 mg/L   | (S-BOD[Solved BOD]=BOD <sub>in</sub> ×0.6) |          |      |      |  |  |
| SS <sub>in</sub> : Inflow SS Concentration                  |                  |                       | 90 mg/L   | (Removal Rate in PST : 50%)                |          |      |      |  |  |
| a : Sludge converting ratio of solved BOI                   |                  |                       | 0.5 mgMLSS/mgBOD  | (0.4~0.6)                                  |          |      |      |  |  |
| b : Sludge converting ratio of SS                           |                  |                       | 0.95 mgMLSS/mgSS  | (0.9~1.0)                                  |          |      |      |  |  |
| c : Sludge reduction ratio caused by endogenous respiration |                  |                       | 0.04 (1/day)  | (0.03~0.05)                                |          |      |      |  |  |
| Effluent Quality (C-BOD)                                    | EQ               | mg/L                  | 10.42×A-SRT <sup>(-0.519)</sup> (15~20°C)   |  | 4.614    |      |      |  |  |
| Water Temperature   |                  |                       | 20 °C   |  |          |      |      |  |  |
| Effluent Water Quality (C=BOD Maximum)                      |                  |                       | EQ×3  | 20mg/l >                                   | 14       |      |      |  |  |
|   |                  |                       |   |  | -OK-     |      |      |  |  |
|   |                  |                       | 1 : 1.5 : 1.5 : 2.25  |  |          |      |      |  |  |
| Partition of Aeration Tank                                  |                  |                       | <table><tr><td>Nn 1</td><td>Nn 2</td><td>Nn 3</td><td>Nn 4</td></tr></table>                      | Nn 1                                       | Nn 2     | Nn 3 | Nn 4 |  |  |
| Nn 1  | Nn 2             | Nn 3                  | Nn 4  |  |          |      |      |  |  |
|   |                  |                       |   |  |          |      |      |  |  |
| Total Length of Tank  | TL               | m                     |   |  | 56.0     |      |      |  |  |
| No.1 Tank Length  | L1               | m                     | TL×1/(1+1.5+1.5+2.25)   |  | 9.0      |      |      |  |  |
| No.2 Tank Length  | L2               | m                     | TL×1.5/(1+1.5+1.5+2.25)   |  | 13.4     |      |      |  |  |
| No.3 Tank Length  | L3               | m                     | TL×1.5/(1+1.5+1.5+2.25)   |  | 13.4     |      |      |  |  |
| No.4 Tank Length  | L4               | m                     | TL×2.25/(1+1.5+1.5+2.25)  |  | 20.2     |      |      |  |  |
|   |                  |                       | Total   |  | 56.0     |      |      |  |  |
|   |                  |                       |   |  |          |      |      |  |  |



**Table I.2 Design Calculation of C2+E1 WWTP (8/11)**

**2-6 Disinfection Channel**

| Item                         | Sign | Unit                | Calculation   | F/S | M/P         |
|------------------------------|------|---------------------|---------------|-----|-------------|
| Type                         | -    | -                   | Chlorination  |     |             |
| Design Sewage Flow           | Q1   | m <sup>3</sup> /day |               |     | 744,000     |
| (Maximum Daily Flow)         | Q2   | m <sup>3</sup> /min |               |     | 516.7       |
| Retention(Chlorination) Time | RT   | min                 |               |     | 15.0        |
| Required Volume              | RV   | m <sup>3</sup>      | Q2×RT         |     | 7,750       |
| Width of channel             | W    | m                   |               |     | 2.0         |
| Depth of channel             | H    | m                   |               |     | 3.0         |
| Pass Number                  | PN   | pass                |               |     | 32          |
| Length of channel            | L1   | m/pass              | RV/(W×H×PN)   |     | 40.4        |
| <i>Therefore</i>             | L2   | m/pass              |               |     | 41.0        |
| <b>Dimension (Width)</b>     | W    | m                   |               |     | <b>2.0</b>  |
| <b>(Depth)</b>               | H    | m                   |               |     | <b>3.0</b>  |
| <b>(Length)</b>              | L    | m/pass              |               |     | <b>41.0</b> |
| <b>(Pass Number)</b>         | N    | pass                |               |     | <b>32</b>   |
| <b>(Check)</b>               |      |                     |               |     |             |
| Retention(Chlorination) Time | RT   | min                 | (W×H×L×PN)/Q2 |     | 15.2        |

**2-7 Sludge Thickening Tank**

| Item                        | Sign | Unit                   | Calculation                                     | F/S | M/P         |
|-----------------------------|------|------------------------|---|-----|-------------|
| Type                        | -    | -                      | Gravity Thickener (Radial Flow Circular Type)   |     |             |
| Generated Sludge Solids     | GS   | t-DS/day               | Refer to Mass Balance Cal.                      |     | 138.68      |
| Generated Sludge Volume     | GSV  | m <sup>3</sup> /day    | Refer to Mass Balance Cal.                      |     | 17,464      |
| Solid Matter Load           | SML  | kg/m <sup>2</sup> /day |   |     | 75          |
| Required Surface Area       | SA   | m <sup>2</sup>         | (GS×10 <sup>3</sup> )/SML                       |     | 1849.1      |
| Water Depth                 | H    | m                      |   |     | 4.0         |
| Basin Number                | BN   | basin                  |   |     | 16          |
| Required Tank Diameter      | TD1  | m                      | (SA×4/(3.14×BN)) <sup>0.5</sup>                 |     | 12.13       |
| <i>Therefore</i>            | TD2  | m                      |   |     | 12.5        |
| <b>Dimension (Diameter)</b> | D    | m/basin                |   |     | <b>12.5</b> |
| <b>(Depth)</b>              | H    | m                      |   |     | <b>4.0</b>  |
| <b>(Basin Number)</b>       | BN   | basin                  |   |     | <b>16</b>   |
| <b>(Check)</b>              |      |                        |   |     |             |
| Solid Matter Load           | SML  | kg/m <sup>2</sup> /day | GS×10 <sup>3</sup> /(3.14×D <sup>2</sup> /4)×BN |     | 70.7        |
| Sludge Thickened Time       | T    | hr                     | (3.14×D <sup>2</sup> /4)×H×BN×24/GSV            |     | 10.8        |
|                             |      |                        |   |     |             |
|                             |      |                        |   |     |             |
|                             |      |                        |   |     |             |
|                             |      |                        |   |     |             |
|                             |      |                        |   |     |             |



**Table I.2 Design Calculation of C2+E1 WWTP (10/11)**

**Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Mechanical Dewatering)**

**Table-1 Input Data**

|  |     |  |
|--|-----|--|
| 1. Calculation Manner                        |     | 1: Premise that the quality of supernatants are same level removed with inlet sewage<br>2: Premise that the entire supernatants are removed at treatment process |
| 2. Selection of Treatment Efficiency         |     | 1: Total Removal Ratio 2: Outlet Water Quality (input 1or2)  |
| In case of 1: input data                     | 90  | (%)  |
| In case of 2: input data                     |     | (mg/l)   |
| 3. Excess Sludge Generation                  |     | 1: Consideration of Solid Matter Only 2: Consideration of Converting of Solved BOD (input 1or2)  |
| In case of 1: Input data (Sludge generation) | 100 | Sludge generation ratio per removal SS (%)   |
| In case of 2: Input data                     | a   | $T2=Q2 \cdot S2=(a \cdot S_{BOD}+b \cdot S1-c \cdot \theta \cdot XA) \cdot Q1 \cdot 10^{-6}$ (Excess sludge generation formula)                                  |
|  | b   | a: Converting ratio of solved BOD (mg)/MLSS (mgBOD)  |
|  | c   | b: Converting ratio of SS (mg)/MLSS (mgSS)   |
|  | SA  | c: Sludge reduction ratio caused by endogenous respiration of activated sludge (1/day)   |
|  | XA  | SA: Solved BOD quality at inlet to reactor<br>XA: MLSS concentration (mg/l)<br>$\theta$ : Hydraulic retention time (day)   |


**Table-2 Basic Conditions**

| Water Flow and Quality                          |        | Sludge Moisture and Recovery Ratio       |      | Chemical Conditions for Dewatering          |      |
|---|--------|--|------|---|------|
| *Inlet flow: Q0 (m3/D)                          | 744000 | *Primary sludge moisture ratio: W1 (%)   | 98.5 | *Chemical dosage: A5 (%)                    | 1.0  |
| *Inlet quality: S0 (mg/l)                       | 180    | *Excess sludge moisture ratio: W2 (%)    | 99.5 | *Recovery ratio in sludge thickener: A3 (%) | 90.0 |
| *Total removal ratio: A1 (%)                    | 90.0   | *Thickened sludge moisture ratio: W3 (%) | 98.0 | *Recovery ratio in dewatering: A4 (%)       | 95.0 |
| *Effluent quality: S6 (mg/l)                    |        | *Dewatered sludge moisture ratio: W4 (%) | 80.0 |   |      |
| *Sludge generation ratio per removal SS: S1 (%) | 100.0  |  |      |   |      |

**Table-3 Material Balance Calculation**

|              | 0      | 1      | 2     | 3      | 4     | 5      | 6      | 7     | 8    | 9      | 10     | 11   | 12    |  | 5-1    |
|--------------|--------|--------|-------|--------|-------|--------|--------|-------|------|--------|--------|------|-------|--|--------|
| Q (m3/day)   | 744000 | 761489 | 5136  | 756353 | 12327 | 744025 | 6241   | 11223 | 624  | 6865   | 599    | 6266 | 17489 |  | 743401 |
| T (t·DS/day) | 133920 | 154091 | 77046 | 77046  | 61637 | 15409  | 124814 | 13863 | 1248 | 126062 | 119759 | 6303 | 20171 |  | 14161  |
| S (mg/l)     | 180    | 202    | 15000 | 102    | 5000  | 21     | 20000  | 1236  | 2000 | 18364  | 200000 | 1006 | 1153  |  | 21     |
| X (t·DS/100) | 100    | 115.1  | 57.5  | 57.5   | 46.0  | 11.5   | 93.2   | 10.4  | 0.9  | 94.1   | 89.4   | 4.7  | 15.1  |  | 10.6   |


**Figure-1 Material Balance Model**



| Calculation Formula   |  |  |  |  |                                    |
|---|--|--|--|--|------------------------------------|
| *Q0=Input Data<br>*T0=Q0*S0*10 <sup>-6</sup> (-6)<br>*S0=Input Data       | *Q3=Q1-Q2<br>*T3=T1*(100-A2)/100<br>*S3=T3*10 <sup>-6</sup> /Q3                    | *Q6=T4*100/(100-W3)<br>*T6=(T2-T4)*A3/100<br>*S6=10 <sup>-6</sup> *Q6/(100-W3)/100 | *Q9=Q6-Q8<br>*T9=T6-T8<br>*S9=T9*10 <sup>-6</sup> /Q9                              | *Q12=Q7+Q11<br>*T12=T7+T11<br>*S11=T11*10 <sup>-6</sup> /Q11 | *Q5=Q5-Q8<br>*T5=T5-T8<br>*S5=1-S5 |
| *Q1=Q0+Q13<br>*T1=T0+T13<br>*S1=T1*10 <sup>-6</sup> /Q1                   | *Q4=T4*100/(100-W2)<br>*T4=(T1-T5)*S6/100<br>*S4=10 <sup>-6</sup> *Q4/(100-W2)/100 | *Q7=(Q2+Q4)-Q6<br>*T7=(T2+T4)-T6<br>*S7=T7*10 <sup>-6</sup> /Q7                    | *Q10=T10*100/(100-W4)<br>*T10=T9*A4/100<br>*S10=10 <sup>-6</sup> *Q10/(100-W4)/100 |  |                                    |
| *Q2=T2*100/(100-W1)<br>*T2=T1-T3<br>*S2=10 <sup>-6</sup> *Q2/(100-W1)/100 | *Q5=Q3-Q4*(T3-T5)/T4<br>*T5=T1*(100-A1)/100<br>*S5=T5*10 <sup>-6</sup> /Q5         | *Q8=T6*A5/A6<br>*T8=Q8*S8/10 <sup>-6</sup><br>*S8=10 <sup>-4</sup> *A6             | *Q11=Q9-Q10<br>*T11=T9-T10<br>*S11=T11*10 <sup>-6</sup> /Q11                       |  |                                    |

Table I.2 Design Calculation of C2+E1 WWTP (11/11)

Material Balance Sheet



**Table I.3 Design Calculation of W1 WWTP (1/11)**

## **1 BASIC CONDITIONS**

### **1-1 Basic Items**

- (1) Name : **W1 WWTP**
- (2) Land Area : Approximately      xxxx      ha
- (3) Ground Level (Elevation) : +      4.10      m (Plan)
- (4) Inlet Pipe Invert Level : -      7.60      m
- (5) Pipe Diameter :      2,000      mm
- (6) Land Use :      —
- (7) Collection System : ~~Combined System~~      **Separate System**
- (8) Treatment Process : Conventional Activated Sludge Process
- (9) Effluent Point : Hlaing River
- (10) Water Level at the Effluent Point :  
         High water level =      3.70      m  
         Low water level =      —      m
- (11) Target Year :    2020 (F/S Stage)  
                               2040 (M/P Stage)

### **1-2 Service Area and Design Population**

- (1) Service Area :    1,654    ha

- (2) Design Population

| Item              |        | Year 2020 | Year 2040 |
|-------------------|--------|-----------|-----------|
| Design Population | person | -         | 483,300   |



**Table I.3 Design Calculation of W1 WWTP (2/11)**

**1-3 Design Sewage Flow**

**(Year 2020)**

| Item                | m <sup>3</sup> /day | m <sup>3</sup> /hr | m <sup>3</sup> /min | m <sup>3</sup> /sec |
|---------------------|---------------------|--------------------|---------------------|---------------------|
| Maximum Daily Flow  |                     | 0.0                | 0.00                | 0.000               |
| Maximum Hourly Flow | 0                   | 0.0                | 0.00                | 0.000               |


**(Year 2040)**

| Item                | m <sup>3</sup> /day | m <sup>3</sup> /hr | m <sup>3</sup> /min | m <sup>3</sup> /sec |
|---------------------|---------------------|--------------------|---------------------|---------------------|
| Maximum Daily Flow  | 184,000             | 7,666.7            | 127.78              | 2.130               |
| Maximum Hourly Flow | 276,000             | 11,500.0           | 191.67              | 3.194               |

**1-4 Design Sewage Quality**

| Item     | BOD<br>(mg/l) | SS<br>(mg/l) | T-N<br>(mg/l) | Coli-group<br>(MPN/cm <sup>3</sup> ) | Oil&Grease<br>(mg/l) |
|----------|---------------|--------------|---------------|--------------------------------------|----------------------|
| Influent | 200           | 180          | -             | -                                    | -                    |
| Effluent | 20            | 30           | -             | 3,000                                | 5                    |

**1-5 Process Flow Diagram**



**Table I.3 Design Calculation of W1 WWTP (3/11)**

**1.6 Design Criteria**

| ITEMS  | UNIT                                | Formula or Value | Application |
|--|-------------------------------------|------------------|-------------|
| <b>1 Grit Chamber (For Maximum Hourly Flow)</b>              |                                     |                  |             |
| (1) Hydraulic Load   | m <sup>3</sup> /m <sup>2</sup> /day | 1,800            | 1,800       |
| (2) Average Velocity   | m/sec                               | 0.3              | 0.3         |
| <b>2 Primary Sedimentation Tank (For Maximum Daily Flow)</b> |                                     |                  |             |
| (1) Hydraulic Load   | m <sup>3</sup> /m <sup>2</sup> /day | 35.0-70.0        | 50          |
| (2) Settling Time (Ref.)                                     | hour                                | 1.5              | 1.5         |
| (3) Water Depth  | m                                   | 2.5-4.0          | 3.5         |
| (4) Weir Loading   | m <sup>3</sup> /m/day               | 250              | 250         |
| <b>3 Aeration Tank (For Maximum Daily Flow)</b>              |                                     |                  |             |
| (1) Hydraulic Retention Time (HRT)                           | hour                                | 6 - 8            | 6.0         |
| (2) MLSS Concentration                                       | mg/l                                | 1,500 -2,000     | 2,000       |
| (3) BOD-SS Load (Reference only)                             | kg/kg/day                           | 0.2 - 0.4        | -           |
| <b>4 Final Sedimentation Tank (For Maximum Daily Flow)</b>   |                                     |                  |             |
| (1) Hydraulic Load   | m <sup>3</sup> /m <sup>2</sup> /day | 20.0-30.0        | 25          |
| (2) Settling Time (Ref.)                                     | hour                                | 3.0-4.0          | -           |
| (3) Water Depth  | m                                   | 2.5-4.0          | 3.5         |
| (4) Weir Loading   | m <sup>3</sup> /m/day               | 150              | 150         |
| <b>5 Disinfection Tank (For Maximum Daily Flow)</b>          |                                     |                  |             |
| (1) Retention (Chlorination) Time                            | min                                 | 15               | 15          |
| <b>6 Gravity Thickener (For Maximum Daily Flow)</b>          |                                     |                  |             |
| (1) Solids Loading   | kg/m <sup>2</sup> /day              | 60-90            | 75          |
| (2) Water Depth  | m                                   |                  | 4.0         |
|  |                                     |                  |             |

**Table I.3 Design Calculation of W1 WWTP (4/11)**

## 2 CAPACITY CALCULATION

### 2-1 Grit Chamber

| Item                     | Sign | Unit                                | Calculation        | F/S | M/P         |
|--------------------------|------|-------------------------------------|--------------------|-----|-------------|
| Type                     | -    | -                                   | Parallel Flow Type |     |             |
| Design Sewage Flow       | Q1   | m <sup>3</sup> /day                 |                    |     | 276,000     |
| (Maximum Hourly Flow)    | Q2   | m <sup>3</sup> /sec                 |                    |     | 3.194       |
| Water Surface Load       | WSL  | m <sup>3</sup> /m <sup>2</sup> /day |                    |     | 1,800       |
| Required Surface Area    | RSA  | m <sup>2</sup>                      | Q1/WSL             |     | 153.33      |
| Basin Number             | BN   | basin                               |                    |     | 4           |
| Average Velocity         | AV   | m/sec                               |                    |     | 0.3         |
| Depth                    | H    | m                                   |                    |     | 1           |
| Width                    | W1   | m                                   | Q2/(AV×H×BN)       |     | 2.66        |
| <i>Therefore</i>         | W2   | m                                   |                    |     | 3.0         |
| Length                   | L1   | m                                   | RSA/(W2×BN)        |     | 12.78       |
| <i>Therefore</i>         | L2   | m                                   |                    |     | 12.5        |
| <b>Dimension (Width)</b> | W    | m                                   |                    |     | <b>3.0</b>  |
| <b>(Length)</b>          | L    | m                                   | L2                 |     | <b>12.5</b> |
| <b>(Depth)</b>           | H    | m                                   | H                  |     | <b>1.0</b>  |
| <b>(Basin Number)</b>    | N    | basin                               |                    |     | <b>4</b>    |
| <b>(Check)</b>           |      |                                     |                    |     |             |
| Water Surface Load       |      | m <sup>3</sup> /m <sup>2</sup> /day | Q1/(W×L×N)         |     | 1,840       |
| Average Velocity         |      | m/sec                               | Q2/(W×H×N)         |     | 0.266       |

### 2-2 Lift Pump Station

| Item                        | Sign | Unit                | Calculation                                | F/S | M/P       |
|-----------------------------|------|---------------------|--|-----|-----------|
| Type                        | -    | -                   | Vertical shaft Volute type mixed flow pump |     |           |
| Design Sewage Flow          | Q1   | m <sup>3</sup> /min | Peak Flow                                  |     | 191.67    |
| Pump Unit -1 Number         | UN1  | unit                |  |     | 2         |
| Discharge per Unit          | DU1  | m <sup>3</sup> /min | 1/10×Q1                                    |     | 19.17     |
| Pump Diameter(V=1.5~3.0m/s) | D1   | mm                  | 146×(DU1/1.5~3.0) <sup>0.5</sup>           |     | 369 ~522  |
| <i>Therefore</i>            | D1   | mm                  |  |     | 450       |
| Pump Unit -2 Number         | UN2  | unit                |  |     | 2         |
| Discharge per Unit          | DU2  | m <sup>3</sup> /min | 2/10×Q1                                    |     | 38.33     |
| Pump Diameter(V=1.5~3.0m/s) | D2   | mm                  | 146×(DU2/1.5~3.0) <sup>0.5</sup>           |     | 522 ~738  |
| <i>Therefore</i>            | D2   | mm                  |  |     | 600       |
| Pump Unit -3 Number         | UN3  | unit                | including 1 stand-by                       |     | 2         |
| Discharge per Unit          | DU3  | m <sup>3</sup> /min | 4/10×Q1                                    |     | 76.67     |
| Pump Diameter(V=1.5~3.0m/s) | D3   | mm                  | 146×(DU3/1.5~3.0) <sup>0.5</sup>           |     | 738 ##### |
| <i>Therefore</i>            | D3   | mm                  |  |     | 800       |



**Table I.3 Design Calculation of W1 WWTP (6/11)**

**2-4 Aeration Tank**

| Item  | Sign             | Unit                  | Calculation   | F/S  | M/P     |      |      |  |  |
|---|------------------|-----------------------|---|--|---------|------|------|--|--|
| Type  | -                | -                     | Multi-tank Complete mixing Type   |  |         |      |      |  |  |
| Design Sewage Flow  | Q1               | m <sup>3</sup> /day   |   |  | 184,000 |      |      |  |  |
| (Maximum Daily Flow)  | Q2               | m <sup>3</sup> /hr    |   |  | 7,666.7 |      |      |  |  |
| Hydraulic Retention Time                                    | HRT              | hr                    |   |  | 6.0     |      |      |  |  |
| Basin Number  | BN               | basin                 |   |  | 6       |      |      |  |  |
| Required Volume per basin                                   | RV               | m <sup>3</sup> /basin | Q2×RT/BN  |  | 7,667   |      |      |  |  |
| Width   | W                | m                     | 1~2H  |  | 10.5    |      |      |  |  |
| Water Depth   | H                | m                     | Deep Aeration Tank  |  | 10.0    |      |      |  |  |
| Length  | L1               | m                     | RV/(W×H)  |  | 73.0    |      |      |  |  |
| Therefore   | L2               | m                     |   |  | 73.0    |      |      |  |  |
| Dimension (Width)   | W                | m                     |   |  | 10.5    |      |      |  |  |
| (Depth)   | H                | m                     |   |  | 10.0    |      |      |  |  |
| (Length)  | L                | m                     |   |  | 73.0    |      |      |  |  |
| (Basin Number)  | N                | basin                 |   |  | 6       |      |      |  |  |
|   |                  |                       |   |  |         |      |      |  |  |
| (Check)   |                  |                       |   |  |         |      |      |  |  |
| Hydraulic Retention Time                                    | HRT              | hour                  | W×H×L×N/Q2  |  | 6.0     |      |      |  |  |
| BOD-SS load   | BSS <sub>L</sub> | kgBOD/kgSS/d          | (Q1×BOD <sub>in</sub> )/(W×H×L×N×X <sub>a</sub> )   |  | 0.24    |      |      |  |  |
| BOD <sub>in</sub> : Inflow BOD Concentration                |                  |                       | 120 mg/L  | (Removal Rate in PST : 40%)                |         |      |      |  |  |
| X <sub>a</sub> : MLSS Concentration                         |                  |                       | 2,000 mg/L  |  |         |      |      |  |  |
| Aerobic Sludge Retention Time                               | ASRT             | day                   | HRT/24×X <sub>a</sub> / (a×S-BOD <sub>in</sub> + b×SS <sub>in</sub> - c×HRT/24×X <sub>a</sub> ) = |  | 4.738   |      |      |  |  |
| S-BOD <sub>ir</sub> : Inflow S-BOD Concentration            |                  |                       | 80 mg/L   | (S-BOD[Solved BOD]=BOD <sub>in</sub> ×0.6) |         |      |      |  |  |
| SS <sub>in</sub> : Inflow SS Concentration                  |                  |                       | 90 mg/L   | (Removal Rate in PST : 50%)                |         |      |      |  |  |
| a : Sludge converting ratio of solved BOl                   |                  |                       | 0.5 mgMLSS/mgBOD  | (0.4~0.6)                                  |         |      |      |  |  |
| b : Sludge converting ratio of SS                           |                  |                       | 0.95 mgMLSS/mgSS  | (0.9~1.0)                                  |         |      |      |  |  |
| c : Sludge reduction ratio caused by endogenous respiration |                  |                       | 0.04 (1/day)  | (0.03~0.05)                                |         |      |      |  |  |
| Effluent Quality (C-BOD)                                    | EQ               | mg/L                  | 10.42×A-SRT <sup>(-0.519)</sup> (15~20°C)   |  | 4.648   |      |      |  |  |
| Water Temperature   |                  |                       | 20 °C   |  |         |      |      |  |  |
| Effluent Water Quality (C=BOD Maximum)                      |                  |                       | EQ×3  | 20mg/l >                                   | 14      |      |      |  |  |
|   |                  |                       |   |  | -OK-    |      |      |  |  |
|   |                  |                       | 1 : 1.5 : 1.5 : 2.25  |  |         |      |      |  |  |
| Partition of Aeration Tank                                  |                  |                       | <table><tr><td>Nn 1</td><td>Nn 2</td><td>Nn 3</td><td>Nn 4</td></tr></table>                      | Nn 1                                       | Nn 2    | Nn 3 | Nn 4 |  |  |
| Nn 1  | Nn 2             | Nn 3                  | Nn 4  |  |         |      |      |  |  |
|   |                  |                       |   |  |         |      |      |  |  |
| Total Length of Tank  | TL               | m                     |   |  | 73.0    |      |      |  |  |
| No.1 Tank Length  | L1               | m                     | TL×1/(1+1.5+1.5+2.25)   |  | 11.7    |      |      |  |  |
| No.2 Tank Length  | L2               | m                     | TL×1.5/(1+1.5+1.5+2.25)   |  | 17.5    |      |      |  |  |
| No.3 Tank Length  | L3               | m                     | TL×1.5/(1+1.5+1.5+2.25)   |  | 17.5    |      |      |  |  |
| No.4 Tank Length  | L4               | m                     | TL×2.25/(1+1.5+1.5+2.25)  |  | 26.3    |      |      |  |  |
|   |                  |                       | Total   |  | 73.0    |      |      |  |  |
|   |                  |                       |   |  |         |      |      |  |  |



**Table I.3 Design Calculation of W1 WWTP (8/11)**

**2-6 Disinfection Channel**

| Item                         | Sign | Unit                | Calculation   | F/S | M/P         |
|------------------------------|------|---------------------|---------------|-----|-------------|
| Type                         | -    | -                   | Chlorination  |     |             |
| Design Sewage Flow           | Q1   | m <sup>3</sup> /day |               |     | 184,000     |
| (Maximum Daily Flow)         | Q2   | m <sup>3</sup> /min |               |     | 127.8       |
| Retention(Chlorination) Time | RT   | min                 |               |     | 15.0        |
| Required Volume              | RV   | m <sup>3</sup>      | Q2×RT         |     | 1,917       |
| Width of channel             | W    | m                   |               |     | 2.5         |
| Depth of channel             | H    | m                   |               |     | 3.0         |
| Pass Number                  | PN   | pass                |               |     | 4           |
| Length of channel            | L1   | m/pass              | RV/(W×H×PN)   |     | 63.9        |
| <i>Therefore</i>             | L2   | m/pass              |               |     | 64.0        |
| <b>Dimension (Width)</b>     | W    | m                   |               |     | <b>2.5</b>  |
| <b>(Depth)</b>               | H    | m                   |               |     | <b>3.0</b>  |
| <b>(Length)</b>              | L    | m/pass              |               |     | <b>64.0</b> |
| <b>(Pass Number)</b>         | N    | pass                |               |     | <b>4</b>    |
| <b>(Check)</b>               |      |                     |               |     |             |
| Retention(Chlorination) Time | RT   | min                 | (W×H×L×PN)/Q2 |     | 15.0        |

**2-7 Sludge Thickening Tank**

| Item                        | Sign | Unit                   | Calculation                                     | F/S | M/P         |
|-----------------------------|------|------------------------|---|-----|-------------|
| Type                        | -    | -                      | Gravity Thickener (Radial Flow Circular Type)   |     |             |
| Generated Sludge Solids     | GS   | t-DS/day               | Refer to Mass Balance Cal.                      |     | 34.298      |
| Generated Sludge Volume     | GSV  | m <sup>3</sup> /day    | Refer to Mass Balance Cal.                      |     | 4,319       |
| Solid Matter Load           | SML  | kg/m <sup>2</sup> /day |   |     | 75          |
| Required Surface Area       | SA   | m <sup>2</sup>         | (GS×10 <sup>3</sup> )/SML                       |     | 457.3       |
| Water Depth                 | H    | m                      |   |     | 4.0         |
| Basin Number                | BN   | basin                  |   |     | 4           |
| Required Tank Diameter      | TD1  | m                      | (SA×4/(3.14×BN)) <sup>0.5</sup>                 |     | 12.07       |
| <i>Therefore</i>            | TD2  | m                      |   |     | 12.0        |
| <b>Dimension (Diameter)</b> | D    | m/basin                |   |     | <b>12.0</b> |
| <b>(Depth)</b>              | H    | m                      |   |     | <b>4.0</b>  |
| <b>(Basin Number)</b>       | BN   | basin                  |   |     | <b>4</b>    |
| <b>(Check)</b>              |      |                        |   |     |             |
| Solid Matter Load           | SML  | kg/m <sup>2</sup> /day | GS×10 <sup>3</sup> /(3.14×D <sup>2</sup> /4)×BN |     | 75.9        |
| Sludge Thickened Time       | T    | hr                     | (3.14×D <sup>2</sup> /4)×H×BN×24/GSV            |     | 10.1        |
|                             |      |                        |   |     |             |
|                             |      |                        |   |     |             |
|                             |      |                        |   |     |             |
|                             |      |                        |   |     |             |
|                             |      |                        |   |     |             |





**Table I.3 Design Calculation of W1 WWTP (10/11)**

**Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Mechanical Dewatering)**

**Table-1 Input Data**

|  |          |  |
|--|----------|--|
| 1. Calculation Manner                        |          | 1: Premise that the quality of supernatants are same level removed with inlet sewage<br>2: Premise that the entire supernatants are removed at treatment process |
| 2. Selection of Treatment Efficiency         |          | 1: Total Removal Ratio 2: Outlet Water Quality (input 1 or 2)  |
| In case of 1: input data                     |          | 90 (%)   |
| In case of 2: input data                     |          | (mg/l)   |
| 3. Excess Sludge Generation                  |          | 1: Consideration of Solid Matter Only 2: Consideration of Converting of Solved BOD (input 1 or 2)  |
| In case of 1: Input data (Sludge generation) |          | Sludge generation ratio per removal SS (%)   |
| In case of 2: Input data                     | a        | $T2 = Q2 \cdot S2 = (a \cdot S_{acc} + b \cdot S1 - c \cdot \theta \cdot XA) \cdot Q1 \cdot 10^{-6}$ (Excess sludge generation formula)                          |
|  | b        | a: Converting ratio of solved BOD (mg/MLSS: mgBOD)   |
|  | c        | b: Converting ratio of SS (mg/MLSS: mgSS)  |
|  | XA       | c: Sludge reduction ratio caused by endogenous respiration of activated sludge (1/day)   |
|  | $\theta$ | S <sub>acc</sub> : Solved BOD quality at inlet to reactor<br>XA: MLSS concentration (mg/l)<br>$\theta$ : Hydraulic retention time (day)                          |


**Table-2 Basic Conditions**

| Water Flow and Quality                          |        | Sludge Moisture and Recovery Ratio       |      | Chemical Conditions for Dewatering          |      |
|---|--------|--|------|---|------|
| *Inlet flow: Q0 (m³/D)                          | 184000 | *Primary sludge moisture ratio: W1 (%)   | 98.5 | *Removal ratio in primary tank: A2 (%)      | 50.0 |
| *Inlet quality: S0 (mg/l)                       | 180    | *Excess sludge moisture ratio: W2 (%)    | 99.5 | *Recovery ratio in sludge thickener: A3 (%) | 90.0 |
| *Total removal ratio: A1 (%)                    | 90.0   | *Thickened sludge moisture ratio: W3 (%) | 98.0 | *Recovery ratio in dewatering: A4 (%)       | 95.0 |
| *Effluent quality: S1 (mg/l)                    | -      | *Dewatered sludge moisture ratio: W4 (%) | 80.0 |   |      |
| *Sludge generation ratio per removal SS: S1 (%) | 100.0  |  |      |   |      |

**Table-3 Material Balance Calculation**

|              | 0       | 1       | 2      | 3       | 4      | 5       | 6      | 7     | 8     | 9      | 10      | 11    | 12    |  | 5-1     |
|--------------|---------|---------|--------|---------|--------|---------|--------|-------|-------|--------|---------|-------|-------|--|---------|
| Q (m³/day)   | 184,000 | 188,325 | 1,270  | 187,055 | 3,049  | 184,006 | 1,543  | 2,776 | 154   | 1,698  | 148     | 1,550 | 4,325 |  | 183,852 |
| T (t·DS/day) | 33,120  | 38,109  | 19,054 | 19,054  | 15,243 | 3,811   | 30,868 | 3,430 | 0,309 | 31,177 | 29,618  | 1,559 | 4,989 |  | 3,502   |
| S (mg/l)     | 180     | 202     | 15,000 | 102     | 5,000  | 21      | 20,000 | 1,236 | 2,000 | 18,364 | 200,000 | 1,006 | 1,153 |  | 21      |
| X (t/TQ*100) | 100     | 115.1   | 57.5   | 57.5    | 46.0   | 11.5    | 93.2   | 10.4  | 0.9   | 94.1   | 89.4    | 4.7   | 15.1  |  | 10.6    |


**Figure-1 Material Balance Model**



| Calculation Formula   |   |  |  |  |                                       |
|---|---|--|--|--|---------------------------------------|
| *Q0=Input Data<br>*T0=Q0*S0*10 <sup>-6</sup> (-6)<br>*S0=Input Data       | *Q3=Q1-Q2<br>*T3=T1*(100-A2)/100<br>*S3=T3*10 <sup>-6</sup> /Q3                         | *Q6=T4*100/(100-W3)<br>*T6=(T2+T4)*A3/100<br>*S6=10 <sup>-6</sup> *Q6*(100-W3)/100 | *Q9=Q6-Q8<br>*T9=T6-T8<br>*S9=T9*10 <sup>-6</sup> /Q9                              | *Q12=Q7+Q11<br>*T12=T7+T11<br>*S11=T11*10 <sup>-6</sup> /Q11 | *Q5=Q5-Q8<br>*T5=Q5-T5-T8<br>*S5=1=S5 |
| *Q1=Q0-Q13<br>*T1=T0-T13<br>*S1=T1*10 <sup>-6</sup> /Q1                   | *Q4=T4*100/(100-W2)<br>*T4=((T1-T5)*S1/100)-T2<br>*S4=10 <sup>-6</sup> *Q4*(100-W2)/100 | *Q7=(Q3-Q4)-Q8<br>*T7=(T2+T4)-T6<br>*S7=T7*10 <sup>-6</sup> /Q7                    | *Q10=T10*100/(100-W4)<br>*T10=T9*A4/100<br>*S10=10 <sup>-6</sup> *Q10*(100-W4)/100 |  |                                       |
| *Q8=T2*100/(100-W1)<br>*T2=T1-T3<br>*S2=10 <sup>-6</sup> *Q8*(100-W1)/100 | *Q5=Q3-Q4*(T3-T5)/T4<br>*T5=T1*(100-A1)/100<br>*S5=T5*10 <sup>-6</sup> /Q5              | *Q8=T6*A5/A6<br>*T8=Q8*S8*10 <sup>-6</sup><br>*S8=10 <sup>-4</sup> *A6             | *Q11=Q9-Q10<br>*T11=T9-T10<br>*S11=T11*10 <sup>-6</sup> /Q11                       |  |                                       |

Table I.3 Design Calculation of W1 WWTP (11/11)

Material Balance Sheet



**Table I.4 Design Calculation of W2 WWTP (1/11)**

## **1 BASIC CONDITIONS**

### **1-1 Basic Items**

- (1) Name : **W2 WWTP**
- (2) Land Area : Approximately      xxxx      ha
- (3) Ground Level (Elevation) : +      4.50      m (Plan)
- (4) Inlet Pipe Invert Level : -      6.54      m
- (5) Pipe Diameter :      1,800      mm
- (6) Land Use :      —
- (7) Collection System : ~~Combined System~~      **Separate System**
- (8) Treatment Process : Conventional Activated Sludge Process
- (9) Effluent Point : Hlaing River
- (10) Water Level at the Effluent Point :
- High water level =      3.70      m
- Low water level =      —      m
- (11) Target Year :      2020 (F/S Stage)
- 2040 (M/P Stage)

### **1-2 Service Area and Design Population**

- (1) Service Area :      2,356      ha

- (2) Design Population

| Item              |        | Year 2020 | Year 2040 |
|-------------------|--------|-----------|-----------|
| Design Population | person | -         | 349,500   |

**Table I.4 Design Calculation of W2 WWTP (2/11)**

**1-3 Design Sewage Flow**

**(Year 2020)**

| Item                | m <sup>3</sup> /day | m <sup>3</sup> /hr | m <sup>3</sup> /min | m <sup>3</sup> /sec |
|---------------------|---------------------|--------------------|---------------------|---------------------|
| Maximum Daily Flow  |                     | 0.0                | 0.00                | 0.000               |
| Maximum Hourly Flow | 0                   | 0.0                | 0.00                | 0.000               |


**(Year 2040)**

| Item                | m <sup>3</sup> /day | m <sup>3</sup> /hr | m <sup>3</sup> /min | m <sup>3</sup> /sec |
|---------------------|---------------------|--------------------|---------------------|---------------------|
| Maximum Daily Flow  | 126,000             | 5,250.0            | 87.50               | 1.458               |
| Maximum Hourly Flow | 189,000             | 7,875.0            | 131.25              | 2.188               |

**1-4 Design Sewage Quality**

| Item     | BOD<br>(mg/l) | SS<br>(mg/l) | T-N<br>(mg/l) | Coli-group<br>(MPN/cm <sup>3</sup> ) | Oil&Grease<br>(mg/l) |
|----------|---------------|--------------|---------------|--------------------------------------|----------------------|
| Influent | 200           | 180          | -             | -                                    | -                    |
| Effluent | 20            | 30           | -             | 3,000                                | 5                    |

**1-5 Process Flow Diagram**



**Table I.4 Design Calculation of W2 WWTP (3/11)**

**1.6 Design Criteria**

| ITEMS  | UNIT                                | Formula or Value | Application |
|--|-------------------------------------|------------------|-------------|
| <b>1 Grit Chamber (For Maximum Hourly Flow)</b>              |                                     |                  |             |
| (1) Hydraulic Load   | m <sup>3</sup> /m <sup>2</sup> /day | 1,800            | 1,800       |
| (2) Average Velocity   | m/sec                               | 0.3              | 0.3         |
| <b>2 Primary Sedimentation Tank (For Maximum Daily Flow)</b> |                                     |                  |             |
| (1) Hydraulic Load   | m <sup>3</sup> /m <sup>2</sup> /day | 35.0-70.0        | 50          |
| (2) Settling Time (Ref.)                                     | hour                                | 1.5              | 1.5         |
| (3) Water Depth  | m                                   | 2.5-4.0          | 3.5         |
| (4) Weir Loading   | m <sup>3</sup> /m/day               | 250              | 250         |
| <b>3 Aeration Tank (For Maximum Daily Flow)</b>              |                                     |                  |             |
| (1) Hydraulic Retention Time (HRT)                           | hour                                | 6 - 8            | 6.0         |
| (2) MLSS Concentration                                       | mg/l                                | 1,500 -2,000     | 2,000       |
| (3) BOD-SS Load (Reference only)                             | kg/kg/day                           | 0.2 - 0.4        | -           |
| <b>4 Final Sedimentation Tank (For Maximum Daily Flow)</b>   |                                     |                  |             |
| (1) Hydraulic Load   | m <sup>3</sup> /m <sup>2</sup> /day | 20.0-30.0        | 25          |
| (2) Settling Time (Ref.)                                     | hour                                | 3.0-4.0          | -           |
| (3) Water Depth  | m                                   | 2.5-4.0          | 3.5         |
| (4) Weir Loading   | m <sup>3</sup> /m/day               | 150              | 150         |
| <b>5 Disinfection Tank (For Maximum Daily Flow)</b>          |                                     |                  |             |
| (1) Retention (Chlorination) Time                            | min                                 | 15               | 15          |
| <b>6 Gravity Thickener (For Maximum Daily Flow)</b>          |                                     |                  |             |
| (1) Solids Loading   | kg/m <sup>2</sup> /day              | 60-90            | 75          |
| (2) Water Depth  | m                                   |                  | 4.0         |
|  |                                     |                  |             |

**Table I.4 Design Calculation of W2 WWTP (4/11)**

## 2 CAPACITY CALCULATION

### 2-1 Grit Chamber

| Item                     | Sign | Unit                                | Calculation        | F/S | M/P         |
|--------------------------|------|-------------------------------------|--------------------|-----|-------------|
| Type                     | -    | -                                   | Parallel Flow Type |     |             |
| Design Sewage Flow       | Q1   | m <sup>3</sup> /day                 |                    |     | 189,000     |
| (Maximum Hourly Flow)    | Q2   | m <sup>3</sup> /sec                 |                    |     | 2.188       |
| Water Surface Load       | WSL  | m <sup>3</sup> /m <sup>2</sup> /day |                    |     | 1,800       |
| Required Surface Area    | RSA  | m <sup>2</sup>                      | Q1/WSL             |     | 105.00      |
| Basin Number             | BN   | basin                               |                    |     | 4           |
| Average Velocity         | AV   | m/sec                               |                    |     | 0.3         |
| Depth                    | H    | m                                   |                    |     | 0.8         |
| Width                    | W1   | m                                   | Q2/(AV×H×BN)       |     | 2.28        |
| <i>Therefore</i>         | W2   | m                                   |                    |     | 2.5         |
| Length                   | L1   | m                                   | RSA/(W2×BN)        |     | 10.50       |
| <i>Therefore</i>         | L2   | m                                   |                    |     | 11.0        |
| <b>Dimension (Width)</b> | W    | m                                   |                    |     | <b>2.5</b>  |
| <b>(Depth)</b>           | L    | m                                   | L2                 |     | <b>11.0</b> |
| <b>(Length)</b>          | H    | m                                   | H                  |     | <b>0.8</b>  |
| <b>(Basin Number)</b>    | N    | basin                               |                    |     | <b>4</b>    |
| <b>(Check)</b>           |      |                                     |                    |     |             |
| Water Surface Load       |      | m <sup>3</sup> /m <sup>2</sup> /day | Q1/(W×L×N)         |     | 1,718       |
| Average Velocity         |      | m/sec                               | Q2/(W×H×N)         |     | 0.273       |
|                          |      |                                     |                    |     |             |

### 2-2 Lift Pump Station

| Item                        | Sign | Unit                | Calculation                                | F/S | M/P      |
|-----------------------------|------|---------------------|--|-----|----------|
| Type                        | -    | -                   | Vertical shaft Volute type mixed flow pump |     |          |
| Design Sewage Flow          | Q1   | m <sup>3</sup> /min | Peak Flow                                  |     | 131.25   |
|                             |      |                     |  |     |          |
| Pump Unit -1 Number         | UN1  | unit                |  |     | 2        |
| Discharge per Unit          | DU1  | m <sup>3</sup> /min | 1/10×Q1/UN1                                |     | 13.13    |
| Pump Diameter(V=1.5~3.0m/s) | D1   | mm                  | 146×(DU1/1.5~3.0) <sup>0.5</sup>           |     | 305 ~432 |
| <i>Therefore</i>            | D1   | mm                  |  |     | 350      |
|                             |      |                     |  |     |          |
| Pump Unit -2 Number         | UN2  | unit                |  |     | 2        |
| Discharge per Unit          | DU2  | m <sup>3</sup> /min | 2/10×Q1/UN2                                |     | 26.25    |
| Pump Diameter(V=1.5~3.0m/s) | D2   | mm                  | 146×(DU2/1.5~3.0) <sup>0.5</sup>           |     | 432 ~611 |
| <i>Therefore</i>            | D2   | mm                  |  |     | 500      |
|                             |      |                     |  |     |          |
| Pump Unit -3 Number         | UN3  | unit                | including 1 stand-by                       |     | 2        |
| Discharge per Unit          | DU3  | m <sup>3</sup> /min | 4/10×Q1/UN3                                |     | 52.50    |
| Pump Diameter(V=1.5~3.0m/s) | D3   | mm                  | 146×(DU3/1.5~3.0) <sup>0.5</sup>           |     | 611 ~864 |
| <i>Therefore</i>            | D3   | mm                  |  |     | 700      |



**Table I.4 Design Calculation of W2 WWTP (6/11)**

**2-4 Aeration Tank**

| Item  | Sign             | Unit                  | Calculation  | F/S                           | M/P     |      |      |  |  |
|---|------------------|-----------------------|--|-------------------------------|---------|------|------|--|--|
| Type  | -                | -                     | Multi-tank Complete mixing Type  |                               |         |      |      |  |  |
| Design Sewage Flow  | Q1               | m <sup>3</sup> /day   |  |                               | 126,000 |      |      |  |  |
| (Maximum Daily Flow)  | Q2               | m <sup>3</sup> /hr    |  |                               | 5,250.0 |      |      |  |  |
| Hydraulic Retention Time                                    | HRT              | hr                    |  |                               | 6.0     |      |      |  |  |
| Basin Number  | BN               | basin                 |  |                               | 8       |      |      |  |  |
| Required Volume per basin                                   | RV               | m <sup>3</sup> /basin | Q2×RT/BN   |                               | 3,938   |      |      |  |  |
| Width   | W                | m                     | 1~2H   |                               | 10.5    |      |      |  |  |
| Water Depth   | H                | m                     | 4.0m~6.0m  |                               | 6.0     |      |      |  |  |
| Length  | L1               | m                     | RV/(W×H)   |                               | 62.5    |      |      |  |  |
| Therefore   | L2               | m                     |  |                               | 63.0    |      |      |  |  |
| Dimension (Width)   | W                | m                     |  |                               | 10.5    |      |      |  |  |
| (Depth)   | H                | m                     |  |                               | 6.0     |      |      |  |  |
| (Length)  | L                | m                     |  |                               | 63.0    |      |      |  |  |
| (Basin Number)  | N                | basin                 |  |                               | 8       |      |      |  |  |
|   |                  |                       |  |                               |         |      |      |  |  |
| (Check)   |                  |                       |  |                               |         |      |      |  |  |
| Hydraulic Retention Time                                    | HRT              | hour                  | W×H×L×N/Q2   |                               | 6.0     |      |      |  |  |
| BOD-SS load   | BSS <sub>L</sub> | kgBOD/kgSS/d          | (Q1×BODin)/(W×H×L×N×Xa)  |                               | 0.24    |      |      |  |  |
| BOD <sub>in</sub> : Inflow BOD Concentration                |                  |                       | 120 mg/L   | (Removal Rate in PST : 40%)   |         |      |      |  |  |
| Xa : MLSS Concentration                                     |                  |                       | 2,000 mg/L   |                               |         |      |      |  |  |
| Aerobic Sludge Retention Time                               | ASRT             | day                   | HRT/24×Xa / (a×S-BODin + b×SSin - c×HRT/24×Xa) =                             |                               | 4.785   |      |      |  |  |
| S-BOD <sub>ir</sub> : Inflow S-BOD Concentration            |                  |                       | 80 mg/L  | (S-BOD[Solved BOD]=BODin×0.6) |         |      |      |  |  |
| SS <sub>in</sub> : Inflow SS Concentration                  |                  |                       | 90 mg/L  | (Removal Rate in PST : 50%)   |         |      |      |  |  |
| a : Sludge converting ratio of solved BOI                   |                  |                       | 0.5 mgMLSS/mgBOD   | (0.4~0.6)                     |         |      |      |  |  |
| b : Sludge converting ratio of SS                           |                  |                       | 0.95 mgMLSS/mgSS   | (0.9~1.0)                     |         |      |      |  |  |
| c : Sludge reduction ratio caused by endogenous respiration |                  |                       | 0.04 (1/day)   | (0.03~0.05)                   |         |      |      |  |  |
| Effluent Quality (C-BOD)                                    | EQ               | mg/L                  | 10.42×A-SRT <sup>(-0.519)</sup> (15~20°C)                                    |                               | 4.624   |      |      |  |  |
| Water Temperature   |                  |                       | 20 °C  |                               |         |      |      |  |  |
| Effluent Water Quality (C=BOD Maximum)                      |                  |                       | EQ×3   | 20mg/l >                      | 14      |      |      |  |  |
|   |                  |                       |  |                               | -OK-    |      |      |  |  |
|   |                  |                       | 1 : 1.5 : 1.5 : 2.25   |                               |         |      |      |  |  |
| Partition of Aeration Tank                                  |                  |                       | <table><tr><td>No.1</td><td>No.2</td><td>No.3</td><td>No.4</td></tr></table> | No.1                          | No.2    | No.3 | No.4 |  |  |
| No.1  | No.2             | No.3                  | No.4   |                               |         |      |      |  |  |
| Total Length of Tank  | TL               | m                     |  |                               | 63.0    |      |      |  |  |
| No.1 Tank Length  | L1               | m                     | TL×1/(1+1.5+1.5+2.25)  |                               | 10.1    |      |      |  |  |
| No.2 Tank Length  | L2               | m                     | TL×1.5/(1+1.5+1.5+2.25)  |                               | 15.1    |      |      |  |  |
| No.3 Tank Length  | L3               | m                     | TL×1.5/(1+1.5+1.5+2.25)  |                               | 15.1    |      |      |  |  |
| No.4 Tank Length  | L4               | m                     | TL×2.25/(1+1.5+1.5+2.25)   |                               | 22.7    |      |      |  |  |
|   |                  |                       | Total  |                               | 63.0    |      |      |  |  |
|   |                  |                       |  |                               |         |      |      |  |  |





**Table I.4 Design Calculation of W2 WWTP (8/11)**

**2-6 Disinfection Channel**

| Item                         | Sign | Unit                | Calculation   | F/S | M/P         |
|------------------------------|------|---------------------|---------------|-----|-------------|
| Type                         | -    | -                   | Chlorination  |     |             |
| Design Sewage Flow           | Q1   | m <sup>3</sup> /day |               |     | 126,000     |
| (Maximum Daily Flow)         | Q2   | m <sup>3</sup> /min |               |     | 87.5        |
| Retention(Chlorination) Time | RT   | min                 |               |     | 15.0        |
| Required Volume              | RV   | m <sup>3</sup>      | Q2×RT         |     | 1,313       |
| Width of channel             | W    | m                   |               |     | 2.0         |
| Depth of channel             | H    | m                   |               |     | 2.5         |
| Pass Number                  | PN   | pass                |               |     | 8           |
| Length of channel            | L1   | m/pass              | RV/(W×H×PN)   |     | 32.8        |
| <i>Therefore</i>             | L2   | m/pass              |               |     | 33.0        |
| <b>Dimension (Width)</b>     | W    | m                   |               |     | <b>2.0</b>  |
| <b>(Depth)</b>               | H    | m                   |               |     | <b>2.5</b>  |
| <b>(Length)</b>              | L    | m/pass              |               |     | <b>33.0</b> |
| <b>(Pass Number)</b>         | N    | pass                |               |     | <b>8</b>    |
| <b>(Check)</b>               |      |                     |               |     |             |
| Retention(Chlorination) Time | RT   | min                 | (W×H×L×PN)/Q2 |     | 15.1        |

**2-7 Sludge Thickening Tank**

| Item                        | Sign | Unit                   | Calculation                                     | F/S | M/P         |
|-----------------------------|------|------------------------|---|-----|-------------|
| Type                        | -    | -                      | Gravity Thickener (Radial Flow Circular Type)   |     |             |
| Generated Sludge Solids     | GS   | t-DS/day               | Refer to Mass Balance Cal.                      |     | 23.487      |
| Generated Sludge Volume     | GSV  | m <sup>3</sup> /day    | Refer to Mass Balance Cal.                      |     | 2,958       |
| Solid Matter Load           | SML  | kg/m <sup>2</sup> /day |   |     | 75          |
| Required Surface Area       | SA   | m <sup>2</sup>         | (GS×10 <sup>3</sup> )/SML                       |     | 313.2       |
| Water Depth                 | H    | m                      |   |     | 4.0         |
| Basin Number                | BN   | basin                  |   |     | 4           |
| Required Tank Diameter      | TD1  | m                      | (SA×4/(3.14×BN)) <sup>0.5</sup>                 |     | 9.99        |
| <i>Therefore</i>            | TD2  | m                      |   |     | 10.0        |
| <b>Dimension (Diameter)</b> | D    | m/basin                |   |     | <b>10.0</b> |
| <b>(Depth)</b>              | H    | m                      |   |     | <b>4.0</b>  |
| <b>(Basin Number)</b>       | BN   | basin                  |   |     | <b>4</b>    |
| <b>(Check)</b>              |      |                        |   |     |             |
| Solid Matter Load           | SML  | kg/m <sup>2</sup> /day | GS×10 <sup>3</sup> /(3.14×D <sup>2</sup> /4)×BN |     | 74.8        |
| Sludge Thickened Time       | T    | hr                     | (3.14×D <sup>2</sup> /4)×H×BN×24/GSV            |     | 10.2        |
|                             |      |                        |   |     |             |
|                             |      |                        |   |     |             |
|                             |      |                        |   |     |             |
|                             |      |                        |   |     |             |
|                             |      |                        |   |     |             |

**Table I.4 Design Calculation of W2 WWTP (9/11)**

## 2-8 Sludge Dewatering

[illegible]

**Table I.4 Design Calculation of W2 WWTP (10/11)**

**Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Mechanical Dewatering)**

**Table-1 Input Data**

|  |          |  |
|--|----------|--|
| 1. Calculation Manner                        |          | 1. Premise that the quality of supernatants are same level removed with inlet sewage<br>2. Premise that the entire supernatants are removed at treatment process |
| 2. Selection of Treatment Efficiency         |          | 1. Total Removal Ratio 2. Outlet Water Quality (input 1or2)  |
| In case of 1 : input data                    | 90       | (%)  |
| In case of 2 : input data                    |          | (mg/l)   |
| 3. Excess Sludge Generation                  |          | 1. Consideration of Solid Matter Only 2. Consideration of Converting of Solved BOD (input 1or2)  |
| In case of 1: input data (Sludge generation) | 100      | Sludge generation ratio per removal SS (%)   |
|  | a        | $T2=Q2 \cdot S2=(a \cdot S_{BOD}+b \cdot S1 \cdot c \cdot \theta \cdot XA) \cdot Q1/10^6$ (Excess sludge generation formula)                                     |
|  | b        | a: Converting ratio of solved BOD (mg/MLSS mgBOD)  |
|  | c        | b: Converting ratio of SS (mg/MLSS mgSS)   |
|  | SBOD     | c: Sludge reduction ratio caused by endogenous respiration of activated sludge (1/day)   |
|  | XA       | $S_{BOD}$ : Solved BOD quality at inlet to reactor   |
|  | $\theta$ | XA: MLSS concentration (mg/l)  |
|  |          | $\theta$ : Hydraulic retention time (day)  |


**Table-2 Basic Conditions**

| Water Flow and Quality                          |        | Sludge Moisture and Recovery Ratio       |      | Chemical Conditions for Dewatering          |      |
|---|--------|--|------|---|------|
| *Inlet flow : Q0(m <sup>3</sup> /D)             | 126000 | *Primary sludge moisture ratio : W1(%)   | 98.9 | *Removal ratio in primary tank : A2(%)      | 50.0 |
| *Inlet quality : S0(mg/l)                       | 180    | *Excess sludge moisture ratio : W2(%)    | 99.5 | *Recovery ratio in sludge thickener : A3(%) | 90.0 |
| *Total removal ratio : A1(%)                    | 90.0   | *Thickened sludge moisture ratio : W3(%) | 98.0 | *Recovery ratio in dewatering : A4(%)       | 95.0 |
| *Effluent quality : S6(mg/l)                    | -      | *Dewatered sludge moisture ratio : W4(%) | 80.0 |   |      |
| *Sludge generation ratio per removal SS : S1(%) | 100.0  |  |      |   |      |

**Table-3 Material Balance Calculation**

|                        | 0       | 1       | 2      | 3       | 4      | 5       | 6      | 7     | 8     | 9      | 10      | 11    | 12    |  |  | 5-1     |  |
|------------------------|---------|---------|--------|---------|--------|---------|--------|-------|-------|--------|---------|-------|-------|--|--|---------|--|
| Q(m <sup>3</sup> /day) | 126,000 | 128,960 | 870    | 128,092 | 2,083  | 126,004 | 1,057  | 1,901 | 106   | 1,163  | 101     | 1,061 | 2,962 |  |  | 125,899 |  |
| T (t·DS/day)           | 22,680  | 26,096  | 13,048 | 13,048  | 10,438 | 2,610   | 21,138 | 2,349 | 0,211 | 21,349 | 20,282  | 1,067 | 3,416 |  |  | 2,398   |  |
| S(mg/l)                | 180     | 200     | 15,000 | 100     | 5,000  | 21      | 20,000 | 1,216 | 2,000 | 18,364 | 200,000 | 1,006 | 1,153 |  |  | 21      |  |
| X(R/100)               | 100     | 115.1   | 57.5   | 57.5    | 46.0   | 11.5    | 93.2   | 10.4  | 0.9   | 94.1   | 89.4    | 4.7   | 15.1  |  |  | 10.6    |  |


**Figure-1. Material Balance Model**



| Calculation Formula                  |                                      |                                      |  |                               |             |
|--------------------------------------|--------------------------------------|--------------------------------------|--|-------------------------------|-------------|
| *Q0=Input Data                       | *Q3=Q1-Q2                            | *Q6=T4*100/(100-W3)                  | *Q9=Q6-Q8                              | *Q12=Q7-Q11                   | *Q5-1=Q5-Q8 |
| *T0=Q0*S0*10 <sup>-6</sup> (t·DS/D)  | *T3=T1*(100-A2)/100                  | *T6=(T2-T4)*A3/100                   | *T9=T6-T8                              | *T12=T7-T11                   | *T5-1=T5-T8 |
| *S0=Input Data                       | *S3=T3*10 <sup>-6</sup> Q3           | *S6=10 <sup>-6</sup> Q6*(100-W3)/100 | *S9=T9*10 <sup>-6</sup> Q9             | *S11=T11*10 <sup>-6</sup> Q11 | *S5-1=S5    |
| *Q1=Q0-Q13                           | *Q4=T4*100/(100-W2)                  | *Q7=(Q3-Q4)-Q6                       | *Q10=T10*100/(100-W4)                  |                               |             |
| *T1=T0-T13                           | *T4=(T1-T3)*S1/100-T2                | *T7=(T2-T4)-T8                       | *T10=T9*A4/100                         |                               |             |
| *S1=T1*10 <sup>-6</sup> Q1           | *S4=10 <sup>-6</sup> Q4*(100-W2)/100 | *S7=T7*10 <sup>-6</sup> Q7           | *S10=10 <sup>-6</sup> Q10*(100-W4)/100 |                               |             |
| *Q2=T2*100/(100-W1)                  | *Q5=Q3-Q4-T3-T5-T4                   | *Q8=T8*A5/A6                         | *Q11=Q9-Q10                            |                               |             |
| *T2=T1-T3                            | *T5=T1*(100-A1)/100                  | *T8=Q8*S8/10 <sup>-6</sup>           | *T11=T9-T10                            |                               |             |
| *S2=10 <sup>-6</sup> Q2*(100-W1)/100 | *S5=T5*10 <sup>-6</sup> Q5           | *S8=10 <sup>-6</sup> A6              | *S11=T11*10 <sup>-6</sup> Q11          |                               |             |

Table I.4 Design Calculation of W2 WWTP (11/11)

**Material Balance Sheet**



**Table I.5 Design Calculation of E3 WWTP (1/11)**

## **1 BASIC CONDITIONS**

### **1-1 Basic Items**

- (1) Name : **E3 WWTP**
- (2) Land Area : Approximately      xxxx      ha
- (3) Ground Level (Elevation) : +      6.90      m (Plan)
- (4) Inlet Pipe Invert Level : -      10.82      m
- (5) Pipe Diameter :      2,400      mm
- (6) Land Use :      —
- (7) Collection System : ~~Combined System~~      **Separate System**
- (8) Treatment Process : Conventional Activated Sludge Process
- (9) Effluent Point : Ngamoeyeik Creek
- (10) Water Level at the Effluent Point :  
         High water level =      3.70      m  
         Low water level =      —      m
- (11) Target Year :      2020 (F/S Stage)  
                               2040 (M/P Stage)

### **1-2 Service Area and Design Population**

- (1) Service Area :      5,418      ha

- (2) Design Population

| Item              |        | Year 2020 | Year 2040 |
|-------------------|--------|-----------|-----------|
| Design Population | person | -         | 921,000   |

**Table I.5 Design Calculation of E3 WWTP (2/11)**

**1-3 Design Sewage Flow**

**(Year 2020)**

| Item                | m <sup>3</sup> /day | m <sup>3</sup> /hr | m <sup>3</sup> /min | m <sup>3</sup> /sec |
|---------------------|---------------------|--------------------|---------------------|---------------------|
| Maximum Daily Flow  |                     | 0.0                | 0.00                | 0.000               |
| Maximum Hourly Flow | 0                   | 0.0                | 0.00                | 0.000               |


**(Year 2040)**

| Item                | m <sup>3</sup> /day | m <sup>3</sup> /hr | m <sup>3</sup> /min | m <sup>3</sup> /sec |
|---------------------|---------------------|--------------------|---------------------|---------------------|
| Maximum Daily Flow  | 264,000             | 11,000.0           | 183.33              | 3.056               |
| Maximum Hourly Flow | 396,000             | 16,500.0           | 275.00              | 4.583               |

**1-4 Design Sewage Quality**

| Item     | BOD<br>(mg/l) | SS<br>(mg/l) | T-N<br>(mg/l) | Coli-group<br>(MPN/cm <sup>3</sup> ) | Oil&Grease<br>(mg/l) |
|----------|---------------|--------------|---------------|--------------------------------------|----------------------|
| Influent | 200           | 180          | -             | -                                    | -                    |
| Effluent | 20            | 30           | -             | 3,000                                | 5                    |

**1-5 Process Flow Diagram**



**Table I.5 Design Calculation of E3 WWTP (3/11)**

**1.6 Design Criteria**

| ITEMS  | UNIT                                | Formula or Value | Application |
|--|-------------------------------------|------------------|-------------|
| <b>1 Grit Chamber (For Maximum Hourly Flow)</b>              |                                     |                  |             |
| (1) Hydraulic Load   | m <sup>3</sup> /m <sup>2</sup> /day | 1,800            | 1,800       |
| (2) Average Velocity   | m/sec                               | 0.3              | 0.3         |
| <b>2 Primary Sedimentation Tank (For Maximum Daily Flow)</b> |                                     |                  |             |
| (1) Hydraulic Load   | m <sup>3</sup> /m <sup>2</sup> /day | 35.0-70.0        | 50          |
| (2) Settling Time (Ref.)                                     | hour                                | 1.5              | 1.5         |
| (3) Water Depth  | m                                   | 2.5-4.0          | 3.5         |
| (4) Weir Loading   | m <sup>3</sup> /m/day               | 250              | 250         |
| <b>3 Aeration Tank (For Maximum Daily Flow)</b>              |                                     |                  |             |
| (1) Hydraulic Retention Time (HRT)                           | hour                                | 6 - 8            | 6.0         |
| (2) MLSS Concentration                                       | mg/l                                | 1,500 -2,000     | 2,000       |
| (3) BOD-SS Load (Reference only)                             | kg/kg/day                           | 0.2 - 0.4        | -           |
| <b>4 Final Sedimentation Tank (For Maximum Daily Flow)</b>   |                                     |                  |             |
| (1) Hydraulic Load   | m <sup>3</sup> /m <sup>2</sup> /day | 20.0-30.0        | 25          |
| (2) Settling Time (Ref.)                                     | hour                                | 3.0-4.0          | -           |
| (3) Water Depth  | m                                   | 2.5-4.0          | 3.5         |
| (4) Weir Loading   | m <sup>3</sup> /m/day               | 150              | 150         |
| <b>5 Disinfection Tank (For Maximum Daily Flow)</b>          |                                     |                  |             |
| (1) Retention (Chlorination) Time                            | min                                 | 15               | 15          |
| <b>6 Gravity Thickener (For Maximum Daily Flow)</b>          |                                     |                  |             |
| (1) Solids Loading   | kg/m <sup>2</sup> /day              | 60-90            | 75          |
| (2) Water Depth  | m                                   |                  | 4.0         |
|  |                                     |                  |             |



**Table I.5 Design Calculation of E3 WWTP (4/11)**

## 2 CAPACITY CALCULATION

### 2-1 Grit Chamber

| Item                     | Sign | Unit                                | Calculation        | F/S | M/P         |
|--------------------------|------|-------------------------------------|--------------------|-----|-------------|
| Type                     | -    | -                                   | Parallel Flow Type |     |             |
| Design Sewage Flow       | Q1   | m <sup>3</sup> /day                 |                    |     | 396,000     |
| (Maximum Hourly Flow)    | Q2   | m <sup>3</sup> /sec                 |                    |     | 4.583       |
| Water Surface Load       | WSL  | m <sup>3</sup> /m <sup>2</sup> /day |                    |     | 1,800       |
| Required Surface Area    | RSA  | m <sup>2</sup>                      | Q1/WSL             |     | 220.00      |
| Basin Number             | BN   | basin                               |                    |     | 4           |
| Average Velocity         | AV   | m/sec                               |                    |     | 0.3         |
| Depth                    | H    | m                                   |                    |     | 1           |
| Width                    | W1   | m                                   | Q2/(AV×H×BN)       |     | 3.82        |
| <i>Therefore</i>         | W2   | m                                   |                    |     | 4.0         |
| Length                   | L1   | m                                   | RSA/(W2×BN)        |     | 13.75       |
| <i>Therefore</i>         | L2   | m                                   |                    |     | 14.0        |
| <b>Dimension (Width)</b> | W    | m                                   |                    |     | <b>4.0</b>  |
| <b>(Length)</b>          | L    | m                                   | L2                 |     | <b>14.0</b> |
| <b>(Depth)</b>           | H    | m                                   | H                  |     | <b>1.0</b>  |
| <b>(Basin Number)</b>    | N    | basin                               |                    |     | <b>4</b>    |
| <b>(Check)</b>           |      |                                     |                    |     |             |
| Water Surface Load       |      | m <sup>3</sup> /m <sup>2</sup> /day | Q1/(W×L×N)         |     | 1,768       |
| Average Velocity         |      | m/sec                               | Q2/(W×H×N)         |     | 0.286       |

### 2-2 Lift Pump Station

| Item                        | Sign | Unit                | Calculation                                | F/S | M/P       |
|-----------------------------|------|---------------------|--|-----|-----------|
| Type                        | -    | -                   | Vertical shaft Volute type mixed flow pump |     |           |
| Design Sewage Flow          | Q1   | m <sup>3</sup> /min | Peak Flow                                  |     | 275.00    |
| Pump Unit -1 Number         | UN1  | unit                |  |     | 2         |
| Discharge per Unit          | DU1  | m <sup>3</sup> /min | 1/10×Q1                                    |     | 27.50     |
| Pump Diameter(V=1.5~3.0m/s) | D1   | mm                  | 146×(DU1/1.5~3.0) <sup>0.5</sup>           |     | 442 ~625  |
| <i>Therefore</i>            | D1   | mm                  |  |     | 500       |
| Pump Unit -2 Number         | UN2  | unit                |  |     | 2         |
| Discharge per Unit          | DU2  | m <sup>3</sup> /min | 2/10×Q1                                    |     | 55.00     |
| Pump Diameter(V=1.5~3.0m/s) | D2   | mm                  | 146×(DU2/1.5~3.0) <sup>0.5</sup>           |     | 625 ~884  |
| <i>Therefore</i>            | D2   | mm                  |  |     | 700       |
| Pump Unit -3 Number         | UN3  | unit                | including 1 stand-by                       |     | 2         |
| Discharge per Unit          | DU3  | m <sup>3</sup> /min | 4/10×Q1                                    |     | 110.00    |
| Pump Diameter(V=1.5~3.0m/s) | D3   | mm                  | 146×(DU3/1.5~3.0) <sup>0.5</sup>           |     | 884 ##### |
| <i>Therefore</i>            | D3   | mm                  |  |     | 1000      |



**Table I.5 Design Calculation of E3 WWTP (6/11)**

**2-4 Aeration Tank**

| Item  | Sign             | Unit                  | Calculation   | F/S  | M/P      |      |      |  |  |
|---|------------------|-----------------------|---|--|----------|------|------|--|--|
| Type  | -                | -                     | Multi-tank Complete mixing Type   |  |          |      |      |  |  |
| Design Sewage Flow  | Q1               | m <sup>3</sup> /day   |   |  | 264,000  |      |      |  |  |
| (Maximum Daily Flow)  | Q2               | m <sup>3</sup> /hr    |   |  | 11,000.0 |      |      |  |  |
| Hydraulic Retention Time                                    | HRT              | hr                    |   |  | 6.0      |      |      |  |  |
| Basin Number  | BN               | basin                 |   |  | 8        |      |      |  |  |
| Required Volume per basin                                   | RV               | m <sup>3</sup> /basin | Q2×RT/BN  |  | 8,250    |      |      |  |  |
| Width   | W                | m                     | 1~2H  |  | 10.5     |      |      |  |  |
| Water Depth   | H                | m                     | Deep Aeration Tank  |  | 10.0     |      |      |  |  |
| Length  | L1               | m                     | RV/(W×H)  |  | 78.6     |      |      |  |  |
| Therefore   | L2               | m                     |   |  | 78.0     |      |      |  |  |
| Dimension (Width)   | W                | m                     |   |  | 10.5     |      |      |  |  |
| (Depth)   | H                | m                     |   |  | 10.0     |      |      |  |  |
| (Length)  | L                | m                     |   |  | 78.0     |      |      |  |  |
| (Basin Number)  | N                | basin                 |   |  | 8        |      |      |  |  |
|   |                  |                       |   |  |          |      |      |  |  |
| (Check)   |                  |                       |   |  |          |      |      |  |  |
| Hydraulic Retention Time                                    | HRT              | hour                  | W×H×L×N/Q2  |  | 6.0      |      |      |  |  |
| BOD-SS load   | BSS <sub>L</sub> | kgBOD/kgSS/d          | (Q1×BOD <sub>in</sub> )/(W×H×L×N×X <sub>a</sub> )   |  | 0.24     |      |      |  |  |
| BOD <sub>in</sub> : Inflow BOD Concentration                |                  |                       | 120 mg/L  | (Removal Rate in PST : 40%)                |          |      |      |  |  |
| X <sub>a</sub> : MLSS Concentration                         |                  |                       | 2,000 mg/L  |  |          |      |      |  |  |
| Aerobic Sludge Retention Time                               | ASRT             | day                   | HRT/24×X <sub>a</sub> / (a×S-BOD <sub>in</sub> + b×SS <sub>in</sub> - c×HRT/24×X <sub>a</sub> ) = |  |          |      |      |  |  |
|   |                  |                       |   |  | 4.698    |      |      |  |  |
| S-BOD <sub>ir</sub> : Inflow S-BOD Concentration            |                  |                       | 80 mg/L   | (S-BOD[Solved BOD]=BOD <sub>in</sub> ×0.6) |          |      |      |  |  |
| SS <sub>in</sub> : Inflow SS Concentration                  |                  |                       | 90 mg/L   | (Removal Rate in PST : 50%)                |          |      |      |  |  |
| a : Sludge converting ratio of solved BOl                   |                  |                       | 0.5 mgMLSS/mgBOD  | (0.4~0.6)                                  |          |      |      |  |  |
| b : Sludge converting ratio of SS                           |                  |                       | 0.95 mgMLSS/mgSS  | (0.9~1.0)                                  |          |      |      |  |  |
| c : Sludge reduction ratio caused by endogenous respiration |                  |                       | 0.04 (1/day)  | (0.03~0.05)                                |          |      |      |  |  |
| Effluent Quality (C-BOD)                                    | EQ               | mg/L                  | 10.42×A-SRT <sup>(-0.519)</sup> (15~20°C)   |  | 4.668    |      |      |  |  |
| Water Temperature   |                  |                       | 20 °C   |  |          |      |      |  |  |
| Effluent Water Quality (C=BOD Maximum)                      |                  |                       | EQ×3  | 20mg/l >                                   | 14       |      |      |  |  |
|   |                  |                       |   |  | -OK-     |      |      |  |  |
|   |                  |                       |   |  |          |      |      |  |  |
|   |                  |                       | 1 : 1.5 : 1.5 : 2.25  |  |          |      |      |  |  |
| Partition of Aeration Tank                                  |                  |                       | <table><tr><td>Nn 1</td><td>Nn 2</td><td>Nn 3</td><td>Nn 4</td></tr></table>                      | Nn 1                                       | Nn 2     | Nn 3 | Nn 4 |  |  |
| Nn 1  | Nn 2             | Nn 3                  | Nn 4  |  |          |      |      |  |  |
|   |                  |                       |   |  |          |      |      |  |  |
| Total Length of Tank  | TL               | m                     |   |  | 78.0     |      |      |  |  |
| No.1 Tank Length  | L1               | m                     | TL×1/(1+1.5+1.5+2.25)   |  | 12.5     |      |      |  |  |
| No.2 Tank Length  | L2               | m                     | TL×1.5/(1+1.5+1.5+2.25)   |  | 18.7     |      |      |  |  |
| No.3 Tank Length  | L3               | m                     | TL×1.5/(1+1.5+1.5+2.25)   |  | 18.7     |      |      |  |  |
| No.4 Tank Length  | L4               | m                     | TL×2.25/(1+1.5+1.5+2.25)  |  | 28.1     |      |      |  |  |
|   |                  |                       | Total   |  | 78.0     |      |      |  |  |
|   |                  |                       |   |  |          |      |      |  |  |



**Table I.5 Design Calculation of E3 WWTP (8/11)**

**2-6 Disinfection Channel**

| Item                         | Sign | Unit                | Calculation   | F/S | M/P         |
|------------------------------|------|---------------------|---------------|-----|-------------|
| Type                         | -    | -                   | Chlorination  |     |             |
| Design Sewage Flow           | Q1   | m <sup>3</sup> /day |               |     | 264,000     |
| (Maximum Daily Flow)         | Q2   | m <sup>3</sup> /min |               |     | 183.3       |
| Retention(Chlorination) Time | RT   | min                 |               |     | 15.0        |
| Required Volume              | RV   | m <sup>3</sup>      | Q2×RT         |     | 2,750       |
| Width of channel             | W    | m                   |               |     | 3.0         |
| Depth of channel             | H    | m                   |               |     | 3.0         |
| Pass Number                  | PN   | pass                |               |     | 8           |
| Length of channel            | L1   | m/pass              | RV/(W×H×PN)   |     | 38.2        |
| <i>Therefore</i>             | L2   | m/pass              |               |     | 38.5        |
| <b>Dimension (Width)</b>     | W    | m                   |               |     | <b>3.0</b>  |
| <b>(Depth)</b>               | H    | m                   |               |     | <b>3.0</b>  |
| <b>(Length)</b>              | L    | m/pass              |               |     | <b>38.5</b> |
| <b>(Pass Number)</b>         | N    | pass                |               |     | <b>8</b>    |
| <b>(Check)</b>               |      |                     |               |     |             |
| Retention(Chlorination) Time | RT   | min                 | (W×H×L×PN)/Q2 |     | 15.1        |

**2-7 Sludge Thickening Tank**

| Item                        | Sign | Unit                   | Calculation                                     | F/S | M/P         |
|-----------------------------|------|------------------------|---|-----|-------------|
| Type                        | -    | -                      | Gravity Thickener (Radial Flow Circular Type)   |     |             |
| Generated Sludge Solids     | GS   | t-DS/day               | Refer to Mass Balance Cal.                      |     | 49.21       |
| Generated Sludge Volume     | GSV  | m <sup>3</sup> /day    | Refer to Mass Balance Cal.                      |     | 6,197       |
| Solid Matter Load           | SML  | kg/m <sup>2</sup> /day |   |     | 75          |
| Required Surface Area       | SA   | m <sup>2</sup>         | (GS×10 <sup>3</sup> )/SML                       |     | 656.1       |
| Water Depth                 | H    | m                      |   |     | 4.0         |
| Basin Number                | BN   | basin                  |   |     | 4           |
| Required Tank Diameter      | TD1  | m                      | (SA×4/(3.14×BN)) <sup>0.5</sup>                 |     | 14.46       |
| <i>Therefore</i>            | TD2  | m                      |   |     | 15.0        |
| <b>Dimension (Diameter)</b> | D    | m/basin                |   |     | <b>15.0</b> |
| <b>(Depth)</b>              | H    | m                      |   |     | <b>4.0</b>  |
| <b>(Basin Number)</b>       | BN   | basin                  |   |     | <b>4</b>    |
| <b>(Check)</b>              |      |                        |   |     |             |
| Solid Matter Load           | SML  | kg/m <sup>2</sup> /day | GS×10 <sup>3</sup> /(3.14×D <sup>2</sup> /4)×BN |     | 69.7        |
| Sludge Thickened Time       | T    | hr                     | (3.14×D <sup>2</sup> /4)×H×BN×24/GSV            |     | 10.9        |
|                             |      |                        |   |     |             |
|                             |      |                        |   |     |             |
|                             |      |                        |   |     |             |
|                             |      |                        |   |     |             |
|                             |      |                        |   |     |             |



**Table I.5 Design Calculation of E3 WWTP (10/11)**

**Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Mechanical Dewatering)**

**Table-1 Input Data**

|  |          |  |
|--|----------|--|
| 1. Calculation on Manner                     |          | 1: Premise that the quality of supernatants are same level removed with inlet sewage   |
|  |          | 2: Premise that the entire supernatants are removed at treatment process   |
| 2. Selection of Treatment Efficiency         |          | 1: Total Removal Ratio 2: Outlet Water Quality (input 1or2)  |
| In case of 1: input data                     |          | (%)  |
| In case of 2: input data                     |          | (mg/l)   |
| 3. Excess Sludge Generation                  |          | 1: Consideration of Solid Matter Only 2: Consideration of Converting of Solved BOD (input 1or2)                                  |
| In case of 1: input data (Sludge generation) |          | 100  |
| In case of 2: input data                     | a        | $T2=Q2 \cdot S2=(a \cdot S_{acc}+b \cdot S1 \cdot c \cdot \theta \cdot XA) \cdot Q1/10^6$ (Excess sludge generation formula)     |
|  | b        | a: Converting ratio of solved BOD (mg/MLSS/mgBOD)  |
|  | c        | b: Converting ratio of SS (mg/MLSS/mgSS)   |
|  | XA       | c: Sludge reduction ratio caused by endogenous respiration of activated sludge (1/day)   |
|  | $\theta$ | $S_{acc}$ : Solved BOD quality at inlet to reactor<br>XA: MLSS concentration (mg/l)<br>$\theta$ : Hydraulic retention time (day) |


**Table 2 Basic Conditions**

| Water Flow and Quality                          |        | Sludge Moisture and Recovery Ratio       |      | Chemical Conditions for Dewatering          |      |
|---|--------|--|------|---|------|
| *Inlet flow: Q0 (m³/D)                          | 264000 | *Primary sludge moisture ratio: W1 (%)   | 98.5 | *Removal ratio in primary tank: A2 (%)      | 50.0 |
| *Inlet quality: S0 (mg/l)                       | 180    | *Excess sludge moisture ratio: W2 (%)    | 99.5 | *Recovery ratio in sludge thickener: A3 (%) | 90.0 |
| *Total removal ratio: A1 (%)                    | 90.0   | *Thickened sludge moisture ratio: W3 (%) | 98.0 | *Recovery ratio in dewatering: A4 (%)       | 95.0 |
| *Effluent quality: S1 (mg/l)                    | -      | *Dewatered sludge moisture ratio: W4 (%) | 80.0 |   |      |
| *Sludge generation ratio per removal SS: S1 (%) | 100.0  |  |      |   |      |

**Table-3 Material Balance Calculation**

|               | 0       | 1       | 2      | 3       | 4      | 5       | 6      | 7     | 8     | 9      | 10      | 11    | 12    |  | 5-1     |
|---------------|---------|---------|--------|---------|--------|---------|--------|-------|-------|--------|---------|-------|-------|--|---------|
| Q (m³/day)    | 264,000 | 270,206 | 1,823  | 268,383 | 4,374  | 264,009 | 2,214  | 3,982 | 221   | 2,436  | 212     | 2,223 | 6,206 |  | 263,788 |
| T (t·DS/day)  | 47,520  | 54,678  | 27,339 | 27,339  | 21,871 | 5,468   | 44,289 | 4,921 | 0,443 | 44,732 | 42,495  | 2,237 | 7,158 |  | 5,025   |
| S (mg/l)      | 180     | 202     | 15,000 | 102     | 5,000  | 21      | 20,000 | 1,236 | 2,000 | 18,364 | 200,000 | 1,006 | 1,153 |  | 21      |
| X (t/10³·100) | 100     | 115.1   | 57.5   | 57.5    | 46.0   | 11.5    | 93.2   | 10.4  | 0.9   | 94.1   | 89.4    | 4.7   | 15.1  |  | 10.6    |


**Figure-1 Material Balance Model**



| Calculation Formula   |                         |                       |                        |                   |             |
|-----------------------|-------------------------|-----------------------|------------------------|-------------------|-------------|
| *Q0=Input Data        | *Q3=Q1-Q2               | *Q6=T4*100/(100-W3)   | *Q9=Q6-Q8              | *Q12=Q7-Q11       | *Q5-1=Q5-Q8 |
| *T0=Q0*S0*10⁻⁶(-6)    | *T3=T1*(100-A2)/100     | *T6=(T2-T4)*A3/100    | *T9=T6-T8              | *T12=T7-T11       | *T5-1=T5-T8 |
| *S0=Input Data        | *S3=T3*10⁻⁶/Q3          | *S6=10⁻⁶*(100-W3)/100 | *S9=T9*10⁻⁶/Q9         | *S11=T11*10⁻⁶/Q11 | *S5-1=S5    |
| *Q1=Q0-Q13            | *Q4=T4*100/(100-W2)     | *Q7=(Q3-Q4)-Q6        | *Q10=T10*100/(100-W4)  |                   |             |
| *T1=T0-T13            | *T4=((T1-T5)*S1/100)-T2 | *T7=(T2-T4)-T5        | *T10=T9*A4/100         |                   |             |
| *S1=T1*10⁻⁶/Q1        | *S4=10⁻⁶*(100-W2)/100   | *S7=T7*10⁻⁶/Q7        | *S10=10⁻⁶*(100-W4)/100 |                   |             |
| *Q2=T2*100/(100-W1)   | *Q5=Q3-Q4*(T3-T5)/T4    | *Q8=T6*A5/A6          | *Q11=Q8-Q10            |                   |             |
| *T2=T1-T3             | *T5=T1*(100-A1)/100     | *T8=Q8*S8*10⁻⁶        | *T11=T9-T10            |                   |             |
| *S2=10⁻⁶*(100-W1)/100 | *S5=T5*10⁻⁶/Q5          | *S8=10⁻⁴*A6           | *S11=T11*10⁻⁶/Q11      |                   |             |

Table I.5 Design Calculation of E3 WWTP (10/11)

**Material Balance Sheet**





- |  |   |                                       |       |                        |
|--|---|---------------------------------------|-------|------------------------|
| (1) Name                               | : | <b>N1 WWTP</b>                        |       |                        |
| (2) Land Area                          | : | Approximately                         | xxxx  | ha                     |
| (3) Ground Level (Elevation)           | : | +                                     | 4.00  | m (Plan)               |
| (4) Inlet Pipe Invert Level            | : | -                                     | 5.82  | m                      |
| (5) Pipe Diameter                      | : |                                       | 1,650 | mm                     |
| (6) Land Use                           | : | —                                     |       |                        |
| (7) Collection System                  | : | <del>Combined System</del>            |       | <b>Separate System</b> |
| (8) Treatment Process                  | : | Conventional Activated Sludge Process |       |                        |
| (9) Effluent Point                     | : | Hlaing River                          |       |                        |
| (10) Water Level at the Effluent Point | : |                                       |       |                        |
|  |   | High water level =                    | 3.70  | m                      |
|  |   | Low water level =                     | —     | m                      |
| (11) Target Year                       | : | 2020 (F/S Stage)                      |       |                        |
|  |   | 2040 (M/P Stage)                      |       |                        |

- (1) Service Area : 3,163 ha
- (2) Design Population

| Item              |        | Year 2020 | Year 2040 |
|-------------------|--------|-----------|-----------|
| Design Population | person | -         | 377,200   |

**Table I.6 Design Calculation of N1 WWTP (2/11)**

**1-3 Design Sewage Flow**

**(Year 2020)**

| Item                | m <sup>3</sup> /day | m <sup>3</sup> /hr | m <sup>3</sup> /min | m <sup>3</sup> /sec |
|---------------------|---------------------|--------------------|---------------------|---------------------|
| Maximum Daily Flow  |                     | 0.0                | 0.00                | 0.000               |
| Maximum Hourly Flow | 0                   | 0.0                | 0.00                | 0.000               |


**(Year 2040)**

| Item                | m <sup>3</sup> /day | m <sup>3</sup> /hr | m <sup>3</sup> /min | m <sup>3</sup> /sec |
|---------------------|---------------------|--------------------|---------------------|---------------------|
| Maximum Daily Flow  | 140,000             | 5,833.3            | 97.22               | 1.620               |
| Maximum Hourly Flow | 210,000             | 8,750.0            | 145.83              | 2.431               |

**1-4 Design Sewage Quality**

| Item     | BOD    | SS     | T-N    | Coli-group             | Oil&Grease |
|----------|--------|--------|--------|------------------------|------------|
|          | (mg/l) | (mg/l) | (mg/l) | (MPN/cm <sup>3</sup> ) | (mg/l)     |
| Influent | 200    | 180    | -      | -                      | -          |
| Effluent | 20     | 30     | -      | 3,000                  | 5          |

**1-5 Process Flow Diagram**



**Table I.6 Design Calculation of N1 WWTP (3/11)**

**1.6 Design Criteria**

| ITEMS  | UNIT                                | Formula or Value | Application |
|--|-------------------------------------|------------------|-------------|
| <b>1 Grit Chamber (For Maximum Hourly Flow)</b>              |                                     |                  |             |
| (1) Hydraulic Load   | m <sup>3</sup> /m <sup>2</sup> /day | 1,800            | 1,800       |
| (2) Average Velocity   | m/sec                               | 0.3              | 0.3         |
| <b>2 Primary Sedimentation Tank (For Maximum Daily Flow)</b> |                                     |                  |             |
| (1) Hydraulic Load   | m <sup>3</sup> /m <sup>2</sup> /day | 35.0-70.0        | 50          |
| (2) Settling Time (Ref.)                                     | hour                                | 1.5              | 1.5         |
| (3) Water Depth  | m                                   | 2.5-4.0          | 3.5         |
| (4) Weir Loading   | m <sup>3</sup> /m/day               | 250              | 250         |
| <b>3 Aeration Tank (For Maximum Daily Flow)</b>              |                                     |                  |             |
| (1) Hydraulic Retention Time (HRT)                           | hour                                | 6 - 8            | 6.0         |
| (2) MLSS Concentration                                       | mg/l                                | 1,500 -2,000     | 2,000       |
| (3) BOD-SS Load (Reference only)                             | kg/kg/day                           | 0.2 - 0.4        | -           |
| <b>4 Final Sedimentation Tank (For Maximum Daily Flow)</b>   |                                     |                  |             |
| (1) Hydraulic Load   | m <sup>3</sup> /m <sup>2</sup> /day | 20.0-30.0        | 25          |
| (2) Settling Time (Ref.)                                     | hour                                | 3.0-4.0          | -           |
| (3) Water Depth  | m                                   | 2.5-4.0          | 3.5         |
| (4) Weir Loading   | m <sup>3</sup> /m/day               | 150              | 150         |
| <b>5 Disinfection Tank (For Maximum Daily Flow)</b>          |                                     |                  |             |
| (1) Retention (Chlorination) Time                            | min                                 | 15               | 15          |
| <b>6 Gravity Thickener (For Maximum Daily Flow)</b>          |                                     |                  |             |
| (1) Solids Loading   | kg/m <sup>2</sup> /day              | 60-90            | 75          |
| (2) Water Depth  | m                                   |                  | 4.0         |
|  |                                     |                  |             |

**Table I.6 Design Calculation of N1 WWTP (4/11)**

## 2 CAPACITY CALCULATION

### 2-1 Grit Chamber

| Item                     | Sign | Unit                                | Calculation        | F/S | M/P         |
|--------------------------|------|-------------------------------------|--------------------|-----|-------------|
| Type                     | -    | -                                   | Parallel Flow Type |     |             |
| Design Sewage Flow       | Q1   | m <sup>3</sup> /day                 |                    |     | 210,000     |
| (Maximum Hourly Flow)    | Q2   | m <sup>3</sup> /sec                 |                    |     | 2.431       |
| Water Surface Load       | WSL  | m <sup>3</sup> /m <sup>2</sup> /day |                    |     | 1,800       |
| Required Surface Area    | RSA  | m <sup>2</sup>                      | Q1/WSL             |     | 116.67      |
| Basin Number             | BN   | basin                               |                    |     | 4           |
| Average Velocity         | AV   | m/sec                               |                    |     | 0.3         |
| Depth                    | H    | m                                   |                    |     | 1           |
| Width                    | W1   | m                                   | Q2/(AV×H×BN)       |     | 2.03        |
| <i>Therefore</i>         | W2   | m                                   |                    |     | 2.5         |
| Length                   | L1   | m                                   | RSA/(W2×BN)        |     | 11.67       |
| <i>Therefore</i>         | L2   | m                                   |                    |     | 12.0        |
| <b>Dimension (Width)</b> | W    | m                                   |                    |     | <b>2.5</b>  |
| <b>(Depth)</b>           | L    | m                                   | L2                 |     | <b>12.0</b> |
| <b>(Length)</b>          | H    | m                                   | H                  |     | <b>1.0</b>  |
| <b>(Basin Number)</b>    | N    | basin                               |                    |     | <b>4</b>    |
| <b>(Check)</b>           |      |                                     |                    |     |             |
| Water Surface Load       |      | m <sup>3</sup> /m <sup>2</sup> /day | Q1/(W×L×N)         |     | 1,750       |
| Average Velocity         |      | m/sec                               | Q2/(W×H×N)         |     | 0.243       |

### 2-2 Lift Pump Station

| Item                        | Sign | Unit                | Calculation                                | F/S | M/P      |
|-----------------------------|------|---------------------|--|-----|----------|
| Type                        | -    | -                   | Vertical shaft Volute type mixed flow pump |     |          |
| Design Sewage Flow          | Q1   | m <sup>3</sup> /min | Peak Flow                                  |     | 145.83   |
| Pump Unit -1 Number         | UN1  | unit                |  |     | 2        |
| Discharge per Unit          | DU1  | m <sup>3</sup> /min | 1/10×Q1/UN1                                |     | 14.58    |
| Pump Diameter(V=1.5~3.0m/s) | D1   | mm                  | 146×(DU1/1.5~3.0) <sup>0.5</sup>           |     | 322 ~455 |
| <i>Therefore</i>            | D1   | mm                  |  |     | 400      |
| Pump Unit -2 Number         | UN2  | unit                |  |     | 2        |
| Discharge per Unit          | DU2  | m <sup>3</sup> /min | 2/10×Q1/UN2                                |     | 29.17    |
| Pump Diameter(V=1.5~3.0m/s) | D2   | mm                  | 146×(DU2/1.5~3.0) <sup>0.5</sup>           |     | 455 ~644 |
| <i>Therefore</i>            | D2   | mm                  |  |     | 500      |
| Pump Unit -3 Number         | UN3  | unit                | including 1 stand-by                       |     | 2        |
| Discharge per Unit          | DU3  | m <sup>3</sup> /min | 4/10×Q1/UN3                                |     | 58.33    |
| Pump Diameter(V=1.5~3.0m/s) | D3   | mm                  | 146×(DU3/1.5~3.0) <sup>0.5</sup>           |     | 644 ~910 |
| <i>Therefore</i>            | D3   | mm                  |  |     | 700      |



**Table I.6 Design Calculation of N1 WWTP (6/11)**

**2-4 Aeration Tank**

| Item  | Sign             | Unit                  | Calculation  | F/S  | M/P     |      |      |      |      |
|---|------------------|-----------------------|--|--|---------|------|------|------|------|
| Type  | -                | -                     | Multi-tank Complete mixing Type  |  |         |      |      |      |      |
| Design Sewage Flow  | Q1               | m <sup>3</sup> /day   |  |  | 140,000 |      |      |      |      |
| (Maximum Daily Flow)  | Q2               | m <sup>3</sup> /hr    |  |  | 5,833.3 |      |      |      |      |
| Hydraulic Retention Time                                    | HRT              | hr                    |  |  | 6.0     |      |      |      |      |
| Basin Number  | BN               | basin                 |  |  | 8       |      |      |      |      |
| Required Volume per basin                                   | RV               | m <sup>3</sup> /basin | Q2×RT/BN   |  | 4,375   |      |      |      |      |
| Width   | W                | m                     | 1~2H   |  | 10.5    |      |      |      |      |
| Water Depth   | H                | m                     | 4.0m~6.0m  |  | 6.0     |      |      |      |      |
| Length  | L1               | m                     | RV/(W×H)   |  | 69.4    |      |      |      |      |
| Therefore   | L2               | m                     |  |  | 70.0    |      |      |      |      |
| Dimension (Width)   | W                | m                     |  |  | 10.5    |      |      |      |      |
| (Depth)   | H                | m                     |  |  | 6.0     |      |      |      |      |
| (Length)  | L                | m                     |  |  | 70.0    |      |      |      |      |
| (Basin Number)  | N                | basin                 |  |  | 8       |      |      |      |      |
|   |                  |                       |  |  |         |      |      |      |      |
| (Check)   |                  |                       |  |  |         |      |      |      |      |
| Hydraulic Retention Time                                    | HRT              | hour                  | W×H×L×N/Q2   |  | 6.0     |      |      |      |      |
| BOD-SS load   | BSS <sub>L</sub> | kgBOD/kgSS/d          | (Q1×BOD <sub>in</sub> )/(W×H×L×N×Xa)   |  | 0.24    |      |      |      |      |
| BOD <sub>in</sub> : Inflow BOD Concentration                |                  |                       | 120 mg/L   | (Removal Rate in PST : 40%)                |         |      |      |      |      |
| Xa : MLSS Concentration                                     |                  |                       | 2,000 mg/L   |  |         |      |      |      |      |
| Aerobic Sludge Retention Time                               | ASRT             | day                   | HRT/24×Xa / (a×S-BOD <sub>in</sub> + b×SS <sub>in</sub> - c×HRT/24×Xa) =     |  |         |      |      |      |      |
|   |                  |                       |  |  | 4.785   |      |      |      |      |
| S-BOD <sub>ir</sub> : Inflow S-BOD Concentration            |                  |                       | 80 mg/L  | (S-BOD[Solved BOD]=BOD <sub>in</sub> ×0.6) |         |      |      |      |      |
| SS <sub>in</sub> : Inflow SS Concentration                  |                  |                       | 90 mg/L  | (Removal Rate in PST : 50%)                |         |      |      |      |      |
| a : Sludge converting ratio of solved BOl                   |                  |                       | 0.5 mgMLSS/mgBOD   | (0.4~0.6)                                  |         |      |      |      |      |
| b : Sludge converting ratio of SS                           |                  |                       | 0.95 mgMLSS/mgSS   | (0.9~1.0)                                  |         |      |      |      |      |
| c : Sludge reduction ratio caused by endogenous respiration |                  |                       | 0.04 (1/day)   | (0.03~0.05)                                |         |      |      |      |      |
| Effluent Quality (C-BOD)                                    | EQ               | mg/L                  | 10.42×A-SRT <sup>(-0.519)</sup> (15~20°C)                                    |  | 4.624   |      |      |      |      |
| Water Temperature   |                  |                       | 20 °C  |  |         |      |      |      |      |
| Effluent Water Quality (C=BOD Maximum)                      |                  |                       | EQ×3   | 20mg/l >                                   | 14      |      |      |      |      |
|   |                  |                       |  |  | -OK-    |      |      |      |      |
|   |                  |                       |  |  |         |      |      |      |      |
|   |                  |                       | 1 : 1.5 : 1.5 : 2.25   |  |         |      |      |      |      |
| Partition of Aeration Tank                                  |                  |                       | <table><tr><td>No.1</td><td>No.2</td><td>No.3</td><td>No.4</td></tr></table> |  |         | No.1 | No.2 | No.3 | No.4 |
| No.1  | No.2             | No.3                  | No.4   |  |         |      |      |      |      |
|   |                  |                       |  |  |         |      |      |      |      |
| Total Length of Tank  | TL               | m                     |  |  | 70.0    |      |      |      |      |
| No.1 Tank Length  | L1               | m                     | TL×1/(1+1.5+1.5+2.25)  |  | 11.2    |      |      |      |      |
| No.2 Tank Length  | L2               | m                     | TL×1.5/(1+1.5+1.5+2.25)  |  | 16.8    |      |      |      |      |
| No.3 Tank Length  | L3               | m                     | TL×1.5/(1+1.5+1.5+2.25)  |  | 16.8    |      |      |      |      |
| No.4 Tank Length  | L4               | m                     | TL×2.25/(1+1.5+1.5+2.25)   |  | 25.2    |      |      |      |      |
|   |                  |                       | Total  |  | 70.0    |      |      |      |      |
|   |                  |                       |  |  |         |      |      |      |      |



**Table I.6 Design Calculation of N1 WWTP (8/11)**

**2-6 Disinfection Channel**

| Item                         | Sign | Unit                | Calculation   | F/S | M/P         |
|------------------------------|------|---------------------|---------------|-----|-------------|
| Type                         | -    | -                   | Chlorination  |     |             |
| Design Sewage Flow           | Q1   | m <sup>3</sup> /day |               |     | 140,000     |
| (Maximum Daily Flow)         | Q2   | m <sup>3</sup> /min |               |     | 97.2        |
| Retention(Chlorination) Time | RT   | min                 |               |     | 15.0        |
| Required Volume              | RV   | m <sup>3</sup>      | Q2×RT         |     | 1,458       |
| Width of channel             | W    | m                   |               |     | 2.0         |
| Depth of channel             | H    | m                   |               |     | 2.5         |
| Pass Number                  | PN   | pass                |               |     | 8           |
| Length of channel            | L1   | m/pass              | RV/(W×H×PN)   |     | 36.5        |
| <i>Therefore</i>             | L2   | m/pass              |               |     | 37.0        |
| <b>Dimension (Width)</b>     | W    | m                   |               |     | <b>2.0</b>  |
| <b>(Depth)</b>               | H    | m                   |               |     | <b>2.5</b>  |
| <b>(Length)</b>              | L    | m/pass              |               |     | <b>37.0</b> |
| <b>(Pass Number)</b>         | N    | pass                |               |     | <b>8</b>    |
| <b>(Check)</b>               |      |                     |               |     |             |
| Retention(Chlorination) Time | RT   | min                 | (W×H×L×PN)/Q2 |     | 15.2        |

**2-7 Sludge Thickening Tank**

| Item                        | Sign | Unit                   | Calculation                                     | F/S | M/P         |
|-----------------------------|------|------------------------|---|-----|-------------|
| Type                        | -    | -                      | Gravity Thickener (Radial Flow Circular Type)   |     |             |
| Generated Sludge Solids     | GS   | t-DS/day               | Refer to Mass Balance Cal.                      |     | 26.096      |
| Generated Sludge Volume     | GSV  | m <sup>3</sup> /day    | Refer to Mass Balance Cal.                      |     | 3,286       |
| Solid Matter Load           | SML  | kg/m <sup>2</sup> /day |   |     | 75          |
| Required Surface Area       | SA   | m <sup>2</sup>         | (GS×10 <sup>3</sup> )/SML                       |     | 347.9       |
| Water Depth                 | H    | m                      |   |     | 4.0         |
| Basin Number                | BN   | basin                  |   |     | 4           |
| Required Tank Diameter      | TD1  | m                      | (SA×4/(3.14×BN)) <sup>0.5</sup>                 |     | 10.53       |
| <i>Therefore</i>            | TD2  | m                      |   |     | 10.5        |
| <b>Dimension (Diameter)</b> | D    | m/basin                |   |     | <b>10.5</b> |
| <b>(Depth)</b>              | H    | m                      |   |     | <b>4.0</b>  |
| <b>(Basin Number)</b>       | BN   | basin                  |   |     | <b>4</b>    |
| <b>(Check)</b>              |      |                        |   |     |             |
| Solid Matter Load           | SML  | kg/m <sup>2</sup> /day | GS×10 <sup>3</sup> /(3.14×D <sup>2</sup> /4)×BN |     | 75.4        |
| Sludge Thickened Time       | T    | hr                     | (3.14×D <sup>2</sup> /4)×H×BN×24/GSV            |     | 10.1        |
|                             |      |                        |   |     |             |
|                             |      |                        |   |     |             |
|                             |      |                        |   |     |             |
|                             |      |                        |   |     |             |
|                             |      |                        |   |     |             |





**Table I.6 Design Calculation of N1 WWTP (10/11)**

**Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Mechanical Dewatering)**

**Table-1 Input Data**

|   |          |  |
|---|----------|--|
| 1. Calculation Manner                       |          | 1.Premise that the quality of supernatants are same level removed with inlet sewage<br>2.Premise that the entire supernatants are removed at treatment process |
| 2. Selection of Treatment Efficiency        |          | 1.Total Removal Ratio 2.Outlet Water Quality(input 1or2)   |
| in case of 1 : input data                   | 90 (%)   |  |
| in case of 2 : input data                   | (mg/l)   |  |
| 3. Excess Sludge Generation                 |          | 1.Consideration of Solid Matter Only 2.Consideration of Converting of Solved BOD (input 1or2)  |
| In case of 1:input data (Sludge generation) | 100      | Sludge generation ratio per removal SS(%)  |
|   |          | $T2=Q2 \cdot S2=(a \cdot S_{BOD}+b \cdot S1-c \cdot \theta \cdot XA) \cdot Q1/10^6$ (Excess sludge generation formula)   |
|   | a        | a:Converting ratio of solved BOD(mgBOD/mgBOD)  |
|   | b        | b:Converting ratio of SS(mgMLSS/mgSS)  |
|   | c        | c:Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)   |
| In case of 2:input data                     | SBOD     | S <sub>BOD</sub> :Solved BOD quality at inlet to reactor   |
|   | XA       | XA:MLSS concentration(mg/l)  |
|   | $\theta$ | $\theta$ :Hydraulic retention time(day)  |


**Table-2 Basic Conditions**

| Water Flow and Quality                          | Sludge Moisture and Recovery Ratio       | Chemical Conditions for Dewatering       |
|---|--|--|
| *Inlet flow: Q0(m <sup>3</sup> /D)              | *Primary sludge moisture ratio : W1(%)   | *Chemical dosage : A5(%)                 |
| *Inlet quality: S0(mg/l)                        | *Excess sludge moisture ratio : W2(%)    | *Chemical dissolve concentration : A6(%) |
| *Total removal ratio : A1(%)                    | *Thickened sludge moisture ratio : W3(%) |  |
| *Effluent quality: S8(mg/l)                     | *Dewatered sludge moisture ratio : W4(%) |  |
| *Sludge generation ratio per removal SS : S1(%) |  |  |

**Table-3 Material Balance Calculation**

|                          | 0       | 1       | 2      | 3       | 4      | 5       | 6      | 7     | 8     | 9      | 10      | 11    | 12    |  | 5-1     |
|--------------------------|---------|---------|--------|---------|--------|---------|--------|-------|-------|--------|---------|-------|-------|--|---------|
| Q(m <sup>3</sup> /day)   | 140,000 | 143,291 | 967    | 142,324 | 2,320  | 140,005 | 1,174  | 2,112 | 117   | 1,292  | 113     | 1,179 | 3,291 |  | 139,887 |
| T (t°DS/day)             | 25,200  | 28,996  | 14,498 | 14,498  | 11,598 | 2,900   | 23,487 | 2,610 | 0,235 | 23,721 | 22,535  | 1,186 | 3,796 |  | 2,665   |
| S(mg/l)                  | 180     | 202     | 15,000 | 102     | 5,000  | 21      | 20,000 | 1,736 | 2,000 | 18,364 | 200,000 | 1,006 | 1,153 |  | 21      |
| X (H <sup>10</sup> /100) | 100     | 115.1   | 57.5   | 57.5    | 46.0   | 11.5    | 93.2   | 10.4  | 0.9   | 94.1   | 89.4    | 4.7   | 15.1  |  | 10.6    |


**Figure-1 Material Balance Model**



| Calculation Formula                   |                                       |                                       |   |                                |
|---------------------------------------|---------------------------------------|---------------------------------------|---|--------------------------------|
| *Q0=Input Data                        | *Q3=Q1-Q2                             | *Q6=T4*100/(100-W3)                   | *Q9=Q6-Q8                               | *Q12=Q7-Q11                    |
| *T0=Q0*S0*10 <sup>-6</sup> (-6)       | *T3=T1*(100-A2)/100                   | *T6=(T2+T4)*A3/100                    | *T9=T6-T8                               | *T12=T7-T11                    |
| *S0=Input Data                        | *S3=T3*10 <sup>-6</sup> /Q3           | *S6=10 <sup>-6</sup> *Q6/(100-W3)/100 | *S9=T9*10 <sup>-6</sup> /Q9             | *S11=T11*10 <sup>-6</sup> /Q11 |
| *Q1=Q0-Q13                            | *Q4=T4*100/(100-W2)                   | *Q7=Q2+Q4-Q6                          | *Q10=T10*100/(100-W4)                   | *Q5-1=Q5-Q8                    |
| *T1=T0-T13                            | *T4=(T1-T5)*S1/100)-T2                | *T7=(T2+T4)-T6                        | *T10=T9*A4/100                          | *T5-1=T5-T8                    |
| *S1=T1*10 <sup>-6</sup> /Q1           | *S4=10 <sup>-6</sup> *Q4/(100-W2)/100 | *S7=T7*10 <sup>-6</sup> /Q7           | *S10=10 <sup>-6</sup> *Q10/(100-W4)/100 | *S5-1=S5                       |
| *Q2=T2*100/(100-W1)                   | *Q5=Q3-Q4+T3-T5-T4                    | *Q8=T6*A5/A6                          | *Q11=Q9-Q10                             |                                |
| *T2=T1-T3                             | *T5=T1*(100-A1)/100                   | *T8=Q8*S8/10 <sup>-6</sup>            | *T11=T9-T10                             |                                |
| *S2=10 <sup>-6</sup> *Q2/(100-W1)/100 | *S5=T5*10 <sup>-6</sup> /Q5           | *S8=10 <sup>-4</sup> *A6              | *S11=T11*10 <sup>-6</sup> /Q11          |                                |

**Table I.6 Design Calculation of N1 WWTP (11/11)**

**Material Balance Sheet**





## **J. WATER PURIFICATION DEMONSTRATION EXPERIMENT AT KANDAWGYI LAKE**

Water Purification Demonstration Experiment

at Kandawgyi Lake

in connection with

Feasibility Study for Yangon City Water and Wastewater

Improvement Program Cooperation

(Fast Track Applicable Case)

REPORT

June 26, 2013

TESCO CO., LTD.

### **1. Purpose of Experiment**

Kandawgyi Lake locates in the northern downtown of Yangon city, the largest city in Myanmar, is very important area as a place of recreation and relaxation for Yangon citizens providing stroll, recreation, concert and so on, with surrounding parks and many restaurants.

It is also externally important place as a typical point of Yangon city with luxury hotels and embassies of various countries. Presently, there are inflows of restaurants wastewater as well as domestic sewage from 5 drains at Kandawgyi Lake. These wastewater inflows cause accumulation of nutrients and eutrophication in the lake. In addition, accumulated nutrients and strong sunshine accelerate a growing of large amount of Blue-green algae in recent years.


Therefore, the purpose of this experiment is to establishment of water quality improvement technology including blue-green algae removal through the implementation of the demonstration experiment at Kandawgyi Lake.

### **2. Test Implementation Period**

From 23<sup>rd</sup> May to 21<sup>st</sup> June, 2013. Number of operation days: 24 days

### **3. Area of Test Site**

Area of test site is described in the picture below. The test was conducted by setting test area near the restaurant “Kalaway Palace”.



The detail of test site is as follows;

- Area of test site: approximately 3,500m<sup>2</sup>
- Operation water depth: from surface to 50cm depth
- Volume of water treatment: 3,500m<sup>2</sup> × 50cm = 1,750m<sup>3</sup>

#### 4. Pictures of Test Site



Mr. U. Hla Myint, Yangon mayor, and city executives visiting the site at early stage.



Collecting blue-green algae by Algae collection fence



Whole view of Algae processing system

## 5. Preliminary Test

As a preliminary test, algae sampling were conducted twice at Kandawgyi Lake and 3 times at Hirosawa Pond in Kyoto, and verification of test condition was made as to selection of the most suitable coagulant injection ratio and treatment condition of Chlorophyll-a (Chl.a), COD, T-N, T-P and SS in the samples.

As a result, it was deemed that using "Aquafrog S" with the injection ratio of 200mg/L was the most suitable condition for treatment.

### Preliminary test result of sampling from Kandawgyi Lake


Flocculant Feeding ratio : 200mg/L

| Item  | Initial concentration (mg/L) | concentration in supernatant water (mg/L) | Removal ratio (%) |
|-------|------------------------------|---|-------------------|
| Chl.a | 6.033                        | 0.064                                     | 100               |
| CODcr | 1,902                        | 129                                       | 94                |
| T-N   | 53                           | 1.98                                      | 96                |
| T-P   | 31                           | 0.42                                      | 99                |



## 6. Outline of Test Equipment

Outline of Test equipment is as follows:



### 1) Blue-green Algae Collection Equipment



Separation Fence (80m) & Algae Collection Fence (60m) before installation



Algae Collection Tank & Raft equipped with Skimmer (4m x 4m)

### 3) Pressure Floatation Unit & Treated Water Return Unit



Micro Bubble Generator



Pressurized Floatation Tank



Treated Water Siphon



Effluent  
Purified by treatment

### 4) Algae Scraper & Alga Collection Jute Bag Stand



Algae Scraper  
To scrape and collect floating algae floc



Algae Collection Jute Bag & Stand  
To dehydrate and collect by Jute Bag

## **7. Operation Procedure**

### **1) Collecting algae forcibly by collection fence**

Algae floating on the surface were collected with collection fence towed by two motorboats. (It was conducted only three times during the early stage of test, because algae were widely spread under the water surface due to rainy seasons.)

### **2) Algae collection**

Algae were collected into the collection tank on the raft by suction pumps of three skimmers. Then they were transferred to reactor tank on the ground site.

### **3) Flocculation treatment**

Proper amount of inorganic flocculant was fed into the tank by powder feeder equipped with inverter control, and then flocculation reaction was made by high speed mixer.

### **4) Floatation separation of algae by pressure floatation unit**

Flocculated algae were floated and separated from water by micro bubble of 10-30 $\mu$ m.

### **5) Collection of flocculated algae**

Floatation separated algae aggregate were dropped down to outlet port of reactor tank by scraper, then collected in jute bag and dehydrated.

## **8. Test Result**

### **1) Observation result of operation condition**

#### **① Operation record**

Refer to the attached "Operation Record".

#### **② Water volume treated by test equipment**

- Water volume treated during one month:

$$141.9\text{L/min} \times 60\text{min} \times \text{Average } 7.83\text{hours/day} \times 24\text{days} = 1,600\text{m}^3$$

(compared to the target of  $150\text{L/min} \times 60\text{min} \times 8\text{hours/day} \times 22\text{days} = 1,584\text{m}^3$ )

It corresponds to 91% of planned volume of  $1,750\text{m}^3$ .

- Test period : 24 days (compared to the target of 22 days)
- Operation hours : 188 hours (compared to the target of 172 hours)

#### **③ Cost of expendables consumed during 24 days operation**

- Diesel fuel : 420L (according to Operation Record)

$$420\text{L} \times 860\text{Kyat/L} = 361,200\text{Kyat: Approximately } 36,000\text{ JPY}$$

- Flocculant: 375kg (used 15bags x 25kg/bag)

$$375\text{kg} \times 800\text{Yen/kg} = 300,000\text{Yen}$$

It is under review to lower the price of flocculant to around 500JPY/kg by means of i.e. changing purchasing source.

- Cost of expendables per unit quantity of algae

Total volume of algae collected during 24 days was 2,760kg (including 80% of water).

Therefore,

$$(36,000\text{JPY} + 300,000\text{JPY}) / 2,760\text{kg} = 121.7\text{JPY/kg}$$

## 2) Test result regarding water quality improvement of the test area

### <Method>

The assessment of water quality improvement by the test equipment was made by analysis and comparing water quality of the samplings inside and outside the test area


#### ① Assessment method

Comparison of water quality inside and outside (control) of the test area

- Sampling point

Samplings were made at the following 4 points. (Refer to the picture below)

- ① Center of test area
- ② Border of test area
- ③ Control
- ④ Near raft



- Water quality items

Transparency, SS, CODcr, T-N and T-P

- Sampling frequency (Total 14 times)

Before test (21/May)

During test (23/May~20/Jun): twice a week、

At the completion of test

In the afternoon of 20<sup>th</sup> May, the sampling point was set by surrounding the specified area with fence, and the first sampling (before the start of test) was made on 21<sup>st</sup> May. From 23<sup>rd</sup> May, it started continuous operation of purification treatment and it continued to 21<sup>st</sup> June principally every day except Sunday.


On 21<sup>st</sup> June, water sampling was collected after the completion of test and the final measurement of its water quality was conducted.

### <Result>


Test result is presented in the attached “Water Quality of Sampling Points”. Weather information at the site is presented in the list. It became much rainy weather after the second week.

The following describes the change of water quality.

### Transparency and SS




In general, it shows a trend that transparency increased gradually, although the values are unstable because measurement in the open air is likely to be affected by light and shade.



Since there was a little rainfall in the first week (till 27/May), the SS value in the point ①, ② and ④ inside the test area shows higher than those outside test area (control). After the second week, these values had gradually decreased in points ①, ②, ④ and point ③ (control). It was deemed that the decrease was an affect of dilution due to rainfall after the second week.

Since SS concentration inside the test area was higher than outside (control) at the beginning of the test, its decreasing rate of inside was accordingly higher than outside. This was deemed as an effect of algae removal equipment.

#### CODcr



As to the concentration change of CODcr, the same trend was observed as SS. Namely,

during the first week (till 27/May), the values in point ①, ② and ④ inside the test area showed higher than in control ③. However, these had decreased both inside and outside of test area after the latter half of the second week. It was also deemed as an affect of rainfall.

The decreasing rate of COD<sub>Cr</sub> was more apparent than that of SS. COD<sub>Cr</sub> inside test area (point ①, ② and ④) showed lower value compared to that of control.


Especially, COD<sub>Cr</sub> inside test area had declined more rapidly than that of control after 2<sup>nd</sup> June.

Same as SS, concentration change was observed because of an affect of dilution by rainfall. However, the decline of value inside test area after 2<sup>nd</sup> June was deemed as an effect of algae removal equipment.


### **T-N and T-P**

Decrease of T-N and T-P concentration were observed.

This decrease was assumed that the effect of progress of algae collection..



In the first two weeks, the first half of the test period, T-N concentration inside the test area decreased to 1/3 of the concentration at the beginning, thereafter it also decreased outside the test area (control). It is deemed that the concentration decrease at the control in the latter half of the test period is an effect of rainfall. Meanwhile, the density decrease inside the test area is deemed as an effect of the algae removal equipment..



As to T-P, a trend was observed that the concentration decreased gradually as the test progressed at the center of the test area. Meanwhile, at the border of test area and control, the concentration once decreased, then increased on the last day of the test period.

Although the reason of this concentration change at the border of test area and at control is not clear, however, the concentration decrease inside test area is deemed as an effect of the algae removal equipment.

According to visual observation, the general condition of algae growing is as follows. At the beginning of test, there observed thick belt-like zone of blue-green algae on the surface of water in the test area (creek area). It was not seen in the center of the lake (control). Through the continuous observation, it was found that the density of algae varied locally depending on direction and strength of wind. This often resulted to belt-like staying of algae drifted to the creek and fence area. The variation was significant at the sampling point ②, inside the fence, and ④, near the coast, and those were deemed as one of the reason for unstable water quality at those area.

Staying of algae on the surface of lake water was especially remarkable in the morning on sunny days. But, it was not seen on rainfall and thereafter. Therefore, it was deemed that this phenomenon was due to stirring, temperature drop and so forth on water surface by rainfall.

There observed very little staying of algae in the area of test site two weeks after the beginning of test.

#### <Observation>

There became much rainfall after Tuesday of the second week because of rainy



season (refer to the list below). It is deemed that increase of transparency and measured value of SS and CODcr were affected by dilution caused by rainfall.

(Assumed volume of rainfall overwhelmingly more than that of treated water)

| Date   |     |    | Weather                    |
|--------|-----|----|----------------------------|
| 23-May | Thr | AM | Little rain                |
|        |     | PM | Cloudy→Fine                |
| 25-May | Sat | AM | Fine                       |
|        |     | PM | Little rain                |
| 27-May | Mon | AM | Little rain                |
|        |     | PM | Rain                       |
| 28-May | Tue | AM | Fine                       |
|        |     | PM | Fine                       |
| 29-May | Wed | AM | Rain                       |
|        |     | PM | Rain                       |
| 30-May | Thr | AM | Fine                       |
|        |     | PM | Fine                       |
| 31-May | Fri | AM | Rain                       |
|        |     | PM | Rain                       |
| 1-Jun  | Sat | AM | Rain                       |
|        |     | PM | Rain                       |
| 3-Jun  | Mon | AM | Heavy Rain                 |
|        |     | PM | Rain                       |
| 4-Jun  | Tue | AM | Heavy rain and strong wind |
|        |     | PM | Heavy rain and strong wind |
| 5-Jun  | Wed | AM | Rain                       |
|        |     | PM | Cloudy→clear               |
| 6-Jun  | Thu | AM | Rain                       |
|        |     | PM | Rain                       |

| Date   |     |    | Weather              |
|--------|-----|----|----------------------|
| 9-Jun  | Sun | AM | Heavy Rain           |
|        |     | PM | Heavy Rain           |
| 10-Jun | Mon | AM | Extremely heavy rain |
|        |     | PM | Extremely heavy rain |
| 11-Jun | Tue | AM | Extremely heavy rain |
|        |     | PM | Extremely heavy rain |
| 12-Jun | Wed | AM | Fine & wind          |
|        |     | PM | Fine & wind          |
| 13-Jun | Thu | AM | Rain                 |
|        |     | PM | Rain                 |
| 14-Jun | Fri | AM | Cloudy               |
|        |     | PM | Heavy Rain           |
| 15-Jun | Sat | AM | Fine                 |
|        |     | PM | Fine                 |
| 17-Jun | Mon | AM | Fine                 |
|        |     | PM | Fine                 |
| 18-Jun | Tue | AM | Fine                 |
|        |     | PM | Rain                 |
| 19-Jun | Wed | AM | Weak rain            |
|        |     | PM | Fine                 |
| 20-Jun | Thu | AM | Rain                 |
|        |     | PM | Rain                 |
| 21-Jun | Fri | AM | Fine                 |
|        |     | PM | Rain                 |

However, values at both inside of test area, points ①, ② and ④, and outside ③ were evenly decreased after the second week, those indicate the affection of dilution by rainfall.

As to concentration of SS, CODcr, T-N and T-P, they show, at inside of test area, ①, ② and ④, lower values than at outside ③ (control), before the beginning of test through the second week. Also, degree of concentration decrease is rather higher at inside of test area through the test period.

The result indicates that there seems to be, slightly but still, the effectiveness of algae removal equipment, although the test is affected by dilution due to rainfall.

There is much volume of belt-like algae staying observed visually on the surface of lake especially along the coast at creek area. This is due to wind blow that often leads to form thick staying layer of algae. It is apparent on sunny days but disappears on rainfall. Likewise, at the beginning of test, thick belt-like algae staying were observed in the test area (creek area), It was not seen in the center of the lake.

Staying of algae was almost never seen in the test area after two weeks from the beginning of test, but it was seen in the other creeks outside test area. Therefore, it is deemed that the equipment was sufficiently effective to remove thick algal belt in creek area.



Algal belt staying near raft at early period of test







No algal belt observed two weeks after the test start (3<sup>rd</sup> June)

### 3) Water treatment capacity of test equipment

#### <Method>

Sampling were implemented, one from influent into the collection tank on raft and the other from treated water with algae removed through pressurized floatation, and they were measured SS, COD<sub>Cr</sub>, T-N and T-P, and compared each other.






<The result and observation>

Getting into rainy season, concentrations of SS, CODcr, T-N and T-P in the influent were gradually decreased as rainfall volume increased.

However, concentrations of those in the treated water were always lower than those in the influent. Therefore it was deemed that the treatment by the equipment was properly made.

Average removal ratio of each parameter is as follows:



All parameters shows removal ratio of 80 to 90% that proves the equipment is effective for purification of water quality.

For details of data, refer to the attached data “Water Quality of Inflow and Outflow” .

4) Pictures of raw water, treated water and collected algae after treatment




From the left: Raw water, treated water (returned water), collected algae  
(Sampling collected on 2013/6/21)

It is apparent that the treated water is very clear and pure compared to raw water.

## 9. Estimation of Material Balance, Required Days and Cost of Expendables in case of purification of entire Kandawgyi Lake with the equipment

### 1) Material Balance (under rated operation)



Left: Algae Influent      Right: Treated water returned to the lake

- 48kg of blue-green algae (dry weight conversion) was removed from 72m³ of algal water per day
- 67.2 m³ of treated water was returned to Kandawgyi Lake.

### 2) Required days and cost of treatment for the entire lake with the equipment

#### • Required days

Presuming 0.5m of water depth with algae to the entire lake area of 430,000m²

Total volume of algal water:  $430,000\text{m}^2 \times 0.5\text{m} = 215,000\text{m}^3$

Total volume of algae (SS conversion):

$215,000\text{m}^3 \times 121.3\text{mg/L (average SS in the test)} = 26,080\text{kg}$

i.e. Required days:  $26,080\text{kg} / 48\text{kg} = 543\text{ days}$

#### • Cost of expendables

According to the result of the demonstration test

$14,000\text{JPY (flocculant + diesel fuel)/day} \times 543\text{days} = 7,602,000\text{JPY}$

## **10. Conclusion**

Continuous operation started on 23<sup>rd</sup> May. From the 1<sup>st</sup> June, rated capacity was demonstrated under the condition such as water treatment volume of 150L/min and flocculant feeding rate of 250mg/L, which was close to the planned condition, by adjusting inflow water volume and flocculant feeding volume.

Then, flocculant feeding rate was adjusted at 205mg/L from 19<sup>th</sup> June.

The average removal ratio under the above condition was, 85% for SS, 80% for COD<sub>Cr</sub>, 98% for T-N and 91% for T-P during the test period.

The test showed that algae were removed properly not only when their density was high but also when they were spread by rainfall and high removal ratio was achieved for T-N and T-P. It was confirmed that the equipment achieved sufficiently its function and capability.

The area of test site is 3,500m<sup>2</sup> which is 1/123 of the total lake of 0.43 km<sup>2</sup>. Assuming if no newly developed algae are considered by the eutrophicated sludge at the bottom of lake, it will require approximately 530 days to remove algae from the entire lake with the same equipment.

It is assumed to require 53 days for removal of algae if equipment of ten times of the capacity (e.g. 5 units of twice capacity) is used.

Therefore, it is expected to be able to remove blue-green algae more effectively by using this equipment intensively for three to four months period in dry season when there is little spread of algae.

## **11. Future Issues**

1) It is deemed that the return of 72m<sup>3</sup> of treated clear water to the lake contributes to the improvement of transparency and of diminution of algae. However, since the test was implemented in rainy season, and so, floating algae spread widely in the water because of large volume of rainfall, it is assumed that algae collecting rate has decreased. Therefore, it shall be necessary to implement the test further in dry season.

2) Collected blue-green algae of 48kg/day (dry weight conversion) contain rich phosphorus and nitrogen and are expected to be useful material for organic fertilizer. YCDC is very much interested in recycle of those. Therefore, as for the blue-green algae collected in this test, we will undertake componential analysis later and will research recycle possibility also.

Attachment

- (A) Operation Record
- (B) Water Quality of Sampling Points
- (C) Water Quality of Inflow and Outflow
- (D) Document for Report Meeting at YCDC on 25<sup>th</sup> June:  
    "Blue-green Algae Processing Test in Kandawgyi Lake"






## **K. CHANGE OF SITES FOR WWTPS**

The following WWTP sites were changed. Location map is shown in Figure K.1.

- C2+E1    Permission from Ministry of Information could not be obtained to use a land, of which area is 44 acre. Therefore, only 22.86 acre is available at the current site (ref. to Figure K.2). Reformation of C2+E1 sewerage zone is necessary.
- C2+ E1    A new land with 5.142 acre is proposed in Thingangyun Township (ref. to Figure K.3). Reformation of C2+E1 sewerage zone is necessary.
- E1+E2    A new land with 23 acre was obtained in North Dagon Township (ref. to Figure K.4). E2 sewerage zone is to be combined with E1 sewerage zone.
- N1        A new land with 11 acre was obtained near the current WWTP. However the land is divided into two parts by a main road (ref. to Figure K.5).
- E3        Permission for land acquisition could not be obtained. E3 sewerage zone is to be combined with C2 sewerage zone.

## Sewerage Zones




| Sr  | Zone    | Township   |
|-----|---------|--|
| 1   | C1      | Pazundaung, Botahtaung, Kyauktada, Pabedan   |
| 2 ✓ | W1+W2   | Lanmadaw, Latha, Ahlone, a part of Kyee Myin Daing, Dagon, a part of Bahan, Kamaryut, Sanchaung, Hlaing, a part of Mayangone |
| 3 ✓ | C2+E1   | a part of Bahan, Mingalar Taung Nyunt, Yankin, Tamwe, South Okkalapa, a part of Mayangone, North Okkalapa                    |
| 4 ✓ | C2+E1   | Thingangyun  |
| 5   | E3      | Taketa, Dawbon, South Dagon  |
| 6 ✓ | N1      | Insein   |
| 7   | E4      | Dagon Seikkan  |
| 8 ✓ | E1 + E2 | North Dagon, East Dagon  |
| 9   | N2      | Mingalardon  |
| 10  | N3      | Shwe Pyi Thar  |
| 11  | S1      | Dala   |
| 12  | W3      | A part of Kyee Myin Daing, Seikgyikhanaungto, Seikkan  |
| 13  | W4      | Hlaing Tharyar   |

Source: YCDC

Figure K.1 Change of Sites for WWTPs, Location Map

## ဇုန် (C2+E1) Mayangone

Existing Area : ( 22.86 Acre )



Source: YCDC

**Figure K.2 Change of Sites for C2+E1 WWTP**



စန် (C2+E1) Thingangyun

Existing Area : (5.142 Acre)

(2) Storey (or) Multi Storey



Source: YCDC

**Figure K.3 Change of Sites for C2+E1 WWTP**

ဇုန် (E1+E2) North Dagon

Existing Area : (23 Acre)



Source: YCDC

**Figure K.4 Change of Sites for E1+E2 WWTP**



ဇုန် (N1) Insein

Existing Area : (11 Acre)



Source: YCDC

Figure K.5 Change of Sites for N1 WWTP