

添付資料 11

PI Activities Final Presentation



# Presentation Materials

## Theme 1

**WELCOME**

**PI SOLVING ACTIVITY 2012**

**Protection Coordination in Trashigang**

By Team 1

### Outlines

- Team Members
  - Background
  - Work done
- Working Methods
  - Findings from the Data
  - Solutions
- Cost and Benefit analysis
  - Implementation Schedule
  - Long term Solution.

**Team Member**

As per the executive order, 59/BPC/DCSD/JICA/2012/112 from the office of the Managing Director the following member

	Mr. Thinley Gyetshen, HoD, TD, Thimphu (Advisor)		Mr. Pema Tashi, Engineer, ESD, T/Gang (Member).
	Mr. Cheten Tshering, Engineer, SMD K/Lung (Team Leader)		Mr. Tshewang Rinzin, Manager, CMTD, Begana (Coordinator).
	Mr. Penjor, Sr. Supervisor, ESD, T/Gang (Member).		Mr. Fujitani, JICA Experts

### Background

- History of non tripping of feeder breaker during faults.
- Respective feeder do not clear its own fault.

Reliability????  
Frustrated  
Consumers?????  
Losses to BPC?????  
Equipment (Asset) Damage?????

Reliability????  
Frustrated  
Consumers?????  
Losses to BPC?????  
Equipment (Asset) Damage?????

### What we did?

- Individual feeder breakers trip during lower fault level w.r.t IC or X-rat breaker during heavy fault
- Interview with operator and Supervisor, ESD Trashigang for 33/11kV Chenary S/S.
- Interview with operator and incharge, Shangkhanglung for 33/11kV Wamrong S/S.
- Interview with Assistant Manager & operator for 33/11kV Wamrong S/S.

### What we did? ..... Testing & calibration

- 56 Relays at 132/33/11kV K/Lung SS
- 18 Relays at 33/11kV Wamrong SS
- 3 Relays at 132/33/11kV Nangkhor SS
- Relay Setting Data Collections

### Team Observation Contd. @ MV Substation

- No record of Relay resetting after Commissioning of the Substation.
- Functionality tests of Relays were satisfactory.
- Few Relays/Auxiliaries were defunct.
- Incomplete Wiring for breaker

### WORKING METHODS

### DATA ANALYSIS

- Impedance Diagram
- Calculation of Fault Level
- Calculate the Saturation Factor of CT
- Relay Setting
- Calculation for Breaker
- Relay Setting for Transformer
- Relay Setting for Outgoing Breakers
- Drawing Protection Coordinated Diagram

### FINDINGS FROM DATA ANALYSIS

Observe the Coordination between 33kV Upstream Breaker and 33kV Downstream Breaker.

### Findings of Causes from Data

- Defunct Equipment
  - Defunct Relays
  - Defunct Auxiliaries
- Poor Checking System
  - Relay setting
  - Incompetent/Skilled personal
- CAUSES OF PROTECTION COORDINATION PROBLEM
  - Low/high Set Values
  - Improper Setting
  - Mismatch with Upstream Setting
  - No Data Analysis
  - Incomplete Tripping Circuitry

PROTECTION COORDINATION PROBLEM

### Main Cause


#### Relay Setting and Coordination

- Relay setting was not done as per the actual loading scenario.
- Relay Coordination was not done with upstream or downstream at MV Substations
- Difference in Relay technologies at MV & MV Substation
- No history of Relay setting after commissioning

### Solutions for the Causes

- Replace Defunct Equipment
  - Replace Defunct Relays
  - Replace Defunct Auxiliaries
- Proper Checking System
  - Develop Skilled personal
  - Coordinate with Upstream Setting
  - Complete Tripping Circuitry
- Use Software for Simulation
  - Proper Values
  - Proper Setting
  - Data Analysis

EFFECTIVE PROTECTION COORDINATION



**Cost Analysis for Relay Setting and Coordination**

Particulars	Cost	Total
Resetting of the relays for coordination	3 Engineers x 700 x 10days = Nu. 21,000 Vehicle expense = Nu.10,000 Driver x 500 x 10 days = Nu. 5,000 Miscellaneous materials = Nu.20,000	Nu.56,000
Replacement of Defunct E/F relays and MCC relays CDG 31 and accessories	7 x 14,440 = Nu. 101,080 Lump sum Nu.50,000	Nu.165,080
Complete check of wiring mechanical problems	3 Engineers x 700 x 7days = Nu. 14,700 Vehicle expense = Nu.10,000 1 Driver x 500 x 7days = Nu. 3,500 Miscellaneous materials = Nu.20,000	Nu.48,200

**CAPE Software for Protection Engineering**


The power that protection engineers need

CAPE (Computer-Aided Protection Engineering) software is built for engineers responsible for protection of high voltage transmission systems and distribution systems within electric power utilities.

- Detailed modelling capabilities based on a single open source database.
- Support for analysis and simulation to solve data management issues, uncover potential network and protective device problems, and evaluate alternatives
- Support for networks of any size
- Support for setting complex modern digital relays.
- Support for relay coordination functions and wide-area studies.

We believe CAPE is simply the best of its kind anywhere in the world today, whether you define "best" based on productivity, improvement, ease of use, flexibility, completeness, technical detail, or price.

**Numerical Cost Analysis(Sample, Wamrong Substation)**  
Income for April : Nu.248052.0  
Assuming outage of 5hrs due to poor Relay Coordination;  
If all feeders trips, loss = (248052x5)/(30x24)=Nu.1723.0  
If Thungkar feeder trips, loss=(12061x5)/(30x24)=Nu.83.75  
Here, in this case we save by almost 20 times the revenue.



**Long Term Solutions, ...Sustainability**

1. The protection coordination team suggests a dedicated protection and control unit to start with a dedicated engineer under O&M Manager at DCSD Head office. He/she must guide and facilitate other trained engineers in the regions (preferably in RM offices). In future it can become a division under a department or wing.
2. Succession Training has to be done.

**ACKNOWLEDGEMENT**  
PI Protection Coordination Team would like to acknowledge the following :

- All the JICA experts who contributed in the progress of the teams work, through feedback, etc.
- Sr. Consultant, DNCD, BPC for providing guidance and for sparing your valuable time with teams queries.
- Ton La, P.E, LA Engineering. "Relay Coordination Study", 2005.
- Varadarajan.M. "Protection of Non Grid feeders". TNEB, 2001.
- Authors of "Transformer and Transformer-Feeder protection". NPAG, 2007.

To all those who helped us directly or indirectly in this Endeavour.



**Theme 2**

**OUTLINE**

1. Members/Theme
2. Background for selecting this theme
3. Selection of feeder and reasons
4. Current badness in this feeder
5. Causes of badness
6. Counter Measures (ARCB,LBS&Fault Indicators)
7. Implementation plan

**Theme & Members**


**Standard/Guideline on Installation of Fault Locating and Switching Devices/Equipments in MV Distribution System**

**Background/Reasons for selecting this theme**

- **Operational Problem:**
  - Difficulties in locating and isolating fault
  - Excessive "trip/close" operation of SS breaker
  - Taking too long to restore the supply (lowers SAIFI/SAIDI)
  - Low customer satisfaction
- **Lack of proper standard for installing different distribution equipments**
  - No uniformity in installing switching and protection devices
  - Difficulties in preparing BoQ

**Identified area:**  
ESD, Wangdue

**Identified system:**  
33 kV feeder No-II




**Reason for selecting 33 kV feeder**

Sl #	Name of Feeder	Line Length in Km	No. of Customer in %	No of Customer in %	
1	33 kV Feeder-II 177 KM Sha	177.00	87.00	8620	88.93
2	33 kV Feeder-IV 35.261 KM Gaxelo	35.261	84.00	2442.00	26.79
3	33 kV Feeder-IV 37.334 KM Burchu	37.334	7.00	305.00	3.41
4	33 kV Feeder-III 36.407 KM Jalla Ulla	36.407	7.00	875.00	9.62
5	33 kV Feeder-V 32.953 KM Omtokha	32.953	8.00	1830.00	20.53
6	33 kV Feeder-I 2.328 KM Helwa	2.328	8.00	84.00	0.92
	<b>Total</b>	<b>366.26</b>		<b>7397.00</b>	

- Longest line length (scattered lines)
- Highest customer base
- The most affected feeder (Interruption)
- Most difficult geographical terrain
- Most of the 33 kV feeders in other ESDs are similar to this feeder in terms of terrain, vegetation, line length, switching/protection equipments etc.

### Current Badness

- When ever there is fault, breaker at the source will trip and all the consumers fed from this feeder are affected
- Fault location is not known
- Restoration has to do on prediction basis by operating LBS time and again and frequency of interruption is high
- More Duration of interruption




### Time taken to travel from office to LBS switches

LBS	ESD office to LBS Time (Min)	Place	Type of road
L1	20.00	Nehque	feeder road
L2	7.00	Bridge	Highway
L3	25.00	Rubesa	Highway
L4	20.00	Raguna	feeder road
L5	30.00	chuzomsa	feeder road
L6	50.00	chungsaykha	feeder road
L7	40.00	Samtangang	feeder road
L8	60.00	Wachey	Highway feeder road
L9	150.00	Khotokha	feeder road
L10	90.00	Khelekh	Highway
L11	120.00	Rachawa	Highway/ no road
L12	150.00	Dungdugesa	Highway
L13 & L14	180.00	Dangchhu	Highway
L15	210.00	Rukhuj	Highway/ feeder road

### LBS to LBS travel time

LBS to LBS G.O	Time(min)	Mode of travel	Type of road
L1-L2	7	by vehicle	Feeder road
L2-L3	28	by vehicle	Highway/Foot path
L3-L4	42	by vehicle	Feeder road/highway/tppt path
L4-L5	7	by vehicle	Feeder road
L5-L6	25	by vehicle	Feeder road/Foot path
L6-L7	10	by vehicle	Feeder road
L7-L8	40	by vehicle	Highway/feeder road/Foot path
L8-L9	80	by vehicle	feeder road (cannot go during raining) by walk 6 hours
L8-L10	45	by vehicle 30 mins and walk 15 mins	Highway/ footpath
L10-L11	60	by vehicle 30 mins and walk 30 mins	Highway/ feeder road/ foot path
L11-L12	60	by vehicle	Highway/ feeder road



### Fault locating Exercise/Time (Existing)

Sl. #	Area	Distance (km)	Time (min)	Remarks
1	...	...	...	...
2	...	...	...	...
3	...	...	...	...
4	...	...	...	...
5	...	...	...	...
6	...	...	...	...
7	...	...	...	...
8	...	...	...	...
9	...	...	...	...
10	...	...	...	...
11	...	...	...	...
12	...	...	...	...
13	...	...	...	...
14	...	...	...	...
15	...	...	...	...
16	...	...	...	...
17	...	...	...	...
18	...	...	...	...
19	...	...	...	...
20	...	...	...	...
21	...	...	...	...
22	...	...	...	...
23	...	...	...	...
24	...	...	...	...
25	...	...	...	...
26	...	...	...	...
27	...	...	...	...
28	...	...	...	...
29	...	...	...	...
30	...	...	...	...

### Reliability Indices at present situation

- fault at Sephu area
- Breaker at the source tripped
- All the 3620 customer will be affected


Sl. #	Reliability Indices	SAIFI	SAIDI
1	Under ESD Control	6.17	7.33

Total number of customer in the feeder: 3620.00  
Sum of customer interruption duration (Customer interrupted \* Duration): 24595.33  
Total number of customer interrupted: 1832.4

### Causes of current badness

As per practical experiences

- Inadequate testing equipments
- Inadequate fault isolator/ indicator in the system
- Longer the line distance, difficult to trace the fault
- Scattered system, most difficult to detect the fault line.
- No access road leads to delay in line patrolling/ restoration and transportation of Crews, equipments & materials
- Bad weather condition
- Bad road condition
- Difficult environment and terrain



### Cause Analysis

A. Beyond Our control

- Natural Climatic
- Environment
- Road

A. Within Our Control

- Manpower
- Facilities
- Distribution System

Note: These will have limited improvement

### Distribution System


- Lengthy Lines
- Too Many spur lines
- Wide Area network

These are existing system and cannot be changed. Moreover, the counter measure for number iv will address all these problems.

iv. Inadequate fault isolators/indicators (solvable cause)

### Counter Measures

- By Installing Auto-reclosers
- Installing Fault Indicator
- ARCB and Fault Indicator



- ### Protection Functions/Features
- Over current
  - Earth fault
  - Under and over voltage
  - Under and over frequency
  - Inrush Restraint
  - Negative Phase Sequence (NPS)
  - Cold load pick up
  - Live Load Blocking
  - Loop Automation

- ### Metering Functions/Features
- Voltage
  - Current
  - Frequency
  - Kilowatt (kw)
  - Energy(kwhr)-Weekly, Monthly
  - Apparent Power(KVA), Reactive power (KVAR)
  - Power factor
  - Outage recording

### Generally Used for:

- Clearing transient faults to reduce frequency of outage experienced by customers at source end of long feeders
- Used to prevent urban consumers being affected by faults in rural areas in situation where feeder serves both urban and rural customers
- Used to segregate lines which has high fault frequency-Eg. Dagachhu project line

- ### Generally used for....
- Segregating faults between two areas or ESDs.
  - Generator control
  - Loop Automation in tie lines
  - Can be used for switching station or substation

### 33 kV Switching station at Duksum, Trashiyantse

-Two Incomer, four Outgoing

25

### Channel Mounted 33 KV Breakers (33/11 KV SS)

26

### 33 KV breaker in 33/11 KV S/S with 33/11 KV transformer

27

### 33KV Pole Mounted Breaker protecting a 10 MVA 33/11 KV Transformer

28

### Cost Comparison between conventional substation and substation with Auto-Reclosers

**i. With Auto-Reclosers**

SL#	Particular	No	Unit Price	Total
1	33 kV Auto-Reclosers	6	1,000,000	6,000,000
2	10 Meter Poles	16	10,000	160,000
3	Channels, fittings etc			50,000
Total				6,210,000

**ii. Conventional Substation**

SL#	Particular	No	Unit Price	Total
1	33 kV switchgears with C.T.P.T,Relays, commissioning	6	1,797,867	10,787,202
2	Civil Works			7,015,480
3	Earthing, LV ac system, etc			361,278
Total				18,163,960

29

### Fault at Sephu Area with ARCB

30

### Outage time with ARCB

Date	Time	Location	SL	SS	ARCBS	Cost	Fault Location	Remarks
08-08-13	13:30	WALC	closed	WALC	4 open	0.00	Not known	Disconnection of WALS. Test charges
08-08-13	13:30	WALC	closed	WALC	4 open	0.00	Not known	Disconnection of WALS. Test charges
08-08-13	13:30	WALC	closed	WALC	4 open	0.00	Not known	Check the state of bus and main bus and main bus
08-08-13	13:30	WALC	closed	WALC	4 open	0.00	Not known	Check the state of bus and main bus and main bus
08-08-13	13:30	WALC	closed	WALC	4 open	0.00	Not known	Check the state of bus and main bus and main bus
08-08-13	13:30	WALC	closed	WALC	4 open	0.00	Not known	Check the state of bus and main bus and main bus

For same date

31

### Reliability Indices with ARCB

- Fault at Sephu area
- ARCB-4 tripped
- 420 Customers

**Reliability Indices without ARCB**

SL#	Reliability Indices	SAIFI	SAIDI
1	Under ESD Control	0.12	1.02

Total number of customer in the feeder: 3620.00  
Sum of customer interruption duration (Customer interrupted \* Duration): 3675  
Total number of customer interrupted: 420

32

### Reliability Indices Comparison

Sl.#	Reliability Indices	SAIFI	SAIDI
1	Existing System	6.17	7.33
2	With ARCB	0.12	1.02
<b>Improvement with ARCB</b>		<b>98.1%</b>	<b>86.1%</b>

33

### Cost Implication for this feeder

SL#	Equipment	Nos	Unit Rate	Total(Nu)
1	Auto-reclosers	2	1,000,000	2,000,000
				2,000,000

34

### Where to use Autoreclosers?

- If the line length is more than 20 km from the T-off or Mid point (more customers, passes through similar terrain, possibility of more transient faults etc)
- Use if it is for Loop Automation
- Use if it is for substations
- For others short lines where there is possibility of transient faults, tie lines between two ESDs, urban-rural segregating line etc. it can be used case by case.

35

### B. Line Fault Indicator and LBS

FLI-2 Fault Indicators  
1. Ring of six LEDs indicates line fault  
2. Change flag; also indicates line fault

36

Technical Index	Overhead earth & short-circuit fault indicator	Overhead earth & short-circuit fault indicator	Overhead short-circuit fault indicator	Overhead short-circuit fault indicator
Model	HESI-FG	HESI-FLG	HSFI-FS	HSFI-FLS
Applicable voltage	6-35 kV	6-35 kV	6-35 kV	6-35 kV
Applicable wire cross-section	16-400 sq mm	16-400 sq mm	16-400 sq mm	16-400 sq mm
Times of actuating	Over 5000	Over 5000	Over 5000	Over 5000
Maximum elevation	4000 m	4000 m	4000 m	4000 m
Indication mode	Red flag	Red flag + LED flash	Red flag	Red flag + LED flash

37

### Advantages of using Fault Indicator

- It will indicate faulty section of the line
- Cheap
- Easy for Installation

### Disadvantages

- It will not isolate the faulty area
- Crew has to do visual inspection

38

### Advantages of using Load Break Switch

- Faulty section of the line can be further narrowed by isolating with LBS
- Cheap
- Easy for Installation

### Disadvantages

- Have to operate manually

39

### Fault at Sephu area with Fault Indicator

40

### Travel time from Service centers to Fault Indicators

Service Center	Fault Indicator/LBS	Travel Time(Min)
Dangchu Service Center	L13 and L14	15
Sephu Service Center	L15	30
Santengang Service Center	L6 and L7	25
Wangdue Service Center	L5	30

41

### Outage time with Fault Indicator

Date	Time	Location	SL	SS	ARCBS	Cost	Fault Location	Remarks
08-08-13	13:30	WALC	closed	WALC	4 open	0.00	Not known	Test charges
08-08-13	13:30	WALC	closed	WALC	4 open	0.00	Not known	Test charges

At 7 am, Service centers at Dangchu area, Sephu Area and Santenggang area to check the status of fault indicator of their area. At the same time CSO Wangdue will check the local area it should be able to inform and locate the fault within the response time of 30 minutes.

42

### Reliability Indices Comparison

Sl.#	Reliability Indices	SAIFI	SAIDI
1	without Fault Indicator (Existing)	5.06	6.79
2	with fault Indicator	1	5.33
Improvement with fault Indicator		80.23%	21.5%

43

### Cost Implication for this feeder

Sl.#	Equipment	Nos	Unit Rate	Total(Nu)
1	Fault Indicator	15	45,000	675,000
				675,000

44

### Recommendation for LBS and Fault Indicator


- ✓ Install LBS after every 10 kms (Existing standard)
- ✓ Install LBS & Fault Indicator on spur lines having more than 5 km
- ✓ No fault indicator after ARCB
- ✓ depend on the probability of faults
- ✓ As per customer base
- Fault Indicators must be installed in the visible areas

45

### C. ARCB and Fault Indicator

- Install two ARCBs
- Install 5 fault indicators

46



### Reliability Indices Comparison

Sl.#	Reliability Indices	SAIFI	SAIDI
1	Existing System	6.17	7.33
2	With ARCB & Fault Indicator	0.12	1.02
Improvement with ARCB		98.1%	86.1%

48

### Cost Implication for this feeder

Sl.#	Equipment	Nos	Unit Rate	Total(Nu)
1	Auto-reclosers	2	1,000,000	2,000,000
2	Fault Indicator	5	45,000	225,000
				2,225,000

\*\*\* Since Auto-Reclosers have been already purchased through RE, actual cost implication is less than Nu. 0.225 million

49

### Comparison

Reliability Indices	Existing (Only LBS)	With ARCB	With Fault Indicator	With ARCB & Fault Indicator
SAIFI	5.06	0.12	1	0.12
SAIDI	6.79	1.02	5.55	1.02
Cost	0	2 M	0.675M	2.225 M

50

### Proposal

- A. By Installing Auto-reclosers
- B. Installing Fault Indicator
- C. ARCB and Fault Indicator(Selected)

51

### Implementation Plan

- ARCB is already purchased by RE. Can be installed this year itself
- Fault Indicator-ESD Punakha already purchased fault indicators, can be used for this pilot project.
- \*\*\*Thus, should be able to implement this year itself!
- Study with other feeders from different regions.
- Present during review presentation

52

### Implementation Plan: 1

Sl.#	Action Plan	2012			2013													
		Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
1	Final presentation to JICA Expert & Management																	
2	Approval of the PI from JICA Expert & Management																	
3	Collection materials from PSD																	
4	Installation & Commissioning																	
5	Monitoring of the project																	
6	First performance presentation to the Management																	
7	Monitoring of the project																	
8	Second performance presentation to the Management																	
9	Monitoring of the project																	
10	Third performance presentation to the Management																	
11	If the project is successful, second approval to roll out to ESD's																	
12	Budget proposal by ESD																	

53

### Thank you

54

## Theme 3

### Calculation Methodology for Correct Reliability Indices from Customer View Point

by Team 3

55

### Presentation Outline

- Aims & Objective
- Rationale Behind this Study
- Improvement Measures & Result Discussion
- Future work & Conclusion



56

### Aims & Objectives

- ❖ Aim & Objective for BPC Management
- ❖ Aim & Objective for PI Solving Study
- ❖ Grasp the Real SAIDI of the System
- ✓ Set the Real SAIDI of the System
- ✓ Analyze the Real SAIDI of the System
- ✓ Develop the Real SAIDI of the System
- ✓ Find the Real SAIDI of the System
- ✓ Grasp the Real SAIDI of the System

❖ Real Time Target Setting/Benchmarking

57



### Rationale


✓ Review of Customer Satisfaction Survey

Particulars	Power Supply Reliability	Bill delivery on time	Response to complaints	BPC staff behavior
Importance level rating of services	4.79	4.60	4.60	4.48
Satisfaction level rating of services	4.11	4.43	3.96	4.13
Difference in Gap	0.68	0.17	0.64	0.35

### Current Badness (Systemic Error)

- Present practice of Outage Data Keeping/Reporting seems improper
- Reliability performance is linked with PBIS without proper tool for its improvement
- Exclusion of Planned Outages in Reliability Computation & 'Major Events' are not well defined
- Improper Target Setting Process/Methodology


Difference in Perception of Reliability between Utility & Customer



- ### Improvement Measures
- Design of New Format for Data Keeping/Recording
  - Data Management Process
  - Defining of Planned outage and Major Events
  - Formulation of Reliability Improvement Guidelines
  - Reliability Target Setting/Benchmarking

### Improvement Measures #1

Design of New Format for Data Keeping/Recording



### Result Discussion



✓ "Near to Accurate" (real) SAIDI can be captured from new system

SAIFI Comparison

Month	SAIFI (Current Practice)	SAIFI (New Practice)
April 2012	2	2
May 2012	0.91	4.44
June 2012	1	2.78
July 2012	1	7.43

SAIDI Comparison

Month	SAIDI (Current Practice)	SAIDI (New Practice)
April 2012	0.66	1
May 2012	11.60	16.28
June 2012	1.25	6.88
July 2012	3.5	42.8



- ### Improvement Measures #3
- Reliability Improvement Guidelines
    - Identify and Target Critical Circuits
    - Identify the Major Causes of Faults & apply Mitigation measures
    - Application of Protection and Switching Devices
    - Automation
    - Restoration Practices
    - Maintenance and Inspection

- ### Improvement Measures #4
- Planned Outage & Major Events
    - Major Event Days needs to be well defined (under process)
    - Planned Outages need to be computed separately with separate Reliability Index
      - SAIDI for planned outages are almost equal to unplanned outages (as per past reports)
      - ESDs style of handling planned outages seems disorganized and also asymmetric among ESDs
      - CAIDI will be used as a Index to measure the performance for each ESDs (internally)
    - Develop planned outage handling procedure in more organized format (under Process)

- ### Improvement Measures #5
- Reliability Target Setting and Benchmarking (2 options)
    - Targets Based on 'Acceptable' past performance
    - Targets based on budget constraints
  - However Target Setting /Benchmarking will be done as per our action plan

### Action Plan

Activities	April 2012 to Dec.2012	Jan.2013 to Dec.2013	Jan.2014
Data Collection for Dagana	Green		
Awareness to ESD Managers		Blue	
Rollout to other ESDs		Red	
Data Review			Blue
Target Setting/ Benchmarking			Purple


- ### Conclusion/Recommendation
- New format is proposed since current format captures only about 50% of the total interruptions.
  - Our aim is to capture outages till DT level, but it might be difficult with present manpower strength. Therefore, we have two options:
    - Meter all DTs through Smart meters???
    - Track outage data till 33/11kV s/st. or identify ESD-wise point of data recording, like till ARCB or feeder LBS point.
  - "We forecast, reliability will further decrease for few years due to more infrastructure, customer, 'increase in distribution voltage level'. Hence target setting has to be done considering all these factors.

- ### Conclusion/Recommendation
- Till proper target setting is done and reliability improvement guidelines are formulated, it may not be wise to link with incentives (PBIS).
  - Planned outages need to be recorded and computed separately with planned outage handling procedure that needs to be formulated and practiced.



# Theme 4

## PI SOLVING ACTIVITY




**TO IDENTIFY REAL TECHNICAL LOSS OF DISTRIBUTION SYSTEM**

Team - 4

### TEAM MEMBERS

1. Ghana Shyam Tamang, DCSD (Team Leader)
2. Lobzang Yeshe, TD (Member)
3. Kinzang Lhamo, EDCD (Member)
4. Kinley Gyem, EDCD (Member)
5. Sushil Pradhan, FAS (Member)
6. Sangay Wangdi, FAS (Member)



**JICA EXPERT: JUNICHI OHISHI**

### PRESENTATION OUTLINE

- Background
- Present Problems with regards to energy loss
- Current methodology for calculating loss
- Case Study - ESD Lhuentse
- Causes of High & Inconsistent Energy Loss
- Fish Bone Analysis - Causes of Loss
- Approach adopted for Determination of REAL TECHNICAL LOSS
- Relevant Formulas for Numerical Calculation of Technical Loss:
- Identification of Pilot Feeder
- Single Line Diagram of Pilot Feeder
- Determination of Technical Loss using Numerical Method
- Results
- Conclusion/Recommendation
- Future plans and benefits

### BACKGROUND

1. Energy Loss is REVENUE LOSS to BPC.
2. In 2011, Energy (MV & LV) loss: 31,393,773.27 kWh  
Loss (MV & LV) in Percentage : 6.38 %  
Approx. Revenue loss: Nu. **53.400** million
3. 1% reduction in loss (6.38% → 5.38%)  
Revenue saving : Nu. **8.4** million!  
0.38% reduction in loss (6.38% → 6.00%)  
Revenue saving opportunity: Nu. **3.2** million!!
4. BPC needs to reduce energy loss to reduce revenue loss.

5. System of loss target setting tied up with the PBIS was introduced and the concept of ratcheting helped to reduce the loss (MV & LV) significantly from 16% in 2004 to 6.38% in 2011.
6. For further reduction of loss, it has become necessary to set **REALISTIC** YEARLY LOSS TARGETS for different ESDs.
7. BPC should determine the allowable Technical Loss in the Distribution System.

1. Determination of Technical Loss of the Distribution System requires a detailed study of power loss that take place in the electrical DISTRIBUTION network mainly due to the flow of current.

**Electrical Distribution Network consists of:**

- MV and LV Lines (both overhead and underground)
- Distribution Transformers
- Service Wires

**Difficulties involved:**

1. Current flowing in the network is not constant and assumptions are necessary
2. Distribution network is very vast and difficult to map

### Revenue Savings with 1% Loss Reduction- excluding ESDs with loss less than 5%

DIVISIONS	Loss % (2011)	Revenue loss (millions Nu.)	Revenue loss with 1% reduction in loss	Savings (millions Nu.)
Bumthang	12.41%	1.78	1.64	0.14
Dagana	10.00%	1.60	1.52	0.08
Gelephu	8.48%	2.38	2.10	0.28
Lha	4.24%	0.73	0.73	0.00
Lhuentse	14.12%	0.76	0.70	0.06
Monjar	11.82%	1.90	1.74	0.16
Pana	6.84%	4.19	3.97	0.21
Pemagatshel	11.28%	0.82	0.75	0.07
Phuntsholing	0.35%	0.07	0.07	0.00
Punakha	6.59%	1.44	1.22	0.22
Samtse	3.41%	2.63	2.63	0.00
S. Jongkhar	15.42%	3.68	3.44	0.24
Trashigang	12.72%	2.77	2.55	0.22
Thimphu	8.86%	25.42	2.84	(2.58)
Troms	11.56%	0.73	0.67	0.06
Tsirang	6.98%	0.49	0.42	0.07
Trashiyangtse	7.35%	0.33	0.36	0.07
Wangdue	1.34%	0.55	0.55	0.00
Zhemgang	2.17%	0.11	0.11	0.00
<b>% Loss (6.38%)</b>	<b>6.38%</b>	<b>53.37</b>	<b>48.41</b>	<b>(4.96)</b>

### Present Problems with regards to energy loss:

- BPC's distribution network has grown in size over the years. Its distribution lines is over 9,500 km and the total number of distribution transformers installed stands at 3,233 as on Dec'11.
- Yearly Aggregate Technical & Commercial (AT&C) Loss of different ESDs - very inconsistent
- BPC is not able to set **REALISTIC YEARLY LOSS TARGET** for different ESDs.
- No system of monitoring energy loss feeder wise.
- BPC lacks strategy to reduce distribution system loss further.


### CURRENT METHODOLOGY for determination of monthly AT&C loss

$$\text{Loss\%} = \frac{\text{Energy input} - \text{Energy Sold}}{\text{Energy Input}} \times 100$$

Where, **Energy Input** = Total energy billed by TD + BPC's Internal Generation  
**Energy Sold** = Energy billed to customers

**Problems with the current methodology:**

1. Not possible to pin point the section which is contributing to high loss
2. As a result, difficult to work out any suitable counter measures for reduction of loss




### Feeder-wise loss analysis

**Abstract**

Sl. no	Feeder	Purchase (May '11 - March '12)	Sale (May '11 - March '12)	(%) Loss
1	Lhuentse	1,653,402.00	1,411,904.80	14.61%
2	Tangmachu	404,660.00	220,620.80	<b>45.48%</b>
3	Minjey	204,860.00	179,462.00	12.40%
4	Gorgan	847,114.00	685,364.12	19.09%
5	Colony	35,911.20	11,012.00	<b>69.34%</b>
<b>Total</b>		<b>3,153,407.60</b>	<b>2,515,824.12</b>	<b>20.22%</b>

### Causes for High and Inconsistent Energy Loss :

- Not reading energy meters every month
- Reading manipulation
- Inaccurate or defective meters
- Reading time difference
- Pilferage



### Approach adopted for determination of REAL TECHNICAL LOSS of DISTRIBUTION SYSTEM

- Identify a feeder for the pilot study
- Map the details of the identified feeder (poles, conductors, transformers and customers)
- Draw single line diagram of the pilot feeder
- Determine Technical Loss using various techniques
- Weigh pros and cons of various methods and recommend the most suitable option

### Relevant Formulas for Numerical Calculation of Technical Loss:

#### 1. Power Loss in the MV/LV LINES & CABLES


Power Loss in the MV/LV lines and Cables takes place due to the electric current that flows through them. Basically, power loss can be determined by:  **$W = I^2 r L$  [W]**

**Where:** **W:** Power Loss in Watt  
**I:** Current [A]  
**r:** Resistance per Unit Length [Ω/m]  
**L:** Length of Distribution Line [m]

2. Concentrated load method:  
 **$W = N(r^2 L^3)/1000$**
3. Equally distributed load method:  
 **$W = N(r^2 L^3)(3^*1000)$**

**Where:** **W:** Power Loss [w]  
**N:** Coefficient  
**N = 2:** Single Phase Two Line  
**N = 3:** Three Phase Three Line  
**L:** Length of Distribution Line [m]  
**I:** Current [A]  
**r:** Resistance of line per km line [Ω/km]

### 4. Power Loss in the Distribution Transformer






**$W_T = W_c + W_t$**

**$W_c = (P/T)^2 W_{c0}$**

**W<sub>T</sub> :** Total Power Loss of DT [W]  
**W<sub>c</sub> :** Copper Loss at Rated Output [W]  
**W<sub>t</sub> :** Copper Loss (Changed by Loading) [W]  
**W<sub>i</sub> :** Iron Loss (Constant value) [W]  
Each coefficient is specified by manufacturer

**P:** Output [kVA]  
**T:** Rated Output [kVA]





### LV System

Transformer	Iron Loss (W)	Full load Copper Loss (W)	Maximum Line length (m)	1,500.00
16 kVA	75.00	300.00	Average Length (m)	800.00
25 kVA	125.00	425.00		
63 kVA	175.00	1,300.00		
125 kVA	300.00	1,700.00	Average number of Feeder	2.00

Service Cable (4.6 & 10 Sq mm) generally used in rural areas

Resistance of 6 sq mm (Copper) cable considered for the study	2.682	Ohm/km
Total customers of Minjey feeder	183	Numbers
Average length of service cable	31	Meters

### Results of the Numerical Calculation

#### OPTION - A

#### 1. MV Line Loss (Calculated section wise)

Sl. No.	Section Type	Line Type	Resistance (Ohm)	Length (km)	IR <sup>2</sup> (%)	Current (A)	Line Loss (kW)
1	Trunk	Dwg	0.2747	7.60	0%	35	0.00910
2	Trunk	Rubber	0.0040	0.0040	0%	35	0.00042
3	Trunk	Rubber	0.5447	0.0040	0%	69	0.122
4	Trunk	Rubber	0.5448	0.014	0%	124	0.0666
5	Trunk	Rubber	0.5448	0.080	0%	15	0.0040
6	Trunk	Rubber	0.5448	0.043	0%	26	0.0025
Total			3.0610	8.08		308	0.2083

#### 2. Transformer Loss

Sl. No.	kVA	Iron Loss (Watt)	Copper Loss (Watt)	Loading (%)	IR <sup>2</sup> (%)	Copper Loss (kW)	Iron Loss (kW)
1	16	75	300	23.08%	0%	0.0202	0.075
2	25	125	425	23.08%	0%	0.0675	0.125
3	63	175	1300	23.08%	0%	0.0877	0.175
4	125	300	1700	23.08%	0%	0.1147	0.300
5	16	75	300	23.08%	0%	0.0202	0.075
6	25	125	425	23.08%	0%	0.0675	0.125
Total	308	770	3400	23.08%	0%	0.3788	0.875

Grand Total Energy = 448.44 kWh

#### 3. LV Loss

#### Option 1: Concentrated load

Sl. No.	TR (kVA)	IR <sup>2</sup> (%)	Current (A)	Line Type	Resistance (Ohm)	Average Length (km)	No. of Outgoing Feeder	LV Loss (kW)
1	16	0%	178	LV ABC Sqmm	0.640	800	2	0.027
2	25	0%	277	LV ABC Sqmm	0.400	800	2	0.308
3	63	0%	427	LV ABC Sqmm	0.240	800	2	0.368
4	125	0%	498	LV ABC Sqmm	0.160	800	2	0.572
5	25	0%	277	LV ABC Sqmm	0.400	800	2	0.308
6	16	0%	178	LV ABC Sqmm	0.640	800	2	0.027
Total	308		1700					0.2083

#### Distributed Load


#### Option 2: Equal Distributed Load

Sl. No.	TR (kVA)	IR <sup>2</sup> (%)	Current (A)	Line Type	Resistance (Ohm)	Line length (km)	No. of Outgoing Feeder	LV Loss (kW)
1	16	0%	178	LV ABC Sqmm	0.640	800	2	0.028
2	25	0%	277	LV ABC Sqmm	0.400	800	2	0.113
3	63	0%	427	LV ABC Sqmm	0.240	800	2	0.123
4	125	0%	498	LV ABC Sqmm	0.160	800	2	0.124
5	25	0%	277	LV ABC Sqmm	0.400	800	2	0.123
6	16	0%	178	LV ABC Sqmm	0.640	800	2	0.028
Total	308		1700					0.521

#### 4. Service Cable Loss

Sl. No.	Feeder Type	No. of Customers	Load per customer (W)	IR <sup>2</sup> (%)	Line Type	Resistance (Ohm)	Average Line length (km)	Current (A)	Service Cable Loss (kW)
1	10	14	811	0%	Service Cable Sqmm	1.803	16	1.13	0.020
2	10	14	546	0%	Service Cable Sqmm	1.803	16	1.40	0.020
3	10	14	451	0%	Service Cable Sqmm	1.803	16	1.53	0.020
4	10	14	475	0%	Service Cable Sqmm	1.803	16	1.46	0.020
5	20	14	590	0%	Service Cable Sqmm	1.803	16	1.65	0.020
6	10	14	546	0%	Service Cable Sqmm	1.803	16	1.76	0.020
Total									0.100

Grand Total Energy = 768.30 kWh



#### Option - B

1. MV Line Loss : Same as Method A = 288.59 kWh  
2. Transformer Loss : Same as Method A = 9480.46 kWh





#### 3. LV Loss

Sl. No.	TR (kVA)	IR <sup>2</sup> (%)	Current (A)	Line Type	Resistance (Ohm)	Line length (km)	No. of Outgoing Feeder	LV Loss (kW)
1	16	0%	178	LV ABC Sqmm	0.640	800	2	0.028
2	25	0%	277	LV ABC Sqmm	0.400	800	2	0.113
3	63	0%	427	LV ABC Sqmm	0.240	800	2	0.123
4	125	0%	498	LV ABC Sqmm	0.160	800	2	0.124
5	25	0%	277	LV ABC Sqmm	0.400	800	2	0.123
6	16	0%	178	LV ABC Sqmm	0.640	800	2	0.028
Total	308		1700					0.521

#### Option 3: Equal Distributed Load

Sl. No.	TR (kVA)	IR <sup>2</sup> (%)	Current (A)	Line Type	Resistance (Ohm)	Line length (km)	No. of Outgoing Feeder	LV Loss (kW)
1	16	0%	178	LV ABC Sqmm	0.640	800	2	0.028
2	25	0%	277	LV ABC Sqmm	0.400	800	2	0.113
3	63	0%	427	LV ABC Sqmm	0.240	800	2	0.123
4	125	0%	498	LV ABC Sqmm	0.160	800	2	0.124
5	25	0%	277	LV ABC Sqmm	0.400	800	2	0.123
6	16	0%	178	LV ABC Sqmm	0.640	800	2	0.028
Total	308		1700					0.521

4. Service Cable Loss : Same as that of Method A = 798.30 kWh



### Conclusion/Recommendation


Technical loss of the pilot feeder was calculated using Numerical Technique. Two options were explored; Option-A: Assuming average length of LV lines and Option-B: Assuming actual length of LV lines.

Option -A is simple to understand and easier to implement. The result of both the options are comparable. Thus, considering the complexity of the network than the pilot feeder, Option-A with distributed load method is recommended for computing technical loss of the distribution system.

- ### Future Plans and Benefits
- All the DTs of the pilot feeder can be metered. This will help to compare the computed loss with that of the actual loss recorded by these meters.
  - Ask all ESDs to properly map the distribution facilities.
  - Once the distribution facilities are mapped by all ESDs, compute technical loss.
  - Set yearly energy loss targets based on the loss so computed.
  - Loss targets can be revised depending upon the load
  - ESDs would be able to monitor energy loss feeder wise, narrow down and pin point problematic areas so that effective loss reduction measures can be implemented.

**Thank you for your patience**

# Theme 5



## PI Activity on Improvement of Billing and Collection System in Rural Areas

### Team 5

Bhutan Power Corporation Limited

### OUTLINE

- Team Members
- Reasons for Prioritizing
- Objective of PI
- Result of Site Survey
- Current Situation
- Causes
- Problems
- Options Available
- Conclusion
- Implementation Schedule

Bhutan Power Corporation Limited

### Team Members








Mr. Akhiro Hayashi

Bhutan Power Corporation Limited

### Reasons for prioritizing

- B&C is the core functions of BPC
- The present cost of MB&C is high
- To maintain CSI of 3.7
- Within threshold of 3% for Distribution for O&M (Employee Cost, O&M & Administrative and Other Expenses)
- Need to come up with cost effective solutions to improve profitability and better customer services

Bhutan Power Corporation Limited


### Result of Site Survey

- Monthly average bill : 61% below Nu. 100
- 79% of customers prefer on the spot payment
- 42% of customers are facing problems for making payment (especially due to long distance)
- 61% is non holders of bank account (Those who are non holders, 40% of them are willing to open an account)
- 70% prefers to pay using mobile voucher and the rest with bank account
- 97% of customers agrees to send meter reading via SMS
- 99% of customers are interested to use POS facility for bill payment

Bhutan Power Corporation Limited

### Current Situation

Time allocation of Multitasking Staff



Bhutan Power Corporation Limited

### Contd...

MBC Cost

ESD Tsiarang	SI #	Service Center	No. of Customers	Revenue Collected	Unit Consumed	Total Expenses	Cost of Metering & Billing / customer	Cost of Collection / customer	Expenses/kwh
1	Kikhorthing/Rangthangling	1574	491,826	337,884	15,231	9,608	0	0.05	
2	Tsiarangtoe	69	30,430	20,953	8,512	94,38	28,99	0.41	

Bhutan Power Corporation Limited

### Contd...

MBC Cost

ESD Thimphu	SI #	Service Center	No. of Customers	Revenue Collected	Unit Consumed	Total Expenses	Cost of Metering & Billing / customer	Cost of Collection / customer	Expenses/kwh
1	Lanjopha	439	497,169	280,332	16,550	37.7	0	0.06	
2	Genechha	630	27,399	222,573	16,689	23,84	2.65	0.07	

Bhutan Power Corporation Limited

### Causes

- Scattered Customers (1 KM – 41 KMs from ESD)
- Low consumption
- Limited Manpower
- Higher cost of Electrification
- Tariff regulated by Bhutan Electricity Authority
- Have to do Site Collection (Nu.70 – Nu.300)

Bhutan Power Corporation Limited

### Problems

- Meter reading & billing takes time due to limited resources
- Meter reading and billing is done manually
- Not many options available for customers for payment
- Cannot do site collection at all Geogs
- Cost of making the payment is high compared to bill amount

Bhutan Power Corporation Limited

### Options Available

#### Meter Reading & Billing

- Send meter reading by customer by SMS or e mails
  - Sign an agreement with the customers
  - Customer submits the reading
  - Bill sent back to customer via SMS
  - Provide incentive for sending message

Bhutan Power Corporation Limited


### 2. Read Meters once in 3 months

- MT staff will get time for O&M works
- Difficult to calculate monthly loss figure

Bhutan Power Corporation Limited


### 3. Prepaid Meters

- Centralized Vending Server
- Smart Pre Payment Energy Meter
- Consumer Interface Unit (CIU)
- Base Computer Software



Bhutan Power Corporation Limited

### 4. RF Network (other technologies)



Bhutan Power Corporation Limited

### Collection


- Direct Debit from Bank
  - Need to have Bank Account
  - Sign agreement with BPC and Bank
  - Monthly bill sent to Bank
  - Deduction done by Bank on behalf of the registered customer

Bhutan Power Corporation Limited

### 2. Mobile Payment (BT)

- Very convenient for the customers
- Customers are willing to opt this
- Cost sharing / Transaction

Bhutan Power Corporation Limited



### 4. Proposal from BDBL

- > Has 29 branches (out of which 3 are offline)
- > Offering the following services
  - > Internet Banking
  - > SMS Banking
  - > PDA Banking
  - > Over the counter

Bhutan Power Corporation Limited

### 5. Point of Sales (BoB)

Bhutan Power Corporation Limited

### 6. Counter Sharing

- ❖ Utilities
- ❖ Geog Offices
- ❖ Banks
- ❖ Connectivity
- ❖ Additional Manpower

Bhutan Power Corporation Limited

### Options Available

#### 1. Meter Reading & Billing

Sl.No	Options Available	Criteria for Selection					Total	Ranking
		Cost	Benefit	Customers Convenience	Implementing Issues	Technology		
1	Through SMS or E-mails	7	7	8	9	5	36	1
2	RF Meters once in 3 months	8	6	5	4	8	31	3
3	Pre Payment Meters	2	9	5	7	7	30	4
4	RF meters (Other Technologies)	5	8	8	7	6	34	2

Rating  
1 - Very Low  
10 - Very High

Bhutan Power Corporation Limited

### 2. Collection

Sl. No	Options Available	Criteria for Selection					Total	Ranking
		Cost	Benefit	Customers Convenience	Implementing Issues	Technological difficulty		
1	Direct Debit from Bank	7	8	7	7	7	44	1
2	Mobile Payment (BT)	5	8	8	6	6	37	2
3	Mobile Payment (Indo Group)	6	8	8	6	6	36	3
4	Through BDBL	6	6	8	6	5	34	5
5	Point of Sales	7	5	8	6	5	35	4
6	Counter Sharing	7	7	6	4	5	34	5

Rating  
1 - Very Low  
10 - Very High

Bhutan Power Corporation Limited

### Conclusion

#### Meter Reading & Billing

- ❑ Through SMS or E mails

#### Collection

- ❑ Direct debit from Bank

Other options will be implemented together with the above options

Bhutan Power Corporation Limited

### Implementation Cost

#### Meter Reading & Billing

1. Send meter reading by customers/representative by SMS or e mails
  - ❖ Nu. 100,000 annually as AMC for SMTP server
  - ❖ Nu. 10, 000 per month for 10, 000 SMS. Additional charges for more than 10, 000 SMS
  - ❖ Approx Nu. 50, 000 for additional lease line
  - ❖ Approx Nu. 30, 000 per month as bandwidth service charge
  - ❖ Total Cost: Nu. 630,000

Bhutan Power Corporation Limited

### Works to be Initiated

#### Meter Reading & Billing

1. Send meter reading by customers/representative by SMS or e mails
  - ❖ Have additional lease line pulled to the SMS gateway server
  - ❖ Select the vendor and carry out the detail blueprinting based on requirements
  - ❖ Sign an agreement with the customers/representative
  - ❖ Provide incentive for sending message

Bhutan Power Corporation Limited

### Works to be Initiated

#### Collection

1. Direct Debit from Bank
  - ❖ Sign tri party agreement between BPC, Banks and Customers
  - ❖ Work on Integration
  - ❖ BPC to send the bills to Banks
  - ❖ Banks to deposit that amount in BPC account

Bhutan Power Corporation Limited

S/N	Work Details	Sept 2012	Oct 2012	Nov 2012	Dec 2012	Jan 2013	Feb 2013	Mar 2013	Apr 2013	May 2013	Jun 2013	Jul 2013	Aug 2013	Sep 2013	Oct 2013	Nov 2013	Dec 2013
1	Finalization of the Management																
2	Finalize the report based on feedback																
3	Prepare the budget for the project																
4	Discussion with other stakeholders for integration																
5	Finalize the integration's technical cost																
6	Initiate the work and sign integration's technical cost																
7	Review materials																
8	Installation																
9	Monitoring/Testing																
10	Prepare for budget for integration of technical cost																
11	Complete integration																

Bhutan Power Corporation Limited

## Thank You & Tashi Delek

Bhutan Power Corporation Limited

### Cost

#### Meter Reading & Billing

2. RF meters (Other Technologies)
  - ❖ Single phase meter – Nu. 2,000 per meter
  - ❖ Data concentrator with RF and GPRS communication – Nu. 20, 000
  - ❖ Central Server Software – Nu. 500, 000
  - ❖ Data Acquisition Server – Nu. 485, 000
  - ❖ AMC – Nu. 150, 000
  - ❖ Training – Nu. 700, 000

Bhutan Power Corporation Limited

Bhutan Power Corporation Limited


# Theme 6a

**PI Solving Activity 2013**

**Group 6A:**  
**"Study on existing manpower and management of existing facilities under DCSD"**

**Members:**  
 1. Didi Rani Adhikari, Manager, ESD Panahua.  
 2. Kinlay Wangmo, Asst. Manager, HRD.  
 3. Sangay Tenzin, Manager, DCSD HQ.  
 4. Tal Man Pradhan, Manager, Finance Department.

**Team Advisor: Mr. Nobor Seki, JICA/TEPCO**



### Current Badness

- Manpower distribution unequal.
- Overstaffing and understaffing
- Heavy work load and light work load.
- Budget proposal for facilities increasing every year.
- No benchmark in distribution of manpower and facilities.

### Objectives

- Optimal distribution of manpower & facilities.
- Efficient & effective utilization of manpower & facilities.
- Get the best practice of other electric utilities.
- Reduce the unnecessary cost.

### Manpower Analysis

- Job Analysis.
- Use of statistical & mathematical models in manpower Analysis.
- Judgement (managerial) Analysis - Thomas D. Murray State University.
- Trend Analysis
- For future studies: **Multiple Regression Analysis, Data Envelopment Analysis.**

### Segmentation of Manpower

- Management
  - Manager
  - Office Asst Cum Dispatcher
  - Finance Officer/Accountant
  - Sweeper cum Gardener
  - Supervisor/In-charges
- Concentrate more on Multitask, O&M & Revenue staff



### 1. Internal Procedure Proposal

- Strict manpower recruitment process.
- Review overall manpower planning every three years (includes all stakeholders).
- Every Employee to have the JD/JA (Third country survey).
- Managers - Accountability & Responsibility for manpower planning.
- New manpower requisition form, Job analysis form (Third country survey).

### Requisition Form

Position Title: \_\_\_\_\_  
 Reporting Manager: \_\_\_\_\_  
 Salary Range: \_\_\_\_\_  
 Job Description: (Attach in a separate sheet (download the form from the SPC Website))

State key drivers for creation of this position or critical business issues being addressed:

Outline the unique knowledge, skills and qualities, if possible:

Describe any knowledge benefits:

Training and strength of the core area/department:

Requirements: Equipment/Additional equipment/Other:

Submitted by the Manager: \_\_\_\_\_  
 Comments & Recommendation by General Manager: \_\_\_\_\_  
 Comments & Recommendation by CEO: \_\_\_\_\_  
 Comments & Recommendation by HRD: \_\_\_\_\_  
 Approved by CEO: \_\_\_\_\_

### Job Analysis

The job analysis should comprise of detailed job description of the post, job specification (knowledge, skills and abilities) required to carry out the job and roles and responsibilities of the post along with the post.

The job analysis has to be provided for each individual.

**Job Title:** \_\_\_\_\_

**Job Description and Roles & Responsibilities:**

The job description is basically an outline of "how the job fits in to the company. First, it should be used to recruit the right people, responsibilities and duties, then, identify job content or summary describing the position's major and minor duties. Finally, define how the job fits into the company's department structure.

**Job Specification:**


The job specification describes the personal requirements you expect from the employee to do the job. It includes education, experience, knowledge and specialized skills or managerial require. Also, any physical or other special requirements associated with the job, as well as any important traits.

**Requisition Specification:**

**Education:** \_\_\_\_\_


**Experience:** \_\_\_\_\_

**Other Notes:** \_\_\_\_\_



### 2. Learning & growth

- Multi-Task Staff**
  - Line length
  - Number of Customers
  - Number of transformers
  - Segregate ESD:
    - Rural
    - Urban
- O&M Staff**
  - Line length
  - Number of Customers
  - Number of transformers
  - Segregate ESD:
    - Rural
    - Urban
- Revenue staff**
  - Number of customers



### Multitask staff Analysis

Dimension	Mean	Weight	SD	CV	% Variance	Wgt. Variance	% Variance	Wgt. Variance	% Variance	Wgt. Variance	% Variance
Customer/Staff	42.8	25%	16.0	48.1%	4%	27%	22%	12%	12%	12%	12%
Transformer/Staff	13.8	22%	5.0	36.2%	4%	16%	27%	33%	17%	17%	17%
Line length/Staff	38.8	22%	13.0	33.5%	17%	29%	16%	16%	16%	16%	16%
<b>Result</b>											



### Multitask staff Analysis Result

Division	Cust./person	Trans./person	Line Length/Person	Manpower as per analysis	Requisition by ESDs
ESD,Burnthang	468.50	13.88	23.78	-	3.00
ESD,Dagana	636.33	26.83	58.46	4.00	8.00
ESD,Jana	318.56	8.67	29.89	2.00	6.00
ESD,Lhunthee	310.55	15.45	48.99	2.00	6.00
ESD,P/Ganshel	477.63	15.50	53.47	2.00	4.00
ESD,Punthak	392.21	11.50	34.76	1.00	3.00
ESD,Samsite	430.82	14.64	59.24	3.00	7.00
ESD,TGang	346.97	9.25	34.08	6.00	2.00
ESD,Tromsaga	478.56	16.56	46.14	2.00	-
ESD,Tromsaga	427.83	6.5	11.82	1.00	2.00
ESD,Tromsaga	392.00	10.08	32.92	1.00	-
ESD,Wangdue	360.11	11.06	38.66	2.00	-
ESD,Zhemgang	305.00	8.50	34.66	1.00	-
ESD,Zhemgang	464.83	9.83	40.75	1.00	-
ESD,Mongar	381.65	11.59	45.85	5.00	-
ESD,Silangthar	592.38	14.15	31.85	3.00	6.00
BTDEV [p]	94.20	4.77	12.58	-	-
Mean	424.49	12.75	39.21	-	-
Correlation Co-efficient [r]					0.90

- means excess



# Theme 6b

**PI SOLVING ACTIVITY**

**Theme#6b**  
**Effectiveness of existing Service Centers**

Members:  
1. Ms. Dechen Dema, Sr. Manager, UED (Team Leader)  
2. Ms. Tashi Lhamo, Asst. Manager, HRAD  
3. Mr. Talman Pradhan, DFO, FAS

Date: 25<sup>th</sup> September, 2013

### Outline

- Background
- Methodology
- Current Situation
- Cause Identification
- Improvement Measures
- Improvement Possibilities
- Conclusion
- Action Plan

### Background




- 19 Electricity Services Division (ESD)s are divided into geographical areas and Service Center (SC) staff look after the areas designated.
- The Service Center concept initiated in 2007 & was launched in 2008
- Mainly initiated to cope with the pressing demand for additional meter readers and linemen
- Enhance productivity of staff
- Improve customer satisfaction
- Presently, 183 Service Center with 289 staff
- No proper procedure or written document to set up SC
- Staff working are called Multi-Task with the following roles and responsibilities.

### Roles and responsibilities

Metering Billing & Collection	Operation and Maintenance (O&M)	Complaint Management
<ul style="list-style-type: none"> <li>• Meter Reading &amp; Billing</li> <li>• Collection for remote areas</li> <li>• Disconnection and Reconnection, new meter issue</li> <li>• Checking in case of high bills/legal connection</li> </ul>	<ul style="list-style-type: none"> <li>• Cleaning of Substation</li> <li>• Cleaning of Bush mainly Low Voltage (LV)</li> <li>• Maintaining Distribution Pillars (DP) and Mini Pilers (MP)</li> <li>• Operation and Maintenance in micro hydro</li> </ul>	<ul style="list-style-type: none"> <li>• Attend to no supply complaints</li> <li>• Rectify problems if possible otherwise inform the O&amp;M Team in ESD</li> <li>• Reporting the status of High Voltage (HV) line and Transformer</li> </ul>

### Merits and Demerits of SC

Merits of Service Centre	Demerits of Service Centre
Faster and prompt service delivery to customers	Manager unable to control or monitor the services provided by the SC staff
One staff performing multiple task	In some cases with more than one staff, work are divided among themselves and information is not shared properly
Adequate knowledge about infrastructure and customers in their designated areas	Lack of coordination between SC staff and ESDs
The SC staff can advice the customers on proper house wiring or safety measures.	Risk of SC staff taking up customer's internal wiring or other electrical related works.
SC Staff who collects the billed amount from the customers helps the customer from saving time to pay the bills.	The risk of misappropriation of the bill amount by SC staff is probable.



### Target Study Area

SL #	ESD Category	ESD	Reason	Survey Questionnaire
1	I	Electricity Services Division, Thimphu	1. Most of the area would represent a urban services 2. Road connectivity is good	- 1,000 customers / 25 926 customers - All 33 SC staff
2	II	Electricity Services Division, Tsirang	1. The area would represent a rural setting 2. Road connectivity only through farm roads	- 500 customers / 4714 customers - All 14 SC staff
3	III	Electricity Services Division, Trongsa	1. Typical rural setting 2. Less road connectivity	-300 customers/ 2567 customers - All 6 SC staff

Survey Questionnaire for Managers to all 19 ESD managers






### CURRENT SITUATION

#### I. Work Load


Average number of days / month / staff

Tasks	Thimphu	Tsirang	Trongsa
Meter Reading and Billing	6	10	11
Operation and Maintenance	2	5	6
Attending to Complaint	5	10	6
Others ( Reconnection, Disconnection, Support to O&M, B&CU)	1	1	3
<b>Total</b>	<b>14</b>	<b>26</b>	<b>25</b>

Source: Results from Survey Questionnaire to SC staff



### III. Cost Implications- Monthly additional cost (Nu)



Source: With SC cost from ERP-SAP system  
Without SC cost: Analysis by Theme 6b

### Cost calculations (monthly)


#### With SC

- Multitasking allowance - Nu. 3000
- Fuel allowance –
  - Nu. 1000 for BPC owned
  - Nu. 1500 for self owned
- Mobile Voucher allowance – Nu. 100- Nu.200
- Voltage Hazard Allowance- Nu. 400

#### Without SC

- Travel Allowance/Daily Allowance of Nu. 500/day for SC staff and driver
  - Distance more than 25 km
  - 11 days cap
- Fuel cost for the distance travelled (Diesel cost considered)
- Voltage hazard allowance of Nu. 400

### Cause Identification



### Selection of Major Improvement Measures

- Problem with increasing number of SC and recruitment of Staff for SC
    - Selection of criteria to establish SC important
    - Even distribution of staff
  - Implement standardized ToR
    - clarity in responsibility and accountability
  - Proper monitoring and information sharing
    - Availability of record and information
- Inadequate qualification of staff – BPC recruitment procedure will resolve
  - Different mobile allowances- to propose to competent authority to approve equal allowance

### Improvement Measure # 1

Criteria for setting up Service Center

Parameters	BPC present level/per SC staff	Weightage
Customer Base (Numbers)	456	42%
Line Length (LV) (km)	21	26%
Distribution Transformer (Numbers)	12	26%
Other factors (geographical terrain, distance)	Distance more than 25 km	7%

Calculated from the existing BPC infrastructure as per Power Data Book 2012

### Improvement Measure # 2

- Draft Terms of Reference for SC


### Improvement Measure # 3

- Register to record the activities in log book
  - To be submitted monthly to ESD
  - Help keep history of the type of complaints
  - ESD Thimphu initiated from August 2013
  - First month report submitted
  - Third Country Survey to Provincial Electricity Authority, Thailand
  - Have advanced recording system

### Improvement Possibilities

- PEA, Thailand - Outsourcing of non-core technical works such as Meter Reading, Tree trimming
- BPC can have strategic plan to have VEEET instead of SC in future
- Village Electrical Entrepreneurs & Electrical Technician (VEEET) first batch of 40 people trained out of total 120 people
- VEEET presently paid Nu.8000 per month, BPC's SC staff currently paid Nu.14,960 per month

### Challenges



- Outsourcing of work of present SC staff as they retire will be slow
- Recruit VEEET in new RE areas
- Replace the present SC in places where present VEEET is trained
- SC staff to be transferred to O&M

### Conclusions

- SC effective for rural areas (ESD, Tsirang and Trogsa)
- Reshuffling of staff and re-allocation of areas for urban areas (ESD, Thimphu)
- Follow SC set up criteria to open new SC
- Follow proper recording system for effective monitoring purposes and proper communication
- Future Recommendation: BPC to outsource non-core technical works and emphasize more on technical works

### Action Plan

Actions	Activities	Deadline	Responsible
Implementation of ToR	Discussion with ESD, Managers	30 November, 2013	Theme 6 b members and DCSD HQ
Implementation of proper monitoring and recording system	-Sensitization on the data to be entered in log book	30 October, 2013	O&M Managers & ESD Managers
	-Log Book to SC to be circulated to all ESDs	30 November, 2013	DCSD HQ and ESD, Managers
	-Documentation on the system to monitor and record	30 December 2013	Theme 6b members and DCSD HQ
Finalization of criteria to set up SC	In consultation with ESD, Managers and GM, DCSD	30 April, 2014	Theme 6 b members and DCSD HQ and ESD Managers

Thank you.  
Any Questions?

## Theme 7




JICA PI Solving Activity

Theme # 7

Study on metering, billing, collection procedures, process and technologies and prepare road map for implementation including cost benefit analysis

8/6/2014



Sandeep

Ujjwal

Tashi

Phurba

Sari Ishizuka

Kinley

### Outline

- Background
- Studies conducted
- AS IS PROCESS – Metering, Billing & Collection
- GAP ANALYSIS
- TO BE PROCESS
- Implementation plan
- Conclusion

8/6/2014

1



# BACKGROUND

8/6/2014 4

## Background

- Study on metering, billing, collection procedures, process and technologies and prepare road map for implementation including cost benefit analysis.
- Metering, Billing & Collection : Core functions of DCSD.
- Annual compact of 2013.
- PBIS of DCSD 2013.
- JICA PI solving activity 2013.
- ESD, Tsiring as the sample ESD

8/6/2014 5

# STUDIES CONDUCTED

8/6/2014 6

## Studies conducted

8/6/2014 7

# AS IS PROCESS

8/6/2014 8

## AS-IS-PROCESS : Metering

- Need for documented procedures & policies
- Inventory policy
- Replacement policy

8/6/2014 9

## AS-IS-PROCESS : Billing

- ESDs have limited Spot Billing Machines (SBM), therefore it has to be shared
- Due to the urgency of the work (since the SBM has to reach another in waiting), the billing function is prone to many reading errors.
- SBMs prone to failure -Hard ware failure , battery failure
- In some cases, the customer reaches the billing section of ESD to pay their bills before the SBM has actually reached the office for downloading purpose.

8/6/2014 10

## AS-IS-PROCESS : Billing

- The reading and billing is spread over the month - the loss calculated by each ESD is not accurate and realistic.
- The billing cycle currently followed does not give a customer a minimum of 30 days grace period to pay his bills.
- 50 % time spent on MB function.

Total Multi tasks by ESD Tsiring	Total costs incurred by EPC (Salary and all allowances) in the year 2012	Total costs on Metering and Billing alone (50%)	Number of Customers as of Dec. 2012	MB costs on MultiTask/Customer/year
14	3,671,374.80	1,835,687.40	4,825	380.45

8/6/2014 11

## AS-IS-PROCESS : Collection

- Conventional payment method (99.63%)
- Internet online Banking (0.36%)
- Point of Sales (POS)

2012 data

8/6/2014 12

## AS-IS-PROCESS : Collection EXPENDITURE IN MBC

8/6/2014 13

## AS-IS-PROCESS : Collection

8/6/2014 14

## AS-IS-PROCESS : Collection Average expenditure by customers

District	Approximate distance from ESD office	Average amount spent while visiting ESD by a customer
Goerweling	1.2km	Ru. 200
Kilbintang	1.5km	Ru. 100
Rangtongling	1.5km	Ru. 75
Takolingkhar	7.5km	Ru. 600
Dzungkhar	1.5km	Ru. 400
Makrolingang	2.5km	Ru. 500
Metrol(Pak-haling)	2.5km	Ru. 700
Serpong	2.5km	Ru. 250
Takramat	2.5km	Ru. 200
Barang	2.5km	Ru. 250
Phuntentaru	2.5km	Ru. 250
Shergithang	1.5km	Ru. 300

8/6/2014 15

# THE GAP ANALYSIS

8/6/2014 16

## The Gap Analysis

- Third country visit to TNB, Malaysia
- Best practices followed shall be adopted
- Metering policies - replacement
- Lessons learnt from TNB – SMS reading

8/6/2014 17

# TO BE PROCESS

8/6/2014 18

## The TO-BE-PROCESS : Metering

- Policy decision to procure static meters taken in 2010.
- Meter specification frozen in 2012 only during CTC meeting on 26 January 2012.
- Decision to replace meters every after 10 years taken.
- Inventory of 10 % of meters .

8/6/2014 19

## The TO-BE-PROCESS - Billing

- Options studied
- (A) Process improvement for rural
  - 4 % of the total energy sales
  - About 3 % of revenue
  - Hence, process improvement schemes and not high investment in introduction of technology
- (B) Introduction of new technology for urban

8/6/2014 20

## The TO-BE-PROCESS - Billing

(A) Process improvement

- 3 Monthly advance payment scheme
- 3 Monthly Post paid scheme
- Yearly advance payment scheme

(B) Introduction of new technology

- Advanced Metering Infrastructure
- Automatic Meter Reading (AMR)
- SMS reading & Billing
- Group metering

8/6/2014 21



# Theme 8

## PI Solving Activity Theme # 8

Theme title: "Fault locating and Rectification of HV/LV Aerial Bundle conductor and UG cables".

Presented by:

- Nidup (Engineer), Team leader
- Nidup Dorji (Supervisor, ESD)
- Duptho Wangdi (Associate Engineer)
- Jigme Sherub (Supervisor, RED)
- Mr. Junichi Ohishi (Chief staff, Advisor) & Mr. Kazuhiro Yoshimura (Advisor)



### Over view ....

- Why this issue was selected?
- Current situation
  - Cause analysis
- Measures taken
  - Fault locator equipment from Togami.
  - Work carried out and its result
- Comparison between Fault Locating Equipment of Togami and Megger
- Cost benefit analysis
- Recommendation
- Formation of fault locator team and it's training
- Action plan



### Reason for selecting this Issue

#### UG Cable

- 10 to 15 years back, cables were laid with route markers. But with rapid development taking place, route markers were not found (may be buried or stolen), losing its cables route. Due to this it's difficult to locate the fault for Under ground cables.
- ABC Cable**
  - When fault occurs, it's very difficult to locate/pinpoint the fault. BPC do have equipment(MTDR300/100) but no one is confident enough to operate in a correct way.

6-Aug-14

2

### Current situation

#### 1. Underground Cable

- Difficult to trace the route of cables.
- No one is confident to use the equipment in a correct way



6-Aug-14

3

### Fault data of Changjalu area (UG Cable)

Date	Location	Tripped	Repaired	Average (Hours/Day)	Note	Cause of Damage
14-03-2009	Changjalu	11am	12:30pm	1	Line trip from 70KV/A through package substations A.	Mechanical occurrence or stabler
4-01-2009	Changjalu	7am	8pm	1	Line trip from 220V-0.5/4 Street cable due to earth fault	Mechanical occurrence or stabler
2-20-2009	Changjalu	11am	7pm	2	Line trip from 70KV/A through package substations A.	Mechanical occurrence or stabler
03-20-2009	SHIK'S air PFL40A near S/S Chashe	5:30pm	Not yet repaired	-	Line trip from DPMV Substation due to earth fault	Unknown
2-18-2009	Changjalu	11:20am	7pm	1.5	Line trip from 70KV/A through package substations A.	Mechanical occurrence or stabler
2-18-2009	Changjalu	8:30am	2:30pm	6	Line trip from 220V-0.5/4 Street cable due to earth fault	Mechanical occurrence or stabler
2-18-2009	Changjalu	3:30pm	7pm	4	Line trip from 70KV/A through package substations A.	Mechanical occurrence or stabler
4-01-2009	Changjalu	8:30pm	7:30pm	1	Line trip from 220V-0.5/4 Street cable due to earth fault	Mechanical occurrence or stabler
11-11-2008	Changjalu	11am	7pm	6	Line trip from 70KV/A through package substations A.	Mechanical occurrence or stabler
11-11-2008	Changjalu	7am	11am	4	Line trip from 70KV/A through package substations A.	Mechanical occurrence or stabler
14-03-2009	Changjalu	1pm	7pm	6	Line trip from 70KV/A through package substations A.	Mechanical occurrence or stabler

6-Aug-14

4

### Causes of fault (UG Cable)

- As per the above data, most of the cable were damaged by external force/excavator. (due to developmental activities)
- As per our third country survey findings, fault occurs mainly through cable jointing

6-Aug-14

5

### 2. HV/LV ABC (OH)

Besides having equipment no one is confident enough to operate in a correct way.

When ever a fault occurs in ABC line, site people inspect visually to locate the fault which takes a lot of time increasing the recovery time.

6-Aug-14

6

### Data collection

Phobjikha, Wangdue, Jan to March, 2013

Date	Location	Tripped Time	Repaired Time	Outage duration(DH)	Remarks/TYPE OF Line
6-9-12-12	120kV/33kV/11kV/0.4kV/230V/0.23kV/0.12kV/0.023kV	5:30pm	6pm	22.5	LT fault 11kV cable sparking
1-4-01-13	Changjalu feeder - Chashe	7am	8pm	11	Line fault from motor and resistance tapping
2-5-01-13	Changjalu feeder - Chashe	8:30pm	5:30pm	23	Line fault from cable
7-8-01-13	Changjalu feeder - Tangchen	7pm	7pm	22	HV ABC insulator and weather tapping sparking
18-21-01-13	Changjalu in Rameshwar	3am	5:07pm	82	HV ABC cable sparking through it
19-21-01-13	Changjalu feeder above Dinku road	10:20am	-	-	Line sparking through cable jointing
19-4-02-13	Changjalu feeder behind BMS	2:27pm	3:45pm	49	Line sparking through cable jointing
06-7-02-13	Changjalu feeder behind BMS	8:20pm	8:42pm	20	Line sparking through cable jointing
6-10-02-13	Insulator between Rameshwar - Chashe feeder	2:37pm	3:58pm	25	Line fault due to loose bolt
12-16-03-13	Changjalu feeder near Dinku road/Changjalu feeder - 720V cable	5:47pm	6:47pm	95	underground cable spark, LT fault and cable sparking
13-22-03-13	Changjalu feeder - Khambu - Tangchen	7pm	7:58pm	92	Line fault through cable in due to cable fall
25-28-03-13	Changjalu feeder - Tangchen	2:20pm	12:27pm	69	Line fault through 70kV line
30-03-13	Changjalu feeder/Chashe	7:17pm	-	-	LT line fault through cable

6-Aug-14

7

### Causes of fault (ABC)

- Based on the data collected, most of the faults occurred through cable jointing.
- Faults occurred through natural calamities
- May be the Cables could have been damaged during the construction phase.

6-Aug-14

11

### Summary on current situation

- Being a developing country, use of underground cables will be more in the near future.
- As per the studies carried out, there are more issues in case of underground cable comparing with ABC line. (Site people are facing problems in locating fault in case of UG cable)
- Based on the above issues, more importance has been given to underground cables.

6-Aug-14

9


### Fault locator equipment(UG Cable) T2LUPIN & HV BRIDGE



6-Aug-14

10


### Procedure for fault locating(UG Cable)



6-Aug-14

11

### Work carried out by JICA Carried out in three location. 1. Changjalu area..



6-Aug-14

12


### 1. Result in location A



6-Aug-14

13

### 1. Fault location B



6-Aug-14

14

### 1. Result location B



6-Aug-14

15

### 1. Fault location at C



6-Aug-14

16

### Result at location C



6-Aug-14

17

### Comparison between UG FLE of Togami & Megger.

Fault locator equipment	TZLUPIN & HV BRIDGE	PFL40A (Megger)
Portability	its portable, so site people wont face difficult regardless of its location.	If the Site is not accessible to road, site people will carry difficulty in facing the equipment.
Route and depth trace	Route is traceable without UG GIS data Mapping	Difficult to trace route As per the previous records
Accurate fault point detection	Although not 100%, Witnessing three fault point location, the team are convinced about its accuracy.	As per previous record, while conducting training they couldn't locate the fault.

### Comparison between FLE of Togami & Megger.

Fault locator equipment	TZLUPIN & HV BRIDGE	PFL40A (Megger)
Usability	Technician people will be able to understand its working principle.	As per it's manual, different methods are there but no one is confident to operate in correct way.

### Cost benefit analysis

#### Cost of equipment



Qty	Description of goods	Unit price	Amount
1 set	TZLUPIN HV Fault Locator	1500	1500
1 set	SLUT-A-Y50	16,100	16100
1 set	Export packing, all courier & handling charges	6000	6000
	<b>TOTAL</b>		<b>23600</b>
1 set	HV BRIDGE MEASUREMENT	24000	24000
1 set	Type 101 1.610, and step down transformer	2100	2100
	<b>TOTAL</b>		<b>26000</b>
	TZLUPIN HV Fault Locator TRAINING (1 joint operation with Tripco)	3000	3000
	Price/loss of two sets of equipment shall be the condition of this training price		
	<b>Total</b>		<b>3600</b>
1 set	100 Ohm meter	777	777
	<b>Total amount (USD)</b>		<b>78077</b>
	<b>Total amount (Bhutan Nu.)</b>		<b>4747405</b>

### Cost benefit analysis

Generator capacity	1250KW	Cost/area	Width	Depth	BB account
Starting time	13.55AM				
Stopping time	11.57AM				
Connected load	5.5KW	912000	2401	1810	884,246.00
Initial diesel in tank	130ltr	302000	2401	1221	876,324.00
Diesel in tank at the end	130ltr	302000	2401	1221	888,237.00
Fuel consumption in 1hr of 5.5KW	9liters	202000	2401	193.4	836,430.00
Fuel consumption in 1hr of 15KW	1.64liters	2401	1163	2,957,985.00	4,224,146.50
Cost of diesel used per hr (Nu) per hr	83.64				87,134.00

### Cost benefit analysis

Area	Zone	Estimated	Actual	Case of Change	Estimated
1-10	Changsha	100	100	100	100
1-11	Changsha	100	100	100	100
1-12	Changsha	100	100	100	100
1-13	Changsha	100	100	100	100
1-14	Changsha	100	100	100	100
1-15	Changsha	100	100	100	100
1-16	Changsha	100	100	100	100
1-17	Changsha	100	100	100	100
1-18	Changsha	100	100	100	100
1-19	Changsha	100	100	100	100
1-20	Changsha	100	100	100	100
1-21	Changsha	100	100	100	100
1-22	Changsha	100	100	100	100
1-23	Changsha	100	100	100	100
1-24	Changsha	100	100	100	100
1-25	Changsha	100	100	100	100
1-26	Changsha	100	100	100	100
1-27	Changsha	100	100	100	100
1-28	Changsha	100	100	100	100
1-29	Changsha	100	100	100	100
1-30	Changsha	100	100	100	100



### Customer connected and it's bill

Route #	Area	No of Customer	Summer 3 months consumption	Winter 3 months Consumption
PSP 21	Chubachu	534	76,912.00	138,697.04
PSP 23	Agri Colony	236	577,380.00	921,365.47
PSP 25	Hongkong Market	593	309,100.00	519,608.93
PSP 31	Abode Norzin Lam	727	383,521.00	613,940.26
PSP 32	Below Chang Lam	877	641,971.00	1,016,874.23
PSP 33	Clock Tower	455	706,602.00	1,123,268.16
PSP 34	Worzon Lam	426	824,971.00	1,579,654.35
PSP 41	PWD colony	380	292,021.00	511,900.17
PSP 42	Hotel B9 area	622	347,955.00	651,244.63
PSP 46	Instant & B&P	42	555,147.00	800,710.87
		4652	4,665,503.00	7,017,284.11

### Financial analysis ...

per month average (Nu)	6,507,200.16
per day average (Nu)	209,909.66
per hour average (Nu)	8,746.23
If the feeder remains shut down for 2 days (Nu)	435,155.72
If the feeder remains shut down for 2hrs (Nu) (recovered using new equipment)	17,089.8333
<b>Benefit of having equipment (Nu)</b>	<b>393,061.11</b>

### Recommendation from fault locating team

#### UG fault locator

Based on


- Comparison done between Fault Locator Equipment of Megger & Togami
- Witnessing fault location using Fault Locator Equipment of Togami.
- Cost benefit analysis

The fault locator team would strongly recommend to buy Fault Locator Equipment of Togami as it serves both as a route tracer and fault locator.

### The team would like to propose two sets of equipment.


#### UG fault locator

Equipment	Unit price(USD)	Qty	Amount(USD)	Training cost(USD)
TZLUPIN SLUT-A-Y50(Togami)	42600	2	85200	3060
HV BRIDGE(Mitsubishi)	26600	2	53200	
MILLI OHM METER(HIOKI)	777	2	1554	
<b>TOTAL</b>		<b>6</b>	<b>139954</b>	<b>3060</b>



### Schedule of training

Day	Activity	Remarks
Day 1	Site visit	
Day 2	Site visit	
Day 3	Site visit	
Day 4	Site visit	
Day 5	Site visit	
Day 6	Site visit	
Day 7	Site visit	
Day 8	Site visit	
Day 9	Site visit	
Day 10	Site visit	



### Recommendation from fault locating team

#### HV/LV ABC fault locator

- In present situation, fault occurs frequently in case of overhead line but when it occurs it is difficult to locate the fault point.
- Training is already finalized for the fault locating equipment (30th September - 3rd October)
- If trainees are satisfied with the equipment then the team would recommend to purchase the equipment.
- As per third country survey, while visiting manufacturing company, their recommendation was to handle the cable properly during construction phase, so to reduce occurrence of fault in near future.

### Action Plan

No	Action	Sept.	Oct.	Nov.	Dec.	Jan.	Feb.	Mar.
01	Hands on training for fault locating equipment (Megger Company)							
02	Review and approval for purchasing of fault locator equipment (Management)							
03	Giving enquiry order to Togami Mig Co Ltd. (PSP)							
04	Delivery of equipment by Togami Mig Co Ltd. to BPC & Payment. (Togami & BPC) Formation of Fault locator team (BPCS)							
05	Hands on Training to Fault locator team by experts from Togami. (Togami)							







### Acknowledgement

The team would like to thank :

- BPC Management for selecting and letting the team to study on this important issue.
- JICA team including the advisor for guiding till date in carrying out the activities in a proper way.
- All ESD offices for providing relevant data.
- PT. Jembo Cable Company and State Electricity Company (Indonesia) for their warm welcome and support which was useful in doing the comparative studies.

*Thank you*

# Theme 9

<p><b>PRIORITY SOLVING ACTIVITY - 2013</b></p> <p><b>Team 9</b></p> <p><b>Effective Utilization of Geographical Information System (GIS) in BPC</b></p> <p>September 25, 2013</p> <p><b>Team Members:</b>          1.Mr. Dorji Tshewang, DCSD.          2.Mr. Pemta Wangchuk, EDCD.          3.Mrs. Kesang Choden, DCSD.          4.Mr. Nema Dorji, RED.          5.Mr. K.B. Gurung, ESD, Zhemgang.          6.Mr. Masaki Iwama, JICA Expert, TEPCO.</p>	<p><b>Outline</b></p> <ul style="list-style-type: none"> <li>◆ Brief Background.</li> <li>◆ Reason for Theme Selection.</li> <li>◆ Objective.</li> <li>◆ Concept of GIS, GPS and Google Earth.</li> <li>◆ Current Situation of GIS in BPC.</li> <li>◆ Third Country Visit.</li> <li>◆ Application of GIS in BPC.</li> <li>◆ Ideal Situation.</li> <li>◆ Counter Measures.</li> <li>◆ Implementation Plan.</li> <li>◆ Cost Analysis.</li> <li>◆ Action Plan.</li> <li>◆ Conclusion.</li> <li>◆ Reference.</li> <li>◆ Appendix.</li> </ul>	<p><b>Brief Background</b></p> <ul style="list-style-type: none"> <li>◆ Introduced in the beginning of 2003 through JICA project during the study of integrated master plan for Dzongkhag-wise electrification in Bhutan.</li> <li>◆ The GIS was started to provide various spatial data for:             <ul style="list-style-type: none"> <li>▪ preparing the master plan.</li> <li>▪ updating the master plan.</li> <li>▪ implementation of RE Projects.</li> </ul> </li> <li>◆ GIS related works are carried out by Environment &amp; GIS Division (EGD), Engineering Design &amp; Contracts Department (EDCD).</li> </ul>												
<p><b>Reason for Theme Selection</b></p> <ul style="list-style-type: none"> <li>◆ The usage of GIS is very marginal and its benefit not appreciable as of today.</li> <li>◆ The GIS unit is largely unorganized and lacks capacity.</li> <li>◆ No GIS Base map in place.</li> <li>◆ No proper system of GIS data reporting.</li> <li>◆ Underutilization of GIS Data.</li> <li>◆ The state of GIS still stands at where it was first initiated in 2003.</li> <li>◆ Lack of awareness of GIS application in BPC.</li> </ul>	<p><b>Objective</b></p> <ul style="list-style-type: none"> <li>◆ To optimize the use of GIS data for overall improvement of efficiency in BPC.</li> <li>◆ To strength the capacity of existing GIS users in BPC.</li> <li>◆ To create awareness on the importance of GIS in BPC.</li> </ul>	<p><b>Concept of GIS, GPS &amp; Google Earth</b></p> <ul style="list-style-type: none"> <li>◆ <b>Geographical Information System (GIS)</b> <ul style="list-style-type: none"> <li>▪ Computer based tool for mapping and analyzing features on earth.</li> <li>▪ System used for land planning, Environmental Management, Mapping of Roads, Railway Lines, Electrical Transmission and Distribution Network.</li> <li>▪ It helps in collecting every information.</li> </ul> </li> </ul> <p>GIS Components: Hardware, Software, Data, People, Methods</p>												
<p><b>Global Positioning System (GPS)</b></p> <ul style="list-style-type: none"> <li>• Satellite based navigation, timing and positioning system.</li> <li>• Applications in GIS data collection, surveying and mapping.</li> </ul> <p>◆ <b>Google Earth.</b></p> <ul style="list-style-type: none"> <li>• A virtual globe, map and geographical information program.</li> <li>• It is simply based on 3D maps, with the capability to show buildings and bridges in 3D.</li> </ul> 	<p><b>Current Situation</b></p> <p><b>Hardware</b>          One or more GPS in every ESD's. Lack of Original Software. Type of GPS. No dedicated computer. No GIS Database. Single Plotter in Head Office.</p> <p><b>Software</b>          Lack of Original Software. Usage of Open source GIS software. No Customer Database and Mapping. Data Error. Inadequate manpower. Lack of Training.</p> <p><b>Data</b>          GIS Database of Distribution and Transmission Network. No Customer Database and Mapping. Data Error. No proper system of GIS data reporting.</p> <p><b>People</b>          GIS/GPS user in BPC. Inadequate manpower. Lack of Training.</p> <p><b>Method</b>          Procedure. No proper system of GIS data reporting.</p> <p><b>GIS Data not Effectively Utilized.</b></p>	<p><b>Sample Geographical view of the Network</b></p>  <p>MV Line, MV Pole</p>												
<p><b>Pole wise Information</b></p> 	<p><b>Details of Distribution Transformer</b></p> 	<p><b>Third Country Visit</b></p> <p>As a part of the Study Tour, the JICA provided an opportunity to visit two Power Utilities such as Provincial Electricity Authority (PEA) and Metropolitan Electricity Authority (MEA), Bangkok, Thailand including one of the well known manufacturing companies know as Thai-Yazaki Manufacturing Company.</p> <p><b>Summary of Day wise Report.</b></p> <table border="1"> <tr> <td>June 24, 2013</td> <td>Travelled to Bangkok, Thailand.</td> </tr> <tr> <td>June 25, 2013</td> <td>Visit to PEA Head Quarter (HQ) and GIS Center in HQ at Bangkok, Thailand.</td> </tr> <tr> <td>June 26, 2013</td> <td>Visit to PEA Area 2 Central Region (Chonburi Province) and Chachoengsao Province.</td> </tr> <tr> <td>June 27, 2013</td> <td>Visit to Thai Yazaki Manufacturing Company.</td> </tr> <tr> <td>June 28, 2013</td> <td>Visit to MEA Head Quarter, Bangkok, Thailand.</td> </tr> <tr> <td>June 29, 2013</td> <td>Return to Bhutan.</td> </tr> </table>	June 24, 2013	Travelled to Bangkok, Thailand.	June 25, 2013	Visit to PEA Head Quarter (HQ) and GIS Center in HQ at Bangkok, Thailand.	June 26, 2013	Visit to PEA Area 2 Central Region (Chonburi Province) and Chachoengsao Province.	June 27, 2013	Visit to Thai Yazaki Manufacturing Company.	June 28, 2013	Visit to MEA Head Quarter, Bangkok, Thailand.	June 29, 2013	Return to Bhutan.
June 24, 2013	Travelled to Bangkok, Thailand.													
June 25, 2013	Visit to PEA Head Quarter (HQ) and GIS Center in HQ at Bangkok, Thailand.													
June 26, 2013	Visit to PEA Area 2 Central Region (Chonburi Province) and Chachoengsao Province.													
June 27, 2013	Visit to Thai Yazaki Manufacturing Company.													
June 28, 2013	Visit to MEA Head Quarter, Bangkok, Thailand.													
June 29, 2013	Return to Bhutan.													
<p><b>Learning Outcome</b></p> <ul style="list-style-type: none"> <li>◆ GIS system is so advanced and fully established.</li> <li>◆ They have GIS Database Server.</li> <li>◆ They have their own GIS Map with their infrastructure details.</li> <li>◆ Everyday data update is very important.</li> </ul> 	<ul style="list-style-type: none"> <li>◆ Their GIS personal are from different background;             <ol style="list-style-type: none"> <li>1. Electrical Engineer,</li> <li>2. Survey Engineer and</li> <li>3. Computer Engineer.</li> </ol> </li> <li>◆ They are trained for a year on GIS and other related applications.</li> <li>◆ GIS has made their work more easy and reliable in the management of power outage and customer services due to the integration of GIS with other applications.</li> </ul>	<p><b>Application of GIS in BPC</b></p> <p>GIS offers power organizations a method of quickly accessing and producing maps. Using GIS streamlines daily workflow and improves decision making.</p> 												

**Distribution & Customer Department (DCSD) & Rural Electrification Department (RED)**

- ❖ Extension of new line.
- ❖ Installation of meter.
- ❖ Distribution Transformer Metering Mapping.
- ❖ Operation and Maintenance.
- ❖ Customer Service.

15

**Extension of new line.**

16

**Installation of new meter.**

17

**Transmission Department (TD).**

- ❖ For routine maintenance.
- ❖ Initial GPS survey for the selection of suitable sites for Transmission route.
- ❖ Supply of construction power to Mega Hydro Projects.
- ❖ GIS in Right of way (ROW) issues like land easement and acquisition.

18

**Supply of construction power to Mega Hydro Projects.**

19

**Environment & GIS Division, EDCD.**

- ❖ GIS applications can manage the power company's environmental compliance.
- ❖ Manage right-of-way activities including planning and management, property acquisition, vegetation management and corridor preservation.
- ❖ To buffer and overlay right-of-way requirements for tower placements, query features to identify property owners and other land information.

20

**Application of GIS in ROW management.**

21

**Infocomm Services Division**

- ❖ GIS mapping of OPGW and ADSS network.
- ❖ GIS in extension of new network to any center.
- ❖ Maintenance of the cable.

**National Load Dispatch Center (NLDC)**

- ❖ GIS integration with SCADA.

22

**Application of Google Earth.**

23

**Google Earth Image**

24

**GIS & SCADA**

- ❖ Supervisory Control & Data Acquisition (SCADA) is used to monitor and control the electrical utility.
- ❖ **Advantage** : Visualize the SCADA events in GIS and help identify consumers within the affected areas.

25

**Ideal Situation for BPC**

26

**Ideal Situation Contd...**

- Provide Complete geographical based network data map which can be used for the management of following:
  - Asset Management/Monitor.
  - Dynamic map production, visualization and understanding real scenario.
  - Efficient Planning of Maintenance.
  - Location of Faults including UG.
  - Effective network extension/augmentation.
  - Right of way issues.
  - Customer Management viz. attending complaint, releasing new service connection etc.
  - Energy Auditing.
  - Provide analytical tool such as distance calculation, shortest path etc.
  - Load forecasting.
  - Substation locating and sizing.
  - Feeder routing.
  - Transformer and feeder optimization.
  - Possibility of data sharing between different users simultaneously.
  - Easy and speedy retrieval of information.

27

**Counter Measure**

1. Develop a clear guideline for GIS management.
2. Reorganize existing GIS system in BPC.
3. Purchase of hardware and software resources.
4. Update incomplete data.
5. Build manpower competency.

28

**Implementation Plan**

29

**Cost Analysis**

Particular	Budget
Computer (45,000.00*19)	855,000.00
GIS Software (4,000.00*19)	1,431,457.41
Google Earth Software (4,000.00*19)	103,740.00
Training (4,000.00*19)	1,825,000.00
Consultant (PEA GIS Specialist)	1,000,000.00
GIS Server (4,000.00*19)	690,000.00
<b>Total</b>	<b>5,905,197.41</b>

30

**Action Plan**

**Action Plan - 2014**

Sl.N o.	Activities	January - April	May - June	July - August	September - December
1	Proposal of Consultancy Firm and formation of GIS Core Group.	█			
2	Prepare actual Road Map with the help of Consultant and Purchase of GIS and Google Earth software.		█		
3	Training and formulation of proper guideline.			█	
4	Data update and collection of spatial data.				█

DCSD, EGD (EDCD) and Infocomm Services Division should be responsible.


31

**Conclusion**

- GIS provide a solutions for comprehensive and effective distribution and transmission management.
- GIS is used to spatially analyze network congestion and determine site feasibility.
- GIS Specialist and capacity development is very important.
- Using GIS will make it more efficient and reliable organization in simplifying daily workflow and improving the decision making.


32

















### PROFIT CONTRIBUTION BY THE MHPs

Year	Profit before tax (whole BPC) in Mil. Nu.	Profit from Plants in Mil. Nu.	Percentage
2008	927.13	34.00	3.67%
2009	986.45	41.68	4.22%
2010	1,353.20	38.56	2.85%
2011	1,209.01	34.88	2.88%
2012	1,212.32	24.70	2.04%



Total revenue generated from MHPs is higher than the cost incurred on MHPs.  
 Benefit to cost ratio is 1.81  
 Personnel cost in the O&M of MHPs is very high especially for the Mini Hydels which are not automated



### SUMMARY OF NPV, IRR FOR GRID CONNECTION OF MICRO HYDELS & GANGZUR MINI HYDEL

Sl. No.	Plant (Capacity in kW)	NPV	IRR	Payback period (in years)
1	Gangzur (2x60)	-1.16	-8%	28.2
2	Sherubling (1x50)	1.772	28%	3.5
3	Ura (1x50)	1.02	21%	5.7
4	Rukubji (1x40)	0.75	4%	8.7
5	Kuenga Rabten (1x30)	0.08	8%	17.7
6	Tamshing (1x30)	0.63	8%	7.1
7	Tangsibji (1x30)	0.91	13%	5.6
8	Kekhar (1x20)	0.11	0.2%	16.9

Investment on Gangzur Mini Hydel includes the cost of connection to grid and rehabilitation of the plant.

### ADDITIONAL REVENUE GENERATION AFTER GRID CONNECTION

Sl. No.	Plant (Capacity in kW)	Revenue generated till 2008-2012 (in Mil. Nu.)	Revenue generation from 2014-2018 (in Mil. Nu.)	Increase by (in Mil. Nu.)	Percentage increase
1	Gangzur (2x60)	0.833	5.403	4.57	84.6%
2	Sherubling (1x50)	0.503	2.293	1.79	76.1%
3	Ura (1x50)	1.468	3.053	1.58	51.9%
4	Rukubji (1x40)	0.553	2.293	1.74	75.8%
5	Tamshing (1x30)	0.683	1.383	0.70	50.4%
6	Tangsibji (1x30)	0.343	1.833	1.49	74.9%
7	Kekhar (1x20)	0.243	0.933	0.69	72.9%
8	Subj (1x20)	0.823	1.373	0.55	40.0%

Estimated cost for Grid connection = Nu. 20.611 MI.  
 Revenue generation shall be enhanced in the next years by Nu. 12.62 MI

### CONCLUSION:

- Overall, revenue generated in the past 5 years is more than the cost incurred.
- However, if we look at the plants individually, it is apparent that only some plants viz. Rangjung, Churney, Gidakom, Thimphu, Changchey, Rongchey, Ura, Tamshing, Kuenga Rabten are sustainable, with the present situation.
- Since the Micro HPs are not connected to the grid, any energy generated beyond the connected load is transferred to dummy load. If connected to grid, except for Kekhar, Kuenga Rabten, Gangzur the remaining hydels will be sustainable.
- Operation Cost (HR) of the plants is high.
- Standard operation procedure (SOP) and standard check list for monitoring and preventive maintenance of MHPs is not available.
- Plant operators are not trained to carry out breakdown maintenance. Restoration period of plant breakdown is longer as maintenance team has come from CAITD, Begans.
- MHPs serve as a back-up service in case of grid supply failure and provide power to essential services / organizations, thus improving reliability/energy security.
- Every single unit generated from MHPs helps meet the internal energy demand and thus equivalent energy generated from large HPs can be exported.



## RECOMMENDATION

1. If the Micro HPPs are connected to grid, surplus energy (currently diverted to dummy loads) can be injected into the grid and hence increase revenue generation. Therefore, it is recommended that some of the micro hydel viz. Sherubling, Ura, Rukubji, Tangsibi and Tamshing be considered for grid connection.
2. High operation cost (HR) can be reduced by going for automation. Therefore, it is recommended that study for automation of plants be carried out.
3. It is recommended that a study be carried out to check the feasibility of availing carbon credit for the MHPs so that part of the O&M cost may be met from the credit earned.
4. Standard operation procedure (SOP) and standard check list for monitoring and carrying out preventive maintenance of plants are required. The standard check list similar to that used by power plants in Indonesia (3<sup>rd</sup> country survey) may be adopted in our MHPs. [Weekly Inspection Check List.pdf](#)

31

## ACTION PLAN

Sl. No	Action	Scheduled Start Date	Scheduled End Date	Responsibilities
1	Drafting of SOP	January 2014	March 2014	To be prepared by PI Team, CMTD & DCSD
2	Study for automation of plants	November 2013	March 2014	To be initiated by DCSD
3	Grid Connection	January 2014	December 2014	To be budgeted & carried out by CMTD in coordination with ESDs
4	Study on carbon credit eligibility for MHPs	April 2014	June 2014	To be initiated by DCSD/PI Team

32

## EXIT STRATEGY

### WHY EXIT STRATEGY

- Recent directive from the DHI Board that BPC's mandate is in transmission and distribution of electricity
- BPC is directed to prepare a proposal on how to exit from the mini and micro HPP.

34

### EXIT STRATEGY


- Option I: Create subsidiary company
- If BPC has plans for investing in additional embedded generation viz. solar, wind, hydro power plants
- Option II: Outsource
- a. Asset to BPC, O&M to private companies
  - b. Both asset and O&M to private companies
- Recommended that a team be constituted with the following members immediately to carry out the study:
1. Tariff Officer, MDO, BPC
  2. Asset Manager, FAS, BPC
  3. Technical engineers (Mechanical, Electrical, Civil)
  4. PI Team

35

## TASHI DELEK

36

## Theme 11



Wednesday, August 06, 2014 © BHUTAN POWER CORPORATION LTD. 2013

### Presentation Contents

- ✓ What is distribution transformer (DT) metering ?
- ✓ Why is it required in BPC distribution network ?
- ✓ Cost benefit analysis
- ✓ Pilot study proposal
- ✓ Cost analysis for pilot study
- ✓ Recommendations


Wednesday, August 06, 2014 © BHUTAN POWER CORPORATION LTD. 2013

### What is Distribution Transformer metering?

A distribution transformer meter (DT Meter) is a "link meter" between the sub-transmission substation and the LV system. Its application covers the following.

- Load flow analysis, energy auditing and accounting.
- Distribution network reliability (History of outage/event log including date and time)
- To monitor the loading condition of the distribution transformer

Wednesday, August 06, 2014 © BHUTAN POWER CORPORATION LTD. 2013



Wednesday, August 06, 2014 © BHUTAN POWER CORPORATION LTD. 2013

### Why in BPC?

- ✓ Energy auditing and accounting
- ✓ Supply reliability
- ✓ To monitor the operating condition of DT
- ✓ To meet up the requirements of regulatory bodies

Wednesday, August 06, 2014 © BHUTAN POWER CORPORATION LTD. 2013

### 1. Energy Accounting and Auditing

**Current scenario:**

- GENCOS
- TRANSMISSION S/S
- DISTRIBUTION S/S
- CONSUMER METER

GENCOS meter reading - Transmission meter reading = Transmission Energy Loss

Transmission S/S meter reading - Submission of customer meter reading = Distribution Loss

- Absence of strategy in place to identify loss at each section of the network.

Wednesday, August 06, 2014 © BHUTAN POWER CORPORATION LTD. 2013

### Improvement measures:

- GENCOS
- TRANSMISSION S/S
- DISTRIBUTION TRANSFORMER METER
- CONSUMER METER

Transmission S/S meter reading - DT meter reading - MV Energy Loss + distribution transformation loss

DT meter reading - Consumer meter reading - LV Energy Loss

- Improved reliability indices

Fig 02: Losses at feeder level

Calculated technical loss % for the 11kV feeder = 14.16%

Wednesday, August 06, 2014 © BHUTAN POWER CORPORATION LTD. 2013

### 2. Supply reliability

**Current scenario:**

- TRANSMISSION S/S
- DISTRIBUTION TRANSFORMER
- CONSUMER METER

Distribution outage is recorded only at Transmission S/S.

No outages are recorded at any point in distribution network.

- Room for manipulation for calculating SAIFI and SAIDI
- Outage period and duration not known unless consumer informs leading to low Customer Satisfaction Index.

Wednesday, August 06, 2014 © BHUTAN POWER CORPORATION LTD. 2013

### Improvement measures:

- TRANSMISSION S/S
- DISTRIBUTION TRANSFORMER
- CONSUMER METER

Distribution outage is recorded at Transmission S/S i.e., upstream reliability.

Distribution outages also recorded at every DT metering point in distribution network i.e., downstream reliability.

- Can avoid room for manipulating reliability indices.
- Reduction in customer call volume and improve CSI.

Wednesday, August 06, 2014 © BHUTAN POWER CORPORATION LTD. 2013

### 3. To monitor the loading condition of DT

**Current scenario:**

- Reasons of distribution transformer failures not exactly known
- Overloading and under loading of distribution transformers not precisely recorded
- Increased outage period

**Improvement measures:**

- Failure reasons can be outlined using more detailed information from DTM along with the data obtained from the maintenance team and identify under-used and overloaded transformers and properly size transformers.
- Enable BPC to more accurately forecast load growth and evaluate system investments resulting in improved asset/distribution system planning.

Wednesday, August 06, 2014 © BHUTAN POWER CORPORATION LTD. 2013

### 4. To meet up the requirements of regulatory bodies

Parameters	% Loss	% Voltage drop
Medium Voltage Line	2.50	± 10
Distribution Transformer		
Low Voltage	12.0	± 6
Service Wires		
Commercial loss	5% of LV sales	

Table 01: Permissible losses and voltage drop as per BEA guidelines

Wednesday, August 06, 2014 © BHUTAN POWER CORPORATION LTD. 2013

### Cost benefit analysis

**General assumptions made**


- The cost benefit analysis is based on Genus, India LT CT meter
- Time value of money is not considered
- 18 % targeted revenue savings every year keeping the loss figure constant
- Meter depreciation time (useful life) period used in the model is 10 years
- Meter growth rate is not considered
- Depreciation cost is Nu. 44.22m @3.33% as per BPC asset depreciation codes
- Assumes full implementation of DTM technologies with 100% deployment of DTM over a period of 2.26 years
- The model analysis period is 10 years ending in 2023, with DTM deployment commencing in year 2014

Wednesday, August 06, 2014 © BHUTAN POWER CORPORATION LTD. 2013

Specification	Genus (India)	DMT (Sampurna)
Model type	DMT (Sampurna) - 1000V, 100A, CT 1	DMT (Sampurna) - 1000V, 100A, CT 1
Compliance standard	IS 6081-22 & IEC 60884-22	IS 6081-22 & IEC 60884-22
Voltage & Current rating	1000V, 100A, CT 1	1000V, 100A, CT 1
Phase factor	230V (3-Phase 3-Wire)	230V (3-Phase 3-Wire)
Accuracy	0.5% & 1%	0.5% & 1%
Performance Protocol	DMT (Sampurna)	DMT (Sampurna)
1. Local data downloading	Substantially Insulated Optical Port for Data Downloading, IRT	Optical Port for Data Downloading
2. Remote data downloading	Compatible for Remote Communication through GPRS/GSM/GPRS communication	Compatible for Remote Communication through GPRS/GSM/GPRS communication
Self-Diagnostic features	Self-Diagnostic and remote tamper detection & event logging	Self-Diagnostic and remote tamper detection & event logging
Installation & mounting	Compact design, push mounting/C-Channel Mounting	Compact design, push mounting/C-Channel Mounting
Software	DMT (Sampurna) can handle up to 200-4000 meters	DMT (Sampurna) can handle up to 200-4000 meters
Ability to be processed	DMT (Sampurna) can be integrated with other meters	DMT (Sampurna) can be integrated with other meters
Approximate cost	Nu. 10,120.00/meter	Nu. 26,180.00/meter

Table 02: Cost comparison of DT meters

Wednesday, August 06, 2014 © BHUTAN POWER CORPORATION LTD. 2013




### Payback Period

Payback period in capital budgeting refers to the period of time required for the return on an investment to "repay" the sum of the original investment.

Description	% Cumulative reduction in revenue loss	Loss figure for every year (Nu. Mn)	Savings every year (Nu. mn)	Cost reduction every year (Nu. mn)
Year 0	0%	63.95	0.00	-68.28
Year 1	18%	63.95	11.51	-56.76
Year 2	36%	63.95	11.51	-45.25
Year 3	54%	63.95	11.51	-33.74
Year 4	72%	63.95	11.51	-22.23
Year 5	90%	63.95	11.51	-10.72
Year 6	108%	63.95	11.51	0.79
Year 7	126%	63.95	11.51	12.30
Year 8	144%	63.95	11.51	23.81
Year 9	162%	63.95	11.51	35.32
Year 10	180%	63.95	11.51	46.83

Table 03: Payback period

Wednesday, August 06, 2014 © BHUTAN POWER CORPORATION LTD. 2013



### Salvage value & depreciation

Year	Depreciation Rate	Depreciation Expense	Accumulated Depreciation	Book value at end of year
Year 0			Original Cost	98.28
Year 1	3.33%	3.27	3.27	95.01
Year 2	3.33%	3.16	6.44	88.57
Year 3	3.33%	3.06	9.50	82.35
Year 4	3.33%	2.96	12.46	76.33
Year 5	3.33%	2.86	15.32	70.52
Year 6	3.33%	2.76	18.08	64.90
Year 7	3.33%	2.67	20.71	59.46
Year 8	3.33%	2.58	23.23	54.21
Year 9	3.33%	2.50	25.68	49.13
Year 10	3.33%	2.41	28.09	44.22

Table 04: Depreciation & salvage value calculation

Wednesday, August 06, 2014 © BHUTAN POWER CORPORATION LTD. 2013

### Calculation of useful life of the system

Total No of meters	1292	Nos
No of meters installed in a day	4.00	Nos
No of days required	823.75	Days
No of years required	2.26	Years
Meters installed in 1st year	1460	Nos
Meters installed in 2nd year	1460	Nos
Meters installed in 3rd year	375	Nos
% of meters with 1.26 years useful life	56	%

Table 05: Useful life of the system

### Cost savings abstract

Description	Amount (Nu. mn)
Cost savings through ten years with 18% revenue loss reduction	16.83
Cost savings during the useful life of 1.26 years	14.50
Salvage value	44.22
<b>Total savings in 11.26 years</b>	<b>75.56</b>

Table 06: Cost savings from the system

Wednesday, August 06, 2014 © BHUTAN POWER CORPORATION LTD. 2013

### Capital cost abstract

Descriptions	Amount (Nu. mn)
Cost of Meter	39.935
Cost of Installation	9.885
Accessories	9.045
Add 5% contingency cost	2.943
Add 2% maintenance cost	1.236
Add recurring cost for 10 years	35.230
<b>Grand total</b>	<b>98.274</b>

EDMI Singapore make - 102.35 million

Table 02: Capital cost

Wednesday, August 06, 2014 © BHUTAN POWER CORPORATION LTD. 2013

- ### Pilot study outline
- To study the achievement of 18% targeted reduction in revenue loss within the annual O&M cost.
  - One No. 11KV MV feeder under Paro ESD has been identified as pilot feeder.
  - Adequate No. of customers (3825 Nos with average connected load of 0.8 KW per household) with 24 DTs (6488KVA installed capacity) to study loading profile of DTs.
  - The line length of 19.67Km for loss analysis purpose.
  - The number of DTs (24 Nos. with 6488 installed KVA) is adequate for load profile analysis as well as reliability indices.
  - The line covers both urban and rural sites (semi urban)
  - Easily accessible by the team who are based in Thimphu
  - Requires minimum of four months including installation, data analysis and generation of DT health report
- Wednesday, August 06, 2014 © BHUTAN POWER CORPORATION LTD. 2013

### Capital cost for the pilot study

Descriptions	Amount (Nu. mn)
Cost of meter	10.390
Installation charges	9.075
Accessories	9.773
Communication charges	0.015
Contingency cost - 5%	0.057
<b>Grand total</b>	<b>1.197</b>

Table 07: Cost abstract

Cost with LT CT and sampurna mixed is more by Nu. 0.13 than only LT CT type

Wednesday, August 06, 2014 © BHUTAN POWER CORPORATION LTD. 2013

- ### Recommendations
- BPC should target to reduce 18% revenue loss annually within the same annual O&M cost
  - To study the achievement of ±18% targeted reduction in revenue loss, a pilot study may be necessary
  - Can be foundation stone for migration to latest energy saving techniques and improvement of distribution system efficiency such as DMS
  - One of the arms in achieving BPCs vision/mission
- Wednesday, August 06, 2014 © BHUTAN POWER CORPORATION LTD. 2013

