

**The Republic of Kenya
Rural Electrification Authority**

**The Project for Establishment of
Rural Electrification Model
Using Renewable Energy
in
the Republic of Kenya**

**Project Completion Report
Volume 3 Attachment 2/2**

March 2015

Japan International Cooperation Agency (JICA)

NIPPON KOEI
Challenging mind, Changing dynamics

KRI International
Corporation
KEEI EXCHANGE INSTITUTE

IL
JR
15-030

**The Republic of Kenya
Rural Electrification Authority**

**The Project for Establishment of
Rural Electrification Model
Using Renewable Energy
in
the Republic of Kenya**

**Project Completion Report
Volume 3 Attachment 2/2**

March 2015

Japan International Cooperation Agency (JICA)

NIPPON KOEI
Challenging mind, Changing dynamics

KRI International
Corporation
1987 ESTABLISHED

The Project for Establishment of
Rural Electrification Model
Using Renewable Energy
in
the Republic of Kenya

Project Completion Report
Volume 3 Attachment 2/2

Attachment K Materials for Technical Transfer for Micro Hydropower (MHP)

Attachment L Materials for Technical Transfer for Biogas

Attachment M Materials for Technical Transfer for Wind

Attachment N Materials for Environmental and Social Considerations

Attachment O Materials of International Workshop

Attachment K

Materials for Technical Transfer for Micro Hydropower (MHP)

Attachment K-1 Technical Guidelines for MHP

- Attachment K-1-1 Guideline for MHP (The main body of contents available in PDF format in the data CD-ROM)
- Attachment K-1-2 Material for Validation Workshop of Guideline for MHP

Attachment K-2 Simple Pre-feasibility Study on Asurur Mini-hydropower Scheme

Attachment K-3 Material of Technical Seminar for MHP

- Attachment K-3-1 Planning of MHP Generation
- Attachment K-3-2 Design of MHP

Attachment K-4 Materials of JKUAT Technical Conference for MHP

- Attachment K-4-1 Technical Paper for JKUAT Technical Conference
- Attachment K-4-2 Poster Presentation for JKUAT Technical Conference

Guideline for MHP Development

February 2015



Ministry of Energy and Petroleum



Table of Contents

Table of Contents	i
List of Tables	iv
List of Figures	v
List of Terms and Abbreviations	viii
List of Electrical Terminology.....	ix
EXECUTIVE SUMMARY	1
1 Background	1
2 Objective of the Guideline.....	1
3 Structure of the Guideline	1
4 Features of the Guideline.....	2
5 Overview of MHP Development in Kenya	3
CHAPTER 1 GENERAL.....	4
1.1 Basic of Hydropower Generation	4
1.1.1 Power Output	4
1.1.2 Annual Energy	5
1.2 Required Generator Capacity for Rural Electrification	5
1.3 Advantage and Disadvantage of MHP	6
1.4 Brand New Technology - ULH -MHP	6
CHAPTER 2 IDENTIFICATION OF THE PROJECT.....	7
2.1 Work Flow of Identification	7
2.2 Selection of the Target Non-electrified Area	8
2.2.1 Clarification of Non-electrified Area	8
2.2.2 Identification of Steep River Site	8
2.2.3 Confirmation of Social Conditions around the Site	9
2.3 Estimation of the Hydropower Potential	10
2.3.1 Measurement of the Catchment Area.....	10
2.3.2 Estimation of Dependable Discharge.....	12
2.3.3 Amount of the Reserve Discharge by WRMA.....	17
2.3.4 Estimation of Probable Flood Discharge	17
2.4 Estimation of the Power Demand.....	21
2.4.1 Estimation of required Generator Capacity.....	21
2.4.2 Estimation of Required Head and Discharge	23
2.5 Comparison between Power Demand and Hydropower Potential	24
CHAPTER 3 INVESTIGATION AND PLANNING	26
3.1 Social Investigation	26
3.1.1 Survey on Power Demand Forecasting	26
3.1.2 Survey on Future Management Capability	28
3.1.3 Survey on Environmental and Social Impacts	28
3.2 Technical Investigation	30
3.2.1 Measurement of River Discharge.....	30
3.2.2 Measurement of Available Head.....	33
3.2.3 Observation of Site Topography	36
3.2.4 Observation of Site Geology	36

3.3	Plan Formulation	37
3.3.1	Preparation of Alternative Layout.....	37
3.3.2	Estimation of Project Cost	40
3.3.3	Estimation of Project Benefit	43
3.3.4	Selection of Optimum Development Plan.....	44
3.4	Application of Water Use Permit	45
CHAPTER 4 BASIC DESIGN.....		46
4.1	Civil Structure	46
4.1.1	Head Works.....	47
4.1.2	Power Canal	54
4.1.3	Head Tank	59
4.1.4	Penstock	61
4.1.5	Powerhouse	64
4.1.6	Tailrace Canal	65
4.1.7	Head Loss Calculation	65
4.2	Electrical Equipment	69
4.2.1	Turbine	69
4.2.2	Generator.....	74
4.2.3	Inlet Valve.....	77
4.2.4	Power Transmission Equipment	78
4.2.5	Governor	79
4.2.6	Transformer.....	80
4.2.7	Main Circuit	80
4.2.8	Integrated Control Panel	81
4.2.9	Other Equipment	82
4.3	Distribution Facilities	83
4.3.1	General	83
4.3.2	Distribution Methods	83
4.3.3	Distribution Line Planning.....	85
4.3.4	Electrical Design	85
4.3.5	Mechanical Design.....	87
4.3.6	Overhead Distribution Lines	88
4.3.7	Others	89
CHAPTER 5 ECONOMIC AND FINANCIAL EVALUATION		91
5.1	Key Comparative Indicators for Evaluation.....	91
5.2	Estimation of Project Cost.....	93
5.2.1	Civil Works	94
5.2.2	Electrical Equipment.....	96
5.2.3	Distribution Facilities.....	97
5.2.4	Planning of Construction Schedule.....	98
5.3	Economic Evaluation.....	100
5.3.1	Economic Project Benefit	100
5.3.2	Economic Project Cost.....	101
5.3.3	Example of Economic Evaluation.....	102
5.4	Financial Evaluation.....	104
5.4.1	Financial Project Benefit.....	104
5.4.2	Financial Project Cost	104
5.4.3	Example of Financial Evaluation	104
CHAPTER 6 ENVIRONMENTAL AND SOCIAL CONSIDERATIONS.....		106
6.1	Environmental Management System in Kenya	106

6.1.1	National Environmental Management Authority (NEMA).....	106
6.1.2	Environmental Management System at County Level.....	106
6.2	EIA Procedures and Licensing System in Kenya.....	107
6.2.1	Projects Sectors Subject to EIA	107
6.2.2	EIA Review Process and Licensing	109
6.3	Specific Subject (Solid Waste Management).....	116
6.3.1	Construction Stage	116
6.3.2	Operation Stage.....	116
6.4	Individual Subjects on MHP Project	121
CHAPTER 7 CONSTRUCTION SUPERVISION.....		122
7.1	Procurement.....	122
7.1.1	Procurement Procedure	122
7.1.2	Procedure of Procurement.....	123
7.1.3	Qualification.....	124
7.2	Construction Supervision	125
7.2.1	Overall Management.....	125
7.2.2	Schedule Control.....	126
7.2.3	Quality Control	127
7.2.4	Documents Control	127
7.2.5	Payment Control	129
7.2.6	Variation Order	129
7.2.7	Safety and Health Management	129
7.3	Civil Works	131
7.3.1	Inspection Items for Construction Supervision.....	131
7.3.2	Procedure of Approval and Confirmation on Site.....	131
7.4	Electrical Equipment	132
7.4.1	Acceptance of the Turbine Efficiency.....	133
7.4.2	Acceptance of the Generator Efficiency	133
7.4.3	Shop Test.....	133
7.4.4	Site Test (Acceptance Test)	134
7.5	Distribution Facilities	136
7.5.1	Inspection Items for Construction Supervision.....	136
7.5.2	Quality of Construction Materials.....	136
7.5.3	Procedures of Approval and Confirmation on Site	136
CHAPTER 8 OPERATION AND MAINTENANCE.....		137
8.1	Establishment of Management Body.....	137
8.2	Financial Management	139
8.2.1	Necessary Expenditure.....	139
8.2.2	Electricity Tariff.....	139
8.2.3	User Charges	140
8.2.4	Billing System.....	140
8.2.5	Balance Sheet.....	141
8.2.6	Management During Initial Stage	142
8.3	Operation and Maintenance.....	142
8.3.1	Administrative Works	142
8.3.2	Civil Structures	143
8.3.3	Electrical Equipment.....	146
8.3.4	Distribution Facilities.....	149
8.4	Assistance for Management Board.....	151

	8.4.1 Assistance before Commencement of Power Generation	151
	8.4.2 Assistance after Commencement of Power Generation	152
REFERENCES.....		154

List of Annexes

Annex-1	Simulated Monthly Surface Water by Sub-basin in NWMP 2030
Annex-2	Regional Area Flood Curve of Major River Basins in NWMP 2030

List of Tables

Table 1	General Description of the Guideline.....	2
Table 1.3.1	Standard Efficiencies for Planning Stage.....	5
Table 2.3.1	21 Sub-basins of Regional Area Flood Curve by NWMP 2030.....	19
Table 2.3.2	Creager’s Coefficient of Hydropower Projects in Western Kenya	20
Table 2.4.1	Basic Assumptions of Consumers and Unit Demand.....	21
Table 2.4.2	Assumed Consumers and Power Demand.....	22
Table 2.4.3	Required Generator Capacity by Community Size	23
Table 2.4.4	Required Discharge by Available Head	23
Table 2.5.1	Evaluation of the Hydropower Potential	24
Table 3.1.1	Item of Social Economic Survey	27
Table 3.1.2	Possible Environmental Impact by Hydropower Development	29
Table 3.2.1	Check Point of Site Topography	36
Table 3.2.2	Check Point of Site Geology	36
Table 3.3.1	Roughness Coefficient of Natural River	39
Table 3.3.2	Estimation of Project Cost.....	40
Table 3.3.3	Empirical Equations for Estimation of Work Quantities of Civil Works.....	41
Table 3.3.4	Required Dimensions for Estimation of Work Quantities of Civil Works.....	42
Table 3.3.5	Required Unit Prices for the Estimation.....	43
Table 3.4.1	Categories of Water Resources Use Activities.....	45
Table 4.1.1	Functions and Requirements for Head Works.....	47
Table 4.1.2	Hydraulic Requirements to Side Intake.....	48
Table 4.1.3	Flow Condition into Intake.....	49
Table 4.1.4	Major Types of Weirs	51
Table 4.1.5	Major Types of Intakes	52
Table 4.1.6	Function and Requirements of Power Canal	54
Table 4.1.7	Major Types of Power Canals	55
Table 4.1.8	Standard Maximum Velocity for Unlined Canal.....	56
Table 4.1.9	Required Facilities for Power Canal	58
Table 4.1.10	Function and Requirements of Head Tank.....	59
Table 4.1.11	Functions and Requirements of Penstock	62
Table 4.1.12	Functions and Requirements of Penstock	62
Table 4.1.13	Functions and Requirements of Powerhouse	64
Table 4.1.14	Functions and Requirements of Tailrace Canal.....	65
Table 4.2.1	Major Types of Impulse Turbines	71
Table 4.2.2	Major Types of Reaction Turbines.....	72
Table 4.2.3	Maximum Specific Speed of Major Turbine Types	74
Table 4.2.4	Standard Revolving Speed of Generator in Japan	74
Table 4.2.5	Required Specifications of Synchronous Generator and Induction Generator.....	76
Table 4.2.6	Major Types of Inlet Valve	78

Table 4.2.7	Comparison of Speed Inverter and Belt Transmission.....	79
Table 4.2.8	Examples of Major Devices and Systems in Main Circuit.....	81
Table 4.2.9	Examples of Functions in an Integrated Control Panel.....	82
Table 4.3.1	Comparison of Grounding Method	84
Table 5.1.1	Example of Future Amount and Present Value.....	91
Table 5.2.1	Assumed Procurement Locations of Equipment, Materials and Suppliers	93
Table 5.2.2	Major Work Items of Civil Works	95
Table 5.2.3	Major Temporary Facilities and Structures.....	95
Table 5.2.4	Components of Unit Price of Civil Works	96
Table 5.2.5	Example of the Construction Cost List of Electrical Equipment	97
Table 5.2.6	Main Distribution Facilities.....	98
Table 5.2.7	Components of Unit Price of Distribution Facilities	98
Table 5.2.8	Example of Construction Schedule	99
Table 5.3.1	Example of Economic Evaluation.....	103
Table 5.4.1	Example of Financial Evaluation	105
Table 6.2.1	“Second Schedule” Specified in EMCA (Project Sectors Subject to EIA).....	108
Table 6.2.2	Contents of the Project Report	111
Table 6.2.3	Contents of the Study Report	113
Table 6.2.4	Public Comments and Public Hearing in EIA Study Report Process.....	115
Table 6.3.1	E-waste Components in Renewable Energy Projects.....	116
Table 6.3.2	Hazardous Elements in Electrical and Electronic Equipment.....	117
Table 6.3.3	Non Hazardous Elements in Electrical and Electronic Equipment.....	117
Table 6.3.4	Handling Procedure of E-waste.....	118
Table 6.3.5	Licensed E-waste Handlers in Kenya (As of August 2013).....	118
Table 6.3.6	Draft E-waste Manifest Log From	120
Table 7.1.1	Types of Procurement and Maximum and Minimum Budgets	122
Table 7.1.2	Example of Procurement Schedule	124
Table 7.2.1	Work Items of Construction Supervision.....	125
Table 7.2.2	Items of Overall Management.....	125
Table 7.3.1	Major Inspection Items of Civil Works.....	131
Table 7.3.2	Procedure for Approval and Confirmation.....	132
Table 7.4.1	Major Items of Witness Test for Generation Equipment	134
Table 7.4.2	Major Items of Acceptance Test for Generation Equipment.....	135
Table 7.5.1	Major Inspection Items of Distribution Facilities	136
Table 8.1.1	Approximate Numbers of Members of Management.....	138
Table 8.2.1	Required Expenses of MHP Operation	139
Table 8.2.2	Sample of Breakdown of the Unit Generation Cost.....	140
Table 8.2.3	Required Expenses of MHP Operation	140
Table 8.2.4	Example of Balance Calculation Sheet	141
Table 8.3.1	Major Administrative Works for a MHP Station	143
Table 8.3.2	Inspection and Maintenance Items for Civil Structures	146
Table 8.3.3	Inspection Items of Periodic Inspection for Electrical Equipment.....	148
Table 8.3.4	Common Spare Parts for Electrical Equipment.....	149
Table 8.4.1	Major Assistance Items of Management Board	152

List of Figures

Figure 1	Potential Areas of Hydropower and Proposed Rural Electrification Method in Kenya	3
Figure 2.1.1	Flow Chart of Identification of Potential MHP Site	7
Figure 2.2.1	Index Map of Topographic Map with Scale of 1: 50,000	8
Figure 2.2.2	Protected and Conservation Areas	9
Figure 2.2.3	Archeological, Cultural Sites and Facilities.....	10
Figure 2.3.1	Example of the Catchment Area Measurement by Visual Estimation.....	11

Figure 2.3.2	Example of Catchment Area Measurement by CAD Software.....	12
Figure 2.3.3	Gauging Stations of WRMA.....	13
Figure 2.3.4	Sample of Double Mass Curves.....	13
Figure 2.3.5	Basic Procedure of the Data Supplementation.....	15
Figure 2.3.6	Discharge Hydrograph and Flow Duration Curve.....	15
Figure 2.3.7	Sub-basins surrounding the Potential Areas of Hydropower.....	17
Figure 2.3.8	Creager’s Coefficient of Hydropower Projects in Kenya.....	20
Figure 2.4.1	Required Head and Discharge.....	24
Figure 2.5.1	Development Pattern.....	25
Figure 3.2.1	Measurement by Float.....	31
Figure 3.2.2	Measurement by Current Meter.....	32
Figure 3.2.3	Sample of Head-Discharge Rating Curve.....	33
Figure 3.2.4	Survey Method by using Water Hose.....	34
Figure 3.2.5	Survey Method by using Carpenter’s Level.....	34
Figure 3.2.6	Survey Method by using Pressure Gauge.....	35
Figure 3.2.7	Survey Method by using Pocket Distance Meter.....	35
Figure 3.3.1	Sample of Alternative Layouts.....	37
Figure 3.3.2	Sample Procedure of Preparation of the Alternative Layout.....	38
Figure 3.3.3	Economical Sections of Open Canal.....	39
Figure 4.1.1	Typical Profile of MHP.....	46
Figure 4.1.2	Schematic Profile of Head Works.....	49
Figure 4.1.3	Flowchart to Estimate Inflow Discharge into Intake and Sample H-Q Curve.....	50
Figure 4.1.4	General Layout of De-silting Basin.....	53
Figure 4.1.5	Cross Drain under and Over Power Canal.....	58
Figure 4.1.6	Typical Profile of Head Tank.....	60
Figure 4.1.7	Typical Profile of Penstock.....	61
Figure 4.1.8	Water Hammer.....	63
Figure 4.1.9	Effective Head.....	66
Figure 4.2.1	Conceptual Diagram of Electrical Equipment in Powerhouse.....	69
Figure 4.2.2	Classification Tree of Turbines.....	70
Figure 4.2.3	Turbine Selection Diagram.....	73
Figure 4.2.4	Mechanism of Synchronous and Induction Generator.....	75
Figure 4.2.5	Examples of Main Circuit Connections.....	81
Figure 4.3.1	Line Constants.....	85
Figure 5.2.1	General Components and Estimation Method of MHP Project.....	93
Figure 5.2.2	Components of Construction Cost of Civil Works.....	94
Figure 6.1.1	Public Notice on Decentralization of NEMA Functions and Services.....	107
Figure 6.2.1	Overview of the EIA Process.....	110
Figure 6.2.2	EIA Project Report Review Process and Duration.....	112
Figure 6.2.3	EIA Study Report Review Process and Duration.....	114
Figure 6.2.4	Possible Schedule for EIA/Environmental Licenses.....	115
Figure 6.3.1	Used Battery Purchasing by a Battery Manufacturer.....	118
Figure 6.3.2	Conceptual Diagram of E-waste Manifest system.....	120
Figure 7.2.1	Sample of Organization of Construction Supervision Team.....	126
Figure 8.1.1	Example of Organization of Management Body.....	137
Figure 8.3.1	Example of Start-up Procedure of Power Generation.....	146
Figure 8.3.2	Inspections for Electrical Equipment.....	147
Figure 8.3.3	Basic Procedure of Accident Restoration Works.....	150

This guideline was prepared by the Working Group (WG) of MHP, composed of the following, under assistance of REA, MoE&P, and JICA. All figures and tables are prepared by the Working Group otherwise specified.

Working Group of MHP Guideline

Rural Electrification Authority (REA)

Eng. Ephantus Kamweru

Eng. James Muriithi

Ms. Judith Kimeu

Mr. Semekiah Ongong'a

Mr. Anthony Wanjara

And JICA Expert Team

List of Terms and Abbreviations

Abbreviation	Description
AC	Alternating Current
APFR	Automatic Power Factor Regulator
AVR	Automatic Voltage Regulator
B/C	Cost-Benefit Ratio
CAAC	Catchement Area Advisory Committee
CAD	Computer-Aided (Computer-Assisted) Detection
CD-ROM	Compact Disc Read Only Memory
CFD	Computational Fluid Dynamics
CH ₄	Chemical formula of methane
CIF	Cost of Insurance and Freight
CO ₂	Chemical formula of carbon dioxide
CPU	Central Processing Unit
CRT	Cathode Ray Tube
CV	Curriculum Vitae
CVCF	Constant Voltage Constant Frequency
DC	Direct Current
DEC	District Environmental Committee
EA	Environmental Audit
IEC	International Electrical Committee
IEEJ	Institution of Electrical Engineers in Japan
EIA	Environmental Impact Assessment
EIA-TAC	Environmental Impact Assessment Technical Advisory Committee
EIRR	Economic Internal Rate of Return
EMCA	Environmental Management and Coordination Act
E-waste	Electronic waste
FAX	Facsimile
FIDIC	Federation International des Ingenieurs Conseils/ International Federation of Consulting Engineers
FIRR	Financial Internal Rate of Return
FSWL	Full Supply Water Level
FV	Future Value
H ₂ S	Chemical formula of Hydrogen Sulfide
HEC-RAS	Hydrologic Engineering Centers River Analysis System
Hg	Chemical formula of Mercury
HH	Household
IC	Integrated Circuit
IPB	Isolated Phase Bus
JICA	Japan International Cooperation Agency
JET	JICA Expert Team
KeNHA	Kenya National Highways Authority
KeRRA	Kenya Rural Roads Authority
KNBS	Kenya National Bureau of Statistic
KP	Kenya Power
KS	Kenya Standard
KSh.	Kenya Shilling
KTDA	Kenya Tea Development Authority
LCPDP	Least Cost Power Development Plan
LED	Light Emitting Diode
L.S.	Lump Sum
LPG	Liquefired Petroleum Gas
MBC	Metering Billing Collection
MEWNR	Ministry of Environment, Water and Natural Resources
MHP	Micro Hydro Power, Mini Hydro Power
MoE&P	Ministry of Energy and Petroleum

MOL	Minimum Operation Level
MWI	Ministry of Water and Irrigation
NEDO	New Energy and Industrial Technology Development Organization in Japan
NEMA	National Environment Management Authority
NGR	Neutral Grounding Resistor
NPV	Net Present Value
NWMP 2030	National Water Master Plan 2030
OJT	On the Job Training
O&M	Operation and Maintenance
PEC	Provincial Environmental Committee
PPOA	Public Procurement Oversight Authority
PV	Present Value
PV	Photovoltaic
PVC	Polyvinyl Chloride
REA	Rural Electrification Authority
SCF	Standard Conversion Factor
SEA	Strategic Environmental Assessment
SHER	Similar Hydrological Elements Response
SSG	Speed Signal Generator
STD	Standard Tender Document
SWER	Single Wire Earth Return
TEL	Telephone
ToR	Terms of Reference
TV	Television
TWL	Tail Water Level
USD	United State Dollar
ULH-MHP	Ultra Low Head Micro Hydro Power
UNIDO	United Nations Industrial Development Organization
USEPA	United States Environmental Protection Agency
WG	Working Group
WRMA	Water Resources Management Authority
WRUA	Water Resource Users Association
WTP	Willingness to Pay

List of Electrical Terminology

Unit	Description
A (Ampere)	Unit of current
V (Volt)	Unit of voltage
kV (kilovolt)	1,000 volts
W (Watt)	Unit of electric power
kW (kilowatt)	1,000 W
MW (Megawatt)	1,000 kW
Wh (Watt-hour)	Unit of energy
kWh (kilowatt-hour)	1,000 Wh
MWh (Megawatt-hour)	1,000 kWh
VA (Volt-Ampere)	Unit of apparent power
kVA (kilovolt-ampere)	1,000 VA
MVA (Megavolt-ampere)	1,000 kVA
Hz (Hertz)	Unit of frequency

EXECUTIVE SUMMARY

1 Background

Access to electricity is one of the fundamental infrastructures which lead to improvement of people's living standards. The Government has given a high priority on rural electrification in "Kenya Vision 2030" as one of the key issues. Rural Electrification Authority (REA) was established by the Government in 2007 as an executing agency for rural electrification.

Hydropower is one of the power resources for rural electrification. The total potential of small scale hydropower in Kenya is estimated to be 3,000 MW out of which 30 MW has been exploited. The upsurge in demand for electric energy since 2004 has revealed an exciting potential for growth in exploitation of the small hydropower subsector. However, the development of hydropower has faced with challenges which include insufficient financial resources and lack of technical personnel and lack of hydrological data for carrying out feasibility studies.

The Government of Kenya and Japan International Cooperation Agency (JICA) agreed to implement the "Project for Establishment of Rural Electrification Model using Renewable Energy in Kenya" together with REA and Ministry of Energy and Petroleum (MoE&P) from the year 2012 to 2015.

The project has two main components;

- (i) To establish the rural electrification model through pilot projects of solar PV systems in public facilities, and
- (ii) To enhance the capacity of REA and MoE&P personnel for micro/mini hydropower (MHP), biomass/biogas and wind technologies.

This guideline was prepared as a tool for one of the capacity development activities.

2 Objective of the Guideline

This guideline describes how to implement MHP projects from identification stage to assistance for operation and maintenance stage.

Definitions of micro/mini/small hydro in the guideline are set as follows:

- ✓ Micro hydro: Less than 100 kW
- ✓ Mini hydro: 100 kW to 1,000 kW (1.0 MW)
- ✓ Small hydro: 1,000 kW to 10,000 kW (1.0 MW to 10.0 MW)

The guideline was prepared for MHP projects whose capacity ranges between 10 to 1,000 kW (Micro hydro and Mini hydro).

The guideline is to be provided to the personnel in Renewable Energy Department of REA, as well as persons who support implementation of REA projects including engineers in power utilities, universities and local consultants, with basic information and knowledge about hydropower technology, in order to utilise it for rural electrification.

3 Structure of the Guideline

This guideline was prepared by Working Group (WG) of REA and JICA Expert Team (JET) during the project period. The guideline was prepared based on the existing guidelines and manuals on small scale hydropower development for rural electrification.

In parallel with the making of the guideline, WG executed a simple pre-feasibility study on Asurur MHP in Nandi County. During the study, the contents of the existing guidelines and manuals were reviewed, modified and reflected on the guideline to incorporate actual conditions in Kenya, especially the planning section.

This guideline consists of the following eight (8) chapters. The general description of each chapter is summarized in the table below.

Table 1 General Description of the Guideline

Chapter	General Description
1. General	This chapter briefly explains advantage and disadvantage of MHP and basics of hydropower generation.
2. Identification of the Project	This chapter describes how to identify the potential MHP site and how to evaluate its hydropower potential and power demand by existing data before site investigation.
3. Investigation and Planning	This chapter describes key points for survey including consultation with the local community, power demand forecasting, technical investigations, and procedure of plan formulation.
4. Basic Design	This chapter describes the basic functions and hydraulic design methods of civil structures (structural design methods are not included), the standard types and estimation methods of basic technical features of electrical equipment and distribution facilities.
5. Economic and Financial Evaluation	This chapter explains key indicators for evaluation and difference between economic evaluation and financial evaluation with examples. Estimation of project cost is also explained in detail since it is important for the evaluation.
6. Environmental and Social Consideration	This chapter explains standard procedures for obtaining the environmental licence, solid waste management issues including E-waste, and other management issues for MHP.
7. Construction Supervision	This chapter explains procurement procedures of public works in Kenya and points of construction supervision works by the Client.
8. Operation and Maintenance	This chapter describes the importance of assistance to management board organized by the local community and key points of operation and maintenance works for MHP station and off-grid distribution system.

4 Features of the Guideline

There are many guidelines and manuals on MHP development in the world. The features of this particular guideline may be the following two points:

(1) Adopting the Results of NWMP 2030

Lack of hydrological data is one of the key challenges for development of MHP. WG also faced difficulty in evaluation of flow duration and definition of reliable discharge in the simple pre-feasibility study on Asurur MHP scheme due to shortage of hydrological data. The same problem might occur for the entire MHP planning process.

To mitigate this problem, WG included the simulated discharge data in “National Water Master Plan 2030 (NWMP 2030)” which was formulated by Ministry of Water & Irrigation (present Ministry of Environment, Water and Natural Resources) with technical cooperation by JICA. In NWMP 2030, rainfall-runoff analysis was conducted in nation-wise, and monthly average naturalized discharges were provided for 204 sub-basins for 20 years period.

By utilizing this data, a reliable discharge at the concerned MHP site is easily estimated without detailed hydrological analysis as preliminary evaluation. Therefore, it may contribute to preliminary identification & planning of MHP scheme.

However, measurement of discharge at the candidate site is essential for detailed planning.

(2) Adopting the Empirical Equations of Japan

In general, location of intake weir, route of power canal and penstock, location of powerhouse and tailrace, etc. can vary depending on the potential site. In the planning process, the optimum locations of those major structures will be determined by comparing generating energy and construction cost. A comparative study shall be carried out to identify the optimum development plan.

Empirical equations to estimate work quantities were presented in the guideline for comparative evaluation. The empirical equations were developed based on the rich experience and actual records of

MHP projects accumulated in Japan. Using these equations, a comparative study can be easily carried out by temporarily setting some major dimensions.

However, these empirical equations are applicable for comparative study only. A further detailed estimation is required in basic design and/or procurement stages.


5 Overview of MHP Development in Kenya

The potential of hydropower is dependent on the availability of river discharge. As indicated in the figure below, the areas around Mt. Kenya and the Western Kenya region around Kericho (also called water towers) receive annual rainfall of more than 1,500 mm. These two regions are regarded as high potential areas for hydropower development.

REA and Ministry of Energy (Present MoE&P) formulated “Rural Electrification Master Plan (REM 2009)” in August 2009 and areas for rural electrification by grid and off-grid were proposed as indicated in the figure below.

As seen in both figures, the potential areas of hydropower are overlapping with many targets to be electrified by grid. It is likely that electrification by MHP will be developed as off-grid systems in short to medium terms and they will be connected to the main grid in medium to long terms.

Therefore, MHP development shall be conducted, taking into consideration the possibility of grid connection in future and optimal development of finite water resources.



Source: “Project on the Development of the National Water Master Plan 2030, Sector Report (B) Meteorology and Hydrology, Figure 5.6.1” published by JICA in 2013, and “Rural Electrification Master Plan (REM 2009), Final Report Volume 1 – Main Report, Figure ES-3” on 15 August 2009, Page 24” (both arranged by JET).

Figure 1 Potential Areas of Hydropower and Proposed Rural Electrification Method in Kenya


CHAPTER 1 GENERAL

1.1 Basic of Hydropower Generation

Since the latter half of the nineteenth century, hydropower generation has been developed worldwide utilizing natural river water flow. Development of electrification first began with local power generation on a small scale, and then progressively developed into larger scale power generation as power demand increased. Through this process, power transmission lines and distribution networks were formed. Small scale hydropower generation has therefore played an important role in rural electrification

Hydropower generation is a power generation system utilizing gravitational potential energy of water.

Water flows down to a lower level by gravity, releasing gravitational potential energy. In hydropower generation, the water flow down to the water turbine causes the turbine to rotate. The water turbine rotates with a generator, and electricity is generated.



1.1.1 Power Output

Power output of hydropower generation is given by the following formula:

$$P = 9.8 \times Q \times H_e \times \eta$$

Where, P : power output (kW)
 Q : plant discharge (m^3/s)
 H_e : effective head (m)
 η : combined efficiency for turbine and generator (-)

Each element of the formula is described below.

(1) Plant Discharge

River flow varies daily, monthly and annually. Therefore, the plant discharge also varies depending on the available river flow. Definition of the plant discharge is one of the key issues in MHP planning. Details are explained in Chapter 2.3.

In general, the minimum and maximum plant discharges are defined as follows;

- ✓ Minimum plant discharge: 90 to 95% of dependable discharge at the site.
- ✓ Maximum plant discharge: Depends on peak load demand and available discharge.

(2) Effective Head

The effective head is given as follows:

$$\text{(Effective head)} = \text{(Gross head)} - \text{(Head loss)}$$

“Gross head” is the difference between the water level at inlet and water level at outlet.

The potential energy of water flowing down to the turbine is reduced as it passes through the waterway due to: friction, bending, reduction, expansion and branching of waterway, impediments along the waterway such as trashracks, valve, etc. Summation of such losses of potential energy between inlet and outlet is known as “head loss”.

Summation of each head loss can be estimated in the planning stage as follows:

$$\text{(Total head loss)} = \text{(7\% of gross head), and/or}$$

$$\text{(Total head loss)} = \text{(Friction loss in power canal)} + \text{(2 to 3\% of gross head as other losses)}$$

Details of head loss calculation are mentioned in Chapter 4.1.

(3) Combined Efficiency

The combined efficiency consists of the efficiencies of the turbine and generator. The exact values depend on the manufacturing companies for the turbine and generator. The following standard values can be applied for MHP planning stage.

Table 1.3.1 Standard Efficiencies for Planning Stage

Output	Efficiency of Turbine η_t (%)	Efficiency of Generator η_g (%)	Combined Efficiency η (%)
Less than 100 kW	79	91	72
100 to 300 kW	81	93	75
300 to 1,000 kW	83	94	78

1.1.2 Annual Energy

Annual energy of hydropower generation is given by the following formula:

$$E = \xi \times P \times 24 \times 365 = 8,760 \times \xi \times P$$

Where, E : Annual energy (kWh)
 ξ : plant factor (kW)
 P : maximum output (kW)
 H_e : effective head (m)

The plant factor (ξ) is the ratio between available discharge and maximum discharge.


In case of a run-of-river scheme, a flow duration curve is useful in estimating the approximate annual energy. The flow duration curve is a graph in which a series of discharge records are arranged in descending order and discharge is plotted along the ordinate axis and days or percentage is plotted along the abscissa axis. The flow duration curve shows flow duration.

The plant factor is given as follows:

$$\xi = \frac{\text{Area}(ABCDE)}{\text{Area}(ABGF)}$$

When a larger discharge is selected, a larger scale power facility with a lower plant factor is required. Conversely, when a smaller discharge is selected, a smaller plant facility with a higher plant factor is required.

The optimum maximum discharge should be selected taking into account the revenue to be generated and the initial construction cost, in principle. In addition, it should be selected bearing in mind that the power tariff needs to be properly established.



1.2 Required Generator Capacity for Rural Electrification

Power demand in local community is unknown before electrification. The generator capacity is able to be approximated by the following equation based on the assumption explained in Chapter 2.4:

$$P_d = 0.2N$$

Where, P_d : required generator capacity (kW)
 N : community size (number of household)

As a rough estimate, head of at least 20 m and discharge of 1.0 m³/s is enough for rural electrification of communities smaller than 500 households.

1.3 Advantage and Disadvantage of MHP

Advantages and disadvantages of MHP development are enumerated below.

Advantages:

- ✓ Hydropower is generated from natural resources. MHP application will contribute to practical use of natural water resources in the country, and minimize procurement cost of importing electricity as well as consumption for power generation,
- ✓ Hydropower could be considered as the safest, cleanest, and cheapest power generation method, in addition to its contribution to CO₂ emission reduction, and
- ✓ MHP development will contribute to regional socio - economic activities by providing electric power supply for household use and possibly for industrial use.

Disadvantages:

- ✓ Potential sites depend more significantly on topographic and hydrological conditions rather than power demand,
- ✓ Annual energy generation is highly dependent on river conditions, and the river flow may vary from rainy to dry seasons in the year and from one year to another. It is therefore difficult to accurately estimate river flow discharge, and
- ✓ Operation and maintenance activities required for both small and large scale hydropower stations are the same in principle. Technical correspondence and financial arrangements are required in both instances, but securing the human resources and budget is more difficult for MHP projects.

MHP is one of the major options for rural electrification. However, development of the MHP system shall be studied carefully taking into consideration the above advantage and disadvantages.

1.4 Brand New Technology - ULH -MHP

Recently, United Nations Industrial Development Organization (UNIDO) is implementing pilot projects of renewable energy generation technology called “Ultra Low-Head Micro Hydropower (ULH-MHP)” system in many countries including Kenya. The ULH-MHP system is the most up-to-date and commercially available technology developed in this field, innovated a few years ago in Japan.



The ULH-MHP is different from the conventional hydropower technologies. The ULH-MHP system can generate electricity from low water head of less than 5 m and discharge of some 0.5 to 1.0 m³/s in regulated water such as waterfall of existing water supply and sewage system, power station waterways, drainage from factories, agricultural waterways, stream channels, etc. Hydropower generation in these conditions has not been previously considered feasible.

The ULH-MHP system is a suitable way to generate electricity due to the following advantages:

- a) It has less civil works since the equipment comes assembled and is mounted on an already existing canal,
- b) The procedure calls for limited environmental concerns and it is easy to install (in the past instances, 3 days in Japan and 7 days in India), and
- c) The maintenance is simple and does not require advanced technology.

UNIDO is planning to execute a pilot project of ULH-MHP system in Mwea Irrigation Project to generate up to 130 kW of electricity by installing 13 units of ULH-MHP along the irrigation canals, and the power generated is planned to be channeled to the rice mills for processing the rice.

CHAPTER 2 IDENTIFICATION OF THE PROJECT

2.1 Work Flow of Identification

Work flow of identification of a potential MHP site for rural electrification is summarized below.




Figure 2.1.1 Flow Chart of Identification of Potential MHP Site

Natural conditions, i.e., topography, annual average discharge and hydropower potential, are constant in principle. However, social conditions such as the status of electrification of the area and accessibility change every several years. Furthermore, environmental regulations may possibly be updated over time as well. Confirmation of the current status of non-electrified areas and their surrounding conditions is important for the identification of a MHP project site.

The following information is required to identify promising sites for MHP development schemes:

- ✓ Existing distribution network from Kenya Power (KP)
- ✓ Grid extension plan from REA and KP
- ✓ Least Cost Power Development Plan (LCPDP) from Ministry of Energy and Petroleum (MoE&P)
- ✓ Environmental Acts and laws from Ministry of Environment, Water and Natural Resources (MEWNR).
- ✓ Existing road network and road construction plan from Kenya National Highways Authority (KeNHA) and Kenya Rural Roads Authority (KeRRA)
- ✓ Topographic map (1:50,000) from Land Survey Department under Ministry of Land, Housing and Urban Development, and
- ✓ Population census data from Kenya National Bureau of Statistics (KNBS).

2.2 Selection of the Target Non-electrified Area

2.2.1 Clarification of Non-electrified Area

Initially, it is necessary to clarify which areas are on-grid, off-grid or connected to an isolated grid. The following information shall be collected and updated regularly (at least once a year).

- ✓ Existing distribution network from REA and KP,
- ✓ Grid extension plan from REA and KP, and
- ✓ Least Cost Power Development Plan (LCPDP) from MoE&P.


For instance, the above clarification can be carried out within the potential areas of hydropower development mentioned in Executive Summary. When the off-grid area is confirmed, a target non-electrified area shall be selected.

2.2.2 Identification of Steep River Site

Once the target non-electrified area is selected, topographic maps with scale of 1: 50,000 are prepared.

(1) Purchasing Topographic Map

Topographic maps are available for purchase from the Land Survey Department under the Ministry of Land, Housing and Urban Development. The index map of the potential areas of hydropower development is shown below.



Source: Land Survey Department under Ministry of Land, Housing and Urban Development (arranged by WG)

Figure 2.2.1 Index Map of Topographic Map with Scale of 1: 50,000

(2) Criteria for the Identification

Steep river sites in and around the target area are studied on the topographic maps. A steep river site means that the river site has closely-spaced contour lines. The criteria of identification of steep river sites are as follows:

- 1) Study area within 5 km of villages in the target area

In general, potential site of MHP shall be identified within 5 km of the target villages due to limitation of efficient distribution.

- 2) Identify the river sites with intervals less than 200 m

In general, the ratio between head (H) and length of waterway (L) shall be less than 10 ($L/H < 10$) to secure its economic feasibility. Therefore, river sites with closely-spaced contour lines less than 200 m in length shall be identified.

On the topographic map with a scale of 1: 50,000, ruled lines which are square in shape and 1 km in height and width are provided, and contour lines are drawn at intervals of 20 m in height.

1 km in the map is equivalent to 2 cm on a hard copy. Accordingly, the actual length on the hard copy is as follows:


- 1) Study area within 10 cm of villages in the target area.
- 2) Identify the river sites with intervals less than 4 mm.

2.2.3 Confirmation of Social Conditions around the Site

There are two major issues of confirmation of social conditions at and around the site, i.e., (1) whether a protected area or conservation area exists, and (2) accessibility to the site.

- (1) Protected Areas and Conservation Areas

Environmental regulations including areas reserved from any development should be reviewed. In addition, procedures of environmental assessment for project planning and implementation shall be confirmed.



Source: "Kenya State of the Environment and Outlook 2010" published by NEMA in 2011

Figure 2.2.2 Protected and Conservation Areas



Source: Base Map; National Museums of Kenya (<http://www.museums.or.ke/content/view/248/127/>) (arranged by JET)

Figure 2.2.3 Archeological, Cultural Sites and Facilities

(2) Accessibility to the Site

Accessibility to the potential site shall be possible not only for site investigation but also for future construction.

Accessibility is confirmed using topographic maps and/or the internet (e.g. Google maps). If access roads are not identified on these maps, the latest road network and road construction plan shall be confirmed from Ministry of Land and/or Ministry of Transport and Infrastructure.

2.3 Estimation of the Hydropower Potential

2.3.1 Measurement of the Catchment Area

The catchment area of the candidate site is indicated and measured on the topographic map with scale of 1: 50,000. The following methods can be applied to measure the catchment area.

(1) Measurement by Visual Estimation

A topographic map provides grid lines at an interval of 1 km, which means that an area of one cell is equivalent to 1 km². It is therefore possible to measure the catchment area manually using the following steps:

- a) Count the number of square cells in the catchment area,
- b) Assume the area of each partial cell in the catchment area, across which the boundary of the catchment area passes, and
- c) Sum up the area of all the square and partial cells in the catchment area.

An example of measurement by visual estimation is shown below.





Figure 2.3.1 Example of the Catchment Area Measurement by Visual Estimation

(2) Measurement by Planimeter

This was the most common method in the past. A planimeter is a device to measure the area of any shape on a plane.

Measurement by Planimeter shall be carried out as follows:

- Draw the boundary line of the catchment area on the topographic map,
- Clean up a desk and fix the topographic map onto it using a tape or paperweight,
- Define a start point on the boundary line of the catchment area,
- Place the planimeter on the topographic map and adjust the scale following the instruction manual of the planimeter,
- Fit the measuring point which is generally located at the arm toe of the planimeter,
- Trace the boundary line of the catchment area by moving the measuring point around on the map, and
- When the measuring point returns to the start point, record the measured value indicated on the screen of the planimeter.



Repeat the tracing more than three times, and calculate the average of measured values. The catchment area is given by the average value.

(3) Measurement by CAD Software

This is the most common method at present. The method is able to measure the catchment area more accurately than other methods.

Measurement by CAD software shall be carried out as follows:

- Convert the topographic map into an image file (bmp, jpg, gif, tif, etc.),
- Import the topographic map into the CAD file,
- Adjust the scale of the topographic map,

- d) Trace the boundary line of the catchment area by polyline,
- e) The CAD file automatically calculates and indicates the area.

An example of measurement by CAD software is shown below.




Figure 2.3.2 Example of Catchment Area Measurement by CAD Software

2.3.2 Estimation of Dependable Discharge

Evaluation of river discharge is vital for proper planning and design of hydropower development. In terms of rural electrification with an isolated grid system, the power generation should be available throughout the year.

River discharge varies daily, monthly and annually, and it is therefore necessary to review discharge data over the longest period possible for MHP planning. At least 10 years of daily discharge data is desirable for proper planning.

The dependable discharge for MHP is estimated using the following steps:

- ✓ Estimate the average monthly discharge at the candidate site;
- ✓ Prepare the flow duration curve for the candidate site, and
- ✓ Define the dependable discharge at 90 to 95% of probable discharge.


The following data are available for hydrological analysis:

- ✓ Discharge data from Water Resources Management Authority (WRMA),
- ✓ Rainfall data from Kenya Meteorological Department (KMD), and
- ✓ Simulated monthly discharge data by National Water Master Plan 2030 (NWMP 2030).

(1) Estimation from WRMA Discharge DATA

WRMA is executing measurement and compilation of river discharge data. Available data can be confirmed on their website as shown below.

However, observed data of WRMA has uncertainties including many periods for which data is missing. Therefore, it is preferable to collect discharge data at as many gauging stations surrounding the candidate site as possible. Then, collected discharge data are examined as explained hereinafter.



Source: WRMA website (<http://mangomap.com/maps/8325/KENYA>)

Figure 2.3.3 Gauging Stations of WRMA

1) Confirmation of the Data Homogeneity

The homogeneity of the data is confirmed by the double mass curve. In the double mass curve, the cumulative volume of daily or monthly discharge data at some gauging station is plotted on the horizontal axis and the cumulative volume of discharge data at another gauging station is plotted on the vertical axis. When the records of two gauging stations are homogeneous, the plots form a continuous straight line as shown below.




Figure 2.3.4 Sample of Double Mass Curves

It is not necessary that the horizontal axis and vertical axis show the discharge volume to determine the data homogeneity. The volume in correlation, for instance, discharge and rainfall, may be used.

2) Confirmation of Data Correlation between each Gauging Station

The correlation of discharge data between each gauging station is evaluated by the correlation coefficient (R), given by the following equation.

$$R = \frac{\sum_{i=1}^n (x_i - x_a) \times (y_i - y_a)}{\sqrt{\sum_{i=1}^n (x_i - x_a)^2 \times \sum_{i=1}^n (y_i - y_a)^2}}$$

Where,

R : correlation coefficient (-)
 x_i : monthly discharge at gauging station X (m^3/s)
 x_a : average discharge at station X (m^3/s)
 y_i : monthly discharge at gauging station Y (m^3/s)
 y_a : average discharge at station Y (m^3/s)

Value of correlation coefficient (R) is variable between minus 1.0 and plus 1.0, and the correlation is evaluated as tabulated below.

Range of "R"	Correlation
$-1.0 < R < -0.7$	Strongly negative correlation
$-0.7 < R < -0.4$	Moderately negative correlation
$-0.4 < R < -0.2$	Slightly negative correlation
$-0.2 < R < 0.2$	Little correlation
$0.2 < R < 0.4$	Slightly positive correlation
$0.4 < R < 0.7$	Moderately positive correlation
$0.7 < R < 1.0$	Strongly positive correlation

3) Supplementation of Missing Data

The discharge record often has some data missing; and it needs to be supplemented before conducting hydrological analysis. The supplementation generally is carried out by the linear regression method with the data at the neighboring gauging stations surrounding the candidate site.

The linear regression line is given by the following equations:

$$y = a \times x + b$$

$$a = \frac{\sum_{i=1}^n (x_i - x_a) \times (y_i - y_a)}{\sum_{i=1}^n (x_i - x_a)^2}$$

$$b = y_a - a \times x_a$$

Where,

Y : missing discharge (m^3/s)
 X : discharge data of the same time of the above missing discharge (m^3/s)
 a : slope of the linear regression line (-)
 b : intercept of the linear regression line (-)
 x_i : monthly discharge at gauging station X (m^3/s)
 x_a : average discharge at station X (m^3/s)
 y_i : monthly discharge at gauging station Y (m^3/s)
 y_a : average discharge at station Y (m^3/s)

The calculation shall be carried out for available gauging stations. The supplementation of one gauging station data shall be carried out by another gauging station which has the highest correlation coefficient.

The basic procedures of the supplementation of missing data are shown below.

1. To select the Gauging Station for Data Supplementation by Use of Correlation Coefficient

R : Correlation Coefficient

	Station A	Station B	Station C
Station A		0.720	0.602
Station B	0.720		0.606
Station C	0.602	0.606	

Data supplement will be made by:

For missing data at Station A → Data at Station B ($0.720 > 0.602$)
 For missing data at Station B → Data at Station A ($0.720 > 0.606$)
 For missing data at Station C → Data at Station B ($0.606 < 0.602$)

2. To prepare the Linear Regression Line

Applied Linear Regression Line

a : Slope of Linear Regression Line

		x		
		Station A	Station B	Station C
y	Station A		0.737	0.724
	Station B	0.704		0.782
	Station C	0.501	0.469	

For Station A: $y = 0.737x + 27.507$

For Station B: $y = 0.704x + 43.102$

For Station C: $y = 0.469x + 41.265$

b : Intercept of Linear Regression Line

		x		
		Station A	Station B	Station C
y	Station A		27.507	42.844
	Station B	43.102		48.359
	Station C	44.530	41.265	




Figure 2.3.5 Basic Procedure of the Data Supplementation

4) Estimation of Discharge at the Site

Discharge at the candidate site is estimated based on available discharge at the gauging station (where it is located downstream of the candidate site) as follows:

$$Q = Q_s \times \frac{A}{A_s}$$

Where, Q : discharge at the candidate site (m^3/s)
 Q_s : discharge data at the gauging station (m^3/s)
 A : catchment area of the candidate site (km^2)
 A_s : catchment area of the gauging station (km^2)

Average discharge data is arranged in discharge hydrograph and flow duration curve as shown below.




Figure 2.3.6 Discharge Hydrograph and Flow Duration Curve

5) Estimation of Dependable Discharge at the Site

The dependable discharge is defined from the flow duration curve, within 90 to 95% of reliable discharge.

It is noted that if there are existing water uses upstream of the site, such as irrigation, domestic consumption, etc., the water amount of use shall be deducted from the estimated monthly average discharge. Water use conditions in upstream basin shall be assumed at this stage, and will be confirmed in site investigation.

(2) Estimation by KMD Rainfall Data

KMD is executing measurement and compilation of rainfall data. It is preferable to collect rainfall data at as many gauging stations surrounding the candidate site as possible. Then, homogeneity and correlation of collected rainfall data are examined in the same manner as WRMA discharge data.

Monthly discharges at the candidate site are estimated using the following formula:

$$Q_{ave} = \frac{C \times R \times 10^{-3} \times CA \times 10^6}{60 \times 60 \times 24 \times D}$$

Where,

Q_{ave} : monthly average discharge (m³/s)
 C : runoff ratio (-)
 R : monthly rainfall (mm)
 CA : catchment area (km²)
 D : days of each month (31, 30, 29 or 28 days)

The runoff ratio depends on the topographic conditions in the catchment area, and is given as follows:

Topographic Condition	Runoff Ratio "C"
Flat countryside, arable land or sandy soil	0.25 – 0.35
Meadow, smooth slope land	0.35 – 0.45
Hilly area with forest, land rocky	0.45 – 0.55
Mountainous area, rock land, frozen surface	0.55 – 0.65


When series of discharge data are prepared, those discharge data are arranged in discharge hydrograph and flow duration curve, and the dependable discharge is defined, in the same manner as WRMA discharge data.

(3) Simulated Monthly Discharge Data by NWMP 2030

Rainfall-runoff analysis was conducted by JICA in 2013 by the "Project on Development of the National Water Master Plan 2030", by applying the Similar Hydrological Elements Response model (SHER model) for the entire country. As a result of simulation by SHER model, the monthly average naturalized discharges were provided for 204 sub-basins for the period from 1991 to 2010.

The sub-basins surrounding the potential area of hydropower development are shown in the figure below. The monthly average naturalized river discharges by sub-basins surrounding the potential area are attached in Annex-1. The naturalized river discharge was defined in NWMP 2030 as the river runoff that is not affected by any water use in the catchment area.

The series of discharge data of sub-basins surrounding the candidate site are converted into the discharges at the candidate site by ratio of catchment area. Additionally, those discharge data are arranged to discharge hydrograph and flow duration curve, then the dependable discharge defined, in the same manner as WRMA discharge data.



Source: “National Water Master Plan 2030” conducted by JICA in 2013 (arranged by WG).

Figure 2.3.7 Sub-basins surrounding the Potential Areas of Hydropower

2.3.3 Amount of the Reserve Discharge by WRMA

The amount of the reserve, consisting of ecological and basic human needs, was determined as the 95% value of the naturalized daily flow for each river in accordance with “Guidelines for Water Allocation (WRMA, 2010)”. Therefore, the minimum discharge shall be determined by deducting of 95% reliable discharge.

2.3.4 Estimation of Probable Flood Discharge

In general, 50 to 100-year probable flood discharges are used for the design flood discharge of MHP schemes.

Information on regional floods is not available or limited in general. The flood analysis is carried out by several methods, these results compared, and then the design flood discharge determined.

The major analysis methods are explained below.

(1) Statistical Analysis

The statistical analysis is carried out among the annual maximum daily discharge by several frequency curves, such as Gumbel’s distribution, Pearson distribution, log normal distribution, log Pearson type

III distribution, etc. The frequency curve which is harmonized with the discharge records will be applied.

(2) Rational Formula

The rational formula is commonly applied for the estimation of flood discharge at the catchment area less than 200 km². The formula is given as follows;

Rational Formula (Lloyd Davies, 1906)

$$Q_P = \frac{1}{3.6} \times f \times R_T \times A$$

Where,

Q_P : peak discharge (m³/s)

f : runoff coefficient (-)

R_T : average rainfall intensity in flood duration (mm/hr)

A : catchment area (km²)

The runoff coefficient is given as follows depending on the land use conditions in the catchment area:

Land use Condition	f	Land use Condition	f
Steep mountainous area	0.75 – 0.90	Irrigated paddy field	0.70 – 0.80
Tertiary mountainous area	0.70 – 0.80	River in highland	0.75 – 0.85
Undulating land and forest	0.50 – 0.75	Small river in plain	0.45 – 0.75
Flat cultivated land	0.45 – 0.60	Large river mostly plain	0.50 – 0.75

The average rainfall intensity is estimated by the following two (2) formulae:

Mononobe Formula

$$R_T = \frac{R_{24}}{24} \times \left(\frac{24}{T} \right)^{2/3}$$

Where,

R_{24} : probable daily rainfall (mm/day)

T : time to concentration of runoff (hr)

t : time to concentration of runoff (min)

Ito Formula

$$R_T = R_{24} \times \left(\frac{347.1}{t^{1.35} + 1,502} \right)$$

The flood concentration time (T , t) is generally estimated by two times, i.e., overland inflow time from the basin to river and river flow time to the site. Those values are given as follows. The required topographic characteristics in the formulae of the catchment area are assumed from the topographic map with scale of 1: 50,000.

Overland Inflow Time [Kerby Formula]

$$T_{OF} = \left(\frac{2}{3} \times 3.28 \times l \times \frac{N}{\sqrt{S}} \right)^{0.467}$$

Where,

T_{OF} : overland inflow time (min)

l : length between basin crest and top of river (m)

N : retardance coefficient (-)

River Flow Time [Rziha Formula]

$$T_{RF} = \frac{L}{W},$$

Where,

T_{RF} : river flow time (s)

L : horizontal length of river channel from top of river to the site (m)

W : flood velocity (m/s)

h : height difference from top of river to the site (m)

The retardance coefficient for overland inflow time is given as follows depending on the land surface conditions in the catchment area:

Land Surface Condition	N	Land Surface Condition	N
Impervious surface	0.02	Forest area with deciduous trees	0.60
Bare ground (grainy surface)	0.10	Forest area with deciduous deposit	0.80
Bare ground (normal surface)	0.20	Forest area with conifer trees	0.80
Rough grass and cultivated fields	0.20	Dense forest area	0.80
Grass farm and normal grass field	0.40	-	-

(3) Estimation by Regional Area Flood Curve in NWMP 2030

Regional area flood curves are given by logarithmic function as the results of flood analysis in NWMP 2030. The flood curve is available for 10-year, 25-year, 50-year, and 100-year probable flood in the following 21 sub-basins.

Table 2.3.1 21 Sub-basins of Regional Area Flood Curve by NWMP 2030

Lake Victoria North	Lake Victoria South	Rift Valley
LVN-2 Yala	LVS-2 Asure	RV-2 Ewaso Ngiro (South)
LVN-3 Nzoia	LVS-5 Mara	RV-12 Kedong
LVN-6 Malikisi	LVS-6 Migori	RV-14 Lake Naivasha
LBN-7 Malaba	LVS-10 Kabondo Awach	RV-19 Lake Bogoria
	LVS-11 Sondu	RV-20 Lake Baringo
	LVS-12 Nyando	Others
	LVS-13 Oruba	AT-1 Athi
	LVS-14 Kibos	TN-1 Tana
	LVS-16 Awach Seme	EN-1 Ewaso Ngiro

Source: "National Water Master Plan 2030" conducted by JICA in 2013 (arranged by WG).

The regional area flood curves are attached in Annex-2. The peak flood discharges are obtained by plugging in the catchment area into the flood curve.

(4) Confirmation by Creager Envelop Curve

Adequacy of the estimated flood discharges is checked by the Creager envelope curve.

The Creager envelope curve is an empirical formula which indicates the relation between catchment area and estimated or recorded flood peak discharge by the form of specific discharge.

The Creager envelop curve is given by the following formula:

$$Q_p = 0.503 \times C \times \left(\frac{A}{2.59} \right)^{a-1}$$

$$a = 0.894 \times \left(\frac{A}{2.59} \right)^{-0.048}$$

Where,

Q_p : Specific peak discharge ($\text{m}^3/\text{s}/\text{km}^2$)

C : Creager's coefficient (-)


A : catchment area (km^2)

The Creager coefficient "C" indicates regional characteristics of catchment area. Therefore, it is variable depending on the location of the basin, but nearby basins have similar values. The "C" value, therefore, shall be estimated based on the available flood records and/or design flood discharges in the existing projects to obtain the appropriate value near the basin.

The flood peak specific discharges and the "C" values of hydropower projects in Kenya are compared as shown below.

Table 2.3.2 Creager's Coefficient of Hydropower Projects in Western Kenya

Project Name	County	A (km ²)	Q _d (m ³ /s)	Q _p (m ³ /s/km ²)	C (-)	Remarks
<i>Proposed MHP</i>						
Ura Kiegoi 1	Meru	59	82	1.396	5.7	Flood during construction
Kazita Githongo	Meru	155	27	0.174	1.0	
Thiba Kiringa Conf.	Embu	252	204	0.812	5.9	
Irati-Maragwa Conf.	Muranga	101	101	1.001	5.0	
Gura-Sagana Conf.	Kirinyaga	439	132	0.300	2.8	
Zaina Falls-Chania Conf.	Nyeri	34	2.2	0.068	0.2	
Greater Orobo	Nandi	50	121	2.407	9.3	
Kiptiget - Itare Conf.	Bomet	186	42	0.227	1.4	
Ainamoi - Kitio	Kericho	333	75	0.227	1.9	
Chemosit - Kabianga	Bomet	1,370	310	0.227	3.8	
Wei Wei - Sighor	Nakuru	203	35	0.172	1.1	
Embobut - Tot	Elegeyo Marakwet	34	496	14.714	50.1	
Embobut - Nguruman	Kajiado	237	3.6	0.015	0.1	
<i>Large Scale HPP</i>						
Sundu/ Miriu	Kisumu	3,345	1,046	0.313	8.6	PMF
			749	0.224	6.1	1000-years flood
Magwagwa	Nyamira	3,160	1,920	0.608	16.1	PMF
			1,634	0.517	13.7	1000-years flood

**Figure 2.3.8 Creager's Coefficient of Hydropower Projects in Kenya**

2.4 Estimation of the Power Demand

2.4.1 Estimation of required Generator Capacity

Power demand in the local community is unknown before electrification. In general, rural electrification plans are based on assumptions of minimum electric equipment in order to identify promising development schemes.

The generator capacity can be approximated using the following equation based on the assumptions explained hereinafter:

$$P_d = 0.2N$$

Where, P_d : required generator capacity (kW)
 N : community size (number of households)

Community size, i.e., the number of households in the communities in the target area shall be identified based on the population and housing census from Kenya National Bureau of Statistics (KNBS).

(1) Assumption of Power Demand

Assumptions of percentage share and unit demand of each consumer are made as shown below.

Table 2.4.1 Basic Assumptions of Consumers and Unit Demand

User	Share per household or Number per village	Assumed Demand			
		Lighting	TV	Fan/Heater	Total
Domestic					
Type A	20% of total households	-	-	-	0
Type B	60% of total households	20 W x 2	-	-	40
Type C	20% of total households	20 W x 3	200 W x 1	-	260
Type D	1 per 100 households	40 W x 5	200 W x 1	200 W x 1	600
Public					
Primary School	1 per 100 households	40 W x 15	200 W x 1	200 W x 1	1,000
Community Hall	1 per 100 households	40 W x 15	-	200 W x 2	1,000
Dispensary	1 per village > 100 households	40 W x 5	-	200 W x 2	600
Streetlight	1 per 4 households	40 W x 1	-	-	40
Business					
Battery Charging Station	1 per 50 households	-	-	-	1,200
Posho Mill	1 per 200 households	-	-	-	5,000

With the basic assumptions outlined above, the power demand of a rural community can be estimated as presented in the table below, for villages of different sizes ranging from 20 to 1,000 households.

Table 2.4.2 Assumed Consumers and Power Demand

Assumed Number of Consumers		(Unit: numbers)								
User	Unit Demand	Community Size (Household)								
		1,000	800	600	400	300	200	100	50	20
Domestic										
Type A	0	200	160	120	80	60	40	20	10	4
Type B	40	600	480	360	240	180	120	60	30	12
Type C	260	200	160	120	80	60	40	20	10	4
Type D	600	10	8	6	4	3	2	1	0	0
Public										
Primary School	1,000	10	8	6	4	3	2	1	0	0
Community Hall	1,000	10	8	6	4	3	2	1	0	0
Dispensary	600	1	1	1	1	1	1	1	0	0
Streetlight	40	250	200	150	100	75	50	25	12	5
Business										
Battery Charging Station	500	20	16	12	8	6	4	2	1	0
Posho Mill	5,000	5	4	3	2	1	1	0	0	0
Total		1,106	885	664	443	332	222	111	53	21

Assumed Power Demand		(Unit: kW)								
User	Unit Demand	Community Size (Household)								
		1,000	800	600	400	300	200	100	50	20
Domestic										
Type A	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Type B	40	24.0	19.2	14.4	9.6	7.2	4.8	2.4	1.2	0.5
Type C	260	52.0	41.6	31.2	20.8	15.6	10.4	5.2	2.6	1.0
Type D	600	6.0	4.8	3.6	2.4	1.8	1.2	0.6	0.0	0.0
Public										
Primary School	1,000	10.0	8.0	6.0	4.0	3.0	2.0	1.0	0.0	0.0
Community Hall	1,000	10.0	8.0	6.0	4.0	3.0	2.0	1.0	0.0	0.0
Dispensary	600	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.0	0.0
Streetlight	40	10.0	8.0	6.0	4.0	3.0	2.0	1.0	0.5	0.2
Business										
Battery Charging Station	500	10.0	8.0	6.0	4.0	3.0	2.0	1.0	0.5	0.0
Posho Mill	5,000	25.0	20.0	15.0	10.0	5.0	5.0	0.0	0.0	0.0
Total		147.6	118.2	88.8	59.4	42.2	30.0	12.8	4.8	1.7

(2) Estimation of required Generator Output

The required generator output (P_r) to supply for the power demand derived above can be calculated by the following formula:

$$P_r = P_d + w_1 + w_2$$

$$= P_d \times (1 + 0.2 + 0.1) = 1.3P_d$$

Where, P_r : required generator output (kW)
 P_d : power demand (kW)
 w_1 : losses of distribution line, assumed to be 20% of P_d
 w_2 : reserved power, assumed to be 10% of P_d

The required generator output to meet the corresponding power demand in Table 2.4.2 is calculated using the above equation and presented in the table below as rounded figures.

Table 2.4.3 Required Generator Capacity by Community Size

(Unit: kW)

Item	Community Size (Household)								
	1,000	800	600	400	300	200	100	50	20
Assumed Power Demand: P_d	147.6	118.2	88.8	59.4	42.2	30.0	12.8	4.8	1.7
Required Generator Output: P_r	191.9	153.7	115.4	77.2	54.9	39.0	16.6	6.2	2.2
Selected Generator Capacity P_g	200	160	120	80	60	40	20	10	3

Accordingly, the generator capacity (kW) can be approximated at 20% of the number of households in the community

2.4.2 Estimation of Required Head and Discharge

When a discharge drops through a head, the work done per unit time is called the “theoretical hydropower”.

Here, the discharge is defined as the amount of water flow used for power generation, and the head is defined as the height difference between intake and turbine outlet. Theoretical hydropower is calculated using the following equation.

$$P_0 = g \times H \times Q = 9.8HQ$$

Where, P_0 : theoretical hydropower (kW)
 g : gravity acceleration (9.8 m/s^2)
 H : static head (m)
 Q : discharge (m^3/s)

In practice, the theoretical hydropower cannot be produced because there are energy losses when converting gravitational potential energy of water into mechanical energy and then further into electrical energy. The relationship between the theoretical hydropower and the required generator capacity can be expressed as follows:

$$P_i = P_0 \times \eta_G \times \eta_T / (1 + m) = 0.65P_0$$

Where, P_i : required generator capacity (kW)
 P_0 : theoretical hydropower (kW)
 η_G : combined efficiency, assumed to be 72%
 m : rate of other losses, assumed to be 10%

The required discharge to obtain the required power is given for various heads as shown below.

Table 2.4.4 Required Discharge by Available Head

Item	Community Size (Household)								
	1,000	800	600	400	300	200	100	50	20
Generator Capacity (kW)	200	120	95	80	55	40	20	10	4
Theoretical Potential (kW)	308	185	146	123	85	62	31	15	6
Available Head (m)	Required Discharge (m^3/s)								
30	1.05	0.63	0.50	0.42	0.29	0.21	0.10	0.05	0.02
25	1.26	0.75	0.60	0.50	0.35	0.25	0.13	0.06	0.03
20	1.57	0.94	0.75	0.63	0.43	0.31	0.16	0.08	0.03
15	2.09	1.26	0.99	0.84	0.58	0.42	0.21	0.10	0.04
10	3.14	1.88	1.49	1.26	0.86	0.63	0.31	0.16	0.06
5	6.28	3.77	2.98	2.51	1.73	1.26	0.63	0.31	0.13
3	10.47	6.28	4.97	4.19	2.88	2.09	1.05	0.52	0.21




Figure 2.4.1 Required Head and Discharge

2.5 Comparison between Power Demand and Hydropower Potential

For MHP with an isolated grid system, it is desirable that the power generated is higher than the power demand. Otherwise, a backup power system needs to be provided to meet the full load.

Taking into consideration the development pattern of MHP, the hydropower potential at the candidate site is evaluated as follows:

Table 2.5.1 Evaluation of the Hydropower Potential

Condition	Evaluation	Next Step
$P_d < P_{90}$	In case P_d is smaller than P_{90} , hydropower potential at the site is enough for electrification of the target area.	Proceed to field investigation.
$P_{90} < P_d < P_{50}$	In case P_d is within the range of P_{90} and P_{50} , hydropower potential at the site is not enough for electrification of the target area. Alternative power sources, such as diesel generator, solar, wind, etc., shall be integrated into the MHP.	Proceed to field investigation.
$P_{50} < P_d$	In case P_d is larger than P_{50} , hydropower potential at the site is not suitable for electrification of the target area.	Do not proceed with the candidate site.

Note: P_d means the power demand; P_{90} & P_{50} means the hydropower potential by 90%/50% reliable discharge.




Figure 2.5.1 Development Pattern

CHAPTER 3 INVESTIGATION AND PLANNING

3.1 Social Investigation

Initially, MHP was identified based on some assumptions and application of limited data and information. Therefore, the assumptions shall be reviewed for precision through site investigation. The MHP planning shall proceed based on the updated conditions.

The major purposes of site investigation are to conduct:

- ✓ Survey on power demand forecasting, and
- ✓ Survey on hydropower potential,

3.1.1 Survey on Power Demand Forecasting

When the planned MHP has been developed successfully, the operation and maintenance will be carried out by a management body organized by local residents. Accordingly, participation of local residents from the planning stage is important for successful development and implementation.

Notwithstanding the above, development of MHP at the target site is not guaranteed at this stage. The purpose of the site survey, the present stage of the MHP plan, and the procedure up to construction shall be explained carefully to local residents in order to avoid exaggerated expectations for electrification.

The social survey at this stage consists of the following activities:

(1) Consultation with Local Community

At first, it is necessary to explain to representatives of the local community the electrification plan and to obtain their approval to access the community area/village for investigation. Essential information to be communicated to the community are as summarized below.

- ✓ Outline of electrification plan,
- ✓ Outline of the hydropower mechanism,
- ✓ Purpose, kinds and period of investigation in the village,
- ✓ Influence of investigation on the residents , if any,
- ✓ Steps of development procedure,
- ✓ Management method after development, and so on.

It is noted that at this stage, the development possibility is still uncertain with equal chance of proceeding or cancellation, and this shall be reiterated during consultations with the local community.

(2) Social Economic Survey

A survey of the attitude of residents towards the proposed electrification is carried out, and their needs for electric energy clarified. The results of the survey will be reflected in the plan and the design.

Table 3.1.1 Item of Social Economic Survey

Category	Item	Content
I. Key Information Survey	Operational period	Time to begin social economic study (Concurrently with prior consultation)
	Target person	District, village, and other local leaders.
	Matters for study	Basic information on population, number of households, industries, etc.
	Usage and purpose	Basic information collection. Scale of household research and materials for survey
II. Workshop (briefing)	Operational period	Before conducting the household research.
	Target person	Local representatives of leaders and residents.
	Purpose	Explanation of outline of MHP rural electrification. Explanation of household research procedure.
III. Household Research	Operational period	After Workshop (briefing)
	Target person	About 20% or more of the total number of households. (Reliability and target accuracy of the statistical study are considered.)
	Method	Interviews
	Main research item	1. Number and composition of family 2. Employment and income. 3. Presence and use of electric equipment (current situation). 4. Attitude and considerations for electrification. 5. Demand level of electrification. 6. Amount of energy expenditure (illumination, power and others). 7. Amount of payment intention. 8. Number of beneficiaries and geographic distribution situation.

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Table 6-4)", published by JICA in 2011 (arranged by WG).

(3) Power Demand Survey

In general, there are no time-series data available in the target rural area to be electrified by MHP scheme. Therefore, the power demand for each household is estimated first using the applicable electric appliances and these are summed up for the target area.

It is therefore necessary to conduct a social and economic survey for the target area in advance. The survey is conducted using interviews or a questionnaire sheet. To collect more accurate information, door-to-door interviews are the recommended survey approach. There are several methods for the study and approach. One of the typical methods is introduced here. However different methods could be used depending on the conditions concerned.

1) Classification of Target Village

It is important to prepare a proper questionnaire to meet the current situation of the target village. There are many kinds of non-electrified villages such as a high income villages in which residents own portable generators, or are supported financially by remittances from relatives, etc. If electricity demand for such a village is estimated based on lighting and TV alone, power supply will run short over time because of increasing numbers of electric appliances year by year. It is therefore very important to conduct a tailored social and economic survey for the target village in advance.

Villages are classified into three categories as follows:

Low income village

A low income village is generally seen in a very remote area far away from the city, with limited crop acreage and a larger aging society. Electricity demand in low income villages is generally limited to lighting and TV, and the annual growth rate of electricity consumption is small.

Middle income village

A middle income village is generally seen in a less remote area, with some economic activity such as cultivation of cash crop and livestock keeping. Some households in the village already use automobile batteries to watch TV. In such villages, the annual growth rate of electricity consumption will rapidly increase.

High income village

Some households in a high income village will generally own portable generators and vehicles. If such a village is electrified, people will purchase electric appliances such as refrigerators, washing machines, etc., and electricity supply will run short, which may lead to frustration. In such high income villages, electrification by grid extension is better than an independent power source.

2) Household survey

An interview or questionnaire survey of residents who live in a non-electrified village is necessary. Such households typically have limited access to information because of lack of televisions, etc., and it is therefore important to prepare a simple questionnaire sheet and not to use difficult words such as “disposable income”. It is also necessary to ask questions that are simple to answer because they do not record energy consumption and expenditure.

3) Industry survey

It is envisaged that there are no large industries in non-electrified villages. However, it is necessary to check for existing cottage industries which may be using a portable generator or to check for possible industrial applications for electricity use after electrification.

3.1.2 Survey on Future Management Capability

As mentioned above, operation and maintenance of MHP system will be carried out by a management body organized by local residents. Therefore, management capability of the community shall be surveyed.

A public consultation meeting shall be held to explain the following issues:

- ✓ Purpose of survey and electrification planning,
- ✓ Power station and distribution facilities will become the community’s property,
- ✓ Operation and maintenance in view of technical and financial requirements will be managed independently by the communities, in principle,
- ✓ Initial cost for wattmeter and lead-in will be borne by each household,
- ✓ Necessity of cooperation on installation of utility pole and distribution line, etc. in respect to site occupancy, and so on.

Through such a meeting, the implementation body and local residents are able to exchange opinions to achieve mutual understanding.

Major points of the survey at this stage are the reactions and results of the discussion regarding future operation and maintenance by the community itself. When the basic plan of MHP project has been confirmed, further specific preparations shall start.

3.1.3 Survey on Environmental and Social Impacts

The possible influences occur due to hydropower development are listed below. A detailed survey will be carried out by environmental specialists registered as lead expert on EIA/EA in NEMA after the feasibility of the project has been confirmed but before making financial arrangements.

However, initial observation is important for the project implementation. Possible environmental and social impacts due to MHP development are listed on the table below.

Table 3.1.2 Possible Environmental Impact by Hydropower Development

Item	Possibility
Physical Impact	
River diversion	River runoff between intake weir and outlet decreases because of the diversion for power generation. The project may affect aquatic life and animals, as well as people using the river flow.
Downstream river flow	In case of pond type development, the natural river flow will be regulated at the intake weir, and river flow conditions downstream will be altered.
Water pollution	Water pollution will affect drinking water and/or aquatic life and animals. During construction stage, water pollution due to improper treatment of used water, leakages of fuels for construction equipment are possible. During operation stage, water pollution due to leakages of lubricating oils and other chemical materials for electrical equipment are possible.
Impact on Natural Environment	
Biological environment	The construction of a power plant needs grounds for generation and distribution facilities, and access roads. Tree cutting and clearing are carried out at the operation stage in order to secure the necessary height and passage under the distribution line.
Disappearance of organisms living environment	The terrestrial habitat in the inundation area is lost due to the construction of intake weir. The ecosystem will be affected and careful attention should be paid to the area if it is a wildlife habitat for rare and endangered species. In addition, aquatic gene biodiversity will be affected because of reduced opportunities of genetic interaction caused by the weir as migration barrier. Migratory fishes in particular, which move between the upstream and downstream areas or sea, would suffer seriously due to the blockage of migration and reproduction. Open channel of headrace, access roads and temporary roads for construction may possibly obstruct the movement of prowling animals.
Impact on Social Environment	
Resettlement and land occupation	Residents who live in the permanent project area have to move to areas outside the project area. People who live in temporary areas, such as disposal areas, stockyards, contractor's camp, etc., might have to move temporarily. There may also be cases where areas such as farm lands and important public facilities are inundated.
Intangible cultural assets	It might happen that an archaeological site or an ancient dwelling site is unexpectedly discovered during construction.
Water use, water right and communal land	In a case where the area affected by river diversion is utilized for inland water fisheries, the project might affect the fisheries. The construction might destroy a landscape and possibly affect the potential development of tourism, such as water fall and/or swale.
Increase of disease and electric accident	Malaria disease might break out because an intake weir creates a pond which may become a breeding ground for mosquitoes. Matters of safety for people using electricity for the first time are important in newly electrified villages.
Influence to local community	Introduction of electricity to a non-electrified area brings a change to the living conditions of villagers. The amount of kerosene usage decreases drastically by changing from kerosene to electricity, and the business opportunity for kerosene and kerosene lamps sellers is affected. Further, kerosene or LPG refrigerator users may also change to electric ones, similarly affecting business opportunities. Concerning the planned distribution line, there might be a concern that its installation may potentially trigger existing friction between conflict areas and renew fighting. If the project is designed unfairly, it might raise an issue that the electrification will advantage a limited part of the community e.g. higher socioeconomic groups, etc.
Traffic accident	Although serious traffic problems might not occur for MHP projects, attention should be paid to cases where the road is used for specific functions of daily life such as access to schools or water facilities, etc.
Improvement of residents life	Since the MHP project changes a non-electrification area to an electrified one, positive effects such as improvement of the living conditions of the people may possibly be large. The positive impacts may contribute to health, education, agriculture, development of new small industries, etc. However the users are required to pay the electricity tariff, and a support strategy might be necessary to ensure residents enjoy the potential benefits of MHP by connecting to the power supply.

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Chapter 7.4.2)", published by JICA in 2011 (arranged by WG).

3.2 Technical Investigation

3.2.1 Measurement of River Discharge

In general, the existence of either discharge or water level records is limited in the rural areas. When a MHP site is identified, discharge measurement of the river over a period of one year is undesirable due to the following two issues:

Estimation of the reliable discharge

In order to supply the required electric power constantly throughout the year, it is essential that the minimum river discharge in the dry season meets the load requirements. In this context, it is important to measure the river discharge in the dry season for the planning of a MHP station with an off-grid system.

Additionally, if there is an irrigation intake upstream of the planned MHP site, the river discharge is likely to be reduced during the irrigation periods. It will therefore be necessary to check the river discharge at the intake site during the irrigation period.

Estimation of the flood discharge

It is also necessary to observe the flood water levels during the rainy season in order to know the possible maximum water level of floods and to protect the intake and waterway facilities from the floods accordingly.

River discharge fluctuates seasonally and annually, and the discharge measurement shall therefore be undertaken continuously for at least 3 years for MHP planning.

(1) Installation of the Water Level Gauge

The site for discharge measurement and water level observation shall be selected on:

- ✓ A straight river stretch where water depth is uniform and flow conditions are stable without any obstructions (If the river section is irregular, wide or shallow, the accuracy of measurement results will be poor),
- ✓ A uniform slope section of the river to avoid being affected by the change in riverbed level and river width due to scouring or sedimentation. Attention is needed to protect the gauge from damage by floods and flowing debris.

A wooden staff with graduation preferably at 1 cm intervals shall be prepared and firmly placed vertically by concreting its bottom end deep into the ground, at a depth of at least 50 cm. The zero level on the gauge shall be below the lowest water level expected in the dry season. Accordingly, the gauge should be installed in the dry season. The graduated surface shall be faced in such a way that the gauge reader can easily read the water level or clean the gauge surface.

It is also possible to place a graduated staff on a rigid rock surface under the water upon each measurement. In this case, the position for placement of the gauge shall be clearly marked for its easy identification at the next measurement.

The water level observation should be made as many times as possible. It is preferable to read the gauge once a day at a fixed time, 7:00 a.m. for example. The task of gathering such information may be assigned to the local community or inhabitants.



Installation of the gauge



Stepped water level gauge

(2) Measurement of Discharge

It is preferable that the discharge measurement for the planned MHP scheme is carried out after defining the position of the water level gauge, because the relationship between discharge and water level is important for planning of the scheme and design of the intake weir.

There are two (2) methods available for measurement of the river discharge as discussed below. Both methods estimate the river discharge from the flow areas and the flow velocities in a stream.

1) Measurement by using Float

This is the easiest method, as it does not require any special equipment.





Figure 3.2.1 Measurement by Float

Measurement by float shall be carried out as follows:

- Define three (3) sections upstream and downstream of the water level gauge section as shown in the above figure,
- Measure flow area at Section 1, Section G and Section 2 as follows:
 - Divide the river width (w) into n (> 2) uniform strips for each section and measure water depth (d_i) at the center of each strip for all three sections,
 - Obtain the section area (a) at each section using the following equation:

$$a = w/n \times (d_1 + d_2 + \dots + d_n)$$



Where,

- a : section area (m^2)
- w : river width (m)
- n : number of strips (nos.)
- d_i : depth at center of each strip (m)

- Obtain the average section area of the 3 sections,
- Drop the float at the center of Section 0,
- Measure the time of float from Section 1 to Section 2 using a stopwatch,
- Repeat the same procedure 3 more times,

f) Calculate the average flow velocity using the following equation:

$$V_i = L_2 / T_i$$

Where, V_i : flow velocity at i-th measurement (m/s)
 L_2 : distance between Section 1 and Section 2 (m)
 T_i : arrival time of float from Section 1 to Section 2 (s)

g) Calculate the discharge using the following equation:

$$Q = c \times V \times A$$

Where, Q : discharge (m³/s)
 c : flow velocity coefficient (-)
 (c=0.65 for shallow stream, c=0.80 for smooth stream, c=0.85 for concrete channel)
 V : average flow velocity (m/s)
 A : average cross sectional area (m²)

2) Measurement by using Current Meter

This is the most common method of measuring velocities where the stream is not irregular or turbulent.




Figure 3.2.2 Measurement by Current Meter

Discharge measurement using current meter is conducted by selecting one section beside the gauging staff. Depth and flow area measurement shall be carried out using a similar method to that for float measurement.

Velocity measurement alone may be sufficient for streams where a MHP site is planned under the following conditions:

- ✓ 2-point method: velocity measurement at two points - 20% and 80% of the depth from the surface (0.2d and 0.8d). It is applicable for depth more than 1 m.
- ✓ 1-point method: velocity measurement at one point - 60% of the depth from the surface (0.6d). It is applicable for depth less than 1 m.

The mean velocity is given by the following equation:

2-point method (for depth > 1 m):

$$V_m = 1/2 \times (V_{0.2} + V_{0.8})$$

1-point method (for depth < 1 m):

$$V_m = V_{0.6}$$


Where,

V_m : mean flow velocity (m/s)

$V_{0.2}$: velocity at 20% depth from surface (m/s)

$V_{0.6}$: velocity at 60% depth from surface (m/s)

$V_{0.8}$: velocity at 80% depth from surface (m/s)



The discharge of flow can be derived using the following equation:

$$Q = V_m \times A$$

Where,

Q : discharge (m^3/s)

A : cross sectional area (m^2)

If the river width is wide, it shall be divided into n (> 2) uniform strips in the same manner as the measurement of flow area, and the velocity measurement shall be made at the center of each strip. In this case, the discharge can be calculated using the following equation:

$$Q = Q_1 + Q_2 + \dots + Q_n$$

$$Q_i = V_i \times A_i = V_i \times W/n \times d_i$$

Where,

Q : river discharge (m^3/s)

Q_i : discharge in i -th strip (m^3/s)

A_i : flow area of i -th strip (m^2)

W : river width (m)

n : number of the strips (nos)

d_i : flow depth at center of i -th strip (m)

V_i : mean flow velocity at $0.6d_i$
or average of $0.2d_i$ and $0.8d_i$ of center of i -th strip (m/s)


It is essential to check if the current meter has been calibrated prior to measurement.

As a general rule, the current meter should be calibrated once a year in order to obtain reliable velocity. Old current meters without calibration shall not be used. In cases where a calibrated meter is not available, float measurements would give more dependable results.

(3) Preparation of Head-Discharge Curve

When the discharge measurement has been done more than 10 times within the appropriate range, the relationship between discharge and water level is converted to a quadratic equation as shown below.

Observed Date (D/M/Y)	Time	Weather	H (m)	Q (m^3/s)
10 Jan. 2011	14:10	Fine	0.42	3.6
10 Feb. 2011	14:05	Fine	0.48	4.2
20 Mar. 2011	13:58	Cloudy	0.75	7.3
15 Apr. 2011	15:50	Rainy	1.03	10.4
15 May 2011	15:53	Rainy	1.06	12.0
17 Jun. 2011	14:09	Cloudy	0.76	7.5
21 Jul. 2011	13:54	Fine	0.52	4.8
21 Aug. 2011	14:03	Fine	0.70	6.4
15 Sep. 2011	14:00	Cloudy	0.78	7.7
18 Oct. 2011	14:10	Cloudy	0.90	8.9
18 Nov. 2011	14:05	Rainy	0.92	9.0
14 Dec. 2011	14:02	Fine	0.87	8.2
12 Jan. 2012	14:55	Fine	0.33	2.9
10 Feb. 2012	14:04	Fine	0.30	2.6



Accumulated data through discharge measurement  Plotting data & converting to a quadratic equation.
To be updated periodically.

Figure 3.2.3 Sample of Head-Discharge Rating Curve

The quadratic equation is known as a “H-Q curve” and/or “Rating Curve”. The discharge can then be estimated by observation of the water level gauge.

However, it is noted that the rating curve should be reviewed periodically for calibration, especially after flood seasons that may result in erosion on the river banks or sedimentation on the riverbed.

3.2.2 Measurement of Available Head

Available head shall be confirmed at the site. The head can be measured quickly using simple and less-costly methods in the preliminary planning stage, as explained below.

(1) Survey Method by using Water Hose

A water hose filled with water is placed as shown below. A transparent water hose may be preferable so that the water level inside the hose is visible. Both ends of the hose shall be kept nearly at the same level by fixing to pieces of timber or leveling rods. Measure the height from the water level in the hose

to the ground at both ends (h_1 and h_2). Measure the distance between the two ends (L) if the slope is required.




Figure 3.2.4 Survey Method by using Water Hose

The head and slope are calculated using the following equations:

$$H = h_2 - h_1$$

$$I = H/L$$

Where, H : height difference between the two point (m)
 h_2 : height at upper point (m)
 h_1 : height at lower point (m)
 I : slope of the ground surface (-)
 L : distance between the two point (m)

Repeat the same procedure until you arrive at the desired place. The gross head is obtained by summing up H_i for $i = 1$ to n steps ($\sum H = H_1 + H_2 + \dots + H_n$).

(2) Survey Method by using Carpenter's Level

The second option is to measure the height difference using a carpenter's level and straight board as shown below. In case the length of the straight board is not enough, the level point on ground is confirmed by using additional straight board or rope.




Figure 3.2.5 Survey Method by using Carpenter's Level

Height difference H_i shall be measured progressively to arrive at the desired place. The gross head can be obtained by summing up H_i for $i = 1$ to n steps ($\sum H = H_1 + H_2 + \dots + H_n$).

(3) Survey Method by using Pressure Meter

The third option is to use a pressure meter and water hose filled with water as shown below.




Figure 3.2.6 Survey Method by using Pressure Gauge

In case the water hose does not reach the desired place, repeat the same procedure until you arrive at the desired place. The gross head can be obtained by summing up H_i for $i = 1$ to n steps ($\sum H = H_1 + H_2 + \dots + H_n$).

(4) Survey Method by using Pocket Distance Meter

The fourth option is to use a combination of a pocket distance meter and an angle measuring device (a hand level with compass, clinometers, etc.) as shown below.




Figure 3.2.7 Survey Method by using Pocket Distance Meter

An inclined length (L) is measured using the pocket distance meter while the horizontal angle (θ) is measured using the angle measurement device. The height difference can be given by the following equation:

$$H = L \times \sin \theta$$

Where, H : height between the two point (m)
 L : length between the two point (m)
 θ : horizontal angle (degree)

In this case, the two points are required to be visible to each other. The angle measurement should be made by targeting the head of a man standing on the reference point. This is to have the same height of the observer's eye level above the ground for accuracy. The distance measurement should also be done using a reflecting board of about 30 cm square.

3.2.3 Observation of Site Topography

The site topography shall be confirmed at site as topographical maps of 1:50,000 are not always of reliable accuracy. The items listed below should be checked. For the sites where further survey is considered to be necessary after the site reconnaissance, topographic survey of the area surrounding the site will be required.

Table 3.2.1 Check Point of Site Topography

Location	Check Point
Intake site	River section, width of water surface, gut, riverbed, outcrop, river slope, gradient of bank slope, bank vegetation, etc.
Power canal route	Topography, gradient of slope, vegetation of slope, landslide, slope collapses, slope deposits, gulleys, etc.
Powerhouse site	Slope situation of penstock route, nature and kind of outcropped rocks, vegetation, river bed at the river outlet, etc.

3.2.4 Observation of Site Geology

The purpose of geological survey is to identify the best placement of installations of system components such as power canal, penstock and powerhouse. A small amount of effort on site geology is easily repaid in cost savings in canal construction, sound penstock and turbine foundations, and safety from canal collapse due to slope instabilities.

(1) Check Point

Since a waterway such as power canal passes mainly on the slope of the terrain, a geological ground surface survey is required in order to inspect the stability of the ground surface. Geological outlines should be grasped by site survey of items such as rock categories of ground surface, strata seen in cliffs and topography.

Use maps and photographs to sketch out the basic geological characteristics of the area. Check points and identification items for the site survey are listed below.

Table 3.2.2 Check Point of Site Geology

Geological Phenomena	Identification
Loose slope	Debris, dry mud, lack of vegetation
Storm gully	Debris
Flood plain	Local residents' knowledge and experience
Landslide, fault	Semi-circular crack or step in hillside

(2) Test Pit

Generally rocks are covered by top soil on which many grasses and trees grow thick. The geological survey should not be finalized by checking only gullies and outcrops, but should be carried out by removing the top soil if necessary. Since the geology is generally complicated, the geological structure should be grasped broadly for the project area.

Test pitting is enough to confirm the foundation geology of the key structures for MHP schemes. A practical pit size is 1.8 m in length, 1.2 m in width and 5.0 m in depth. It can be dug manually using scoops and picks, and a rope and bucket to lift up the excavated soil without using any further heavy lifting equipment.

A pit log should be prepared for every test pit, as a report of the test pitting, and should contain the pit number, its location, boundaries and depths, description of soil, groundwater table and bedrock surface, and all other additional relevant information, if any.

3.3 Plan Formulation

In general, there are many alternative approaches, such as location of intake weir, route of power canal and penstock, and location of powerhouse and tailrace, which can be taken in development at a potential site. A comparative study shall be carried out to identify the optimum development scale and optimum structures' layout.

Prior to the comparative study, power demand of the target area and hydropower potential are reviewed based on the site investigation results.

3.3.1 Preparation of Alternative Layout

(1) Preparation of Topographic Map

The detailed planning and design shall be conducted based on a topographic map with a scale of 1:500 or more.

(2) Selection of Alternative Sites of Intake Weir and Powerhouse

Intake weir site and powerhouse site can generally be arranged at several positions depending on the longitudinal profile of the river. The longitudinal profile is created from the topographic map, and alternative sites of intake weir and powerhouse shall be defined to obtain high head within a short horizontal length as shown below.




Figure 3.3.1 Sample of Alternative Layouts

(3) Preparation of Alternative Layout

Alternative sites of intake weir and powerhouse, as well as layouts of civil structures depend on the topographic conditions at the candidate site. Alternative layouts are prepared by taking the following steps:

- 1). Define the intake weir site near the position selected in the above,
- 2). Define the penstock line to be arranged along the ridge lines of hills as much as possible, from the powerhouse site near the position selected in the above,
- 3). Define the powerhouse and the head tank position by adjustment with the penstock line, and
- 4). Define the power canal alignment to connect the de-silting basin and the head tank along the contour line.

A sample of an alternative layout is shown below. In case the waterway distance on one bank is clearly shorter than on the other bank, it is not necessary to prepare an alternative layout.




Figure 3.3.2 Sample Procedure of Preparation of the Alternative Layout

(4) Definition of Turbine Center Level

Turbine center level is designed to avoid inundation during flooding. Hydraulic calculation is necessary to estimate flood water level against design flood discharge as explained below. The turbine center level is defined above the flood water level.

1) Uniform Flow Calculation

Water level against some discharge can be estimated as uniform flow using the following Manning's equation:

$$Q = \frac{A}{n} \times R^{2/3} \times I^{1/2}$$

Where,

Q :	discharge (m^3/s)
A :	flow area (m^2)
n :	roughness coefficient (-)
R :	hydraulic radius = A/S (m)
S :	wetted perimeter (m)
I :	gradient of water surface (= slope of river) (-)

The river's cross section and gradient in front of the planning site is obtained from the topographic map.

Roughness coefficient is selected from the following values in accordance with the river condition confirmed during site visit.

Table 3.3.1 Roughness Coefficient of Natural River

River Conditions and Materials	Roughness Coefficient: n		
	Min.	Typical	Max.
Small River in the Plains			
1. River channel is straight without weeds and there is no edge.	0.025	0.030	0.033
2. Same as above, but there are stones and weeds often.	0.030	0.035	0.040
3. No weeds but meandering, there are some shoals and brink.	0.033	0.040	0.045
4. Same as above, but there are some stones and/or weeds.	0.035	0.045	0.050
5. Same as above, but change of the cross-section and gradient is less at low water level.	0.040	0.048	0.055
6. Same as 4, but the stones are often further apart.	0.045	0.050	0.060
7. River flow is gentle; there is a deep abyss and weeds.	0.050	0.070	0.080
8. Section where weeds are dense, grove and/or deep abyss appears often.	0.075	0.100	0.115
Mountain River: There are no plants in the river channels, river bank is steep, shrubs and trees along the river bank are submerged at high water level.			
1. Riverbed is gravel and cobble.	0.030	0.040	0.050
2. Riverbed is large boulder.	0.040	0.050	0.070
Large River			
1. Rules section without shrubs and large boulders.	0.025	-	0.060
2. Course irregular section.	0.035	-	0.100

Source: "Planning and Designing Criteria for Agricultural Land Improvement Project" published by Rural Development Bureau in Ministry of Agriculture, Forestry and Fisheries of Japan in 2001.

2) Non-uniform Calculation

Water level against some discharge can be estimated as non-uniform flow calculation by utilizing free software called "Hydrologic Engineering Centers River Analysis System" (HEC-RAS), developed by US Army Corps of Engineers. The software and user's manual are available on their website free of charge.

Procedures of analysis are described in the user's manual and are briefly itemized below.

- 1). Create new project,
- 2). Input geometric data (coordinates of cross sections (station and elevation), downstream reach lengths, Manning's values, main channel bank stations, etc.),
- 3). Input flow data (discharge), and
- 4). Run the analysis.

(5) Definition of Dimensions of Power Canal

Dimensions of the power canal are calculated using Manning's formula to determine the economical section against the design maximum discharge. The economical section is that which circumscribes the semicircle of radius equal to the water depth as shown below.




Figure 3.3.3 Economical Sections of Open Canal

(6) Definition of Crest Level of Intake Weir

Crest level of intake weir is defined as follows, and the intake water level is defined as the crest level. The gross head for alternative study is obtained by subtracting the intake water level from the turbine centre level.

$$CL = EL_{RB} + h_{sf} + h0$$

Where, CL : crest level of intake weir (EL.m)
 EL_{RB} : original riverbed level (EL.m)
 h_{sf} : depth for sand deposit and flushing (m)
 $h0$: design water depth of power canal (m)

3.3.2 Estimation of Project Cost

Project cost is estimated based on the empirical methods and equations compiled in the following references:

- ✓ “Guide Manual for Development Aid Programs and Studies of Hydro Electric Power Development” published by New Energy Foundation under Ministry of Economy, Trading and Industry of Japan in December 1996.
- ✓ “Handbook for Estimation of Hydropower Project Costs” published by Agency for Natural Resources under Ministry of Economy, Trading and Industry of Japan in March 2013.

These references describe in an understandable manner the studies involved from the initial planning stage to the feasibility study stage of development projects. It is intended for hydropower engineers and is based on the rich experience in MHP accumulated in Japan.

Estimation of MHP project cost hereinafter is for comparative study only. Further detailed estimation is therefore required in basic design and/or procurement stages.

(1) Component of Project Cost

Project cost of MHP is estimated using the following components and empirical methods.

Table 3.3.2 Estimation of Project Cost

Description	Estimation Method
I. Preparatory Works	Access road: assumed length (km) multiple unit prices. Land compensation: 5% of Item II + Item III. Temporary facilities: 20% of Item II + Item III. Environmental mitigation: 3% of Item II.
II. Civil Works	Estimate work quantity of major works of each structure using empirical equations as explained in Table 3.3.3, and the work quantities using multiple unit prices
III. Electrical Equipment	Estimate using empirical equation shown in Section (4) based on the maximum power output and effective head.
IV. Distribution System	Assumed length (km) multiple unit prices.
Sub-total 1 (Direct Cost)	Sum of Item I, II, III, and IV.
V. Administration and Engineering Cost	15% of sub-total 1 (Direct cost)
VI. Physical Contingency	10% of sub-total 1 (Direct cost)
Sub-total 2 (Indirect Cost)	Sum of Item V and VI.
Total	Sum of Sub-total 1 and Sub-total 2 (direct cost and indirect cost).

Source: “Guide Manual for Development Aid Programmes and Studies of Hydro Electric Power Development” and “Handbook for Estimation of Hydropower Project Costs” (arranged by WG).

(2) Estimation of Work Quantities of Civil Works

The work quantities of civil works can be estimated using empirical equations in the references listed below.

Table 3.3.3 Empirical Equations for Estimation of Work Quantities of Civil Works

Description	Empirical Equation	Remarks
1. Intake Weir		Less than 15 m of height.
a. Excavation (m ³)	$V_e = 0.181 \times (H \times L)^{1.92}$	H: height of the weir (m)
b. Concrete (m ³)	$V_c = 11.9 \times (H^2 \times L)^{0.701}$	L: crest length of the weir (m)
c. Re-bar (ton)	$W_r = 0.00893 \times V_c^{1.04}$	Q: design flood discharge (m ³ /s)
d. Sand flush gate (ton)	$W_g = 0.145 \times Q^{0.692}$	
e. Others (L.S.)	30% of sum of the above costs.	Grouting, river diversion, etc.
2. Intake		Non-pressure type
a. Excavation (m ³)	$V_e = 637 \times (R \times Q)^{0.580}$	R: inner radius of waterway (m)
b. Concrete (m ³)	$V_c = 43.6 \times (R \times Q)^{1.01}$	Q: design plant discharge (m ³ /s)
c. Re-bar (ton)	$W_r = 0.0345 \times V_c^{1.05}$	
d. Intake gate (ton)	$W_g = 2.67 \times (R \times Q)^{0.470}$	
e. Intake screen (ton)	$W_s = 1.04 \times (R \times Q)^{0.534}$	
f. Others (L.S.)	25% of sum of the above costs.	River diversion, dust collector, etc.
3. De-silting basin		Q: design plant discharge (m ³ /s)
a. Excavation (m ³)	$V_e = 515 \times Q^{1.07}$	
b. Concrete (m ³)	$V_c = 392 \times Q^{0.882}$ (with slab) $V_c = 188 \times Q^{1.04}$ (without slab)	
c. Re-bar (ton)	$W_r = 0.150 \times V_c^{0.808}$	
d. Drainage gate (ton)	$W_g = 0.910 \times Q^{0.613}$	
e. Drainage screen (ton)	$W_s = 0.696 \times Q^{1.27}$	
f. Others (L.S.)	20% of sum of the above costs.	Slope protection, dust collector, etc.
4. Power Canal		Open type
a. Excavation (m ³)	$V_e = 1.66 \times \{(B \times H)^{1/2}\}^{2.40} \times L$	B: inner width of canal (m)
b. Concrete (m ³)	$V_c = \{H \times t \times 2 + (B + 2t) \times t\} \times L$	H: inner height of canal (m)
c. Re-bar (ton)	$W_r = 0.0592 \times V_c^{0.896}$	L: Length of the canal (m) t: thickness of concrete (m)
d. Others (L.S.)	30% of sum of the above costs.	Slope protection, fence, etc.
5. Head Tank		Q: design plant discharge (m ³ /s)
a. Excavation (m ³)	$V_e = 398 \times Q^{1.07}$	
b. Concrete (m ³)	$V_c = 66.0 \times Q^{1.14}$	
c. Re-bar (ton)	$W_r = 0.0724 \times V_c$	
d. Others (L.S.)	40% of sum of the above costs.	Slope protection, gate, screen, etc.
6. Spillway Canal		R: inner radius of spillway (m) L: length of spillway
a. Excavation (m ³)	$V_e = 17.4 \times R^{1.01} \times L$	
b. Concrete (m ³)	$V_c = 3.38 \times R^{1.31} \times L$	
c. Re-bar (ton)	$W_r = 0.0358 \times V_c$	
d. Others (L.S.)	30% of sum of the above costs.	Slope protection, fence, etc.
7. Penstock		D: inner diameter of penstock (m) L: length of penstock (m) H _e : effective head (m) Q: design plant discharge (m ³ /s)
a. Excavation (m ³)	$V_e = 12.2 \times D^{1.26} \times L$ (single lane) $V_e = 10.9 \times D^{1.33} \times L$ (multi lanes)	
b. Concrete (m ³)	$V_c = 2.92 \times D^{1.26} \times L$ (single lane) $V_c = 1.86 \times D^{1.48} \times L$ (multi lanes)	
c. Re-bar (ton)	$W_r = 0.0178 \times V_c$	
d. Steel penstock (ton)	$W_p = (0.0003 \times H_e + 0.04) \times L$ $W_p = (0.0006 \times H_e + 0.08) \times L$ $W_p = (0.0009 \times H_e + 0.12) \times L$ $W_p = (0.0012 \times H_e + 0.14) \times L$ $W_p = (0.0014 \times H_e + 0.16) \times L$ $W_p = (0.0017 \times H_e + 0.17) \times L$ $W_p = (0.0020 \times H_e + 0.18) \times L$	
e. Others (L.S.)	20% of sum of the above costs.	Grouting, slope protection, etc.

8. Powerhouse		
a. Excavation (m ³)	Surface type: $V_e = 11.4 \times (Q \times H_e^{2/3} \times n^{1/2})^{0.952}$ Semi-surface type: $V_e = 38.0 \times (Q \times H_e^{2/3} \times n^{1/2})^{0.952}$	Q: design plant discharge (m ³ /s) H _e : effective head (m) n: number of turbine (nos.)
b. Concrete (m ³)	Surface type: $V_c = 6.79 \times (Q \times H_e^{2/3} \times n^{1/2})^{0.824}$ Semi-surface type: $V_c = 15.9 \times (Q \times H_e^{2/3} \times n^{1/2})^{0.933}$	
c. Re-bar (ton)	Surface type: $W_r = 0.0326 \times V_c^{1.04}$ Semi-surface type: $W_r = 0.0764 \times V_c^{0.979}$	
d. Others (L.S.)	50% of sum of the above costs.	Building works, drainage, etc.
9. Tailrace		Non-pressure type without gate.
a. Excavation (m ³)	$V_e = 164 \times (R \times Q)^{0.532}$	R: radius of tailrace (m)
b. Concrete (m ³)	$V_c = 36.4 \times (R \times Q)^{0.353}$	Q: design plant discharge (m ³ /s)
c. Re-bar (ton)	$W_r = 0.113 \times V_c^{0.823}$	
d. Others (L.S.)	25% of sum of the above costs.	River diversion, slope protection, etc.
10. Miscellaneous (L.S.)	5% of sum of the above costs (1 to 9).	

Source: "Guide Manual for Development Aid Programmes and Studies of Hydro Electric Power Development" and "Handbook for Estimation of Hydropower Project Costs" (arranged by WG).

It is noted that some civil structures are not required depending on the topographic conditions. For example, intake can be directly connected to the head pond in case of development of a waterfall, and de-silting basin and power canal are not necessary.

The following specific dimensions shall be determined for the estimation of work quantities. For further details, refer to Chapter 4 (Basic design).

Table 3.3.4 Required Dimensions for Estimation of Work Quantities of Civil Works

Category	Required Dimensions	Estimation Method	Remarks
Overall Plan	Q _p : design maximum discharge (m ³ /s)	Determined from flow duration curve	
	n: number of turbine (nos.)	Given (2 units as standard).	
	η: combined efficiency (%)	Given (Refer to Table 1.3.1).	
	H _e : effective head (m)	93% of gross head.	Various
	P _{max} : maximum output (kW)	$P_{max} = g \times Q \times H_e \times \eta$	Various
Intake Weir	Q _s : design discharge of flush gate (m ³ /s)	2-year to 5-year probable flood.	
	H: height		
	L: crest length	Assumed from topographic map.	Various
Intake Structure	R: radius of portal (m)	$Q = A \times V$, $V = 1.0$ m/s,	
	H: height of portal (m)	$A = B \times H$, $R = W/2$	
De-silting basin	R: radius of drainage gate (m)	$Q = 0.6 \times A \times (2 \times g \times H)^{1/2}$ $A = B \times H$, $R = W/2$	
Power Canal	B: inner width (m)	Calculated using Manning's formula	
	H: inner height (m)	Calculated using Manning's formula	
	t: concrete thickness (m)	20% of inner width or height	
	L: length of canal (m)	Assumed from topographic map.	Various
Spillway Canal	R: radius (m)	Calculated using Manning's formula	
	L: length (m)	Assumed from topographic map.	Various
Penstock	D: inner diameter (m)	Calculated using Manning's formula	
	L: length (m)	Assumed from topographic map.	Various
Tailrace	R: radius (m)	Same as intake portal.	

Notes: Dimension with "Various" in remarks means that the dimension is various by alternative layout. Other dimensions are constant for potential site.

(3) Required Unit Prices for the Estimation

Required unit prices for the estimation of direct cost are listed in the table below. These unit prices shall be updated as required.

Table 3.3.5 Required Unit Prices for the Estimation

Work Item	Unit	Source
1. Access Road	KSh./km	Available from REA
2. Excavation	KSh./m ³	Current Construction Costs Handbook published by Cost Planning Unit of the Quantities and Contracts Department, Ministry of Public Works
3. Concrete	KSh./m ³	
4. Re-bar	KSh./ton	
5. Metal works (Gate and screen)	KSh./ton	
6. Steel Penstock	KSh./ton	
7. Distribution Line	KSh./km	Available from REA

(4) Estimation of Direct Cost of Electrical Equipment

Electrical equipment is defined as all equipment for MHP including inlet valve, turbine, generator, and all attachments of these equipment. The direct cost of electrical equipment is given by the following empirical equation in the references:

$$C_E = 7.09 \times \left(\frac{P_{\max}}{\sqrt{H_e}} \right)^{0.774} \times F$$

$$F = 1,000,000 \times 0.333$$

Where,

C_E : direct cost of electrical equipment (USD)
 P_{\max} : maximum output (kW)
 H_e : effective head (m)
 F : conversion factor from Japanese Yen to US Dollar (USD)

According to the interview results of Kenya Tea Development Agency (KTDA) in 2014, existing small hydropower projects in Kenya procured electrical equipment from Europe and/or India. Direct cost of the equipment from Europe and India is approximately 30% of that in Japan, based on the interview results and experience of JICA expert.

Additionally, the original empirical equation in the references gives direct cost of the equipment in million Japanese Yen. It is therefore necessary to convert the direct cost into USD by dividing by a million and multiplying by 30%.

3.3.3 Estimation of Project Benefit

Benefit (B) of a hydropower project is the cost of an alternative thermal power plant that supplies electricity equivalent to the hydropower project, and the cost (C) is derived from the construction cost of the MHP project.

The annualized benefit (B) is estimated based on the fixed cost and variable cost of alternative thermal power using the following formula:

Annualized Benefit (B)

$$B = B_1 + B_2$$

$$B_1 = P_h \times b_1$$

$$B_2 = E \times b_2$$

Effective Output (P_h)

$$P_h = 9.8 \times Q_{\min} \times H_e \times \eta$$

Annual Energy Generation (E)

$$E = 8,760 \times \xi \times P$$

Where,

B : annual benefit of hydropower plant (KSh.)
 B_1 : kW benefit (KSh.)
 B_2 : kWh benefit (KSh.)
 P_h : effective output (kW)
 E : annual energy generation (kWh)
 B_1 : kW value (KSh./kW)
 B_2 : kWh value (KSh./kWh)

Q_{\min} : minimum plant discharge (m³/s)

H_e : effective head (m)

η : combined efficiency

ξ : plant factor

P : maximum output (kW)

kW value (b_1)

$$b_1 = Ct \times \alpha \times \beta$$

$$\alpha = RCF + OM = \frac{i \times (1+i)^n}{(1+i)^n - 1} + OM$$

$$\beta = \frac{(1-H_1) \times (1-H_2) \times (1-H_3)}{(1-T_1) \times (1-T_2) \times (1-T_3)}$$

Ct : unit construction cost of alternative thermal power (KSh./kW)

α : annual cost factor of alternative thermal power

RCF : capital recovery factor

i : interest rate (%)

n : service line (year)

OM : ratio of operation and maintenance cost

β : kW adjustment factor (-)

H_1 : ratio of station use of hydropower plant

H_2 : ratio of forced outage of hydropower plant

H_3 : ratio of scheduled outage of hydropower plant

T_1 : ratio of station use of alternative thermal power plant

T_2 : ratio of forced outage of alternative thermal power plant

T_3 : ratio of scheduled outage of alternative thermal power plant

kWh Value (b_2)

$$b_2 = R_h \times P_f = \frac{860}{T_e} \times P_f$$

R_h : heat consumption rate

P_f : unit price of fuel (KSh./kcal)

T_e : thermal efficiency

3.3.4 Selection of Optimum Development Plan

Alternative plans are compared in view of economic feasibility by following two indexes.

(1) Benefit-Cost Method

Benefit-Cost method is an economic analysis to compare benefit (B) and cost (C) as follows:

$B/C \geq 1$, or $B - C \geq 0$: MHP is economically better than the thermal power alternative.

$B/C < 1$, or $B - C < 0$: MHP is economically less attractive than the thermal power alternative.

Where an alternative plan shows higher B/C value than others, it is judged that the alternative plan is more economically attractive than the others.

The benefit is applied as mentioned in Chapter 3.3.3, and the cost is applied not only to construction cost but also annualized cost as given by the following formula:

Annualized Cost (C)

$$C = Ch \times \alpha$$

Annual cost factor (α)

$$\alpha = RCF + OM = \frac{i \times (1+i)^n}{(1+i)^n - 1} + OM$$

Where,

RCF : capital recovery factor

i : interest rate (%)

n : service line (year) = 50 years

OM : ratio of operation and maintenance cost = 1%

The annual cost factor (α) varies in accordance with the interest rate, but can be regarded as 10 to 12% in planning stage according to empirical methods.

(2) Generation Cost Method

$$C_G = Ch / E \times \alpha$$

Where,

C_G : generation cost (KSh./kWh)

Ch : construction cost (KSh.)

E : annual energy generation (kWh)

α : annual cost factor = 0.10 to 0.12 (-)

Where an alternative layout shows cheaper generation cost value (C_G) than others, it is judged that the alternative plan is economically more attractive than the others. Additionally, the economic soundness of the site or alternative layout can be confirmed by comparison with the present electric tariff.

(3) Comparative Study

Development scale of a hydropower project varies depending on the discharge and effective head. Therefore, the optimum development plan is selected through comparative study by applying different parameters.

In case of MHP project, the following aspects are often examined;

- ✓ At first, alternative plans with different locations of intake weir and powerhouse (i.e., with different head) are compared, and the intake site and powerhouse site selected, and
- ✓ Alternative plans with different values of maximum and minimum plant discharges are compared on the selected plan (intake site and powerhouse site).

3.4 Application of Water Use Permit

There are four major government organizations related to water resources management as listed below:

- ✓ Ministry of Water and Irrigation (MWI) act as the policy maker,
- ✓ Water Resources Management Authority (WRMA) is the regulator at the national and regional levels under MWI,
- ✓ Catchment Area Advisory Committees (CAACs) are advisers of WRMA at catchment level, and
- ✓ Water Resource Users Associations (WRUAs) are the regulators at local level.

The water use activities which need the approval of WRMA are stipulated in the Fifth Schedule of the WRMR 2007. The water use activities are categorized into four from the view point of its scale and impact of the relevant water use activities. These categories are explained as follows:

Table 3.4.1 Categories of Water Resources Use Activities

Category	Description
A	<ul style="list-style-type: none"> ✓ Water use activity deemed by virtue of its scale to have a low risk of impacting the water resource. ✓ Applications in this category will be determined by the regional offices.
B	<ul style="list-style-type: none"> ✓ Water use activity deemed by virtue of its scale to have the potential to make a significant impact on the water resource. ✓ Permit applications in this category will be determined by the regional offices.
C	<ul style="list-style-type: none"> ✓ Water use activity deemed by virtue of its scale to have a significant impact on the water resource. ✓ Permit applications in this category will be determined by the regional offices in consultation with the CAACs.
D	<ul style="list-style-type: none"> ✓ Water use activity which involves either two different catchment areas, or is of a large scale or complexity and which is deemed by virtue of its scale to have a measurable impact on the water resource. ✓ Permit applications in this category will be determined by the regional offices in consultation with the CAACs and approval by the WRMA Headquarters.

Source: Water Resources Management Rules, 2007.


The permit application process for water use is stipulated in Sections 16 to 48 of the WRMR 2007. Any person intending to or currently undertaking any water use activity described above shall obtain approval from the WRMA.

When a MHP project is formulated, the application of water permit is necessary.

CHAPTER 4 BASIC DESIGN

4.1 Civil Structure

The main components of the civil structures are weir, intake, de-silting basin, power canal, head tank, penstock, powerhouse and tailrace. A typical profile of a MHP station is shown below with accompanying technical notes. However, components of the civil structures vary depending on the topographic condition at the candidate site, nature of the work and the design conditions involved.



Source: “The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Figure 1.5.4 & 1.5.5)” conducted by JICA in 2003 (arranged by WG).

Figure 4.1.1 Typical Profile of MHP

Based on the experiences in many MHP plants, the major issues relating to the civil components are: i) Sedimentation and ii) Hydraulic characteristics during floods.

Therefore, suitable combinations and layouts according to the specific site conditions need to be properly reflected in the design.

It is rare for dam or tunnel waterway types of layouts to be adopted in MHP. However, existing irrigation dams and/or existing irrigation canals with drops may be utilized for MHP schemes in re-

development plans. In such cases, penstock pipes can be connected to the intake or the de-silting basin without provision of a power canal.

4.1.1 Head Works

This section deals with run-of-river schemes that do not require dam construction, but employ a diversion structure or weir across the river.

Head works commonly consist of weir, intake and de-silting basin. Functions and requirements of the head works design are summarized in the table below.

Table 4.1.1 Functions and Requirements for Head Works

Description	Remarks
Hydraulic Functions <ul style="list-style-type: none"> ✓ To ensure design discharge is obtained from the river. ✓ To minimize inflow of sediment and flowing debris (leaves) into the power canal. ✓ Intake gate to block flood flow entry into the power canal, and to prevent overflow from the power canal from causing catastrophic erosion and damage to the slope and canal foundation. 	<ul style="list-style-type: none"> ✓ Width and height of the gate. ✓ Selection of appropriate intake site and, provision of skimmer wall. ✓ Intake gate with sufficient height and strength to be provided.
Structural Requirements <ul style="list-style-type: none"> ✓ Intake gate to withstand flooding while intake weir is under repair after the flooding season is over. 	<ul style="list-style-type: none"> ✓ Selection of weir type taking topographic, geological and flood conditions into consideration.
Issues of the Design <ul style="list-style-type: none"> ✓ Method for determining the normal water levels of intake and head tank. ✓ Criteria for determining the gate height and width. 	<ul style="list-style-type: none"> ✓ Uniform flow depth of power canal. ✓ Investigation of flood levels at the intake site.

Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-3 Design Manual – Village Hydros (Chapter 3.3)" conducted by JICA in 2003 (arranged by WG).

(1) Site Selection

One of the most common problems affecting a MHP scheme is damage to the intake caused by floods. And another is sediment deposited upstream of the intake or flowing into the waterway. The following points are to be considered in locating the intake structures

Intake (A): The best location for an intake is to locate it along a relatively straight stretch of the stream.

Intake (B): Susceptible to severe damage from floods, debris, and erosion.



Intake (C): Sediments tend to accumulate in front of the intake and can enter and/or block it.

(2) Countermeasures against Sedimentation

Countermeasures against sedimentation are explained below.

1) Tyrolean Intake

The Tyrolean intake is applicable to MHP schemes located on steep rivers containing boulders and pebbles. The characteristics of Tyrolean type intake are as follows:



- a) Intake facilities can be minimized.
- b) Relatively large amounts of sediment will enter the intake especially during a flood. It is therefore indispensable to install a sand drain facility with enough hydraulic gradient and capacity to drain out the sediment. Periodic sand draining operations are required.
- c) It is necessary to carry out cleaning work to remove driftwood or leaves trapped on the screen.
- d) An intake discharge of 0.1 to 0.3 m³/s/m², a screen slope gentler than 30°, and a screen bar interval of 20 to 30 mm are generally practiced.

2) Sand Flush Gate

A sand flush gate should be located towards one side of the weir to release sediments deposited upstream of the weir. The intake is located at a side of the river just upstream of the weir in order to minimize the volume of sand entering the intake. Sill level of a sand flush gate is generally set at 0.5 to 1.0 m higher than the original riverbed level and 1.0 to 1.5 m lower than the intake floor level.

If slope failures or sediment yield are confirmed in the upstream basin, protection work such as a gabion wall may be effective in controlling the sediment outflow.


(3) Hydraulic Requirements

Hydraulic requirements generally applied to side intake with concrete weir are summarized below.

Table 4.1.2 Hydraulic Requirements to Side Intake

Item	General Application	Symbol
Crest level of intake weir	= Full Supply Water Level (FSWL)	EL.1
Sill level of sand flush gate	= Original riverbed + (0.5 to 1.0 m)	EL.2
Floor level of intake	= EL.2 + (1.0 to 1.5 m)	EL.3
Velocity of intake deck	= 0.5 to 1.0 m/s approximately	-
Top of intake deck	= Flood Water Level + freeboard (> 1.0 m)	-
Top of intake gate	= FSWL = EL.1	EL.1
Velocity at intake gate	= 1.0 to 1.5 m/s approximately	-
Crest level of side spillway	= FSWL – (0 to 10 cm)	EL.5
Slope of de-silting basin	= 1:10 to 1:30	n ₁
Velocity of de-silting basin	< 0.3 m/s	-
Length of de-silting basin	(2 to 3) x depth x velocity / sedimentation rate = (2 to 3) x depth x 0.3 / 0.1 = (6 to 9) x depth	-
Elevation of sand drain	(Sand drain outlet level) > (Water level of the river)	EL.6
Floor level of power canal	= EL.3	EL.7
Gradient of power canal	= 1:1,000 to 1:2,000	n ₂
Velocity in power canal	< 2.0 m/s maximum for lined canal	-

Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Table 2.1.3)" conducted by JICA in 2003 (arranged by WG).



Source: “The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Chapter 2.1)” conducted by JICA in 2003 (arranged by WG).

Figure 4.1.2 Schematic Profile of Head Works

(4) Estimation of Inflow Discharge into Intake

The weir crest level is normally designed equal to the Full Supply Water Level (FSWL) under the maximum design discharge.

The hydraulic design of weir and intake should be made appropriately to take the proper discharge into the waterway. Since the flow taken from a river is not regulated in a run-of-river scheme, any excess water above the maximum design discharge should be released safely from spillways.


When a weir crest is set equal to the FSWL at the maximum design discharge, the inflow into the intake can be divided into the following cases:

Table 4.1.3 Flow Condition into Intake

(River flow) < (Maximum design discharge)	(River flow) > (Maximum design discharge)
<ul style="list-style-type: none"> ✓ Full flow enters the intake, ✓ The water level varies between FSWL (EL.1) and the intake floor level (EL.2), ✓ The maximum design discharge flows into the intake at FSWL, and ✓ The minimum flow to the downstream basin shall be released from the river outlet at any conditions if need be. 	<ul style="list-style-type: none"> ✓ Water level is above FSWL (EL.1), when partial discharge is spilt over the weir and the remainder, which exceeds the maximum design discharge, enters the waterway, ✓ Any excess discharge taken from the intake should be released from a side spillway, which needs to be provided at a suitable location of the waterway, and ✓ The intake gate should be closed during a flood to avoid excessive sediment inflow into the waterway.

Source: “The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Chapter 2.1)” conducted by JICA in 2003 (arranged by WG).

If a river water level is known from water level gauge readings at the forebay, discharge entering the waterway can be estimated through the sequence described below. Then, a rating curve at the forebay can be prepared.



Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Chapter 2.1)" conducted by JICA in 2003 (arranged by WG).

Figure 4.1.3 Flowchart to Estimate Inflow Discharge into Intake and Sample H-Q Curve

Overflow discharge from spillway and outflow discharge through sand flush gate can be calculated using the following formulas:

Discharge from a weir spillway:

$$Q_{spill} = 1.84 \times B \times H^{1.5}$$

Where, Q_{spill} : discharge from spillway (m³/s)
 B : width of spillway (m)
 H : Overflow depth (water level minus crest level of spillway) (m)

Discharge from a sand flush gate:

For orifice flow:

$$Q = 0.6 \times A \times \sqrt{2 \times g \times H}$$

For pipe flow:






$$Q = A \times \sqrt{\frac{2 \times g \times H}{1 + f_e + f}}$$

Where, Q : discharge through the gate (m³/s)
 A : section area of the gate (m²)
 f_e : loss coefficient for entrance (-)
 $f_e = 0.1$ to 0.5)
 f : loss coefficient for friction (-)
 $f = 124.5n^2 L/D^{(4/3)}$

(5) Major Types of Weirs and Intakes

Major types of weirs and intakes are summarized below.

Table 4.1.4 Major Types of Weirs




Type	Characteristics
Concrete Gravity 	<ul style="list-style-type: none"> ✓ Applicable on rock foundations, ✓ Most commonly applied, ✓ Durable and impervious, and ✓ Relatively high cost.
Floating Concrete Weir 	<ul style="list-style-type: none"> ✓ Applicable on gravel foundations, ✓ Needs enough seepage path, ✓ Durable, and ✓ Relatively high cost.
Gabion Covered with Concrete 	<ul style="list-style-type: none"> ✓ Applicable on gravel foundations, ✓ Surface protection by concrete, and ✓ Relatively low cost.
Gabion 	<ul style="list-style-type: none"> ✓ Applicable on gravel foundations, ✓ Flexible, and ✓ Low cost and easy maintenance.
Stone Masonry 	<ul style="list-style-type: none"> ✓ Applicable on gravel foundations, and ✓ Low cost and easy maintenance.

Source: “The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Table 2.1.1)” conducted by JICA in 2003 (arranged by WG).

It should be noted that the type of weir to be applied should be determined according to the power scale, importance, flood discharge, foundation condition, and maintenance requirements. The use of high quality materials and construction techniques will result in less maintenance and repair work over the lifespan of the scheme.

Major types of intakes are summarized below.

Table 4.1.5 Major Types of Intakes

Type	Characteristics
<p>Side Intake with Weir</p> 	<ul style="list-style-type: none"> ✓ Most commonly used for run-of-river type power schemes, ✓ Sand flush gate is located towards one side of the weir to release sediments deposited upstream of the weir, ✓ Intake is located at a side of the river just upstream of the weir/sand flush gate, and ✓ Intake gate is provided at upstream section of de-silting basin. Its function is to close during sand drain operation or maintenance of the waterway.
<p>Tyrolean Type Intake</p> 	<ul style="list-style-type: none"> ✓ Suitable for steep rivers containing boulders, ✓ Weir is not necessary, ✓ Necessary to remove drift woods or leaves on the screen, and ✓ Necessary to remove fine sands which have entered the intake.
<p>Intake to utilize Natural Pond</p> 	<ul style="list-style-type: none"> ✓ Applied to natural/artificial ponds to utilize the water for power generation.

Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Table 2.1.2)" conducted by JICA in 2003 (arranged by WG).

The site selected for the head works should be stable and suitable for reliable foundations. All excess water and debris taken from the river need to be minimized in the design of head works, and those entering during a flood flow need to be returned to the river before entering the canal or penstock.

(6) Facilities provided in Intake


The following facilities are provided in the intake:

Skimmer Wall

The skimmer wall at the entrance of the inlet may be effective in preventing driftwood or excessive flood flow from entering the intake. It also restricts excessive inflow by ensuring orifice flow when the river water level is higher than the FSWL during a flood.


Intake Gate

An intake gate is provided at the upstream section of the de-silting basin. The gate is to be closed during the sand drain operation or maintenance of the waterway and during floods to avoid excessive sediment inflow. The velocity through the intake gate opening should be limited to about 1.0 m/s.



Trashrack


Trashracks are provided at the entrance of the intake to prevent trash, leaves, and floating debris from entering the waterway. The screen bars are generally arranged with 5 ~ 9 mm thickness, 50 ~ 120 mm width, 100 ~ 150 mm intervals, and 60 ~ 70° angle to the horizontal.



Thickness	$t = 5 \sim 9 \text{ mm}$
Width	$w = 50 \sim 120 \text{ mm}$
Interval	$b = 100 \sim 150 \text{ mm}$
Inclination	$\theta = 60 \sim 70^\circ$

(7) De-silting Basin

General layout of de-silting basin is shown below.



Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Chapter 2.2)" conducted by JICA in 2003 (arranged by WG).

Figure 4.1.4 General Layout of De-silting Basin

The de-silting basin is designed to settle sand particles bigger than 0.5 to 1.0 mm diameter of which the settling velocity corresponds to 0.1 m/s. Average flow velocity in a de-silting basin is generally 0.3 m/s, and the channel slope is 1/10 to 1/30.

1) Length of De-silting Basin

The length of de-silting basin is given by the following empirical formula:


$$L = \alpha \times \frac{v}{u} \times h_s$$

Where,

L :	length of de-silting basin (m)
α :	coefficient (-) = 2 to 3
v :	average velocity in de-silting basin (m/s) = 0.3 m/s
u :	settling velocity for target sand particle (m/s) = 0.1 m/s
h_s :	depth of de-silting basin (m)

2) Length of Spillway

A side spillway should be provided at the de-silting basin to release excess inflow during a flood. The length of spillway required for overflow of the excess discharge and the water surface profile can be computed using the following De-Marchi's equations:



Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Figure 2.2.4)" conducted by JICA in 2003 (arranged by WG).

It is noted that the outflow path needs to be protected against scouring.

4.1.2 Power Canal

This section deals with open canals only, which are the type most commonly applied to MHP schemes. Functions and requirements of the power canal are summarized in the table below.

Table 4.1.6 Function and Requirements of Power Canal

Description	Remarks
<p>Hydraulic Functions</p> <ul style="list-style-type: none"> ✓ To lead the design discharge to the head tank without causing overflow from power canal. ✓ To release the excess water, if any, through spillway, or, ✓ To confine all the water within power canal by raising the side walls in case the canal flow is blocked. 	<ul style="list-style-type: none"> ✓ Standard hydraulic gradient at or gentler than 1: 1,000 to reduce flow velocity. ✓ Spillway and chuteway required at the head tank. ✓ Three possible cases are: <ol style="list-style-type: none"> a. Turbine guide vane is closed, b. Penstock is clogged, and c. Canal is filled and blocked by sliding soils from side slopes.
<p>Hydraulic Requirements</p> <ul style="list-style-type: none"> ✓ Flow velocity to be lower than 0.3 m/s so as not to cause canal erosion. ✓ Preferably provide a fused spillway section downstream of the intake, in addition to the raised side walls in the option above. 	<ul style="list-style-type: none"> ✓ Low flow velocity is preferable. ✓ Chuteway can be shorter compared to that of spillway at the head tank
<p>Issues of the Design</p> <ul style="list-style-type: none"> ✓ Sedimentation in power canal. ✓ Criteria for determining height and width of the canal. ✓ Criteria for determining crest elevation of side walls of power canal. ✓ - Criteria for determining crest elevation and length of the side-overflow spillway. 	<ul style="list-style-type: none"> ✓ Canal to be periodically cleared of sediment deposit. ✓ A freeboard of 30 cm (= 1 feet) is preferable for earth canal. ✓ Overflow crest level can be at the intake water level.

Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-3 Design Manual – Village Hydros (Chapter 3.4)" conducted by JICA in 2003 (arranged by WG).

(1) Route Selection

A route for the power canal needs to be selected after consideration of the topographic features along the canal for the following points:

- ✓ Stability against slope above and/or below the canal, and
- ✓ Specific conditions such as streams, roads, and the existing structures to be crossed.

Selection of the canal route and the design of canals should be made in consideration of the fact that the water level in a canal may rise for any of several possible reasons:

- ✓ When the canal flow is obstructed by a landslide or closure of a gate at the downstream structures,
- ✓ When excess water enters the intake during a flood, and
- ✓ When excess running water is drained into the canal during heavy rain.




When selecting the canal route, the existing structures such as foot pass and irrigation channel can be utilized to minimize the construction cost of the canal as well as for ease of access.

It is noted that the power canal may be possible to omit from the design, depending on the topographic conditions. In this case the penstock may be connected directly to the de-silting basin or the head tank.

(2) Major Types of Canals

Major types of power canals are summarized below.


Table 4.1.7 Major Types of Power Canals

Type	Characteristics
Earth Canal 	<ul style="list-style-type: none"> ✓ Ease of construction and maintenance, ✓ Low cost, ✓ Not applicable to pervious and erosive foundation, ✓ Velocity < 0.3 m/s, ✓ Roughness coefficient $n = 0.014$ on average, ✓ Seepage loss = $1.0 \times 10^{-6} \text{ m}^3/\text{s}/\text{m}^2$ (clay) to $8.0 \times 10^{-6} \text{ m}^3/\text{s}/\text{m}^2$ (sand)
Stone Masonry Canal 	<ul style="list-style-type: none"> ✓ Ease of construction and maintenance, ✓ Velocity < 1.5 m/s (dry stone masonry) and velocity < 2.0 m/s (wet stone masonry), ✓ Roughness coefficient $n = 0.032$ (dry stone masonry) and 0.025 (wet stone masonry)
Concrete Canal 	<ul style="list-style-type: none"> ✓ Durable, ✓ Relatively high cost, ✓ Velocity < 3.0 m/s, ✓ Roughness coefficient $n = 0.015$ on average.


Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Chapter 2.3)" conducted by JICA in 2003 (arranged by WG).

Shape of cross section is given as follows:

- ✓ For unlined canals, a trapezoid cross-section is the most common. Side slopes of a canal are 1.0 (V): 0.5 (H) for rock foundation, and 1.0 (V): 2.0 (H) for sandy loam foundation.



Sliding may be induced by overflow from a canal in which debris enters the canal.



Properly designed lined canal reduces the canal size and the excavation volume to convey the same discharge.

- ✓ For lined canals, a rectangular or a trapezoid cross-section is commonly used for stone masonry lining, and a rectangular cross-section for concrete lining.

(3) Canal Dimension

Power canals are to be designed in consideration of 1) flow capacity, 2) velocity, 3) roughness, 4) slope, 5) sectional shape, 6) lining (with or without, material), and 5) maintenance.

The steeper the slope of the canal, the smaller the sectional area required. However the effective head decreases as the slope increases. The best combination of a canal size and a slope should be established within a suitable range of flow velocity.

1) Velocity

The velocity in a canal should be low enough to prevent erosion of the canal, especially if it is unlined, and to keep effective head as high as possible.

Maximum Velocity for Unlined Canal

The maximum permissible velocities for unlined canals are set to avoid erosion, depending on the soil materials as summarized in the table below.

Table 4.1.8 Standard Maximum Velocity for Unlined Canal

Soil Material	Roughness Coefficient “n” (-)	Maximum Velocity (m/s)	Permeability (x 10 ⁻⁶ m ³ /s/m ²)
Fine sand	0.020 – 0.025	0.3 – 0.4	> 8.3
Sandy loam	0.020 – 0.025	0.4 – 0.6	2.8 – 8.3
Clayey loam	0.020 – 0.025	0.6 – 0.8	1.4 – 2.8
Clay	0.020 – 0.025	0.8 – 2.0	0.3 – 1.4

Source: “The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Table 2.3.2)” conducted by JICA in 2003 (arranged by WG).

Maximum Velocity for Lined Canal

The maximum permissible velocities for lined canal are set depending on the wear of abrasion. Velocities above 10 m/s will not damage a concrete lined canal when the water is clear, but velocities above 4 m/s containing sand and gravel may scour the lining.

The maximum velocity in a lined canal is normally lower than 2.0 m/s.

Minimum Velocity

The velocity in a canal should be high enough to prevent sedimentation and to avoid the growth of aquatic plants especially in unlined earth canals.

Minimum velocities are given as follows;

Against sedimentation for flow carrying silty water: $V_{min} = 0.3$ m/s

Against sedimentation for flow carrying fine sand: $V_{min} = 0.3$ to 0.5 m/s

Against aquatic plants: $V_{min} = 0.7$ m/s

2) Longitudinal Slope

A canal slope, depending on the topographic conditions, is generally as follows:

1/500 ~ 1/1,000: to minimize the canal size in high head plant

1/1,000 ~ 1/1,500: general application

1/1,500 ~ 1/2,000: to minimize a head drawdown in low head plant

3) Roughness Coefficient

Roughness coefficient “n” is an empirical measure of surface roughness of a waterway. The following values are usually applied;


Steel: 0.012 ~ 0.013

Concrete:	0.014 ± 0.001
Stone-masonry:	0.016 ~ 0.020

(4) Water Surface Profile

The canal floor elevation at the downstream end (EL.4 in the figure) is commonly selected to provide a uniform flow depth for the maximum design discharge when the water level in the head tank or the regulating pond is at the Full Supply Water Level (FSWL). In this condition, the flow depth in the canal is uniform over the whole stretch, if the canal slope is uniform.

Uniform flow depth in a canal can be calculated using Manning's Formula:



$$Q = \frac{A}{n} R^{\frac{2}{3}} I^{\frac{1}{2}} \quad Q = V \cdot A$$

For a rectangular section

$$A = b \cdot h \quad R = \frac{h}{1 + 2h/b}$$

For a triangular section

$$A = h(b + mh) \quad R = \frac{h(b + mh)}{b + 2h\sqrt{1 + m^2}}$$

where, Q : discharge (m³/s), n : roughness coefficient, b : width of canal (m)
h : depth of flow (m), R : hydraulic radius (m), I : slope of canal

A non-uniform flow analysis should be carried out in the full section of the waterway starting from the head tank or the regulating pond up to the intake. For the analysis, parameters to be varied include discharge, roughness coefficient, and the initial water level at the head tank. The wall height of the canal is to be designed so that the energy line for the maximum inflow into the canal should be lower than the wall crest.

Non-uniform flow analysis involves solving the following differential equation. The analysis is usually calculated using computer soft ware.

$$\frac{dh}{dx} = \frac{i + \frac{\alpha Q^2}{gA^3} \frac{\partial A}{\partial b} \frac{\partial b}{\partial x} - \frac{n^2}{R^{4/3}} \left(\frac{Q}{A}\right)^2}{1 - \frac{\alpha Q^2}{gA^3} \frac{\alpha A}{\partial h}}$$

(5) Related Facilities

Design of the following facilities for a canal may be required for the above conditions:


Table 4.1.9 Required Facilities for Power Canal

Site Condition	Required Facilities
Potential landslide	(a) Box culvert or canal covers (concrete/wood). (b) Slope protection by structural reinforcement of the slope, excavation in a gentler slope, and vegetation such as sodding or planting
Crossing of stream or valley	(a) Aqueduct to release excess flow from a flood or debris flow. (b) Siphon to path under the stream. (c) Drainage facilities to collect the running water in the catchment basin and to release it safely to protect the canal from being eroded by the drained flow or invaded by debris.
Crossing of roads or existing structures	(a) Box culvert or bridge to connect the existing road. (b) Steel pipe or concrete conduit embedded under the existing structures.
Excessive inflow	(a) Side spillway for overflow of excess flow over the maximum design discharge. Appropriate protection work against scouring by the overflow is indispensable. (b) Drainage facilities to avoid excess inflow into the canal.

Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Table 2.3.1)" conducted by JICA in 2003 (arranged by WG).

1) Cross Drain

If a power canal passes through valleys with catchment areas, drain facilities that cross under or over the power canal should be provided to protect the canal structure from impact of running water containing debris during rainfall. Box culverts, concrete pipes, polyethylene pipes, etc. are used as under drains, and open chutes as over drains. Under drains need adequate flow area, since they are likely to be clogged with debris, soil, etc. A minimum inner space of 60 cm is preferable for manual cleaning.




- Slope steeper than 1/500
- Size bigger than $\phi 60\text{cm}$,
- Enough flow area not to be clogged, and
- Maintenance for clogging.

Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Figure 2.3.12 & 2.3.13)" conducted by JICA in 2003.

Figure 4.1.5 Cross Drain under and Over Power Canal

2) Side Spillway

A side channel spillway is generally provided at the de-silting basin and the head tank. However, it may be necessary to design it in a suitable section of the power canal depending on the design conditions. The outflow path needs to be protected against scouring.



4.1.3 Head Tank

A head tank is provided between power canal and penstock pipe to adjust turbine discharge corresponding to the load fluctuation, while a surge tank is required when a pressure tunnel or conduit is applied as headrace. When a penstock pipe is connected directly to a de-silting basin, the de-silting basin may be designed to function as a head tank.

Functions and requirements of the head tank are summarized in the table below.



Head Tank with Spillway

Table 4.1.10 Function and Requirements of Head Tank

Description	Requirements
Hydraulic Functions <ul style="list-style-type: none"> ✓ To ensure smooth transition of the water, from free flow in power canal to pressure flow in penstock. ✓ To trap flowing debris and leaves using trashracks. ✓ To deposit sediments (sill elevation of penstock inlet must be higher than the floor by 30 cm). ✓ To release excess water from spillway. 	<ul style="list-style-type: none"> ✓ Adequate water surface area is required to adjust difference in the discharge of power canal and penstock. ✓ Trashracks at low flow velocity. ✓ Periodic sand flushing/ clearing is required. ✓ Spillway can be omitted when side walls of power canal and head tank are raised to confine water within the waterway.
Structural Requirements <ul style="list-style-type: none"> ✓ Width of head tank to be determined to have flow velocity slower than 0.2 m/s. ✓ Total water surface area of the head tank and power canal to be more than 5 to 10 times of the design discharge. ✓ Sand flushing gate and chuteway preferably to be provided. 	
Issues of the Design <ul style="list-style-type: none"> ✓ Criteria for determining the normal water level (crest elevation of the spillway of the head tank). 	<ul style="list-style-type: none"> ✓ To be equal to the intake water level.

Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-3 Design Manual – Village Hydros (Chapter 3.5)" conducted by JICA in 2003 (arranged by WG).

(1) Site Selection

The location of a head tank is generally selected to be on a ridge with firm foundations, depending on the topographical and geological conditions.

Spillway and a sand drain gate should be considered and incorporated into the head tank. When a spillway is provided (it may be omitted under some conditions), the route of the spillway should be properly designed not to cause sliding or erosion of the slope.

(2) Hydraulic Design

1) Required Volume

The capacity of the head tank is determined according to the responsive characteristics of the governors installed in the power plant.

Case 1:

$$V > Q_{\max} \times (120 \sim 180)$$

Where, V : Volume of tank (m^3)

Case 2:

$$V > Q_{\max} \times 20 \text{sec} + A \times 0.8$$

A : Surface area of tank (m^2)

Q_{\max} : Maximum design discharge (m^3/s)

Case 1: for mechanical governors and manual operation, and

Case 2: for electric governor, computer governor and dummy load governor.

2) Discharge from Spillway

Spillway discharge can be calculated as follows.

$$Q = 1.84 \times B_s \times H^{1.5}$$

Where, Q : Spill-out discharge (m³/s)
 B_s : Length of overflow crest (m)
 H : Overflow depth (m)

3) Discharge from Sand Drain Gate

Discharge capacity of sand drain gate is calculated using the following formulas:

For orifice flow:

$$Q = 0.6 \times A \times \sqrt{2 \times g \times H}$$


For pipe flow:

$$Q = A \times \sqrt{\frac{2 \times g \times H}{1 + f_e + f_b + f}}$$

$$f_b = [0.131 + 0.1632 \times (D/R)^{3.5}] \times (\theta/90)^{0.5}$$

$$f = 1245 \times n^2 \times L/D^{4/3}$$

Q : Discharge through the gate (m³/s)
 A : Flow area (m²)
 g : Gravity acceleration = 9.8 (m/s)
 H : Overflow depth (m)
 f_e : Loss coefficient for entrance (m)
 f_b : Loss coefficient for bend (m)
 f : Loss coefficient for friction (m)
 D : Pipe diameter (m)
 R : Radius of curvature (m)
 θ : Bend angle (degree)
 n : Roughness coefficient of pipe = 0.012 (-)
 L : Length of pipe (m)



Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Figure 2.4.3)" conducted by JICA in 2003.

Figure 4.1.6 Typical Profile of Head Tank

4) Minimum Operation Level

Water depth between the Minimum Operational Level (MOL) and the centre level of the penstock inlet is given by the equation below:

$$h > \varphi, \varphi < 1.0 \text{ m}$$

$$h > \varphi^2, \varphi > 1.0 \text{ m}$$

Where, h : Depth between MOL and penstock center (m)
 φ : Diameter of penstock pipe (m)

5) Air Vent Pipe

An air vent pipe is required when inlet gate is provided at the inlet of the penstock. The diameter of the air vent pipe is given by the following empirical formula:

$$\varphi = 0.0068 \times \left(\frac{P^2 \times L}{H} \right)^{0.273}$$

Where, φ : Diameter of air vent pipe (m)
 P : Power output (kW)
 L : Length of air vent pipe (m)
 H : Head of penstock (m)

6) Others

The sectional shapes of head tank should be designed to avoid any abrupt changes that can cause the occurrence of a vortex.

Average slope of head tank is 1/15 to 1/50 in order to drain the sediment deposited in the tank through a sand drain gate.


(3) Omission of Spillway

The spillway of the head tank can be omitted when the discharge is regulated at the intake and the following conditions are applied:

- 1) Deflectors are attached for Pelton or Turgo Impulse type turbines.
- 2) An outlet valve, branched from the penstock pipe, is provided to release the discharge during load rejection. The valve opening is connected with the closure of the guide vane.
- 3) A dummy load governor, which is applied to MHP schemes smaller than 300 kW, is provided to respond to load rejection.

4.1.4 Penstock

Functions and requirements of the penstock are summarized below.



Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Figure 2.6.1)" conducted by JICA in 2003 (arranged by WG).

Figure 4.1.7 Typical Profile of Penstock

Table 4.1.11 Functions and Requirements of Penstock



Description	Remarks
Hydraulic Functions ✓ To lead the pressured water to the turbine.	
Structural Requirements ✓ The flow in the penstock pipe should always be pressured flow, that is, the head tank water level should always be above the penstock inlet sill by 2 times of the diameter. ✓ To be rigid enough and anchored to avoid vibration.	✓ Penstock slope to be protected and drains provided to avoid possible erosion by rainwater.
Issues of the Design ✓ Negative pressure acts on the penstock when the penstock is located above hydraulic grade line. ✓ Hydraulic force operates upon bend.	✓ Alignment of the penstock should be designed for it to be located below the minimum hydraulic grade line during the load rejection. ✓ Penstock is fixed by anchor block.

Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-3 Design Manual – Village Hydros (Chapter 3.6)" conducted by JICA in 2003 (arranged by WG).

(1) Major Types of Penstocks

Major types of penstocks are summarized below.

Table 4.1.12 Functions and Requirements of Penstock


Type	Features
<p>Open Type</p> 	<ul style="list-style-type: none"> ✓ Most commonly applied to small hydro schemes ✓ Anchor blocks are provided at bend portions, which should be founded on foundations firm enough to support the blocks with penstock pipes against sliding, overturning and bearing. ✓ Interval between anchor blocks should be less than 100 m generally. ✓ Saddle piers are provided at 6 m interval. ✓ Maximum angle of pipe inclination should be 55° ✓ Drainage and slope protection should be considered for the open excavated areas. ✓ Expansion joints just below the head tank and between anchors. ✓ Bitumen between pipes and anchors/saddles to avoid corrosion.
<p>Embedded Type</p> 	<ul style="list-style-type: none"> ✓ Applicable to the following conditions: <ul style="list-style-type: none"> (a) soft foundations not adequate to support the anchor blocks (b) areas susceptible to landslides or running water (c) gentle slopes to maintain the stability of backfill materials ✓ Steel pipes should be galvanized, and double coated with either bitumen or high zinc content paint.

Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Table 2.6.1)" conducted by JICA in 2003 (arranged by WG).

(2) Water Hammer

Discharge in the penstock changes during the power generation. Discharge is controlled by inlet valve in front of the water turbine in the powerhouse. According to the changes in discharge, the velocity in the penstock also changes, and pressure wave occurs at the inlet valve.

The pressure wave occurs up and down in the penstock, acting on it. This pressure wave is known as “water hammer”. It is 10 – 30% of the static water at the inlet valve and disappears at the inlet of penstock (at the head tank).



Source: “The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Figure 2.6.2)” conducted by JICA in 2003 (arranged by WG).

Figure 4.1.8 Water Hammer

(3) Inner Diameter

In cases where the diameter of the penstock is smaller, the construction cost decreases. On the other hand, energy loss during power generation increases due to the increasing head loss. Conversely, in cases where the diameter of the penstock is larger, energy loss decreases due to the decreasing head loss, but the construction cost increases.

Therefore, the optimum diameter of a penstock is determined by minimizing the total annual cost mainly consisting of the annualized construction cost of the penstock, and decrease of the annual benefit by head loss during generating. The formula for calculating the optimum diameter is shown below.

$$S = Cc + B'$$

The annualized construction cost

$$C_c = C_w \times F_a = C_w \times (f_c + C_m)$$

The annualized energy loss

$$B' = P_d \times C_t' / kW + E \times C_t / kWh$$

$$P_d = 9.8 \times Q_{\max} \times h_{lg} \times \eta_g$$

$$E = P_d \times T_g$$

$$C_t' / kW = C_t / kW \times f_k \times F_t$$

Where,

S : total annual cost of penstock (US\$)

C_c : annualized construction cost of penstock (US\$)

B' : decrease of annual benefit by head loss (US\$)

F_a : annual conversion factor (%)

f_c : capital recovery factor (%)

C_m : annual operation & maintenance cost (%)

P_d : decreasing of effective output in generating (US\$)

Q_{\max} : maximum discharge in generation (m^3/s)

h_{lg} : head loss in generation (m)

η_g : total efficiency in generation (%)

E : annual energy loss in generating by head loss (US\$)

T : annual generating hour (hour)

C_t' / kW : unit cost of alternative thermal power plant (US\$/kW)

C_t / kW : fixed unit cost of alternative thermal power plant (US\$/kW)

f_k : kW adjustment ratio (%)

F_t : annual conversion factor of alternative thermal power plant (%)

C_t / kWh : variable cost per kWh of alternative thermal power plant (US\$/kWh)

(4) Thickness

Thickness of penstock is given by the following formula:

$$t = \frac{P \times D}{2 \times \sigma_a \times \eta} + \varepsilon$$

Where, t :	thickness of steel penstock (mm)
P :	design pressure at calculation point (N/mm ²)
D :	inner diameter of steel penstock (mm)
σ_a :	allowable tensile stress of steel (N/mm ²)
η :	efficiency of welding = 85 (%)
ε :	tolerance of steel against corrosion = 20 (mm)

4.1.5 Powerhouse

Functions and requirements of the powerhouse are summarized in the table below.

Table 4.1.13 Functions and Requirements of Powerhouse


Description	Remarks
Functions ✓ To protect generating equipment from rainwater. ✓ To provide shelters for operation.	
Structural Requirements ✓ To be free from flooding. ✓ To have space, lighting, toilet facilities, and footpath for operators.	
Issues of the Design ✓ Criteria for determining the turbine center elevation.	✓ To select a level free from flood submergence.

Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-3 Design Manual – Village Hydros (Chapter 3.7)" conducted by JICA in 2003.

(1) Site Selection

The location of the powerhouse should be selected taking into account the following conditions;

- ✓ Easy access is required for operation and maintenance after completion.
- ✓ Rock foundations are preferable but a well consolidated foundation to support equipment load of 5 ton/m² will be acceptable.
- ✓ The floor elevation of the powerhouse should be higher than the flood water level of the river downstream, and the slopes surrounding the powerhouse should be stabilized if required.
- ✓ The drainage facilities around the powerhouse should be properly designed to protect the powerhouse from invasion by water rush flow from the slopes and inundation during heavy rain.



(2) Tail Water Level (TWL)

TWL at the powerhouse should be determined so that it will not be affected by the backwater from the river during a flood.

1) Impulse turbine

The water that passes through a runner is directly discharged into the tailrace; and the water flow under the turbine will be turbulent. Therefore, it is necessary to ensure that the clearance between the power plant slab and water surface at the afterbay is at least 30 to 50 cm. The water depth at the tailrace is calculated using the following formula.

$$h_c = \left(\frac{1.1 \times Q_d^2}{g \times b^2} \right)^{1/3}$$

Where, h_c : water depth at tailrace (m)
 Q_d : maximum plant discharge (m³/s)
 g : gravity acceleration = 9.8 (m/s²)
 b : width of tailrace canal (m)

The water level at the tailrace should be higher than the design flood water level.

2) Reaction turbine

As a draft tube is used in the reaction turbine, the tail-water level should be designed not to be lower than the outlet of draft tube even during the minimum discharge.

The head between the center of turbine and tail-water level can be used to generate power. So it is possible to set the tail-water level lower than the design flood water level by installing a tailrace channel gate. In this case, the power plant requires a watertight structure and drainage pumps.

4.1.6 Tailrace Canal

Functions and requirements of the tailrace canal are summarized in the table below.

Table 4.1.14 Functions and Requirements of Tailrace Canal

Description	Remarks
Hydraulic Functions ✓ To lead the water back to the river.	
Structural Requirements ✓ Preferably not to receive backwater and bottom elevation of tailrace.	
Issues of the Design ✓ Criteria for determining the width and bottom elevation of the tailrace.	✓ Uniform flow depth above the flood level at the river outlet.

Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-3 Design Manual – Village Hydros (Chapter 3.8)" conducted by JICA in 2003.



Tailrace canal is generally not required for MHP schemes, and the powerhouse is selected near the river. In case a tailrace canal is required, it is designed in the same manner as the power canal, in principle.

However, normal and flood water levels at the outlet shall be determined and applied as a start condition of the non-uniform flow analysis. The tailrace canal shall be designed to avoid the effect of the backwater from the river as much as possible.

4.1.7 Head Loss Calculation

In case of MHP scheme, the effective head to be used to estimate power output can be obtained from the head difference between FSWL at the head tank and TWL at the powerhouse after deducting head losses.

However, effective head changes depending on the type of turbine as shown below:

Impulse Turbine (Pelton, Turgo Impulse and Cross Flow)**Reaction Turbine (Francis, Propeller and Tubular)**

Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Figure 1.6.3 & 1.6.4)" conducted by JICA in 2003.

Figure 4.1.9 Effective Head

The head losses between the head tank and the powerhouse are expressed in a number of equations. The head losses are a summation of nine (9) kinds of head losses defined below. Head losses to be taken into account depend on the plan and profile of penstock.

(1) Velocity Head in Head Tank

$$h_1 = \frac{v_{in}^2}{2g}$$


Where,

h_1 : head loss in head tank (m)
 v_{in} : flow velocity in head tank (m/s)
 g : gravity acceleration (m/s²)

(2) Head Loss at Trashracks

$$h_2 = f_r \times \frac{v_1^2}{2g}$$

$$f_r = 2.34 \times \sin \theta \times (t/b)^{4/3}$$




Where,

- h_2 : head loss of trashracks (m)
 f_r : head loss coefficient of trashracks (-)
 v_1 : velocity before trashracks (m/s)
 θ : inclination of trashrack ($^\circ$) $\theta = 60$ to 70°
 t : thickness of bar (mm)
 $t = 5$ to 9 mm
 b : space between bars (mm)
 $b = 100$ to 150 mm

(3) Head Loss at Entrance

$$h_3 = f_e \times \frac{v_2^2}{2g}$$



Where,

- h_3 : head loss at entrance (m)
 f_e : head loss coefficient of entrance (-)
 v_1 : velocity after entrance (m/s)

(4) Head Loss due to Friction


$$h_4 = \frac{124.5 \times n^2}{D^{4/3}} \times L \times \frac{v^2}{2g}$$

Where,

- h_4 : head loss due to friction (m)
 n : roughness coefficient of penstock (-)
 $= 0.012$
 D : penstock diameter (m)
 L : penstock length (m)
 v : velocity in penstock (m/s)


(5) Head Loss due to Pipe Reducer

$$h_5 = f_{gc} \times \frac{v_2^2}{2g}$$



Where,


- h_5 : head loss due to pipe reducer (m)
 f_{gc} : head loss coefficient of reducer (-)
 θ : reducer angle ($^\circ$)
 L : reducer length (m)
 v_1 : velocity before reducer (m/s)
 v_2 : velocity after reducer (m/s)



(6) Head Loss due to Bend

$$h_6 = f_b \times \frac{v^2}{2g}$$

$$f_b = \left[0.131 + 0.1632 \times (D/R)^{3.5} \right] \times (\theta/90)^{0.5}$$




Where,

- h_6 : head loss due to bend (m)
 f_b : head loss coefficient of bend (-)
 D : penstock diameter (m)
 R : bend radius (m)
 θ : bend angle ($^\circ$)
 v : velocity in penstock (m/s)

(7) Head Loss due to Branch

$$h_7 = f_B \times \frac{v_1^2}{2g}$$



Where,

- h_7 : head loss due to branch (m)
 f_B : head loss coefficient of branch (-)
 (a) $f_B = 0.75$, (b) $f_B = 0.50$
 v_j : velocity before branch (m/s)

(8) Head Loss due to Inlet Valve


$$h_8 = f_v \times \frac{v^2}{2g}$$

Where,

- h_8 : head loss due to inlet valve (m)
 f_v : head loss coefficient of valve (-)
 For sluice valve (full open): $f_v = 0$
 For butterfly valve: $f_v = t/d$
 t : thickness of valve circle end (m)
 d : diameter of valve circle (m)

(9) Head Loss due to Enlargement at Outlet

$$h_9 = \left\{ 1 - \left(\frac{A_1}{A_2} \right) \right\}^2 \times \frac{v_1^2}{2g}$$



Where,

- h_9 : head loss due to enlargement (m)
 A_1 : flow area before enlargement (m^2)
 A_2 : flow area after enlargement (m^2)
 v_1 : velocity before enlargement (m/s)

4.2 Electrical Equipment

Main components of the electrical equipment are turbine and generator. The turbine converts gravitational potential energy of water into rotational energy, and the generator receives the rotational energy and converts it into electrical energy. To support the operation of turbine and generator a number of equipment are installed in the powerhouse including inlet valve, power transmission equipment, transformers, control panel, governor, etc.

Conceptual diagram of electrical equipment in the powerhouse is shown below.




Figure 4.2.1 Conceptual Diagram of Electrical Equipment in Powerhouse

Basically, MHP schemes are similar to general power supply businesses but are at a very small scale. The main requirements for planning and designing electrical equipment in MHP schemes are as follows:

- ✓ Equipment must be designed to be operated easily and safely by villagers because securing the services of an expert to operate high level technology is difficult,
- ✓ In the selection, equipment that have characteristics of small fluctuation in output without requiring special adjustment should be prioritized, and
- ✓ In the selection of equipment, simplicity and durability shall be given priority over efficiency and other functions in order to ensure easy operation, maintain and repair.

Construction budget may be limited, but a MHP scheme should be sustainable and stable. The scheme should be planned to supply stable and high quality electricity, with consideration for future demand increase.

On the other hand, detailed characteristics of electrical equipment vary depending on manufacturers, as they produce electrical equipment based on their individual technical know-how. Some manufactures provide a package of all required equipment for a MHP station known as "Water to Wire System".

Therefore, the explanations in this chapter focus on the standard types and estimation methods based on basic technical features of the turbine and generator, as well as functions of other major equipment for MHP scheme.

4.2.1 Turbine

(1) Major Types of Turbines

Turbines are classified into two types according to their water energy utility:

Impulse Turbines

All available water energy is converted by a free jet through a nozzle into rotational energy before water contacts the moving turbine blades (runner peripheral). The energy is then taken from the jet by suitable flow through moving vanes. The vanes are partially filled, with the jet open to the atmosphere throughout its travel through the runner. Losses occur in flow from the reservoir through the penstock to the base of the nozzle.

Reaction Turbines

A portion of the water energy is converted into rotational energy by the water passing through adjustable wicket gates before entering the runner, and the remainder of the energy conversion takes place through the runner. All passages are completely filled with water, including the draft tube from the runner to the downstream water surface. The static water pressure occurs on both sides of the vanes and hence does not do work. All the work done is entirely due to the conversion of water energy into rotational energy.

Both impulse turbines and reaction turbines are comprised of many types. The major types of turbines mainly applied for MHP schemes are summarized below.




Figure 4.2.2 Classification Tree of Turbines

Table 4.2.1 Major Types of Impulse Turbines






Type	Characteristics
<p data-bbox="201 275 363 297">Pelton Turbine</p>  <p data-bbox="201 568 405 600">Applicable Range:</p> <p data-bbox="229 602 461 629">$n_s = 12$ to 24 (m-kW)</p> <p data-bbox="229 631 424 658">$H = 75$ to 500 (m)</p> <p data-bbox="229 660 474 687">$P = 300$ to $5,000$ (kW)</p>	<ul style="list-style-type: none"> - Water jet from the nozzle strikes the runner. The turned jets over the buckets exert a balanced force that rotates the turbine shaft. - There are one nozzle and two-nozzle types. One-nozzle turbine is applied to high head and low discharge. Two-nozzle turbine is used with relatively large discharge. In general, two-nozzle type is more widely used. - Discharge of the water jet can be adjusted by the needle valve. - A deflector is attached between the top of nozzle and the buckets that enables adjustment of the speed of rotation and immediate interception of water jet flows into the runner. - The structure is rather simple. The turbine is suitable for MHP since pressure rise and speed rise at load rejection can be controlled to lower values by the use of deflector.
<p data-bbox="201 768 453 790">Turgo Impulse Turbine</p>  <p data-bbox="201 1133 405 1164">Applicable Range:</p> <p data-bbox="229 1167 461 1193">$n_s = 55$ to 65 (m-kW)</p> <p data-bbox="229 1196 424 1223">$H = 40$ to 300 (m)</p> <p data-bbox="229 1225 474 1252">$P = 300$ to $5,000$ (kW)</p>	<ul style="list-style-type: none"> - Water jet from the nozzle strikes the runner at an angle of 20 to 25° at the top of the inlet of horizontal vanes each of three or four runner blades. The water jet is discharged roughly towards the direction of the shaft from the outlet side and opposite to that of the inlet. - It has one runner and one or two nozzles. - Water jet enters between the outer circumference of the runner and shaft. Thus, the radius of the radical pitch at which the water jet operates is small in the Turgo Impulse turbine. - It is applicable to relatively large discharge against head compared to Pelton turbine. - The structure of the deflector is simple and durable, which enables the turbine to be stopped by the deflector when the nozzle is fully opened and continuing to discharge. Accordingly, the inlet valve and spillway can be omitted. It can also be applied to river maintenance discharge.
<p data-bbox="201 1290 416 1312">Cross Flow Turbine</p>  <p data-bbox="201 1659 405 1691">Applicable Range:</p> <p data-bbox="229 1693 474 1720">$n_s = 90$ to 100 (m-kW)</p> <p data-bbox="229 1722 400 1749">$H = 8$ to 60 (m)</p> <p data-bbox="229 1751 461 1778">$P = 50$ to $1,000$ (kW)</p>	<ul style="list-style-type: none"> - The water is led by the guide vane and flows in through the outer side of the runner. It strikes the vanes, passes inside the runner to move the vanes again from the inside, and is then released. - The runner is cylindrical in shape with a long horizontal axis. It includes one (1) or two (2) guide vanes depending on the inlet width. - In the case of a turbine with large maximum discharge, two guide vanes are equipped with vane lengths of either $1/3$ and $2/3$ of the inflow width. When the discharge is small, i.e., $1/3$ of maximum discharge, only the shorter vane is used. If the discharge is more than $1/3$ of maximum discharge, only the longer vane is used. If the discharge exceeds $2/3$ of maximum discharge, both vanes are used at the same time, which enables operation with small reduction of efficiency against discharge change. - The structure is simple, maintenance is easy, and both equipment and installation costs low. It is therefore widely used in MHP.


Table 4.2.2 Major Types of Reaction Turbines

Type	Characteristics
<p>Francis Turbine (Horizontal Shaft)</p>  <p>Applicable Range: $n_s = 12$ to 24 (m-kW) $H = 75$ to 500 (m) $P = 300$ to $5,000$ (kW)</p>	<ul style="list-style-type: none"> - They are applied mostly to middle and small scale hydro schemes. They are applicable for a wide range of heads and capacities with high efficiency. Gross head is available down to the tailrace level as a result of draft tube effect that enables a high speed of rotation. - Vertical turbines are mainly applied to medium and small hydro of more than 5,000 kW output. As for horizontal axis Francis turbine less than 5,000 kW output, there are many types according to discharge. - It should not be selected for powerhouses that will experience long operation under low load.
<p>Propeller (Tubular) Turbine</p>  <p>Applicable Range: $n_s = 55$ to 65 (m-kW) $H = 10$ to 300 (m) $P = 40$ to $5,000$ (kW)</p>	<ul style="list-style-type: none"> - It is a tubular shaped horizontal propeller turbine that is applicable under low heads and relatively large discharges. - It can maintain high efficiency against change of head and discharge by rotating both or either runner blades of guide vane. - So far, vertical Kaplan turbine is used in this range of low head and large discharge applications. Horizontal type turbines have advantages in construction, maintenance and operation for MHP and are increasingly being adopted. - There are many types of Tubular turbines.

(2) Selection of Turbine

The type of turbine is selected according to design rated head and maximum discharge, taking the range of specific speed of each type into account. A diagram for selecting the applicable turbine type for given discharge and head is shown below.

In the diagram, many types of applicable turbines may be selected for the same discharge and head. In this case, the most appropriate turbine will be selected according to the site conditions and with consideration of size and efficiency and comparison of characteristics.



Source: "Guidebook on Micro Hydropower Introduction" published by NEDO of Japan in 2003 (arranged by WG).

Figure 4.2.3 Turbine Selection Diagram

(3) Specific Speed (n_s)

Specific speed is a constant widely used in selection of the turbine type and in preliminary design. The specific speed is defined as the rotating speed of a hypothetical turbine which is geometrically similar, producing a unit output (1 kW) under a unit head (1 m).

The specific speed is given by the following formula:

$$n_s = \frac{N \times \sqrt{P_t}}{H_e^{5/4}} \quad N = \frac{n_s \times H_e^{5/4}}{\sqrt{P_t}}$$

Where,

n_s :	specific speed (m-kW)
N :	revolving speed (min^{-1})
P_t :	turbine output (kW)
H_e :	effective head (m)

The specific speed is proportional to the revolving speed of turbine. In case higher specific speed and higher revolving speed are selected, the turbine and generator will become smaller, as will the powerhouse building. However, the specific speed has equipment strength and limitations to avoid cavitations occurrence as shown below.

Table 4.2.3 Maximum Specific Speed of Major Turbine Types

Impulse Turbine		Reaction Turbine	
Pelton Turbine	$n_s \leq \frac{4,300}{H_e + 200} + 14$	Francis Turbine	$n_s \leq \frac{23,000}{H_e + 30} + 40$
Cross Flow Turbine	$n_s \leq \frac{4,000}{H_e + 14} + 16$	Propeller Turbine	$n_s \leq \frac{21,000}{H_e + 16} + 50$

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Chapter 10.1)" published by JICA in 2011.

(4) Revolving Speed (N)

Revolving speed of turbine and generator, without adopting a speed-up gear and/or a direct current generator, is estimated using the following formula;

$$N = \frac{120 \times f}{p} = \frac{120 \times 50}{p} = \frac{6,000}{p} \quad \text{Where, } \begin{array}{l} N: \text{ revolving speed (min}^{-1}\text{)} \\ f: \text{ power system frequency (Hz) = 50 Hz} \\ p: \text{ number of poles (nos.)} \end{array}$$

It is common for the revolving speed to be chosen among the standard revolving speeds of a generator, originally obtained in the generator design. The upper limit of the revolving speed is calculated using the maximum specific speed of each turbine type, and the revolving speed is selected from the standard revolving speed which is closest to the calculated value.

The standard revolving speed of a Japanese generator is shown below. For MHP station, the number of poles used is generally up to 12.

Table 4.2.4 Standard Revolving Speed of Generator in Japan

Number of Pole (nos.)	4	6	8	10	12	14	16	18	20	24
Revolving Speed (min ⁻¹)	1,500	1,000	750	600	500	429	375	333	300	250

Note: The above revolving speeds are for frequency of 50 Hz.

Source: IEEJ standard JEC-4001 Hydro Turbine and Pump Turbine published by the Institution of Electrical Engineers of Japan (IEEJ), extracted and arranged by WG.

(5) Turbine Efficiency (η_t)

Turbine efficiency (η_t) is the ratio of output to input of the turbine.


$$\eta_t = \frac{P_t}{9.8 \times Q_{\max} \times H_e} \quad \text{Where, } \begin{array}{l} P_t: \text{ turbine output (kW)} \\ Q_{\max}: \text{ maximum design discharge (m}^3\text{/s)} \\ H_e: \text{ effective head (m)} \end{array}$$

Generally, the turbine is designed to attain the highest efficiency at around 80% of the maximum discharge. The efficiency decreases depending on the fluctuation of discharge. The efficiency curve is varies depending on the turbine type, the specific speed, and the manufacturer.

4.2.2 Generator

(1) Major Types of Generators

There are two types of generators for hydropower, namely synchronous generator and induction generator. The mechanism and characteristics of each type are summarized below.



Source: "Institution of Electrical Engineers of Japan (IEEJ)" webpage (<http://www.jeea.or.jp/course/contents/12125/>) (arranged by WG)

Figure 4.2.4 Mechanism of Synchronous and Induction Generator

Synchronous Generator

This type induces a voltage in armature coils by rotating magnetic poles. There are several types of exciter systems such as separate excitation, static excitation, and alternate current excitation brushless type. Brushless type generators are often employed in MHP scheme because they are easy to maintain.

It is widely used and generates three-phase alternating current (AC) with low-voltage terminal voltage. For small capacity more than 1,000 kVA, 11,000 V might be applicable.

Revolving speed of the generator is the same as that of the turbine in principle (refer to 4.2.1 (4)).

Induction Generator

This type is a rotating structure composed of armature winding and rotor winding. Electricity is generated through electromagnetic induction between the windings.

Generally, this type of generator cannot generate electricity independently. Operation must be established by supplying an excitation current to the armature winding, from another power source. In addition, the generator causes a rush current which is several times the value of the rated current, when it is connected to the power system on null voltage.

However, it tends to be applied to MHP schemes because of low cost, simple maintenance and easy operation. Induction motors are applied to generators at low cost. In this case, it should be noted that the induction motor is not able to withstand the over speed condition. Because induction generator operates by excitation current from a connected power grid, isolated operation and power factor adjustment are not possible.

To improve the power factor, a parallel condenser is connected to the generator. When load shedding occurs with a large condenser in place, it is necessary to pay attention to the following fact: As the rotational frequency of generator increases, the generator is excited by the leading current of condenser, which eventually causes self-excitation phenomenon with a high voltage.

It is applied to powerhouse less than 1,000 kW connected to power grid in parallel. Generator structure can be simple and low cost by applying a squirrel cage type secondary winding.

The required specification items of each generator type are listed below.

Table 4.2.5 Required Specifications of Synchronous Generator and Induction Generator

Item	Synchronous Generator	Induction Generator
Direction of shaft	Horizontal	-
Axis direction	-	Horizontal
Rated Capacity	Variable	Continuous
Capacity	kVA	kW
Voltage	V	V
Current	A	A
Power factor	0.8 to 0.5	Depending on manufacturer.
Frequency	Hz	Hz
Revolving speed	min ⁻¹	min ⁻¹
Slip	-	%
Insulation class	F class	F class
Type of bearing	With or without thrust bearing.	-
Type of excitation	To be specified.	-
Short circuit ratio	To be specified in case of large size.	-

Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Chapter 3.2)" conducted by JICA in 2003 (arranged by WG).

(2) Output and Rated Capacity

The output and capacity of a generator is estimated using the following formulae:

Generator Output (P_g)

$$P_g = \frac{P_t \times P_{g(temp)}}{P_{g(temp)} + P_{gl}}$$

$$P_{gl} = 0.1628 \times P_{g(temp)}^{0.8184}$$

Generator Capacity (P_g')

$$P_g' = P_g / P_f$$

$$\eta_g = P_g / P_t$$

Where, P_g : generator output (kW)
 P_t : turbine output (kW)
 $P_{g(temp)}$: generator output (temporary value) (kW)
 P_{gl} : generator loss (kW)
 P_g' : generator rated capacity (kVA)
 P_f : generator rated power factor (-)
 η_g : generator efficiency (-)

Several trial calculations are required to obtain the generator output as explained below.

- ✓ At first, plug in the turbine output (P_t) for the temporary generator output ($P_{g(temp)}$), and calculate the generator loss (P_{gl}) and generator output (P_g),
- ✓ Then, plug in the calculated generator output (P_g) for the temporary generator output ($P_{g(temp)}$), and repeat the same calculation until the temporary and the calculated outputs becomes equal ($P_{g(temp)} = P_g$).

Example

Calculation of generator output (P_g)

First assumption: $P_t = 45$ kW, and $P_{g(temp)} = 45$ kW

Generator loss: $P_{gl} = 0.1628 \times 45^{0.8184} = 3.7$ (kW)

Generator output: $P_g = 45 \times 45 / (45 + 3.7) = 41.6 = 42$ (kW)

Second assumption: $P_t = 45$ (kW), $P_{g(temp)} = 42$ (kW)

Generator loss: $P_{gl} = 0.1628 \times 42^{0.8184} = 3.5$ (kW)

Generator output: $P_g = 45 \times 42 / (42 + 3.5) = 41.5 = 42$ (kW) OK.

Calculation of generator rated capacity (P_g')

Generator efficiency: $\eta_g = 42 / 45 = 0.933$

Generator rated power factor: $P_f = 0.93$ (93%)

Generator rated capacity: $P_g' = 42 / 0.93 = 45$ (kVA)

The generator rated power factor (P_f) is generally adopted to be approximately 98% to 85%. However, it is determined in consideration of the characteristics of the load and connected power system.

(3) Voltage and Current

The relationship between generator rated voltage and generator rated current are given by the following formula.

$$I_g = P_g' / \sqrt{3} / E$$

Where, I_g : generator rated current (A)
 P_g' : generator rated capacity (kVA)
 E : generator rated voltage (kV)

In the case that the generator voltage adopted is higher, the stator coil insulator becomes thicker, the occupation ratio of conductor becomes lower, and total weight of generator becomes larger. As a result, the generator becomes expensive. On the other hand, higher voltage needs lower current and capacities of cables, conductors and breaking devices becomes smaller.

Therefore, comparative study is necessary to obtain an applicable voltage and current. Empirically, the generator rated voltage is adopted as shown below.

Generator Capacity:	Rated Voltage:
Less than 3 MVA	400 V
3 to 10 MVA	6.6 kV
10 to 50 MVA	11 kV

(4) Excitation System

Excitation system is equipped in a synchronous generator, and serves the function of controlling generator output and generator voltage to be constant by supplying a field current.

Exciter supplies a field current for the rotor in generator to generate magnetic flux. The generated excitation current in the magnetic flux is adjusted by Automatic Voltage Regulator (AVR) to be the constant generator voltage. The power factor of generator voltage is adjusted to be constant by the Automatic Power Factor Regulator (APFR), responding to the voltage fluctuation of the connected power system.

The system is generally adopted in MHP station, except independent operation of the generator.

4.2.3 Inlet Valve

Inlet valve is mechanical equipment to control water flow into the turbine. It is installed in front of the turbine inlet at the end of the penstock.




The inlet valve is opened during power generation. When power generation is interrupted, it is closed to shut off water flow before commencement of operation. This may be during inspection and maintenance, or in the case of an emergency involving the turbine. In this case, water inflow to the runner is closed off by a preceding operation of the guide vane or the needle.

In case the diameter of the inlet valve is relatively large and there is a low head and a large discharge, the inlet valve may be omitted by providing a regulating gate at the inlet of the penstock.

In case of automatic operation, there are two types of drives i.e., motor driven and hydraulic oil driven types. Generally, motor drives are more widely adopted. The power source for driving motor is basically direct current (DC), but alternating current (AC) may be applied. Hydraulic oil drives are used for large diameter applications. It is recommended that opening and closing time is set at less than 180 seconds.

The major types of inlet valves mainly applied for MHP schemes are summarized below.

Table 4.2.6 Major Types of Inlet Valve

Type	Characteristics
<p data-bbox="199 275 373 300"><u>Butterfly Valve</u></p> 	<ul style="list-style-type: none"> - It is applicable for heads of less than 150 m. - There are horizontal axis type and vertical axis type valves. Horizontal axis type valves have the advantage that the weight of the valve body is easy to support. - The valve diameter is generally 1.1 to 1.2 times the turbine inlet pipe diameter. - The structure is simple. Sealing method is good in rubber seal type valves. - The head loss is rather large compared to other valve types, but this is still applied in relatively small diameter because of the low cost.
<p data-bbox="199 515 427 573"><u>Through-flow Valve</u> (Double leaf valve)</p> 	<ul style="list-style-type: none"> - It is applicable for heads of less than 200 m. - The structure is the same as Butterfly Valve, but the valve body is thin and is strengthened by combining two pieces in order to reduce head loss. - The valve diameter is 1.1 to 1.2 times the turbine inlet pipe diameter, similar to the Butterfly Valve.
<p data-bbox="199 784 328 808"><u>Slice Valve</u></p> 	<ul style="list-style-type: none"> - It is applicable to high heads and small discharges. - It has small head loss. - There are two types of spindles that operate the valve electrically. - One is an inner screw type with a female screw attached to the valve body and a male screw on a spindle is turned for up-down movement. - The other type, the outer screw, turns a female screw at the top of the spindle. - The former is for relatively large diameter applications, but the latter has the advantage of safety and is applied for hydro more frequently.

Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Chapter 3.4)" conducted by JICA in 2003 (arranged by WG).

4.2.4 Power Transmission Equipment

Power transmission equipment is mechanical equipment to transmit the rotational energy from the turbine to the generator.

Since it is desirable to directly couple turbine and generator, the turbine speed will be selected to be equal to that of the generator as much as practically possible. However, when it is difficult to select the same speed between turbine and generator or when the turbine speed is very low and therefore requires many magnetic poles of the generator (required to obtain rated frequency at the low speed given, but will be complicated, expensive, and not readily available in the local market), a gear system to increase the revolving speed is required to transmit the turbine output to a generator.

For a MHP scheme, the number of poles used is generally up to 12. For more than 12 poles, the generator size is generally larger and more expensive. Application of speed-up gears paired with application of a 4-6 high speed generator is therefore necessary to increase the turbine speed, especially for cross flow turbine.

Major methods of increasing the revolving speed and the characteristics of each method are explained and are compared as shown below.

Speed Increaser

This is the ideal power transmission mechanism, which is applied to a turbine-generator of more than 30 kW output. Series of gears are contained in oil immersed casing for lubrication and cooling. A transmission efficiency of some 98% is obtained.

A flange coupling is employed for connecting the turbine-speed increaser and speed increaser-generator. The centering between the turbine and generator is difficult since both employ

roller bearings. Accordingly, a flexible coupling is used in order not to cause excess stresses on the bearing.

Belt Transmission

Belt transmission is most often applied for small capacity turbine-generator since it is easy to choose the necessary gear ratio.

There are various types of belt transmission such as plane belt, V-belt, and ditched belt. Among these, the V-belt is the most commonly used.



Belt Transmission

Table 4.2.7 Comparison of Speed Increaser and Belt Transmission

Item	Speed Increaser	Belt Transmission
Gear Ratio	Relatively large, but the ratio shall be selected from the standard goods.	Relatively adjustable as required.
Required Space	Relatively narrow.	Relatively huge.
Safety	High safety while the rotating portion is completely covered.	Relatively low while the belt is normally exposed.
Capacity	Adjustable for large capacity.	Limited due to belt proof strength
Economic Efficiency	Relatively expensive	Relatively cheap
Serviceability	In principle, it is maintenance free except for regular replacement of grease, etc.	Control of belt tension force, regular cleaning is required.
Load to Axis of Turbine and Generator	None	Radial load acts to the axis. Tolerated dose shall be considered.
Erection Adjustment	High accuracy is required	There is some tolerance
Noise	Relatively large	Relatively small

4.2.5 Governor

(1) Speed Governor

This is electrical equipment to control the revolving speed and output of turbine within the specified value.

The speed governor adjusts the water inflow devices such as guide vanes, needle valves and deflectors, and controls water inflow to synchronous the generator output with the load demand, and the power system frequency keeps the rated value. When operation is disconnected due to a fault or breakdown of the distribution line, the turbine is immediately shutdown by closing the guide vanes to prevent an abnormal rise in speed of the turbine and generator.

Large force is required against the water flow to adjust these devices directly. A hydraulic servomotor is used for medium-small scale hydro, while an electric servomotor is used for MHP scheme since control is accurate and maintenance and inspection are easy.

Detection of the control parameter (such as speed, water level, discharge and output), calculation of the required range for control, and relay of the control signal to the servomotor are conducted by a CPU and electronic circuit.

(2) Dummy Load Governor

This is electrical equipment to control the generator output to be synchronous with load demand within the specified value.

The dummy load governor is a method to adjust the surplus electricity by dummy loads (resistors). Surplus electricity is the difference between the generating output and the power system demand. The dummy load governor detects the differences from change in revolving speed and/or frequency, and adjusts the electricity automatically to be constant.

Advantages of the dummy load governor are:

- ✓ The control characteristics are fine and it can respond to sudden output change even from minimum to maximum,
- ✓ Turbine revolves at the most suitable point depending on the flow discharge control, and mechanical wear of the turbine is therefore mitigated, and
- ✓ Mechanical operation such as a servomotor is not involved.

The dummy load governor is applicable for units less than 200 kW, isolated operation in a small grid and for turbines without a water inlet adjusting mechanism, such as a reversible pump turbine system.

4.2.6 Transformer

Transformer is electrical equipment to step-up or step-down voltage. Transformers in power station are classified into the following three types:

- ✓ A main transformer used to step up generator voltage to line voltage,
- ✓ A station service transformer to lower the generator voltage to house voltage, and
- ✓ A station low-voltage transformer to lower the house voltage to equipment voltage.

(1) Main Transformer

Outdoor three-phase transformers are normally used in hydropower station. Regarding the cooling method, a self-cooling type is used in small capacity units. In case the transformer is installed indoors, dry-type is adopted due to the space limitation, in the majority of cases.

The rated capacity of the main transformer is set at a value equal to the rated output of the generator. The primary voltage is normally set at about 5% lower than the rated voltage of the generator. In case the system becomes ultra-high voltage and the power factor approaches 100%, primary voltage is set at the rated generator voltage.

In addition, in a MHP station, in case the voltage of the transmission line and that of the generator are the same, an insulation transformer of the same voltage is installed as a main transformer. This functions to protect the generator from external attack such as a thunder surge from a transmission line and to reduce the short circuit capacity in the power station.

(2) Station Service Transformer and Station Low-Voltage Transformer

Capacity of the station service transformer and station low-voltage transformer are determined to satisfy the required power for plant equipment such as a water supply pump, water drainage pump, lighting for the plant and power supply to a crane for the installation and maintenance works. Dry-type transformer is generally used for a small capacity unit installed indoors to avoid the danger of fire. It is installed in the same place parallel to the metal enclosed switchgears as a safety consideration.

It is noted that impedance of both station service transformer and main transformer are sometimes influenced by the short circuit current of the station service circuit. Appropriate values of impedances and the short circuit current shall be selected.

4.2.7 Main Circuit

Main circuit connects electrical equipment in powerhouse. The main circuit is designed taking the following aspects into consideration:

- ✓ Number and capacity of generators,
- ✓ Existence, number and connection method of distribution lines,
- ✓ Receiving method of station power,
- ✓ Restrictions such as space in power station,
- ✓ Construction cost and transportation conditions of transformers and switchgears,
- ✓ Range of power failure caused by in-station accidents, and
- ✓ Safety and ease of repair and maintenance.


The main circuit consists of the following electrical devices and systems.

Table 4.2.8 Examples of Major Devices and Systems in Main Circuit

Name	Function
Circuit Breaker	Open and close the load current, short-circuit in interruption and failure, interruption of ground-fault current, etc.
Disconnecting Switch	Divide electrical equipment and devices from the main circuit.
Instrument Transformer	Measure circuits for high voltage/large current, and supply voltage/current to instruments, relay and watt-hour meter based on the principle of the power transformer.
Arrester	Protect electrical equipment and devices from lightning and/or over surging voltage. The arrester includes protective gaps and protective condensers.
Metal Enclosed Switchgear	Put away circuit breakers, disconnecting switches and instrument transformers of each power supply (400V, 200V, 100V and a 6.6kV circuit of the power station) in steel boxes for safety and security.
Control Panel	Operate, control and protect all electrical equipment in powerhouse.
Protective Relay System	Protect electrical equipment against emergency, emergency stop for electrical failure, quick stop for mechanical failure, normal stop in alarm mode, and alarm.
Direct Current Power Supply System	Supply a direct current for controlling the control panel, switchboards, and protective relay system. Batteries with chargers are used as a power source. There are two types of batteries, lead acid and alkali. Alkali batteries are adopted more commonly these days because of simplicity of maintenance.

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Chapter 10.4)" published by JICA in 2011 (arranged by WG).

Examples of the main circuit connections are shown below.



Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Figure 10-36, 10-37 & 10-38)" published by JICA in 2011 (arranged by JICA).

Figure 4.2.5 Examples of Main Circuit Connections

4.2.8 Integrated Control Panel

An integrated control panel uses a Central Processing Unit (CPU) to perform integrated operations of control, operations of protective equipment, and storage of operation record for the powerhouse. It is contained in a small board.

Examples of the functions included in an integrated control panel are as follows:

Table 4.2.9 Examples of Functions in an Integrated Control Panel

Function	Element
Control Functions	Operation sequence, starting speed control, voltage control, power factor control, frequency control, load control, water level control, discharge control, program operation control, etc.
Protective Functions	Over current, over voltage, under voltage, bus ground fault, lack of phase fault
Display Functions	Voltage, current, power output, power factor, frequency, water level, opening, bearing temperature, faults, etc.
Recording Functions	kWh, discharge, historical record of fault, daily operation report, monthly report, annual salary, testing record, etc.

Source: "The Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros (Chapter 3.3)" conducted by JICA in 2003 (arranged by WG).

4.2.9 Other Equipment

(1) Cooling Water Supply System

Cooling water supply system is provided to cool down the electrical equipment to maintain normal temperature as well as for fire-fighting.

Water for the system is collected from penstock by an automatic valve via a pressure reducer. In the case of a power station with head less than 30 m or higher than 150 m, the water is fed from the tailrace by a water pump.

In the case of MHP station, cooling water supply system is omitted by adopting air-cooling for generator with air duct, plastic packing for main shaft sealing, air-cooling with the heat radiation fin, heat piping of the main bearings, etc. It aims at simplification of the equipment and ease of future maintenance works.

(2) Water Drainage System

A water drainage system is required for the powerhouse. Miscellaneous water flows arise in the powerhouse due to leakages from turbine seals, penstock, casing, rain water from building walls, general service water for maintenance works, etc.

Drainage pit is provided at the lowest level of the powerhouse to collect these miscellaneous water flows in powerhouse. Water flows are led to the drainage pit through drain ditches and drain pipes, and are removed to the outside by manual or drainage pumping.

The capacity of the drainage pit is estimated from time span of arrival time of the station staff and operation time for measures to be effected in the case of an emergency. An oily water separator pit is provided in the drainage pit to separate leaks of lubricating oil and turbine oil from equipment from the rest of the water to avoid direct release of oily water into the river.

(3) Crane

Overhead travelling crane or gantry crane is installed for installation and maintenance works of the water turbine and generator in powerhouse. In case of MHP station; truck crane, small electric hoist, hand-operated hoist and chain block are applicable. The capacity of crane is generally designed to hoist the heaviest equipment. Generator rotor is generally the heaviest among the electrical equipment.

(4) Grounding Wire

Grounding wire mesh is installed in and around the powerhouse area in order to avoid occurrences of step voltage or touch voltage. At the time of a ground fault of transmission line or generator, an electric current flows between the ground fault point and the powerhouse. It is indispensable to connect all the electrical equipment such to a grounding mesh.

4.3 Distribution Facilities

4.3.1 General

Consideration of the following points is generally required when designing the distribution facilities for a mini-grid. It is necessary for planning and designing the distribution facilities to consider the safety and the life cycle cost. Therefore the facilities for a mini-grid are technically the same as the facilities for the conventional distribution system.

- ✓ The design satisfies the technical standards required for power facilities in Kenya,
- ✓ The design satisfies the safety standards in Kenya,
- ✓ The distribution system supplies electrical power to all consumers at or above the quality of the electrical power standards.
- ✓ The cost of the equipment is minimized over the life cycle of MHP, not only by reducing initial investment cost but also maintenance cost.

4.3.2 Distribution Methods

(1) Medium Voltage Distribution Methods

Medium voltage distribution methods can be classified broadly by the neutral grounding method.

These are further classified as single or multiple grounding methods, according to the number of grounding locations. Various neutral grounding methods and their characteristics are tabulated in the next page.

Selection of the neutral grounding method is made primarily on the basis of the distribution voltage and facility conditions. Generally, a non-grounding method is used for 11kV or less, and a neutral point resistively grounding method is used for 20kV or more.

Three-phase loads may be used for the distribution methods listed above. A SWER (Single Wire Earth Return) method can also be used if it is for rural electrification of single-phase load only and the demand is small. The SWER method uses only a single medium voltage conductor, and an earth return system is used for the return circuit. Although the cost of the insulating transformers is high, the cost of the conductor drops as the distance becomes longer. Therefore, this method is used where there are points of load across large areas.

The advantages include low initial investment and low maintenance costs. However, there are many disadvantages such as;

- ✓ Possibility of accidents for the public caused by an electric current passing through large areas of land,
- ✓ A large amount of electromagnetic induction in the communication equipment compared to other distribution methods, and
- ✓ Necessity to change to a single-phase two-wire method or other distribution methods in case the SWER method is unable to handle the load that exceeds a certain volume.

(2) Low Voltage Distribution Methods

Low voltage distribution methods include a single-phase two-wire method, a single-phase three-wire method for a lighting load, and a three-phase three-wire method for a dynamic load. In general, a three-phase four-wire method is used to supply both lighting load and dynamic load. A star-connection three-phase four-wire method is common for the standard of 230/400V. The most suitable method is selected based on the configuration and density of demand in the area.

Table 4.3.1 Comparison of Grounding Method

Item	Grounding		Solidly Grounding Method	Resistively Grounding Method			Arc Suppression Coil Compensated Grounding Method	Non-grounding Method	Remarks								
				40 to 90 Ω	Around 200 Ω	500Ω (22kV) 950Ω (33kV)											
Abnormal Voltage	Switching		There is a problem with input surge, and the size is not directly affected by the grounding method.						There are no grounding methods that are difficult to use for insulation design.								
	Single-line Grounding Fault	Steady State	1.3 times or less	If $R_0/X_1 > 10$, 2.0 times or less • Impedance of earth capacity that satisfies conditions of 2.0 times or less. <table border="1" style="margin: 5px auto;"> <tr> <td>R_N</td> <td>50</td> <td>190</td> <td>950</td> </tr> <tr> <td>X_C</td> <td>$> 250\Omega$</td> <td>$> 300\Omega$</td> <td>$> 600\Omega$</td> </tr> </table> X_C for model system: City 150 to 1,500Ω Urban 180 to 6,700Ω Rural 3,700 to 10,000Ω			R_N	50		190	950	X_C	$> 250\Omega$	$> 300\Omega$	$> 600\Omega$	If overcompensated, $3^{0.5}$ times or less	If $X_0/X_1 < 10$, 2 times or less
		R_N	50	190	950												
X_C	$> 250\Omega$	$> 300\Omega$	$> 600\Omega$														
Transient	1.5 times or less	If $R_0/X_1 > 10$, 3.0 times or less			If overcompensated, 2.5 times or less	If $X_0/X_1 < 10$, 3 times or less											
	One Line Disconnected	No problem	No problem			<table border="1" style="margin: 5px auto;"> <tr> <td>α</td> <td>0.1</td> <td>0.2</td> <td>0.3</td> <td>0.5</td> </tr> <tr> <td>V_0</td> <td>$5E_a$</td> <td>$2.5E_a$</td> <td>$1.7E_a$</td> <td>$5E_a$</td> </tr> </table> Where, α α = overcompensation rate $= (3X_L - X_C) / 3X_L$	α	0.1	0.2	0.3	0.5	V_0	$5E_a$	$2.5E_a$	$1.7E_a$	$5E_a$	No problem
α	0.1	0.2	0.3	0.5													
V_0	$5E_a$	$2.5E_a$	$1.7E_a$	$5E_a$													
Induction toward Communication Line	Single-line Grounding Fault Normary	Large For multiple groundings, there might be interference from earth branches of load unbalance current.	Medium No problem	Small No problem	Small No problem	Small No problem		Neutral point solidly grounding cannot be used. Neutral point resistively grounding becomes more difficult to use for lower resistances.									
Rise in Electrical Potential on Low Voltage side when mixed with Low Voltage		Excessive	Large	Medium	Medium	Small											
Grounding Fault Protection	Wave Distortion	No problem	Small	Small	Medium	Large											
	Applicable Relays	OC	3CT + DG	3CT + DG might also be used.	3CT + DG might also be used.	CT + OCG, GPT+OVG, ZCT+DG ZCT+DG might malfunction depending upon conditions at the fault point, and careful consideration of DG performance is required.		Although the development of a relay might be required, resolution of the problem is not difficult.									
	Fault Detection Sensitivity	Cannot be set very high.	100-900Ω (10-30%)	2,000Ω (10%)	4,500-8,500Ω (10%)	About 1,000Ω		Figures shown in () are the minimal detection sensitivity for DG.									

Notes;

 R_0 : zero-phase resistance, X_1 : positive-phase resistance, V_0 : zero-phase voltage,

OC: over current relay,

OVG: grounding over voltage relay,

3CT: items using residual circuitry for 3 CT units of each phase,

 X_0 : zero-phase reactance, X_C : earth capacity reactance,

OCG: grounding over current relay,

DG: directional grounding fault relay,

ZCT: zero-phase current transformer, and

 X_L : reactor reactance.

Source: "20kV Distribution Method (Overhead Edition)", Vol. 3 No.3, published by Electric Technology Research Association in Japan (arranged by WG).

4.3.3 Distribution Line Planning

Distribution line planning requires consideration of not only construction but also maintenance in relation to the facility location, topography, the route, and the relationship with other structures.


Specifically, the following should be considered when selecting the route:

- ✓ The route preferably follows roadways,
- ✓ There are fewer trees that would require cutting or clearing,
- ✓ The area is not susceptible to natural damages, such as landslides, avalanches, and flooding,
- ✓ Swamps and steep mountainous areas should be avoided,
- ✓ There are fewer river and roadway crossings. When a crossing is required, it can be done at a right angle,
- ✓ The route is straight and level as much as possible between the supports, with equal spans on both sides,
- ✓ The supports can be built on risers firmly when passing through rice paddies and agricultural fields, and so on.

4.3.4 Electrical Design

(1) Line Constants

Distribution lines are electric circuits with four line constants, i.e., resistance, inductance, capacitance, and leakage conductance as shown below.



Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Figure 11-4)" published by JICA in 2011.

Figure 4.3.1 Line Constants

These line constants must be known in order to calculate the electric properties of the distribution line. They are determined by the type, thickness, and layout of conductors, and they are mostly unaffected by voltage, current, and power factor. In addition, since the distribution lines have lower voltage and shorter lengths than the transmission lines, only resistance and inductance need to be considered here normally.

(2) Voltage Drop

A voltage drop is the difference between the delivered voltage and the received voltage, occurring when there is a load current on a distribution line. The voltage drop is calculated in order to check the maximum and minimum voltages at each point to finally determine whether it is within a standard range.

Since the load of distribution lines is dispersed in different ways depending on the location, capacity, and type, it is difficult to calculate the voltage drop. Therefore, a usual method for determining an approximate value of voltage drop is to refer to the scattering loss coefficients for common forms of load distribution.

(3) Power Loss

Power loss in distribution lines is primarily a resistive loss in lines, an iron loss (no-load loss) and a copper loss (load loss) in transformers.

The resistive loss in lines and loss in transformer are given by the following formula.

<p>Power loss in distribution line</p> $W = I^2 \times r \times L \times N$	<p>Where,</p> <p>W: power loss of distribution line (W)</p> <p>I: load current (A)</p> <p>r: resistance per km ($\Omega \cdot \text{km}$)</p> <p>L: length of distribution line (km)</p> <p>N: number of lines (nos.)</p>
<p>Power Loss in Transformer</p> $P = W_i + W_c \times F^2$	<p>Where,</p> <p>P: power loss in transformer (W)</p> <p>W_i: iron loss (W)</p> <p>W_c: copper loss (W)</p> <p>F: usage rate of transformer</p>

Since the loss in transformers is determined according to the specifications of the transformer itself, power loss in a transformer is one indicator of the quality of the transformer.

(4) Fault Current

Electric faults can be classified into a grounding fault and a short circuit.

- ✓ A grounding fault occurs when trees or other objects come into contact with lines, or when lightning causes discharge in insulators, resulting in the flow of current into the ground. The grounding fault current value will vary depending on the neutral grounding methods.
- ✓ As for a short circuit, the impedance of electric line becomes nearly zero at the point of the short circuit, and generally the current flows from the power source through the impedance of the line or transformer. Therefore, the value of a short circuit current is huge.

Regardless of which type of fault occurs, it is necessary to cope with the faulty current (short circuit current in particular) through the use of protection relays to detect the fault and circuit breakers to cut off the current. This is done in order to prevent the fault from spreading to the entire power system as well as to protect the equipment on the load side.

(5) Allowable Current

Allowable current is the maximum current that can pass through electric facilities. Physical objects have resistance to electricity, which results in the generation of heat when voltage is applied and current flows through the objects. In the case of electric lines, they may generate sufficient heat to melt the insulation and cause a short circuit, or even possibly start a fire. Therefore, the allowable current is specified for electrical materials, and fuses and circuit breakers are used for protection.

The allowable current varies based on the type of insulating body, electric line laying method and ambient temperature.

(6) Inductive Interference

Inductive interference is the phenomenon of flowing an electric current in other electric lines or communication lines, thereby causing injury to people and interfering with telecommunications.

Electrostatic Induction

In general, there is electrostatic capacitance between conductors located near each other. Such nearby conductors act as a kind of condenser, so that the charge in one of the lines will induce voltage in the other, even if they are not directly connected. This is called electrostatic induction. The size of the voltage occurring in the second conductor is determined based on the mutual electrostatic capacitance and the voltage of the first conductor.

Electromagnetic induction

It occurs when a fluctuating magnetic field caused by the current in one conductor intersects with another conductor, resulting in inductive voltage in the second conductor. The size is determined based on the mutual inductance, current and parallel route length of the two conductors.

Normally, inductive interference almost never occurs because distribution voltage is small, and ground current is also small if a non-grounding method is used. However, inductive interference must be considered when distribution voltage is 20 kV or greater, and it must be controlled below the allowable inductive interference value stipulated in the standards.

(7) Insulation Design

Targets for insulation design can be broadly classified as: i) commercial frequency voltage, ii) internal abnormal voltage generated by internal factors, such as switching surges, and iii) external abnormal voltage caused by lightning surges. Since the external abnormal voltage caused by lightning surges is much greater than that of i) or ii), designs resistant to lightning form the basic concept for insulation design in distribution lines.

Arrestors are required to satisfy the following performance to meet the insulation level of the distribution line and protective coordination:

- ✓ The voltage level at which arrestors operate must be higher than the internal abnormal voltage that occurs in the distribution line.
- ✓ The lightning impulse limit voltage of arrestors must be lower than the insulation level of the insulators and equipment in the distribution line, with sufficient margin to allow protective coordination.
- ✓ The continuous cutoff voltage for arrestors must be higher than the maximum voltage occurring in the distribution line circuitry.

4.3.5 Mechanical Design

(1) Acting Load

The loads on distribution line supports, electric lines, etc. include wind load, uneven tension between electric lines on both sides, own weight, and the weight of other supporting structures. Since these loads have a compounded effect on distribution lines, they must be classified separately when designing them according to the direction of action. They can generally be categorized into the following three groups:

- ✓ Vertical load
- ✓ Horizontal lateral load, and
- ✓ Horizontal longitudinal load

Since supports for distribution lines are normally strong enough against vertical load, it is necessary to consider during the design stage whether they can withstand horizontal loads in particular.

(2) Support Strength

Support strength refers to the moment of resistance for support against stresses such as the moment of bending. In general, supports must be designed so that the safety factor against a breaking load is equal to the defined number in the standards or greater, and guys and struts must be used to distribute the load.

(3) Guy and Strut Strength

Guys and struts can be used to distribute the load acting on supports for distribution lines. They are necessary to ensure the required safety factor against uneven tension generated when hanging conductors, the combined tension resulting from directional angles with conductors, and also uneven tension due to different span lengths on both sides of the support.

(4) Support Foundation Strength

The support foundations must be set so that the moment of resistance for the ground on which the foundations sit is greater than the moment of rotation caused by external forces under the worst load conditions acting on the support. The strength of the foundations of the support will vary depending on the embedded length, the usage of guy anchors and soil factors based on a type of soil.

(5) Dip in Electric Lines

Although the tension on electric lines themselves is reduced and the safety improved through a greater (deeper) dip in the lines, the height of the supports must be increased to keep the low-hanging lines up from the ground. This results in lateral oscillation caused by wind, increasing the possibility of faults due to tangled lines, etc. Therefore, the dip and tension that satisfy the safety factor must be considered during the design stage.

4.3.6 Overhead Distribution Lines

There are overhead and underground distribution lines. Overhead distribution lines are common for mini-grids due to the low construction costs and the possibility of quick recovery in the event of a fault.

(1) Supports

With overhead distribution lines, supports must be used to ensure that the lines remain at a height from the ground that is safe for both motorists and pedestrians. If a support should collapse, there is a high possibility of personal injury and property damage due to the proximity between distribution lines and residential areas. Further, the reconstruction of the collapsed supports involves an additional cost and would require a service interruption in the surrounding area. Therefore, the avoidance of such problems requires the selection of supports that are strong enough against the load acting on them and durable enough for use over a long time.

Different types of supports include reinforced concrete poles, wooden poles, steel poles, and iron poles.

Reinforced concrete poles are economical and strong, and the most commonly used type of support.

Wooden poles are used in areas such as mountainous regions where it is difficult to bring in concrete poles or to construct new poles. These poles require the injection of creosote or other wood preservatives to prevent a reduction in strength due to the decomposition of the wood in the portion of the pole to be embedded in the ground. The strength of wooden poles will vary depending upon the material used.

(2) Guys and Struts

Guys and struts are used in areas where the tension on electric lines acts unevenly on supports, such as at the ends of distribution lines and sections where lines curve. Struts are used where it is not possible to use guys for a land-related reason, and they are installed in the direction opposite to the guys to be installed, if possible.

In general, galvanized steel stranded conductors are used for guys. In addition, anchors that can withstand the guy tension must be embedded in the foundation of guys.

(3) Crossarms

Crossarms are used to mount electric lines on supports. Wooden crossarms are used on wooden poles, and also need to be treated with creosote or other wood preservatives. Metal crossarms are used widely on all types of supports.

(4) Insulators

Insulators are used to maintain insulation and also to mount electric lines when using metal crossarms. Insulators are grouped by voltage and the installation method of electric lines, pin insulators or line post insulators are used for bypass lines and bridle wires, and strain insulators or dead-end insulators are used to mount the ends of electric lines. Although porcelain is generally used for insulators, there are also polymer insulators made of light-weight silicon rubber for use in medium voltage distribution lines.

(5) Conductor

A single conductor is commonly made up of several individual strands. Copper and aluminum are commonly used as conductors due to their low resistance, and there are a variety of structures including bare conductors or the use of insulation, various materials, and steel cores. Since conductors

used in overhead distribution lines are often located near residential areas, insulated conductors are normally used for low voltage lines as a safety consideration.

When selecting a conductor, it is necessary to consider a type and sectional area according to the allowable current required, topography of the route, mechanical strength, resistance to corrosion, economical efficiency and other factors.

(6) Transformers

Overhead distribution lines normally have pole transformers to step down the voltage from medium voltage. Most pole transformers are of oil-filled self-cooling type, in which the main transformer unit (core and windings) is immersed in insulating oil. Silicon steel strips are widely used for the core. Grain-oriented silicon steel strips can be used to reduce loss, and amorphous materials are also sometimes used to reduce loss even further. There are two types of transformers, single-phase and three-phase; and wiring methods vary depending on medium or low voltage distribution. Two single-phase transformers with V wiring can be used for a three-phase load, and single-phase transformers with different capacities and V wiring can be used for a combined single- and three-phase load with a three-phase four-wire method.

The primary indicators of transformer performance are no-load current, no-load loss, voltage regulation and efficiency. When selecting a transformer, it is necessary to consider not only the suitable capacity for the load, but also performance indicators such as no-load loss and efficiency.

(7) Switches

Switches can cut off an electric current, and are used to disconnect areas of distribution lines that have a fault, or to limit the range of power outage when repairs to distribution lines are required. Varieties of arc suppressing media are used, such as oil-filled switches, air switches, vacuum switches, and gas switches. The use of oil-filled switches is not recommended for overhead distribution lines in public areas due to possibility of fire if a short circuit occurs. There are also some switches with built-in transformers for controlling the system, arrester components, and a variety of other sensors.

Cutouts are switches with built-in fuses that are installed on the primary side of transformers. If an overload or an internal short circuit occurs at the transformer, they automatically disconnect the transformer from the distribution line and can be used as switches on the primary side. They are also used as switches for branching distribution lines with a small load current. Some also have built-in arresters.

(8) Arresters

Arresters are installed between distribution lines and earth to protect distribution facilities from lightning surges. Many are made of zinc oxide (ZnO) components, non-linear resistive elements. Arresters operate most effectively when installed as near as possible to the equipment to be protected.

4.3.7 Others

(1) Service Drops

Service drops are electric lines that branch from distribution lines and supply electricity into customers' homes.

Normally, the point of insertion is the property demarcation point, as well as the obligation demarcation point for maintenance and security between power companies and customers. If watt hour meters are installed on poles to prevent the theft of electricity and the secondary side of a watt hour meter is at the property demarcation point or the obligation demarcation point, the customer will in most cases be required to install electric lines as service drops to his/her residence or business.

It is necessary to select lines, in the same manner as selecting electric lines and cables. That is, with conductors and a sectional area of sufficient mechanical strength for the allowable current, and to keep voltage drops within the allowable range.

Since service drops are installed in residential areas, insulated conductors are normally used as a safety consideration.

(2) Watt Hour Meters

Watt hour meters measure the amount of electricity used by customers, to calculate electricity rates based on the contracts between the power company and the customers. The type of watt hour meter used, therefore, will vary according to the type of contract.

In case of customers with small-scale demand, whose usage conditions are almost always the same, such as for public street lighting, watt hour meters are not installed. In some instances, load limiters might be used in place of watt hour meters to ensure a more consistent electricity rate when compared with the cost required to calculate the rates by reading meters. Recently prepayment watt hour meters are becoming increasingly popular for the same reason.

CHAPTER 5 ECONOMIC AND FINANCIAL EVALUATION

5.1 Key Comparative Indicators for Evaluation

Evaluation of the efficiency of a MHP project is based on the following four aspects: i) technically sound, ii) socially and environmentally acceptable, iii) economically efficient, and iv) financially viable. The latter two aspects are evaluated on the basis of economic analysis and financial analysis, respectively.

Economic analysis is a way to evaluate the project by comparing the social and economic benefit with the construction cost, from the perspective of public interest or national economy. On the other hand, financial analysis is a way to evaluate the profitability of the project by comparing the revenues accrued to the investment cost from the perspective of business enterprise.

Key comparative indicators for evaluating economic and financial viability of the project are as follows:

- i) Present Value (PV)
- ii) Net Present Value (NPV) (B-C)
- iii) Cost-Benefit Ratio (B/C)
- iv) Internal Rate of Return (IRR)
- v) Unit Energy Cost (kWh Cost)

(1) Present Value (PV)

In economics, present value is a future amount of money that has been discounted to reflect its current value. The relationship between the present value (PV) and future value (FV) is expressed in terms of the following formula for discounting:

$$FV = PV \times (1 + r)^n$$

$$PV = \frac{FV}{(1 + r)^n}$$

Where, *FV*: future value (currency unit)
PV: present value (currency unit)
r: discount rate (%)
n: year in the future (year)

For example, as shown in the table below, the present value of KSh. 1,000 is expected to rise to KSh. 2,594 in 10 years at the interest rate of 10%. Conversely, KSh. 2,594 after 10 years from now is discounted in value to a present value of KSh. 1,000. The future value of money is therefore considered to be equivalent to a smaller value at present.

On the contrary, this means that a present value has an increased future value, the increase being “interest”. The word “interest” therefore expresses the same idea as the word “discount”. Both the discount rate and market interest rate take inflation and the cost of capital into account. For instance, a bank will quote a market rate of interest because it expects repayments which compensate it for lending the money, and also compensate it for devaluation due to inflation.

The table below shows an example of present value calculation of annual cost.

Table 5.1.1 Example of Future Amount and Present Value

Year End	Future Amount		Present Value	
	Interest rate $i = 10\% = 0.1$	1,000	Discount rate $i = 10\% = 0.1$	1,000
1	$P \times (1+i)^1 = 1,000 \times (1+0.1)^1 =$	1,100	$P / (1+i)^1 = 1,000 / (1+0.1)^1 =$	909
2	$P \times (1+i)^2 = 1,000 \times (1+0.1)^2 =$	1,210	$P / (1+i)^2 = 1,000 / (1+0.1)^2 =$	826
3	$P \times (1+i)^3 = 1,000 \times (1+0.1)^3 =$	1,331	$P / (1+i)^3 = 1,000 / (1+0.1)^3 =$	751
4	$P \times (1+i)^4 = 1,000 \times (1+0.1)^4 =$	1,464	$P / (1+i)^4 = 1,000 / (1+0.1)^4 =$	683
5	$P \times (1+i)^5 = 1,000 \times (1+0.1)^5 =$	1,611	$P / (1+i)^5 = 1,000 / (1+0.1)^5 =$	621
6	$P \times (1+i)^6 = 1,000 \times (1+0.1)^6 =$	1,772	$P / (1+i)^6 = 1,000 / (1+0.1)^6 =$	564
7	$P \times (1+i)^7 = 1,000 \times (1+0.1)^7 =$	1,949	$P / (1+i)^7 = 1,000 / (1+0.1)^7 =$	513
8	$P \times (1+i)^8 = 1,000 \times (1+0.1)^8 =$	2,144	$P / (1+i)^8 = 1,000 / (1+0.1)^8 =$	467
9	$P \times (1+i)^9 = 1,000 \times (1+0.1)^9 =$	2,358	$P / (1+i)^9 = 1,000 / (1+0.1)^9 =$	424
10	$P \times (1+i)^{10} = 1,000 \times (1+0.1)^{10} =$	2,594	$P / (1+i)^{10} = 1,000 / (1+0.1)^{10} =$	386

(2) Net Present Value (NPV) (B-C)

The MHP project is expected to bring in revenue as well as to incur running costs in subsequent years after its completion. The Net Present Value (NPV) is the present value (PV) of all revenues (benefit) minus the present value of all capital and running costs. It is expressed as follows:

$$NPV = B - C$$

$$= \sum_{t=1}^n \frac{B_t}{(1+r)^t} - \sum_{t=1}^n \frac{C_t}{(1+r)^t}$$

$$= \sum_{t=1}^n \frac{B_t - C_t}{(1+r)^t}$$

Where, NPV : net present value (currency unit)
 B_t : benefit in t-th year (currency unit)
 C_t : cost in t-th year (currency unit)
 r : discount rate (%)
 n : years for evaluation (project life)

(3) Cost-Benefit Ratio (B/C)

The Cost-Benefit Ratio (B/C), expressed by the below equation is one of the indicators of the efficiency of project. If the B/C is greater than 1.0, it means that the project will earn more than it costs.

$$\frac{B}{C} = \frac{\sum_{t=1}^n \frac{B_t}{(1+r)^t}}{\sum_{t=1}^n \frac{C_t}{(1+r)^t}}$$

(4) Internal Rate of Return (IRR)

The Internal Rate of Return (IRR) is the discount rate at which NPV becomes zero. In other words, the IRR is the discount rate at which the NPV of benefit and cost are equal, as expressed below.

$$NPV = \sum_{t=1}^n \frac{B_t - C_t}{(1+r)^t} = 0 \quad \therefore \sum_{t=1}^n \frac{B_t}{(1+r)^t} = \sum_{t=1}^n \frac{C_t}{(1+r)^t}$$

(5) Unit Energy Cost (kWh Cost)

Unit Energy Cost (kWh Cost) is an important indicator of financial viability of the MHP project. This indicator provides a guideline for determining the selling price of energy. The unit energy cost is calculated using the following equation:

$$\text{Energy Cost} = (Ca + Cr) / E$$

$$Ca = C \times C_f = \frac{r \times (1+r)^n}{(1+r)^n - 1}$$

$$E = P \times 24 (\text{hour}) \times 365 (\text{days}) \times PF$$

$$= P \times 8,760 \times \xi$$

Where,
 Ca : annualized construction cost (currency unit)
 Cr : Annual running (O&M) cost (currency unit)
 C_f : capital recovery factor (%)
 r : discount rate (%)
 n : years for evaluation (project life)
 E : annual energy (kWh)
 P : installed capacity (kW)
 ξ : plant factor (%)


It is noted that the annualized construction cost “Ca” shall be given in terms of a constant annual sum throughout the life of the project. Therefore, the unit energy cost varies according to the discount rate applied and the project life. The annuity equation provides a simple way of converting the initial construction cost into an annual cost.

5.2 Estimation of Project Cost

The project cost shall be updated after the basic design and/or detailed design are completed in order to increase the accuracy of the cost estimate.

The project cost consists of construction cost, engineering fee and owners' project management cost. The construction cost of a MHP project is roughly divided into the cost of civil structure, electrical equipment and distribution facility.

Estimation methods of a MHP project cost vary depending on the country and donor/financing organization. However, the following methods are generally adopted:



Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Figure 12-1)" published by JICA in 2011 (arranged by WG).

Figure 5.2.1 General Components and Estimation Method of MHP Project

The estimation of costs should include contingency, which can be determined by surveying current market prices etc., in order to avoid budget shortages during the implementation stage.

The estimation of construction costs specifically requires preparation of estimate data which are clear and logical, to adequately meet any demand for disclosure to a financing or donor organization.

Some assumptions may be made regarding the procurement locations of equipment, materials and suppliers as shown below.


Table 5.2.1 Assumed Procurement Locations of Equipment, Materials and Suppliers

Component	Item	Near the Site	Domestic	Import
Civil Works	Sand, gravel, stone	●		
	Cement		●	●
	Steel		●	●
	Building materials	●	●	●
Electrical Equipment	Turbine			●
	Generator			●
	Control panel			●
Distribution Facilities	Pole		●	●
	Electric wire, cable		●	●
	Transformer, switch		●	●
	Telecommunication system		●	●

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Table 12-1)" published by JICA in 2011.

5.2.1 Civil Works

The construction cost of civil works consists of various components as shown below.



Source: “Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Table 12-2)” published by JICA in 2011 (arranged by WG).

Figure 5.2.2 Components of Construction Cost of Civil Works

Indirect costs and management costs are generally estimated as a percentage of direct cost, and each set at 10 to 15%.

The direct cost of civil works is estimated by bill of quantity method. The bill of quantity method is based on the unit price of each type of work and requires provisional calculation of the cost as shown in the following equation.

$$Cost = Quantity \times Unit Price$$

The quantity and unit price are estimated for each work item of construction of civil structures. Quantities are estimated based on drawings, while unit prices are estimated based on current market prices of related materials, equipment, and others.

(1) Quantity

Quantities of civil works vary depending on the geological conditions at the site. Despite this variability, the construction schedule and unit prices are estimated on the basis of these quantities. Quantity calculation of civil works is therefore one of the key issues in the estimation of project cost.

At minimum, quantities should be estimated for the following work items for each permanent structure.

Table 5.2.2 Major Work Items of Civil Works

Item	Description
Excavation	It is estimated from the sectional area and distance between each cross section in the drawings. Soil portion and rock portion are estimated separately based on the assumed rock line in each cross section. 10 to 15% of the calculated volumes are added as contingency, because excavation volume varies depending on the geological condition. The quantity is estimated by cubic meter (m ³).
Disposal of Excavated Material	It is estimated as total excavation volume minus reuse volume of excavated material. The quantity is estimated by cubic meter (m ³).
Backfilling	It is estimated from the drawings, in the same manner as excavation volume.
Gabion	It is estimated using the surface area of the area protected by the gabion and the thickness of the gabion indicated in the drawings. The quantity is estimated by cubic meter (m ³).
Concrete	It is estimated from the sectional area and distance of each element in the drawings. The volume shall be estimated for each strength class specified in the drawings. The quantity is estimated by cubic meter (m ³).
Formwork	It is estimated from the sectional area of each element in the drawings. The volume shall be estimated for each type of formwork specified in the drawings. Surfaces exposed to water, those exposed to air, and hidden surfaces are estimated separately. The quantity is estimated by cubic meter (m ³).
Reinforcement Bar	It is estimated from the typical re-bar arrangement or unit weight of concrete (ton/m ³) of each structure. The quantity is estimated by weight (ton).
Screen and Gate	It is estimated from the volume and unit weight of steel. The volume is calculated from the dimensions indicated in the drawings. 5 to 10% of the calculated volume is added to represent the weight of attached steels. The quantity is estimated by weight (ton).
Steel Penstock	It is estimated from the volume and unit weight of steel. The volume is calculated from the diameter, thickness and length of penstock. 5 to 10% of the calculated volume is added to represent the weight of attached steels. The quantity is estimated by weight (ton).
Other Metal Works	It may consist of steel pipe, hand rail, fence, etc., and is estimated from the drawings in the same manner as screen and gate.

For temporary facilities and structures which are required for the construction, the quantities are estimated in the same manner as permanent structures or a lump sum cost is determined. Major temporary facilities and structures and their quantity estimation methods are summarized below.

Table 5.2.3 Major Temporary Facilities and Structures

Item	Description
Clearing and Grubbing	It is estimated as surface area of temporary facilities from the drawings including cut slope. The quantity is estimated by square meter (m ²).
Labor Camp	It is estimated based on the number of laborers and required period. The quantity is estimated as lump sum.
Care of River	It is estimated based on the size of the river and probable flood discharge at intake site and tailrace site. The quantity is estimated as lump sum.
Reclamation of temporary yards	It is estimated in the same manner as permanent structures, with the exception of rent base which will not be used after the construction.
Rehabilitation of existing Road	It is estimated from the required width for construction and distance of the existing road. In case rehabilitation of a bridge is required, it will also be included in the estimates. The quantity is estimated by length (km).

(2) Unit Price

Unit price of civil works is a summation of the following 6 components:

Table 5.2.4 Components of Unit Price of Civil Works

Item	Description
Labor Cost	Cost of laborers directly involved in the construction work: specially skilled persons such as operators, carpenters, reinforcing bar workers, welding operators, and general workers etc.
Material Cost	Cost of hiring materials such as cement, sand, aggregates, woods, reinforcement, steel, forms, scaffolds, supports, etc.
Machinery Cost	Cost of hiring or leasing construction equipment such as bulldozer, backhoe, dump truck, crane etc.
Fuel Cost	Cost of fuel and lubricants such as gasoline, diesel oil, electric energy, etc., for construction equipment.
Temporary Work Cost	Cost of temporary facilities, equipment, electric energy, water, fences, etc.
Transportation Cost	Cost of wrapping and transportation of construction materials and equipment. (In the case of long distance transportation, this category is considered separately.)

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Table 12-4)" published by JICA in 2011.

For cost estimation to be undertaken as described above, special knowledge of construction methods and man-days of work is necessary. In instances where such detailed knowledge is lacking, the first step will be to conduct market price survey. The following recommendations should be considered and taken into account when conducting the market price survey.

Obtain more than Three (3) Quotations

When requesting and receiving cost proposals, details of estimate conditions, time schedule, quantity and specifications should be defined. Further, quotations should show not only the total amount but also the details such as material cost, labor cost and machinery cost. Lastly, at least three quotations should be obtained for comparison.

Select Reliable Procurement Companies

To prevent issues such as inferior quality, delay of delivery date, cancellation due to bankruptcy etc., reliable procurement companies should be selected.

5.2.2 Electrical Equipment

The electrical equipment consists of: water turbine, generator, main transformer, switchgears, control equipment, auxiliary equipment, and others. The manufacturing and installation costs are estimated based on the following conditions:

- ✓ Assuming that most of the equipment is to be imported and procured either directly from the manufacture or through an agency,
- ✓ Preparing draft contract documents including technical specifications based on global specifications such as *Federation Internationale des Ingenierus Conseils/ International Federation of Consulting Engineers – (FIDIC) guideline*, and
- ✓ Adopting tenders in package deals rather than numerous separate tenders in general, and
- ✓ Estimating the cost based on the contract performance of the same type of equipment and/or receiving estimates from several manufacturers.

The final cost estimation should not be decided on the basis of price alone. Other factors such as delay of delivery, the performance of equipment and manufacturers and/or suppliers after the installation, convenience of procurement of spare parts, etc., shall also be taken into consideration.

In regards to the specifications, it is noted that the demarcation between contracts, i.e., civil works and distribution works, shall be indicated clearly.

An example of a construction cost list of electrical equipment is shown below.

Table 5.2.5 Example of the Construction Cost List of Electrical Equipment

Item	Foreign Currency	Local Currency	Total	Remarks
Turbine				
Design and manufacturing				
Installation				
Generator				
Design and manufacturing				
Installation				
Main Transformer				
Design and manufacturing				
Installation				
Switchgears and Control Equipment				
High voltage switchgears				
Metal enclosed switchgears				
Control equipment				
Water level measurement equipment				
Transmission line protection system				
Tele-control equipment				
Main circuit bus				
Power and control cable and rack				
Installation				
Steel Structure				
Auxiliary Equipment				
Station service transformers				
Crane				
DC power system and CVCF				
Arrestor				
Emergency generator				
Grounding Wire				
Spear Parts				
Other Equipment				
Testing equipment				
Plant communication system				

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Table 12-7)" published by JICA in 2011.

5.2.3 Distribution Facilities

Distribution facilities consist of supports (poles), conductors, cables, transformers, switches, communication facilities, and so on.

Distribution facilities work is in many cases classified into two portions;

- ✓ Procurement of materials and equipment
The direct cost is estimated based on quantity and unit prices, and indirect cost is not considered.
- ✓ Installation and construction works of the procured materials and equipment.
The direct cost is estimated based on quantity and unit prices, and indirect cost is considered including common temporary facilities cost and site management cost.

In the case of a power pole, procurement covers its purchase and transportation to the construction site. Construction work is therefore installation at the site.

(1) Quantity

The quantities shall be estimated for each type of the following main equipment.

Table 5.2.6 Main Distribution Facilities

Facility	Unit	Specification
Middle Voltage Overhead Lines	cct-m	Line type, cross section (mm ²)
Low Voltage Overhead Lines	cct-m	Line type, cross section (mm ²)
Middle Voltage Underground Cables	cct-m	Line type, cross section (mm ²)
Low Voltage Underground Cables	cct-m	Line type, cross section (mm ²)
Supports	nos.	Type, length, strength.
Pole Mounted Transformers	nos.	Single phase or three phase, capacity.
Switches	nos.	Type, capacity.
Watt-hour Meters	nos.	Single phase or three phase, capacity.

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Table 12-8)" published by JICA in 2011.

In addition, it is necessary to calculate the incidental costs such as those of cutting trees, etc.

(2) Unit Price

The unit prices of distribution facilities consist of the costs outlined below. Surveying current market prices may inform the process of setting unit prices.

Table 5.2.7 Components of Unit Price of Distribution Facilities

Procurement Cost	Installation and Construction Cost
Material Price	Labor Cost
Local Transportation Cost	Material Cost
Tax	Machinery Cost
Cost of Insurance and Freight (CIF)	Fuel Cost
	Temporary Work Cost
	Transportation Cost

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Table 12-9)" published by JICA in 2011 (arranged by WG).

5.2.4 Planning of Construction Schedule

Hydropower has the advantage of not incurring fuel costs as it utilizes energy from water to run the turbine. For this reason, it is preferable to construct the MHP project and commence generation as quickly as possible. However, even in a short construction period the required safety conditions should be secured in terms of quality and performance.

In practice, the actual construction work is affected by not only natural conditions such as climate, hydrology, topography and geology; but also resource conditions such as laborers' performance, construction machinery arrangement and equipment procurement procedure.

It is therefore necessary to especially consider the following points for planning the construction schedule:

- ✓ Traffic conditions in each season including the presence of a detour,
- ✓ Difficulty of transportation of construction materials and equipment, and
- ✓ Effect of other conditions on the construction work, such as river discharge, rainfall pattern, etc.

A rough indication of preparation of a basic construction schedule is shown in the following table.

Table 5.2.8 Example of Construction Schedule

Item	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	
1. Preparation Works																			
Land acquisition and access road	■	■																	
2. Civil Works																			
1) Head works			■	■	■	■	■												
2) Power canal, head tank, spillway					■	■	■	■	■	■	■	■							
3) Penstock																			
Manufacturing and transportation						■	■	■	■	■	■								
Installation											■	■	■	■					
4) Powerhouse and tailrace																			
5) Miscellaneous Works			■	■	■	■	■	■	■	■	■	■	■	■	■	■	■	■	■
3. Electrical Works																			
1) Design and procurement		■	■	■	■														
2) Manufacturing and transportation					■	■	■	■	■	■	■	■							
3) Installation													■	■	■				
4. Distribution Works																			
1) Detailed site survey		■	■	■	■														
2) Design and procurement				■	■	■	■	■	■	■	■	■							
3) Installation																			■
5. Adjustment and Trial Operation																			■

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Table 12-10)" published by JICA in 2011.

(1) Rough Indication of Total Construction Period

1) Procurement

A series of procurement procedures such as construction announcement, contractor's estimation, evaluation of proposals and contractor selection generally requires more than six (6) months. However, preparation of tender documents such as technical specifications and drawings for procurement bid, and preparation of contracts are not included in the above period.

2) Contract Negotiation

In a case where negotiation with the first contractor failed, it will generally take around 1 month for the contract to be signed by one of the next negotiating contractors.

3) Construction Period at the Site

It generally takes around one year to one and a half years from the date of the contract to the date of completion or handover to the client. A construction schedule is different from a fund payment schedule, and these two schedules should be prepared separately.

(2) Civil Works

In the following items, preparation works and temporary works are usually difficult to implement simultaneously with other items.

The entire civil works generally takes around one year to one and a half years, comprised of:

- | | |
|------------------------------|---|
| i) Preparation works | 1 to 3 months |
| ii) Temporary works | About 1 month |
| iii) Access road | Depends on the site conditions |
| iv) Head works | Half a year to one year
(depends on the rainy season and flood conditions) |
| v) Power canal and head tank | Several months (depends on the length of headrace) |
| vi) Penstock | Several months to half a year
(manufacturing period should be considered separately) |
| vii) Powerhouse and tailrace | Several months to half a year |

(3) Electrical Works

In the case of a MHP project, the approximate periods outlined below are based on the premise that the turbine and generator are relatively ready-made. The entire period of construction for electrical equipment is approximately one year, in general.

i) Design for shop drawings and procurement of materials	Several months
ii) Manufacturing and transportation	Several months
iii) Erection of turbine and generator	2 to 3 months
iv) Trial operation	1 to 2 months

However, for installation work at the project site, it is necessary to adjust the schedule between civil works and distribution works. In addition, civil works and distribution works must be almost complete before electrical works for trial operation.

(4) Distribution Works

The construction period for distribution facilities depends on the distance of the line. In the case of an electrification scale of 500 to 1,000 households and a distance of 50 km for the electricity distribution line, for instance, distribution works generally take around 8 months to 1 year.

Items of distribution works are undertaken for the following periods:

i) Distribution line survey	Several weeks to one month
ii) Design for shop drawings and procurement of materials	2 to 3 months
iii) Manufacturing and transportation	1 to 2 months
iv) Construction of poles, distribution of electric wires and installation of watt-hour meters	Several months to half a year
v) Trial operation	1 to 2 months

5.3 Economic Evaluation

5.3.1 Economic Project Benefit

Economic analysis evaluates the economic viability of the project, taking into account the effects of the project on the national economy or society as a whole. In this sense, the economic benefit shall be estimated from the perspective of contribution to national income.

Past experiences indicate that when a non-electrified village is electrified, a number of productive opportunities are subsequently identified and initiated by village entrepreneurs. These activities undoubtedly increase the production level of the country, and contribute to economic benefits. They should therefore be added, whenever they are possible to identify.

In a broader perspective, socio-economic benefits of electricity include improved education (e.g. longer reading time), improved manageability of routine household tasks particularly for women, better entertainment and updated information, and improved health. These benefits are generally difficult to measure and quantify. However they can be referred to in the narrative section of economic analysis.

In practice, two methods are applied to estimate the MHP project's benefit from an economic perspective:

An Alternative Facility Cost Method

This method is often applied to estimate the benefits of medium to large hydropower projects. In this method, the benefit of a hydropower project is defined as the cost of the least-cost thermal plant alternative having comparable electric supply performance as the hydropower that would be saved by implementation. It shall be considered to save the cost of second best alternative under the fixed demand condition. Under this method, the capacity and energy values of hydropower are calculated.

Consumer's Willingness-to-pay (WTP) Method

This method is often applied for MHP projects. Economic benefits are calculated using consumer's average WTP for connection fee and for electricity tariff.

For example, when setting connection fee as US\$ 100, only households having more than US\$ 100 of WTP will apply for the service. WTP adopted for financial analysis is determined to satisfy WTP of 80% of households. Additionally, the financial benefits are computed based on the actual payments from consumers.

On the other hand, even households having US\$ 100 of WTP will pay US\$ 70. In this case, the remaining US\$ 30 is regarded as consumer surplus of the household. Economic benefit includes not only actual payment of US\$ 70 but also consumer surplus of US\$ 30.

These benefits in WTP method are calculated as per the following formula:

(1) Benefit from Grid Connection

$$B_{GC} = HH \times R_a \times WTP_{CF}$$

Where, B_{GC} : benefit from grid connection (currency unit)
 HH : number of total household (HH)
 R_a : Application ratio (%)
 WTP_{CG} : WTP for connection fee (currency unit/HH)

(2) Benefit from Electricity Consumption

$$B_{EC} = E \times R_L \times WTP_{ET}$$

Where, B_{EC} : benefit from electricity consumption (currency unit)
 E : generating energy (MWh/year)
 R_L : total loss ratio (%) = 10%
 WTP_{ET} : WTP for electricity tariff (currency unit/kWh)

Both WTP for connection fee and WTP for electricity tariff need to be defined based on the social economic survey.

5.3.2 Economic Project Cost

Economic costs need to be adjusted for market distortions caused by government intervention; import duties, sales tax, price control, and transfer payments (taxes and subsidies) for many cost items. They also have to be evaluated with the concept of the opportunity cost.

For economic evaluation, all costs involved in the project have to be measured as economic costs, i.e. the real costs incurred from the viewpoint of national economy. In other words, economic cost estimate is a modification of the project construction cost estimate reflecting an adjustment, to the local currency portion of the project cost from the national economic point of view.

The economic cost is measured as the value in case that resources employed to the project are used for other activities, known as the "shadow" price. The shadow price is represented as the value of the local component of the project cost which could be earned foreign exchange if sold abroad or as the value to the economy of local labourer drawn from another sector, primarily agriculture. Estimating the shadow prices for all the cost items is a difficult task, depending upon a myriad of assumptions about the nature of the labour pool drawn and the market conditions for each category of material. For the purposes of the pre-feasibility or feasibility estimate, a simplified procedure is adopted.

For instance, actual project costs consist of local currency portion and foreign currency portion.

$$(\text{Economic Project Cost}) = (\text{Local Currency Portion}) \times \text{SCF} + (\text{Foreign Currency Portion})$$

SCF is the standard conversion factor of internal transfer portion.

Economic project costs of MHP project are estimated by the following five groups.

(1) Construction Cost of MHP Station and Distribution System

Costs of civil works are assumed to be 100% of local portion, while costs of electrical equipments are assumed to be 100% of foreign portion. In calculating economic price, the foreign costs are valued at Cost, Insurance and Freight (CIF) price, and local costs (non-tradable costs) are converted into boarder price using the SCF.

(2) Installation Costs of House Wiring and Watt-hour Meter for each Customer,

House wiring cost (C_{HW}) is estimated by the following assumption;

$$C_{HW} = HH \times R_a \times C_{HWO}$$

Where, C_{HW} : house wiring cost (currency unit)
 HH : number of total household (HH)
 R_a : Application ratio (%)
 C_{HWO} : unit cost of house wiring & watt-hour meter (currency unit/HH)

Application ratio means the ration of household in the target area applying for electricity service. It will be defined based on the results of social economic survey.

(3) Operation and Maintenance Cost

Annual O&M costs are assumed to be 2.0% of capital costs (construction cost of MHP station and distribution system), which cover salary of staff, spare parts for routine maintenance, and consumables for operation.

(4) Replacement Costs of Electrical Equipment.

Rehabilitation is supposed to be executed 10 to 15 years after the completion. Rehabilitation costs and replacement cost of electrical equipment are assumed to be 20% of civil work cost and 90% of electrical equipment cost.

5.3.3 Example of Economic Evaluation

Economic viability of the project is usually assessed in terms of the economic internal rate of return (EIRR) and the net present value (NPV) by use of the estimated economic project benefits and costs. It has been standard practice for major donors to use EIRR for evaluation of economic viability of projects:

- i) Project with an EIRR of at least 12% can be considered acceptable.
- ii) Projects with an EIRR between 10 and 12% may be accepted if additional unvalued (unquantifiable) benefits are sufficiently demonstrated.
- iii) Projects with an EIRR below 10% are not accepted.

An example of economic evaluation is shown below. In this case, EIRR of the project exceeds 12%. Accordingly, the project is confirmed to be economically viability.

Table 5.3.1 Example of Economic Evaluation

COST							
<u>Construction Cost</u>							
	Civil Works		Electrical Equipment		Distribution Facilities		Total
1st year	346,717	40%	29,865	15%	260,988	50%	637,570 (USD)
2nd year	520,075	60%	169,234	85%	260,988	50%	950,297 (USD)
Total	866,792	100%	199,099	100%	521,976	100%	1,587,867 (USD)
<u>Economic Cost</u>							
	Civil		Electrical		Distribution		Total
SCF	90%		100%		95%		
1st year	312,045	40%	29,865	15%	247,939	50%	589,849 (USD)
2nd year	468,068	60%	169,234	85%	247,939	50%	885,242 (USD)
Total	780,113	100%	199,099	100%	495,877	100%	1,475,091 (USD)
<u>Repairing & Replacement Cost</u>		20% of the civil works				156,023 (USD)	
		90% of the electrical equipment				179,189 (USD)	
				Total		335,212 (USD)	
<u>Annual O&M Cost</u>		2% of the construction cost.				31,757 (USD/year)	
<u>House Wiring Cost</u>		Number of total household				1,549 (HH)	
		Application ratio				80%	
		Number of connection household				1,239 (HH)	
		House wiring & watt-hour meter cost				60.0 (USD/HH)	
						74,340 (USD)	
BENEFIT							
<u>Annual Available Energy</u>							
Annual generating energy		1,148 (MWh/year)		Load factor		50%	
Total Loss Ratio		10%		WTP for onnection fee		97.74 (USD/HH)	
Annual available energy		1,033 (MWh/year)		WTP for tariff		27.32 (USC/kWh)	

CASH FLOW

Year	Cost				Energy				Benefit			B-C
	Capital Cost (USD)	House Wiring (USD)	O&M (USD)	Cost Total (USD)	Abailable Energy (MWh)	Peak Demand (W/HH)	Energy Demand (MWh)	Sold Energy (MWh)	Electricity Tariff (USD)	Connection Charge (USD)	Benefit Total (USD)	
0	589,849			589,849							0	-589,849
1	885,242	74,340	31,757	991,339	1,033	90	488	488	133,435	121,100	254,535	-736,805
2			31,757	31,757	1,033	106	575	575	157,156		157,156	125,399
3			31,757	31,757	1,033	122	662	662	180,878		180,878	149,121
4			31,757	31,757	1,033	139	754	754	206,082		206,082	174,325
5			31,757	31,757	1,033	155	841	841	229,804		229,804	198,047
6			31,757	31,757	1,033	171	928	928	253,526		253,526	221,768
7			31,757	31,757	1,033	187	1,015	1,015	277,248		277,248	245,490
8			31,757	31,757	1,033	196	1,064	1,033	282,221		282,221	250,464
9			31,757	31,757	1,033	205	1,112	1,033	282,221		282,221	250,464
10			31,757	31,757	1,033	214	1,161	1,033	282,221		282,221	250,464
11			31,757	31,757	1,033	223	1,210	1,033	282,221		282,221	250,464
12			31,757	31,757	1,033	232	1,259	1,033	282,221		282,221	250,464
13			31,757	31,757	1,033	241	1,308	1,033	282,221		282,221	250,464
14			31,757	31,757	1,033	250	1,357	1,033	282,221		282,221	250,464
15	335,212		31,757	366,969	1,033	259	1,406	1,033	282,221		282,221	-84,748
16			31,757	31,757	1,033	268	1,454	1,033	282,221		282,221	250,464
17			31,757	31,757	1,033	277	1,503	1,033	282,221		282,221	250,464
18			31,757	31,757	1,033	286	1,552	1,033	282,221		282,221	250,464
19			31,757	31,757	1,033	295	1,601	1,033	282,221		282,221	250,464
20			31,757	31,757	1,033	304	1,650	1,033	282,221		282,221	250,464

Present Value		
Cost	Benefit	NPV
1,754,491	4,752,821	2,998,329

B/C Ratio	EIRR
2.709	12.80%

Discount ratio 10%

5.4 Financial Evaluation

5.4.1 Financial Project Benefit

Benefits of the off-grid type projects are determined as the total expected revenue from sales of energy and revenue from connection fees as follows:

- (1) Revenue from Connection Fee

$$B_{CF} = HH \times R_a \times CF$$

Where, B_{CF} : benefit from connection fee (currency unit)
 HH : number of total household (HH)
 R_a : Application ratio (%)
 CF : connection fee (currency unit/HH)

- (2) Revenue from Electricity Tariff

$$B_{ET} = E \times R_L \times ET$$

Where, B_{ET} : benefit from electricity tariff (currency unit)
 E : generating energy (MWh/year)
 R_L : total loss ratio (%) = 10%
 WTP_{ET} : electricity tariff (currency unit/kWh)

5.4.2 Financial Project Cost

MHP project is a risk because most of the cost must be met at the start of the project. The investor (a private individual, prospective owner, funding agency, or rural development bank) will need to be convinced that such a major investment is safe. It is necessary to convince the investor that the project will produce financially viable results, and it is necessary to identify which proposed schemes are likely to fail and warn the investor of the poor financial potential.

Financial costs shall be estimated based on the current price level. Price escalation shall be taken into account applying annual inflation rates. The O&M cost also shall be inflated to the current price level.

- (1) Construction Cost of MHP Station and Distribution System

The estimated construction costs are directly considered as the financial cost of construction costs.

- (2) Installation Costs of House Wiring and Watt-hour Meter for each Customer,

It is assumed in a manner similar to the economic evaluation.

- (3) Operation and Maintenance Cost

It is assumed in a manner similar to the economic evaluation.

- (4) Replacement Costs of Electrical Equipment.

It is assumed in a manner similar to the economic evaluation.

5.4.3 Example of Financial Evaluation

Financial analysis examines the profitability of project to the operating entity. Financial viability of the project is usually assessed in terms of the financial internal rate of return (FIRR), the net present value (NPV) and benefit-cost ratio (B/C) by use of the estimated project cost and revenue.

An example of financial evaluation is shown below. In this case, all the financial indicators show very bad performance, and accordingly the project are judged to be financially not viable.

Table 5.4.1 Example of Financial Evaluation

COST		Construction Cost							
		Civil Works		Electrical Equipment		Distribution Facilities		Total	
1st year	346,717	40%	29,865	15%	260,988	50%	637,570 (USD)		
2nd year	520,075	60%	169,234	85%	260,988	50%	950,297 (USD)		
Total	866,792	100%	199,099	100%	521,976	100%	1,587,867 (USD)		
<u>Repairing & Replacement Cost</u>		20% of the civil works				173,358 (USD)			
		90% of the electrical equipment				179,189 (USD)			
						Total		352,548 (USD)	
<u>Annual O&M Cost</u>		2% of the construction cost.				31,757 (USD/year)			
<u>House Wiring Cost</u>		Number of total household				1,549 (HH)			
		Application ratio				80%			
		Number of connection household				1,239 (HH)			
		House wiring & watt-hour meter cost				60.0 (USD/HH)			
						74,340 (USD)			
BENEFIT		<u>Annual Available Energy</u>		1,148 (MWh/year)		Load factor		50%	
		Total Loss Ratio		10%		Connection fee		62.1 (USD/HH)	
		Annual available energy		1,033 (MWh/year)		Electricity Tariff		9.01 (USC/kWh)	

CASH FLOW

Year	Cost				Energy				Benefit			B-C
	Capital Cost (USD)	House Wiring (USD)	O&M (USD)	Cost Total (USD)	Available Energy (MWh)	Peak Demand (W/HH)	Energy Demand (MWh)	Sold Energy (MWh)	Electricity Tariff (USD)	Connection Charge (USD)	Benefit Total (USD)	
0	637,570			637,570							0	-637,570
1	950,297	74,340	31,757	1,056,395	1,033	90	488	488	44,006	76,942	120,948	-935,447
2			31,757	31,757	1,033	106	575	575	51,829		51,829	20,072
3			31,757	31,757	1,033	122	662	662	59,653		59,653	27,895
4			31,757	31,757	1,033	139	754	754	67,965		67,965	36,208
5			31,757	31,757	1,033	155	841	841	75,788		75,788	44,031
6			31,757	31,757	1,033	171	928	928	83,612		83,612	51,854
7			31,757	31,757	1,033	187	1,015	1,015	91,435		91,435	59,678
8			31,757	31,757	1,033	196	1,064	1,033	93,075		93,075	61,318
9			31,757	31,757	1,033	205	1,112	1,033	93,075		93,075	61,318
10			31,757	31,757	1,033	214	1,161	1,033	93,075		93,075	61,318
11			31,757	31,757	1,033	223	1,210	1,033	93,075		93,075	61,318
12			31,757	31,757	1,033	232	1,259	1,033	93,075		93,075	61,318
13			31,757	31,757	1,033	241	1,308	1,033	93,075		93,075	61,318
14			31,757	31,757	1,033	250	1,357	1,033	93,075		93,075	61,318
15	352,548		31,757	384,305	1,033	259	1,406	1,033	93,075		93,075	-291,230
16			31,757	31,757	1,033	268	1,454	1,033	93,075		93,075	61,318
17			31,757	31,757	1,033	277	1,503	1,033	93,075		93,075	61,318
18			31,757	31,757	1,033	286	1,552	1,033	93,075		93,075	61,318
19			31,757	31,757	1,033	295	1,601	1,033	93,075		93,075	61,318
20			31,757	31,757	1,033	304	1,650	1,033	93,075		93,075	61,318

Present Value		
Cost	Benefit	NPV
1,829,392	1,601,096	-228,296

Discount ratio 10%

B/C Ratio	FIRR
0.875	-7.27%

CHAPTER 6 ENVIRONMENTAL AND SOCIAL CONSIDERATIONS

6.1 Environmental Management System in Kenya

6.1.1 National Environmental Management Authority (NEMA)

The National Environment Management Authority (NEMA) is the government institution responsible for implementing environment policies, reviewing “EIA Project Reports” and “EIA Study Reports” and issuing environment licenses for development projects in Kenya.

NEMA’s organizational structure is headed by the Board of Management and Director General. The Authority has further established six departments and one sub-department; among which the following have functions in activities related to EIA: (Source, National Environment Management Authority Strategic Plan 2008-2012, June 2009, NEMA)

- ✓ The Director General appoints members of Environmental Impact Assessment Technical Advisory Committee (EIA-TAC) and prescribes the terms of reference and rules of procedure for the review of EIA related reports received by NEMA.
- ✓ The Compliance and Enforcement Department identifies projects and programmes or types of projects and programmes, and plans and policies for which environmental audits (EA) or environmental monitoring must be conducted under the Act, and ensures that EIAs and EAs are conducted.

6.1.2 Environmental Management System at County Level

(1) Decentralization and Administrative Structure Reform (Transitional Period)

Since the new Kenyan Constitution came into force in 2010, decentralization, administrative structure reform and regulatory revisions for “County System” in place of former “Province and District System” have started.

- ✓ As a matter of fact, NEMA issued a public notice with regard to the decentralization of its EIA functions to the county since 1st of July 2012 (See Figure 6.1.1).

As far as reforms of environmental management and EIA review procedures are concerned, the reform processes are in a transition period since January 2014.

- ✓ Due to the fact that the environmental management and EIA procedural reforms have not adequately come into effect in order to conform to the new constitutional dispensation especially on administrative units, the provisions of the current EMCA 1999 and EIA/EA Regulations (Amendment) 2009 are still in force until such a time as they will be reviewed. However, NEMA through an administrative procedure, has done away with District and Provincial offices and effectively replaced them with County offices.
- ✓ The transition period therefore means that the former systems (especially where the relevant laws are concerned) are still in operation alongside the current administrative re-alignment. Therefore, the former local systems of “Provincial Environmental Committee” as well as “District Environmental Committee” are envisaged to be reviewed.

(2) Provincial Environmental Committee (PEC) & District Environmental Committee (DEC)

According to the current EMCA 1999 and EIA/EA Regulations (Amendment) 2009, NEMA operates at provincial and district levels. Namely the Provincial Environmental Committees (PECs) and District Environmental Committees (DECs) are a primary mechanism for NEMA to undertake its functions, which will be altered to County Environmental Committees in order to conform to the new administrative structure of County system.



nema
NATIONAL ENVIRONMENT MANAGEMENT AUTHORITY

PUBLIC NOTICE

DECENTRALIZATION OF NEMA FUNCTIONS AND SERVICES

The National Environment Management Authority (NEMA), effective 1st July 2012 implemented a decentralization programme to counties. This is in adherence to the Constitution of Kenya 2010 provisions for government agencies to devolve their operations and functions to counties to ensure efficient provision of their services. The decentralization will in particular address processing of Environmental Impact Assessment, Environmental Audit, Noise and Excessive Vibration Control and transportation of waste (garbage and sewage) licences.

SPECIFIC CRITERIA FOR DECENTRALIZATION

A. Low impact Environmental Impact Assessment (EIA) projects

The EIA for the following low impact projects shall be submitted and processed at respective offices of the County Director of Environment:

1. Residential houses (bungalows, maisonettes, flats) in zoned area (of not more than 30 units)
2. Commercial buildings (of not more than 10 storey's) in zoned areas
3. Go-downs for storage of goods only in zoned areas
4. Community based and/or constituency development Fund (CDF) projects such as:
 - i. Water projects, boreholes and water pans
 - ii. Roads (small feeder roads) and bridges
 - iii. Markets
 - iv. Cattle dips
5. Cottage industry/jua kali sector/garages
6. Car and bus parks
7. Restaurants (excluding tourism facilities in or surrounding National parks and game reserves).
8. Expansion of existing facilities for same use especially socially uplifting projects (SUPs) such as schools and dispensaries
9. Afforestation/re-afforestation programmes
10. Sand harvesting, quarrying and brick making
11. Slaughter houses (handling not more than 15 animals a day)
12. Construction of churches and mosques
13. Timber harvesting

B. Medium and low risk Environmental Audit (EA) reports

Medium and low impact project audits will be processed at respective offices of County Directors of Environment. These include:

1. Animal feed milling
2. Apartments
3. Colleges
4. Campsites
5. Metal welding
6. Restaurants
7. Schools
8. Tea farms
9. Transport Companies
10. Timber Products
11. Warehouses
12. Stadiums

C. High impact/risk projects will be processed at NEMA headquarters

All high impact/risk projects will be processed at NEMA headquarters. These include:

1. Asbestos manufacturing /based industries
2. Battery recycling
3. Airports
4. Airports hangars
5. Base transceiver stations(BTS)
6. Cement factories
7. Chemical factories
8. Distilling and blending spirits
9. Geothermal plants
10. Hydroelectric power generation plants
11. Incinerators
12. Landfills
13. Large scale irrigated agriculture farming (exceeding 50ha)
14. Molasses plants
15. Petroleum refining
16. Paper mills
17. Vegetable oil refineries
18. Steel mills
19. Sewerage works
20. Thermal power generation
21. Tanneries
22. Tourist facilities in protected areas
23. Wood preservation

N.B. All other facilities/projects not included in the high risk category list shall be submitted and processed at the respective offices of the County Director of Environment.

D. Noise and excessive vibration control licensing

Noise and excessive vibration control licences and permits shall be issued at the county level for one off activities, where noise emitted is expected to go beyond maximum permissible noise levels. Such one off activities include: weddings and birthday parties, road shows, ceremonies, parties, religious festivals, mobile cinemas among others. The licence is valid for a maximum of seven days and costs KShs 2,200.

Permits will be issued for the following one off activities: demolition activities, construction sites, fireworks, mines and quarries, firing ranges, specific heavy duty industry. The permit shall be valid for a period of up to three months and costs KShs 5,500

Commercial activities, discos/ live bands/ pubs, entertainment joints, places of worship among others, shall not be licenced as they are required to sound proof their premises to keep their noise to within permissible noise levels.

E. Waste transportation licensing

Licenses to transport garbage and sewage waste shall be issued at the county level. All the other categories of waste management license applications will continue to be received at county level. These will be forwarded to NEMA Headquarters for processing.

Office contacts of respective County Directors of Environment (CDE) can be found on the NEMA website at www.nema.go.ke.

For further information, please contact:

PROF. GEOFFREY WAHUNGU
DIRECTOR GENERAL
NEMA
Popo road, off Mombasa Road
P.O. Box 67839- 00200, Nairobi, Kenya
Tel: (254 020) 6006522, 020 2101370, 0724 263398, 0735 010237
Fax (254 020) 6008997

Email: dg@nema.go.ke Website: www.nema.go.ke
Face book: National Environment Management Authority
Report any environmental related corruption to: anticorruption@nema.go.ke

Source: a Clip DAILY NATION, Monday July 9, 2012.

Figure 6.1.1 Public Notice on Decentralization of NEMA Functions and Services

6.2 EIA Procedures and Licensing System in Kenya

6.2.1 Projects Sectors Subject to EIA

Project Sectors subject to EIA procedures in Kenya are specified in the Environmental Management and Coordination Act of 1999 (EMCA) as “Second Schedule” as shown in Table 6.2.1.

Table 6.2.1 “Second Schedule” Specified in EMCA (Project Sectors Subject to EIA)

Sector	Including	
General	· An activity out of character with its surrounding, any structure of a scale not in keeping with its surroundings	· Major changes in land use
Urban development	· Designation of new townships · Establishment of industrial estates · Establishment or expansion of recreational areas	· Establishment or expansion of recreational townships in mountain areas, national parks and game reserves · Shopping centers and complexes
Transportation	· All major roads · All roads in scenic, wooded or mountainous areas and wetlands, Railway lines	· Airports and airfields · Oil and gas pipelines · Water transport
Dams, rivers and water resources	· Storage dams, barrages and piers · River diversions and water transfer between catchments	· Flood control schemes · Drilling for the purpose of utilizing ground water resources including geothermal energy
Aerial spraying	-	-
Mining	· Quarrying and open cast extraction of · Precious metal, Gemstones, Metalliferous ores, Coal, Phosphates, Limestone and dolomite	· Stone and slate · Aggregates, sand and gravel, Clay, Exploration for the production of petroleum in any form, Extracting alluvial gold with use of mercury
Forestry related activities	· Timber harvesting · Clearance of forest areas	· Reforestation and afforestation
Agriculture	· Large scale agriculture · Use of pesticide · Introduction of new crops and animals	· Use of fertilizers · Irrigation
Processing and manufacturing industries	· Mineral processing, reduction of ores and minerals · Smelting and refining of ores and minerals · Foundries · Brick and earth wear manufacture · Cement works and lime processing · Glass works · Fertilizer manufacture or processing · Explosive plants · Oil refineries and petrochemical works · Tanning and dressing of hides and skins · Abattoirs and meat processing plants · Chemical works and processing plants · Brewing and malting	· Bulk grain processing plants · Fish processing plants · Pulp and paper mills · Food processing plants · Plants for manufacture or assembly of motor vehicles · Plant for the construction or repair of aircraft or railway equipment · Plants for the manufacture or assembly of motor vehicles · Plants for the manufacture of tanks, reservoirs and sheet metal containers · Plants for manufacture of coal briquettes · Plants for manufacturing batteries
Electrical infrastructure	· Electrical generation stations · Electrical transmission lines	· Electrical sub-stations · Pumped storage schemes
Management of hydrocarbons	· Storage of natural gas and combustible or explosive fuels	
Waste disposal	· Sites for solid waste disposal · Sites for hazardous waste disposal · Sewage disposal works	· Works involving major atmospheric emissions · Works emitting offensive odours
Natural conservation areas	· Creation of national parks, game reserves and buffer zones · Establishment of wilderness areas · Formulation or modification of forest management policies · Formulation of modification of water catchment management policies	· Policies for the management of ecosystems especially by use of fire · Commercial exploitation of natural fauna and flora · Introduction of alien species of fauna and flora · Introduction of alien species of fauna and flora into ecosystems
Nuclear reactors	-	-
Major development in biotechnology	· Introduction and testing of genetically modified organisms	

Source: Environmental Management and Coordination Act of 1999 (EMCA)

However, “Second Schedule” does not specify the scale and size of each project. Specifically, without reference to scale or size, any project falling under the Second Schedule shall go through the EIA procedures.

(1) Renewable Energy Projects and Necessity of EIA

Renewable energy projects (PV, MHP, Biogas and Wind power systems) fall under “No. 10 Electrical Infrastructure” in the “Second Schedule” of EMCA. Therefore, all renewable energy projects are naturally subject to the EIA procedures.

(2) Draft NEMA EIA Guidelines and Administration Procedures

In addition, NEMA developed Draft EIA Guidelines and Administration Procedures in November 2002 in response to the National Policy on Environment and EMCA 1999. The NEMA Draft EIA Guidelines provide procedural guidelines for:

- ✓ Implementation of EIA,
- ✓ Monitoring and Environmental Audit (EA),
- ✓ Strategic Environmental Assessment (SEA),
- ✓ Issues of Trans-boundary, Regional and International Conventions, Treaties and Agreements,
- ✓ Steps in EIA studies and Environmental Audits,
- ✓ The contents and format of the study reports to be submitted to NEMA,
- ✓ The EIA study review process and decision-making, and
- ✓ Others.

CHAPTER 7 of the NEMA Draft EIA Guidelines mentions that Lead agencies are mandated by section 58 of the EMCA 1999, in consultation with the Authority, to develop EIA Guidelines to ensure that environmental concerns are integrated into sector development policies, plans, projects or programmes. The sector guidelines shall focus on specific mandates in line with the statutory relationships with the administration of the EIA process.

- ✓ However, such sector guidelines have not been developed by relevant lead agencies with the exception of the petroleum sector (Source, A meeting with NEMA headquarters).
- ✓ In addition, the Draft Guidelines are rendered rather conceptual. Practically, the processes of EIA and licensing shall refer to EIA/EA Regulations (Amendment) 2009.

6.2.2 EIA Review Process and Licensing


The Environmental Management and Coordination Act of 1999 (EMCA) and EIA/EA Regulations (Amendment) 2009 specify that the EIA Review process consists of the following two steps.

- ✓ EIA “Project Report” Process
- ✓ EIA “Study Report” Process

(1) Overview of the EIA Process

Based on EMCA 1999, EIA/EA Regulations (Amendment) 2009 and discussions with NEMA officials; and considering the decentralization of NEMA’s functions to the County level, Kenya’s EIA procedures can be comprehensively depicted as shown in Figure 6.2.1

Detailed procedures for “EIA Project Report” and “EIA Study Report” will appear afterward (See Figure 6.2.2 and Figure 6.2.3).



Note: *According to NEMA, "days" in the procedures stands for "Working days"

*** According to NEMA, not "within forty-five days" but "Minimum forty-five days" for the EIA Project Report Review and Licensing period

*** According to NEMA, not "within 90 days" but "Minimum 90 Working days" for the EIA Project Report Review and Licensing period

Source: NEMA, (modified by the JET based on discussions with NEMA Headquarters officials)

Figure 6.2.1 Overview of the EIA Process

(2) EIA "Project Report"

According to EMCA 1999, EIA/EA Regulation (Amendment) 2009 and discussions with NEMA officials; and considering the decentralization of NEMA's functions to the County level, the EIA "Project Report" Process can be summarized as follows and depicted in Figure 6.2.2.

- ✓ The process starts by a project proponent, selecting a consultant who must be licensed and registered with NEMA as a Lead Expert on EIA/EA

- ✓ An EIA “Project Report” shall be prepared by the consultant (Registered Lead Expert on EIA/EA). The following shows contents to be stated in the “Project Report”.


Table 6.2.2 Contents of the Project Report

<ul style="list-style-type: none"> · Nature of the project, · Location of the project including the physical area that may be affected by the project's activities, · Activities that shall be undertaken during the project construction, operation and decommissioning phases, · Design of the project, · Materials to be used, products and by-products, including waste to be generated by the project and the methods of their disposal, · Potential environmental impacts of the project and the mitigation measures to be taken during and after implementation of the project, 	<ul style="list-style-type: none"> · Action plan for the prevention and management of possible accidents during the project cycle, · Plan to ensure the health and safety of the workers and neighbouring communities, · Economic and socio-cultural impacts to the local community and the nation in general · Project budget, and · Any other information the Authority may require.
--	---

Prepared by JET

- ✓ The proponent shall submit at least ten copies and one soft copy (CD-ROM) of the EIA “Project Report” to the Authority (NEMA headquarters or its County Office(s)) accompanied by the prescribed fees of 0.05% of the project cost. (50% of the 0.05 of the project cost paid at the time of submission of the EIA “Project Report” and the remainder of 50% paid at the time of collection of license)
- ✓ The Authority shall **within seven (7) days** upon receipt of the project report, where the “Project Report” conforms to the requirements of regulation, distribute a copy of the “Project Report” to Relevant Lead Agencies and Relevant District Environment Committee(s) (DEC(s)) for their review and written comments.
- ✓ The comments of Lead Agencies and DEC(s) shall be submitted to the Authority *within twenty one (21) days* from the date of receipt of the “Project Report” from the Authority, or such other period as the Authority may prescribe.
- ✓ On receipt of the comments or where no comments have been received **by the end of the period of thirty (30) days** from the date of receipt of the “Project Report”, the Authority shall proceed to determine the project report.
- ✓ On determination of the “Project Report”, the decision of the Authority, and the reasons thereof, shall be communicated to the proponent **within forty-five (45) days**¹ of the submission of the “Project Report”.
- ✓ Where the Authority is satisfied that the project will have no significant impact on the environment, or that the project report discloses sufficient mitigation measures, the Authority may issue a license.
- ✓ If the Authority finds that the project will have significant impact on the environment, and the project report discloses no sufficient mitigation measures, the Authority shall require that the proponent undertake an EIA study.
- ✓ A proponent who is dissatisfied with the Authority's decision that an environmental impact assessment study is required, may **within fourteen (14) days** of the Authority's decision, appeal against the decision to the Tribunal.

¹ According to NEMA, EIA Project Report Review and Licensing period is not “within forty-five days” but “Minimum forty-five days”.



Note: *According to NEMA, "days" in the procedures stands for "Working days"

*** According to NEMA, not "within forty-five days" but "Minimum forty-five days" for the EIA Project Report Review and Licensing period

**** 50% of the 0.05 of the project cost paid at the time of submission of the EIA Project Report and the remainder of 50% paid at the time of collection of license

Source: Prepared by the JET referring to the EIA/EA Regulations (Amendment) 2009 and based on discussions with NEMA headquarters

Figure 6.2.2 EIA Project Report Review Process and Duration

(3) EIA "Study Report"

According to EMCA 1999, EIA/EA Regulation (Amendment) 2009 and discussions with NEMA officials; and considering the decentralization of NEMA's functions to the County level, the EIA "Study Report" Process can be summarized as follows and depicted in Figure 6.2.3.

- ✓ An EIA study shall be conducted in accordance with Terms of Reference (ToR) to be developed during the "Scoping" exercise. The ToR shall subsequently be submitted to be approved **within seven (7) days** by the Authority, Every EIA study shall be carried out by an EIA/EA Lead Expert


- ✓ During the process of conducting an EIA study, the proponent shall in consultation with the Authority, seek the views of persons who may be affected by the project.
- ✓ Specifically, holding at least three public meetings with the affected parties and communities to explain the project and its effects, and to receive their oral or written comments
- ✓ A proponent shall submit to the Authority, environmental contents of EIA “Study Report” incorporating but not limited to the following information:

Table 6.2.3 Contents of the Study Report

<ul style="list-style-type: none"> · Proposed location of the project, · Concise description of the national environmental legislative and regulatory framework, baseline information, · Any other relevant information related to the project, the objectives of the project, · Technology, procedures and processes to be used, in the implementation of the project, · Materials to be used in the construction and implementation of the project, · Products, by-products and waste generated project, · Description of the potentially affected environment, · Environmental effects of the project including the social and cultural effects and the direct, indirect, cumulative, irreversible, short term and long-term effects anticipated, · Alternative technologies and processes available and reasons for preferring the chosen technology and processes, · Analysis of alternatives including project site, design and technologies and reasons for preferring the proposed site, design and technologies, 	<ul style="list-style-type: none"> · Environmental management plan proposing the measures for eliminating, minimizing or mitigating adverse impacts on the environment, including the cost, time frame and responsibility to implement the measures, · Provision of an action plan for the prevention and management of foreseeable accidents and hazardous activities in the cause of carrying out activities or major industrial and other development projects, · Measures to prevent health hazards and to ensure security in the working environment for the employees and for the management of emergencies, · Identification of gaps in knowledge and uncertainties which were encountered in compiling the information, · Economic and social analysis of the project, · Indication of whether the environment of any other state is likely to be affected and the available alternatives and mitigating measures, and · Such other matters as the Authority may require.
---	--

Prepared by JET

- ✓ EIA “Study Report” shall be accompanied by a non-technical summary outlining the key findings, conclusions and recommendations of the study, Proponent shall submit ten copies and a soft copy (CD-ROM) of an EIA “Study Report” to the Authority
- ✓ The Authority shall **within fourteen (14) days** of the receipt of the EIA “Study Report” submit a copy of the report to any Relevant Lead agencies as well as District Environmental Committee(s) (DEC(s)) for their comments.
- ✓ Upon receiving the EIA “Study Report”, the lead agencies and DEC(s) shall review the report and shall thereafter send their comments on the “Study Report” to the Authority **within thirty (30) days** or such extended period as the Authority may specify.
- ✓ The Authority shall **within fourteen (14) days** of receiving the EIA “Study Report”, invite the public to make oral or written comments on the report, at the expense of the proponent.
- ✓ Upon receipt of these comments, the Authority may hold a public hearing
- ✓ The Authority shall give its decision on EIA “Study Report” **within three (3) months** of receiving an EIA “Study Report”
- ✓ Where the Authority approves an EIA “Study Report” , it shall issue an EIA license on terms and conditions as it may deem necessary
- ✓ A person who is aggrieved by the decision may appeal to the Tribunal against the decision.



Note: *According to NEMA, "days" in the procedures stands for "Working days"

**According to NEMA, not "within 90 days" but "Minimum 90 Working days" for the EIA Project Report Review and Licensing period

*** 50% of the 0.05 of the project cost paid at the time of submission of the EIA Project Report and the remainder of 50% paid at the time of collection of license

Source: Prepared by the JET referring to the EIA/EA Regulations (Amendment) 2009 and based on discussions with NEMA

Figure 6.2.3 EIA Study Report Review Process and Duration

(4) Public Comments and Public Hearing in the EIA Study Report Process

Table 6.2.4 shows differences between “Public Comments” and “Public Hearing” in the course of the EIA Study Report Process. Both public comments and public hearing are means of public consultation.


Table 6.2.4 Public Comments and Public Hearing in EIA Study Report Process

Public Comments	Public Hearing
- Invitation is done both at the time of conducting EIA and after submission of Study report.	- Conducted only after submission of the EIA study report at NEMA offices
- Invitation of public comments must be done as follows. - At least three public meetings for comments must be done by the EIA consultant in the course of the study. - One public comments window after submission of EIA study report at NEMA office.	- Public hearing done only once after submission of EIA study report.
- Comments are received both by EIA consultant and NEMA.	- Sessions for public hearing only organized by NEMA and the report of the public hearing only prepared by the presiding NEMA official.
- Invitation for public comments is mandatory as per the regulations.	- Conducting public hearing sessions is at the discretion of NEMA based on the nature of the proposed study and adequacy of the study report.

Prepared by JET

(5) Possible Schedule of EIA Review Process and Licensing for Renewable Energy Projects

In accordance with the EIA processes noted above, a possible schedule of EIA review and licensing for renewable energy projects can be depicted as a bar-chart as shown in Figure 6.2.4.



Prepared by JET

Figure 6.2.4 Possible Schedule for EIA/Environmental Licenses

(6) Revision of EMCA and EIA/EA Regulation in 2014

In light of the new constitution enacted in 2010, the relevant laws and regulations, especially EMCA 1999 and the EIA/EA regulations 2009 are being reviewed (as of January 2014) to conform to the expectations of the new constitution. Therefore, revised EMCA and EIA/EA regulations may apply to relevant projects after 2014. For more details on any revisions, contact NEMA.

6.3 Specific Subject (Solid Waste Management)

Solid waste management issues shall be addressed in compliance with the following laws and regulations in Kenya.

- ✓ Environmental Management and Coordination Act of 1999 (EMCA)
- ✓ Environmental Management and Coordination (Waste Management) Regulations 2006
- ✓ Guidelines for E-Waste Management in Kenya 2010
- ✓ Others (if any)

6.3.1 Construction Stage

All trash and packaging materials which might result from the construction process will be collected by the contractor(s) for adequate disposal, which shall be one of the prerequisites for the contract(s) for the contractor(s) to be employed. In this regard, the solid waste management during construction stage can be secured as follows.

- ✓ REA is required to instruct contractor(s) to ensure such solid waste management.

6.3.2 Operation Stage

Replacement of used batteries, fluorescent tubes and other electrical appliances shall be managed by each project facility. REA is required to have discussions with each facility, and/or initiate stakeholder meetings in each site to discuss and find solutions for management of such solid waste as follows.

(1) E-waste

The issues of “e-waste management” are prominent. Especially, e-waste components like used batteries, used fluorescent lamps and other used electrical appliances including solar PV panels, inverters and etc. are the core issues as summarized in Table 6.3.1.

Table 6.3.1 E-waste Components in Renewable Energy Projects

E-waste	Hazardous Element
Used Lead-acid batteries	Lead and Sulfuric Acid
Used Fluorescent tubes	Mercury
Used PV panels, Inverters and other appliances	Other heavy metals

Prepared by JET

(2) Hazardous and Non-Hazardous Elements

Hazardous elements and Non-Hazardous Elements in Table 6.3.1 are regulated by EMCA, especially by the Guidelines for E-Waste Management in Kenya (See Table 6.3.2 and Table 6.3.3).

Table 6.3.2 Hazardous Elements in Electrical and Electronic Equipment

Element	For example found in electrical and electronic equipment such as:
Americium	Smoke alarms (radioactive source).
Mercury	Fluorescent tubes (numerous applications); tilt switches (pinball games, mechanical doorbells, thermostats)
Sulfur	Lead-acid batteries
PCBs	Prior to ban, almost all 1930s-1970s equipment, including capacitors, transformers, wiring insulation, paints, inks and flexible sealants used PCBs.
Cadmium	Light-sensitive resistors, corrosion-resistant alloys for marine and aviation environments and nickel-cadmium batteries.
Lead	Old solder, CRT monitor glass, lead-acid batteries and formulations of PVC.
Beryllium oxide	Filler in some thermal interface materials such as thermal grease used on heat sinks of CPUs and power transistors, magnetrons, X-ray-transparent ceramic windows, heat transfer fins in vacuum tubes, and gas lasers.
Polyvinyl chloride	PVC contains additional chemicals to change the chemical consistency of the product. Some of these additives can leach out of vinyl products e.g. plasticizers that are added to make PVC flexible.

Source: Guidelines for E-Waste Management in Kenya, December 2010, NEMA

Table 6.3.3 Non Hazardous Elements in Electrical and Electronic Equipment

Element	For example found in electrical and electronic equipment such as:
Tin	Solder, coatings on component leads.
Copper	Copper wire, printed circuit board tracks, component leads.
Aluminum	Nearly all electronic goods using more than a few watts of power, including electrolytic capacitors.
Iron	Steel chassis, cases, and fixings.
Germanium	1950s-1960s transistorized electronics (bipolar junction transistors).
Silicon	Glass, transistor, ICs, printed circuit boards.
Nickel	Nickel-cadmium batteries.
Lithium	Lithium-ion batteries.
Zinc	Plating for steel parts.
Gold	Connector plating, primarily in computer equipment.

Source: Guidelines for E-Waste Management in Kenya, December 2010, NEMA

Possibility of “hazard to health and environment” caused by the hazardous elements shown in Table 6.3.2, is one of the reasons for the necessity of e-waste management.

(3) Handling Procedure of E-waste

Unlike domestic waste which is generated daily, e-waste is generated after the life span of each component of the project facilities has finished.

Specifically, the life span of batteries and fluorescent lamps are about two to several years, while that of electrical appliances including solar PV panels, inverters, etc. are up to 0-25 years for which disposals shall be handled as summarized in Table 6.3.4.

Table 6.3.4 Handling Procedure of E-waste

Component	Possible Life Span* (years)	Handling	Remarks
Battery	3 to 8	<ul style="list-style-type: none"> - In order to prevent diffusion of toxic substances in batteries, used ones shall safely be kept without damage (Do not Crash! Do not Take Apart!) until properly disposed. - Used batteries can be sold to licensed e-waste handlers and/or battery producing companies in Kenya. 	<ul style="list-style-type: none"> - Licensed e-waste handlers (See Table 6.3.5) or contact each NEMA county office to get updated information on such handlers. - Battery Producing Companies (See Figure 6.3.1 or contact each NEMA county office). - Purchase Prices are subject to the market trends.
Fluorescent Lamp	2 to 4	<ul style="list-style-type: none"> - In order to prevent diffusion of mercury in fluorescent lamps, used ones shall safely be kept without damage (Do not Crash! Do not Take Apart!) until properly disposed. - Used Fluorescent Lamps shall be transported to licensed e-waste handlers in Kenya to be disposed. 	<ul style="list-style-type: none"> - Licensed e-waste handlers (See Table 6.3.5) or contact each NEMA county office to get updated information on such handlers.
LED Lamp	5	<ul style="list-style-type: none"> - Used LED Lamps shall be transported to registered e-waste handlers in Kenya to be disposed. 	
Solar PV Panel	20 to 25	<ul style="list-style-type: none"> - Used solar PV panels shall be transported to registered e-waste handlers in Kenya to be disposed. 	
Inverter	5 to 10	<ul style="list-style-type: none"> - Used Inverters shall be transported to licensed e-waste handlers in Kenya to be disposed. 	

* Note: Vary depending on the intended use as well as status of use

Prepared by JET



Photo by JET

A battery manufacturer already has a program to buy used batteries at KSh. 40 per kilogram

Figure 6.3.1 Used Battery Purchasing by a Battery Manufacturer**Table 6.3.5 Licensed E-waste Handlers in Kenya (As of August 2013)**

Handler	Contact	District	Waste Type
East Africa Computer Recyclers Ltd.	P.O. Box 49266-00100, Nairobi Email: estafricancomputer@yahoo.com 07215036515, 0729308221	Mombasa	Electronic Recycling
Waste Electrical and Electronic Equipment Center	P.O. Box 48584-00100, Nairobi Email: infor@weecenter.com 0733-986-558, 202060921	Nairobi	Electronic Recycling

Source: NEMA (tabulated by JET)

(4) E-waste Management Structure

Used batteries, fluorescent tubes and other used electrical apparatuses/devices can be handled by organizing an e-waste management sub-committee under the Pilot Project management structure to be set up by each community and/or facility as follows:

- a. The structure (sub-committee) to be organized for the e-waste management shall be discussed among stakeholders on the initiative of REA.
- b. Each community is to be enlightened that even the electrical apparatuses/devices such as PV panels and inverters which have a longer lifespan eventually need replacement
- c. Each community is to be enlightened that those hazardous elements shown in Table 6.3.2 are hazardous to health and environment and some hazardous substances like “lead” in batteries and some non-hazardous elements shown in Table 6.3.3 can be recycled and reused.


(5) E-waste Disposal System

Practically, the aforementioned e-wastes shall be transported to the licensed E-waste Handlers and/or battery manufacturers in the following approach:

- a. Request suppliers to take away used ones from each facility when carrying out replacements (this shall be set as a condition for carrying out replacements).
- b. Being public property of the project, earnings from the sale of used e-waste including batteries shall be remitted using the “m-pesa” system by suppliers receiving earnings from the licensed E-waste Handlers and/or battery manufacturers.
- c. The earnings shall be kept in each facility as revenue.
- d. In order to ensure proper transportation and treatment, an e-waste manifest system shall be introduced in the e-waste disposal system as shown in Figure 6.3.2 and Table 6.3.6.

* Manifest system: A system to keep all logs from e-waste discharge stage to transportation as well as final treatment in order to prevent illegal dispose of e-waste during the transportation as well as to make sure appropriate final treatment of such waste.

** The following web site of USEPA on Hazardous Waste Manifest System can be referred as reference.
<http://www.epa.gov/waste/hazard/transportation/manifest/index.htm>



- A Keep two logs on e-waste between Generator (facility) and Supplier which will transport e-waste to the (2 logs: one is for the generator and one is for the supplier)
- B Keep two logs on the e-waste between the Supplier and Licensed e-waste handler and/or Battery Maker for the treatment of the e-waste (2 logs: one is for the supplier and one is for the Licensed E-waste Handlers and/or Battery Makers)
- C Keep two logs on the residue of the e-waste between the Licensed e-waste handler and/or Battery Maker and a final disposal site (2 logs: one is for the Licensed e-waste handler and/or Battery Maker and one is for the final disposal facility like a landfill)
- D Send two copies of the logs of B and C to Generator (project facility) by which each project facility can identify the proper transportation, treatment and final disposal of the e-wastes by mail.
- E After receiving the copies in D, each facility shall report showing one of the copies to REA, as well as regulatory agency such as Ministry of Education (for Primary Schools) or Ministry of Health (for Dispensaries).

Prepared by JET

Figure 6.3.2 Conceptual Diagram of E-waste Manifest system

Table 6.3.6 Draft E-waste Manifest Log Form

	Date:	No. of Manifest		
1	Facility (Generator)	Name	Address/TEL/FAX	
		Person –in Charge:	Contact address/TEL	
	E-waste	name 1:	Quantity	E-waste
		name 2:	Quantity	
		name 3:	Quantity	
		name 4:	Quantity	
name 5:	Quantity			
2	Supplier (Transportation)	Name	Address/TEL/FAX	
		Person –in Charge:	Contact address/TEL	
	Received the above listed e-waste from the Facility on date _____ and Sign _____			
3	Licensed E-waste Handler and/or Battery Maker	Name	Address/TEL/FAX	
		Person –in Charge:	Contact address/TEL	
	Received the above listed e-waste from the Supplier on date and Sign _____			
	Treated appropriately the e-waste on date _____ and Sign _____ in compliance with the relevant laws and regulations in Kenya, especially the followings <input checked="" type="checkbox"/> Environmental Management and Coordination Act of 1999 (EMCA) <input checked="" type="checkbox"/> Environmental Management and Coordination (Waste Management) Regulations 2006 <input checked="" type="checkbox"/> Guidelines for E-Waste Management in Kenya 2010			
4	Final Disposal	Name	Address/TEL/FAX	
		Person –in Charge:	Contact address/TEL	
	Received the residues of above listed e-waste from the Licensed E-waste Handler and/or Battery Maker on date and Sign _____			
	Disposed the residues on date _____ and Sign _____ in compliance with the relevant laws and regulations in Kenya, especially the followings <input checked="" type="checkbox"/> Environmental Management and Coordination Act of 1999 (EMCA) <input checked="" type="checkbox"/> Environmental Management and Coordination (Waste Management) Regulations 2006 <input checked="" type="checkbox"/> Guidelines for E-Waste Management in Kenya 2010			

Note: At least eight copies are necessary.

Prepared by JET

6.4 Individual Subjects on MHP Project

(1) Mosquito Emergence Controls

In order to prevent water borne diseases such as malaria, mosquito emergence controls are required for waster body (sluice) dammed (enclosing bunds and dams) for MHP projects as follows:

- ✓ Periodic clean up of rubbish such as branches and leaves, water hyacinth, etc. in the water body.
- ✓ Regular operation of water table control (adjustment of vertical water level, i.e. “Up and Down of the level”. Maintaining the water table at one level may create a suitable water environment for breeding of mosquito larva).

(2) Wastewater Contamination Control

In order to prevent pollution of waster body (sluice) dammed for the MHP projects, wastewater shall be controlled and managed.

- ✓ Wastewater from surrounding settlements shall be captured and not discharged immediately to the water body.
- ✓ If the quantity of such wastewater is relatively small, leaching pit or septic tank methods can be utilized for wastewater management.
- ✓ If the quantity of such wastewater is relatively large, stabilization pond method (if there is enough space) can be utilized for wastewater management.

(3) Water Quality Control

In order to avoid anaerobic conditions in the water body (at enclosing bunds and dams) which will create Methane (CH_4), Hydrogen sulfide (H_2S), methylated inorganic mercury ($\text{Hg} \rightarrow \text{CH}_4\text{Hg}$) (if there is inorganic mercury in the water body), and other compounds in the water, the water quality shall be controlled as follow:.

- ✓ Periodic clean up of rubbish such as branches and leaves, water hyacinth, etc. in the water body.
- ✓ Regular de-sludge of bottom sediment of the water body.

CHAPTER 7 CONSTRUCTION SUPERVISION

7.1 Procurement

7.1.1 Procurement Procedure

Procurement should be conducted according to Public Procurement and Disposal Act 2005 and the Public Procurement and Disposal Regulations 2006 as stipulated by Government of Kenya.

MHP projects have components of civil works, electrical equipment, and distribution facility. It is therefore necessary to procure individually or to combine applicable descriptions in the tender document.

The procurement method consists of the following:

1) International open tender

International open tender is applied mainly where there are few or no domestic supplier who have experience of similar projects, and the tender calls for international suppliers. There is no maximum level of expenditure.

2) National open tender

National open tender is mainly for tender among national suppliers. When several national suppliers have experiences of similar projects and sufficient ability to implement, this method will be selected.

3) Restricted tender method

Restricted tender method is the procurement method that relies on the establishment of a list of authorized bidders who will be offered the opportunity to bid for a specific procurement package. The establishment of the list is subject to conditions.

Table 7.1.1 Types of Procurement and Maximum and Minimum Budgets

Type		Goods	Works	Services
International Open Tender	Maximum	The budget allocation		
	Minimum	No minimum		
National Open Tender (Threshold Class A)	Maximum	The budget allocation		
	Minimum	Kshs. 6,000,000	Kshs. 6,000,000	Kshs. 3,000,000
National Open Tender (Threshold Class B)	Maximum	The budget allocation		
	Minimum	Kshs. 4,000,000	Kshs. 4,000,000	Kshs. 2,000,000
National Open Tender (Threshold Class C)	Maximum	The budget allocation		
	Minimum	Kshs. 3,000,000	Kshs. 3,000,000	Kshs. 1,000,000

Note: Class A, B, C is classification made by procuring entities.

Source: "Public Procurement and Disposal General Manual" issued by PPOA (arranged by JET).

4) Direct procurement method

Direct procurement does not require the use of competitive bidding. Direct procurement is strictly regulated since it is completely devoid of competition and transparency. It is only applicable in the following cases:

- i) When there is only one supplier who can supply the goods, works or services being procured and there is no reasonable alternative or substitute for the goods, works or services, or
- ii) Where the goods being produced are urgent and because of the urgency the available methods of procurement are not practical. This type of situations can be regarded as an institutional emergency. In such cases, the circumstances that gave rise to the urgency were not foreseeable and were not the result of dilatory conduct or negligence on the part of the procuring entity.

5) Request for quotations method.

Procuring entities may request for quotations for goods, works and services which are readily available in the market and whose costs are below the set thresholds in schedule one of the regulations. It is mandatory for the procuring entity to have a pre-qualified suppliers list which is maintained for effective use of the “request for quotations” procurement method.

Procurement for public projects applies Standard Tender Document (STD) of Government of Kenya. The following STD would be applicable for MHP projects.

- ✓ Standard tender document for procurement of works (buildings and associated civil engineering works,
- ✓ Standard tender document for procurement of works (electrical and mechanical), and
- ✓ Standard tender document for turnkey projects.

MHP projects have aspects of civil works, building works, electrical works, and procurement of equipment. In the event that procurement is undertaken in a single phase, MHP project category is considered to be a combination of the above categories. It is therefore necessary to select the closest category and undertake modifications as required.

The above STDs are available in the Public Procurement Oversight Authority (PPOA) website. PPOA requires that standard tender documents are used with minor necessary modifications. Use of any other tender documents developed by a procuring entity requires prior approval of the PPOA.

STD generally consists of the following:

Section I:	Invitation to Tender
Section II:	Instructions to Tenderers
Section III:	Conditions of Contract
Section IV:	Appendix to Conditions of Contract
Section V:	Specifications
Section VI:	Drawings
Section VII:	Bills of Quantities
Section VIII:	Standard Forms

The above components are based on STD of buildings and associated civil engineering works. However, the contents of other types of STDs are almost same.

Specific description has to be prepared according to the format. Especially, specifications, drawings, bills of quantities, and standard forms have to be prepared according to plan and design. It is also necessary to consider evaluation criteria so that all tenders can be evaluated against the same technical and financial base.

In the specifications, it is necessary to strictly specify quantity and quality requirement, guarantee performance order, guidelines and standards that the supplier shall follow, including user training requirements, reporting obligations, and testing and commissioning. It is necessary to conduct supervision of suppliers and specify the quality requirement in the specifications to ensure high work quality.

For drawings, it is a requirement to include facility and general layouts, plan, profile, typical sections of the permanent civil structures including penstock, major dimensions of gates and valves, powerhouse layout, single line diagram, and related facilities of the MHP station.

For bills of quantities, work and equipment quantities need to be specified in a table. The bills of quantity table will be referred to for inspection prior to commissioning in order to assess if the supplier’s work has been completed.

7.1.2 Procedure of Procurement

Generally, the procurement procedure will take more than six months. The tendering process consists of the following tasks:

- ✓ Preparation of tender document and specifications,
- ✓ Request for Expression of Interest and Pre-qualification (when pre-qualification is conducted),
- ✓ Invitation to tender or advertisement of procurement,
- ✓ Preparation of tender,
- ✓ Bid opening,
- ✓ Bid evaluation, and
- ✓ Contract negotiation and award.

A tendering schedule should be considered and incorporated in the project implementation schedule. A sample procedure and schedule of a general national tender process is shown in the table below.

Table 7.1.2 Example of Procurement Schedule

Work Items	M1				M2				M3				M4				M5				M6				M7				M8				M9			
	W1	W2	W3	W4	W1	W2	W3	W4	W1	W2	W3	W4	W1	W2	W3	W4	W1	W2	W3	W4	W1	W2	W3	W4	W1	W2	W3	W4	W1	W2	W3	W4	W1	W2	W3	W4
Preparation of tender document and specification (Request for Expression of Interest and Pre-qualification)	■	■	■	■	■	■	■	■	■	■	■	■																								
Invitation to tenderer or advertise of procurement													■																							
Preparation of tender													■	■	■	■	■																			
Question and reply about tender													■	■	■	■																				
Bid opening																	■																			
Bid evaluation																	■	■	■	■	■															
Contract negotiation award																									■	■	■	■	■	■	■	■	■	■	■	■
Implementation and contract administration																													■	■	■	■	■	■	■	■

Prepared by JET

If funding is provided by an external donor, concurrence processes are required in addition to the above.

7.1.3 Qualification

The method for qualification is described in details in Chapter 5 of “Public Procurement and Disposal General Manual” issued by PPOA.

Eligibility criteria need to be described in the bidding document. For MHP projects, at least three projects with similar technical requirements and budgets should be required of the bidders.

Qualification should include the capability, experience, resources, equipment and facilities to install the MHP station. Qualification criteria may relate to:

- i) Technical competencies and resources, including the availability of sufficient manpower, the qualifications and experience of key personnel or managers, available equipment, and manufacturing or construction facilities,
- ii) Financial position, including financial soundness, and sufficient turnover or sufficient cash flow,
- iii) Experience and satisfactory performance of similar contracts, taking into account relevant factors, including similar or comparable references and litigation record.

A project Manager should be assigned and the bidder required including a CV showing that the identified person has the necessary capability and experience.

Pre-qualification is the process that the bidders first participate in, bidding to prove their qualification. Pre-qualification criteria are the basis for short-listing bidders for tendering. In applying this method, the time and costs constraints versus the size and estimated value of the procurement requirement should be duly considered. Generally, pre-qualification is conducted for projects with potentially numerous contractors and tight competition in the tender process.

7.2 Construction Supervision

This chapter describes construction supervision works by the Client, which is different from supervision works by the contractor.

General work items of construction supervision by the Client are summarized below.

Table 7.2.1 Work Items of Construction Supervision

Item	Description
1. Overall management	Overall management of the project internally and external correspondence regarding the project to central government, county government, financing institution, etc. as required.
2. Schedule control	Monitoring the official schedule and actual progress of construction works, adjust the schedule amongst the contractors, update the official schedule as required, etc.
3. Quality control	Monitoring and control of the construction materials, methods, equipment and facilities, check the dimension, shape and form of permanent structures and equipment, etc. based on the technical specifications in the contract.
4. Document control	Filing the correspondences and minutes of meetings, preparing the technical report if necessary, control of the approved drawings, on-site instruction and on-site approval, etc.
5. Payment control	Checking the work performance and quantity calculation sheets for payment, assuming the total budget is based on the construction progress.
6. Variation order	Confirming the necessity of alterations, additions and omissions of works, and availability of project budget, issuing the variation order, etc.
7. Safety and health control	Preparing the emergency communication network chart, monitoring the contractor's activities and natural and social conditions surrounding the project site, responding in case of emergency.

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Table 13-1)" published by JICA in 2011 (arranged by WG).

Prepared by WG of MHP

The construction work for a MHP project is a small scale undertaking, but it is necessary to supervise three (3) main different types of work, i.e., civil structures, electrical equipment and distribution facilities. It is necessary to adjust their design and schedule during the construction period.

Because the supervision of construction work needs complicated technical knowledge, it is often necessary for supervision to be implemented under the leadership of the experts, or be entrusted to a consulting firm.

7.2.1 Overall Management


The items related to overall construction management of the project are listed below.

Table 7.2.2 Items of Overall Management

Item	Description
1. Organization management	Organize the management team among the Client, contractors and consultants.
2. Submission control	Manage submissions by the contractors according to the contract.
3. Safety and health control	Establish and operate the management system including basic regulations, regular monitoring items, response manual in case of emergency, etc.
4. Progress report	Define the contents and procedures of reporting by each contractor.
5. Procedure of handover	Prepare the handover procedure from contractor to contractor at milestones and the handover procedure from contractor to client at overall completion. Prepare the project completion report to central government, county government, financing institution, etc., as required.

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Table 13-2)" published by JICA in 2011 (arranged by WG).

A construction supervision team shall be organized for the project. A resident engineer shall be stationed at the site, and at least one personnel and a specialist will visit the site in accordance with the progress of construction work. A sample construction supervision team is shown below.



Source: “Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Figure 13-2)” published by JICA in 2011 (arranged by WG).

Figure 7.2.1 Sample of Organization of Construction Supervision Team

7.2.2 Schedule Control

This is a task to monitor and control the time schedule in compliance with the actual progress of all the construction activities as explained below.

(1) Management of Construction Schedule

The construction activities will be controlled using the construction schedule. However, actual construction activities often change due to site conditions and/or external factors. The construction schedule, therefore, shall be revised and updated within the contract period.

The construction schedule planned and attached to the contract is the original construction schedule. When the site conditions and/or external factors are different and/or change from the assumed conditions, the construction schedule will be revised and officially adopted as the revised construction schedule.

The work progress is monitored using either the original or the revised construction schedule, by indicating the actual work progress on the construction schedule, and comparing them against each other periodically. In case the actual progress falls behind the schedule, the supervision team shall clarify the reasons and implement countermeasures to catch-up to the schedule.

(2) Management of Key Dates and Milestones

In the construction schedule, some important dates such as starting date of concrete placement, delivery date of the turbine, etc. are set as milestones, and designated as “Key Dates” which have to be adhered to contractually.

If a key date is rescheduled backward or forward, it will influence not only its work but also that of subsequent relevant works. Therefore, the schedules and actual work progress shall be continuously confirmed and the concerned parties notified.

(3) Adjustment of Construction Schedules among Contractors

Civil works, electrical works and distribution works are mutually related to each other for completion of the construction work. Especially, for works which relate to the key dates, it is necessary to confirm the actual progress against the construction schedule at all times. The supervision team shall hold regular meetings in order to adjust the construction schedule of each contractor. In general, regular meetings are organized as follows:

- ✓ Weekly Meeting: It is normally held on the last weekday to clarify the results of the week and the plan of the coming week, and to adjust the related work schedule as required.
- ✓ Monthly Meeting: It is normally held at the end of the month to clarify the results of the month and the plan of the coming month, and to adjust the related work schedule as required.

7.2.3 Quality Control

This is a task to monitor and control the quality, such as strength, shape, efficiency, etc., of the permanent structures and equipment as explained below.

(1) Management of Construction Materials

The quality of construction materials, such as filling materials, aggregates, cement, concrete, reinforcement bar, rock bolts, etc., which are used for the permanent structures shall be controlled. The technical requirement and test method of each material will be specified in the technical specifications in the contract, in accordance with Kenya Standard (KS) and/or related international standards. Construction materials for temporary works are not included.

The supervision team shall define the procedure, inspection sheets and required documents to be prepared by the contractor, before the commencement of construction works.

(2) Management of Construction Method

The construction method of each structure is proposed by the contractor for approval. The construction supervision team shall check the construction method in view of validity and safety.

(3) Management of Construction Equipment and Facilities

The construction equipment and facilities used for the construction works are proposed by the contractor for approval. The construction supervision team shall check the quality, quantity, performance, and maintenance plan.

(4) Management of Dimension, Shape and Form

The dimension, shape and form of the permanent structures shall be checked to determine whether permanent structures have been constructed in line with the drawings and the specifications.

In case of concrete structures, it is desirable to check the dimensions and shapes two times, i.e., the form setting condition before concrete placement, and the concrete after its placement.

7.2.4 Documents Control

This is a task to record the instructions of the Client and performance of the contractor as explained below.

(1) Letters between the Client and Contractors

Communications between the Client and contractors are to be established by official letters, in principle. These letters shall be issued and filed properly.

1) Numbering of letters

Numbering of letters should be defined before issuing the first letter. Items such as number of letter, issuing place and date, sending address and name of person should be simple and clear in order to organize the record of letters.

2) Letter control

Issuing and receiving of letters should be recorded, and the records should be filled separately. The followings are basic points for writing a letter.

- ✓ One letter shall be for one subject,
- ✓ Name of the relevant structure should be indicated in the captioned title, and
- ✓ Reference number, if necessary, should be indicated alongside the issuing date in the caption.

(2) Minutes of Meetings

Minutes of meetings should be filed after confirmation by concerned parties.

- ✓ Joint Meeting: Client, supervisor and all individual contractors participate in the joint meeting periodically to discuss mainly the construction program.
- ✓ Coordination Meeting: Supervisor meets contractors in turn mainly for the coordination of the programs which are related to one another, and
- ✓ Meeting between persons in charge mainly to discuss daily practical issues.

(3) Technical Reports

These are reports showing clarifications and analysis of special technical issues of the project. Technical reports are prepared by the contractor and/or the consultant and submitted to the Client, as required.

(4) Drawings

Drawings indicate the location, dimensions, materials, etc. of the permanent structures and equipment to be constructed and installed by the contractors. The original drawings are generally included in the contract document.

However, additional drawings are further required for construction as explained below.

1) Drawings issued by Supervisor

The drawings issued by supervisor are called Approval-for-Construction Drawings. They are usually revised versions of the original drawings to suit actual site conditions as required.

It is recommended that a numbering system for the drawings be defined before starting construction. Basically, new number is added at the end of the number of the tender drawing, and the record of revision mentioned there as well.

2) Drawings submitted by the Contractors

The contractor prepares the shop drawings which indicate details of construction works (re-bar bending details, arrangement of anchor bars, etc.). The contractor submits these drawings to the Client for approval before the commencement of related construction activities. The person in charge on behalf of the Client checks and approves these drawing.

The following items should be defined before starting construction work.

- ✓ Format -size and title- of drawings,
- ✓ Number of drawings submitted to the Client and number of the drawing approved by the Client and returned to Contractor,
- ✓ Procedure for submitting drawings for approval,
- ✓ Final signatory on behalf of the Client, and so on.

3) As-built drawings

As-built drawings are compilations of all drawings used for construction activities. These are important for the project operation and maintenance, as well as rehabilitation in future.

Generally, as-built drawings are prepared and submitted by the contractor according to the contract.

(5) Onsite Instructions

Construction supervisor issues onsite instructions. The instructions should mention the payment terms and influence on the construction program. It is recommended that there should be the number, the name of structure and the issuing date and year in the instruction form.

The original is kept by the contractor while the Client and supervisor keep individual copies.

(6) Onsite Approval

The contractor makes a request for inspection; which describes the objective structure, inspection date and inspection contents. Whether the Client might sign it or not depends on the Client's availability

and daily presence to conduct the inspection. This should be discussed and decided preferably before the construction work begins.

The supervisor approves the inspection and maintains the original inspection form in his records, while the contractor keeps the copy.

7.2.5 Payment Control

In instances where a “progress payment” method is adopted in the contract, it is necessary to confirm the progress of the construction works by the amount of work done and measurement of performance.

(1) Work Performance Investigation

Set up the standard of work performance management in advance. Make a graph for work performance management, comparing measured value according to work performance measurement sheet against the designed one. Thereafter, manage the construction performance to go well with the design.

Generally, the following items are controlled and supervised.

- ✓ Base Line Survey: The contractor carries out a base line survey in the presence of the supervisor,
- ✓ Work Performance Measurement: Dimensions of the structures whose construction has been completed by the time of the inspection are measured and confirmed, and
- ✓ Calculation Sheet: Quantities written in the calculation sheet are checked against the data of the work performance measurement and baseline survey.

(2) Inspection at the Time of Accomplishment of Milestone

It is one of the “progress payment” methods in which a certain amount of payment is paid to the contractor when a milestone has been accomplished.

Examples milestones which can be set are as follows:

- ✓ A certain percentage of the costs is paid when concrete placing work is commenced at the intake weir.
- ✓ A certain percentage of the costs is paid when 30% of foundation concrete has been placed at the intake weir.

Methods of inspection and confirmation are the same as mentioned before.

7.2.6 Variation Order

It often becomes necessary to modify the original design, especially civil structures, in accordance with the actual site conditions and/or adjustments to other works during the construction. The design changes shall be carried out according to the procedure for design change stipulated in the contract.

The variations include 3 actions; alterations, additions, and omissions. These include variations of work volume, alterations of characteristics, quality and types of the work, modifications of the levels, base lines, positions and sizes of the structures, variations of the construction order, work additions, and work omissions.

In case the project’s procurement budget was provided by a financial institution, it is also necessary to confirm and report the variations to the financial institution concerned, for approval.

7.2.7 Safety and Health Management

Construction sites have a lot of hazards which may cause accidents. Moreover, MHP development projects are often located in remote areas. Once an accident or any other fatal disaster occurs, significant time and effort is required to deal with the occurrence. It is therefore necessary to take steps to manage all kinds of situations in order to prevent accidents.

In the first instance, an emergency communication network chart shall be prepared in the early stages of the construction. The network chart shall include essential parties such as the Client, the contractors, police station, hospital, representatives of local residents, etc. and for each the name and telephone number of the contact person.

The supervision team shall oversee and ensure that the contractor is properly executing safety and health control, and also provide instructions for reinforcement and/or improvement, if necessary.

- ✓ Monitoring of safety measures on the construction site by periodic site patrol,
- ✓ Monitoring of disposal status of construction waste by periodic site patrol,
- ✓ Monitoring of natural conditions, especially water pollution due to construction activities, by periodic patrol and water quality inspection,
- ✓ Monitoring of social conditions, especially traffic conditions caused by construction activities, by periodic patrol,
- ✓ Confirmation of the points of reinforcement and improvement at weekly and/or monthly meetings.

The supervisor shall also instruct the contractor to undertake the following items:

- ✓ Convening a daily morning safety assembly before work begins to confirm the daily tasks, and confirm awareness of the precautions and perform physical exercise,
- ✓ Indicating safety targets (priority safety issues corresponding to the progress and characteristics of the ongoing work should be set up on a monthly basis to raise awareness amongst the laborers.), and
- ✓ Preparation of a daily safety report; which should be perused by the supervisor as needed.

7.3 Civil Works

7.3.1 Inspection Items for Construction Supervision

Major inspection items of civil works are summarized in the table below.

Table 7.3.1 Major Inspection Items of Civil Works

Inspection Items	Description	Timing
1. Confirmation of right of way and reference survey points.	Joint inspection for confirmation of borders and reference points by land owners, contractor and supervisor.	Before commencement of construction works.
2. Confirmation of temporary accommodations and areas.	Joint inspection for confirmation of borders and areas by land owners, contractor and supervisor.	Before mobilization of the contractor.
3. Care of River Flow.	Construction work under conditions of river flow, diversion and care of river flow is necessary. <Related Structure> Headwork, powerhouse and tailrace outlet.	As required during the construction period in accordance with the progress of works.
4. Confirmation of Foundation Conditions.	Joint inspection for confirmation of the foundation ground conditions to avoid differential settlement. <Related Structure> Headwork, headpond, penstock, powerhouse and other buildings.	After excavation and before concrete placement.
5. Protection of Water Leakage.	Joint inspection for sealing condition of each gate and stoplog. <Related Structure> Intake, power canal, silting basin, headpond, and tailrace outlet.	During construction and after installation of gate and stoplog.
6. Leveling control.	Reference point management. <Related Structure> Headwork, power canal, and powerhouse.	During construction period.
7. Steel penstock	Factory inspection and site inspection of welding.	Before delivery of the steel, during and after erection at the site.
8. Connection points with electrical works	Arrangement and confirmation of electrical works at connection points (anchor bars, opening, etc.) in powerhouse.	Before and during erection works.
9. Care of roads	Public road and project maintenance road shall be cared for properly.	During construction period.

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Table 13-6)" published by JICA in 2011 (arranged by WG).

7.3.2 Procedure of Approval and Confirmation on Site

Inspection, approval and confirmation of the construction activities are carried out in a number of stages, in order of importance.

If inspection, approval and confirmation of all construction activities are carried out using the same methods, the procedure will become too detailed and result in significant amount of work and time consumption for both the contractor and the supervision team. As a result, the construction period will be long and the construction costs expensive.

Table 7.3.2 Procedure for Approval and Confirmation

Grade	Form	Application	Process by Supervisor	Example
A	Covering letter with the transmittal	<ul style="list-style-type: none"> ✓ Approval item by supervisor written in the contract document. ✓ Milestone for payment ✓ Design change, ✓ Minutes of meeting of important issue, etc. 	Supervisor signs the transmittal at the time of approval. If some defects are found, re-submission is required. Finally, a copy is returned to the contractor.	Approval of major construction materials (concrete, re-bar, etc.), commencement of works (excavation of waterway, etc.)
B	Application for Approval	<ul style="list-style-type: none"> ✓ Approval item which is a relatively minor issue written in the contract document. ✓ Minutes of meeting, ✓ Other issues not mentioned above but required by the contractor. 	Stamp of approval is sealed on the application form, and a copy is returned to the contractor.	Approval of construction materials, approval of concrete placement, etc. excluding milestones.
C	Covering letter only	Issues which are written in the specification as submissions.	Receipt stamp is sealed on the letter, and a copy is returned to the contractor.	Submission of weekly and monthly reports.
D	Verbal communication	Confirmation at the site without approval.	Send the person responsible for checking and confirming to the site. If some issues arise, minutes of the meeting are prepared by the contractor and submitted for approval.	Concrete test at laboratory, confirmation of land border, etc.

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Table 13-9)" published by JICA in 2011.

7.4 Electrical Equipment

Construction management for electrical equipment is partially performed under the same rules for the civil works, with some differences. In principle, rules for the civil works will similarly be applied to electrical equipment including: design documents, approval documents, final documents, completion documents and manual of equipment.

In regards to payment, it is stipulated in the contract how to authorize payment for fabrication and installation. Further, it is common for payment to be authorized upon witnessing equipment tests at the factory, upon delivery or on the installation date at the construction site, and on acceptance of the commissioning test. In the case of MHP projects, the construction costs of electrical equipment may be paid in a lump sum at the time of acceptance of the commissioning test, for example.

Two key points of construction supervision for electrical equipment are:

Interface with the Civil Works

The civil contractor and electrical equipment supplier are generally different service providers. Coordination between the two contractors is one of the most important aspects of construction management and supervision.

Some openings and embedded metals shall be prepared in the concrete to allow electrical equipment to be fixed, including:

- ✓ Blockouts in the concrete floor and foundation metal,
- ✓ Location of anchor bars embedded in concrete for electrical apparatus,
- ✓ Space for cables to be installed after the civil works, etc.

The concrete works are executed by the civil contractor. Therefore, required information and materials shall be clarified before approval of working drawings for the civil contractor. These requirements will be reflected in the approved drawings for the civil contractor.

Rigorous Execution of Inspections and Tests

Control of the turbine efficiency and generator efficiency, and the error allowance of fabrication and installation are important to maintain the quality of electrical equipment. Inspections, tests and measurements procedures specified in the technical specifications to control them should be executed by the designer, or submitted for approval by the contractor. It is important to carry out such inspections, tests and measurements correctly in the factory and at the construction site for quality control of electrical equipment.

7.4.1 Acceptance of the Turbine Efficiency

Turbine efficiency is an important parameter for a hydropower generation scheme. To ensure the planned turbine efficiency, the following measures are generally adopted for procurement of the turbine:

Performance Order

The guaranteed level of efficiency of the turbine is stipulated in the procurement specifications and/or the tender specifications. In case the actual efficiency of the turbine does not achieve the guaranteed efficiency, the supplier has an obligation to pay the penalties.

Model Test Before Fabrication

Execution of the model test of the turbine is stipulated in the contract documents in order to confirm performance parameters such as efficiency, runaway speed, cavitations characteristics, etc. The model test is executed in the factory upon completion of fluid design and before the commencement of fabrication of the turbine based on international standards prescribed by IEC (International Electrical Committee) or equivalents.

However, the model test is too expensive and therefore influences construction costs of the MHP project. Therefore, there are instances where a turbine model test can be omitted in a MHP project. Instead, the efficiency can be confirmed and ensured by using the following alternatives:

- ✓ Confirmation by Computational Fluid Dynamics (CFD) analysis,
- ✓ In case of application of a completed type of turbine developed in series, or a reverse pump turbine, confirmation can be done using performance data generated during product development by the manufacturer.

7.4.2 Acceptance of the Generator Efficiency

Generator efficiency is also an important parameter to control the economy of a hydropower scheme, and the efficiency stipulated in the contract is guaranteed by supplier.

There are two measurement methods to confirm the generator efficiency as follows:

- ✓ Measurement in the factory with generator assembled, and carrying out a revolving test,
- ✓ Measurement on site using an actual machine at the time of a filed acceptance test.

The test methods are prescribed by international standards such as IEC, and are applied as well.

For a MHP project, the revolving test carried out in the factory may be omitted with the aim of reducing cost, and it is common to measure efficiency using an actual generator on site.

7.4.3 Shop Test

A shop test is important for checking whether generation apparatus is produced according to the specifications, the contract, and the approved drawings. Confirmation of the factory test data and all witness tests must be carried out carefully to perform quality control impeccably.

An example of a witness test is shown below. When purchasing a finished product or a general purpose product, witness tests may be omitted. However, it is necessary for the manufacturer to submit factory test data for the supervisor to confirm.

Table 7.4.1 Major Items of Witness Test for Generation Equipment

Inspection Equipment	Test Item
Turbine	<ul style="list-style-type: none"> ✓ Model turbine test, ✓ Dimension measurements of draft tube liners, ✓ Dimension measurements and nondestructive test of a spiral casing, ✓ Nondestructive test of a runner (before finishing machining), ✓ Nondestructive test of a runner (after finishing machining), ✓ Nondestructive test of guide vanes (before finishing machining), ✓ Dimension measurements of guide vanes, ✓ Dimension measurements and nondestructive test of a top cover, a bottom cover and a guide ring, ✓ Turbine main shaft alignment test and nondestructive test, ✓ Turbine temporary assembly test, ✓ Governor performance test, ✓ Performance tests for turbine auxiliary equipment, etc.
Generator	<ul style="list-style-type: none"> ✓ Dimension measurements and nondestructive test of a top and bottom bracket, ✓ Dimension measurements and nondestructive test of guide bearings and thrust bearing, ✓ Generator main shaft alignment test and nondestructive test, ✓ Combination and revolving balance alignment test of rotor spoke, turbine and generator main shaft, ✓ Dimension measurements and withstand voltage test of stator coils, ✓ Dimension measurements and withstand voltage test of rotor coils, ✓ Dimension measurements and withstand voltage test of a stator, ✓ Dimension measurements and withstand voltage test of a rotor, ✓ Performance test and withstand voltage test of an exciter, ✓ Dimension measurements, withstand voltage test and performance test of a Neutral Grounding Resistor (NGR), etc.
Main Transformer	<ul style="list-style-type: none"> ✓ Dimension measurements, ✓ Withstand voltage test, ✓ Measurements of various fixed number, etc.
Control panels, Switch Gears, etc.	<ul style="list-style-type: none"> ✓ Dimension measurements ✓ Performance test (open-close test, interlock system test, sequence test, etc.) ✓ Withstand voltage test, etc.

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Table 13-10)" published by JICA in 2011.

7.4.4 Site Test (Acceptance Test)

The site test is performed in order to determine the acceptance of the generation apparatus. Attention shall be paid to performance of the power plant, purchase conditions, and construction quality in particular. As for factory test data, measurements at the time of installation at the site and site test data are necessary as initial values for comparative observation of changes due to aging of the generation facilities.

The major items of site tests are listed below.

Table 7.4.2 Major Items of Acceptance Test for Generation Equipment

Inspection Equipment	Test Item
Turbine	<ul style="list-style-type: none"> ✓ General structural inspection, ✓ First revolving test, ✓ Bearing running in test, ✓ Revolving balance alignment test, ✓ Protection system test, ✓ Load rejection stop test, ✓ Emergency stop test, ✓ Quick stop test, ✓ Quick stop test by power source (oil pressure, voltage) drop of guide vane servomotor, ✓ Load test (continuous operation test with full output), ✓ Remote control and supervision test (includes alarm test), etc.
Generator	<ul style="list-style-type: none"> ✓ General structural inspection, ✓ First revolving test, ✓ Bearing running in test, ✓ Revolving balance alignment test, ✓ Measurements of insulation resistance and withstand voltage test, ✓ Measurements of various fixed number of the generator, ✓ Check of phase sequence, ✓ No-load saturation test, ✓ 3 phase short-circuit test, ✓ Calculation of short-circuit ratio and voltage regulation, ✓ Measurements of deviation factor of voltage waveform, ✓ Operation test combined with excitation system, ✓ Shaft voltage/current measurements, ✓ Protection system test, ✓ Load rejection stop test, ✓ Emergency stop test, ✓ Quick stop test, ✓ Load test (continuous operation test with full output), ✓ Remote control and supervision test (includes alarm test), etc.
Main Transformer	<ul style="list-style-type: none"> ✓ General structural inspection, ✓ Measurements of various fixed number of the transformer, ✓ Measurements of insulation resistance, ✓ Withstand voltage test, etc.
Control panels, Switch Gears, etc.	<ul style="list-style-type: none"> ✓ General structural inspection, ✓ Performance test (open-close test, interlock system test, sequence test, etc.), ✓ Withstand voltage test, ✓ Remote control and supervision test (includes alarm test), etc.

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Table 13-11)" published by JICA in 2011.

7.5 Distribution Facilities

7.5.1 Inspection Items for Construction Supervision

The major inspection items of distribution facilities are summarized in the table below.

Table 7.5.1 Major Inspection Items of Distribution Facilities

No.	Inspection Items	Description	Timing
1	Pole positions and wiring routes	To confirm pole positions with land owner, contractor and supervisor.	Before the construction.
2	Supporting structures	To plumb the pole up, To check the pole length in ground, To check foundation	During and after the installation.
3	Guys	To check the linkage of anchor, and To check the height of guy wire.	During and after the installation.
4	Grounding	To check the depth of grounding electrode and grounding wire installation method, and To check the grounding resistance.	During and after the installation.
5	Cross arms	To check the installation condition of cross arm, arm tie and band.	During and after the installation.
6	Insulators	To check the type and installation method.	During and after the installation.
7	Conductors	To check the dip, To check ground height and distance between conductor and surrounding object, To check fixing condition, and To measure the insulation resistance.	During and after the installation.
8	Transformers	To check the installation condition	During and after the installation.
9	Switches	To check the installation condition, and To check the fuse value of cutout.	During and after the installation.
10	Watt-hour meters	To check the place and height, To check the wiring, and To measure the insulation resistance.	After the installation.

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Table 13-12)" published by JICA in 2011.

7.5.2 Quality of Construction Materials

Quality control of materials for distribution facilities should be chosen from witness test at the factory, while quality inspection and sampling test should be according to the level of importance and quantity.

7.5.3 Procedures of Approval and Confirmation on Site


Inspection, approval and confirmation of construction activities are carried out in various stages depending on the level of importance and construction stage, in the same way as the civil works.

CHAPTER 8 OPERATION AND MAINTENANCE

8.1 Establishment of Management Body

It is expected that electricity consumers of a MHP station in a remote area are less than 1,000 households and some enterprises. This scale is too small to be managed by Government and/or parastatals. As a result, the operation and maintenance of a MHP station has to be executed by local residents.

The management body of a MHP station shall be prepared simultaneously with the construction stage of the MHP project. Organization of the management body constituted by the local community may be as follows:



Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Table 14-1)" published by JICA in 2011 (arranged by WG).

Figure 8.1.1 Example of Organization of Management Body

Each component of the organization functions as follows:

(1) Steering Committee

The steering committee is responsible for project management in general. Its members consist of officials from local authorities, beneficiaries of the rural electrification, supervisors of the electricity project, and representatives from the agencies financially supporting the construction of the project, if any.

The steering committee is responsible for:

- ✓ Establishing management policies,
- ✓ Assigning and removing officers executing the management,
- ✓ Setting an electricity tariff (submitting an electricity tariff to a higher institution, if any, for approval),
- ✓ Approving important repair and renovation plans.,
- ✓ Financial audit, etc.

The steering committee should hold a meeting every quarter of the year to supervise and guide the operations.

(2) Technical Support Organization

Since the MHP project will be operated by staff members with inadequate technical experience, it is important to arrange for additional support to be provided by a special organization such as a public electricity corporation which specializes in operation and maintenance of electricity facilities.

The technical support organization is responsible for;

- ✓ Handling trouble-shooting at the initial stage, upon commencement of operation,
- ✓ Regular checks and repairs,
- ✓ Instructions for replenishment of spare parts, etc.

If the above responsibilities are neglected, the equipment may be out of order often and the life span of the MHP station will become considerably shorter. Therefore it is desirable to enter into an umbrella agreement with the organization to get technical support from the construction stage.

(3) Management Body

Members of the management board are appointed by the steering committee to execute the operation and maintenance of MHP.

The management body consists of two departments: administrative and technical. The major tasks of each department are as listed below and explained in Chapter 8.3.

1) Administrative Department

- ✓ Personnel and labor affairs (employment, pay control, working control),
- ✓ General affairs (Meetings, document control, control of office equipment & consumables, safety control, miscellaneous affairs),
- ✓ Budget control (Business planning, fiscal budget, control of revenues and expenses),
- ✓ Accounting (Bookkeeping, account settlement, asset management),
- ✓ Fund administration (Cashier, fund administration),
- ✓ Customer management (Customer management, bill collection),
- ✓ Procurement (Contract for construction work, contract for maintenance work, purchases),
- ✓ Inventory control (Warehouse control, control of inventory goods and fuels), etc.

In implementing the above tasks, responsibilities shall be simplified and implemented in order of a priority to be established.

2) Technical Department

- ✓ Operating the MHP station as well as maintaining and controlling the facilities,
- ✓ Maintaining and checking the distribution facilities as well as controlling and repairing spare parts,
- ✓ Understanding well about the operation conditions of the MHP station and giving instructions for startup or shutdown,
- ✓ Checking watt-hour meters, etc.

The constitution of the management body will depend on the scale of consumers as shown below.

Table 8.1.1 Approximate Numbers of Members of Management

Position	Unit	Appropriate Number of Staff			
		Less than 200	200 – 500	500 – 1,000	More than 1,000
Scale of consumers	Nos.	Less than 40	40 – 100	100 – 300	More than 300
Scale of MHP	kW				
1. Director	Person	1	1	1	1
2. Deputy director	Person	–	–	1	2
3. Administrator	Person	1	2	2	4
4. Plant Operator	Person	2	4	4	5
5. Distribution staff	Person	2	2	2	3
Total	Person	6	8	10	15

Source: “Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Table 14-1)” published by JICA in 2011.

8.2 Financial Management

The financial management of a MHP station is important to achieve the sustainable operation of the power generating service. The financial conditions require a balance between income from electricity tariff and the expenditures of MHP station and distribution system.

For sound management, it is important to set an electricity tariff that will not cause a deficit. It is desirable to employ a tariff system that ensures fairness and transparency and is simple and easy to operate based on the explanation of necessary expenditures to residents.

8.2.1 Necessary Expenditure

The following expenses are generally taken into account for MHP operation.

Table 8.2.1 Required Expenses of MHP Operation

Category	Description
1. Personnel Expenses	Calculate personnel costs -salaries and allowances of persons in charge of office management, operators and other employees.
2. Administrative Expenses	Calculate all the administrative expenses excluding the personnel expenses of the management body but including expenses for the office's electricity use, administrative commodities and others. It is estimated that administrative expenses amount to about 60 to 120% of personnel expenses.
3. O&M Expenses of Facilities	Calculate the expenses for power facilities' maintenance needed for normal operation including the costs of machinery tools, oils, spare parts, etc.
4. Cost Depreciation	This is a cost associated with changes in the properties of equipment e.g. its value distributed over their life span.
5. Reserved Fund for Overhaul	Accumulate a fund to inspect and overhaul the electrical components and equipment. Since the inspection and overhaul will be conducted every several years by manufacturers, a large budget is needed.
6. Others	Calculate expenses for taxes, insurances, loyalty, etc.

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Chapter 14.2)" published by JICA in 2011 (arranged by WG).

Regarding the cost depreciation, it is normally supported by aid or a subsidy in the case of rural electrification projects because of the following reasons:

- ✓ Electricity tariff set with cost depreciation will become quite expensive,
- ✓ An expensive tariff makes it difficult for customers to afford electrification, and
- ✓ Rural electrification of households is not attained even if the power source has been developed.

Therefore, it is recommended that the electricity tariff is set without the cost depreciation of fixed assets to make it affordable for subscribers.

If the cost depreciation is not calculated and reflected in the electricity tariff, the facilities renewal costs will not be accumulated. In other words, if the facilities break down, power generation will stop and the areas will be un-electrified as before. In order to prevent such a problem, a reserved fund for overhaul should be taken into account.

8.2.2 Electricity Tariff

Generally, the electricity tariff is divided into the following two charges:

- Fixed charge: a charge not related with the amount of electricity consumed.
- Consumption charge: a charge related with the amount of electricity consumed.

In case of small scale rural electrification projects, a fixed charge is commonly accepted to save for operation and maintenance costs of the MHP station. In case of relatively large scale electrification projects, a fixed charge is sometimes called a basic charge and depends on the capacity of the watt-hour meter.

The average electricity tariff per kWh shall be set above the cost price per kWh to be sold or consumed. The power demand is expected to be unstable for about one year after the commencement of power generation. Therefore, the amount of energy consumption used to estimate the electricity tariff should be adopted based on the value two or three years after the commencement of power generation.

A sample breakdown of the unit generation cost, which is basic data for setting the electricity tariff, is shown below.

Table 8.2.2 Sample of Breakdown of the Unit Generation Cost

Item	Unit	Middle Scale	Large Scale
Condition of Electrification			
1. Number of household	nos.	300	1,000
2. Distance of distribution line	km	15	35
3. Monthly energy consumption per household	kWh/month	15	40
4. Installed capacity	kW	55	300
5. Annual energy consumption	MWh/year	54	480
6. Monthly energy consumption	MWh/month	5	40
7. Number of employees	person	6	12
Cost Estimation on Monthly Bases			
1. Employment cost	L.S.	300	1,020
2. Overhead cost	L.S.	300	1,020
3. O&M cost	L.S.	200	200
4. Depreciation cost	L.S.	0	0
5. Provision for Overhaul	10%	80	224
6. Other expenses	5%	40	112
Total		920	2,576
Unit Cost per kWh	US Cent/kWh	20.4	6.4
Monthly Expenses for Electric Energy per Household	US\$/month	3.1	2.6

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Table 14-4)" published by JICA in 2011.

8.2.3 User Charges

Generally, an electricity user is required to pay the following charges at the time of connection.

Table 8.2.3 Required Expenses of MHP Operation

Category	Description
1. Cost of Service Drop Installation	Where a watt-meter is installed on a power pole, a service drop from the power pole to the subscribed house is needed. The line extension shall be around several meters to tens of meters, depending on the location.
2. Cost of Indoor Wiring Work	It is the cost of indoor wiring with smaller cords and installing a circuit breaker box.
3. Cost of Watt-meter Installation	It is the cost of equipment to measure kWh which a subscriber consumes. In some cases, it is installed at the expense of the management body.
4. Deposit	There are cases where a deposit equivalent to one-or-two months' electricity fee is needed as a guarantee for the payment of electricity bills. The management body may use it for operation expenses in the initial period of electrification.

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Chapter 14.2)" published by JICA in 2011 (arranged by WG).

8.2.4 Billing System

The normal billing system for rural electrification is Metering-Billing-Collection (MBC).

A series of procedures need to be established for MBC including: application from subscribers, subscription contract signing, checking electricity consumed at subscribers' houses, and issuing and paying electricity bills.

In cases where subscribers fail to pay their bills, measures for coping with non-payment should be taken into consideration. It is important not only from an income perspective but also as a discipline aspect of management, which is also part of the management of the accounting system.

8.2.5 Balance Sheet

The manager shall monitor the financial conditions of the MHP station by simple balance calculation between the income from the electricity tariff and expenses of the MHP station, in order to maintain sound management.

The balance calculation indicates the comparison of estimates and actual achievements. In case there are differences between the estimates and actual achievements, it is necessary to explore the reasons, and take them into consideration for improvement in management. These improvements may include: mitigation of losses, adjustment of maintenance and/or repair schedule, etc., and adjustments should be used to calculate estimates for the next few months and for the next year.

An example of a simple balance calculation sheet is shown below. It should be noted that the entire financial balance of account needs to be calculated with a detailed breakdown of all incomes and expenditures.

Table 8.2.4 Example of Balance Calculation Sheet

Month	Electricity			Revenue			Expenditure							Cost per kWh \$/kWh	Profit	
	Generation	Consumption	Loss	Invoice	Revenue	Loss	Salary	Overhead	O&M	Misc.	Sub-total	Provision for Overhaul	Total		\$	%
	kWh	kWh	%			%										
Jan	5,869	4,850	17%	1,067	1,014	5%	300	300	200	40	840	101	941	0.17	73	7%
Feb	6,081	5,110	16%	1,124	1,069	5%	300	300	200	40	840	107	947	0.16	122	11%
Mar	6,344	5,200	18%	1,144	1,087	5%	300	300	200	40	840	109	949	0.16	138	13%
Apr	5,924	5,020	15%	1,104	1,049	5%	300	300	200	40	840	105	945	0.17	104	10%
May	6,000	5,000	17%	1,100	1,045	5%	300	300	200	40	840	105	945	0.17	100	10%
Jun	6,000	5,000	17%	1,100	1,045	5%	300	300	200	40	840	105	945	0.17	100	10%
Jul	6,000	5,000	17%	1,100	1,045	5%	300	300	200	40	840	105	945	0.17	100	10%
Aug	6,000	5,000	17%	1,100	1,045	5%	300	300	200	40	840	105	945	0.17	100	10%
Sep	6,000	5,000	17%	1,100	1,045	5%	300	300	200	40	840	105	945	0.17	100	10%
Oct	6,000	5,000	17%	1,100	1,045	5%	300	300	200	40	840	105	945	0.17	100	10%
Nov	6,000	5,000	17%	1,100	1,045	5%	300	300	200	40	840	105	945	0.17	100	10%
Dec	6,000	5,000	17%	1,100	1,045	5%	300	300	200	40	840	105	945	0.17	100	10%
	72,218	60,180	17%	13,240	12,579	5%	3,600	3,600	2,400	480	10,080	1,262	11,342	0.17	1,237	9.8%

Electricity	(a) Energy generation (kWh/month):	Value at the end of generator
	(b) Energy consumption (kWh/month)	Value at the User end, watt-hour meter value
	(c) Distribution Losses	Technical energy loss by distribution line
Revenue	(d) Amount of invoice (Monetary Unit)	Corresponding to item (b), monthly sales of energy.
	(e) Amount of revenue (Monetary Unit)	Corrected amount by due date of the month to be revised when the payment is made.
	(f) Recovery rate (%)	When the payment is made, table shall be revised.
Expenditure	(g) Salary (Monetary Unit)	Monthly salary cost
	(h) Administration cost (Monetary Unit)	Expenses for operation of the office
	(i) Operation and maintenance cost (Monetary Unit)	Spare parts, repair, maintenance cost
	(j) Other cost (Monetary Unit)	Taxes, royalty
	(k) Deposit (Monetary Unit)	Reserve fund for overhaul
	(l) Total	(g)+(h)+(i)+(j)+(k)
Generation and Profit	(m) Unit cost per kWh (Monetary Unit/kWh)	(l)/(b)
	(n) Monthly balance (Monetary Unit)	(l) – (b)
	(o) Profit-earning ratio (%)	Monthly Basis

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Chapter 14.2)" published by JICA in 2011 (arranged by WG).

8.2.6 Management During Initial Stage

Customers of a new distribution system increase over time. Especially, customer numbers increase from the initial stage up to 1 to 2 years after the commencement of power generation. This means that income from the electricity tariff also increases over time.

As a result, revenue from the electricity tariff does not meet the operation expenditures of the MHP station and distribution system at the initial stage in most cases, and it is necessary to put some financial measures in place.

The following measures can be undertaken:

- i) To allocate the security deposits from subscribers (paid upon signing-up) to operation funds for the time being,
- ii) To borrow from a lending institution, and
- iii) To obtain financial assistance from an aid agency and/or a governmental institution.

i) and ii) above are liabilities which need to be compensated and repaid. Allotted to these repayable sources are shares of the profits and/or surplus generated by the management body.

In the case of a further lack, electricity tariff system needs to be revised.

8.3 Operation and Maintenance

In order to supply electricity to customers for 24 hours continuously at all times, functions of the MHP station and distribution system shall be maintained in good condition for proper power generation. Furthermore, customer support is required.

Administrative and technical activities are essential to realize uninterrupted proper power generation and supply. Essential issues of operation and maintenance activities are explained hereafter. However, actual activities shall be adjusted for each MHP station and distribution system.

8.3.1 Administrative Works

Required administrative works are summarized in the table below.

Table 8.3.1 Major Administrative Works for a MHP Station

Component	Item	Activities
General Affairs	Labor Management	Work management for technical staff, such as work shift.
	Operational Coordination	Providing places and opportunities for coordination amongst those in charge.
	Safety control	Managing the safety of electric power facilities from a technical point of view.
	Document Control	Storage and compilation of operation plans and records such as; - Daily/weekly/monthly/annual plans and reports, - Maintenance and repair plans and records, - Accident and emergency response records, etc.
Med-term Planning	Repair Plan	Plan for repair for up to 5 years and estimate of the budget.
	Inspection Plan	Plan for periodic inspections according to facilities and equipment and estimate of the budget.
	Replacement Plan	Plan for tools and parts replacement to maintain the performance and quality of equipment, parts and oil of facilities, and estimate of the budget.
Asset Management	Equipment ledger	Technical division is responsible for reporting in a case where any change happens due to a disaster or a repair.
	Inventory Book of Parts	Technical division is responsible for reporting a utilization schedule of parts and their prospects.
Complaint and Request Response	Accidental Service Interruption	Since the working group that supervises the equipment causing the fault handles the restoration.
	Abnormal Voltage	Since the working group that supervises the equipment causing abnormal voltage takes charge of the investigation and countermeasures.
	Malfunction of Watt-hour Meters	Responses to complaints and requests to the malfunction of watt-hour meters, such as problems with the circular plate.
	Check of Watt-hour Meters	It is important to check a watt- hour meter in a case where a large error is suspected.
Customer support	Technical review of Application	It is to check the need for additional distribution facilities in the case of the increase in electronic products of current customers.
	Connection Setup	Construction work in response to customer's application for electric power receiving, such as setting a watt- hour meter and a service drop for new customers or replacement of a watt- hour meter in response to current customers.
	Meter Reading	Read a number of watt- hour meters every month or at agreed intervals.
	Issue of Invoice	Issue the invoice to customers based on the meter reading.
	Temporary Connection and Removal	Set up and remove a watt-hour meter in the case of a temporary use of electricity, such as construction work.
	Removal of Watt-hour Meters	Remove watt-hour meters when customers stop the use of electricity such as service cancellation.

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Chapter 15.1)" published by JICA in 2011 (arranged by WG).

8.3.2 Civil Structures

In order to realize the planned functions of the MHP station, the civil structures shall be operated and maintained properly. The major operation activities for civil structures are gate operation and inspection.

In fact, many hydropower stations experience reduction of power generation capability because of degradation of maintenance due to lack of budgets and/or insufficient takeovers, and so on. That would cause inattention to fundamental maintenance activities, and/or delays in detection of damages or defects.

In order to avoid such situations, maintenance activities shall be systematically executed, reported and recorded even if no damages or defects are identified, in order to ensure timely actions and sustainable maintenance activities in the long term.

All operation and maintenance activities shall be recorded, filed and kept in the station. The records shall consist of the following information:

- ✓ Names of staff involved, date and time, weather conditions, locations,
- ✓ Identified indications, damages and/or defects with photographs as required,
- ✓ Regular maintenance activities such as cleaning of drain ditch, repainting of steel cover, replacement of security light lamp, and so on.

(1) Operation

The following major operations are required:

Regular Operation

- ✓ Clearing floating debris on water surface of river in front of the intake, along the power canal, the head pond, etc.,
- ✓ Flushing sediments at the intake weir, the de-silting basin and/or the head pond, etc.,

Special Operation (as required)

- ✓ Draining or re-filling water from or to the penstock.

The above operations will be carried out with gates and valves installed in the civil structure. In case the integrated control system is installed in the power station, regular operation is executed by the system. If not, operation of the gates shall be executed by the station staff.

1) Regular Operation

Generally, the following gates are installed in the civil structures:

- ✓ Intake Gate and Tailrace Gate
These gates are opened during power generation, and closed during inspection of the turbine and generator and/or in case of emergency.
- ✓ Sand Flush Gate and Drainage Gates
The sand flush gate is installed at intake weir, and drainage gates are installed at de-silting basin and/or head pond. These are installed for sand drainage operations. Sedimentation progress dependings on each MHP site, as well as each structure. Appropriate frequency of operation shall be determined through the monitoring of sedimentation after commencement of power generation in each MHP station.

Detailed operation rules for each gate will vary depending on the scale of the gate, and the rules might be prepared by the contractor. In general, there are two basic regulations of gate operation:

- ✓ A gate opening speed has limitation in order to avoid any adverse effects of a quick water rise in the downstream reach.
- ✓ A gate opening height has limitation in order to avoid damage to gate bottom lips caused by cavitations phenomenon.

2) Special Operation

Water draining operations are necessary for special inspections or in case problems appear along the waterway. Conversely, water filling operations are required to resume the power generation. In principle, these operations shall be carefully performed during daytime in order to avoid any accidents.

Water draining or filling operations are for replacement of water and air in the penstock. Special attention shall be paid to control incoming and outgoing air in the penstock to avoid the following worst-case damages:

- ✓ Crushing of the penstock due to shortage of air supply during water draining operation,

✓ Destruction of the penstock valve due to air pressure during water filling operation, In order to avoid any damage during these operations, the operations shall be carried out slowly, steadily, and step by step to minimize impacts to the penstock. Therefore, fluctuation of static water head in the penstock shall be limited in both operations as follows:

✓ Fluctuation of static water head: 30m in elevation per hour.

(2) Maintenance

Maintenance work shall be executed under the concept of “Preventive Maintenance” to achieve sustainable operation and safety of the power station. Continuous routine inspection, maintenance, and monitoring activities for civil structures are indispensable for checking problems, and planning timely solutions to them, as necessary.

Maintenance activities are categorised as follows:

1) Regular Inspection

Regular inspection is defined as patrol of civil structures and surrounding facilities to check the conditions to determine whether they are maintained in good condition or have any defects or damages.

Regular inspection shall be carried out on a weekly or monthly basis. Furthermore, extra inspections shall be carried out in case of any unusual events, such as big floods, strong earthquakes, heavy rains, etc.

In case any damage is observed during the regular inspection, it shall be reported to the station manager.

2) Regular Maintenance

Regular maintenance is defined as repair or cleaning work when any defects are observed in civil structures during the regular inspection. It includes such work as cleaning of drain ditches, replacing of lamps, etc.

Regular maintenance shall be carried out whenever required.

3) Special Maintenance

Special maintenance is defined as repair or rehabilitation work.

The station manager shall review damages or defects from the point of view of safety and function of the structure, in order to judge the necessity of special maintenance and to decide proper measures - technical, financial and environmental.

The station manager shall arrange for specialists, as required, to obtain appropriate advice to make the above judgment.

In case repair and rehabilitation work requires stoppage of power generation, special maintenance shall be performed with careful preparation by all parties concerned, whenever it is required.

4) Special Inspection

Special inspection is defined as inspection of the power canal and penstock, and requires stoppage of power generation. Therefore, special inspections shall be conducted based on careful consideration and preparation except in the case of an emergency. Time schedule, participating specialists, equipment, etc. shall be determined for each case.

Major items of the inspection and maintenance are summarized in the table below.

Table 8.3.2 Inspection and Maintenance Items for Civil Structures


Items	Details
Condition of Security Facilities	Security facilities such as gates, fences, and security lights, etc., shall be maintained properly. Any holes in the fence shall be repaired, and blown-out lamps shall be replaced immediately.
Condition of Cable Duct Covers	Covers of pits, manholes, ducts, etc., shall be maintained in closed condition to protect the installed cables against deterioration. Any foreign materials shall be cleaned out.
Condition of Drainage Facilities	Deposits in drainage facilities shall be removed regularly.
Condition of Slopes	In case any deformations and/or unusual leakages of water are observed, monitoring shall be continued and special maintenance planned as required.
Condition of exposed Concrete Structures	In case the following damages and/or defects are observed, appropriate repair and/or monitoring shall be undertaken, reviewed by specialists, and special maintenance planned as required: <ul style="list-style-type: none"> ✓ Settlement, heaving, deflections or lateral or out-of-alignment movement at construction or contraction joints, ✓ Development of cracks on concrete surface, ✓ Development of cavitations due to high velocity water flow, ✓ Abnormal leakage or seepage from construction or contraction joints, ✓ Change of drain conditions from embedded drain holes, and so on.
Condition of Structures under the Water	Condition of structures under the water; i.e., intake, de-silting basin, power canal, head tank, penstock, and tailrace outlet, cannot be confirmed under stoppage of power generation without draining the water. It is recommended that special inspections are carried out when the power generation is stopped.

8.3.3 Electrical Equipment

Electrical equipment shall be maintained to generate electric power efficiently and properly.

In recent years, the operation of power generation is executed as automatic control by utilizing computer technology. An integrated control panel performs integrated operation of controls including: starting speed control, voltage control, power factor control, frequency control, load control, water level control, discharge control, program operation control, etc.

For example, generator start operation requires the following control. The integrated control panel performs all operations including such starting operation automatically.



Source: "Guideline and manual for hydropower development Vol. 2, Small Scale Hydropower (Figure 10-40)" published by JICA in 2011 (arranged by WG).

Figure 8.3.1 Example of Start-up Procedure of Power Generation

Accordingly, the major operation and maintenance activities for electrical equipment are explained below.


(1) Regular Patrol

The regular patrol is to check for general abnormalities of the equipment and to check the operational conditions of electrical components. The key detection factors are abnormal noise, smell and vibration.

The regular patrol is to be conducted daily or weekly, setting a patrol course and check list beforehand, and recording the readings of indicators such as a meter, pressure gauge, oil gauge, and opening angle meter.

(2) Inspection

The inspections of electrical equipment can be classified as shown below.



Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Chapter 15.3)" published by JICA in 2011 (arranged by WG).

Figure 8.3.2 Inspections for Electrical Equipment

It is recommended that the inspection cycle is set based on the inspection results and the operation conditions. For example, from cavitations measurement of turbine runner to be carried out once annually for 1 to 3 years, repair works are set to coincide with the time of internal inspection depending on the progress and damage due to cavitations.

Major items of the periodic inspection are summarized in the table below.

Table 8.3.3 Inspection Items of Periodic Inspection for Electrical Equipment

Component	Inspection Items	Details
External Inspection		
Turbine	Turbine internal	<ul style="list-style-type: none"> ✓ Inspect and measure for abrasion, cracks, erosion and rust on the runner, guide vane and casing interior. ✓ Measure the runner gap and guide vane gap. ✓ Check the bearing lubricant quality * Test: automatic start/stop
Inlet Valve	Inlet valve internal	<ul style="list-style-type: none"> ✓ Measure leakage. Inspect for abrasion and erosion and erosion. Measure sheet surface clearance. ✓ Inspect position indicator conditions.
Speed Governor	Mechanism	✓ Inspect for abrasion of movable parts. Loose wiring/lever and strainer overhaul.
	Controller	✓ Inspect the conditions of the printed circuit board and position transducer. Measure the insulation resistance.
Oil Pressure Supply and Lubrication oil System	Performance	✓ Measure load operation time.
	Oil filtration	✓ Test oil quality.
Water Supply and Drainage System	Strainer overhaul	✓ Inspect abrasion and erosion.
Generator	Generator internal	<ul style="list-style-type: none"> ✓ Inspect for loose electric circuit terminals, discoloured, peeled or loose coil, abrasion and damage to slip ring, loose and rusted revolving part. ✓ Measure brush contact pressure and insulation resistance of electric circuit.
	Brake equipment	✓ Inspect for shoe abrasion loss and operation condition.
	Neutral grounding resistor	✓ Measure resistance and insulation resistance.
Control Panels, etc.		✓ Performance test of all relays.
Internal Inspection		
Turbine	Overhaul	<ul style="list-style-type: none"> ✓ Measure abrasion loss at each part of turbine. ✓ Inspect the sliding area and packing for damage and fine cracks on turbine. ✓ Measure the damage and gap on the sliding surface of bearing. ✓ Calibrate the cooling water pipe pressure resistance, thermometer and oil gauge. * Replace worn parts * Test: load rejection, vibration measurement, stroke output, automatic start/stop.
Inlet Valve	Overhaul	<ul style="list-style-type: none"> ✓ Inspect damage to movable part and sliding area. ✓ Inspect for abrasion and erosion. ✓ Inspect for damage to the packing and the sealing condition. Replace worn parts.
Speed Governor	Overhaul	<ul style="list-style-type: none"> ✓ Overhaul movable part and Speed Signal Generator (SSG). ✓ Replace worn parts. * Test: characteristics measurement and load rejection.
Oil Pressure Supply and Lubrication oil System	Overhaul	✓ Inspect for abrasion and damage to internal movable part and sliding area, and motor insulation resistance.
	Performance test	<ul style="list-style-type: none"> ✓ Measure pump discharge and grease feed volume ✓ Performance test of sensors, detectors, and protection relays
Water Supply and Drainage System	Overhaul	✓ Inspect for abrasion and damage to internal movable part and sliding area, and motor insulation resistance.
	Performance test	✓ Measure water supply and drain volume.
Generator	Rotor lifting	<ul style="list-style-type: none"> ✓ Inspect for loose rotor core and winding. ✓ Measure winding deterioration. ✓ Inspect loose wedge, flaking varnish, and rust.
	Overhaul	<ul style="list-style-type: none"> ✓ Brake equipment, bearings and air cooler overhaul. * Measure shaft current. * Exciter characteristic test.
Control Panels, etc.		✓ Performance test of all relays

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Table 15-5)" published by JICA in 2011.

(3) Spare Parts

Spare parts shall be stored in the powerhouse for quick correction and recovery from abnormalities and breakdowns. The variety and quantity of spare parts are determined according to: their frequency of breakdown, the manufacturing period, the importance level, and so on. The storage location is determined on the basis of the haul distance and other conditions.

Examples of spare parts for a MHP station are shown below.

Table 8.3.4 Common Spare Parts for Electrical Equipment

Component	Part Name	Quantity	Remarks
Turbine Main Unit	Main bearing metal	For 1 unit	The replaced parts can be utilized as auxiliary parts after repair of damaged parts.
	Guide vane weak point pin	For 1 unit	
	Searing packing	For 1 unit	
	Runner	For 1 unit	
	Guide vane	For 1 unit	
	Nozzle tip	For 1 unit	
	Bucket	For 1 unit	
Governor	Printed circuit board	1 each	
	Moving coil	1	
	Various springs	1 each	
Oil Pressure Supply and Lubrication Oil System	Oil pressure lubricant pump	1 unit	In case the auxiliary system is not installed only.
	Un-loader spring	1	
	Safety valve spring	1	
Air compressor	Pressure reduction valve	1	
Automatic control system	Solenoid for electromagnetic valve	1	In case the auxiliary system is not installed only.
Generator Main Unit	Thrust bearing metal	For 1 unit	
	Guide bearing metal	For 1 unit	
	Stator coil	5 to 10	
	Brush holder	For 1 unit	
Exciter	Printed circuit board	1 each	
	Field breaker coil	1	
	Semiconductor rectifier	For 1 phase	
Transformer	Bushing	For 1 phase	Not stored if available from other stocks.
	Bushing board	1	
Switchgear, Breaker	Bushing	For 1 phase	Not stored if available from other stocks.
	Fixed and movable contact	For 1 phase	
	Switching coil	1 each	
Switchgear, Disconnecting switch	Switching coil	1 each	
Control Panel	Printed circuit board	1 each	
Generator Main Circuit	Current transformer (per model)	1 each	Not stored if available from other stocks.
	Instrument transformer (per model)	1 each	

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Table 15-6)" published by JICA in 2011.

8.3.4 Distribution Facilities

Distribution facilities shall be maintained efficiently and properly in order to operate the system safely and prevent accidents.

To realize this objective, major operation and maintenance works for the distribution facilities are required as explained below. All results of operation and maintenance activities should be described in the defined form and reported to the person in charge.

(1) Scheduled Outage


Planned outages are necessary to check distribution facilities and conduct repairs. A planned outage shall be planned and executed taking the followings into consideration:

- ✓ The procedure for installation and operation of the switches and grounding short-circuit equipment etc. shall be decided in detail at the initial stage,
- ✓ The safety of works shall be ensured,
- ✓ The outage period shall be minimized to mitigate inconveniences to customers, and
- ✓ The executing date and times shall be communicated to the affected consumers in advance.

(2) Fault Recovery

In case electricity failure occurs, it is preferable to restore power as soon as possible. The fault will often be accompanied by damage to the equipment, and the safety of the community and workers shall be considered adequately.

The basic procedure of accident restoration works is shown below. As shown in the figure, regular practice of accident restoration and preparation of materials and tools are essential for early fault recovery.



Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Chapter 15.4)" published by JICA in 2011 (arranged by WG).

Figure 8.3.3 Basic Procedure of Accident Restoration Works

(3) Measurement

Regular measurement of voltage, current, and ground resistance, etc. of the system at peak and off-peak is important to check the status of the distribution line and conduct maintenance. When they are out of the permissible ranges it is also necessary to take measures to restore them to the acceptable ranges.

A watt-hour meter should be set up on the secondary side of the transformer in order to detect both technical losses and non-technical losses such as stolen electricity. Whether electricity is being stolen

can be determined by comparing the indication of the meter to the total amount of power supplied by the transformer.

(4) Maintenance

Periodic patrol and annual inspection of distribution facilities are the major maintenance activities.

- ✓ Periodic Patrol (weekly or monthly)
General patrol of the entire distribution facilities to clear out flying obstacles, broken facilities, fallen trees, obstructive building constructions, etc.
- ✓ Annual Inspection (yearly)
Detailed inspection to identify signs of degradation and damage in the distribution system.

Basically, these patrols and inspections are carried out without interruption of power supply. Lastly, the maintenance check sheets shall be prepared in advance.

8.4 Assistance for Management Board

In case of MHP development in rural areas, a new management body should be established and operated by local residents. The members of the management body might not have any experience or knowledge of electrical utility services.

Therefore, assistance for management board should include training of their staff who have minimum ability to operate and maintain the electricity utility service, which is essential to commence power generation and successful electrification.

8.4.1 Assistance before Commencement of Power Generation

Once an electrical supply service is commenced, it is difficult to commit a significant amount of time for the training as the number of staff in the management board is limited. Therefore, it is necessary to conduct the training before the commencement of supply services and simultaneous with the planning or construction stage of MHP project.

To develop human resource capacities of the staff of management board, the assistance program shall include:

- ✓ “On the job training (OJT)” through the practice of management, operation, and maintenance of the existing hydropower plant, and
- ✓ Technical training carried out by experts working for parastatals or aid agencies related to electric power generation.

The following items should be effectively considered for planning and putting into practice the assistance program.

- i) To arrange for opportunities for staff to be involved in the construction work in order to increase their understanding of facilities and mechanisms, and to gain experience in operation and troubleshooting
- ii) To arrange for opportunities for staff to attend lectures in training centers of parastatals and/or vocational training schools in order to learn basic electrical knowledge and safety matters before actual operation.
- iii) To establish a monitoring system to check the learning and skills level of staff after the commencement of operation.
- iv) To establish and implement periodic auditing of management and operations by related government authorities.

Major items to provide guidance and training of the management board are summarized below:

Table 8.4.1 Major Assistance Items of Management Board

Responsible Person	Assistance Item	Description
Representative and Manager	Establishment of management body and joint steering committee.	To provide technical guidance on development of rules and on how to operate the organization when the management body is established, and help it establish joint steering committee.
	Arrangements to obtain the business license.	To provide technical guidance on how to prepare an application form for electricity business license, and to help them become capable of obtaining the license.
	Start-up of power supply business.	To check management of power utilization during test operation, advise on points for improvement, and help the local staff continuously carry out their own management.
Administrative Staff	Outline and functions of power facilities.	To help the trainees learn the basics of power plant facilities and understand the roles of the staff through lectures, including visits to the site.
	Lecture on electricity charge system	To hold a lecture on the concept of electricity charge and its system so that the trainees can learn the background of the work of 3) and 4).
	Development of office management manuals	To help the trainees complete the office management manuals based on the draft prepared in advance and establish the work flow through workshops.
	Guidance on work procedures	To help the trainees memorize the work procedures such as recording energy consumption, issuing and sending invoices, and collection of electricity charges, etc., through lectures and field practice.
Technical Staff	Outline and functions of power plant facilities	To help the trainees learn the basics of power plant facilities and understand the roles of the staff through lectures, including visits to the site.
	Guidance on functions and structures of facilities	To help the trainees understand the functions and structures of the civil structures, electrical equipment and distribution facilities through lectures and field visits.
	Preparation of operation and maintenance manuals	To help the trainees complete the manuals based on the draft prepared in advance and establish the work flow through workshops.
	Guidance on inspection, maintenance and repairing	To help the trainees learn how to conduct daily inspection, mainly through field practice, and be capable of judging repair necessity.
	Guidance on documentation of maintenance	To help the trainees become capable of filling in inspection sheets, mainly through field practice.

Source: "Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower (Chapter 16.2)" published by JICA in 2011.

8.4.2 Assistance after Commencement of Power Generation

Assistance after the commencement of the power supply service is also necessary because of the following reasons:

- ✓ Initial troubles during operation will often occur within the first one year,
- ✓ Some contradictions among the regulations and/or manuals which are apparent, as well as problems which had not been anticipated, occur within a few years,
- ✓ In case of hydropower generation, the manner of operation varies between rainy seasons and dry seasons and depends on the natural river flow. At the same time, power demand also changes with the seasons,
- ✓ Repeated training on actual situations is required to improve staff capacities to conduct inspection, operation and maintenance, troubleshooting etc., and
- ✓ The status of power generation, charge collection and expenses shall be audited to determine whether the management board is executing their responsibilities properly.

Taking into consideration the above situations, elaborate assistance by experts is indispensable for 2 to 3 years after the commencement of power supply service. Major items to guide and train the management board are similar to the items required before the commencement of power generation. Coaching is carried out practically.

Simultaneous with the coaching; documents such as regulations, workflow, manual, etc., shall be reviewed based on the actual situations, and modified as required.

REFERENCES

- Agency for Natural Resources under Ministry of Economy, Trading and Industry of Japan (2013) Handbook for Estimation of Hydropower Project Costs
- Electric Technology Research Association in Japan, 20kV Distribution Method (Overhead Edition), Vol. 3 No.3
- IEEJ standard JEC-4001 Hydro Turbine and Pump Turbine
- IEEJ Webpage (<http://www.jeea.or.jp/course/contents/12125/>)
- JICA (2013) Project on the Development of the National Water Master Plan 2030, Sector Report B
- JICA (2011) Guideline and Manual for Hydropower Development, Vol. 2 Small Scale Hydropower
- JICA (2003) Study on Introduction of Renewable Energies in Rural Areas in Myanmar, Final Report Volume 4, Part 4-2 Design Manual – Small Hydros and Part 4-3 Design Manual – Village Hydros
- National Museums of Kenya (<http://www.museums.or.ke/content/view/248/127/>)
- NEDO of Japan (2003) Guidebook on Micro Hydropower Introduction
- NEMA (2011) Kenya State of the Environmental and Outlook 2010
- NEMA (2010) Guidelines for E-Waste Management in Kenya
- New Energy Foundation under Ministry of Economy, Trading and Industry of Japan (1996) Guide Manual for Development Aid Programs and Studies of Hydro Electric Power Development
- PPOA, Public Procurement and Disposal General Manual
- REA (2009) Rural Electrification Master Plan August, Final Report Volume 1 – Main Report
- Rural Development Bureau in Ministry of Agriculture, Forestry and Fisheries of Japan (2001) Planning and Designing Criteria for Agricultural Land Improvement Project
- WRMA (2007) Water Resources Management Rules
- WRMA website (<http://mangomap.com/maps/8325/KENYA>)

Annex-1

Simulated Monthly Surface Water by Sub-basin in NWMP 2030

Annex-1 Simulated Monthly Surface Water by Sub-basin in NWMP 2030

Table of Contents

1.	Lake Victoria North Catchment Area (LVNCA)	3
	1AA, 1AB, 1AC, 1AD, 1AE, 1AF, 1AG and 1AH.....	3
	1BA, 1BB, 1BC, 1BD, 1BE, 1BG & 1BH.....	5
	1CA, 1CB, 1CC, 1CD & 1CE.....	8
	1DA, 1DB, 1DC & 1DD	9
	1EA, 1EB, 1EC, 1ED, 1EE, 1EF & 1EG	11
	1FA, 1FB, 1FC, 1FD, 1FE, 1FF & 1FG.....	13
2.	Lake Victoria South Catchment Area (LVSCA)	15
	1GA, 1GB, 1GC, 1GD, 1GE & 1GG	15
	1HA1, 1HA2, 1HB1, 1HB2, 1HD, 1HE & 1HG	17
	1JA, 1JB, 1JC, 1JD, 1JE, 1JF, 1JG1 & 1JG2.....	20
	1KA, 1KB & 1KC.....	22
	1LA1, 1LA2, 1LA3, 1LB1 & 1LB2.....	23
3.	Rift Valley Catchment Area (RVCA)	25
	2BA, 2BB & 2BC.....	25
	2CB	26
	2EA, 2EB, 2EC, 2ED, 2EE, 2EF, 2EG1, 2EG2, 2EH & 2EK	26
	2FB	30
	2GA, 2GB, 2GC & 2GD	30
	2KA	31
4.	Athi River Catchment Area (ATCA).....	32
	3AA	32
	3BA, 3BB, 3BC & 3BD	32
	3CB & 3DA.....	34
5.	Tana River Catchment Area (TNCA).....	35
	4AA, 4AB, 4AC & 4AD	35
	4BA, 4BB, 4BC, 4BD, 4BE, 4BF & 4BG.....	36
	4CA, 4CB & 4CC.....	38
	4DA, 4DB, 4DC & 4DD	39
	4EA, 4EB, 4EC & 4ED	41
	4FA & 4FB.....	42
	4GA	43
6.	Ewaso Ngiro Catchment Area (ENCA).....	43
	5AA & 5AB	43
	5BA, 5BB, 5BC1, 5BD & 5BE.....	44
	5DA	46

1. Lake Victoria North Catchment Area (LVNCA)

1AA, 1AB, 1AC, 1AD, 1AE, 1AF, 1AG and 1AH

Sub-basin: **1AA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	1.34	0.89	0.93	3.48	10.70	4.90	3.56	3.37	2.90	6.39	3.05	1.52
1992	0.92	0.74	0.81	0.79	4.11	3.55	4.32	3.41	3.72	7.17	3.57	1.81
1993	1.24	1.06	1.02	0.86	5.29	4.75	2.69	2.08	4.31	4.03	2.70	1.42
1994	0.88	0.74	0.78	1.00	11.29	4.82	2.83	3.92	3.73	2.48	7.62	3.66
1995	1.06	0.73	0.81	1.33	5.77	3.71	3.23	3.80	6.64	3.78	3.80	1.77
1996	0.95	0.88	1.10	7.43	9.77	6.72	4.65	3.43	8.58	6.71	3.57	2.77
1997	1.10	0.71	0.76	4.24	9.37	3.52	3.24	3.45	2.01	6.63	11.61	7.12
1998	9.12	3.42	1.61	3.37	9.29	5.50	6.00	5.10	5.01	8.73	8.00	1.70
1999	1.00	0.78	1.34	9.29	11.48	4.53	3.81	5.52	5.53	13.48	4.24	2.68
2000	1.28	0.80	0.78	0.75	2.70	2.99	2.91	3.73	3.01	5.57	4.63	2.66
2001	1.41	1.00	0.88	3.96	6.88	3.94	2.67	2.70	2.45	3.22	5.87	1.78
2002	0.87	0.70	0.74	0.84	10.67	3.45	1.65	1.02	0.85	1.17	2.36	2.96
2003	2.94	0.88	0.80	3.38	14.82	6.72	5.75	3.51	5.26	2.16	1.72	1.29
2004	0.94	0.74	0.78	1.82	6.71	2.70	1.71	2.73	3.18	3.91	6.97	2.43
2005	1.17	0.71	0.72	0.84	7.99	5.60	3.86	1.97	2.11	3.55	3.33	1.17
2006	0.76	0.66	1.07	11.38	7.05	4.98	3.06	3.86	6.90	5.33	9.64	8.67
2007	3.22	1.78	1.36	1.89	8.30	5.66	5.95	6.74	7.49	5.04	3.12	1.17
2008	0.76	0.65	0.70	2.44	6.36	7.55	2.88	5.13	9.63	9.58	7.76	1.85
2009	0.82	0.72	0.71	2.45	11.56	4.71	2.39	2.39	5.86	4.84	3.00	2.75
2010	5.37	1.34	5.00	7.92	9.88	6.27	6.49	4.00	9.43	11.37	5.72	2.74

Sub-basin: **1AB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	3.20	2.34	2.41	7.04	15.75	9.96	9.82	10.45	8.65	13.98	6.96	3.58
1992	2.34	1.89	2.05	2.06	6.47	8.03	9.73	9.26	8.44	15.78	7.44	3.70
1993	2.83	3.20	3.01	2.37	11.79	10.01	6.54	5.86	10.02	8.79	5.97	3.26
1994	2.18	1.85	1.95	2.08	18.45	11.02	7.30	10.34	8.44	5.03	13.55	7.40
1995	2.62	1.86	2.06	2.33	9.59	7.75	7.59	9.45	13.22	8.20	8.11	3.94
1996	2.38	2.23	2.79	13.22	18.37	13.21	9.48	9.09	16.21	11.11	7.28	5.24
1997	2.56	1.78	1.86	8.22	17.75	7.36	7.98	9.34	4.59	9.38	19.86	11.12
1998	17.96	8.17	4.61	7.25	17.48	11.84	14.60	12.69	11.08	18.02	16.56	4.08
1999	2.49	1.93	3.04	15.25	20.16	9.90	8.93	10.87	8.85	23.78	8.77	4.19
2000	2.56	1.90	1.93	1.86	5.86	7.19	7.42	8.92	7.71	12.51	7.94	5.00
2001	2.98	2.24	2.25	7.50	12.55	9.15	7.36	7.58	5.99	7.64	13.58	4.51
2002	2.23	1.76	1.89	2.09	15.58	7.63	4.45	3.30	2.65	3.54	3.92	4.78
2003	6.48	2.17	1.97	5.23	29.72	13.69	13.62	9.14	11.92	4.92	3.30	2.72
2004	2.17	1.78	1.88	4.72	14.64	6.27	4.16	6.90	6.13	6.23	12.06	5.85
2005	3.30	1.94	1.85	2.43	15.83	10.74	9.27	5.01	6.42	7.14	6.85	2.73
2006	1.86	1.60	2.45	19.02	12.95	10.43	7.10	10.38	15.06	10.36	18.87	15.42
2007	6.96	3.74	3.42	5.11	15.80	12.80	14.23	16.85	18.63	11.06	5.77	2.73
2008	1.91	1.63	1.75	3.70	11.78	16.37	6.94	12.24	13.89	16.95	13.77	4.02
2009	2.06	1.79	1.76	3.62	20.46	10.11	5.48	7.51	12.08	10.90	6.17	5.12
2010	10.81	3.36	10.24	17.01	20.83	12.55	13.90	8.98	18.42	21.91	11.68	6.38

Sub-basin: **1AC** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.03	0.00	0.00	0.00	2.97	1.71	1.20	1.10	0.67	1.85	1.04	0.07
1992	0.00	0.00	0.00	0.00	0.00	0.01	1.06	1.23	0.90	2.57	1.44	0.24
1993	0.00	0.00	0.00	0.00	0.20	1.76	0.78	0.57	1.79	1.25	0.67	0.03
1994	0.00	0.00	0.00	0.00	2.05	2.28	1.10	1.52	1.45	0.44	1.86	1.59
1995	0.03	0.00	0.00	0.00	0.55	1.45	1.04	1.08	2.11	1.21	1.22	0.40
1996	0.00	0.00	0.00	2.69	5.15	3.03	1.74	1.12	3.08	2.55	1.46	0.79
1997	0.02	0.00	0.00	0.29	4.71	1.30	1.45	1.45	0.51	1.65	4.83	2.45
1998	3.83	1.21	0.25	0.40	4.14	2.68	3.50	2.26	2.19	3.87	3.54	0.31
1999	0.00	0.00	0.00	4.20	5.01	2.20	1.62	2.28	2.00	6.30	1.91	0.21
2000	0.00	0.00	0.00	0.00	0.01	0.61	0.91	0.96	0.78	1.51	1.21	0.62
2001	0.06	0.00	0.00	0.36	2.52	1.19	0.40	0.26	0.18	0.29	1.03	0.22
2002	0.00	0.00	0.00	0.00	1.19	1.69	0.43	0.02	0.00	0.00	0.00	0.02
2003	0.95	0.01	0.00	0.00	7.05	3.13	3.05	1.20	2.28	0.72	0.13	0.00
2004	0.00	0.00	0.00	0.00	2.12	0.92	0.26	0.54	0.62	0.69	1.69	0.86
2005	0.10	0.00	0.00	0.00	2.15	2.29	1.17	0.27	0.33	0.68	0.91	0.05
2006	0.00	0.00	0.00	4.49	2.92	2.10	1.34	1.46	3.10	1.76	4.04	3.81
2007	1.40	0.28	0.03	0.15	3.09	2.93	2.65	2.90	3.11	2.32	1.18	0.06
2008	0.00	0.00	0.00	0.01	2.34	3.93	1.06	1.81	3.45	4.26	3.06	0.46
2009	0.00	0.00	0.00	0.01	4.82	2.47	0.87	0.54	2.03	1.93	0.69	0.38
2010	1.82	0.26	1.79	3.43	3.88	2.52	2.84	1.32	3.93	5.66	2.92	0.99

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **IAD** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	1.74	1.00	1.09	3.53	17.13	6.36	4.47	2.79	1.82	3.21	4.11	1.77
1992	1.02	0.81	0.88	0.88	2.65	5.01	5.46	3.70	3.63	6.89	5.55	3.03
1993	1.96	1.37	1.14	0.98	5.22	6.38	3.10	1.93	3.94	4.04	3.09	1.70
1994	0.99	0.79	0.91	2.77	15.32	6.80	4.02	3.92	4.43	3.15	8.61	6.31
1995	1.32	0.85	1.09	2.86	8.66	6.01	4.27	3.11	5.95	5.80	5.49	2.86
1996	1.25	1.49	2.05	11.31	13.21	8.34	5.70	3.74	9.63	9.69	5.39	4.02
1997	1.45	0.80	0.80	3.33	12.97	4.93	4.37	3.85	2.73	9.04	14.68	10.75
1998	11.37	4.58	2.00	3.24	12.50	6.43	6.29	3.64	4.41	8.75	9.41	2.18
1999	1.20	0.91	1.56	12.26	15.17	6.55	4.71	5.52	8.84	18.18	6.18	5.13
2000	2.05	0.99	0.90	0.86	2.43	3.14	2.41	2.77	2.77	4.40	6.40	5.06
2001	2.44	1.53	1.13	5.10	9.66	5.39	2.72	1.88	2.03	2.73	4.09	1.94
2002	0.95	0.74	0.81	1.22	13.71	5.23	2.20	1.19	1.03	2.06	5.72	3.88
2003	4.13	1.07	0.95	3.94	17.12	8.69	7.24	3.29	5.14	3.01	2.73	2.05
2004	1.33	0.94	0.96	1.72	8.00	3.28	1.89	2.34	3.27	6.52	9.00	3.68
2005	1.27	0.74	0.77	0.98	7.36	7.31	4.53	2.27	1.61	2.90	4.37	1.41
2006	0.82	0.70	1.38	13.49	9.66	5.72	3.30	2.98	6.28	6.19	10.92	11.99
2007	4.88	2.82	1.56	1.99	9.22	6.90	4.52	6.03	6.45	6.32	4.66	1.52
2008	0.83	0.70	0.75	2.43	8.16	8.48	3.42	4.53	16.20	11.76	11.86	2.73
2009	0.92	0.84	0.75	2.71	13.86	5.60	2.88	1.54	3.47	5.07	4.01	2.71
2010	6.68	1.68	4.87	7.09	9.73	6.74	6.61	3.57	7.78	12.16	7.39	3.18

Sub-basin: **IAE** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.99	0.63	0.72	2.03	9.07	3.32	1.94	1.03	0.79	1.39	1.91	1.22
1992	0.69	0.51	0.55	0.54	2.49	2.20	2.04	1.44	1.70	2.78	2.33	1.63
1993	1.18	0.81	0.69	0.64	2.23	2.84	1.37	0.77	0.95	1.39	1.34	1.00
1994	0.64	0.50	0.58	1.84	6.73	2.63	1.64	1.28	1.46	1.77	4.04	2.93
1995	0.79	0.52	0.75	2.19	4.09	2.49	1.60	1.12	2.40	2.63	2.37	1.21
1996	0.77	0.79	1.20	3.35	4.11	3.16	2.38	1.60	3.18	3.44	2.31	1.50
1997	0.76	0.48	0.50	0.78	3.92	1.99	1.44	1.25	1.01	4.61	6.14	5.28
1998	4.35	2.00	0.97	1.51	4.84	2.25	1.38	0.89	0.97	2.27	3.11	1.06
1999	0.71	0.58	0.74	4.75	5.55	2.45	1.71	2.02	3.73	7.96	2.46	3.69
2000	1.22	0.61	0.56	0.52	0.75	0.91	0.80	0.94	1.03	1.68	3.55	2.72
2001	1.42	0.92	0.70	2.06	4.25	2.63	1.33	0.90	1.10	1.55	2.20	1.04
2002	0.59	0.47	0.52	1.56	6.58	1.97	0.89	0.65	0.57	1.19	2.84	1.72
2003	1.38	0.58	0.54	2.31	5.33	3.02	2.23	1.19	1.51	1.19	1.69	1.29
2004	0.87	0.61	0.61	0.82	2.55	1.29	0.89	1.08	1.78	3.39	4.15	1.61
2005	0.62	0.43	0.46	0.49	2.28	2.87	1.97	1.16	0.93	1.81	2.07	0.80
2006	0.50	0.45	0.68	4.02	3.55	1.78	1.12	1.04	1.71	3.01	3.88	4.53
2007	2.06	1.54	0.86	0.94	3.30	2.26	1.42	2.00	1.92	2.09	1.93	0.81
2008	0.50	0.42	0.45	0.77	2.36	2.59	1.24	1.41	6.56	4.90	5.01	1.30
2009	0.57	0.52	0.47	1.08	4.96	1.94	1.25	0.73	1.34	2.15	2.16	1.62
2010	2.35	0.79	2.05	2.28	3.30	2.16	1.51	1.04	1.60	3.26	2.64	1.26

Sub-basin: **IAF** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	2.64	1.82	1.96	5.08	15.81	7.13	4.64	3.27	2.58	4.35	4.18	2.46
1992	1.79	1.47	1.60	1.55	2.11	4.27	5.68	4.09	4.42	7.00	5.62	3.49
1993	2.62	2.05	1.90	1.67	5.16	6.39	3.60	3.30	5.05	4.85	3.75	2.41
1994	1.70	1.43	1.53	2.44	13.50	7.26	4.47	4.38	4.24	3.50	8.62	6.57
1995	2.07	1.45	1.73	3.16	8.34	5.93	4.93	3.67	6.49	6.31	6.65	3.40
1996	2.04	2.20	3.63	13.14	15.21	9.45	6.48	4.06	11.00	11.03	6.16	4.96
1997	2.25	1.43	1.46	3.02	12.87	6.07	5.09	4.99	3.15	8.60	15.29	12.04
1998	12.72	5.30	2.75	4.98	12.86	7.82	7.65	4.78	5.94	9.96	10.47	2.91
1999	2.02	1.62	2.76	13.20	15.81	7.30	5.13	6.58	8.90	18.51	7.20	5.17
2000	2.61	1.68	1.58	1.51	2.91	3.34	3.11	3.67	3.19	5.15	6.09	5.33
2001	3.25	2.29	1.95	7.11	10.77	5.62	3.26	2.54	2.62	3.18	4.36	2.32
2002	1.57	1.34	1.42	1.49	11.67	6.04	2.69	1.91	1.70	2.35	5.90	4.75
2003	4.36	1.65	1.54	3.74	18.34	10.00	7.86	5.00	6.09	3.58	3.23	2.46
2004	1.95	1.53	1.63	3.01	7.91	3.93	2.49	3.03	3.82	6.22	8.95	3.89
2005	1.99	1.31	1.35	1.52	7.37	7.87	4.90	3.01	2.76	4.04	4.30	2.03
2006	1.40	1.23	1.81	14.72	10.62	7.03	4.17	3.56	6.77	6.54	12.15	12.97
2007	5.30	3.14	2.13	3.04	10.34	7.51	5.76	6.76	7.80	7.68	5.65	2.28
2008	1.47	1.25	1.33	3.49	8.82	9.26	4.38	6.20	15.29	12.83	12.08	3.43
2009	1.60	1.47	1.38	3.51	13.93	6.72	3.79	2.40	4.95	5.63	3.99	3.66
2010	6.15	2.51	7.01	7.47	10.44	7.92	6.76	4.93	7.80	12.65	8.40	4.05

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **1AG** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	1.62	0.91	0.95	4.28	13.29	5.58	2.97	1.91	1.53	2.66	3.17	1.41
1992	0.78	0.57	0.61	0.59	1.14	3.41	4.55	2.90	2.98	4.77	3.93	2.31
1993	1.55	1.13	0.95	0.73	3.49	5.18	2.65	1.98	3.70	3.39	2.56	1.39
1994	0.72	0.53	0.58	1.46	11.02	5.75	3.03	2.63	3.05	2.24	6.53	5.17
1995	1.04	0.58	0.84	2.13	7.05	4.53	3.80	2.53	4.55	5.14	5.41	2.61
1996	1.12	1.41	2.33	12.04	12.55	7.69	4.53	2.68	9.13	9.76	4.74	4.07
1997	1.27	0.56	0.54	1.63	10.71	4.78	3.64	3.32	2.14	5.21	12.21	10.44
1998	10.71	3.91	1.69	3.63	10.96	5.78	5.43	3.31	4.05	7.93	8.70	1.91
1999	1.05	0.74	1.41	9.88	13.05	5.65	3.54	4.09	6.86	13.83	5.83	3.72
2000	1.59	0.77	0.61	0.57	1.63	2.17	2.03	2.46	2.17	3.71	4.16	4.13
2001	2.26	1.44	1.00	5.62	9.08	4.59	2.31	1.55	1.66	2.19	3.14	1.38
2002	0.65	0.49	0.52	0.78	10.41	5.04	1.63	0.95	0.81	1.55	5.06	3.87
2003	3.41	0.81	0.63	2.17	15.32	8.29	6.14	3.60	4.75	2.54	2.12	1.44
2004	0.95	0.66	0.70	1.81	6.06	2.98	1.49	1.77	2.39	4.98	7.11	2.93
2005	1.05	0.51	0.49	0.68	5.66	6.57	3.75	2.20	2.12	2.67	3.02	1.15
2006	0.53	0.43	0.93	13.21	9.17	5.96	3.15	2.32	4.41	4.50	10.07	11.23
2007	4.34	1.96	1.17	1.87	8.36	5.98	3.95	4.84	6.11	6.14	4.52	1.37
2008	0.59	0.46	0.47	2.29	7.73	7.64	3.20	4.58	13.37	10.26	10.35	2.52
2009	0.71	0.67	0.51	2.16	11.58	5.25	2.70	1.42	3.21	4.42	2.78	2.22
2010	4.55	1.44	4.96	5.64	8.54	6.34	5.49	3.45	5.99	9.85	6.62	2.85

Sub-basin: **1AH** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.97	0.47	0.50	5.67	15.23	5.37	2.40	1.04	0.69	1.84	2.32	1.28
1992	0.48	0.24	0.22	0.24	2.78	3.06	3.14	1.71	2.99	4.55	3.78	2.50
1993	2.08	0.90	0.61	0.44	4.93	4.92	1.51	0.67	1.61	2.55	2.18	1.06
1994	0.44	0.22	0.30	3.48	13.33	4.42	2.35	2.08	2.21	2.95	8.55	4.46
1995	0.61	0.29	0.54	5.27	7.84	3.61	2.46	1.20	4.95	5.60	5.06	1.66
1996	0.81	0.95	2.86	9.51	9.15	6.22	4.01	1.67	8.13	8.69	3.95	2.84
1997	0.71	0.25	0.18	1.05	8.34	3.63	2.11	1.97	1.07	7.70	13.34	12.16
1998	9.53	2.63	0.87	4.01	9.69	3.75	1.79	0.97	2.32	5.33	5.93	1.04
1999	0.55	0.38	0.42	9.31	12.58	3.84	2.37	3.48	7.33	14.34	4.58	6.65
2000	1.22	0.43	0.28	0.23	0.60	0.94	0.78	1.44	1.40	3.51	7.02	4.60
2001	2.38	1.32	0.67	6.62	8.31	4.91	1.63	1.04	1.99	2.69	4.17	0.99
2002	0.37	0.20	0.23	3.65	12.22	2.78	0.82	0.47	0.40	1.62	7.28	3.05
2003	2.43	0.44	0.30	5.81	10.96	5.78	3.75	1.10	1.92	1.36	2.62	1.37
2004	0.76	0.45	0.45	1.57	5.07	1.97	1.01	1.50	3.35	6.93	8.60	1.85
2005	0.51	0.18	0.14	0.25	5.63	5.48	2.82	1.57	1.38	3.60	3.13	0.68
2006	0.23	0.17	0.54	11.08	8.05	3.55	1.76	1.28	3.55	4.66	8.93	11.24
2007	3.27	2.43	0.89	2.57	8.41	4.24	1.78	2.98	2.87	4.27	3.18	0.80
2008	0.28	0.17	0.15	3.09	6.43	4.40	1.84	3.54	16.16	9.47	10.43	1.36
2009	0.35	0.33	0.18	3.06	10.77	2.92	1.84	0.70	3.03	4.15	3.10	3.00
2010	4.12	0.57	4.61	4.27	7.19	3.70	2.01	1.23	3.29	7.10	4.43	1.60

1BA, 1BB, 1BC, 1BD, 1BE, 1BG & 1BH

Sub-basin: **1BA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	1.75	1.45	1.21	1.93	1.26	6.86	10.34	15.96	6.93	2.94	2.76	1.99
1992	0.93	0.61	0.63	0.68	6.39	5.63	8.54	11.45	6.30	10.06	7.89	2.81
1993	2.75	7.28	2.44	1.08	17.40	8.53	5.11	4.22	3.58	1.65	1.41	2.78
1994	1.09	0.63	0.62	2.43	16.67	12.25	8.91	12.81	4.21	1.41	9.12	4.99
1995	1.26	0.67	0.73	0.96	4.55	2.36	5.93	6.23	7.58	5.22	6.08	2.68
1996	1.45	0.89	1.02	3.97	3.02	13.56	13.36	9.63	8.67	2.61	1.82	2.46
1997	0.92	0.60	0.60	10.90	8.93	2.17	13.11	11.84	2.10	3.03	17.30	11.28
1998	18.42	5.35	1.93	1.67	12.00	4.09	11.69	6.34	3.27	7.91	6.14	1.83
1999	0.82	0.58	0.79	2.67	12.33	2.99	4.66	4.07	3.55	11.43	5.77	3.46
2000	1.11	0.65	0.62	0.58	3.37	3.57	7.59	9.00	4.96	9.65	5.15	3.07
2001	1.53	2.15	1.15	10.35	9.69	9.21	7.19	11.84	6.32	3.39	14.71	3.25
2002	1.15	0.70	0.75	0.86	8.87	2.34	1.60	1.76	1.21	2.20	3.99	6.77
2003	5.75	1.14	0.70	6.09	23.10	7.95	6.88	12.40	6.06	1.44	0.83	0.89
2004	0.72	0.57	0.59	8.07	17.77	2.96	3.62	13.74	3.55	3.56	13.86	4.08
2005	1.82	1.08	0.92	1.91	22.49	9.89	7.07	5.40	10.02	3.58	1.88	0.99
2006	0.66	0.57	0.67	8.52	6.17	2.39	5.78	12.69	4.85	4.62	20.50	13.42
2007	5.11	2.80	1.60	6.21	10.16	18.50	12.99	14.14	12.13	3.63	1.72	0.84
2008	0.65	0.56	0.60	2.55	3.03	4.93	5.61	10.79	9.31	14.56	16.46	2.18
2009	0.83	0.65	0.61	0.61	5.73	3.02	1.59	1.48	1.10	2.11	2.82	2.62
2010	7.26	1.29	14.47	16.06	16.66	6.31	5.20	4.64	8.23	6.64	5.04	1.56

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **IBB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	6.07	4.86	4.71	6.13	5.34	22.43	39.21	53.54	24.65	15.12	10.78	7.04
1992	4.48	3.71	4.03	4.28	21.57	20.61	32.51	41.68	25.14	34.70	23.47	8.68
1993	8.76	20.17	7.87	4.64	54.13	29.84	17.65	14.99	13.97	7.70	6.62	7.90
1994	4.50	3.74	3.93	8.36	53.92	42.96	32.55	43.26	14.92	5.93	26.00	14.90
1995	5.07	3.75	4.11	5.11	14.44	9.65	25.46	23.75	25.24	20.06	21.80	8.46
1996	5.35	3.99	4.53	10.29	11.19	39.12	35.33	30.22	31.81	9.38	8.00	8.39
1997	4.44	3.57	3.86	38.32	30.05	8.98	37.72	36.93	7.42	9.64	45.07	32.72
1998	54.33	20.54	8.50	9.71	42.00	15.51	42.49	24.68	13.69	31.22	23.07	6.73
1999	4.39	3.66	4.73	7.65	35.01	12.63	18.81	14.56	11.45	40.63	20.60	11.32
2000	4.80	3.70	3.94	3.78	17.29	12.08	25.61	30.90	20.28	35.09	17.07	9.15
2001	5.55	6.07	4.51	23.81	32.79	34.59	26.61	38.97	22.22	14.56	48.00	10.64
2002	4.84	3.79	4.03	4.23	27.27	8.04	6.16	7.34	5.57	9.70	11.11	17.13
2003	18.30	4.51	3.89	19.52	77.99	31.63	30.38	39.52	22.84	5.94	4.19	4.19
2004	3.90	3.42	3.74	23.27	55.43	11.38	11.86	42.79	12.25	11.07	38.72	12.68
2005	6.23	4.29	4.17	4.82	58.80	32.42	25.23	17.74	29.60	12.35	7.11	4.62
2006	3.88	3.54	3.94	22.04	20.07	8.19	15.60	40.44	21.35	13.92	56.41	42.21
2007	15.84	9.02	5.85	17.02	32.24	54.83	40.92	49.83	46.81	14.77	6.59	4.40
2008	4.07	3.62	3.98	9.08	8.06	21.73	20.20	39.13	28.07	39.07	52.36	7.76
2009	4.44	3.78	4.02	3.90	16.97	10.23	6.61	6.80	5.85	9.79	9.39	7.88
2010	22.12	5.19	37.74	46.36	56.90	22.10	21.09	17.30	26.31	21.56	15.29	5.91

Sub-basin: **IBC** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	2.20	1.70	1.68	2.64	3.80	10.56	18.63	23.01	13.41	12.58	8.74	3.67
1992	1.98	1.53	1.67	1.63	3.35	7.93	15.42	18.86	13.88	17.07	9.26	3.60
1993	2.65	5.02	3.81	1.95	16.99	14.54	8.42	6.78	9.05	6.91	4.11	2.68
1994	1.81	1.52	1.65	1.36	14.65	18.26	13.23	19.36	10.73	4.58	8.97	6.58
1995	2.31	1.57	1.73	1.47	3.23	5.02	14.27	13.32	13.96	11.01	10.28	4.30
1996	2.33	1.65	1.64	2.12	5.27	9.17	7.05	9.45	15.82	7.77	4.69	3.85
1997	1.98	1.48	1.56	7.83	15.08	5.47	9.68	12.82	4.81	2.65	8.88	8.34
1998	16.83	9.80	5.88	4.54	16.41	10.20	16.64	13.75	10.19	16.77	15.24	4.58
1999	2.08	1.49	1.56	1.48	6.03	6.40	8.58	7.70	5.99	15.03	9.92	4.31
2000	2.06	1.47	1.55	1.46	4.20	4.34	7.78	13.71	12.72	17.39	8.57	4.28
2001	2.11	1.81	1.65	2.55	10.46	16.31	14.24	15.25	10.22	10.70	22.23	6.77
2002	2.34	1.57	1.68	1.68	8.28	4.93	3.93	3.99	3.47	3.53	3.11	2.45
2003	5.62	1.95	1.54	2.86	29.67	16.18	21.62	14.29	14.28	4.76	2.46	2.02
2004	1.57	1.37	1.48	2.34	14.22	5.70	4.48	11.07	6.66	4.80	9.02	6.26
2005	3.16	1.77	1.51	1.54	10.73	12.97	11.99	7.82	7.91	6.67	4.39	2.10
2006	1.48	1.32	1.41	1.84	5.29	5.02	4.65	13.05	13.67	8.20	15.95	14.79
2007	5.83	2.95	2.58	3.45	9.93	17.00	15.39	25.41	26.23	11.66	3.33	1.84
2008	1.48	1.31	1.42	1.25	1.74	7.59	8.28	18.21	10.07	8.84	13.42	3.96
2009	1.71	1.35	1.41	1.40	2.71	4.27	2.83	4.74	6.23	7.27	5.04	2.83
2010	6.73	2.19	4.50	11.98	27.06	11.32	11.07	9.37	11.14	11.82	7.89	3.11

Sub-basin: **IBD** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	5.14	4.44	4.74	5.61	6.42	9.48	12.89	17.86	15.35	12.95	9.23	6.54
1992	5.01	4.25	4.67	4.48	6.68	8.43	12.06	16.62	13.15	15.37	11.32	6.34
1993	5.36	5.63	5.84	4.61	9.27	12.28	8.84	7.78	9.48	8.10	5.82	5.24
1994	4.59	4.18	4.41	3.75	13.57	15.03	13.34	16.67	12.63	7.09	9.32	8.79
1995	5.08	4.11	4.50	4.13	6.82	7.01	8.82	12.50	14.19	9.58	8.66	5.94
1996	4.77	4.03	4.33	4.95	6.26	8.73	10.72	13.10	14.31	8.52	5.61	5.01
1997	4.36	3.83	4.19	4.80	15.12	6.79	9.46	12.61	6.42	4.92	10.68	12.24
1998	14.80	9.99	6.94	6.10	15.52	10.61	12.32	18.05	11.86	13.96	13.69	6.57
1999	4.76	3.99	4.36	4.06	11.10	8.30	8.81	9.92	8.38	12.19	9.70	6.22
2000	4.69	3.90	4.25	4.09	4.47	5.66	8.95	11.44	12.43	12.89	8.90	5.97
2001	4.70	4.11	4.24	4.22	7.88	11.88	12.69	13.71	12.39	9.62	17.23	8.35
2002	4.83	3.99	4.23	4.13	9.95	7.53	6.31	6.15	5.34	5.06	4.73	4.41
2003	8.48	4.24	4.04	3.09	23.16	12.11	12.57	10.93	14.31	6.53	4.47	4.28
2004	4.03	3.58	3.93	3.93	13.67	7.75	6.48	10.22	8.68	7.63	9.65	8.47
2005	5.32	3.92	3.97	3.96	8.01	12.97	10.37	9.14	8.99	8.04	5.71	4.25
2006	3.87	3.57	3.80	5.22	10.32	8.05	7.92	15.49	14.14	9.63	14.15	15.72
2007	10.30	6.76	6.29	6.13	9.90	12.88	16.50	19.19	22.52	11.75	5.51	4.44
2008	4.16	3.71	4.08	3.78	4.41	7.83	8.28	13.34	12.50	11.94	17.95	6.46
2009	4.38	3.77	4.08	3.98	6.90	8.29	5.89	7.98	9.44	10.15	7.82	5.73
2010	12.00	5.14	7.13	13.96	25.20	12.22	13.24	10.13	16.92	14.38	9.31	5.65

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **IBE** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	3.43	2.29	2.03	4.75	7.87	24.14	43.11	52.49	31.88	31.52	22.32	7.59
1992	2.84	1.86	1.97	2.07	4.64	14.09	29.66	42.29	32.09	40.80	22.25	7.17
1993	4.68	8.60	7.99	3.03	30.44	32.79	18.49	13.70	19.23	15.53	9.03	4.83
1994	2.28	1.73	1.83	0.79	29.26	39.38	27.51	43.13	26.64	9.28	18.90	16.32
1995	3.91	1.94	2.16	1.62	5.85	10.90	31.12	34.28	32.37	25.71	23.58	9.15
1996	3.80	2.16	1.94	3.76	14.00	19.30	13.55	17.25	35.39	19.76	9.72	6.45
1997	2.49	1.56	1.60	7.15	38.89	12.76	18.88	29.27	10.95	4.19	16.27	18.60
1998	33.83	23.51	15.58	11.29	38.06	26.41	31.49	33.17	24.27	38.54	39.15	10.82
1999	3.18	1.73	1.69	0.96	9.66	13.54	18.48	18.04	13.27	30.28	23.82	8.65
2000	3.03	1.61	1.60	1.51	3.48	7.60	14.15	26.90	29.40	37.67	19.89	8.24
2001	3.04	2.29	1.80	2.71	18.19	37.00	31.02	34.39	24.11	23.25	53.43	16.72
2002	3.97	1.86	2.05	2.15	16.74	11.31	8.40	8.78	7.81	7.20	5.80	2.92
2003	10.52	3.01	1.52	0.39	65.46	34.15	49.69	29.19	33.96	10.65	4.37	3.05
2004	1.75	1.34	1.39	1.61	23.52	13.09	8.27	16.57	15.14	9.86	18.07	14.17
2005	5.92	2.54	1.45	1.66	16.37	30.51	28.87	17.25	14.15	15.89	10.18	3.32
2006	1.38	1.10	1.21	1.58	11.30	12.95	11.55	27.36	33.14	21.19	37.39	34.90
2007	12.02	5.33	4.20	6.04	22.05	35.81	35.37	59.09	63.97	29.96	6.96	2.53
2008	1.49	1.21	1.30	1.03	1.81	12.85	17.86	41.87	25.00	18.39	29.16	8.57
2009	2.13	1.34	1.26	1.33	4.63	9.96	5.60	9.86	14.81	17.92	11.77	4.88
2010	14.69	3.88	6.10	24.57	65.73	26.84	25.34	22.44	25.41	29.12	20.56	6.39

Sub-basin: **IBG** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	6.47	5.30	5.60	11.82	20.92	26.41	33.94	42.74	29.03	38.87	19.52	10.02
1992	6.17	5.00	5.48	5.55	12.28	20.01	31.74	33.19	28.28	40.78	18.32	8.64
1993	6.95	9.58	9.17	6.10	29.55	27.71	17.04	13.92	23.02	19.52	11.50	7.56
1994	5.63	5.00	5.33	4.88	35.17	30.02	24.82	38.35	26.74	13.43	28.90	15.45
1995	6.54	5.01	5.58	5.23	12.31	16.87	26.55	30.15	34.02	23.02	19.16	9.22
1996	6.22	5.06	5.42	7.89	17.39	18.26	16.10	25.37	30.59	18.41	11.60	7.83
1997	5.51	4.66	5.10	12.78	33.59	13.86	16.73	22.81	10.48	7.41	22.12	17.59
1998	29.79	17.23	11.84	10.28	35.77	23.28	24.57	33.22	26.25	40.68	34.11	10.57
1999	5.95	4.68	5.14	5.54	25.16	18.57	19.86	20.46	16.15	32.29	16.82	8.81
2000	5.74	4.58	4.98	4.81	8.14	14.69	20.02	28.35	24.38	36.32	17.21	9.55
2001	6.54	5.10	5.28	7.44	20.15	31.84	31.08	27.43	21.06	27.91	46.31	14.05
2002	6.28	4.78	5.33	5.72	27.49	15.16	12.77	12.61	9.91	9.88	7.99	7.33
2003	14.26	5.74	5.01	7.27	56.49	28.81	36.96	25.91	30.39	12.54	6.84	5.85
2004	5.01	4.35	4.75	5.91	26.62	14.61	11.26	18.14	17.20	13.76	20.87	15.43
2005	8.64	5.36	4.93	5.60	27.15	24.39	24.83	16.20	16.56	15.04	11.64	6.04
2006	4.72	4.28	4.76	12.95	25.14	20.15	16.88	33.20	34.17	22.75	34.50	29.52
2007	14.85	9.20	8.73	10.82	23.58	28.58	33.00	54.63	57.14	25.48	8.40	5.46
2008	4.75	4.19	4.63	4.67	6.50	27.58	18.35	34.18	24.38	23.41	29.54	8.85
2009	5.06	4.30	4.59	5.00	19.89	18.00	9.88	20.92	24.74	26.74	14.57	9.79
2010	20.67	7.17	9.75	34.35	58.11	24.37	31.24	21.99	39.56	37.59	19.63	9.94

Sub-basin: **IBH** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	4.47	3.46	3.62	9.36	16.54	17.38	19.29	24.66	19.29	25.63	12.75	6.36
1992	3.88	3.13	3.40	3.34	8.40	13.06	19.31	20.18	17.25	26.74	12.39	5.69
1993	4.46	5.91	5.33	3.80	19.68	18.18	11.42	9.79	16.48	13.66	8.25	4.91
1994	3.45	3.03	3.20	3.15	22.05	19.98	15.39	22.24	17.63	9.18	20.11	10.52
1995	4.06	3.00	3.26	3.28	10.44	11.74	15.03	18.64	22.54	14.34	12.46	5.88
1996	3.72	3.13	3.41	8.75	16.94	15.55	12.67	15.58	22.32	14.39	9.00	5.81
1997	3.49	2.78	2.99	8.27	23.68	10.32	11.62	14.43	6.70	6.49	20.59	12.97
1998	21.69	11.47	6.99	8.25	25.13	16.65	18.58	22.89	18.48	27.34	24.48	6.78
1999	3.73	2.87	3.32	8.69	23.04	14.37	13.90	14.98	11.76	25.79	11.96	5.63
2000	3.52	2.79	2.99	2.86	6.33	10.39	13.68	17.26	15.80	22.69	11.83	6.42
2001	4.30	3.18	3.24	6.98	14.85	18.48	17.82	16.90	12.33	16.64	27.66	8.73
2002	3.72	2.81	3.00	3.31	19.81	11.41	8.51	7.49	5.65	6.35	5.32	6.18
2003	10.13	3.41	2.96	5.24	39.44	20.62	23.21	16.36	20.60	8.38	4.44	3.62
2004	3.00	2.55	2.74	4.80	18.68	10.42	7.45	12.63	10.72	9.16	14.99	9.88
2005	5.53	3.16	2.86	3.63	20.53	16.70	15.37	9.54	11.00	9.98	8.37	3.71
2006	2.71	2.41	2.86	16.04	19.12	15.21	11.77	21.21	23.03	16.11	24.34	20.79
2007	10.75	6.30	5.88	8.27	18.06	19.59	22.55	32.76	35.99	18.05	6.23	3.55
2008	2.84	2.46	2.69	3.15	8.12	22.43	12.21	20.89	18.13	19.22	20.67	5.84
2009	3.06	2.59	2.68	3.45	19.77	13.73	7.63	15.17	18.59	18.32	9.78	7.45
2010	15.05	4.87	10.31	24.97	37.07	18.63	22.23	14.87	29.14	29.84	15.72	8.32

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

1CA, 1CB, 1CC, 1CD & 1CE

Sub-basin: **1CA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	5.45	4.81	4.96	7.05	6.05	10.30	16.43	16.00	12.08	7.88	6.12	5.76
1992	4.71	4.00	4.37	4.30	9.21	7.80	10.78	16.83	11.38	11.14	10.78	6.27
1993	5.51	6.21	5.80	4.51	8.28	10.74	7.99	7.64	7.67	5.98	4.92	4.73
1994	4.32	3.95	4.20	5.42	20.70	14.53	15.96	15.56	10.00	5.80	6.59	7.08
1995	4.79	3.98	4.48	4.46	10.28	7.24	8.51	11.06	11.92	7.44	6.89	5.85
1996	4.86	4.10	4.71	8.01	6.84	12.08	16.14	14.04	12.31	6.90	4.90	4.72
1997	4.27	3.78	4.15	7.43	12.95	5.79	12.32	13.97	5.71	5.49	14.31	15.11
1998	19.63	10.17	6.35	5.86	14.89	9.27	15.59	16.58	9.35	11.03	9.91	5.88
1999	4.69	4.03	4.71	6.01	12.55	6.76	7.66	9.48	7.78	12.35	9.33	7.79
2000	5.10	4.05	4.34	4.16	4.65	5.01	6.82	10.52	9.98	9.13	7.27	5.32
2001	4.70	4.57	4.42	5.26	8.22	10.87	11.65	14.34	12.49	6.85	12.50	7.10
2002	4.90	4.12	4.29	4.23	11.40	6.70	5.59	5.66	4.97	4.60	4.36	8.95
2003	11.65	4.56	4.19	4.38	21.59	10.41	8.64	11.96	10.79	5.59	4.30	4.26
2004	4.12	3.66	4.02	6.47	20.48	7.27	6.79	11.71	7.72	8.08	8.32	6.77
2005	4.78	3.93	4.18	4.29	11.87	11.11	8.29	10.42	12.17	7.18	4.75	4.17
2006	4.00	3.70	4.00	6.88	9.97	6.78	8.30	19.38	12.77	7.64	15.61	19.71
2007	10.85	8.17	6.60	7.58	10.52	17.58	18.62	17.78	21.50	9.64	5.83	4.74
2008	4.42	3.93	4.31	4.27	4.80	6.74	7.75	13.11	13.65	17.20	23.10	6.64
2009	4.73	4.06	4.36	4.21	5.65	6.21	5.42	6.14	6.15	7.33	7.25	6.28
2010	13.02	5.73	12.40	12.88	22.56	11.12	10.81	12.17	14.69	10.45	7.12	5.25

Sub-basin: **1CB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	5.25	4.38	4.43	9.40	6.63	14.24	21.00	17.66	13.61	7.76	5.75	5.35
1992	3.80	3.06	3.30	4.44	12.96	8.34	14.24	21.67	14.32	13.29	11.90	5.73
1993	5.00	6.05	5.02	3.53	9.26	13.48	8.47	8.61	8.90	5.99	4.73	4.14
1994	3.40	3.03	3.28	8.28	26.95	17.87	20.59	19.32	11.29	5.36	6.30	6.65
1995	3.85	3.12	3.97	4.77	14.23	8.18	11.23	14.33	15.22	7.47	7.23	5.67
1996	4.11	3.40	4.35	10.03	7.19	14.35	18.45	16.48	14.34	6.76	4.23	4.10
1997	3.40	2.94	3.22	11.00	14.96	5.49	15.49	14.87	5.18	5.53	17.55	17.27
1998	22.20	12.44	6.04	5.41	17.01	10.28	19.61	21.28	10.14	12.58	10.91	5.13
1999	3.75	3.16	4.25	6.26	13.47	6.57	8.82	12.22	9.10	16.10	9.89	8.72
2000	4.34	3.21	3.40	3.25	4.35	4.68	7.87	12.92	11.67	9.92	7.30	4.56
2001	4.05	4.69	3.75	4.96	8.48	12.79	14.13	16.79	14.19	6.69	13.66	6.76
2002	4.19	3.38	3.50	3.78	16.44	6.70	5.24	5.59	4.99	3.93	3.69	18.32
2003	14.39	3.97	3.35	3.89	27.33	12.27	9.97	16.84	12.85	5.43	3.60	3.50
2004	3.35	2.95	3.22	8.40	23.50	7.45	7.27	14.42	8.17	9.34	8.04	6.29
2005	4.16	3.32	3.55	3.87	13.48	12.17	8.59	12.14	14.68	6.98	4.09	3.33
2006	3.13	2.91	3.48	9.81	11.41	7.16	10.29	26.92	16.34	7.70	14.71	21.72
2007	12.29	8.74	6.62	8.65	12.09	22.50	22.29	23.59	29.21	10.48	5.42	3.94
2008	3.54	3.13	3.44	4.07	5.13	8.66	10.26	17.48	17.14	18.84	24.34	6.16
2009	3.88	3.28	3.47	3.47	5.87	6.83	5.40	6.67	6.67	9.62	8.86	6.67
2010	16.30	5.68	13.65	12.79	28.57	13.02	14.72	16.70	18.36	12.16	7.06	4.60

Sub-basin: **1CC** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	9.28	7.80	8.34	15.79	13.96	23.17	26.86	20.85	17.70	11.98	10.21	9.29
1992	7.99	6.83	7.43	8.09	19.72	15.30	24.79	29.37	23.46	21.14	17.08	10.49
1993	9.55	10.84	9.98	7.81	17.21	22.32	14.28	15.82	14.64	10.79	10.72	9.73
1994	7.96	7.04	7.54	15.98	36.06	23.72	25.22	25.88	15.70	9.65	12.63	12.24
1995	8.36	7.11	8.84	10.72	20.81	13.17	18.49	18.58	20.39	12.63	13.06	10.50
1996	8.58	7.34	8.72	16.28	13.49	20.42	23.80	24.13	20.14	11.16	8.97	9.75
1997	8.14	6.92	7.50	24.02	20.45	10.13	23.67	17.86	9.82	11.37	28.26	23.47
1998	30.22	18.91	10.84	9.09	21.29	15.43	26.23	25.99	14.34	17.73	16.86	9.86
1999	8.32	7.20	8.96	12.03	17.51	10.92	17.89	22.20	15.06	24.49	14.94	15.03
2000	9.04	7.29	7.86	7.52	9.01	10.45	17.82	20.00	16.62	17.72	12.14	9.35
2001	9.32	11.03	8.55	11.51	17.09	21.73	21.28	21.83	18.08	11.64	19.90	11.21
2002	8.90	7.68	8.10	8.02	23.60	10.74	9.84	12.82	11.98	8.78	8.32	23.60
2003	20.93	8.00	7.74	9.65	36.32	17.60	14.48	26.25	19.52	11.23	8.32	8.18
2004	7.82	6.90	7.56	19.32	27.09	12.38	14.57	22.75	13.08	16.15	15.58	12.79
2005	9.95	7.93	8.70	10.11	25.88	18.17	15.88	17.77	21.75	11.88	9.22	8.02
2006	7.62	7.03	7.83	20.33	15.70	12.45	19.55	32.83	20.90	11.53	18.75	26.57
2007	16.98	12.60	11.48	16.03	19.78	31.69	32.12	33.27	37.39	15.81	10.67	8.87
2008	8.29	7.37	8.12	14.84	13.53	15.90	19.73	26.50	23.34	24.45	26.37	11.06
2009	8.73	7.62	8.19	7.92	13.06	12.23	10.22	11.98	12.68	17.35	14.01	12.40
2010	22.86	10.34	19.47	17.78	34.73	18.95	20.51	21.60	24.24	18.16	12.37	9.71

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **ICD** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	15.54	13.35	13.86	23.52	26.04	37.04	54.43	49.26	37.34	31.34	19.84	16.90
1992	13.14	11.05	12.06	12.94	29.37	28.74	46.79	56.05	41.16	42.27	32.14	17.97
1993	15.47	17.03	15.78	12.40	31.75	38.45	25.16	25.37	28.78	19.87	15.18	13.64
1994	12.07	10.98	11.73	20.37	71.27	48.23	56.35	55.51	34.58	18.37	24.71	22.30
1995	13.42	11.07	12.80	13.63	38.92	28.60	34.93	40.92	42.21	24.24	23.05	18.10
1996	13.68	11.62	13.67	27.78	24.37	38.24	47.79	43.30	39.71	22.20	15.11	14.14
1997	12.12	10.53	11.52	30.35	45.20	18.30	41.61	40.52	17.16	16.98	47.28	42.01
1998	55.01	30.11	17.87	16.22	51.15	32.76	53.66	57.52	31.34	39.72	31.50	16.37
1999	12.79	10.95	13.56	22.74	42.68	23.70	29.46	40.31	28.80	47.05	27.38	21.84
2000	13.85	11.00	11.84	11.37	18.47	19.80	27.78	39.06	34.08	32.94	22.36	15.99
2001	14.51	15.47	12.93	16.94	28.47	38.03	40.01	43.70	39.46	23.03	38.88	20.54
2002	13.60	11.38	11.89	12.12	46.27	21.77	19.27	21.52	17.98	14.67	14.21	37.89
2003	37.30	12.90	11.68	13.35	77.39	38.40	34.31	47.26	38.33	18.98	12.59	12.17
2004	11.61	10.26	11.20	21.34	60.28	22.82	22.38	39.83	25.60	27.93	26.54	20.66
2005	14.16	11.24	12.00	13.97	40.80	34.81	25.63	31.61	36.39	20.92	14.05	11.64
2006	10.99	10.18	11.65	35.03	33.86	23.84	30.16	65.92	47.19	23.72	40.68	55.79
2007	33.90	25.49	20.55	24.64	32.75	54.12	57.45	65.28	76.94	30.28	16.83	12.96
2008	11.90	10.57	11.61	16.19	19.79	31.39	30.44	46.97	46.71	47.99	62.02	18.15
2009	12.66	10.90	11.68	12.61	27.85	22.05	18.02	26.05	24.26	27.76	23.48	20.09
2010	43.94	16.72	36.07	39.33	73.39	38.91	43.38	42.06	57.34	39.38	22.01	15.10

Sub-basin: **ICE** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	3.97	3.49	3.72	5.97	9.64	8.62	9.83	11.65	9.47	14.68	6.79	4.85
1992	3.93	3.38	3.72	3.53	5.14	7.85	13.60	10.80	9.95	13.53	7.26	4.78
1993	4.05	3.78	4.01	3.62	10.37	10.35	7.05	6.46	9.11	6.76	4.64	3.97
1994	3.66	3.38	3.59	3.47	12.09	10.80	10.97	14.02	10.69	6.57	8.83	6.33
1995	3.90	3.28	3.57	3.22	8.41	9.35	9.57	11.31	12.18	7.00	5.91	4.61
1996	3.73	3.28	3.49	4.70	5.50	6.47	6.59	7.18	9.00	6.77	4.83	4.01
1997	3.54	3.13	3.45	4.70	11.67	5.31	7.05	6.80	4.49	4.19	8.28	6.73
1998	6.65	4.74	3.89	3.57	11.69	8.55	9.30	14.16	9.23	12.38	8.79	4.35
1999	3.55	3.08	3.39	5.00	11.22	7.47	7.66	10.13	8.33	11.74	6.18	4.01
2000	3.50	3.04	3.34	3.22	5.75	6.97	8.89	10.08	8.69	10.10	6.04	4.63
2001	4.14	3.55	3.49	3.64	5.63	7.68	9.18	8.15	8.67	7.78	9.66	5.28
2002	3.55	3.10	3.27	3.35	12.38	6.81	5.97	5.54	4.74	4.71	4.38	5.70
2003	8.37	3.43	3.33	3.15	16.17	10.37	11.44	9.73	11.25	5.96	3.70	3.41
2004	3.24	2.89	3.16	3.32	8.50	6.00	5.56	8.25	7.13	6.62	6.02	5.51
2005	3.89	3.01	3.13	3.38	7.65	8.67	5.73	5.09	5.70	5.19	4.09	3.26
2006	3.06	2.84	3.11	8.67	9.47	7.93	7.48	12.65	12.32	7.34	6.39	9.33
2007	7.42	5.22	5.03	5.05	6.68	9.22	9.94	14.50	15.16	7.61	3.85	3.26
2008	3.08	2.76	3.04	3.25	4.90	10.62	6.90	10.16	10.21	7.91	10.00	4.10
2009	3.15	2.78	3.02	3.97	11.49	7.68	4.98	9.21	9.80	8.18	5.32	4.68
2010	9.55	3.83	5.61	11.89	15.82	9.68	12.79	7.73	19.41	13.76	6.72	4.46

1DA, 1DB, 1DC & 1DD

Sub-basin: **IDA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	7.44	6.56	7.21	12.03	25.79	14.86	16.77	19.24	16.01	24.55	12.22	8.33
1992	6.93	6.00	6.58	6.71	8.67	16.23	26.33	17.44	17.25	24.49	13.84	9.19
1993	7.43	6.77	7.46	6.87	21.86	19.53	12.09	12.28	18.90	12.68	8.78	7.19
1994	6.53	5.94	6.46	9.56	29.48	20.88	22.22	24.89	19.77	11.52	18.73	13.55
1995	7.15	5.83	6.42	7.52	19.80	21.39	19.00	18.42	21.69	13.53	14.58	10.15
1996	6.94	6.73	7.51	19.25	21.59	17.90	13.93	11.83	19.66	17.06	10.39	8.97
1997	6.83	5.66	6.21	12.90	28.45	11.77	15.76	15.39	9.59	9.57	19.80	14.39
1998	16.21	9.82	7.77	7.62	27.30	19.69	19.74	20.93	17.68	25.65	18.02	8.08
1999	6.55	5.62	8.66	20.07	26.77	17.22	15.18	21.13	18.36	28.22	12.99	7.45
2000	6.54	5.59	6.09	6.08	14.97	14.02	15.16	15.67	14.68	17.74	11.61	9.71
2001	8.79	7.09	6.78	10.30	17.24	14.17	14.37	12.53	13.28	12.85	16.28	9.70
2002	6.48	5.63	5.94	7.05	26.91	14.64	12.39	10.67	9.28	9.79	11.65	15.18
2003	15.49	6.37	6.13	5.37	38.86	22.83	25.89	20.65	21.47	12.14	7.19	6.58
2004	6.26	5.44	5.91	8.29	20.13	11.80	9.82	13.86	13.31	12.40	12.37	10.80
2005	7.59	5.66	5.88	8.29	19.21	17.13	10.94	9.59	9.90	9.42	8.11	6.26
2006	5.62	5.18	7.12	31.13	21.18	17.34	14.04	20.01	25.57	12.80	14.76	22.66
2007	14.44	9.45	8.44	11.08	16.91	20.47	19.31	28.65	28.53	16.74	9.65	6.59
2008	5.77	5.11	5.72	9.78	17.75	23.35	13.39	21.57	23.32	17.95	20.88	8.23
2009	5.94	5.39	5.64	12.14	26.50	15.63	9.98	14.89	18.65	14.49	9.81	8.84
2010	19.07	8.14	13.52	22.19	27.54	22.15	24.21	16.21	34.74	28.46	14.77	9.52

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **IDB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	12.16	10.03	10.70	20.55	30.91	26.05	27.12	30.55	25.11	34.44	19.71	13.08
1992	10.55	9.09	9.96	9.82	17.37	20.12	28.74	27.01	24.20	37.48	20.67	13.15
1993	11.48	12.64	12.13	10.28	30.11	26.41	19.39	19.08	27.00	22.70	16.55	11.91
1994	10.00	8.99	9.55	9.53	37.85	30.20	23.56	31.11	24.76	16.18	30.38	19.86
1995	10.82	8.78	9.71	10.22	23.51	21.78	23.47	26.58	31.74	22.27	21.79	13.75
1996	10.38	9.56	11.21	27.69	38.80	31.30	23.77	24.18	34.38	27.51	18.45	15.27
1997	10.49	8.52	9.20	19.96	40.75	20.16	22.50	25.02	14.23	17.98	38.62	25.04
1998	36.82	20.64	14.66	18.58	38.94	29.05	35.04	33.47	29.20	40.41	37.26	13.61
1999	10.38	8.73	10.95	29.36	43.79	25.96	24.14	27.33	22.54	46.45	22.62	12.78
2000	10.19	8.62	9.30	8.95	18.02	19.85	22.37	25.39	21.82	31.06	19.37	14.20
2001	11.38	9.43	9.99	19.52	27.17	24.77	22.89	22.26	18.00	22.50	32.93	14.47
2002	9.85	8.51	9.10	9.46	32.17	21.32	15.69	13.74	11.69	13.31	13.04	15.94
2003	19.15	9.20	9.12	13.94	61.62	33.49	35.28	26.42	30.85	16.02	11.25	10.38
2004	9.41	8.19	8.88	15.52	32.04	18.52	14.18	21.10	17.11	16.68	25.72	16.66
2005	12.39	8.81	8.94	10.87	34.66	26.66	23.10	15.52	18.84	17.94	16.11	10.17
2006	8.66	7.85	9.49	39.70	31.86	26.76	20.66	29.00	35.20	24.88	37.91	34.11
2007	20.03	12.58	12.66	17.30	32.40	31.85	33.99	41.91	46.47	28.09	15.24	10.40
2008	8.89	7.82	8.56	12.01	24.28	39.58	20.30	32.12	29.89	33.92	31.73	12.98
2009	9.17	8.14	8.58	12.14	40.25	25.34	16.16	23.36	28.56	26.77	16.70	15.11
2010	25.53	11.63	23.92	38.29	47.21	30.20	34.44	23.57	42.62	47.60	27.42	17.84

Sub-basin: **IDC** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	5.58	4.58	4.78	7.32	15.27	11.11	8.72	9.31	9.25	11.01	9.28	5.85
1992	4.78	4.12	4.53	4.29	4.21	6.86	12.14	10.39	9.18	11.75	10.43	6.53
1993	5.16	4.39	5.12	4.38	8.20	11.55	8.05	7.30	11.44	9.09	6.79	5.18
1994	4.49	4.05	4.31	3.63	14.44	13.79	9.85	11.43	11.37	7.01	9.82	10.90
1995	5.07	3.97	4.47	4.32	10.79	10.26	10.16	9.06	11.68	9.91	10.26	7.56
1996	4.93	4.89	5.54	15.90	20.23	14.86	9.87	7.44	14.73	15.53	9.05	8.11
1997	5.10	3.92	4.20	4.33	20.93	9.34	9.99	10.33	7.26	6.14	15.65	13.86
1998	15.61	8.53	6.09	5.93	17.89	13.02	14.55	11.73	12.15	15.55	16.38	6.48
1999	4.76	3.99	5.23	14.03	20.68	11.69	9.94	11.44	12.17	19.40	12.23	5.94
2000	4.76	3.94	4.23	4.07	5.73	7.67	8.24	7.73	8.57	9.95	8.36	7.23
2001	5.74	4.83	4.61	7.67	13.35	8.94	7.30	6.60	7.04	6.42	8.76	6.44
2002	4.38	3.84	4.02	4.05	11.95	11.03	7.15	5.58	5.35	5.59	7.64	6.14
2003	10.77	4.39	4.17	2.59	26.36	15.37	16.12	10.66	14.33	8.33	5.32	4.67
2004	4.26	3.71	4.03	4.41	12.63	8.10	5.91	6.45	7.23	8.13	8.72	7.84
2005	5.29	3.81	3.93	4.37	10.28	13.06	8.21	6.82	6.17	6.85	6.34	4.55
2006	3.84	3.52	4.11	19.36	16.25	12.32	9.09	9.31	13.36	9.63	12.92	18.00
2007	11.18	5.35	5.06	5.40	12.97	13.39	12.13	14.70	16.97	13.69	8.72	5.02
2008	4.01	3.52	3.83	5.39	12.39	16.73	8.42	12.10	16.14	14.86	16.09	6.75
2009	4.18	3.79	3.88	5.62	17.26	12.37	7.65	6.20	10.58	10.53	6.65	4.98
2010	10.54	5.48	8.61	12.82	17.53	13.44	14.03	9.37	15.63	19.94	13.53	7.61

Sub-basin: **IDD** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	6.42	5.20	5.56	9.41	18.56	12.09	8.31	7.79	7.86	9.10	9.12	6.26
1992	5.28	4.56	4.99	4.91	5.17	7.33	10.88	9.24	8.68	10.68	10.19	7.16
1993	6.03	5.07	5.71	4.95	8.45	11.24	8.07	7.54	10.80	9.14	7.35	5.91
1994	4.99	4.50	4.91	4.91	14.99	13.77	9.07	9.25	9.80	7.12	10.74	11.40
1995	5.48	4.46	5.32	5.98	12.24	10.24	9.90	8.16	10.59	10.80	11.41	8.15
1996	5.59	5.74	6.86	20.21	22.99	16.21	10.38	7.56	16.31	18.55	10.34	9.85
1997	5.83	4.37	4.67	5.38	20.78	10.71	10.05	10.04	7.54	8.04	18.48	17.35
1998	18.40	9.54	6.74	7.87	19.56	13.37	14.44	10.54	11.45	15.63	17.40	6.97
1999	5.59	4.62	6.31	15.68	23.01	12.57	9.78	10.77	13.24	21.48	13.42	7.68
2000	5.74	4.54	4.83	4.69	6.41	7.38	7.70	7.52	7.91	9.46	8.83	8.50
2001	6.62	5.46	5.33	10.01	15.56	9.81	7.14	6.35	6.71	6.47	7.83	6.18
2002	4.82	4.31	4.65	5.11	14.00	11.65	6.88	5.60	5.49	6.42	9.69	7.67
2003	10.24	4.70	4.72	4.71	26.86	16.53	15.10	10.19	13.38	8.38	6.17	5.52
2004	5.00	4.26	4.77	5.82	12.91	8.36	6.12	6.40	7.08	9.51	10.85	8.09
2005	5.60	4.20	4.53	4.92	10.83	13.49	8.83	7.26	6.78	7.30	7.14	5.23
2006	4.38	4.04	5.06	21.03	18.25	13.33	9.13	7.98	11.65	9.56	15.20	20.32
2007	11.60	5.83	5.52	6.16	14.62	13.33	11.08	12.35	15.08	14.09	10.06	5.76
2008	4.58	4.06	4.46	6.66	14.14	16.50	8.77	11.70	19.31	17.32	18.09	7.63
2009	4.77	4.44	4.46	6.65	18.74	12.83	8.12	6.06	9.26	10.40	7.02	5.94
2010	10.23	5.88	10.14	12.26	16.83	13.55	13.03	9.17	13.59	19.10	14.58	8.25

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

1EA, 1EB, 1EC, 1ED, 1EE, 1EF & 1EG

Sub-basin: **1EA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	13.02	11.24	12.28	22.35	39.75	23.86	24.30	25.33	20.78	29.33	19.37	13.98
1992	12.01	10.45	11.46	11.06	13.41	32.71	36.92	25.51	27.39	28.77	18.76	14.98
1993	12.82	12.23	13.42	12.35	33.10	27.57	17.84	18.36	24.03	16.63	13.38	12.19
1994	11.38	10.41	11.40	25.24	39.24	27.31	32.15	31.34	25.24	16.53	27.56	20.70
1995	12.23	10.34	12.78	18.97	29.83	29.65	30.34	22.78	26.27	21.59	24.26	17.03
1996	12.59	12.80	15.37	32.96	29.00	25.10	21.05	18.65	26.66	22.14	15.58	15.46
1997	12.37	10.23	10.95	22.10	33.05	18.76	23.54	22.32	15.42	13.65	23.58	22.53
1998	26.42	15.43	13.24	13.55	37.33	25.56	23.96	21.65	21.51	30.63	22.37	12.86
1999	11.26	9.89	12.89	25.92	30.77	22.82	21.81	30.88	26.30	33.21	17.19	13.03
2000	11.45	9.86	10.76	10.37	20.14	19.40	22.23	23.29	20.45	24.25	16.48	16.76
2001	18.33	15.21	12.52	20.53	27.74	24.43	24.80	19.13	21.86	21.05	21.58	15.54
2002	11.73	10.16	11.24	14.75	41.14	20.85	18.92	21.82	18.01	17.21	21.14	23.13
2003	22.22	10.92	10.80	11.50	46.24	31.78	33.47	37.94	26.72	19.99	12.41	12.26
2004	11.54	10.03	10.79	16.81	29.51	17.33	15.52	20.70	20.60	21.07	19.23	16.17
2005	12.91	10.51	11.74	17.34	27.22	22.27	17.89	18.17	17.07	14.25	11.80	10.82
2006	10.16	9.41	11.60	42.89	27.11	22.51	21.10	26.22	29.50	17.08	21.28	28.27
2007	20.49	14.58	14.18	19.09	23.08	26.75	25.92	42.80	41.36	22.46	16.13	11.86
2008	10.60	9.39	10.30	19.17	26.95	28.53	22.84	29.58	30.29	23.80	27.39	13.23
2009	10.70	10.02	10.38	18.12	29.40	18.21	16.48	20.74	23.22	20.74	15.34	15.17
2010	25.03	13.53	20.68	25.07	33.62	29.40	28.70	24.18	35.55	29.28	17.80	13.27

Sub-basin: **1EB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	11.21	9.71	10.65	18.40	31.36	17.39	14.45	16.29	15.75	19.90	15.78	11.65
1992	10.31	9.00	9.88	9.56	10.79	22.22	23.41	16.90	16.99	17.99	14.12	12.11
1993	10.78	9.84	10.99	10.30	19.73	18.99	13.91	13.27	16.63	13.34	11.19	10.32
1994	9.74	8.96	9.85	16.91	26.73	18.43	18.37	18.13	16.81	12.83	19.19	16.07
1995	10.21	8.78	11.05	15.32	20.65	19.60	20.58	15.13	17.59	17.12	18.91	13.71
1996	10.60	11.02	13.16	27.89	24.48	20.01	14.70	12.38	21.36	20.31	13.20	13.52
1997	10.48	8.75	9.49	13.20	24.45	15.18	16.31	16.03	12.47	11.20	16.55	19.22
1998	21.90	12.18	10.91	13.36	27.22	18.53	17.04	14.57	15.47	23.37	18.61	10.90
1999	9.88	8.67	10.44	19.47	23.56	16.60	15.08	16.71	19.22	23.58	14.13	11.08
2000	9.93	8.59	9.39	9.06	12.13	12.92	14.62	14.88	13.90	16.46	12.66	13.48
2001	14.23	11.73	10.74	18.13	21.84	16.07	16.78	13.54	14.99	16.10	16.41	12.42
2002	9.88	8.71	9.59	13.55	28.86	16.41	13.15	13.82	12.46	14.13	18.91	15.64
2003	16.02	9.01	9.35	9.30	31.07	23.07	23.30	26.20	19.02	14.71	10.53	10.28
2004	9.75	8.55	9.36	11.47	18.68	13.61	11.40	12.62	13.83	16.22	14.59	12.38
2005	10.26	8.56	9.35	11.22	18.92	16.49	13.25	14.56	14.60	11.51	9.63	9.30
2006	8.86	8.23	9.62	32.79	21.79	18.53	14.61	15.83	19.21	13.50	18.30	23.28
2007	15.01	10.20	10.40	12.68	18.28	17.85	16.03	25.33	27.42	18.53	14.30	10.33
2008	9.21	8.18	8.97	11.53	21.93	19.50	14.49	20.45	23.68	19.30	22.14	11.44
2009	9.35	8.77	9.11	12.99	21.67	14.58	13.01	12.58	16.18	16.08	11.63	10.83
2010	15.80	10.67	16.13	18.04	23.21	19.69	18.41	16.43	20.93	20.44	15.09	11.44

Sub-basin: **1EC** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	6.71	5.77	6.33	8.88	16.83	10.07	9.76	10.58	9.28	11.48	8.96	6.86
1992	6.24	5.52	6.08	5.87	6.19	10.60	14.19	10.51	10.15	11.76	9.22	7.48
1993	6.65	6.03	6.49	6.06	12.22	11.34	8.30	7.87	10.83	8.45	6.92	6.29
1994	5.98	5.53	5.91	8.59	16.46	11.78	12.23	12.63	11.20	7.95	11.25	9.57
1995	6.30	5.43	6.22	7.49	12.27	12.38	12.16	9.90	11.11	10.24	10.70	8.30
1996	6.41	6.29	7.21	15.24	14.42	11.63	9.22	8.03	12.27	12.05	7.98	7.78
1997	6.37	5.38	5.85	8.72	15.22	8.89	10.43	10.08	7.62	7.07	11.00	10.46
1998	11.97	7.50	6.58	6.90	15.40	11.64	11.33	9.56	10.26	13.93	11.10	6.64
1999	6.05	5.33	6.51	12.46	14.74	10.26	9.91	10.85	11.73	15.15	8.94	6.73
2000	6.09	5.32	5.83	5.62	8.43	8.74	9.07	9.24	8.56	10.06	7.97	7.85
2001	7.66	6.43	6.32	9.50	12.34	9.41	9.39	8.10	8.30	8.80	9.19	7.19
2002	5.96	5.35	5.70	6.12	15.69	9.88	8.54	8.22	7.47	8.06	9.95	9.96
2003	9.77	5.58	5.76	5.86	18.90	13.70	14.12	13.55	11.30	8.78	6.38	6.21
2004	5.92	5.21	5.70	6.57	11.44	8.20	7.14	8.07	8.39	9.29	8.82	7.82
2005	6.35	5.25	5.73	6.65	11.08	10.09	8.13	7.85	7.54	6.96	6.14	5.72
2006	5.45	5.06	5.83	17.93	12.59	10.72	8.93	10.01	12.81	8.59	10.60	13.08
2007	9.17	6.63	6.47	7.87	10.86	11.40	9.95	15.35	15.26	10.95	8.16	6.18
2008	5.62	5.01	5.51	7.25	12.14	12.37	9.05	12.41	14.55	11.17	12.81	6.83
2009	5.69	5.22	5.55	7.81	13.88	9.20	7.73	7.65	9.83	9.40	7.11	6.77
2010	10.54	6.52	9.26	10.96	13.52	12.44	12.21	9.99	14.29	13.70	9.40	7.13

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **IED** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	2.70	2.18	2.37	4.87	8.06	4.60	3.40	3.25	3.17	3.64	3.84	2.68
1992	2.30	2.00	2.20	2.12	2.28	3.56	5.44	3.77	3.80	4.14	3.75	3.11
1993	2.84	2.41	2.53	2.22	4.28	5.00	3.38	2.80	3.93	3.48	2.89	2.50
1994	2.20	1.99	2.13	2.68	7.75	4.84	3.76	3.86	4.13	3.19	4.86	4.38
1995	2.34	1.97	2.40	3.28	5.75	4.38	4.56	3.42	4.24	4.96	5.04	3.62
1996	2.54	2.52	2.98	8.65	7.29	5.59	3.80	2.99	6.68	7.16	3.79	4.01
1997	2.50	1.97	2.12	2.42	7.45	4.16	4.01	3.60	3.04	2.96	6.09	6.62
1998	6.81	3.30	2.57	3.38	7.56	4.65	4.27	3.53	4.03	5.95	5.61	2.77
1999	2.36	2.00	2.30	5.01	8.07	4.45	3.68	3.61	5.31	6.91	4.49	3.36
2000	2.53	2.00	2.14	2.06	2.63	2.89	3.16	3.49	3.25	4.10	3.52	3.77
2001	3.24	2.81	2.53	5.38	6.18	4.50	3.49	2.94	3.04	3.54	3.74	2.79
2002	2.21	1.96	2.09	2.72	7.62	4.33	2.89	2.58	2.72	3.48	5.54	3.93
2003	4.29	2.11	2.15	2.66	9.03	5.99	5.48	4.02	4.67	3.44	2.75	2.47
2004	2.24	1.94	2.14	2.76	4.84	3.47	2.73	2.80	3.06	4.82	4.75	3.36
2005	2.41	1.91	2.05	2.39	4.88	5.00	3.47	3.31	3.21	3.12	2.76	2.26
2006	2.02	1.86	2.26	9.05	6.81	5.27	3.50	3.31	4.17	3.59	5.75	7.85
2007	4.26	2.64	2.46	3.12	5.64	4.80	3.53	4.73	5.61	5.17	4.02	2.51
2008	2.10	1.85	2.02	3.29	5.74	5.34	3.49	4.84	8.75	5.80	6.99	3.00
2009	2.14	1.96	2.06	2.82	6.66	4.01	3.07	2.54	3.47	4.12	2.99	2.73
2010	4.21	2.36	3.99	4.21	6.18	4.55	4.77	3.47	4.72	5.87	4.53	3.00

Sub-basin: **IEE** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	1.80	1.50	1.47	10.40	15.30	8.47	3.25	1.71	2.42	1.44	3.43	1.39
1992	1.80	1.19	1.50	1.31	0.70	2.12	4.26	3.01	3.88	4.04	5.85	4.13
1993	4.73	1.80	1.84	1.45	4.21	9.18	3.64	0.96	3.06	3.56	2.95	1.76
1994	1.62	1.27	1.52	0.00	14.01	10.74	3.83	2.74	5.18	3.37	9.47	7.87
1995	1.68	1.41	1.16	3.95	13.01	6.46	4.41	2.19	5.81	10.48	10.94	5.53
1996	2.08	1.67	2.34	18.77	16.00	11.85	5.04	1.85	15.09	21.44	7.05	7.72
1997	1.67	1.20	1.62	0.00	14.14	7.25	4.30	2.93	2.72	2.13	15.56	22.67
1998	16.29	5.05	1.87	3.68	17.05	6.72	2.80	2.47	4.60	8.43	10.66	2.74
1999	1.19	1.62	1.07	3.51	22.68	7.58	3.46	2.59	9.75	12.95	10.68	8.61
2000	2.52	1.44	1.29	1.46	0.59	1.25	1.41	1.10	3.43	4.81	6.69	8.55
2001	4.31	3.39	1.35	10.43	14.46	10.63	4.03	2.33	3.64	4.24	5.63	3.02
2002	1.68	1.24	1.61	3.76	16.00	6.81	2.01	1.14	1.95	3.19	13.03	6.30
2003	8.04	1.57	1.70	3.64	19.18	11.17	7.69	0.88	4.32	2.53	2.81	1.55
2004	1.46	1.42	1.52	1.72	7.19	4.35	2.25	1.40	3.12	11.20	11.82	5.84
2005	1.66	1.44	1.53	1.05	5.04	11.36	4.61	3.63	1.86	3.76	4.50	1.61
2006	1.26	1.22	1.49	16.22	19.73	10.60	3.60	2.42	3.48	3.37	9.41	24.14
2007	10.74	3.80	1.93	3.77	12.77	8.45	2.87	2.30	4.80	7.88	5.90	1.68
2008	1.52	1.35	1.29	4.67	9.73	8.69	3.24	6.31	29.01	13.28	19.02	4.13
2009	1.61	1.27	1.63	2.13	12.99	7.48	2.73	0.32	2.96	5.53	3.66	2.44
2010	7.26	1.29	3.63	4.60	12.82	6.71	4.39	1.22	3.89	6.98	9.24	3.22

Sub-basin: **IEF** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.00	0.00	0.00	7.79	17.04	6.96	0.00	0.00	1.45	0.00	1.49	0.16
1992	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00	5.32	1.74
1993	2.47	0.00	0.00	0.00	0.00	7.70	0.66	0.00	0.00	0.00	0.00	0.00
1994	0.00	0.00	0.00	0.00	17.16	10.18	0.04	0.00	4.60	0.21	10.75	10.12
1995	0.00	0.00	0.00	2.84	15.30	4.48	0.05	0.00	3.28	8.26	8.97	3.27
1996	0.00	0.00	0.57	18.94	15.86	12.59	2.34	0.00	10.51	21.66	5.55	5.73
1997	0.00	0.00	0.00	0.00	11.40	2.64	0.52	0.00	0.74	0.00	22.62	33.99
1998	19.49	2.80	0.00	1.62	17.94	2.76	0.00	0.00	0.12	0.86	9.38	0.51
1999	0.00	0.00	0.00	0.13	27.73	4.00	0.87	0.00	9.61	15.27	11.25	10.54
2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.76	0.00	6.52	7.24
2001	2.70	1.57	0.00	6.83	13.13	8.24	0.00	0.00	0.68	0.17	5.15	1.42
2002	0.00	0.00	0.00	0.00	20.27	3.20	0.00	0.00	0.00	0.00	12.40	0.00
2003	8.28	0.00	0.00	0.00	20.84	6.67	5.15	0.00	4.09	0.00	0.27	0.00
2004	0.00	0.00	0.00	0.00	5.01	0.56	0.00	0.00	0.57	10.12	14.20	4.17
2005	0.00	0.00	0.00	0.00	0.00	10.92	1.32	1.16	0.00	2.85	3.80	0.00
2006	0.00	0.00	0.00	11.90	19.71	6.05	0.00	0.00	0.00	1.68	8.08	31.40
2007	11.50	1.25	0.00	1.42	16.08	7.10	0.17	0.00	0.52	5.95	4.41	0.00
2008	0.00	0.00	0.00	0.08	7.78	8.12	0.00	3.10	34.83	14.88	22.13	1.74
2009	0.00	0.00	0.00	0.00	16.30	5.98	0.05	0.00	0.28	4.25	1.97	0.33
2010	7.38	0.00	0.00	3.80	15.85	2.36	1.10	0.00	0.65	5.86	7.26	0.00

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **IEG** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	3.98	2.36	2.60	18.99	22.73	12.79	6.61	4.67	4.07	4.73	7.14	3.93
1992	2.39	1.83	2.00	2.03	2.57	7.05	10.10	5.94	7.36	8.18	7.53	6.60
1993	7.82	4.53	3.52	2.37	10.56	14.84	6.87	3.63	5.47	5.03	4.37	3.44
1994	2.21	1.83	2.30	6.12	22.76	14.44	8.36	6.44	8.22	5.70	16.08	11.34
1995	2.68	2.15	3.38	11.33	19.27	11.31	10.04	5.13	8.46	15.52	17.72	9.28
1996	4.63	4.32	5.95	31.91	21.27	16.25	8.17	4.44	18.96	27.19	9.26	12.07
1997	3.32	1.94	2.00	3.71	17.01	11.13	8.12	5.45	4.03	3.66	15.36	32.27
1998	25.45	7.19	3.00	7.26	25.69	11.14	6.16	4.46	5.83	12.49	12.26	4.19
1999	2.77	1.97	2.45	8.34	26.59	11.25	6.12	5.58	12.94	17.16	11.58	11.55
2000	4.59	2.05	2.06	1.97	3.07	3.12	3.90	5.21	5.09	8.13	7.53	11.99
2001	9.34	8.20	4.18	18.04	19.65	16.14	8.27	5.08	6.67	10.47	10.25	5.07
2002	2.55	1.94	2.23	11.10	25.67	10.29	4.03	3.34	4.33	7.12	21.29	12.98
2003	11.25	2.58	2.50	8.33	25.91	17.18	12.52	6.62	7.67	5.61	4.90	3.63
2004	2.65	2.07	2.42	5.18	11.45	7.59	4.75	4.23	5.62	16.04	16.71	8.55
2005	3.48	2.04	2.35	3.61	12.14	14.94	7.25	6.50	6.60	6.44	5.94	2.79
2006	2.00	1.81	2.78	28.79	25.09	16.37	7.24	5.67	6.92	5.46	17.56	31.70
2007	14.24	6.74	4.64	9.33	19.52	13.64	5.63	7.26	10.45	11.69	8.98	3.57
2008	2.16	1.79	2.09	8.67	16.96	13.34	6.64	11.89	37.74	19.87	25.96	6.41
2009	2.33	2.09	2.08	5.12	19.53	9.90	4.62	3.19	5.01	8.73	5.58	6.06
2010	11.12	2.87	8.78	9.55	19.93	10.33	6.76	4.12	6.83	10.89	11.70	5.28

1FA, 1FB, 1FC, 1FD, 1FE, 1FF & 1FG

Sub-basin: **1FA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	1.13	0.77	0.78	3.92	4.27	7.83	8.08	5.52	4.77	2.94	1.83	1.01
1992	0.55	0.38	0.39	0.49	3.76	5.01	9.30	10.06	8.95	7.14	4.94	1.76
1993	1.82	2.95	1.36	0.60	6.56	8.32	4.33	4.44	3.74	1.79	3.07	1.82
1994	0.65	0.41	0.46	4.04	13.01	7.23	6.93	8.32	4.17	1.25	4.13	2.36
1995	0.68	0.45	1.62	2.81	5.04	3.56	5.19	4.69	5.84	2.85	3.38	1.40
1996	0.84	0.63	1.46	3.88	3.69	4.99	6.12	8.37	6.04	1.88	1.73	1.97
1997	0.78	0.43	0.41	8.23	5.69	2.32	6.41	3.94	1.33	2.66	10.09	7.38
1998	9.77	5.56	1.57	0.91	5.40	3.94	7.31	6.95	3.19	4.38	4.87	1.22
1999	0.58	0.41	0.76	2.33	3.48	2.11	5.47	8.15	4.10	7.84	3.66	3.94
2000	0.90	0.45	0.44	0.40	0.56	1.38	5.63	5.78	4.26	5.54	2.63	1.20
2001	2.19	1.90	0.75	3.72	5.45	7.15	6.57	6.18	4.31	2.66	5.69	1.93
2002	1.16	0.74	0.84	1.29	8.37	1.95	1.40	4.72	2.98	1.10	1.18	7.69
2003	4.78	0.76	0.46	2.04	12.26	4.80	3.61	9.76	6.10	2.33	0.91	0.81
2004	0.56	0.43	0.47	6.35	6.45	3.06	4.08	7.27	3.59	4.10	5.12	4.21
2005	1.70	1.11	1.52	2.45	9.39	5.29	4.58	4.65	7.29	2.39	1.45	0.64
2006	0.45	0.39	0.51	6.28	4.45	3.63	6.61	10.01	6.10	1.86	5.35	7.72
2007	4.02	2.72	1.90	4.09	6.34	9.78	10.57	11.52	11.95	3.95	1.50	0.74
2008	0.51	0.43	0.49	4.35	3.11	4.17	5.80	10.22	7.68	5.85	5.48	1.54
2009	0.66	0.52	0.47	0.47	2.26	2.09	1.61	2.82	3.71	5.53	2.97	2.73
2010	6.40	2.00	4.73	4.63	11.25	5.84	5.92	5.77	7.91	5.56	2.70	1.31

Sub-basin: **1FB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	6.07	5.08	6.31	14.51	20.42	21.74	21.25	15.35	14.12	14.57	10.40	6.58
1992	5.13	4.20	4.52	4.65	13.20	19.60	28.79	26.00	25.67	21.12	13.98	7.67
1993	6.37	7.79	6.87	5.34	21.19	23.45	11.86	12.31	14.27	8.34	10.28	7.81
1994	5.06	4.25	5.45	15.73	33.56	21.30	23.53	25.42	16.72	8.02	17.59	12.71
1995	5.64	4.51	7.41	11.16	19.57	15.70	19.58	17.71	18.28	13.06	13.80	8.80
1996	6.24	6.35	10.18	18.96	17.79	18.47	18.97	19.08	19.91	11.55	9.31	9.50
1997	5.95	4.48	4.42	23.22	21.59	10.38	21.37	14.96	8.16	10.15	26.54	20.74
1998	25.53	13.94	8.35	6.93	23.49	16.74	23.19	20.22	14.86	17.47	16.35	6.71
1999	5.03	4.18	6.60	13.56	19.39	12.64	20.20	29.56	17.81	26.41	12.85	10.70
2000	5.63	4.32	4.55	4.30	10.57	13.27	19.89	19.67	16.81	18.61	11.44	8.38
2001	12.68	9.94	5.92	12.97	19.23	22.14	19.64	17.07	16.26	11.72	15.41	7.97
2002	6.48	4.85	6.85	7.67	27.65	10.91	9.42	17.92	12.77	7.85	9.66	16.12
2003	16.59	5.28	4.63	9.68	40.00	21.40	18.69	26.99	20.43	12.53	6.14	6.65
2004	5.55	4.63	5.04	20.03	25.00	11.85	11.77	17.68	14.33	15.15	16.75	11.33
2005	7.31	6.28	9.39	10.93	23.82	16.99	14.77	13.07	14.74	9.77	7.61	5.13
2006	4.42	3.98	6.17	27.23	15.77	13.87	18.45	23.55	19.40	9.70	17.50	22.83
2007	14.08	10.62	10.71	12.89	20.41	24.34	29.18	37.06	39.24	15.27	8.34	5.68
2008	4.76	4.27	6.88	20.38	15.77	20.56	19.22	22.37	20.09	18.26	18.75	7.06
2009	4.94	4.57	4.51	7.46	19.08	11.25	10.95	15.91	17.26	16.08	11.42	10.28
2010	20.63	9.15	15.72	15.21	29.86	21.41	20.15	16.19	25.30	20.87	10.86	7.16

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **IFC** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	3.88	3.28	3.47	8.12	11.80	11.74	10.45	7.49	6.81	8.48	6.80	4.24
1992	3.37	2.93	3.26	3.07	5.76	11.48	15.52	12.25	14.68	10.80	7.77	4.87
1993	3.84	3.82	4.53	3.51	11.47	13.12	6.85	6.31	8.09	5.16	5.08	4.84
1994	3.46	3.00	3.33	7.90	17.06	10.95	10.56	12.60	9.67	5.24	9.38	8.64
1995	3.75	2.98	4.29	5.36	11.59	8.66	10.21	8.93	9.87	7.77	7.98	5.87
1996	4.12	3.91	5.07	11.67	10.54	9.96	9.28	8.91	11.35	7.20	5.58	6.66
1997	4.10	2.99	3.19	10.45	13.11	5.66	10.58	7.54	5.33	4.53	13.66	12.14
1998	13.38	7.35	5.35	4.12	11.86	9.03	9.88	9.31	7.86	9.42	9.15	4.62
1999	3.31	2.86	3.49	7.31	11.10	7.02	10.73	16.41	11.31	13.17	8.12	5.76
2000	3.76	2.89	3.16	3.05	5.07	7.58	10.50	10.82	9.20	10.12	7.14	5.86
2001	6.91	6.88	3.94	7.10	11.75	12.32	10.27	8.64	8.52	7.29	7.67	5.32
2002	3.97	3.25	4.03	4.57	15.84	6.49	5.68	9.28	8.60	5.18	5.81	6.73
2003	10.37	3.48	3.13	3.95	21.53	12.71	10.74	13.45	12.13	8.08	4.25	4.24
2004	3.66	3.07	3.27	9.98	14.96	6.31	6.12	8.67	8.12	9.16	8.87	6.51
2005	4.69	3.90	5.02	7.22	11.67	10.24	7.74	7.32	6.41	5.64	4.84	3.47
2006	3.06	2.87	3.63	15.65	9.79	7.58	9.76	11.15	9.09	5.89	7.89	12.45
2007	9.17	5.19	6.11	6.79	11.46	13.07	15.17	19.58	20.14	8.89	5.67	3.82
2008	3.18	2.84	3.18	12.61	10.16	11.57	10.10	11.98	10.37	9.75	9.83	4.65
2009	3.27	3.02	3.03	4.56	9.90	7.39	6.18	8.39	10.76	9.21	6.49	5.68
2010	11.27	4.98	7.93	8.91	14.81	11.93	10.76	8.07	12.76	11.74	6.98	4.50

Sub-basin: **IFD** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	5.88	4.68	5.39	14.75	18.28	23.26	20.42	11.11	10.57	11.98	9.11	5.47
1992	4.48	3.68	3.96	4.01	12.66	20.01	27.80	26.36	28.49	21.70	14.40	7.61
1993	6.14	7.26	6.66	4.89	21.89	25.49	12.13	11.74	12.45	7.53	12.85	10.03
1994	5.12	3.95	4.97	15.05	34.23	19.56	16.54	22.19	14.38	7.05	17.12	11.56
1995	5.09	4.11	7.11	9.78	18.19	13.49	15.62	14.02	16.51	12.28	12.68	7.53
1996	5.79	5.42	8.38	17.63	16.63	14.96	16.97	18.59	19.22	10.12	9.73	11.34
1997	5.89	4.11	3.96	25.64	21.66	9.17	19.21	11.27	6.89	9.29	30.98	23.67
1998	27.90	14.33	8.02	5.84	17.98	14.37	19.53	17.98	12.55	13.47	16.02	6.48
1999	4.67	3.80	5.54	10.73	15.83	11.03	19.42	29.16	17.53	24.99	13.71	12.62
2000	5.49	3.98	4.15	3.86	7.67	11.47	21.05	19.62	14.70	18.71	11.87	8.29
2001	13.41	9.94	5.36	13.67	19.90	22.45	17.90	15.91	14.09	11.40	14.83	7.43
2002	6.78	4.85	7.17	7.64	25.37	9.12	7.52	16.47	13.00	7.36	8.34	12.31
2003	16.22	4.68	4.13	10.03	37.66	18.71	13.47	23.19	21.58	12.61	5.93	6.36
2004	5.13	4.20	4.52	24.93	24.79	11.16	12.35	17.32	13.12	13.29	18.20	12.77
2005	7.89	6.28	9.51	11.03	23.70	17.87	14.90	11.56	14.44	10.15	8.35	4.91
2006	4.14	3.68	5.00	26.63	15.23	12.91	19.20	20.28	14.77	8.39	17.20	23.38
2007	14.41	9.78	10.37	12.81	24.04	26.55	32.22	35.01	35.26	14.61	7.97	5.32
2008	4.45	3.97	5.60	24.20	14.16	16.94	17.40	21.48	17.72	17.37	15.34	6.60
2009	4.66	4.18	4.19	5.47	15.87	10.83	8.78	13.52	18.90	16.55	11.63	11.08
2010	21.06	8.83	15.36	15.92	29.93	20.44	15.50	12.41	22.09	20.35	11.55	7.73

Sub-basin: **IFE** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	9.94	7.86	7.95	27.69	45.62	28.89	19.80	16.83	17.29	25.55	21.19	10.58
1992	7.37	5.97	6.48	6.27	11.77	34.80	37.51	24.64	30.28	24.63	17.29	11.80
1993	9.44	8.60	10.57	9.04	32.97	32.48	15.96	13.28	19.63	12.42	9.65	8.75
1994	6.97	5.94	7.73	27.86	46.38	28.65	25.70	26.75	22.89	12.92	28.16	24.03
1995	8.34	6.41	10.65	19.83	36.49	26.07	29.08	18.98	21.98	23.77	27.04	16.49
1996	9.96	11.43	16.46	45.44	33.89	29.45	20.61	15.40	28.78	26.23	14.24	18.38
1997	9.12	6.35	6.33	17.26	39.06	17.05	22.37	17.75	12.42	9.17	23.89	42.36
1998	40.03	15.18	11.05	14.49	40.19	25.51	19.90	15.85	15.80	28.66	23.45	9.80
1999	7.22	5.95	7.74	25.05	37.33	19.76	21.58	31.70	29.59	31.66	17.60	13.01
2000	8.47	6.09	6.41	6.12	12.37	16.46	20.13	21.05	18.90	22.96	17.17	20.09
2001	24.32	17.94	10.13	23.87	32.89	27.94	22.96	17.90	21.93	23.57	22.22	13.99
2002	8.82	6.86	9.44	22.41	52.01	19.91	14.30	19.66	17.82	15.38	25.99	21.39
2003	25.82	7.80	6.78	9.77	56.07	34.25	31.82	35.86	30.35	19.34	10.17	10.21
2004	8.86	7.29	7.47	20.88	35.29	15.42	11.45	15.41	19.78	25.15	21.20	15.15
2005	10.69	8.39	10.28	17.61	28.33	26.48	16.36	17.62	16.14	11.79	9.60	7.42
2006	6.20	5.66	7.72	50.23	31.87	24.30	19.91	21.67	22.41	15.41	27.10	42.14
2007	25.73	12.47	13.97	18.41	28.71	29.01	27.26	44.74	44.39	22.98	14.81	8.70
2008	6.75	5.86	5.96	21.71	30.92	32.52	21.80	30.82	34.25	31.07	32.57	11.75
2009	7.11	7.18	6.64	14.48	30.55	17.79	13.79	15.11	23.49	22.67	14.27	13.58
2010	26.42	11.21	21.18	25.78	43.85	27.66	24.73	19.34	33.05	27.44	17.28	10.72

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **1FF** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.72	0.12	0.01	7.45	12.62	6.43	2.36	1.15	1.32	3.27	4.72	0.71
1992	0.01	0.00	0.00	0.00	0.02	6.52	6.82	3.21	4.61	3.95	2.25	1.04
1993	0.51	0.47	0.30	0.27	7.33	7.10	2.35	0.72	1.88	0.63	0.12	0.01
1994	0.00	0.00	0.01	6.21	12.04	5.80	4.00	3.28	2.95	0.80	6.01	5.01
1995	0.13	0.00	0.03	5.22	9.26	5.47	5.23	2.09	2.53	4.82	7.26	2.67
1996	0.52	1.25	3.56	13.46	9.00	6.59	3.28	1.02	4.55	6.77	2.15	4.17
1997	0.32	0.00	0.00	0.70	9.25	3.18	2.93	1.64	0.71	0.01	2.44	16.68
1998	12.15	1.99	0.39	3.23	9.81	4.98	2.70	1.00	0.69	4.15	4.16	0.38
1999	0.00	0.00	0.01	5.59	9.41	3.58	2.36	4.40	5.70	6.03	2.57	2.19
2000	0.34	0.00	0.00	0.00	0.02	1.13	2.18	2.18	1.89	3.27	2.51	5.53
2001	6.37	3.73	0.76	5.60	7.09	5.55	3.41	2.07	4.18	5.61	5.00	1.95
2002	0.10	0.00	0.01	7.91	13.69	3.74	1.15	1.16	1.41	1.96	7.69	4.54
2003	4.74	0.16	0.00	1.53	13.12	6.70	5.58	6.65	6.06	2.56	0.54	0.40
2004	0.09	0.07	0.01	2.68	7.94	2.00	0.54	0.65	2.55	5.68	4.43	2.37
2005	0.84	0.16	0.01	2.17	7.38	5.43	2.00	2.24	2.25	1.01	0.35	0.01
2006	0.00	0.00	0.00	11.25	7.99	5.71	2.85	2.44	2.60	1.79	8.47	12.70
2007	5.66	1.89	1.78	3.69	6.29	5.56	3.12	7.56	8.04	4.15	2.05	0.11
2008	0.00	0.00	0.00	0.61	7.53	6.87	2.71	4.92	8.58	8.51	9.14	1.40
2009	0.01	0.01	0.00	0.54	7.68	2.79	0.93	0.45	1.89	3.76	1.29	1.71
2010	4.66	0.78	3.92	7.04	12.22	4.25	2.96	1.54	5.06	4.85	2.51	0.71

Sub-basin: **1FG** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.00	0.00	0.00	30.18	24.55	9.76	1.51	0.00	0.00	0.00	3.39	0.00
1992	0.00	0.00	0.00	0.00	0.00	0.00	1.47	0.00	1.14	1.55	3.92	1.95
1993	6.54	0.00	0.00	0.00	7.73	14.24	0.84	0.00	0.00	0.00	0.00	0.00
1994	0.00	0.00	0.00	0.00	40.23	12.71	0.73	2.90	4.56	0.49	26.01	16.42
1995	0.00	0.00	0.00	17.74	32.07	6.53	2.79	0.00	3.89	14.76	19.79	5.52
1996	0.00	0.00	9.25	49.02	25.14	21.43	3.25	0.00	14.47	27.47	7.19	12.20
1997	0.00	0.00	0.00	0.00	11.85	3.53	0.68	0.00	0.00	0.00	31.81	70.87
1998	40.77	0.93	0.00	11.19	30.55	3.12	0.00	0.00	0.00	0.00	4.28	0.00
1999	0.00	0.00	0.00	9.11	38.99	4.00	0.00	0.00	15.06	20.23	10.70	17.31
2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	9.14	12.37
2001	13.38	9.13	0.00	20.22	19.65	16.09	0.22	0.00	4.08	6.03	13.71	0.82
2002	0.00	0.00	0.00	15.36	39.53	2.44	0.00	0.00	0.00	0.00	28.93	8.60
2003	10.15	0.00	0.00	6.21	28.73	10.45	5.22	0.00	1.59	0.00	0.92	0.00
2004	0.00	0.00	0.00	0.00	10.99	0.91	0.00	0.00	0.93	16.41	28.48	2.74
2005	0.00	0.00	0.00	0.00	7.58	13.86	0.00	0.62	5.97	4.61	3.41	0.00
2006	0.00	0.00	0.00	35.51	29.00	10.85	0.00	1.51	0.00	1.41	25.38	52.63
2007	16.90	2.98	0.00	14.54	35.86	14.85	0.00	0.00	1.36	7.00	5.25	0.00
2008	0.00	0.00	0.00	10.09	19.28	13.06	0.00	10.58	54.61	28.98	37.88	1.16
2009	0.00	0.00	0.00	2.24	33.14	4.53	0.00	0.00	1.52	4.46	2.36	7.25
2010	12.86	0.00	7.56	11.84	31.10	0.71	0.00	0.00	0.00	10.14	4.65	0.00

2. Lake Victoria South Catchment Area (LVSCA)

1GA, 1GB, 1GC, 1GD, 1GE & 1GG

Sub-basin: **1GA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	6.64	4.14	4.17	20.03	19.62	25.25	24.25	15.12	13.43	12.35	7.97	3.38
1992	2.24	1.83	1.85	2.87	15.49	21.49	29.97	37.55	30.31	22.07	13.92	5.60
1993	6.01	10.04	5.35	2.96	24.81	25.80	14.70	12.74	11.32	6.17	7.94	9.27
1994	3.01	1.90	4.76	20.36	44.09	23.03	19.77	25.28	11.28	3.88	14.52	8.82
1995	2.74	2.01	7.28	10.43	19.90	12.41	16.43	13.32	17.59	12.94	13.32	5.08
1996	3.07	4.29	7.26	21.14	14.79	15.08	18.98	25.89	19.53	6.83	6.19	9.22
1997	3.24	1.95	1.82	29.84	20.87	6.08	17.72	10.56	4.68	4.52	35.25	22.70
1998	30.43	14.32	5.20	5.47	23.23	16.43	24.41	19.88	11.29	16.79	14.48	3.91
1999	2.37	1.80	5.75	15.74	18.33	8.75	16.66	24.07	14.77	22.50	10.63	11.03
2000	3.28	1.98	1.90	1.78	6.13	10.02	22.43	20.61	10.95	19.55	12.75	6.90
2001	15.04	7.93	3.32	23.82	23.06	23.22	19.31	15.67	13.08	10.60	22.56	7.89
2002	5.67	3.34	8.02	8.09	33.11	6.55	5.37	17.22	9.32	5.76	15.00	19.13
2003	18.18	2.88	2.03	14.13	42.26	16.73	11.72	29.86	18.00	8.09	3.71	4.84
2004	3.44	2.41	2.42	34.45	21.50	8.46	11.47	22.52	10.48	11.70	18.84	16.75
2005	6.24	4.22	7.16	12.17	29.15	17.01	13.31	13.63	24.05	7.35	4.89	2.51
2006	1.96	1.67	6.54	38.58	17.72	13.65	20.91	26.52	16.80	6.05	26.15	37.11
2007	17.73	14.90	8.31	16.04	30.01	24.82	28.12	31.45	31.67	10.84	4.47	2.60
2008	2.10	1.87	3.66	22.94	11.25	15.04	19.24	39.92	27.26	20.21	17.17	5.39
2009	2.58	2.19	2.05	4.34	15.04	7.93	5.12	6.40	22.87	14.07	10.72	13.63
2010	28.56	6.83	18.95	19.15	40.89	20.03	15.86	14.51	25.20	17.91	10.57	6.39

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **IGB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	4.52	1.75	4.16	21.80	22.43	26.07	17.51	3.80	3.71	14.22	5.62	1.87
1992	0.97	0.65	0.63	1.20	14.29	25.41	23.40	27.63	29.11	19.63	8.41	2.66
1993	2.12	2.29	3.46	2.01	27.47	24.95	5.97	3.62	5.51	2.52	5.88	11.92
1994	1.68	0.77	6.38	29.69	39.28	17.26	13.38	20.07	8.48	2.95	21.91	9.08
1995	1.47	0.89	2.51	15.08	23.67	9.51	11.01	11.62	13.45	18.08	11.42	3.29
1996	3.15	6.81	15.95	36.14	19.12	14.64	21.95	16.16	20.64	7.63	12.33	6.97
1997	1.79	0.83	0.66	22.24	23.23	5.63	15.07	4.74	2.45	2.53	41.91	43.33
1998	35.86	9.96	5.85	9.21	24.21	11.09	6.95	9.18	10.76	15.28	8.74	1.97
1999	1.03	0.66	1.50	9.92	22.22	10.90	14.52	28.39	17.32	24.01	7.94	11.21
2000	2.14	0.93	0.79	0.67	2.74	4.92	18.12	16.81	7.85	17.29	16.55	7.44
2001	26.89	5.96	2.10	25.15	24.39	22.99	14.34	11.74	11.02	6.72	12.99	3.87
2002	6.26	1.86	13.83	14.14	37.54	5.17	2.80	11.08	6.89	4.52	23.59	16.65
2003	20.74	1.52	0.85	17.35	45.58	20.20	9.10	15.69	16.23	8.80	2.48	7.56
2004	3.48	1.69	1.18	45.49	25.39	4.14	4.06	9.47	8.24	6.03	15.78	8.50
2005	5.31	5.63	11.06	10.06	15.20	11.80	7.59	5.33	6.55	4.51	5.05	1.20
2006	0.61	0.43	2.77	39.49	13.51	10.03	11.50	8.57	10.49	3.10	32.40	42.77
2007	17.11	8.53	12.51	12.65	40.49	25.45	28.37	31.30	35.78	7.12	2.41	1.12
2008	0.78	0.69	1.66	32.62	11.37	18.65	16.19	22.52	21.07	21.21	13.32	2.14
2009	0.94	0.92	0.73	2.43	11.06	5.05	4.26	4.30	31.91	11.23	14.94	11.88
2010	28.54	4.58	22.95	18.02	38.88	20.72	8.20	7.28	23.94	17.42	8.06	4.78

Sub-basin: **IGC** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	21.07	11.70	9.58	34.48	37.58	40.33	36.21	34.19	29.72	24.43	21.04	8.64
1992	6.31	5.36	5.62	14.35	28.22	28.57	39.47	55.28	45.17	34.03	23.98	13.78
1993	18.85	31.20	14.64	9.11	40.11	39.22	30.25	19.83	17.55	11.60	9.56	11.40
1994	6.28	4.99	9.73	22.78	62.66	38.73	40.71	44.76	20.41	10.00	19.61	16.03
1995	6.60	5.46	16.34	20.50	38.76	28.57	29.76	23.18	32.10	31.42	28.61	12.51
1996	9.12	13.96	13.39	37.18	24.47	24.46	35.43	35.13	37.38	17.31	12.25	17.36
1997	7.00	5.10	5.23	12.62	31.38	10.95	24.48	20.90	9.44	7.14	43.21	39.05
1998	43.42	27.12	11.00	17.69	43.61	26.58	43.29	43.60	26.33	43.67	21.93	8.38
1999	6.07	5.01	9.00	22.76	30.98	14.48	16.80	36.49	22.30	32.02	18.68	12.61
2000	6.64	5.05	5.17	5.21	13.10	14.06	23.44	34.69	18.30	24.95	28.88	23.26
2001	41.77	18.00	9.68	46.67	41.64	36.29	29.97	25.51	22.07	29.49	50.75	20.23
2002	13.95	7.96	18.61	18.12	69.38	15.51	12.86	26.37	15.84	11.83	35.72	36.89
2003	29.53	7.07	5.74	32.92	72.94	31.72	19.24	41.26	28.34	16.03	12.21	15.95
2004	10.96	7.55	7.20	48.40	37.73	13.75	11.85	26.39	19.34	19.24	21.13	18.89
2005	11.42	8.28	15.52	25.28	38.46	30.37	21.88	32.28	41.69	14.46	9.82	6.40
2006	5.37	4.63	10.72	53.86	38.58	21.41	32.09	37.83	25.12	14.41	52.58	75.70
2007	39.93	31.22	15.16	26.34	40.33	38.19	35.45	45.29	51.43	22.74	10.04	6.61
2008	5.72	5.17	7.57	27.83	24.51	21.86	26.69	60.20	44.43	39.35	36.50	12.42
2009	6.63	6.32	5.79	9.55	16.39	12.93	9.16	7.82	18.91	20.01	15.66	31.45
2010	40.61	12.38	37.28	38.85	64.92	25.87	26.96	27.82	36.40	34.25	19.54	15.46

Sub-basin: **IGD** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	12.60	4.37	9.38	22.05	23.78	21.47	12.46	8.08	5.65	10.84	5.73	4.78
1992	5.01	5.02	5.27	6.19	12.47	14.25	11.99	21.37	17.39	10.76	6.25	4.09
1993	4.87	6.62	4.52	5.15	16.32	13.70	7.26	4.65	4.67	5.05	4.83	9.61
1994	4.96	4.76	13.16	25.97	30.36	12.33	10.85	10.90	5.07	4.66	14.35	5.66
1995	4.86	4.64	6.07	12.98	16.31	10.43	7.84	7.79	10.86	20.15	8.90	4.04
1996	5.12	12.02	13.73	31.28	16.52	14.56	18.87	9.00	12.94	5.44	10.96	8.52
1997	4.74	4.52	5.40	8.80	14.78	4.45	8.85	4.89	4.63	5.53	24.82	38.20
1998	29.29	7.99	5.22	13.49	17.71	13.22	7.63	9.10	7.66	16.26	5.54	5.14
1999	5.25	4.84	8.27	17.08	20.19	8.98	6.99	13.79	9.46	14.21	5.27	9.67
2000	4.60	4.67	5.15	5.21	6.52	7.56	11.54	12.91	4.44	10.04	17.22	9.35
2001	35.91	5.95	5.14	26.68	22.31	13.16	8.27	5.71	6.62	10.47	16.74	7.02
2002	9.29	4.08	17.96	12.21	34.86	5.72	4.56	8.00	4.46	6.01	35.51	16.50
2003	18.13	4.01	5.21	20.42	33.62	14.44	6.01	10.66	7.32	6.41	4.47	9.04
2004	6.10	4.23	5.60	40.70	19.48	4.78	4.87	6.69	6.87	4.66	8.10	6.37
2005	4.73	5.39	11.83	9.85	11.28	10.08	6.93	8.78	8.39	4.46	4.67	5.19
2006	5.15	4.81	7.30	27.47	15.36	10.32	11.33	10.70	8.10	6.60	37.33	47.85
2007	21.45	15.09	12.07	15.38	32.40	17.77	15.93	17.75	25.72	6.04	0.00	0.00
2008	0.00	0.00	0.00	3.64	3.68	3.88	0.18	12.84	14.45	14.25	9.02	0.00
2009	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.37	0.52	1.76	4.99
2010	12.74	0.00	15.75	17.24	33.06	6.28	2.20	0.58	6.25	4.08	0.91	0.00

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **IGE** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	2.08	0.06	0.05	0.57	20.47	18.48	2.04	0.05	0.05	0.30	0.24	0.02
1992	0.01	0.01	0.01	0.01	0.09	0.97	0.32	0.51	0.65	6.92	0.44	0.07
1993	0.13	0.02	0.01	0.01	0.72	5.49	0.93	0.06	0.05	0.05	0.05	0.06
1994	0.05	0.04	0.08	7.78	20.94	5.76	5.84	7.47	0.85	0.06	3.85	3.78
1995	0.05	0.04	0.05	0.27	2.65	6.74	0.10	0.08	0.17	21.57	4.78	0.12
1996	0.07	2.97	14.11	35.75	16.99	11.11	12.89	0.23	5.78	0.14	10.08	4.44
1997	0.05	0.04	0.04	0.04	0.07	0.06	0.06	0.05	0.05	0.04	1.02	11.40
1998	29.75	5.59	0.06	1.04	14.32	1.24	0.06	0.05	0.05	1.12	0.04	0.01
1999	0.01	0.01	0.01	0.01	0.06	0.21	0.03	4.35	0.50	0.82	0.03	0.38
2000	0.05	0.04	0.04	0.04	0.22	0.03	0.10	0.44	0.03	0.33	1.09	0.62
2001	26.28	1.42	0.06	12.43	15.81	6.83	0.07	0.13	0.10	0.16	13.80	0.07
2002	0.37	0.05	1.28	8.10	36.09	0.08	0.05	0.05	0.04	0.05	16.40	11.64
2003	11.50	0.05	0.05	8.05	37.91	4.01	0.07	0.15	0.08	0.02	0.01	0.22
2004	0.02	0.02	0.01	17.32	15.94	0.05	0.05	0.05	0.05	0.07	0.06	0.06
2005	0.05	0.06	0.12	0.31	0.35	0.04	0.04	0.03	0.04	0.01	0.01	0.00
2006	0.00	0.00	0.00	0.63	0.64	0.06	0.08	0.02	0.18	0.04	24.73	4.33
2007	0.74	2.64	8.25	10.82	21.11	14.75	6.86	7.63	15.65	0.08	0.05	0.04
2008	0.04	0.04	0.04	0.06	0.08	0.29	0.07	0.55	1.27	0.99	6.85	0.06
2009	0.04	0.04	0.04	0.04	0.05	0.04	0.04	0.04	0.05	0.06	0.07	0.46
2010	0.78	0.02	1.45	1.36	23.18	4.78	3.48	0.39	4.48	2.91	0.18	0.07

Sub-basin: **IGG** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	10.41	3.85	4.22	22.41	19.39	19.70	17.28	11.71	10.82	10.63	7.35	1.83
1992	1.08	0.85	0.86	5.09	13.82	15.27	17.22	28.38	21.95	14.75	9.17	3.41
1993	5.01	8.24	3.68	2.87	20.28	17.55	11.04	6.90	6.85	3.53	2.78	5.78
1994	1.47	0.83	6.45	16.00	32.50	17.42	15.76	18.16	6.67	2.27	10.19	5.96
1995	1.31	0.93	7.17	9.77	17.12	11.90	11.26	9.29	13.68	13.45	11.33	3.42
1996	2.06	6.70	6.39	20.40	11.41	12.20	15.85	14.90	15.60	5.17	4.70	7.70
1997	1.55	0.80	0.67	9.69	14.43	3.46	10.26	6.92	2.06	1.41	24.02	16.51
1998	20.22	10.22	2.79	8.31	19.74	13.96	16.63	14.14	10.54	19.12	8.46	1.71
1999	1.06	0.79	5.09	16.84	18.70	6.60	8.17	14.92	9.48	15.52	6.32	5.68
2000	1.52	0.78	0.71	0.79	7.37	8.11	14.69	15.41	6.19	12.68	13.17	7.92
2001	21.41	6.71	3.01	23.32	21.54	17.97	11.42	8.82	8.28	12.34	22.20	7.46
2002	5.59	2.06	10.25	9.21	30.52	5.40	3.61	10.34	5.33	5.12	21.51	15.71
2003	14.11	1.48	0.89	16.61	31.61	14.39	7.92	17.77	11.31	6.07	3.35	5.80
2004	3.57	1.62	1.31	28.56	17.59	5.28	4.87	12.77	7.86	7.01	10.92	8.23
2005	3.97	2.20	8.34	11.53	18.25	14.41	8.90	11.04	17.00	4.90	2.77	1.07
2006	0.76	0.62	7.13	33.49	18.41	10.52	15.74	17.95	10.64	5.49	25.90	38.55
2007	17.60	16.02	5.92	13.76	23.55	17.67	16.94	19.80	24.66	8.04	2.11	1.11
2008	0.86	0.76	2.71	16.77	10.35	10.84	11.35	30.65	22.37	18.07	14.63	3.27
2009	1.20	1.30	0.99	4.83	9.88	4.70	2.79	2.02	15.37	9.74	7.53	14.34
2010	19.21	5.15	17.69	17.28	33.87	13.25	10.94	10.81	15.48	13.38	7.48	6.22

1HA1, 1HA2, 1HB1, 1HB2, 1HD, 1HE & 1HG

Sub-basin: **1HA1** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	3.72	2.37	2.50	10.59	21.33	13.95	4.85	2.66	2.51	7.29	5.98	2.61
1992	2.58	2.37	2.57	2.25	6.93	13.46	9.12	7.01	11.71	7.54	4.65	3.01
1993	2.97	2.42	2.57	2.65	16.98	14.35	4.08	2.86	3.41	2.51	2.44	2.63
1994	2.60	2.37	7.41	14.78	23.39	8.52	6.91	6.56	4.46	2.52	9.22	9.14
1995	2.35	2.13	2.89	8.18	20.71	7.69	6.30	4.62	4.85	9.09	8.51	3.67
1996	2.97	4.15	14.14	22.66	16.95	9.86	9.14	4.82	8.64	5.25	7.71	8.05
1997	2.41	2.20	2.60	8.91	13.95	4.35	5.24	3.16	2.61	2.62	9.12	43.81
1998	26.00	5.23	3.51	9.88	12.88	8.67	4.46	2.78	2.61	6.71	4.90	2.61
1999	2.49	2.32	2.42	10.61	10.26	5.38	6.46	17.34	9.63	9.80	4.75	7.09
2000	2.58	2.27	2.44	2.34	6.57	4.73	6.13	5.85	4.99	6.53	7.42	11.68
2001	22.96	5.37	2.65	9.62	10.84	10.22	5.85	5.71	12.75	7.44	10.83	3.61
2002	3.30	2.41	6.08	19.93	27.06	5.08	2.77	3.54	4.29	3.46	12.92	10.01
2003	9.62	2.18	2.51	13.95	25.13	8.88	6.29	11.13	10.31	4.61	2.52	3.94
2004	3.38	2.73	2.35	20.52	15.61	2.96	2.47	3.66	7.77	6.61	6.97	4.82
2005	3.80	3.32	4.99	6.99	16.14	7.11	4.10	4.05	3.68	2.64	2.81	2.59
2006	2.47	2.32	2.44	16.08	8.09	6.46	4.63	4.37	4.29	3.32	21.84	26.52
2007	12.51	4.35	11.18	7.85	14.28	10.42	11.20	14.46	12.83	5.04	2.64	1.52
2008	1.31	1.17	1.39	10.38	8.40	9.63	6.82	8.29	7.88	18.81	12.61	2.96
2009	1.62	1.85	1.43	4.38	9.42	3.98	2.69	2.73	7.28	5.75	3.98	6.47
2010	10.03	3.02	12.35	18.65	26.70	7.16	4.99	4.09	10.37	6.19	4.13	2.94

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **IHA2** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.12	0.03	0.01	0.17	4.44	4.03	0.11	0.02	0.01	0.01	0.02	0.01
1992	0.01	0.00	0.00	0.00	0.00	0.04	0.21	0.09	0.73	0.27	0.12	0.03
1993	0.02	0.02	0.01	0.00	0.94	1.81	0.07	0.01	0.01	0.00	0.00	0.00
1994	0.00	0.00	0.00	0.91	4.34	0.82	0.13	0.18	0.06	0.01	0.10	0.51
1995	0.03	0.01	0.00	0.01	1.65	0.77	0.05	0.02	0.01	1.42	0.54	0.06
1996	0.02	0.05	3.88	16.84	2.84	1.04	1.10	0.13	0.29	0.11	1.07	1.96
1997	0.04	0.01	0.01	0.01	0.03	0.03	0.01	0.01	0.00	0.00	0.02	38.59
1998	14.31	0.42	0.07	0.65	1.21	0.15	0.08	0.02	0.01	0.01	0.00	0.00
1999	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.81	0.91	0.93	0.08	0.80
2000	0.05	0.02	0.02	0.01	0.02	0.02	0.02	0.02	0.02	0.11	0.65	1.49
2001	18.01	0.33	0.05	0.62	0.84	0.68	0.06	0.06	0.73	0.44	0.98	0.05
2002	0.03	0.04	0.20	2.79	18.43	0.10	0.03	0.01	0.01	0.00	2.00	0.99
2003	1.20	0.06	0.03	8.31	8.09	0.37	0.08	0.12	0.27	0.07	0.01	0.01
2004	0.01	0.01	0.00	10.46	7.95	0.07	0.02	0.01	0.01	0.01	0.03	0.09
2005	0.06	0.13	0.07	0.25	0.80	0.44	0.04	0.02	0.01	0.01	0.01	0.01
2006	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	19.30	13.06
2007	5.74	0.15	3.10	0.79	5.87	1.15	0.64	1.07	0.77	0.11	0.03	0.01
2008	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.34	4.82	1.19	0.06
2009	0.02	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01
2010	0.49	0.05	1.40	4.58	11.00	0.22	0.10	0.03	0.57	0.16	0.02	0.01

Sub-basin: **IHB1** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	1.11	0.19	0.00	9.02	9.33	6.98	2.67	0.63	0.14	0.15	1.49	0.87
1992	0.07	0.00	0.00	0.00	0.01	0.87	3.90	1.54	1.96	2.46	2.11	1.88
1993	2.39	1.22	0.32	0.06	3.44	7.15	2.75	0.42	0.32	0.08	0.13	0.01
1994	0.00	0.00	0.01	2.98	14.87	7.28	3.19	1.92	2.26	0.70	6.17	8.41
1995	0.72	0.01	0.09	6.51	13.72	5.77	3.41	1.04	0.85	3.25	8.77	5.10
1996	1.70	1.21	4.52	18.47	12.32	9.06	3.99	0.87	2.03	10.07	3.90	6.61
1997	0.82	0.04	0.00	0.01	7.86	3.76	2.47	0.95	0.20	0.01	4.91	30.69
1998	18.56	2.78	0.51	3.02	12.19	4.39	1.70	0.30	0.01	0.37	1.01	0.13
1999	0.00	0.00	0.00	3.56	13.20	4.26	1.45	1.48	3.07	5.28	3.95	5.74
2000	1.23	0.03	0.01	0.00	0.01	0.01	0.01	0.01	0.01	0.44	1.90	7.22
2001	8.63	6.10	1.49	6.16	7.57	6.70	2.89	1.35	2.11	5.46	6.20	2.92
2002	0.43	0.04	0.01	9.06	16.62	4.01	0.68	0.18	0.13	0.20	7.00	6.44
2003	5.70	0.48	0.01	3.51	12.60	6.34	3.67	1.58	2.22	1.07	0.81	0.51
2004	0.16	0.03	0.01	0.37	5.32	2.16	0.84	0.17	0.42	3.22	8.09	4.00
2005	1.22	0.20	0.01	0.63	5.93	6.42	1.89	1.24	2.04	1.89	1.97	0.25
2006	0.00	0.00	0.00	11.22	11.99	6.33	2.52	1.47	0.84	0.58	7.91	20.92
2007	9.64	2.98	2.34	4.56	13.36	7.68	2.32	1.67	1.74	2.14	2.17	0.53
2008	0.01	0.00	0.00	3.82	8.29	6.93	2.07	3.23	13.49	12.20	11.88	2.46
2009	0.09	0.04	0.00	0.93	10.18	3.94	0.86	0.10	0.35	1.60	0.92	2.15
2010	4.49	0.59	3.16	6.95	16.01	3.47	0.85	0.03	0.46	1.36	1.80	0.69

Sub-basin: **IHB2** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	1.13	0.48	0.23	5.48	9.10	6.30	1.68	0.41	0.24	0.81	2.70	0.70
1992	0.12	0.03	0.03	0.15	1.40	6.72	3.71	1.56	2.58	2.63	1.49	0.88
1993	0.74	0.39	0.24	0.43	5.91	5.62	1.60	0.45	0.32	0.10	0.06	0.08
1994	0.02	0.00	3.47	7.01	10.83	4.15	2.33	1.56	0.89	0.24	2.87	4.16
1995	0.45	0.13	0.37	4.11	10.50	3.62	2.64	0.91	0.59	3.33	4.94	1.69
1996	0.77	1.09	5.25	11.57	7.31	5.26	2.71	0.83	1.46	2.40	2.09	3.79
1997	0.54	0.13	0.01	2.30	7.66	2.04	1.32	0.54	0.17	0.09	1.54	22.14
1998	12.54	1.73	0.77	4.64	5.34	3.70	1.67	0.37	0.11	0.40	0.64	0.13
1999	0.05	0.04	0.17	7.32	6.93	2.39	1.27	3.44	3.34	3.35	1.53	2.98
2000	0.78	0.16	0.05	0.07	1.83	1.21	1.01	0.64	0.43	0.79	2.02	6.06
2001	10.03	3.17	0.92	3.56	3.81	3.03	1.30	1.06	4.67	3.97	4.89	1.49
2002	0.69	0.30	1.01	9.92	12.30	2.35	0.66	0.34	0.24	0.24	5.25	4.11
2003	3.17	0.36	0.12	4.67	9.85	3.28	2.05	3.33	4.01	1.34	0.53	0.56
2004	0.59	0.47	0.21	4.19	6.26	1.00	0.30	0.23	0.88	2.73	3.13	2.02
2005	1.29	0.60	0.53	1.81	6.31	3.42	1.09	0.88	0.85	0.35	0.34	0.06
2006	0.01	0.01	0.05	7.27	5.37	3.47	1.46	0.85	0.61	0.57	8.27	13.08
2007	6.48	2.09	3.42	3.52	5.57	3.72	1.99	3.64	2.75	1.44	0.50	0.10
2008	0.02	0.01	0.01	2.11	5.17	5.02	1.43	2.52	4.01	8.90	6.78	1.17
2009	0.22	0.42	0.13	2.18	6.03	1.67	0.48	0.16	0.33	0.94	0.54	2.26
2010	3.66	0.80	4.53	7.64	12.43	2.12	0.79	0.30	1.90	2.23	1.20	0.56

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **IHD** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	4.91	2.27	0.39	11.43	17.08	26.47	8.72	1.60	3.91	10.79	9.68	2.68
1992	0.58	0.11	0.09	8.34	16.38	17.29	15.75	6.98	13.25	20.51	11.06	6.75
1993	12.36	8.88	2.11	0.65	22.27	28.73	9.12	1.74	1.90	0.57	0.74	2.48
1994	0.27	0.01	8.29	31.06	35.86	18.74	14.84	8.51	7.97	4.75	26.18	16.49
1995	1.88	0.25	7.73	13.28	25.50	23.24	16.34	4.36	2.84	9.84	18.94	8.23
1996	5.99	13.50	15.78	34.16	25.62	16.26	14.69	4.74	17.85	12.52	10.96	13.12
1997	2.49	0.21	0.01	1.68	23.71	7.44	3.63	4.30	4.27	0.59	16.15	55.80
1998	36.80	7.86	1.65	10.09	24.38	14.49	7.98	2.72	3.55	13.47	8.95	0.99
1999	0.09	0.01	0.07	17.03	18.12	10.84	5.76	10.73	10.91	24.60	9.02	12.56
2000	2.83	0.10	0.11	5.87	27.22	8.74	9.08	6.74	6.72	9.08	19.09	23.35
2001	31.39	13.29	2.04	18.25	19.24	23.38	6.24	3.37	10.32	16.32	25.39	5.95
2002	3.69	2.50	7.22	19.76	49.45	10.29	2.26	1.30	1.90	1.13	23.28	11.60
2003	13.27	1.23	0.13	12.04	43.79	15.37	9.49	6.72	10.91	7.28	4.65	7.84
2004	3.34	1.62	2.13	26.53	25.21	7.46	1.43	1.98	12.30	9.96	8.86	10.38
2005	5.07	1.40	1.54	13.13	14.64	14.38	7.01	3.08	7.48	3.25	1.72	0.10
2006	0.00	0.00	0.34	29.00	29.04	11.07	5.16	1.48	1.40	1.44	22.61	33.95
2007	31.28	13.44	10.09	11.84	15.72	21.83	10.18	5.56	6.51	3.08	0.70	0.15
2008	0.02	0.00	0.02	13.01	11.40	8.05	5.18	12.76	14.33	19.02	17.79	4.33
2009	0.33	0.42	0.14	7.50	21.28	12.58	3.57	2.45	7.01	6.17	1.98	12.79
2010	18.25	2.55	16.72	25.49	49.41	13.41	7.30	3.18	18.83	13.37	6.61	7.91

Sub-basin: **IHE** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	2.68	0.50	0.01	6.76	18.35	17.27	7.15	0.30	0.34	4.99	11.38	3.71
1992	0.46	0.01	0.01	1.29	16.20	13.52	12.67	4.70	7.29	16.24	9.22	6.48
1993	9.14	7.71	2.26	0.70	18.01	20.32	6.67	1.12	1.72	1.40	1.42	1.35
1994	0.01	0.00	1.21	24.28	27.58	14.05	10.47	5.07	4.96	2.81	25.16	16.76
1995	1.47	0.01	2.38	12.13	20.82	14.64	12.86	3.12	0.60	2.10	13.79	8.42
1996	2.43	3.61	11.42	24.33	25.62	11.45	9.18	2.52	18.64	14.26	8.63	11.23
1997	2.78	0.24	0.01	0.03	23.18	7.06	2.35	1.20	2.26	0.27	14.25	48.65
1998	28.57	4.60	0.48	5.91	21.87	14.72	6.43	1.19	1.01	8.17	7.06	0.69
1999	0.01	0.00	0.01	11.34	22.69	9.55	4.15	5.26	5.85	19.55	9.75	11.70
2000	2.20	0.01	0.01	0.02	24.96	6.87	6.32	2.65	2.83	8.03	14.23	18.68
2001	20.87	8.80	0.75	12.26	20.24	24.24	4.07	0.73	2.92	15.21	22.84	4.97
2002	1.37	0.51	3.18	23.73	41.04	8.77	1.67	0.10	0.02	0.23	18.77	8.79
2003	11.17	0.84	0.01	5.55	38.26	13.74	9.74	3.58	9.46	6.93	5.10	6.06
2004	1.60	0.13	0.35	8.34	20.89	7.95	1.32	0.01	5.05	10.79	12.53	11.19
2005	4.57	0.46	0.01	6.65	16.70	12.15	5.18	2.45	7.40	4.32	1.61	0.01
2006	0.00	0.00	0.01	27.12	27.52	9.60	2.71	0.29	0.01	0.01	9.73	26.50
2007	24.86	10.81	4.71	5.39	13.89	21.50	7.51	2.82	2.78	1.99	0.89	0.01
2008	0.01	0.00	0.00	9.48	11.98	7.16	4.64	11.47	11.39	14.27	15.82	2.86
2009	0.01	0.01	0.01	1.58	25.83	13.47	3.14	0.50	2.34	4.03	1.39	12.07
2010	16.62	1.04	5.81	20.34	41.03	9.33	4.66	0.27	12.97	11.70	7.62	6.65

Sub-basin: **IHG** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.10	0.03	0.01	4.09	9.55	4.46	0.97	0.07	0.01	0.03	2.45	1.10
1992	0.11	0.00	0.00	0.43	5.85	1.52	1.49	0.25	0.12	0.53	1.65	6.53
1993	4.04	2.35	0.57	0.02	2.10	3.42	0.71	0.01	0.01	0.01	0.01	0.00
1994	0.00	0.00	0.10	8.39	14.15	4.72	1.99	0.72	0.91	0.23	6.55	6.13
1995	0.59	0.02	0.12	5.74	9.96	3.36	1.16	0.15	0.01	0.01	1.39	2.01
1996	0.30	0.02	0.14	5.29	13.61	3.31	1.24	0.08	3.57	5.89	2.44	2.60
1997	0.52	0.02	0.00	3.44	12.02	1.28	0.33	0.02	0.00	0.59	11.42	25.31
1998	19.53	1.31	0.10	1.20	10.53	4.43	1.05	0.04	0.01	0.01	0.00	0.00
1999	0.00	0.00	0.00	1.18	12.28	2.64	0.27	0.01	0.00	0.01	0.59	4.91
2000	0.68	0.00	0.00	0.01	1.89	0.86	0.43	0.02	0.00	0.01	0.02	1.92
2001	4.93	2.19	0.30	4.92	5.97	3.77	0.63	0.03	0.00	0.01	0.85	1.07
2002	0.04	0.00	0.00	7.90	19.01	3.20	0.55	0.02	0.00	0.00	0.05	0.94
2003	2.20	0.14	0.00	6.27	20.14	6.43	3.41	0.73	1.80	1.41	1.95	1.87
2004	0.19	0.01	0.02	0.04	7.59	2.87	0.53	0.01	0.01	0.15	7.73	4.98
2005	1.08	0.06	0.17	2.70	9.93	3.88	1.11	0.44	4.25	3.30	2.79	0.15
2006	0.00	0.00	0.39	21.15	14.99	3.61	0.80	0.12	0.01	0.01	4.21	15.25
2007	10.52	3.05	1.01	1.44	10.72	10.26	1.94	0.54	0.44	0.94	1.75	0.79
2008	0.05	0.00	0.01	11.54	6.26	4.04	3.48	6.35	6.67	6.30	10.54	1.09
2009	0.04	0.01	0.00	6.91	18.16	5.87	1.01	0.05	0.02	0.07	0.10	7.11
2010	5.63	0.31	0.78	7.23	16.75	2.37	0.71	0.01	0.29	1.91	2.39	2.21

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

1JA, 1JB, 1JC, 1JD, 1JE, 1JF, 1JG1 & 1JG2

Sub-basin: **1JA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	22.81	15.99	11.22	34.92	39.60	51.34	29.06	27.44	31.92	28.49	25.11	12.68
1992	9.37	7.78	8.86	18.97	34.88	31.30	37.54	34.81	41.36	39.14	26.01	18.04
1993	26.07	34.83	17.37	11.15	38.13	42.48	27.21	16.60	14.91	12.15	14.21	16.41
1994	9.52	7.18	18.57	44.39	70.34	38.91	36.10	39.39	28.28	17.93	40.00	25.97
1995	10.38	9.90	29.57	32.17	50.86	38.64	34.84	21.10	28.71	33.60	36.40	20.47
1996	20.80	30.05	31.63	62.68	30.90	27.82	35.13	27.73	37.39	22.64	16.34	26.88
1997	11.69	7.92	7.60	14.06	34.15	15.38	29.82	25.53	14.54	13.27	50.62	44.09
1998	48.43	24.86	13.77	19.53	45.02	29.63	33.31	28.76	25.16	44.47	25.31	11.70
1999	9.61	7.94	13.24	34.30	33.36	17.97	15.85	25.82	23.19	27.15	19.95	19.75
2000	11.15	7.61	7.96	10.10	17.58	16.24	21.26	30.00	19.29	19.31	32.83	34.54
2001	56.77	25.38	13.85	40.67	33.78	29.60	26.04	21.76	20.10	30.96	49.05	20.43
2002	15.09	11.13	19.50	21.49	75.31	18.12	15.48	23.78	17.91	12.08	30.00	29.72
2003	27.27	9.90	8.27	34.97	70.25	32.39	18.42	32.01	29.39	20.10	16.55	19.41
2004	14.59	13.04	18.47	54.83	49.05	18.19	12.94	18.04	19.65	18.90	16.73	16.32
2005	11.67	9.57	15.98	32.45	34.06	31.01	22.86	22.17	29.40	16.45	13.01	9.27
2006	7.58	6.50	11.79	53.85	45.34	19.30	25.98	25.85	18.56	14.24	48.99	71.15
2007	43.60	29.46	22.09	27.43	34.13	36.60	25.71	35.29	45.73	22.65	12.40	9.26
2008	7.92	7.21	8.81	30.08	27.08	21.18	20.18	35.08	32.44	34.65	36.98	14.69
2009	8.93	9.30	8.33	12.56	26.01	17.41	11.53	10.11	15.55	19.17	14.50	30.50
2010	39.87	15.15	43.30	39.28	59.96	23.18	20.49	18.94	25.37	36.10	21.44	23.04

Sub-basin: **1JB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	5.64	3.45	2.01	8.26	10.43	13.63	5.77	6.11	7.02	7.51	5.89	2.39
1992	1.58	1.24	1.50	5.04	8.65	7.06	9.00	7.34	10.06	9.79	5.43	3.10
1993	5.09	6.06	2.79	1.84	10.29	10.39	6.31	3.18	2.73	2.21	3.00	3.59
1994	1.69	1.13	4.68	13.40	19.09	8.05	7.84	8.39	7.08	4.68	11.79	6.19
1995	1.82	1.90	7.70	8.44	12.78	9.84	8.04	3.94	5.77	9.95	10.02	4.85
1996	5.47	9.42	9.16	16.38	7.91	5.89	7.65	4.89	7.89	5.45	4.22	6.81
1997	2.22	1.33	1.22	2.29	7.20	3.14	5.74	4.83	2.56	2.50	13.40	10.29
1998	12.14	4.45	2.40	4.44	10.47	6.30	7.15	4.46	4.49	10.56	5.47	2.10
1999	1.72	1.43	3.84	10.13	9.75	4.55	3.21	4.58	4.83	6.73	3.95	4.14
2000	2.00	1.23	1.32	2.03	5.78	4.48	5.28	6.71	4.07	4.55	7.51	8.80
2001	16.25	5.87	2.70	8.32	7.64	7.46	5.54	3.83	3.54	8.07	11.15	4.25
2002	3.11	2.16	3.74	5.12	17.94	3.83	3.40	5.62	4.01	2.41	7.42	5.45
2003	5.29	1.68	1.34	8.89	15.36	7.06	3.68	5.88	6.74	4.82	3.73	3.97
2004	2.85	2.51	4.02	13.48	11.66	3.66	2.57	3.59	4.53	4.21	3.31	2.86
2005	1.94	1.55	4.00	8.13	7.03	7.73	5.41	3.91	5.02	2.97	2.58	1.48
2006	1.17	0.99	2.53	15.26	11.15	4.63	7.02	5.02	3.35	2.87	11.55	17.11
2007	8.92	6.61	5.08	6.90	8.42	8.59	5.08	6.53	11.31	5.10	2.38	1.58
2008	1.26	1.14	1.84	8.54	6.45	5.05	3.70	6.51	7.16	8.13	7.58	3.03
2009	1.58	2.05	1.53	3.34	6.57	3.59	2.37	2.19	4.96	4.68	3.00	7.38
2010	7.79	2.97	8.98	9.08	14.72	4.98	4.47	3.67	4.52	7.83	4.19	4.57

Sub-basin: **1JC** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	12.85	7.88	6.20	18.04	21.84	23.13	13.05	13.68	14.34	15.24	12.79	6.45
1992	5.05	4.49	4.95	12.39	17.74	15.07	17.61	17.78	19.90	18.85	11.56	7.70
1993	10.58	12.05	7.28	5.72	22.09	19.30	14.04	8.59	8.02	6.69	7.64	8.32
1994	5.23	4.28	7.00	20.65	34.38	15.86	16.91	18.14	12.85	8.82	18.89	11.99
1995	5.27	4.92	13.44	14.78	22.34	18.75	14.87	9.93	14.02	19.28	18.32	9.82
1996	9.47	15.01	14.96	27.06	15.39	12.59	16.49	11.85	16.17	11.46	9.37	13.20
1997	5.83	4.26	4.59	7.81	14.35	7.38	12.73	10.17	6.05	5.68	25.02	19.41
1998	23.43	10.81	6.68	10.68	20.12	13.77	15.78	11.57	11.33	21.65	11.67	5.90
1999	5.04	4.31	7.11	17.36	20.07	10.01	8.25	12.65	10.61	15.45	9.23	8.18
2000	5.21	4.27	4.44	4.63	11.30	10.33	12.29	14.94	9.25	12.09	14.14	15.57
2001	27.85	10.73	6.51	17.70	18.33	17.13	12.15	10.14	9.17	17.05	22.37	10.00
2002	8.19	5.81	9.69	10.63	32.36	8.90	8.64	13.11	8.87	6.85	17.90	14.06
2003	12.06	4.76	4.63	18.46	29.93	14.72	9.35	13.03	14.22	10.25	8.68	9.55
2004	7.04	5.93	6.62	23.22	19.53	7.85	6.81	9.54	10.29	9.68	9.04	7.23
2005	5.56	5.14	10.10	14.74	15.99	15.06	11.61	12.69	12.98	7.49	6.78	4.90
2006	4.51	3.95	6.32	26.39	19.98	10.95	15.58	12.64	9.70	8.29	23.47	31.29
2007	16.91	13.35	9.62	13.81	17.72	17.43	13.70	15.95	23.95	11.74	6.55	4.99
2008	4.72	4.36	6.06	16.55	13.76	12.02	9.95	16.94	16.14	18.24	15.84	7.44
2009	4.99	5.33	4.76	7.30	11.45	7.80	6.22	5.89	12.20	10.72	8.07	16.09
2010	14.90	6.58	16.07	17.62	27.65	11.67	11.81	10.54	12.56	16.92	9.36	9.43

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **IJD** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	8.53	5.88	5.07	10.35	12.21	15.31	9.39	8.92	10.65	11.84	11.01	5.89
1992	5.07	4.47	4.85	8.71	11.28	9.60	11.31	9.55	11.86	14.70	10.57	6.69
1993	8.94	7.34	5.62	4.82	13.43	13.19	10.36	6.51	5.91	5.41	5.94	6.62
1994	5.08	4.25	6.93	14.84	20.57	10.21	12.55	16.76	15.57	9.26	19.61	15.75
1995	5.49	4.98	10.28	10.17	18.36	23.98	18.82	7.75	9.10	14.22	23.02	11.05
1996	9.37	14.11	19.08	46.52	21.19	13.67	13.66	8.52	11.55	9.02	7.57	9.39
1997	5.34	4.36	4.69	6.03	10.18	5.99	7.57	7.23	5.38	5.04	14.02	13.87
1998	14.18	6.73	5.51	7.60	12.22	8.29	8.57	6.55	6.87	12.47	7.62	5.29
1999	4.78	4.26	5.34	10.65	11.36	7.27	6.29	8.31	7.70	10.58	6.40	6.88
2000	5.14	4.34	4.66	5.40	10.23	7.11	8.24	9.29	6.58	7.92	9.60	10.20
2001	16.23	7.66	5.44	10.48	9.85	9.55	7.89	6.93	6.91	10.07	12.53	6.77
2002	6.38	5.12	6.89	7.68	17.76	6.55	6.21	8.05	6.46	5.62	11.57	8.35
2003	8.01	4.58	4.68	11.03	17.07	8.59	6.77	7.92	8.55	7.32	6.46	7.33
2004	5.80	5.19	5.54	14.59	11.86	5.90	5.51	6.45	7.61	6.95	6.37	5.91
2005	5.07	4.60	7.08	9.42	8.80	9.22	7.66	7.22	7.92	5.84	5.59	4.76
2006	4.51	4.03	5.35	15.05	12.18	7.09	9.08	7.11	6.59	5.98	13.49	16.63
2007	11.00	7.85	7.81	9.11	10.53	10.59	8.15	8.83	12.23	7.67	5.47	4.91
2008	4.67	4.29	5.34	10.57	8.24	7.56	6.73	9.28	9.55	10.68	9.37	5.91
2009	4.84	4.71	4.74	5.86	8.32	6.14	5.49	5.53	8.37	7.01	5.82	9.66
2010	9.22	5.33	10.20	11.46	15.89	7.82	7.83	7.20	8.04	9.77	6.41	6.82

Sub-basin: **IJE** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	7.91	5.94	6.30	18.28	12.82	26.28	9.78	5.69	10.38	10.99	8.41	4.24
1992	3.22	1.95	2.58	9.94	13.47	13.78	14.29	8.39	15.22	19.58	11.99	8.27
1993	12.78	17.81	8.00	4.37	13.89	18.22	8.01	3.65	3.87	3.41	6.45	6.13
1994	2.78	1.92	21.49	29.43	27.09	19.63	14.52	10.24	9.31	6.80	23.68	14.15
1995	4.69	4.79	19.89	17.60	24.71	18.62	17.43	6.14	7.31	10.00	15.66	8.06
1996	14.76	25.01	18.17	33.89	15.71	11.11	16.21	9.69	23.11	13.11	7.97	13.43
1997	5.65	2.88	1.80	7.64	27.72	6.96	9.87	12.79	9.98	7.21	25.96	36.05
1998	26.50	10.57	6.30	17.74	27.27	15.52	11.81	7.29	8.68	17.99	16.27	4.89
1999	4.73	3.29	13.39	26.53	11.05	7.51	5.81	9.54	11.16	15.24	8.78	12.36
2000	5.69	2.41	2.91	10.86	14.10	8.16	10.28	10.60	7.99	7.49	21.67	22.22
2001	34.52	14.99	5.58	21.36	14.25	15.48	10.34	5.88	9.76	13.88	22.38	6.97
2002	5.93	4.25	8.18	12.13	38.60	8.04	4.37	6.07	5.10	2.97	10.83	8.85
2003	10.52	4.09	2.67	14.76	31.82	11.81	6.94	11.92	10.97	8.48	5.27	7.27
2004	6.40	6.45	14.35	32.77	30.27	9.67	4.36	6.15	10.72	8.32	6.41	9.41
2005	5.77	3.26	6.47	18.46	11.38	15.52	8.58	3.37	4.84	4.49	3.46	2.15
2006	1.71	1.49	6.84	31.38	25.49	6.64	5.27	3.90	3.21	3.23	19.92	37.84
2007	27.10	13.61	13.63	12.75	16.26	19.81	6.66	6.78	9.83	5.91	3.60	3.39
2008	2.54	2.02	4.41	19.98	10.70	6.30	5.89	11.37	14.77	11.80	15.36	5.57
2009	2.75	4.38	3.11	12.63	22.68	10.52	5.46	6.17	9.95	8.26	4.73	14.69
2010	24.32	8.65	25.61	22.49	36.63	11.51	6.40	4.95	11.99	17.20	9.56	17.17

Sub-basin: **IJF** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	21.94	16.62	12.22	36.73	36.57	68.47	32.85	24.55	39.08	32.96	27.56	13.89
1992	10.77	8.27	9.36	24.89	35.61	35.02	38.51	29.56	46.65	55.21	39.12	22.61
1993	32.51	43.57	20.10	12.90	39.86	66.15	33.87	15.55	13.92	12.15	18.22	18.23
1994	10.33	7.67	29.11	63.41	81.37	59.64	47.06	42.98	37.57	24.99	63.45	44.88
1995	13.90	12.36	42.10	42.88	80.49	69.55	57.49	21.73	25.94	34.31	49.02	26.93
1996	31.30	48.32	55.97	115.52	53.36	36.03	45.40	29.15	53.23	32.13	20.76	30.09
1997	13.40	8.82	8.20	18.30	48.05	18.29	31.28	33.23	18.54	17.74	56.75	70.28
1998	82.23	26.71	15.09	26.31	67.61	40.15	35.18	24.11	23.48	50.62	39.27	13.89
1999	10.99	9.11	16.01	43.23	31.30	19.13	17.00	24.77	27.19	34.63	21.63	27.44
2000	14.27	8.74	10.65	21.54	24.95	19.06	25.20	30.73	21.15	18.26	41.97	45.39
2001	69.71	33.00	15.89	50.09	41.17	42.29	35.02	22.44	26.11	32.27	62.32	22.70
2002	16.46	12.57	20.59	26.86	104.55	23.41	16.14	25.54	18.45	11.80	26.55	25.47
2003	27.74	11.68	9.53	37.40	78.75	30.00	19.13	32.70	29.46	24.30	17.65	22.78
2004	17.71	16.80	27.49	71.82	83.95	24.64	14.06	18.90	23.96	20.90	17.96	21.33
2005	14.64	10.42	17.02	39.43	29.55	35.80	24.04	15.30	25.00	19.75	14.58	10.11
2006	8.40	7.34	18.04	69.17	55.53	19.15	22.95	19.05	15.25	13.34	51.07	77.81
2007	53.70	29.65	32.39	34.57	43.46	51.77	23.40	29.38	39.65	20.94	12.64	10.87
2008	9.14	8.04	13.61	38.71	27.35	19.34	19.04	32.44	34.49	33.13	39.38	16.07
2009	10.06	11.75	9.99	20.92	40.96	22.44	15.04	16.92	23.80	21.44	14.64	31.59
2010	49.55	21.04	53.66	49.01	73.80	26.23	19.14	17.75	28.21	38.58	22.67	32.72

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **IJG1** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	4.35	2.56	0.75	6.26	9.71	13.88	5.40	2.99	5.84	6.03	6.06	1.38
1992	1.24	1.85	2.45	5.96	9.07	6.98	9.04	5.56	10.25	10.50	6.45	2.85
1993	5.63	7.17	1.73	0.33	10.74	19.28	8.77	2.07	1.37	0.52	1.18	1.97
1994	1.37	2.15	5.81	17.16	21.64	13.07	11.65	9.86	9.65	4.36	17.41	12.58
1995	1.32	1.13	7.10	7.03	18.20	19.81	15.38	4.18	3.61	10.18	14.94	6.31
1996	5.93	11.10	14.94	35.62	17.61	10.39	10.43	4.66	11.30	7.72	5.08	8.48
1997	1.32	1.76	2.61	2.68	10.86	2.99	2.89	4.25	2.26	0.83	11.12	21.24
1998	25.11	6.09	1.70	3.18	14.77	7.99	5.81	3.34	3.24	10.50	7.44	1.23
1999	2.61	2.38	2.79	8.43	7.44	4.72	2.64	4.67	5.92	10.08	3.65	4.65
2000	1.27	2.59	2.04	2.87	11.38	3.85	5.04	5.49	4.64	4.27	8.32	12.17
2001	28.20	11.31	2.22	10.98	11.44	12.01	6.02	4.17	4.10	8.52	18.72	4.60
2002	2.54	1.77	2.82	4.36	30.02	6.15	2.16	2.84	2.98	1.18	9.78	4.69
2003	6.59	0.80	1.91	7.38	26.92	9.18	4.72	4.19	6.80	4.19	3.01	4.39
2004	2.01	1.37	1.94	17.25	19.57	4.43	1.43	1.87	4.31	5.41	2.94	3.01
2005	1.57	1.30	1.56	8.02	5.88	6.76	4.99	2.77	4.45	2.29	1.57	1.49
2006	2.70	2.28	1.20	15.29	13.27	4.15	5.20	2.52	2.26	1.53	11.55	17.83
2007	19.06	8.70	6.28	9.06	11.25	15.84	7.31	4.60	8.76	4.62	1.43	0.57
2008	0.73	0.80	0.40	7.94	5.99	3.64	2.25	5.93	7.46	8.39	7.81	2.37
2009	0.62	0.64	0.86	1.51	7.24	4.74	1.91	1.82	4.44	4.12	1.69	4.21
2010	10.06	1.01	8.82	12.70	25.87	8.95	7.01	3.59	8.40	9.74	4.87	3.77

Sub-basin: **IJG2** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	2.59	1.74	1.80	3.40	5.75	7.50	2.25	2.91	3.27	3.08	2.54	1.62
1992	1.83	2.14	2.20	3.39	3.59	4.33	3.53	2.89	6.03	4.60	2.48	1.42
1993	2.58	3.92	1.95	1.47	5.59	5.77	2.23	1.61	1.53	1.40	1.81	1.58
1994	2.09	2.73	4.01	8.41	10.61	5.97	4.39	3.71	3.41	1.66	6.96	4.30
1995	1.77	1.41	4.05	3.30	8.01	5.80	4.29	1.28	2.32	5.86	4.04	2.18
1996	2.27	4.07	4.56	9.97	5.82	3.80	4.60	2.45	4.89	2.23	1.88	3.31
1997	1.71	2.09	3.36	3.24	5.20	1.43	2.33	1.89	1.74	1.73	5.57	13.10
1998	9.50	2.42	1.78	2.92	5.85	3.06	2.68	2.30	2.13	5.50	2.38	1.91
1999	2.18	2.67	3.24	4.58	3.09	1.55	1.50	3.37	2.11	3.28	1.47	2.73
2000	1.64	3.38	2.44	1.46	5.43	1.71	2.00	2.25	1.74	1.76	5.16	7.28
2001	12.65	3.32	1.81	5.11	4.02	3.51	2.01	1.53	2.58	4.03	6.29	1.84
2002	1.64	1.50	1.86	3.68	11.50	1.96	1.63	2.14	1.85	1.61	5.37	2.55
2003	3.04	1.49	2.34	6.67	9.05	3.29	1.35	3.48	2.15	1.65	1.89	2.01
2004	1.56	2.04	2.13	9.98	7.50	1.92	1.62	1.98	1.95	2.29	1.65	1.98
2005	1.50	1.66	2.13	3.89	2.68	3.25	1.84	2.06	2.16	2.06	1.64	2.69
2006	3.58	2.61	2.01	6.30	6.83	1.72	2.92	2.10	1.58	1.75	7.03	11.11
2007	7.28	3.28	2.55	3.43	4.10	5.01	1.61	2.55	4.57	1.67	0.79	0.52
2008	0.42	0.26	0.00	0.50	1.55	0.83	0.22	0.81	2.06	3.73	2.77	1.02
2009	0.47	0.63	0.41	0.02	2.57	1.54	0.74	0.48	0.45	0.87	0.73	0.00
2010	4.13	0.00	2.57	5.74	8.72	1.17	0.89	0.37	2.73	1.13	1.16	0.42

1KA, 1KB & 1KC

Sub-basin: **1KA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	2.24	1.82	3.21	8.60	11.20	13.28	4.19	1.18	2.74	7.19	7.18	3.11
1992	1.83	0.64	0.47	9.41	11.48	8.72	8.54	3.56	5.76	13.09	6.25	7.51
1993	7.60	6.61	2.38	1.48	14.93	13.70	3.79	2.42	2.91	2.77	3.15	2.58
1994	0.61	0.07	6.39	15.17	16.92	10.42	8.37	4.11	4.03	3.66	17.51	10.91
1995	1.83	0.93	8.19	6.96	11.65	10.18	9.03	2.25	2.08	3.72	10.37	5.09
1996	3.31	8.28	7.33	13.30	17.22	7.54	6.25	3.70	15.37	11.10	6.69	7.70
1997	3.01	0.93	0.04	4.59	18.26	4.18	2.34	4.13	3.29	1.25	11.34	29.21
1998	19.11	4.05	2.10	9.21	16.55	12.01	5.39	2.19	4.40	7.57	5.94	1.30
1999	0.63	0.16	3.29	14.26	14.97	7.56	3.43	5.13	4.45	15.14	7.25	7.63
2000	2.15	0.23	0.26	7.16	17.91	5.91	6.78	3.19	4.44	5.67	10.03	11.08
2001	10.48	4.78	1.07	13.26	16.55	17.38	2.79	1.17	4.31	8.93	13.10	3.32
2002	3.45	1.31	5.39	11.92	28.51	7.62	2.11	1.54	1.82	2.23	11.38	5.47
2003	6.80	1.07	0.21	5.43	24.10	10.93	6.48	3.90	6.85	6.22	4.24	4.25
2004	1.57	0.93	3.07	7.14	13.95	7.10	1.63	1.75	8.06	6.30	8.00	9.02
2005	2.95	1.03	2.39	8.46	10.72	8.97	3.67	2.53	6.89	2.56	1.25	0.15
2006	0.00	0.00	4.44	21.65	19.46	6.41	2.23	1.09	1.39	1.54	9.27	16.55
2007	18.19	8.87	3.18	4.73	8.93	15.17	5.39	2.42	4.17	2.84	2.16	1.32
2008	0.42	0.03	1.36	13.27	8.04	4.98	5.53	9.68	9.07	9.34	10.77	2.19
2009	0.52	0.81	0.37	11.48	19.17	11.44	3.14	3.12	4.83	3.55	2.27	11.42
2010	11.59	1.39	6.59	12.51	28.34	9.02	3.61	1.95	14.45	10.27	5.09	9.30

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **1KB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	21.26	17.14	25.31	68.84	72.01	83.17	27.69	12.16	19.61	35.01	36.42	18.41
1992	12.31	5.52	6.68	45.77	65.52	41.32	46.79	22.04	35.16	73.30	38.31	55.00
1993	47.66	44.27	18.13	12.22	96.79	74.29	23.18	12.55	14.39	14.47	18.93	15.22
1994	7.48	4.40	55.11	98.00	114.28	61.72	49.77	26.68	24.67	18.44	85.18	60.46
1995	14.83	12.31	51.28	44.68	78.66	57.25	50.21	16.40	18.85	27.53	62.37	26.99
1996	30.89	66.45	51.66	91.11	97.22	38.52	37.31	22.23	78.66	55.59	30.12	45.80
1997	21.51	8.97	3.39	34.75	131.22	22.22	15.78	24.29	20.46	9.28	70.31	218.99
1998	163.32	36.88	20.31	70.34	116.76	72.23	31.59	15.64	22.30	40.06	37.54	11.73
1999	8.77	5.31	36.10	97.17	83.15	40.77	20.16	28.14	26.25	64.30	41.53	46.88
2000	17.29	5.21	4.78	38.05	89.39	31.20	41.33	25.22	23.94	27.96	54.82	65.68
2001	72.50	34.67	12.62	89.79	92.05	86.78	21.25	13.22	26.69	38.79	62.50	21.54
2002	20.25	11.17	23.37	55.28	188.91	49.10	15.42	13.01	11.51	6.91	40.12	24.31
2003	33.16	9.60	4.54	32.94	142.03	48.86	29.26	23.51	30.68	28.04	16.43	19.75
2004	13.49	10.96	22.71	44.81	106.97	41.24	11.59	12.92	33.02	27.07	29.01	46.87
2005	22.75	10.75	17.16	50.02	58.07	54.01	25.35	11.59	26.92	17.68	14.07	4.71
2006	2.42	2.04	22.80	142.60	119.94	31.42	15.77	9.44	9.88	10.91	63.07	131.93
2007	118.47	55.75	25.77	29.58	66.07	102.96	30.14	17.84	25.78	18.58	14.44	10.48
2008	5.60	2.32	6.24	87.31	48.01	29.65	32.93	62.83	59.78	51.53	89.76	16.15
2009	5.33	7.76	5.00	69.27	141.50	65.60	20.94	16.90	27.05	23.84	14.14	69.68
2010	79.01	13.51	53.94	95.27	183.03	49.31	22.50	11.01	58.52	60.27	32.47	61.42

Sub-basin: **1KC** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	33.24	30.11	39.04	79.41	54.03	81.55	32.52	11.88	7.46	9.51	21.88	13.71
1992	9.01	5.14	5.56	12.29	47.92	29.00	34.89	16.11	14.86	47.35	37.92	41.19
1993	43.45	47.44	24.82	11.92	74.52	47.81	19.55	8.03	6.74	7.37	8.31	8.31
1994	6.31	5.37	43.08	92.13	84.29	56.86	43.54	21.98	16.97	9.08	41.56	55.47
1995	19.76	16.33	49.89	37.66	70.21	32.53	37.46	17.01	13.50	24.34	49.58	24.67
1996	33.09	99.02	56.18	104.10	60.33	36.40	29.58	17.75	65.95	47.94	22.14	36.69
1997	26.01	10.03	4.89	26.02	133.07	21.79	12.46	9.74	11.73	6.62	37.34	203.55
1998	133.25	56.16	31.90	81.53	113.04	65.60	25.96	10.10	8.60	18.89	34.76	13.91
1999	10.43	6.03	61.77	102.87	52.22	30.78	17.28	15.56	16.33	42.30	47.90	45.74
2000	21.16	7.01	5.66	22.14	82.40	33.76	43.11	27.67	17.83	19.37	47.28	72.08
2001	70.04	46.31	20.14	100.76	87.69	71.87	21.97	13.22	10.38	22.92	58.42	26.75
2002	16.74	11.68	12.08	36.62	161.37	46.14	17.72	9.76	5.81	4.54	8.02	15.31
2003	29.03	8.88	5.05	8.44	86.82	33.62	17.52	10.87	13.29	11.10	7.96	6.70
2004	5.54	4.53	6.26	16.55	106.18	38.35	12.18	8.57	10.89	22.20	18.15	33.21
2005	28.55	12.53	14.36	48.78	41.02	46.65	30.53	10.25	10.55	10.73	9.72	5.50
2006	3.89	3.38	10.51	100.48	91.07	27.52	13.86	8.30	7.23	7.11	55.21	137.16
2007	110.17	58.02	29.37	27.98	58.46	89.97	30.56	19.55	22.60	19.16	12.59	11.23
2008	7.57	5.03	5.96	71.65	44.92	27.08	23.56	50.28	59.18	43.46	74.97	19.62
2009	7.31	7.70	5.88	56.80	117.88	57.22	22.89	13.94	23.54	31.33	18.03	68.28
2010	86.31	20.77	72.85	94.36	160.55	46.61	25.95	12.05	42.01	68.06	39.19	62.11

1LA1, 1LA2, 1LA3, 1LB1 & 1LB2

Sub-basin: **1LA1** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	13.09	10.36	7.48	26.29	26.76	50.67	23.41	18.51	24.46	17.80	16.48	7.12
1992	4.64	3.28	3.67	5.76	21.42	26.86	27.71	22.22	25.91	28.62	20.01	15.72
1993	24.52	43.18	15.75	6.28	16.22	25.97	14.72	8.30	7.08	5.68	8.83	11.04
1994	4.75	3.07	18.18	49.91	57.46	41.51	26.14	26.08	17.74	9.89	37.64	24.76
1995	6.75	5.70	31.06	35.58	59.64	30.39	29.56	13.48	17.99	21.00	25.46	13.62
1996	20.53	35.96	35.98	75.75	27.28	25.13	35.86	26.19	42.21	23.08	12.45	25.67
1997	8.68	4.54	3.12	16.32	41.43	12.70	32.44	24.12	16.85	14.45	51.00	69.55
1998	65.10	29.03	12.82	23.26	57.58	32.23	27.22	22.31	18.06	37.98	23.85	8.01
1999	6.58	4.39	10.35	40.78	22.08	9.91	8.25	18.40	18.30	15.45	14.14	20.74
2000	9.08	4.08	3.80	5.63	11.08	8.44	10.89	19.32	12.24	10.17	33.01	37.75
2001	67.68	31.69	12.21	40.62	27.65	20.80	19.89	15.58	15.98	21.53	45.69	14.58
2002	10.35	7.52	15.64	18.64	91.52	16.77	9.89	16.42	10.68	5.70	19.40	24.11
2003	21.27	6.61	4.20	30.94	72.03	27.46	11.24	28.43	23.38	12.78	9.84	13.29
2004	9.42	10.69	25.37	67.29	64.70	19.99	8.60	12.48	14.44	12.29	9.24	12.85
2005	7.77	5.52	9.15	30.97	32.42	23.71	15.33	11.44	19.78	10.15	7.68	5.08
2006	3.21	2.59	5.90	52.17	46.82	12.10	11.15	13.17	9.91	7.45	37.70	75.15
2007	57.30	27.80	26.00	28.51	32.92	40.72	17.18	26.36	32.92	13.68	6.85	4.97
2008	3.72	3.24	3.60	26.44	22.03	13.16	11.49	21.07	23.00	26.11	34.10	9.64
2009	4.32	4.74	3.89	7.30	31.28	15.04	6.52	4.68	6.11	9.39	7.92	24.30
2010	48.13	14.37	53.54	42.30	65.24	21.25	12.50	9.91	18.58	35.79	20.04	28.93

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **1LA2** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	21.27	19.33	21.15	22.81	22.16	34.68	18.94	7.82	9.79	7.42	7.80	6.55
1992	6.53	5.38	6.37	6.13	11.80	11.30	13.10	9.72	11.41	13.92	14.10	13.12
1993	17.32	32.59	15.99	7.56	11.85	12.28	8.61	6.48	5.92	5.75	5.59	5.90
1994	6.02	4.73	9.68	31.02	33.11	32.98	18.63	11.35	9.23	6.57	14.26	21.26
1995	10.29	8.72	25.25	18.32	27.44	14.80	13.96	8.14	7.21	10.21	9.85	7.20
1996	15.77	31.68	23.76	50.07	21.95	15.71	18.43	11.96	25.34	15.99	7.84	15.76
1997	7.80	6.40	5.65	7.41	51.47	11.63	12.54	10.96	9.06	7.83	15.34	64.61
1998	44.79	27.66	14.06	21.84	44.41	26.19	12.00	10.60	7.91	11.82	11.87	8.31
1999	6.63	6.13	20.72	42.32	13.98	8.26	6.42	7.73	10.06	15.13	16.74	19.92
2000	11.75	6.10	6.44	14.12	27.83	15.62	17.66	13.41	11.85	10.01	22.68	38.77
2001	55.78	30.43	12.17	37.10	34.35	31.75	14.51	9.72	10.13	17.84	30.89	14.40
2002	10.14	8.12	10.30	13.68	66.53	19.85	9.04	6.99	7.74	6.62	12.77	12.51
2003	16.90	6.99	6.18	11.43	30.87	17.36	8.04	9.88	10.76	6.95	6.16	6.45
2004	5.53	5.49	13.63	32.51	44.41	21.12	7.65	6.90	12.44	13.27	8.99	13.21
2005	11.03	7.19	8.75	26.14	19.29	20.90	14.09	6.53	7.48	7.23	6.08	6.09
2006	5.23	4.65	5.42	35.97	44.50	14.67	7.87	6.22	5.70	6.58	14.51	60.03
2007	59.04	27.59	20.04	18.91	22.26	33.31	13.68	10.58	13.77	9.18	5.81	6.40
2008	6.28	5.61	5.70	20.36	22.97	12.75	8.87	16.54	21.74	17.81	25.83	10.92
2009	6.44	5.88	6.44	14.10	37.70	24.62	10.39	7.28	9.92	10.38	6.51	10.21
2010	45.95	11.40	34.27	39.03	62.61	21.11	10.89	6.13	14.46	27.67	20.55	24.56

Sub-basin: **1LA3** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	10.61	10.46	11.24	40.84	73.42	61.63	23.32	7.30	6.24	6.16	5.51	5.35
1992	5.62	5.00	4.91	8.04	24.50	11.78	11.28	8.27	7.39	9.07	12.42	12.21
1993	57.67	93.47	33.04	11.99	19.82	19.35	9.80	6.12	6.08	5.39	5.65	6.16
1994	5.11	5.31	11.80	42.43	54.01	35.00	21.00	11.41	6.99	6.53	7.76	13.01
1995	8.76	8.81	48.39	20.89	44.61	15.45	9.61	6.23	6.61	8.01	8.70	7.42
1996	11.04	68.06	50.12	115.84	31.02	28.47	36.80	19.09	37.97	23.30	9.93	17.38
1997	11.65	6.89	5.55	52.41	146.14	20.48	14.53	11.47	7.27	6.42	46.08	170.85
1998	124.72	88.37	36.44	52.64	98.44	48.89	15.67	9.27	7.97	7.75	7.58	7.72
1999	6.68	6.11	59.68	109.61	29.25	9.69	5.21	5.97	5.48	3.68	4.17	7.44
2000	8.47	5.10	5.91	4.34	6.48	5.06	4.71	4.19	3.76	3.57	6.44	22.68
2001	134.56	54.14	18.23	46.63	40.00	27.46	14.15	10.67	6.67	7.65	17.06	12.65
2002	16.94	15.85	23.58	16.70	175.45	23.09	7.46	4.61	5.74	7.11	8.79	31.60
2003	48.90	12.78	8.56	10.48	93.12	29.82	10.51	8.57	7.22	6.31	6.09	6.75
2004	6.15	6.47	7.03	31.26	76.86	19.93	6.45	4.09	3.75	3.75	3.13	3.57
2005	3.71	3.50	3.62	11.33	28.97	27.56	11.20	5.88	5.64	4.48	5.45	5.69
2006	5.45	4.49	6.25	83.81	61.43	14.19	5.83	4.96	5.38	5.35	10.51	97.90
2007	92.00	55.58	27.53	18.30	21.00	23.69	9.87	6.17	5.90	3.92	3.01	3.01
2008	2.97	2.80	3.26	34.99	27.07	8.41	4.64	4.37	4.86	4.40	6.09	4.79
2009	3.01	2.65	2.96	2.91	8.56	16.34	6.86	3.97	3.28	3.34	2.89	2.15
2010	36.67	17.18	43.81	48.57	64.29	19.14	6.71	3.51	3.52	5.68	14.97	33.96

Sub-basin: **1LB1** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	18.10	13.99	12.12	33.02	34.04	65.12	30.23	18.71	24.95	18.29	17.19	8.68
1992	6.34	4.77	5.22	6.16	20.40	29.16	31.59	25.30	27.03	30.57	25.31	20.51
1993	38.11	62.36	25.06	9.35	15.55	28.96	16.93	9.57	7.22	5.73	6.54	9.41
1994	5.78	4.36	28.18	67.13	66.89	55.28	32.10	28.31	20.81	11.21	43.37	34.19
1995	10.99	9.14	43.72	44.43	96.50	41.93	40.92	18.17	21.31	21.49	25.95	16.03
1996	27.21	52.00	52.72	145.45	39.03	34.72	52.51	35.35	59.31	29.04	14.20	29.37
1997	12.02	6.28	4.53	22.06	67.74	16.42	34.11	32.00	20.01	14.60	66.84	125.24
1998	130.33	66.32	22.68	30.84	91.12	52.30	27.53	21.85	17.99	33.48	27.51	9.96
1999	7.95	5.70	20.42	56.98	22.49	10.82	8.20	13.15	19.34	15.38	14.70	28.43
2000	13.60	5.75	5.44	8.25	12.98	8.61	8.71	12.37	12.92	9.20	36.08	49.42
2001	85.64	38.44	14.29	46.88	28.96	17.32	19.32	19.63	16.44	22.19	47.73	16.94
2002	13.53	10.62	20.09	23.38	110.26	18.89	10.14	13.47	10.59	6.37	19.29	30.31
2003	34.57	10.60	6.52	32.71	103.52	38.18	14.83	30.48	29.77	15.24	10.71	12.69
2004	9.74	11.10	33.29	102.63	125.64	29.85	10.94	12.12	15.19	13.06	9.45	13.45
2005	10.16	6.45	9.59	36.30	36.93	29.67	18.15	13.92	19.27	10.89	8.01	5.99
2006	4.46	3.73	7.61	70.31	60.76	15.16	10.01	11.47	10.49	7.53	39.62	100.18
2007	72.22	39.85	35.59	33.93	40.81	57.44	21.55	28.00	35.36	16.51	8.53	6.56
2008	5.03	4.54	5.26	33.73	25.95	14.06	11.33	18.87	24.90	28.54	44.21	13.85
2009	6.00	6.10	5.24	8.87	36.73	20.20	8.56	5.54	5.61	7.01	6.20	20.37
2010	70.80	22.19	70.28	52.35	74.11	23.76	12.57	11.65	17.79	45.81	28.60	37.54

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **1LB2** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	9.40	8.64	9.22	29.76	33.25	45.86	12.17	0.66	0.00	0.00	0.00	0.00
1992	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.00	0.01	2.58	4.65
1993	31.78	51.15	16.71	3.14	7.68	7.75	1.64	0.00	0.00	0.00	0.00	0.00
1994	0.00	0.00	0.01	18.98	34.34	28.49	12.62	3.70	0.98	0.00	0.00	5.17
1995	3.56	3.45	37.37	11.09	35.70	7.32	3.68	0.69	0.63	1.13	0.76	0.15
1996	2.96	56.56	35.02	78.90	16.44	15.00	25.95	8.77	24.96	13.11	1.96	6.17
1997	3.65	0.34	0.00	14.97	90.09	7.68	4.50	3.18	0.44	0.00	13.66	97.75
1998	88.39	129.46	52.20	83.80	195.61	103.06	16.84	3.12	0.38	2.22	5.83	0.77
1999	0.00	0.00	41.03	82.16	20.70	3.46	0.17	0.00	0.00	0.00	0.00	0.00
2000	0.01	0.00	0.00	0.00	0.01	0.01	0.00	0.00	0.00	0.00	0.01	5.32
2001	91.14	35.53	6.82	28.37	20.46	17.72	9.20	5.51	3.90	11.75	31.87	8.29
2002	9.64	7.54	11.86	8.70	121.55	22.09	3.03	0.00	0.00	0.00	0.01	4.42
2003	25.38	3.18	0.09	0.00	57.65	14.49	2.17	0.00	0.00	0.00	0.00	0.00
2004	0.00	0.00	0.00	12.00	59.95	11.42	0.59	0.00	0.00	0.00	0.00	0.00
2005	0.00	0.00	0.00	0.02	5.83	16.08	4.62	0.02	0.00	0.00	0.00	0.00
2006	0.00	0.00	0.00	45.04	43.58	5.58	0.19	0.00	0.00	0.00	0.06	71.86
2007	63.17	35.60	16.28	10.08	13.35	20.56	3.57	0.07	0.00	0.00	0.00	0.00
2008	0.00	0.00	0.00	1.49	13.97	1.55	0.00	0.00	0.00	0.00	0.01	0.01
2009	0.00	0.00	0.00	0.00	0.03	5.03	1.08	0.00	0.00	0.00	0.00	0.00
2010	14.24	10.55	40.48	31.96	50.75	9.07	0.74	0.00	0.00	0.01	17.37	30.25

3. Rift Valley Catchment Area (RVCA)

2BA, 2BB & 2BC

Sub-basin: **2BA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	1.01	0.07	0.00	0.00	0.00	9.79	51.21	81.58	29.99	21.25	11.58	3.62
1992	1.54	0.21	0.00	0.00	1.45	17.39	47.74	74.89	41.46	33.57	18.07	4.71
1993	2.42	2.26	1.36	0.26	67.53	54.10	25.11	17.01	18.17	6.48	2.90	1.47
1994	0.23	0.00	0.00	0.00	45.34	67.94	54.47	82.07	21.76	6.40	11.02	5.83
1995	1.90	0.42	0.01	0.00	0.00	0.00	30.95	30.87	29.97	26.05	26.99	5.81
1996	2.48	0.79	0.04	0.00	0.00	16.89	22.26	27.10	55.40	11.94	11.28	9.57
1997	2.34	0.68	0.02	33.18	40.28	5.61	40.49	38.60	7.25	4.01	37.84	26.23
1998	70.95	25.55	7.46	2.98	36.08	17.57	74.19	38.30	17.85	42.25	30.08	5.70
1999	2.66	0.82	0.04	0.00	11.66	15.69	26.79	12.83	8.99	63.80	36.24	9.21
2000	3.22	1.19	0.16	0.00	15.21	5.82	29.20	47.47	38.06	62.95	27.52	8.63
2001	3.53	1.69	0.56	2.24	43.41	59.36	42.02	60.26	30.95	23.51	71.15	11.58
2002	4.02	1.65	0.35	0.00	7.16	0.88	0.62	0.11	0.02	0.72	2.13	4.69
2003	7.54	0.73	0.06	2.94	118.37	68.66	84.17	66.64	45.05	8.30	3.74	1.66
2004	0.29	0.00	0.00	0.04	49.67	9.27	9.21	58.37	14.11	7.06	28.04	9.02
2005	3.80	1.62	0.43	0.00	32.76	39.07	25.68	15.95	39.28	13.75	4.68	2.30
2006	0.64	0.01	0.00	0.00	0.19	0.41	0.76	31.30	25.81	9.02	55.01	45.39
2007	12.79	4.09	1.88	0.52	20.79	79.07	56.76	120.36	114.32	32.32	9.03	3.89
2008	1.14	0.09	0.00	0.00	0.00	12.18	24.80	63.26	25.96	27.32	54.24	8.14
2009	3.40	1.28	0.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2010	0.00	0.00	0.92	27.84	73.80	38.50	39.56	27.82	37.90	27.63	16.50	4.96

Sub-basin: **2BB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	1.62	0.11	0.00	0.00	0.00	15.73	82.34	131.17	48.22	34.17	18.63	5.81
1992	2.47	0.34	0.00	0.00	2.33	27.97	76.77	120.41	66.67	53.98	29.05	7.57
1993	3.89	3.63	2.19	0.42	108.58	86.99	40.38	27.34	29.22	10.42	4.66	2.36
1994	0.37	0.00	0.00	0.00	72.91	109.25	87.59	131.95	34.99	10.29	17.71	9.37
1995	3.06	0.67	0.01	0.00	0.00	0.00	49.76	49.63	48.18	41.88	43.40	9.35
1996	3.99	1.27	0.07	0.00	0.00	27.15	35.79	43.57	89.07	19.20	18.14	15.39
1997	3.77	1.09	0.03	53.35	64.76	9.03	65.10	62.06	11.65	6.44	60.84	42.17
1998	114.08	41.08	12.00	4.79	58.01	28.25	119.29	61.58	28.70	67.94	48.36	9.16
1999	4.28	1.32	0.07	0.00	18.75	25.23	43.07	20.62	14.46	102.58	58.26	14.81
2000	5.18	1.91	0.26	0.00	24.46	9.36	46.95	76.33	61.20	101.21	44.25	13.87
2001	5.68	2.72	0.90	3.61	69.80	95.44	67.56	96.90	49.77	37.80	114.41	18.63
2002	6.46	2.66	0.56	0.00	11.52	1.42	1.00	0.18	0.03	1.16	3.43	7.54
2003	12.12	1.18	0.09	4.73	190.32	110.40	135.34	107.15	72.43	13.34	6.02	2.67
2004	0.46	0.00	0.00	0.07	79.87	14.91	14.80	93.86	22.69	11.36	45.08	14.50
2005	6.12	2.61	0.69	0.00	52.67	62.82	41.29	25.65	63.15	22.10	7.52	3.71
2006	1.03	0.02	0.00	0.00	0.30	0.66	1.22	50.33	41.50	14.51	88.45	72.98
2007	20.57	6.57	3.02	0.84	33.42	127.14	91.27	193.52	183.82	51.97	14.51	6.26
2008	1.84	0.14	0.00	0.00	0.00	19.59	39.88	101.71	41.74	43.93	87.21	13.08
2009	5.47	2.05	0.33	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2010	0.00	0.00	1.48	44.76	118.66	61.90	63.61	44.72	60.94	44.42	26.53	7.97

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **2BC** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.82	0.00	0.00	0.00	0.00	31.99	61.65	82.38	42.73	47.99	21.84	6.29
1992	0.71	0.00	0.00	0.00	0.00	13.17	42.00	60.08	40.92	49.00	20.41	5.07
1993	1.28	3.98	4.69	0.23	55.37	53.71	25.42	17.81	23.16	12.16	5.85	1.43
1994	0.00	0.00	0.00	0.00	48.95	74.02	61.21	121.94	39.06	10.76	23.89	11.48
1995	1.13	0.00	0.00	0.00	0.00	6.71	54.48	40.76	34.80	30.60	28.32	7.38
1996	1.01	0.00	0.00	0.00	11.36	27.26	14.77	27.55	65.97	26.23	16.48	10.79
1997	2.22	0.07	0.00	20.29	76.02	16.14	37.28	44.87	11.27	2.95	41.42	29.63
1998	92.24	38.16	16.22	7.50	54.87	29.97	69.74	48.75	32.19	68.60	66.79	14.78
1999	3.64	0.43	0.00	0.00	16.47	29.97	42.27	26.94	17.61	74.07	47.82	14.51
2000	3.81	0.45	0.00	0.00	1.13	11.39	24.42	46.82	45.45	76.48	31.90	12.74
2001	3.60	1.13	0.03	0.00	38.20	76.33	67.35	80.94	43.42	44.03	102.39	20.89
2002	5.15	0.85	0.00	0.00	17.32	7.78	5.48	5.67	5.80	5.02	4.26	1.38
2003	9.96	1.31	0.00	0.00	143.56	84.19	123.74	78.85	61.27	14.63	4.62	1.18
2004	0.02	0.00	0.00	0.00	31.84	11.62	8.12	30.70	13.59	8.38	23.23	10.97
2005	3.98	0.34	0.00	0.00	25.51	40.81	34.80	19.26	44.81	24.13	12.93	3.08
2006	0.11	0.00	0.00	0.00	2.33	10.50	10.51	38.04	38.05	18.40	78.18	80.67
2007	21.83	5.84	2.19	1.48	31.18	77.11	78.84	205.94	218.06	56.99	12.76	3.03
2008	0.27	0.00	0.00	0.00	0.00	11.63	25.08	72.75	32.65	30.40	58.82	15.91
2009	3.86	0.61	0.00	0.00	0.00	2.39	2.68	4.16	9.37	14.60	6.32	1.84
2010	13.66	2.00	4.18	32.70	95.55	49.88	57.48	52.48	60.29	47.62	25.41	7.66

2CB

Sub-basin: **2CB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	9.10	4.99	1.91	13.74	10.35	80.11	122.19	135.61	83.11	12.96	9.42	5.50
1992	1.58	0.09	0.05	0.08	31.63	11.01	60.99	105.75	48.70	53.98	61.50	12.44
1993	14.49	71.00	13.47	4.09	74.96	117.42	55.71	33.67	13.67	5.36	1.58	0.20
1994	0.07	0.03	0.01	49.01	232.51	138.44	136.52	191.27	45.84	12.63	18.72	19.62
1995	4.92	1.62	0.16	1.63	27.35	8.57	45.20	37.36	90.95	16.38	25.71	10.09
1996	4.83	2.07	0.74	9.32	4.15	86.79	181.35	171.47	106.74	19.14	8.97	5.23
1997	1.65	0.07	0.04	99.30	92.06	7.88	155.94	138.94	13.97	10.12	177.70	199.06
1998	223.32	92.62	18.27	9.36	92.08	30.47	99.75	100.63	22.43	51.60	48.82	8.27
1999	3.80	0.70	0.09	1.68	32.86	3.91	12.83	20.56	20.42	54.78	24.59	32.38
2000	4.59	1.12	0.09	0.04	0.02	0.00	0.00	9.15	9.36	9.76	9.88	5.82
2001	1.51	3.89	0.16	21.05	35.68	69.94	90.49	134.41	71.66	14.27	133.75	22.02
2002	7.01	3.24	0.71	0.16	95.66	7.40	4.02	1.48	0.42	0.09	0.04	79.31
2003	85.39	4.77	1.85	1.38	237.78	41.07	32.58	190.22	61.03	10.85	5.02	1.89
2004	0.09	0.04	0.01	42.90	201.16	16.99	11.94	86.79	17.34	30.89	40.34	15.40
2005	6.13	2.19	0.41	0.12	127.63	90.39	37.48	67.98	182.41	20.54	8.59	4.18
2006	1.05	0.05	0.03	20.23	35.96	13.10	81.72	163.23	53.23	14.99	195.71	244.79
2007	82.07	41.11	13.62	86.62	72.39	298.47	228.65	267.14	273.53	60.19	23.72	10.68
2008	4.94	1.32	0.07	0.04	0.02	0.01	6.78	151.94	147.69	176.13	237.97	23.60
2009	11.59	5.10	2.09	0.06	0.04	0.01	0.01	0.01	0.00	0.01	0.01	0.06
2010	44.05	2.09	158.78	163.35	297.47	88.05	88.00	116.25	130.25	68.51	28.80	8.36

2EA, 2EB, 2EC, 2ED, 2EE, 2EF, 2EG1, 2EG2, 2EH & 2EK

Sub-basin: **2EA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.11	0.02	0.00	0.13	0.19	0.58	2.89	7.51	6.57	1.65	0.68	0.24
1992	0.05	0.00	0.00	0.00	0.03	0.21	1.98	7.42	8.52	5.05	2.27	1.61
1993	2.59	6.82	1.82	0.29	0.58	1.97	2.85	2.42	1.25	0.43	0.11	0.09
1994	0.01	0.00	0.00	0.00	2.23	3.91	7.86	9.29	3.01	0.64	0.58	0.70
1995	0.09	0.00	0.11	0.10	0.51	0.46	1.39	1.28	2.78	2.18	6.35	1.70
1996	0.45	0.04	0.00	0.00	0.00	0.26	6.83	10.58	8.98	1.91	0.65	0.55
1997	0.05	0.00	0.00	3.26	11.97	2.01	9.17	9.09	1.55	0.72	8.01	11.19
1998	15.11	8.45	2.20	0.74	10.45	5.74	7.26	8.00	5.32	7.17	2.97	0.96
1999	0.13	0.00	0.00	0.00	0.04	0.03	0.35	2.01	2.04	0.71	0.46	0.38
2000	0.07	0.00	0.00	0.00	0.00	0.00	0.00	0.03	1.05	0.62	0.68	0.75
2001	0.36	0.26	0.09	2.82	5.75	4.46	5.68	13.14	9.03	1.63	4.25	2.04
2002	0.60	0.16	0.21	0.16	8.28	1.79	1.03	1.17	0.73	0.21	0.40	1.80
2003	4.46	0.55	0.05	0.06	13.09	5.25	3.93	17.18	7.11	1.49	0.61	2.53
2004	0.75	0.30	0.05	0.60	4.49	1.29	0.77	2.82	1.52	0.63	0.80	0.73
2005	0.19	0.02	0.00	0.00	0.24	3.46	5.53	10.09	13.92	3.01	1.00	0.26
2006	0.01	0.00	0.00	0.00	0.27	0.26	1.36	2.54	2.06	0.73	2.93	9.93
2007	7.77	3.19	0.94	0.75	2.03	11.52	17.15	20.15	26.76	5.19	2.70	0.85
2008	0.07	0.00	0.00	0.00	0.00	0.00	0.00	4.92	6.79	8.15	10.26	1.78
2009	0.23	0.01	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.05
2010	4.83	3.21	11.58	16.47	18.82	6.21	2.67	9.24	13.41	5.91	2.62	0.62

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **2EB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.15	0.01	0.00	0.01	0.05	0.90	4.77	12.44	10.89	2.74	1.12	0.40
1992	0.05	0.00	0.00	0.00	0.00	0.02	2.88	12.28	14.12	8.37	3.76	2.67
1993	4.30	11.29	3.02	0.48	0.95	3.26	4.72	4.02	2.07	0.71	0.13	0.05
1994	0.00	0.00	0.00	0.00	3.69	6.48	13.02	15.40	4.98	1.07	0.97	1.16
1995	0.13	0.00	0.01	0.02	0.67	0.69	2.27	2.13	4.60	3.60	10.51	2.81
1996	0.75	0.05	0.00	0.00	0.00	0.06	11.25	17.52	14.88	3.17	1.08	0.91
1997	0.07	0.00	0.00	5.40	19.83	3.33	15.20	15.06	2.57	1.20	13.27	18.54
1998	25.02	13.99	3.64	1.23	17.30	9.51	12.02	13.25	8.81	11.87	4.92	1.59
1999	0.19	0.00	0.00	0.00	0.00	0.00	0.07	3.11	3.38	1.17	0.74	0.59
2000	0.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.08	1.03	1.11	1.25
2001	0.57	0.40	0.03	4.58	9.52	7.39	9.41	21.77	14.96	2.71	7.05	3.38
2002	1.00	0.26	0.32	0.27	13.69	2.96	1.71	1.94	1.20	0.31	0.63	2.87
2003	7.38	0.91	0.05	0.01	21.68	8.70	6.51	28.46	11.78	2.46	1.02	4.19
2004	1.24	0.50	0.05	0.93	7.43	2.13	1.28	4.68	2.53	1.03	1.33	1.21
2005	0.29	0.00	0.00	0.00	0.05	5.70	9.16	16.71	23.06	4.99	1.65	0.42
2006	0.01	0.00	0.00	0.00	0.03	0.12	2.20	4.18	3.41	1.21	4.85	16.45
2007	12.88	5.28	1.55	1.25	3.37	19.09	28.42	33.37	44.32	8.60	4.48	1.40
2008	0.11	0.00	0.00	0.00	0.00	0.00	0.00	8.09	11.25	13.51	17.00	2.96
2009	0.37	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2010	7.79	5.32	19.18	27.29	31.18	10.28	4.42	15.31	22.22	9.78	4.34	1.03

Sub-basin: **2EC** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.02	0.00	0.00	0.00	0.02	0.03	3.09	6.35	7.61	3.02	1.41	0.21
1992	0.00	0.00	0.00	0.00	0.01	0.04	3.57	10.42	11.42	7.29	6.02	4.97
1993	4.45	12.14	5.83	0.71	1.73	4.59	4.89	3.11	1.28	0.14	0.01	0.00
1994	0.00	0.00	0.00	0.00	0.07	3.21	7.96	15.44	8.25	1.47	1.44	1.20
1995	0.03	0.00	0.00	0.02	3.34	2.93	5.16	4.17	10.48	7.53	10.66	3.45
1996	0.79	0.01	0.00	0.00	0.01	0.24	4.29	7.72	12.37	5.32	1.57	1.90
1997	0.07	0.00	0.00	0.05	9.32	3.12	9.37	13.51	4.04	1.44	10.23	22.32
1998	17.24	11.74	4.21	1.66	9.56	9.61	8.09	8.66	8.33	11.41	6.73	1.92
1999	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.04	0.03	0.05	0.49	1.31
2000	0.14	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.03	0.36	1.78
2001	0.76	0.90	0.16	5.79	7.91	3.29	5.42	18.86	14.02	5.55	11.95	6.27
2002	1.31	0.22	0.32	0.25	15.41	4.52	2.35	2.77	1.42	0.13	0.35	2.76
2003	8.96	1.07	0.01	0.01	22.11	16.30	6.29	12.57	14.91	4.54	2.14	1.48
2004	0.46	0.19	0.00	1.29	5.68	2.77	0.85	1.48	0.95	0.47	0.60	0.54
2005	0.12	0.01	0.00	0.00	0.03	0.07	0.76	4.62	13.31	6.19	2.57	0.75
2006	0.00	0.00	0.00	0.00	0.03	0.03	0.04	0.43	1.83	0.64	3.27	13.35
2007	20.28	8.88	2.50	2.47	6.79	11.66	17.13	27.21	29.57	11.60	4.10	0.66
2008	0.00	0.00	0.00	0.00	0.00	0.01	0.02	3.56	6.63	8.54	19.71	4.80
2009	0.35	0.00	0.00	0.00	0.00	0.01	0.01	0.00	0.00	0.00	0.00	0.00
2010	1.87	2.10	12.19	27.47	27.04	13.52	6.23	12.67	26.11	19.11	11.09	2.59

Sub-basin: **2ED** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.13	0.01	0.00	0.01	0.03	0.21	7.93	17.61	24.69	6.93	4.83	1.49
1992	0.04	0.00	0.00	0.01	0.29	0.36	7.76	23.25	21.14	12.87	12.70	6.71
1993	6.17	19.39	11.02	1.14	7.09	16.81	15.33	12.58	6.29	2.37	0.48	0.01
1994	0.00	0.00	0.00	0.03	8.51	18.28	27.38	37.40	17.76	2.44	2.73	3.34
1995	0.12	0.00	0.01	0.02	6.36	5.48	13.10	10.73	18.11	10.63	12.41	3.67
1996	0.86	0.02	0.01	0.01	0.00	0.86	10.80	24.07	29.90	10.47	2.32	3.94
1997	0.27	0.01	0.00	3.36	17.02	3.89	17.32	19.96	5.57	1.21	12.46	28.99
1998	25.25	19.93	6.94	2.77	15.82	10.33	27.70	32.69	22.57	21.35	13.40	2.71
1999	0.05	0.01	0.01	0.00	0.00	0.00	0.01	1.07	7.42	6.61	7.09	3.69
2000	0.26	0.00	0.00	0.00	0.00	0.00	0.00	0.12	0.67	0.44	3.95	6.66
2001	3.00	2.88	0.33	9.24	14.03	10.00	16.71	31.07	24.27	7.55	22.24	12.42
2002	2.37	0.48	0.79	0.49	17.36	6.74	3.32	5.29	3.41	0.34	0.27	2.42
2003	12.70	1.47	0.02	0.04	33.96	19.56	7.66	23.48	25.85	5.02	1.33	0.80
2004	0.02	0.00	0.00	0.56	7.92	2.61	1.24	6.76	5.14	4.64	3.95	4.15
2005	1.73	0.11	0.01	0.02	5.09	14.57	10.07	20.17	38.47	13.92	4.01	0.89
2006	0.01	0.00	0.00	0.00	0.00	0.00	0.01	5.90	11.63	3.15	5.72	27.16
2007	34.86	12.56	3.48	5.23	13.09	27.80	31.50	45.29	42.90	18.88	6.06	0.84
2008	0.02	0.01	0.01	0.01	0.00	0.00	0.06	28.43	35.12	20.95	26.59	7.04
2009	0.45	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01
2010	5.62	2.41	15.90	34.72	44.13	22.86	15.79	26.96	41.50	26.40	14.35	3.89

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **2EE** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.23	0.02	0.00	0.00	0.42	9.02	23.36	24.30	23.77	4.05	3.68	0.69
1992	0.00	0.00	0.00	0.00	2.18	4.23	21.72	27.87	17.66	12.79	10.53	3.21
1993	4.89	16.40	4.56	0.00	10.72	21.91	15.98	11.33	6.26	1.97	0.00	0.00
1994	0.00	0.00	0.00	1.03	45.07	32.54	35.41	45.45	12.23	1.91	1.98	4.04
1995	0.03	0.00	0.01	0.53	10.85	4.96	13.27	8.09	16.93	5.48	7.11	1.77
1996	0.11	0.00	0.00	0.00	0.00	5.42	24.42	40.54	27.51	5.78	1.16	2.68
1997	0.03	0.00	0.00	23.81	31.57	2.64	33.56	33.22	4.27	0.62	26.13	39.35
1998	39.98	19.44	4.55	1.35	16.66	6.94	36.09	36.56	11.98	16.09	9.89	1.52
1999	0.00	0.00	0.00	0.00	0.10	0.13	3.65	11.94	8.13	7.07	7.11	3.31
2000	0.11	0.00	0.00	0.00	0.00	0.00	0.00	6.29	5.37	5.38	5.99	5.40
2001	1.60	2.81	0.00	10.04	11.43	13.05	19.81	27.16	21.93	4.30	27.34	7.33
2002	0.95	0.01	0.00	0.00	20.83	3.24	1.31	5.80	3.80	0.04	0.00	13.11
2003	14.99	0.58	0.00	0.42	55.87	11.09	5.24	48.19	19.81	2.80	0.24	4.85
2004	0.41	0.02	0.00	8.60	22.16	3.14	2.62	16.77	4.47	7.88	5.84	8.08
2005	2.31	0.00	0.00	0.13	21.64	21.66	9.77	34.55	57.77	8.38	2.12	0.12
2006	0.00	0.00	0.00	1.24	4.53	2.49	11.11	24.75	14.08	1.94	10.37	45.35
2007	24.61	9.55	2.58	9.94	14.83	65.39	52.97	68.94	72.99	16.92	11.14	2.01
2008	0.22	0.00	0.00	0.00	0.00	0.00	6.61	59.36	36.20	24.10	36.41	4.87
2009	0.52	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2010	22.58	3.31	35.46	40.69	80.59	22.15	22.76	32.21	40.50	17.96	9.45	2.45

Sub-basin: **2EF** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.09	0.00	0.00	0.01	0.02	0.14	5.17	11.50	16.11	4.52	3.16	0.97
1992	0.03	0.00	0.00	0.00	0.19	0.23	5.06	15.18	13.80	8.40	8.29	4.38
1993	4.03	12.65	7.19	0.74	4.63	10.97	10.00	8.21	4.10	1.54	0.31	0.01
1994	0.00	0.00	0.00	0.02	5.55	11.93	17.87	24.40	11.59	1.59	1.78	2.18
1995	0.08	0.00	0.01	0.01	4.15	3.57	8.55	7.00	11.82	6.94	8.10	2.39
1996	0.56	0.01	0.00	0.01	0.00	0.56	7.05	15.71	19.52	6.83	1.51	2.57
1997	0.17	0.00	0.00	2.20	11.11	2.54	11.31	13.03	3.64	0.79	8.13	18.92
1998	16.48	13.01	4.53	1.81	10.33	6.74	18.08	21.34	14.73	13.93	8.75	1.77
1999	0.03	0.00	0.00	0.00	0.00	0.00	0.00	0.70	4.84	4.31	4.63	2.41
2000	0.17	0.00	0.00	0.00	0.00	0.00	0.00	0.08	0.44	0.29	2.58	4.35
2001	1.96	1.88	0.21	6.03	9.15	6.53	10.91	20.27	15.84	4.92	14.52	8.11
2002	1.55	0.31	0.51	0.32	11.33	4.40	2.17	3.45	2.22	0.22	0.18	1.58
2003	8.29	0.96	0.01	0.02	22.16	12.77	5.00	15.33	16.87	3.28	0.87	0.52
2004	0.01	0.00	0.00	0.36	5.17	1.70	0.81	4.41	3.35	3.03	2.58	2.71
2005	1.13	0.07	0.01	0.01	3.32	9.51	6.57	13.17	25.11	9.08	2.62	0.58
2006	0.00	0.00	0.00	0.00	0.00	0.00	0.01	3.85	7.59	2.06	3.73	17.72
2007	22.75	8.19	2.27	3.41	8.55	18.15	20.56	29.56	27.99	12.32	3.96	0.55
2008	0.01	0.00	0.00	0.00	0.00	0.00	0.04	18.55	22.92	13.67	17.36	4.60
2009	0.29	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2010	3.67	1.57	10.38	22.66	28.80	14.92	10.31	17.59	27.08	17.23	9.37	2.54

Sub-basin: **2EG1** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.00	0.00	0.00	0.00	0.00	0.04	3.70	3.84	4.35	1.16	0.49	0.03
1992	0.00	0.00	0.00	0.00	0.00	0.00	3.14	6.67	5.11	2.92	2.78	1.98
1993	1.77	6.50	2.09	0.06	0.80	3.60	2.83	1.98	0.81	0.11	0.00	0.00
1994	0.00	0.00	0.00	0.00	1.51	6.98	8.85	12.94	4.72	1.07	0.69	0.75
1995	0.00	0.00	0.00	0.00	3.47	1.46	3.38	2.29	5.34	3.03	3.80	0.90
1996	0.06	0.00	0.00	0.00	0.00	0.22	4.20	6.87	8.45	2.72	0.67	0.72
1997	0.00	0.00	0.00	0.28	9.15	1.51	8.68	10.80	2.47	0.68	6.15	12.09
1998	11.74	6.82	2.33	0.89	5.48	3.69	6.33	9.86	5.25	6.62	3.35	0.87
1999	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.31	1.06	1.03	1.48	0.90
2000	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.21	1.39	1.32
2001	0.29	0.52	0.01	4.27	3.36	1.37	4.01	8.63	6.81	2.41	6.99	2.77
2002	0.45	0.02	0.00	0.00	8.47	1.30	0.65	1.54	0.94	0.01	0.00	3.19
2003	3.86	0.21	0.00	0.00	15.31	6.37	2.63	12.61	7.20	2.14	0.87	2.65
2004	0.60	0.18	0.00	1.40	3.79	1.23	0.19	0.97	0.92	0.45	0.73	0.82
2005	0.27	0.00	0.00	0.00	0.34	2.07	1.71	8.66	15.21	3.95	1.58	0.45
2006	0.00	0.00	0.00	0.00	0.01	0.35	0.59	2.62	1.97	0.43	3.31	8.52
2007	9.91	4.18	1.11	1.13	3.49	10.55	13.10	20.69	22.89	6.84	4.71	1.38
2008	0.39	0.02	0.00	0.00	0.00	0.00	0.00	7.40	7.50	7.25	11.67	2.43
2009	0.31	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2010	2.15	1.07	9.22	15.63	21.71	7.46	5.08	8.83	13.88	8.90	4.34	1.35

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **2EG2** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.01	0.00	0.00	0.00	0.00	0.11	12.33	12.82	14.53	3.88	1.64	0.09
1992	0.00	0.00	0.00	0.00	0.00	0.00	10.47	22.27	17.05	9.74	9.29	6.61
1993	5.89	21.70	6.97	0.04	2.47	12.03	9.45	6.59	2.71	0.36	0.00	0.00
1994	0.00	0.00	0.00	0.00	5.03	23.29	29.53	43.16	15.74	3.58	2.29	2.50
1995	0.00	0.00	0.00	0.00	11.58	4.87	11.27	7.64	17.81	10.10	12.67	3.00
1996	0.05	0.00	0.00	0.00	0.00	0.70	14.00	22.94	28.20	9.08	2.24	2.40
1997	0.00	0.00	0.00	0.92	30.53	5.04	28.98	36.03	8.26	2.27	20.53	40.34
1998	39.18	22.77	7.78	2.97	18.29	12.30	21.12	32.91	17.51	22.10	11.19	2.90
1999	0.03	0.00	0.00	0.00	0.00	0.00	0.00	1.01	3.52	3.44	4.95	3.02
2000	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.69	4.65	4.39
2001	0.90	1.73	0.00	14.09	11.22	4.58	13.37	28.79	22.73	8.04	23.32	9.24
2002	1.50	0.02	0.00	0.00	28.27	4.34	2.18	5.14	3.12	0.00	0.00	10.46
2003	12.88	0.64	0.00	0.00	51.07	21.25	8.76	42.08	24.04	7.15	2.91	8.84
2004	1.99	0.57	0.00	4.64	12.65	4.10	0.62	3.23	3.08	1.49	2.43	2.75
2005	0.91	0.00	0.00	0.00	1.13	6.92	5.72	28.91	50.77	13.18	5.28	1.51
2006	0.01	0.00	0.00	0.00	0.01	1.17	1.98	8.73	6.56	1.44	11.03	28.44
2007	33.08	13.95	3.69	3.76	11.66	35.19	43.71	69.03	76.38	22.81	15.70	4.60
2008	1.29	0.08	0.00	0.00	0.00	0.00	0.00	24.70	25.04	24.19	38.95	8.11
2009	1.04	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2010	7.17	3.56	30.78	52.14	72.44	24.91	16.96	29.46	46.33	29.71	14.48	4.50

Sub-basin: **2EH** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.66	0.22	0.02	0.01	0.01	2.78	5.43	9.87	7.13	1.27	0.36	0.02
1992	0.00	0.00	0.00	0.00	0.69	1.04	5.78	7.37	2.32	1.43	2.33	1.24
1993	0.57	5.17	1.46	0.37	1.78	10.93	4.78	2.76	1.07	0.28	0.01	0.00
1994	0.00	0.00	0.00	8.56	24.72	13.29	12.45	25.92	3.66	1.33	0.42	0.52
1995	0.05	0.00	0.00	0.00	0.00	0.00	2.21	1.40	8.19	1.72	1.48	1.12
1996	0.40	0.03	0.01	0.01	0.01	0.80	15.05	20.55	9.32	2.05	0.78	0.22
1997	0.00	0.00	0.00	17.12	10.44	1.14	18.58	20.60	1.74	0.56	15.19	16.65
1998	22.81	5.96	2.02	0.73	7.49	3.98	12.70	13.19	3.55	2.26	2.14	1.15
1999	0.29	0.01	0.00	0.63	2.96	0.81	0.53	1.14	2.06	1.02	0.95	0.47
2000	0.06	0.00	0.00	0.00	0.00	0.00	0.00	6.41	1.69	0.80	0.44	0.37
2001	0.06	0.01	0.00	1.87	2.95	2.33	5.98	13.62	5.75	1.52	7.99	1.98
2002	0.78	0.18	0.01	0.00	8.77	1.17	0.53	0.04	0.00	0.00	0.00	4.29
2003	4.98	0.55	0.05	0.95	32.97	2.75	4.27	32.39	6.76	1.41	0.39	5.32
2004	0.70	0.11	0.01	6.73	18.07	1.67	0.86	3.32	1.48	1.45	3.14	2.02
2005	0.57	0.04	0.00	0.00	9.62	6.83	4.57	14.09	30.86	2.85	1.16	0.29
2006	0.02	0.00	0.00	2.36	1.90	1.26	8.48	8.03	2.48	1.07	21.25	21.48
2007	6.75	3.67	1.56	6.68	2.57	31.47	25.46	35.27	40.81	4.75	6.67	1.66
2008	0.57	0.05	0.00	0.00	0.00	0.00	1.18	13.24	12.68	12.24	23.62	2.05
2009	0.64	0.08	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2010	4.39	0.07	23.21	18.47	40.64	7.25	5.84	10.82	12.97	5.29	3.17	1.44

Sub-basin: **2EK** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.01	0.00	0.00	0.00	0.00	0.00	0.01	0.67	2.75	0.14	0.06	0.03
1992	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.13	0.22	0.20	0.17	0.10
1993	1.10	5.51	1.03	0.06	0.09	1.98	1.54	1.00	0.17	0.02	0.00	0.00
1994	0.00	0.00	0.00	0.00	5.98	6.56	11.85	11.45	2.66	0.25	0.06	0.18
1995	0.01	0.00	0.00	0.00	0.00	0.00	0.01	0.03	0.13	0.09	0.23	0.16
1996	0.06	0.01	0.00	0.00	0.00	0.05	10.84	15.29	10.45	1.33	0.16	0.05
1997	0.01	0.00	0.00	6.99	14.39	1.10	13.65	14.74	1.57	0.25	10.45	13.38
1998	18.42	6.53	1.35	0.42	12.55	4.74	8.80	11.85	4.87	4.80	1.80	0.45
1999	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.11	0.04	0.02	0.02
2001	0.01	0.00	0.00	0.03	0.12	0.17	0.78	8.48	6.08	0.17	0.76	0.18
2002	0.06	0.02	0.03	0.04	5.88	1.03	0.27	0.05	0.02	0.00	0.00	0.00
2003	0.01	0.00	0.00	0.00	24.47	4.00	2.65	25.02	8.39	1.32	0.81	32.03
2004	2.65	1.06	0.43	0.57	7.10	0.74	0.10	0.53	0.29	0.07	0.07	0.23
2005	0.02	0.00	0.00	0.00	0.11	5.77	8.69	28.87	31.52	4.13	1.56	0.72
2006	0.23	0.06	0.00	0.00	0.00	0.00	0.00	0.02	0.05	0.01	1.95	13.77
2007	8.15	3.43	0.54	0.41	0.74	13.40	20.47	21.26	34.83	5.68	12.31	2.51
2008	0.84	0.31	0.12	0.01	0.00	0.00	0.00	3.69	6.39	7.38	10.58	1.00
2009	0.04	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2010	1.68	0.26	7.91	18.37	32.21	6.23	2.35	7.52	11.14	2.88	1.26	0.23

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

2FB

Sub-basin: **2FB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.08	0.02	0.00	0.04	0.08	0.59	1.04	0.74	0.86	0.53	0.32	0.12
1992	0.01	0.00	0.00	0.00	0.02	0.31	1.25	1.70	1.75	1.11	0.82	0.69
1993	0.58	1.89	0.69	0.10	0.14	0.32	0.39	0.27	0.17	0.03	0.01	0.00
1994	0.00	0.00	0.00	0.00	0.00	0.00	0.24	0.72	0.69	0.24	0.32	0.41
1995	0.06	0.00	0.00	0.03	0.28	0.33	0.74	0.38	0.73	0.60	1.35	0.81
1996	0.24	0.03	0.00	0.00	0.01	0.24	0.80	1.09	1.53	0.83	0.41	0.46
1997	0.07	0.00	0.00	0.00	1.07	0.43	0.46	0.62	0.34	0.21	1.65	2.09
1998	2.06	1.24	0.56	0.27	2.84	1.57	0.84	0.53	0.47	0.77	0.74	0.43
1999	0.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.07	0.09	0.07	0.12
2000	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.13	0.24
2001	0.10	0.06	0.02	0.50	1.04	0.55	0.68	1.54	0.92	0.59	0.95	0.71
2002	0.20	0.04	0.04	0.08	2.42	0.59	0.42	0.41	0.14	0.05	0.29	0.51
2003	1.18	0.18	0.01	0.00	2.12	1.83	0.93	1.10	1.75	0.69	0.54	0.44
2004	0.17	0.09	0.01	0.33	1.11	0.49	0.31	0.44	0.32	0.23	0.24	0.19
2005	0.06	0.00	0.00	0.00	0.10	0.62	0.67	0.88	1.56	0.91	0.64	0.19
2006	0.01	0.00	0.00	0.00	0.04	0.14	0.21	0.25	0.32	0.10	0.19	1.05
2007	1.54	1.06	0.34	0.34	1.08	1.31	1.37	1.33	2.15	1.02	0.40	0.08
2008	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.37	0.95	1.14	1.68	0.57
2009	0.08	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2010	0.29	0.30	1.22	2.55	2.88	1.18	0.42	0.95	2.51	2.60	1.82	0.38

2GA, 2GB, 2GC & 2GD

Sub-basin: **2GA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.27	0.01	0.00	0.65	1.25	7.26	5.47	2.84	3.09	1.69	1.21	0.33
1992	0.02	0.00	0.00	0.00	1.62	2.84	6.84	7.05	6.51	4.78	4.21	3.94
1993	5.60	14.71	4.12	0.66	0.55	1.55	1.24	0.70	0.34	0.04	0.00	0.00
1994	0.00	0.00	0.00	0.00	0.15	2.80	3.08	4.21	2.56	1.14	3.80	4.85
1995	0.77	0.04	0.60	0.69	1.87	1.69	4.56	1.66	2.49	1.68	5.27	2.69
1996	0.82	0.07	0.01	0.00	0.00	2.22	4.76	4.72	7.64	3.29	1.65	1.78
1997	0.17	0.00	0.00	1.05	5.94	1.10	1.33	1.66	0.69	0.46	6.74	7.61
1998	15.18	9.91	3.94	1.89	14.57	9.36	4.17	2.02	1.80	2.33	2.03	0.79
1999	0.05	0.00	0.00	0.00	0.00	0.00	0.01	1.02	1.20	0.27	0.22	0.42
2000	0.06	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.84	0.24	0.71	0.73
2001	0.21	0.14	0.04	2.69	3.38	1.83	2.55	4.15	2.02	1.70	3.96	1.79
2002	0.61	0.15	0.12	0.30	11.96	3.07	2.20	1.53	0.42	0.03	1.00	2.28
2003	2.83	0.36	0.00	0.00	10.53	7.31	4.17	6.12	5.82	2.02	2.05	1.55
2004	0.36	0.17	0.01	1.52	5.23	1.79	1.09	1.54	0.71	0.43	0.67	0.44
2005	0.09	0.00	0.00	0.00	1.51	2.42	1.31	2.45	4.77	2.69	2.12	0.44
2006	0.00	0.00	0.00	0.11	2.41	0.77	0.75	1.03	0.85	0.20	0.89	3.59
2007	4.77	3.40	0.94	1.07	3.18	6.02	4.27	3.98	6.52	1.95	0.78	0.09
2008	0.00	0.00	0.00	0.00	0.40	0.24	0.47	2.05	2.27	2.81	3.11	0.80
2009	0.05	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00
2010	2.78	0.61	4.58	7.94	12.06	4.92	1.48	3.73	7.13	11.28	7.24	1.76

Sub-basin: **2GB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	1.98	0.71	0.18	4.80	6.84	26.96	15.30	10.97	10.29	6.79	5.53	2.44
1992	0.99	0.18	0.00	0.00	10.96	13.64	24.02	23.24	21.44	16.56	12.93	12.98
1993	18.84	35.71	6.68	1.61	3.65	9.58	6.34	3.91	2.84	1.38	0.94	1.37
1994	0.64	0.03	0.00	0.28	9.08	14.53	11.81	14.25	7.99	5.36	19.58	14.06
1995	2.28	0.55	3.71	4.36	10.41	9.51	17.57	5.32	9.50	10.08	27.03	8.73
1996	3.17	0.94	0.74	1.15	2.17	14.93	21.12	17.47	23.92	9.37	5.73	7.56
1997	1.43	0.22	0.00	6.14	25.92	4.52	7.50	8.29	4.38	5.56	36.14	25.35
1998	46.21	24.13	7.74	9.43	56.02	24.65	12.47	7.34	8.03	11.35	9.35	4.28
1999	1.25	0.16	0.00	0.00	0.77	0.92	1.53	5.99	8.43	3.25	2.90	5.42
2000	2.18	0.40	0.00	0.00	0.00	0.00	0.00	0.37	2.67	1.97	4.88	5.63
2001	2.98	2.54	1.72	19.82	19.83	10.38	13.82	16.66	9.94	9.02	19.24	6.46
2002	3.18	1.48	1.61	3.26	47.19	7.18	5.91	6.21	2.45	1.79	10.67	15.25
2003	13.51	2.26	0.43	0.04	48.33	19.80	11.80	25.63	16.24	6.24	8.41	6.80
2004	2.49	1.79	1.12	11.24	24.66	6.79	5.02	7.92	3.68	3.03	6.94	4.15
2005	2.09	0.81	0.27	0.39	8.35	13.54	7.11	11.85	22.61	10.37	7.06	2.40
2006	0.52	0.02	0.57	3.72	14.08	4.38	4.93	6.02	5.04	2.39	10.71	21.78
2007	18.20	10.85	3.04	6.16	13.54	29.42	15.13	18.53	29.40	6.88	4.03	1.57
2008	0.45	0.05	0.00	1.66	3.10	1.63	1.77	9.60	13.60	19.15	15.61	4.48
2009	0.98	0.17	0.00	0.00	0.00	0.21	0.43	0.06	0.06	0.02	2.30	1.47
2010	14.34	5.89	24.85	27.84	36.65	10.60	4.15	17.68	27.77	36.19	17.30	4.37

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **2GC** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	3.14	0.75	0.56	8.33	24.02	30.05	10.89	3.97	5.07	8.98	9.68	3.63
1992	1.34	0.21	0.01	2.34	34.95	19.64	18.48	13.10	12.47	16.44	16.13	15.40
1993	21.44	25.43	6.69	2.43	15.12	15.13	6.36	2.87	1.61	0.77	1.18	5.20
1994	1.95	0.58	0.63	12.96	39.90	21.94	11.14	8.73	7.52	12.83	40.94	18.65
1995	3.16	1.20	11.36	9.96	21.83	14.81	19.26	5.17	6.95	6.46	24.15	11.69
1996	5.05	2.55	3.56	8.24	10.12	23.72	16.13	11.11	17.63	9.22	9.05	10.55
1997	2.05	0.35	0.01	17.26	33.40	6.71	8.11	8.23	4.89	12.12	49.60	26.55
1998	44.23	29.02	9.57	24.75	51.89	27.08	9.55	3.91	3.76	7.61	8.69	5.72
1999	1.46	0.20	0.01	0.04	4.76	4.24	4.11	6.32	10.37	4.60	6.24	18.00
2000	5.86	1.03	0.10	0.00	0.00	0.06	0.27	1.49	1.85	2.79	8.94	11.14
2001	10.33	7.20	5.79	34.79	33.99	11.15	10.81	9.65	5.88	11.72	20.90	8.33
2002	5.13	2.38	4.35	11.43	59.42	8.94	5.84	4.08	2.18	4.45	24.12	16.91
2003	17.34	2.96	0.53	1.94	62.43	22.37	8.61	9.81	11.29	7.06	14.31	8.52
2004	2.18	1.33	1.08	18.28	37.70	7.78	3.26	1.78	0.82	0.97	10.71	6.63
2005	2.88	1.34	0.70	1.27	12.01	13.61	5.53	3.66	13.09	8.82	8.08	2.63
2006	0.38	0.02	0.38	5.84	19.26	6.24	3.12	2.28	1.73	1.17	11.13	20.43
2007	17.70	6.17	2.41	11.76	22.21	35.26	9.01	15.04	15.74	8.56	10.56	3.97
2008	1.21	0.38	0.18	11.61	10.28	4.15	2.09	2.63	7.25	18.41	16.19	5.84
2009	0.95	0.14	0.00	0.00	0.00	1.12	0.71	0.23	0.14	0.20	4.28	2.62
2010	11.04	3.49	18.17	21.46	27.01	8.48	2.61	3.52	12.44	20.45	16.31	4.80

Sub-basin: **2GD** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	4.44	1.06	0.80	11.78	33.88	42.40	15.37	5.60	7.15	12.67	13.65	5.13
1992	1.89	0.30	0.01	3.34	49.36	27.70	26.07	18.48	17.60	23.20	22.75	21.73
1993	30.26	35.88	9.44	3.43	21.36	21.36	8.98	4.05	2.27	1.08	1.68	7.35
1994	2.76	0.82	0.89	18.35	56.31	30.95	15.71	12.31	10.61	18.11	57.76	26.31
1995	4.46	1.69	16.05	14.06	30.81	20.90	27.16	7.30	9.80	9.14	34.08	16.50
1996	7.12	3.60	5.02	11.64	14.29	33.50	22.76	15.67	24.88	13.00	12.78	14.88
1997	2.90	0.50	0.01	24.48	47.12	9.47	11.45	11.62	6.89	17.13	69.99	37.45
1998	62.40	40.94	13.50	34.95	73.21	38.20	13.47	5.52	5.31	10.74	12.27	8.07
1999	2.07	0.28	0.01	0.06	6.73	5.98	5.81	8.95	14.63	6.51	8.81	25.43
2000	8.28	1.45	0.14	0.00	0.00	0.13	0.38	2.10	2.61	3.95	12.63	15.74
2001	14.62	10.16	8.20	49.13	47.95	15.72	15.26	13.61	8.30	16.54	29.49	11.75
2002	7.23	3.37	6.14	16.19	83.86	12.62	8.24	5.75	3.08	6.31	34.04	23.88
2003	24.46	4.18	0.75	2.78	88.11	31.55	12.15	13.85	15.93	9.97	20.20	12.03
2004	3.07	1.87	1.52	25.84	53.21	10.98	4.59	2.50	1.16	1.36	15.14	9.37
2005	4.08	1.89	0.99	1.79	16.98	19.20	7.80	5.17	18.46	12.44	11.40	3.70
2006	0.53	0.02	0.55	8.26	27.17	8.80	4.40	3.22	2.44	1.65	15.75	28.83
2007	24.97	8.70	3.39	16.63	31.34	49.76	12.71	21.22	22.21	12.08	14.90	5.60
2008	1.70	0.53	0.26	16.41	14.51	5.86	2.95	3.72	10.24	26.00	22.84	8.25
2009	1.35	0.19	0.00	0.00	0.01	1.64	1.00	0.32	0.20	0.29	6.04	3.70
2010	15.61	4.93	25.66	30.27	38.11	11.96	3.69	4.98	17.56	28.86	23.00	6.77

2KA

Sub-basin: **2KA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	2.59	1.79	0.40	11.78	51.74	77.11	28.09	8.97	8.19	4.33	3.88	1.46
1992	0.60	0.10	0.13	0.50	10.56	8.40	12.36	12.16	12.43	10.22	9.42	9.06
1993	65.81	127.40	46.16	9.38	16.31	33.99	13.47	4.00	1.30	0.23	0.38	1.60
1994	0.22	0.00	2.69	24.54	90.43	54.57	29.39	19.92	11.27	3.22	13.73	18.93
1995	4.61	2.66	23.82	24.14	91.16	25.57	21.04	8.75	11.43	10.84	12.24	6.75
1996	7.44	19.47	33.00	120.39	27.77	55.64	73.10	36.62	44.75	17.66	5.31	10.68
1997	3.84	1.25	0.07	31.33	168.00	25.84	26.97	25.59	9.87	4.44	71.12	164.70
1998	178.94	138.82	39.03	36.44	107.31	65.25	17.44	7.39	5.16	7.74	5.37	1.29
1999	0.34	0.16	10.38	80.15	26.35	5.49	1.38	2.80	4.43	2.79	3.10	6.97
2000	1.90	0.24	0.00	0.00	0.00	0.00	0.02	1.87	2.17	1.27	6.16	11.99
2001	105.20	80.74	24.36	65.09	45.43	13.06	9.73	13.88	9.87	9.80	23.50	10.40
2002	16.86	14.04	32.35	19.87	231.51	28.55	7.30	3.91	1.75	0.42	5.92	43.12
2003	99.79	18.90	5.96	18.74	251.44	61.42	16.38	14.14	23.47	6.53	2.64	2.84
2004	1.41	1.72	6.29	83.04	135.94	27.59	5.86	2.63	2.44	1.92	1.64	2.59
2005	1.16	0.86	1.11	6.06	18.83	28.58	8.78	4.36	6.28	2.86	1.44	0.57
2006	0.01	0.00	1.08	89.60	101.62	16.58	4.58	3.23	2.49	1.01	17.42	133.10
2007	133.05	106.06	44.66	33.32	32.82	53.57	19.29	16.23	25.90	11.70	2.78	1.10
2008	0.26	0.15	0.40	31.05	28.16	6.53	2.44	4.45	5.30	7.01	22.92	7.77
2009	1.33	0.80	0.11	0.17	5.00	6.99	2.04	0.25	0.01	0.00	0.00	1.75
2010	55.06	22.70	76.48	77.40	95.18	25.21	5.93	1.86	5.41	40.33	48.79	28.29

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

4. Athi River Catchment Area (ATCA)

3AA

Sub-basin: **3AA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	6.33	3.65	3.51	4.49	15.70	9.63	4.37	3.54	3.21	3.36	3.70	5.33
1992	4.89	3.48	3.39	11.19	25.31	5.60	4.20	3.44	3.17	3.25	3.90	4.83
1993	18.52	25.00	7.09	4.06	4.16	3.60	3.40	3.30	3.17	3.27	3.66	4.96
1994	3.74	3.62	3.64	5.51	9.80	5.35	3.77	3.43	3.22	3.70	14.58	13.03
1995	5.78	4.36	12.21	9.19	17.99	6.16	3.86	3.38	3.18	3.40	4.16	4.14
1996	3.64	3.22	3.61	5.98	4.81	5.30	4.08	3.38	3.22	3.23	4.18	5.19
1997	3.51	2.91	3.18	18.09	26.15	6.13	3.79	3.45	3.18	3.83	17.46	33.73
1998	34.11	31.41	17.15	15.82	34.67	19.28	7.17	5.32	3.89	3.77	3.67	3.86
1999	3.75	3.27	4.42	9.05	7.31	4.04	3.65	3.57	3.55	3.59	4.69	22.72
2000	7.30	3.65	3.65	3.87	4.07	3.80	3.68	3.57	3.42	3.57	3.97	4.81
2001	30.33	11.65	11.33	24.18	13.09	7.60	4.72	3.87	3.62	3.68	5.27	4.96
2002	4.21	3.56	4.88	4.44	28.19	6.46	4.03	3.70	3.58	3.79	5.14	12.00
2003	12.54	4.53	3.93	4.54	34.07	12.55	5.13	3.89	3.64	3.70	4.62	4.62
2004	4.26	3.93	4.17	9.88	25.40	5.61	3.98	3.68	3.53	3.78	4.29	4.65
2005	4.38	4.14	4.45	5.49	18.02	13.25	5.30	3.92	3.54	3.69	4.12	3.95
2006	3.67	3.37	4.17	4.90	6.14	4.13	3.65	3.61	3.56	3.57	4.56	7.68
2007	10.43	5.69	4.27	4.24	4.60	4.00	3.60	3.51	3.39	3.47	3.41	3.54
2008	3.82	3.36	3.66	5.24	5.63	3.76	3.60	3.49	3.49	3.99	5.61	4.35
2009	3.61	3.38	3.60	3.73	4.12	3.88	3.78	3.44	3.24	3.61	3.83	4.17
2010	9.83	4.81	11.07	23.29	34.40	8.96	4.28	3.54	3.36	3.62	4.29	4.44

3BA, 3BB, 3BC & 3BD

Sub-basin: **3BA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	3.18	1.38	0.89	2.30	10.56	5.89	1.47	0.90	0.67	0.73	1.70	2.56
1992	1.18	0.88	0.74	5.81	15.47	2.40	1.68	0.80	0.57	0.57	2.29	3.07
1993	8.32	12.77	3.03	1.35	2.09	1.51	0.90	0.60	0.56	0.60	1.76	4.12
1994	1.29	1.25	1.03	3.96	8.04	2.75	1.24	0.96	0.70	1.60	13.44	8.93
1995	2.58	1.97	6.38	6.70	10.82	2.59	0.98	0.68	0.55	0.77	2.71	2.61
1996	1.55	0.97	1.30	3.51	1.65	2.90	1.56	0.77	0.73	0.58	2.92	5.21
1997	1.22	0.49	0.55	11.70	15.83	2.73	1.09	0.82	0.62	1.88	15.34	25.11
1998	22.01	19.06	8.93	11.75	23.55	11.20	3.16	1.87	1.02	1.05	1.13	1.44
1999	1.05	0.66	2.25	5.26	4.70	1.43	0.82	0.76	0.93	0.77	2.69	17.49
2000	4.52	1.03	0.86	1.56	1.74	1.35	0.95	0.76	0.64	0.84	1.82	2.65
2001	14.24	6.78	5.52	14.78	7.05	3.31	1.23	0.86	0.91	0.86	3.64	2.05
2002	1.32	0.89	3.18	2.20	25.88	2.98	1.05	0.84	0.94	1.20	3.64	8.24
2003	7.52	1.39	0.97	2.62	27.14	5.98	1.69	0.91	0.86	0.86	3.20	2.37
2004	1.60	1.46	1.50	8.49	18.74	2.19	0.98	0.79	0.70	1.06	2.40	2.34
2005	1.88	1.88	1.69	2.36	10.87	10.01	2.38	1.03	0.74	0.85	2.16	1.34
2006	0.83	0.65	1.93	5.70	8.94	2.26	0.94	0.78	1.01	0.80	4.00	8.02
2007	6.77	1.50	1.34	2.63	4.93	3.71	1.46	0.87	0.81	0.83	0.88	0.89
2008	1.35	1.15	0.94	4.23	3.97	1.24	1.02	0.78	1.03	1.76	3.89	1.41
2009	0.86	1.18	1.06	1.65	2.02	1.44	1.27	0.74	0.60	1.52	2.06	2.04
2010	6.17	2.30	6.72	17.01	18.12	4.39	1.19	0.73	0.73	1.06	2.43	1.78

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **3BB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	2.32	1.27	1.12	2.22	8.18	4.35	1.39	1.07	0.89	0.95	1.77	2.33
1992	1.22	1.06	0.93	5.39	10.80	1.95	1.62	0.98	0.82	0.83	2.20	2.62
1993	6.25	8.53	2.28	1.34	1.97	1.43	1.00	0.86	0.81	0.84	1.80	3.28
1994	1.23	1.37	1.17	3.75	5.88	2.23	1.29	1.10	0.93	1.69	9.41	5.72
1995	2.03	1.88	5.05	5.12	7.91	2.11	1.10	0.90	0.82	1.06	2.45	2.26
1996	1.40	1.15	1.47	2.95	1.69	2.52	1.48	0.96	0.93	0.85	2.73	3.40
1997	1.17	0.76	0.80	9.27	10.18	2.09	1.14	1.01	0.86	1.99	11.17	15.19
1998	13.50	12.56	6.44	7.84	16.16	7.58	2.52	1.67	1.13	1.14	1.27	1.47
1999	1.16	0.88	2.19	4.19	3.45	1.34	0.99	0.95	1.09	0.96	2.91	11.92
2000	3.08	1.09	1.02	1.61	1.73	1.38	1.08	0.95	0.90	1.02	1.87	2.36
2001	10.92	4.59	4.63	9.95	5.07	2.74	1.27	1.04	1.08	1.04	3.24	1.69
2002	1.35	1.04	2.85	2.82	16.59	2.23	1.13	1.00	1.11	1.34	3.24	6.11
2003	5.18	1.33	1.11	2.64	18.36	4.20	1.53	1.05	1.03	1.04	2.94	1.96
2004	1.60	1.46	1.53	6.83	13.43	1.82	1.09	0.96	0.92	1.25	2.26	2.10
2005	1.78	1.75	1.71	2.26	8.79	6.60	1.96	1.13	0.94	1.04	2.06	1.38
2006	1.01	0.88	1.87	4.30	5.96	1.82	1.06	1.00	1.15	0.99	3.39	5.27
2007	4.13	1.41	1.36	2.39	3.50	2.86	1.37	1.03	1.00	1.01	1.03	1.03
2008	1.45	1.21	1.21	3.75	2.98	1.25	1.15	0.98	1.20	1.82	3.35	1.34
2009	1.07	1.28	1.19	1.67	1.97	1.47	1.35	0.94	0.84	1.59	1.94	2.00
2010	4.72	1.95	5.32	10.98	13.20	3.24	1.23	0.94	0.94	1.23	2.26	1.73

Sub-basin: **3BC** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	9.43	6.27	6.11	6.98	28.26	16.27	8.21	6.73	5.96	6.01	6.39	8.09
1992	6.83	5.40	5.78	13.87	32.71	10.76	8.77	6.74	5.89	6.05	7.95	13.57
1993	22.24	21.07	9.76	7.24	12.86	11.04	7.71	6.31	5.71	5.80	5.85	10.76
1994	7.40	5.90	6.05	13.91	27.32	11.20	8.53	7.06	6.25	6.96	33.54	18.64
1995	8.97	6.76	15.26	18.57	27.36	10.77	7.84	6.62	5.91	5.96	7.90	11.56
1996	8.75	6.44	6.92	11.76	11.69	15.79	10.14	7.26	6.47	5.98	7.95	14.94
1997	7.12	5.30	5.67	24.35	30.68	9.90	8.04	7.05	5.92	7.84	39.26	37.94
1998	36.98	35.75	17.59	26.38	49.31	26.56	11.54	8.61	6.99	6.88	6.94	7.41
1999	6.74	5.76	6.49	11.20	16.61	8.45	6.83	6.45	6.20	6.23	8.63	35.19
2000	11.49	6.39	6.36	6.31	7.17	6.70	6.50	6.21	5.91	6.06	6.24	9.00
2001	30.67	14.03	12.96	28.24	25.10	10.51	7.54	6.70	6.15	6.25	9.54	10.12
2002	7.75	6.23	9.30	17.79	50.15	10.17	7.11	6.51	6.11	6.36	13.02	22.92
2003	16.24	7.04	6.51	7.79	55.88	18.73	8.82	7.03	6.61	6.58	11.17	10.67
2004	7.29	6.60	6.82	22.10	39.37	8.95	6.93	6.41	6.08	6.29	6.77	8.58
2005	7.67	6.42	6.61	7.37	29.45	18.68	9.45	7.10	6.32	6.28	6.75	6.79
2006	6.14	5.63	6.23	11.33	19.54	8.44	6.60	6.14	5.86	5.94	9.25	18.13
2007	13.20	6.51	6.36	8.92	17.48	18.39	9.54	8.75	8.44	8.39	8.85	7.59
2008	6.81	5.93	6.18	15.96	13.57	7.52	6.52	6.14	5.79	7.57	15.15	9.08
2009	6.19	5.35	5.75	5.60	6.03	5.86	5.74	5.54	5.30	5.59	5.75	6.33
2010	12.23	7.58	14.27	26.52	31.68	11.07	6.53	5.71	5.37	5.51	5.81	6.07

Sub-basin: **3BD** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	3.37	2.25	2.18	2.26	13.03	5.76	2.92	2.33	2.08	2.12	2.08	2.42
1992	2.34	1.90	2.05	6.81	13.21	3.86	3.04	2.38	2.06	2.09	2.20	5.10
1993	10.11	8.41	3.33	2.46	4.36	4.16	2.80	2.22	2.02	2.06	2.06	4.80
1994	2.79	2.05	2.09	5.64	10.94	3.87	2.90	2.34	2.08	2.18	15.50	7.36
1995	3.16	2.31	5.73	8.25	10.81	3.79	2.66	2.29	2.07	2.11	2.61	5.25
1996	3.33	2.23	2.35	4.38	4.21	6.57	3.53	2.54	2.13	2.08	2.39	6.62
1997	2.56	1.89	2.04	12.97	13.04	3.45	2.76	2.39	2.08	2.45	18.56	17.48
1998	17.28	15.32	7.32	11.38	20.73	9.43	3.73	2.88	2.37	2.32	2.25	2.30
1999	2.27	2.03	2.29	5.07	6.74	3.02	2.38	2.25	2.15	2.21	3.65	15.77
2000	4.03	2.31	2.30	2.22	2.28	2.17	2.20	2.18	2.11	2.16	2.14	3.31
2001	13.69	5.02	5.33	12.26	9.26	3.61	2.64	2.32	2.16	2.21	3.19	4.03
2002	2.72	2.17	3.15	8.11	21.92	3.85	2.62	2.32	2.18	2.24	4.71	10.57
2003	5.68	2.47	2.33	2.43	26.07	6.89	3.19	2.46	2.24	2.26	2.94	4.24
2004	2.61	2.23	2.33	9.90	15.71	3.36	2.54	2.31	2.18	2.25	2.29	3.40
2005	3.00	2.29	2.29	2.36	13.07	7.53	3.48	2.54	2.21	2.22	2.19	2.24
2006	2.18	2.02	2.22	6.67	9.25	2.99	2.34	2.20	2.10	2.14	5.44	8.27
2007	5.28	2.36	2.33	3.88	7.66	7.12	3.42	2.74	2.74	2.63	3.12	2.90
2008	2.48	2.14	2.18	7.67	4.78	2.70	2.29	2.16	2.04	2.16	5.28	3.30
2009	2.26	1.94	2.10	2.04	2.16	2.07	2.05	2.02	1.94	2.04	2.23	2.77
2010	6.58	2.86	6.81	11.94	13.72	4.06	2.46	2.13	1.99	2.04	2.12	2.38

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

3CB & 3DA

Sub-basin: 3CB (Unit: m ³ /s)												
Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	7.05	5.81	6.25	6.57	15.49	10.32	7.34	6.42	5.94	6.09	6.20	6.80
1992	6.48	5.56	5.98	7.83	19.52	7.66	7.42	6.38	5.81	5.95	6.52	7.88
1993	13.16	14.81	6.71	6.55	8.64	8.49	6.98	6.11	5.71	5.92	6.22	7.11
1994	6.36	5.85	6.15	7.30	15.30	7.99	7.13	6.36	5.86	6.37	22.16	13.00
1995	6.69	6.17	8.28	10.87	14.96	8.05	6.86	6.28	5.83	6.11	6.77	8.62
1996	7.66	6.05	6.69	9.02	8.53	10.35	8.07	6.56	5.91	5.85	6.17	10.55
1997	6.44	5.27	5.76	20.67	20.14	6.74	6.85	6.43	5.77	6.56	27.36	27.65
1998	28.60	23.86	11.22	18.38	30.28	15.18	7.55	7.45	6.58	6.64	6.52	6.74
1999	6.60	5.80	6.77	7.33	11.00	7.50	6.61	6.36	6.19	6.32	6.81	23.01
2000	8.30	6.11	6.40	6.45	6.62	6.32	6.34	6.18	5.95	6.19	6.25	7.18
2001	18.18	9.91	8.13	18.08	14.12	8.12	6.90	6.45	6.16	6.29	6.99	7.80
2002	6.95	6.03	7.73	13.53	34.62	7.38	6.77	6.41	6.21	6.47	7.33	14.90
2003	10.48	6.42	6.51	6.76	35.31	11.26	7.70	6.68	6.29	6.43	7.48	8.68
2004	6.98	6.22	6.67	13.97	23.72	7.17	6.69	6.41	6.12	6.46	6.64	7.47
2005	7.22	6.17	6.61	6.65	17.45	12.65	7.20	6.61	6.09	6.27	6.40	6.40
2006	6.19	5.65	6.54	8.62	15.10	6.61	6.31	6.11	5.95	6.00	8.39	14.35
2007	11.37	5.84	6.59	7.40	12.45	10.71	7.85	6.91	6.66	6.60	7.20	7.05
2008	6.71	5.95	6.15	11.02	9.63	6.75	6.27	5.99	5.85	6.31	8.35	7.38
2009	6.13	5.57	5.99	6.04	6.30	5.91	5.99	5.69	5.44	5.97	6.13	6.27
2010	8.63	5.23	10.21	19.86	18.50	7.76	6.34	5.78	5.51	5.78	6.18	6.30

Sub-basin: 3DA (Unit: m ³ /s)												
Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	4.40	1.26	2.72	0.00	0.76	2.38	3.43	4.28	3.98	4.01	3.43	2.46
1992	2.66	2.87	3.98	0.00	11.46	1.27	2.87	4.00	4.01	4.01	3.28	3.42
1993	19.78	18.94	3.10	0.10	1.37	3.26	3.87	4.25	3.97	4.00	3.56	5.19
1994	1.72	2.52	3.99	2.91	7.52	1.62	2.91	4.07	3.98	3.56	26.22	17.28
1995	2.62	0.06	0.91	2.80	4.00	1.44	4.11	4.10	3.99	3.87	2.56	0.94
1996	1.01	3.04	3.69	0.30	1.50	2.91	3.65	4.16	3.93	4.22	5.26	11.51
1997	1.22	3.44	3.88	13.77	19.52	2.60	1.85	4.12	4.04	3.32	26.09	55.29
1998	60.78	24.51	5.77	15.35	20.93	6.80	1.16	2.34	3.95	3.98	3.77	3.89
1999	3.99	3.76	2.89	5.75	3.97	1.61	3.99	4.06	4.10	4.06	2.54	24.41
2000	5.45	0.94	4.29	3.41	3.79	3.61	4.02	4.23	4.03	4.20	3.14	2.06
2001	10.87	6.07	1.08	20.75	3.81	1.18	3.85	3.99	3.98	4.01	1.64	1.94
2002	0.90	2.67	1.10	0.00	28.04	2.45	2.20	4.16	4.02	3.88	1.77	16.29
2003	7.55	1.13	3.71	2.71	35.69	3.83	1.58	4.19	4.02	3.90	2.19	0.82
2004	2.28	3.21	3.83	3.86	8.30	1.10	3.87	4.02	4.06	4.10	3.01	1.15
2005	0.48	1.86	3.40	2.97	2.22	7.09	1.67	4.33	3.72	4.13	3.47	4.10
2006	4.07	3.84	3.63	5.66	10.41	1.32	3.45	4.25	3.84	4.09	10.84	18.23
2007	16.30	0.54	3.07	4.22	6.86	2.19	2.54	3.91	3.72	3.91	3.66	3.96
2008	3.90	3.51	3.71	2.06	2.01	3.24	3.89	4.30	3.86	3.50	1.97	3.72
2009	4.16	3.55	4.33	3.58	3.67	3.94	4.08	4.13	3.97	3.54	3.79	2.67
2010	3.73	1.90	13.27	19.51	5.04	2.07	3.11	4.27	3.86	3.70	3.50	3.83

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

5. Tana River Catchment Area (TNCA)

4AA, 4AB, 4AC & 4AD

Sub-basin: **4AA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	8.43	3.49	3.16	3.28	42.10	9.42	4.01	3.39	3.04	3.05	4.14	7.28
1992	4.19	2.97	3.01	3.04	16.56	9.80	4.03	3.24	2.89	2.93	6.37	21.74
1993	16.61	11.05	5.05	7.17	16.92	6.00	3.61	3.06	2.85	2.91	3.41	9.24
1994	4.09	3.08	2.97	12.51	39.42	5.94	4.13	3.41	2.96	3.21	32.53	10.40
1995	4.83	4.74	7.70	11.53	33.51	5.63	3.48	3.10	2.92	8.20	18.81	11.45
1996	5.73	3.51	3.16	3.58	11.44	9.87	4.48	3.29	2.92	2.91	2.80	3.91
1997	3.21	2.62	2.83	16.96	23.59	4.92	3.96	3.11	2.78	20.58	54.48	24.30
1998	28.14	14.04	7.48	18.34	30.91	7.36	4.15	3.49	3.18	3.18	3.18	3.92
1999	3.37	2.83	3.09	4.15	19.76	4.60	3.34	3.10	2.93	3.00	4.28	19.91
2000	8.87	3.90	3.18	2.95	3.07	2.92	2.93	2.91	2.80	2.87	2.76	4.18
2001	7.42	5.50	3.49	17.15	21.60	4.35	3.29	2.94	2.75	2.81	7.01	8.32
2002	3.91	2.82	2.87	7.84	30.60	4.81	3.33	2.89	2.71	2.79	18.75	10.82
2003	7.56	3.14	2.87	7.27	32.46	10.45	3.66	3.08	2.92	5.08	19.59	16.11
2004	5.25	3.59	3.07	5.72	12.79	3.49	2.96	2.81	2.67	2.76	19.51	9.54
2005	3.83	2.67	2.77	2.69	14.86	12.57	3.98	3.12	2.80	2.80	4.63	4.51
2006	3.01	2.53	2.91	18.75	23.88	3.93	2.93	2.74	2.59	5.28	36.75	17.28
2007	15.45	3.82	3.23	12.10	15.94	12.74	3.97	4.61	3.91	4.36	9.00	5.39
2008	4.46	3.22	2.86	7.71	7.72	4.23	3.01	2.75	2.60	3.59	9.32	4.37
2009	3.10	2.59	2.66	2.53	8.51	3.88	2.78	2.58	2.46	2.55	10.54	6.50
2010	4.69	2.78	14.89	28.77	26.26	4.08	2.89	2.67	2.53	2.58	7.12	5.27

Sub-basin: **4AB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	8.68	5.15	5.06	6.08	47.38	16.29	8.13	6.46	5.47	5.20	5.74	8.01
1992	6.35	4.62	4.84	4.79	22.35	13.88	9.45	6.93	5.68	5.64	11.33	23.15
1993	20.39	15.38	7.84	6.54	19.78	11.41	6.92	5.28	4.69	4.73	4.55	5.04
1994	5.08	4.58	4.71	12.36	47.78	11.82	8.98	6.89	5.77	6.22	33.51	14.14
1995	8.57	7.45	11.98	9.86	35.96	10.10	7.83	5.88	5.25	8.44	22.00	12.69
1996	8.74	5.60	5.38	6.90	13.50	15.89	8.50	6.12	5.54	5.22	5.14	9.44
1997	5.78	4.35	4.57	21.28	33.53	8.84	7.87	5.87	4.74	20.67	62.79	28.96
1998	36.07	24.38	10.48	21.40	44.75	15.23	8.03	6.02	5.22	5.15	5.06	5.59
1999	5.19	4.48	4.91	4.73	15.59	7.62	5.59	5.07	4.74	4.79	4.68	13.66
2000	8.91	5.11	4.88	4.59	4.76	4.56	4.62	4.58	4.40	4.52	4.36	4.89
2001	8.55	8.46	6.17	30.16	30.06	8.47	6.20	5.45	4.60	4.60	9.43	10.09
2002	6.36	4.78	4.92	8.70	39.00	8.13	5.76	4.81	4.40	4.56	21.11	15.50
2003	13.83	5.27	4.66	7.96	48.35	16.51	7.00	6.01	6.50	8.85	21.43	15.05
2004	6.88	5.14	4.86	8.25	24.11	6.76	5.06	4.61	4.31	4.45	15.69	13.31
2005	7.14	4.44	4.47	4.28	15.41	16.78	6.84	5.06	5.38	5.78	8.49	6.94
2006	4.73	4.05	4.69	14.27	27.32	6.89	4.86	4.45	4.14	4.32	36.14	19.63
2007	15.64	6.56	5.36	11.48	20.45	21.87	7.88	11.45	9.10	11.28	14.27	7.62
2008	5.62	4.33	4.42	8.75	10.47	6.87	4.82	4.39	4.13	5.19	13.76	6.99
2009	4.81	3.91	4.16	3.98	4.29	4.26	4.12	4.03	3.87	3.98	5.27	5.92
2010	7.39	4.80	15.36	25.64	29.87	7.36	4.78	4.24	4.01	4.17	12.89	7.53

Sub-basin: **4AC** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	10.16	6.75	7.00	9.46	43.03	18.90	10.33	8.45	7.69	8.58	9.25	9.20
1992	7.81	6.16	6.59	7.77	24.80	16.74	11.76	9.26	8.29	9.66	12.56	22.28
1993	20.95	17.15	10.13	8.68	21.52	14.45	9.23	7.39	6.64	6.61	6.68	9.02
1994	7.39	6.54	6.91	14.66	45.03	14.84	11.09	9.29	8.17	10.30	32.85	16.76
1995	10.31	8.83	13.81	11.92	34.79	13.61	11.04	8.05	7.84	8.53	20.12	14.29
1996	10.89	7.93	8.23	10.86	14.79	17.87	10.89	8.43	9.16	8.06	8.69	11.19
1997	7.37	5.91	6.29	26.49	35.74	11.28	10.38	8.74	7.08	19.67	56.47	28.14
1998	34.24	26.54	13.37	22.72	43.00	19.79	10.63	8.18	7.56	8.22	8.99	8.78
1999	7.43	6.24	6.79	6.68	18.31	9.82	7.91	7.58	8.25	7.33	8.56	18.67
2000	11.08	6.77	6.67	6.37	7.10	6.86	6.77	6.73	6.36	6.77	8.39	10.13
2001	13.25	11.13	8.94	30.31	32.29	10.92	8.80	8.24	6.94	8.33	12.58	11.25
2002	8.76	6.84	7.98	11.59	41.76	10.67	8.01	7.05	6.52	8.26	24.79	16.50
2003	16.36	7.15	6.52	9.24	46.88	19.61	9.34	8.54	8.72	9.18	20.79	16.55
2004	8.70	6.81	6.87	12.29	26.78	9.03	7.13	6.54	6.11	6.63	16.42	15.03
2005	9.02	6.35	6.52	6.68	17.46	18.41	8.83	7.05	8.28	7.97	9.34	7.96
2006	6.31	5.60	6.22	10.12	25.01	8.85	6.80	6.33	5.91	6.21	29.78	20.36
2007	18.11	8.18	7.09	12.76	22.31	24.53	10.31	14.26	11.47	12.75	17.02	9.84
2008	7.60	6.06	6.30	13.23	13.56	8.71	6.77	6.42	6.73	10.35	14.25	9.08
2009	6.48	5.40	5.77	5.53	6.19	6.37	5.90	5.65	5.40	5.67	8.00	7.34
2010	9.44	6.26	14.57	26.39	31.95	9.11	6.46	6.03	7.21	9.07	11.72	8.39

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **4AD** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	10.79	6.91	7.22	10.46	56.55	22.69	11.65	9.07	8.08	9.52	11.25	11.68
1992	8.52	6.29	6.65	10.66	41.08	20.02	13.95	10.40	9.17	11.19	18.81	28.27
1993	26.55	20.36	11.23	9.98	32.52	17.58	10.40	7.80	6.87	6.77	7.18	13.19
1994	8.72	6.97	7.18	24.99	58.79	17.45	13.17	10.34	9.06	13.64	49.65	20.77
1995	11.05	9.57	16.91	17.10	45.25	15.59	13.36	8.75	8.41	8.70	25.09	17.60
1996	12.57	9.02	9.48	15.98	22.64	21.62	12.13	9.21	10.37	8.79	9.77	16.35
1997	8.07	6.05	6.34	38.74	45.56	13.01	12.81	10.28	7.71	26.53	71.49	35.31
1998	44.29	34.68	15.45	33.89	53.84	23.63	11.59	8.63	8.00	9.16	11.03	11.15
1999	8.05	6.39	6.88	7.09	27.29	10.88	8.44	8.07	9.27	7.76	10.69	30.22
2000	12.29	6.97	6.73	6.47	8.43	8.05	7.27	7.03	6.51	7.08	9.15	14.02
2001	22.08	13.66	9.97	43.22	42.58	12.58	9.87	9.11	7.40	9.43	18.22	14.23
2002	9.98	7.41	8.87	21.35	59.96	11.83	8.54	7.40	6.79	9.13	36.74	21.66
2003	19.29	7.55	6.64	13.01	64.77	24.79	10.15	8.98	10.00	12.26	29.36	18.16
2004	8.92	7.08	7.09	19.35	37.85	10.04	7.36	6.64	6.19	6.77	22.87	17.54
2005	9.49	6.58	6.74	6.99	24.51	21.04	9.70	7.37	8.68	8.39	11.49	9.49
2006	6.48	5.61	6.25	10.85	28.68	9.68	7.11	6.42	5.96	6.31	34.29	23.62
2007	19.57	8.44	7.07	20.22	30.99	33.48	12.16	20.50	14.72	19.06	21.93	11.22
2008	8.27	6.36	6.53	22.08	17.14	9.82	7.13	6.77	7.39	13.91	20.72	10.60
2009	6.59	5.37	5.73	5.51	6.38	7.13	6.10	5.68	5.40	5.82	9.72	8.06
2010	12.22	7.02	18.93	31.35	38.01	9.55	6.36	5.82	6.16	8.07	12.46	9.20

4BA, 4BB, 4BC, 4BD, 4BE, 4BF & 4BG

Sub-basin: **4BA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	3.40	1.38	1.15	1.10	19.63	5.87	1.95	1.36	1.14	1.08	1.07	1.50
1992	1.41	1.03	1.09	1.28	17.63	7.03	2.12	1.35	1.10	1.04	2.92	8.22
1993	8.57	6.54	2.40	1.76	11.74	4.07	1.82	1.21	1.06	1.07	0.96	1.79
1994	1.51	1.10	1.07	9.28	23.11	4.00	2.03	1.35	1.11	1.03	22.94	6.28
1995	2.30	1.68	2.83	9.33	23.93	4.04	1.66	1.26	1.08	0.52	5.32	5.01
1996	2.75	1.43	1.20	1.70	4.84	5.08	1.93	1.22	1.05	1.06	0.91	1.13
1997	1.09	0.94	1.02	18.51	17.02	2.88	1.70	1.18	1.04	4.02	32.60	15.06
1998	14.26	8.57	3.69	10.87	22.04	6.08	2.12	1.36	1.12	1.14	1.02	1.16
1999	1.13	1.00	1.09	1.00	7.59	2.44	1.33	1.10	1.05	1.07	2.12	12.60
2000	4.04	1.44	1.12	1.04	1.04	1.04	1.05	1.04	1.00	1.02	0.93	1.18
2001	3.36	2.63	1.34	8.21	16.92	2.72	1.39	1.12	0.99	1.00	1.82	3.32
2002	1.53	1.04	1.07	7.35	29.66	2.95	1.43	1.09	1.00	0.89	11.91	5.76
2003	4.20	1.34	1.06	1.79	26.24	7.43	1.79	1.20	1.13	0.68	7.19	6.79
2004	2.14	1.22	1.09	1.42	8.31	1.84	1.17	1.03	0.97	0.97	7.18	6.32
2005	2.19	1.06	1.01	0.95	12.74	9.84	2.18	1.25	0.97	0.98	1.03	1.33
2006	1.03	0.91	0.96	1.99	16.16	2.52	1.24	1.01	0.94	0.87	15.45	9.31
2007	8.56	1.72	1.14	3.87	10.28	8.32	2.04	1.93	1.64	1.35	5.11	2.45
2008	1.67	1.12	0.96	4.45	5.58	2.13	1.20	1.01	0.92	0.86	1.62	1.48
2009	1.04	0.87	0.93	0.90	1.40	1.46	0.99	0.91	0.87	0.88	1.83	1.90
2010	1.51	1.07	2.55	12.48	20.26	2.67	1.19	0.94	0.87	0.86	1.08	1.60

Sub-basin: **4BB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	5.08	3.29	3.45	6.11	36.47	11.83	5.25	4.24	3.72	3.90	7.99	7.05
1992	4.05	3.03	3.24	12.69	35.37	11.27	6.65	4.31	3.63	5.56	16.13	18.72
1993	18.01	12.04	5.21	6.44	27.23	10.45	4.86	3.59	3.16	3.18	4.00	11.51
1994	4.15	3.18	3.18	24.02	38.36	8.55	6.77	5.03	4.05	10.29	39.82	12.16
1995	5.07	5.22	10.04	16.56	34.31	8.78	6.10	4.05	3.43	3.72	16.22	10.67
1996	6.47	4.89	5.47	13.69	16.85	11.26	5.23	3.72	4.06	3.39	7.14	10.52
1997	3.54	2.73	2.94	35.60	31.66	6.96	6.87	5.06	3.29	17.01	47.89	24.24
1998	28.78	23.48	8.54	25.96	36.45	14.58	5.07	3.95	3.52	3.82	8.32	5.93
1999	3.84	3.02	3.23	6.53	23.28	4.84	3.62	3.29	3.33	3.19	12.44	24.91
2000	5.45	3.03	3.08	2.95	6.61	3.87	3.25	3.02	2.82	2.88	4.53	10.40
2001	20.07	7.61	5.52	31.31	29.76	5.82	3.91	3.61	2.98	2.93	15.38	7.81
2002	4.76	3.14	5.37	23.33	47.44	5.37	3.61	3.07	2.84	4.16	29.18	14.07
2003	9.89	3.19	2.97	10.99	48.89	14.95	4.16	4.12	4.55	7.39	21.45	8.79
2004	3.75	3.02	3.03	15.56	27.05	4.24	3.15	2.94	2.79	3.26	17.06	10.72
2005	4.08	2.79	2.86	2.81	23.61	12.91	4.24	3.11	2.99	3.11	6.70	4.31
2006	2.82	2.49	2.66	4.50	16.69	3.79	2.97	2.63	2.47	2.52	19.88	13.79
2007	9.76	3.06	2.70	15.87	22.24	21.50	6.84	14.07	7.74	14.84	14.28	5.61
2008	3.84	2.89	2.89	20.62	10.92	4.08	3.00	2.95	2.64	9.52	12.95	4.90
2009	2.71	2.29	2.47	2.37	3.96	3.36	2.51	2.38	2.27	2.32	5.74	3.48
2010	6.83	2.79	11.11	20.03	26.77	3.89	2.52	2.34	2.23	2.28	5.16	3.63

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **4BC** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	9.71	5.14	4.69	1.93	3.70	5.80	4.49	4.21	4.04	3.97	0.00	1.70
1992	4.27	4.08	4.46	0.00	0.00	8.39	3.26	3.90	3.86	2.06	0.00	2.10
1993	3.27	6.67	5.90	3.57	0.00	2.88	4.03	4.25	4.22	4.38	3.31	0.00
1994	4.25	4.06	4.29	0.00	9.59	5.52	2.76	3.07	3.36	0.00	5.67	6.48
1995	5.09	3.15	0.57	2.88	13.76	4.85	2.74	3.98	4.12	3.91	1.48	6.22
1996	5.51	3.14	2.50	0.00	0.00	4.13	4.34	4.21	3.27	4.10	0.05	0.00
1997	3.86	3.89	4.35	0.00	1.88	4.02	1.62	2.51	3.86	0.00	17.93	10.57
1998	5.87	0.00	6.09	3.41	24.64	4.87	5.46	4.64	4.32	4.12	0.00	2.07
1999	4.02	3.99	4.49	1.07	0.00	5.63	4.62	4.45	4.04	4.36	0.00	3.12
2000	10.66	5.55	4.74	4.45	1.01	3.41	4.17	4.36	4.27	4.41	2.50	0.00
2001	0.00	0.35	2.04	0.00	3.68	4.95	4.12	3.73	3.95	4.17	0.00	2.89
2002	3.53	3.63	1.76	0.00	12.70	6.32	4.50	4.28	4.11	2.92	0.00	2.08
2003	3.33	4.17	4.26	0.00	0.00	3.95	4.72	3.60	2.64	0.00	0.00	12.56
2004	6.83	4.51	4.44	0.00	0.00	4.17	4.28	4.19	4.04	3.77	0.94	7.48
2005	5.33	3.90	4.19	3.99	0.00	9.04	5.41	4.51	3.91	3.90	0.38	3.33
2006	4.23	3.92	4.22	9.57	20.08	6.64	4.55	4.38	4.18	4.77	17.59	11.95
2007	15.20	5.48	4.97	0.00	1.38	0.00	2.28	0.00	0.00	0.00	0.00	3.44
2008	4.51	4.03	4.16	0.00	5.52	5.11	4.43	4.03	3.98	0.00	0.00	2.95
2009	4.37	3.95	4.23	4.14	6.52	5.66	4.45	4.22	4.05	4.20	4.06	6.54
2010	1.68	3.91	1.14	11.97	15.38	6.61	4.79	4.43	4.21	4.32	2.11	4.79

Sub-basin: **4BD** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	9.83	6.37	6.64	10.66	60.88	20.97	9.64	7.91	7.03	7.31	13.83	12.47
1992	7.59	5.80	6.23	21.08	61.99	20.22	11.89	7.99	6.84	9.82	27.14	31.74
1993	30.82	21.62	9.69	11.37	45.55	18.28	8.94	6.78	6.03	6.09	7.27	19.59
1994	7.66	6.01	6.06	40.24	65.45	15.32	11.98	9.04	7.45	17.33	68.91	21.80
1995	9.29	9.32	17.24	28.77	60.47	15.77	10.89	7.52	6.47	6.78	27.28	18.69
1996	11.64	8.76	9.71	23.09	28.04	19.34	9.38	6.91	7.41	6.35	12.14	18.03
1997	6.59	5.19	5.60	61.40	54.61	12.42	12.00	9.05	6.16	27.94	81.18	43.37
1998	50.28	39.89	15.23	43.93	63.44	25.82	9.45	7.41	6.63	7.14	14.22	10.57
1999	7.14	5.72	6.15	11.33	39.02	8.90	6.77	6.22	6.23	6.04	20.72	43.81
2000	10.38	5.77	5.88	5.63	11.48	7.11	6.12	5.73	5.38	5.49	7.97	17.59
2001	33.05	13.28	9.61	51.52	51.07	10.52	7.18	6.64	5.59	5.54	25.47	13.80
2002	8.52	5.82	9.43	39.93	85.24	9.92	6.74	5.80	5.40	7.36	48.77	24.29
2003	17.35	5.94	5.62	18.22	84.28	26.06	7.71	7.48	8.19	12.51	35.40	15.38
2004	6.96	5.65	5.72	25.69	45.88	7.90	5.94	5.56	5.28	5.98	28.58	19.09
2005	7.66	5.25	5.41	5.31	40.56	23.66	7.92	5.87	5.60	5.82	11.49	7.81
2006	5.34	4.75	5.08	7.99	29.82	7.28	5.62	5.03	4.73	4.83	34.05	24.73
2007	18.39	5.81	5.17	26.35	38.00	36.29	11.78	23.45	13.27	24.37	23.84	9.81
2008	6.98	5.34	5.30	34.01	19.36	7.48	5.59	5.50	4.97	15.92	21.47	8.70
2009	5.08	4.33	4.68	4.52	7.17	6.17	4.74	4.51	4.30	4.42	9.94	6.37
2010	11.67	5.12	18.38	34.23	46.85	7.43	4.80	4.45	4.23	4.33	8.91	6.54

Sub-basin: **4BE** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	12.62	7.42	7.29	9.70	50.51	21.77	10.99	8.76	7.70	8.29	12.35	12.70
1992	8.89	6.33	6.72	19.32	60.66	21.76	12.53	8.63	7.42	9.57	20.76	27.50
1993	29.36	25.27	12.32	10.35	40.20	19.92	11.03	7.70	6.65	6.61	7.26	21.12
1994	9.75	6.84	6.77	34.38	58.67	16.83	12.23	9.45	8.37	13.59	68.01	25.21
1995	10.97	8.66	15.75	28.47	58.28	18.20	11.63	8.49	7.18	6.09	21.10	19.62
1996	13.42	9.77	10.76	23.62	24.50	20.99	11.21	8.22	8.66	7.46	12.49	20.16
1997	8.16	5.84	6.16	59.37	54.64	14.20	12.99	10.50	7.14	19.86	76.52	49.95
1998	54.54	43.12	17.76	44.01	64.45	29.32	11.90	8.76	7.76	8.62	12.84	11.42
1999	8.09	6.45	6.93	12.40	37.24	11.36	7.89	7.29	8.18	7.34	21.69	47.41
2000	14.35	6.97	6.70	6.48	11.95	8.62	7.30	6.86	6.28	6.36	10.88	17.53
2001	38.33	16.53	10.56	47.19	49.12	12.70	8.41	7.67	6.54	6.74	21.48	16.36
2002	9.93	7.31	10.52	41.72	95.59	13.24	8.13	6.89	6.39	8.23	38.76	26.33
2003	19.70	7.62	6.61	14.55	85.52	27.79	9.82	7.97	9.24	9.49	28.67	16.63
2004	8.33	6.63	6.75	26.42	47.93	10.48	7.16	6.45	6.05	6.43	19.42	21.16
2005	10.40	6.60	6.62	7.47	40.92	26.02	10.38	7.18	6.84	6.99	9.61	8.86
2006	6.23	5.50	5.82	5.18	24.11	9.84	6.84	5.96	5.53	5.49	26.29	25.95
2007	21.67	7.45	6.28	24.62	37.42	35.26	13.11	20.18	14.40	20.41	22.34	11.93
2008	8.96	6.88	6.47	33.44	20.38	9.97	7.10	6.82	6.22	13.77	19.94	11.51
2009	6.22	5.10	5.43	5.24	5.95	5.95	5.39	5.21	5.00	5.10	6.19	6.88
2010	10.67	6.72	12.82	32.28	44.22	10.87	5.96	5.19	4.90	4.97	5.41	6.86

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **4BF** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	8.62	6.41	6.75	6.79	17.73	8.63	7.06	6.71	6.39	6.55	6.30	6.74
1992	6.64	5.79	6.35	9.88	24.34	8.39	6.88	6.51	6.18	6.33	6.89	11.15
1993	14.18	12.90	7.42	6.42	9.46	7.37	6.57	6.28	6.00	6.15	5.93	8.47
1994	6.67	5.74	6.02	14.38	16.34	7.21	6.42	6.12	5.82	6.03	29.62	11.46
1995	6.92	5.84	7.22	15.54	20.03	7.46	6.49	6.23	5.94	6.09	7.64	10.85
1996	7.14	5.72	6.21	7.52	7.08	6.84	6.17	5.91	5.64	5.78	6.04	9.63
1997	6.11	5.20	5.68	28.01	17.87	6.89	6.18	5.94	5.67	5.88	28.80	27.18
1998	27.04	16.96	9.95	18.37	28.14	13.38	7.69	6.91	6.46	6.58	6.32	6.49
1999	6.44	5.78	6.36	9.84	11.55	6.74	6.42	6.30	6.05	6.20	9.00	22.57
2000	8.19	5.95	6.30	6.03	6.18	5.94	6.09	6.05	5.81	5.97	5.74	6.12
2001	13.18	7.79	7.25	18.74	13.94	6.72	6.20	6.01	5.75	5.90	7.27	7.48
2002	6.22	5.50	6.08	20.30	37.94	7.13	6.33	6.10	5.84	5.99	11.20	14.09
2003	8.27	5.70	6.03	6.50	38.19	8.69	6.62	6.27	5.96	6.10	6.40	8.15
2004	6.41	5.52	5.99	12.40	18.12	6.56	6.15	6.01	5.76	5.91	7.02	8.44
2005	6.83	5.44	5.82	5.59	21.43	12.01	6.61	6.00	5.66	5.79	5.56	5.71
2006	5.66	5.26	5.59	7.51	17.37	6.44	5.81	5.63	5.39	5.53	16.08	15.18
2007	11.52	5.62	5.77	10.83	14.00	8.86	6.20	5.79	5.46	5.58	5.37	5.52
2008	5.47	4.91	5.39	10.33	8.79	5.65	5.47	5.36	5.14	5.28	5.13	5.25
2009	5.19	4.66	5.12	4.93	5.50	5.20	5.05	4.98	4.78	4.91	5.17	5.58
2010	6.85	5.18	10.28	16.25	17.16	6.25	5.26	5.03	4.80	4.92	4.81	5.01

Sub-basin: **4BG** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	6.35	4.13	3.73	2.25	4.13	8.12	4.50	3.84	3.53	3.10	2.82	3.60
1992	3.77	3.02	3.23	0.00	19.32	7.88	4.38	3.77	3.37	2.47	3.12	3.58
1993	7.36	14.37	5.59	3.10	2.92	4.97	4.08	3.45	3.14	3.14	2.24	3.59
1994	3.88	3.15	3.15	0.07	13.62	6.81	3.99	3.40	3.31	1.47	20.34	10.77
1995	4.88	2.98	3.62	3.06	17.84	6.49	4.24	3.66	3.14	0.48	4.27	3.99
1996	4.46	3.13	3.00	3.54	1.34	5.00	3.54	3.18	2.86	2.93	0.99	4.91
1997	3.54	2.79	2.92	8.69	20.61	4.88	3.81	3.46	3.12	0.00	15.28	34.65
1998	33.12	13.44	5.98	11.64	23.33	10.53	5.46	4.15	3.43	3.40	2.50	3.68
1999	3.21	2.79	2.98	2.04	4.63	4.48	3.44	3.12	2.95	3.01	0.00	15.25
2000	7.09	3.72	3.34	2.99	2.66	3.11	2.95	2.88	2.73	2.78	1.60	2.92
2001	2.84	5.67	2.76	7.22	15.08	4.84	3.61	3.29	2.91	2.81	0.56	4.88
2002	3.12	2.90	2.47	0.00	50.54	5.42	3.85	3.19	2.91	1.67	2.47	5.74
2003	7.42	3.64	3.17	0.00	30.09	9.96	4.28	2.80	3.31	0.12	2.36	5.57
2004	3.18	2.68	2.81	0.03	9.81	4.39	3.27	2.97	2.74	2.31	0.28	6.13
2005	4.43	2.97	2.91	2.53	0.10	14.94	4.39	3.27	2.55	2.68	2.08	3.44
2006	2.74	2.43	2.49	0.20	10.19	4.66	3.31	2.86	2.62	2.23	4.77	13.96
2007	15.14	3.95	3.26	3.39	9.34	7.13	3.54	2.63	3.67	0.23	4.37	3.09
2008	2.83	2.46	2.27	0.00	6.11	3.91	2.79	2.62	2.41	1.28	2.39	3.37
2009	2.53	2.18	2.35	2.20	1.82	2.68	2.41	2.29	2.19	2.17	1.46	2.72
2010	2.42	2.70	1.99	14.05	11.89	5.19	3.32	2.72	2.42	2.25	1.47	3.09

4CA, 4CB & 4CC

Sub-basin: **4CA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	20.72	16.11	17.32	21.04	51.84	32.17	21.68	18.71	17.35	19.53	21.80	21.00
1992	17.33	14.21	15.26	28.88	53.37	26.72	23.27	19.07	17.37	21.18	28.58	33.31
1993	37.38	30.40	21.12	18.94	39.81	27.57	20.12	16.92	15.34	15.25	16.61	28.49
1994	17.44	14.46	15.20	36.05	56.64	24.83	21.85	19.13	17.41	24.46	62.43	31.51
1995	19.16	15.94	27.28	31.08	45.39	24.94	22.63	17.94	16.50	16.47	27.93	26.28
1996	20.71	17.69	19.44	29.62	30.53	30.95	22.08	18.39	19.25	17.09	24.62	29.32
1997	16.28	13.10	13.94	46.59	51.62	21.58	22.31	20.52	15.98	29.41	68.49	47.95
1998	55.85	50.56	27.80	48.21	63.16	37.30	22.85	19.88	18.92	20.17	23.76	22.63
1999	18.49	15.29	16.60	22.96	39.01	19.88	17.86	17.67	18.52	16.86	28.96	48.43
2000	21.63	15.01	15.52	15.03	20.03	17.15	16.24	15.60	14.38	14.89	19.26	26.43
2001	44.81	22.40	21.70	50.94	50.23	21.31	18.43	17.63	15.48	17.16	31.79	22.50
2002	18.99	15.30	20.84	39.96	78.38	20.95	17.36	16.17	15.06	18.11	41.09	35.26
2003	27.34	15.56	15.21	21.88	81.70	33.54	19.47	18.56	18.86	19.37	35.83	22.37
2004	16.62	14.73	15.73	41.02	54.73	19.20	16.38	15.35	14.40	15.58	22.94	23.67
2005	17.34	14.26	15.09	16.42	40.11	27.27	18.39	15.49	16.25	15.76	17.61	16.02
2006	13.47	12.07	12.79	15.76	27.53	15.85	13.87	12.88	12.06	12.30	23.58	28.63
2007	22.28	13.07	12.79	29.32	38.41	40.18	20.94	27.36	23.28	26.95	26.05	18.19
2008	15.43	13.26	14.38	38.68	24.04	16.18	14.58	14.25	13.98	24.26	29.78	18.34
2009	13.10	11.17	12.00	11.46	12.09	12.17	11.64	11.20	10.62	10.90	11.88	12.05
2010	19.95	12.46	21.85	31.58	37.63	16.38	12.10	11.15	10.68	12.07	14.93	12.72

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **4CB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	14.01	10.86	11.58	12.96	33.88	19.12	13.40	12.05	11.10	12.07	12.93	13.09
1992	11.30	9.46	10.23	20.36	34.90	16.34	13.67	11.46	10.45	12.30	15.50	21.36
1993	24.17	19.91	13.38	12.27	25.38	17.44	12.80	10.87	9.99	10.06	11.10	18.78
1994	11.48	9.50	9.93	23.06	34.42	14.71	13.07	11.65	10.58	13.70	41.38	20.40
1995	12.56	10.55	16.63	22.40	31.35	15.47	12.97	11.19	10.26	10.51	16.92	18.27
1996	13.61	11.35	12.17	19.13	19.42	18.79	13.32	11.12	10.89	10.22	13.76	19.81
1997	10.58	8.63	9.28	36.48	33.44	13.82	13.51	12.33	10.01	17.39	46.55	33.74
1998	36.55	33.80	18.71	32.52	43.27	24.23	14.88	13.21	12.47	12.93	14.84	13.66
1999	12.16	10.38	11.36	16.80	26.59	13.14	11.69	11.44	11.48	11.00	19.10	34.38
2000	14.55	10.19	10.68	10.33	13.59	10.88	10.60	10.22	9.59	9.77	12.36	15.21
2001	32.22	15.05	14.16	32.26	30.37	13.40	11.44	10.93	10.01	10.41	18.29	15.05
2002	12.02	9.89	13.05	29.21	49.68	13.58	11.25	10.64	10.05	11.82	25.15	24.56
2003	17.28	10.26	10.37	14.54	53.23	20.90	12.54	11.83	11.64	12.41	21.00	15.27
2004	11.27	9.94	10.52	26.60	34.98	12.41	10.91	10.43	9.87	10.65	14.06	15.98
2005	11.93	9.54	10.12	10.72	30.24	18.42	12.05	10.25	9.96	9.93	10.77	10.16
2006	9.13	8.30	8.76	11.32	20.34	10.30	9.04	8.55	8.07	8.18	17.82	19.66
2007	14.76	8.44	8.56	19.02	25.20	23.98	13.25	15.88	13.51	16.45	16.95	12.26
2008	10.57	9.11	9.77	26.34	16.09	10.49	9.72	9.39	8.78	13.41	18.62	12.06
2009	8.88	7.66	8.26	7.89	8.37	8.10	7.85	7.65	7.27	7.41	7.96	8.55
2010	13.10	8.36	14.18	22.49	26.33	10.48	8.02	7.53	7.13	7.24	7.39	7.85

Sub-basin: **4CC** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	14.39	8.96	8.16	7.59	15.94	12.42	8.94	8.16	7.80	7.72	7.53	8.33
1992	8.18	7.09	7.78	6.33	32.42	11.35	8.70	8.00	7.58	7.20	7.86	11.48
1993	24.11	30.29	12.31	8.47	8.32	8.18	8.11	7.73	7.38	7.57	6.96	12.25
1994	9.59	7.29	7.47	9.90	25.03	10.99	8.38	7.58	7.31	6.63	44.36	26.59
1995	11.14	7.92	10.18	14.06	21.03	10.16	8.22	7.75	7.28	7.06	7.72	11.70
1996	9.77	7.00	7.50	9.40	7.58	7.99	7.60	7.19	7.15	7.16	6.19	16.52
1997	8.48	6.61	7.14	31.37	36.08	11.24	8.21	7.55	7.22	5.51	42.59	71.69
1998	74.03	36.01	17.96	31.21	46.44	22.15	11.42	8.99	7.84	8.24	7.37	8.37
1999	8.03	7.19	7.99	11.98	15.51	9.03	8.12	7.66	7.74	7.76	5.08	36.87
2000	15.87	8.30	8.04	7.55	7.56	7.61	7.69	7.67	7.33	7.57	6.56	7.93
2001	18.23	14.75	11.06	39.41	18.79	9.43	8.03	7.73	7.35	7.45	7.33	10.05
2002	8.18	7.18	7.54	10.94	67.73	11.93	8.57	7.80	7.40	7.10	8.12	23.14
2003	16.10	8.02	7.75	5.54	66.13	14.66	9.08	7.71	7.65	7.07	7.55	9.64
2004	8.03	6.96	7.56	12.17	25.64	9.70	8.00	7.65	7.30	7.18	7.00	11.45
2005	9.57	7.32	7.51	6.97	17.75	20.68	9.51	7.79	7.12	7.29	6.95	7.54
2006	7.28	6.74	7.24	12.84	24.45	9.96	7.81	7.31	6.98	7.14	19.02	30.65
2007	28.87	8.59	7.95	13.29	22.39	13.36	8.13	7.34	7.50	6.47	7.47	7.38
2008	7.23	6.44	6.38	7.76	11.90	7.74	7.05	6.99	6.74	6.26	6.66	7.77
2009	6.90	6.16	6.77	6.52	6.89	6.59	6.68	6.63	6.38	6.56	6.65	7.50
2010	11.98	9.34	23.46	37.48	20.00	10.58	7.45	6.82	6.47	6.56	6.33	6.77

4DA, 4DB, 4DC & 4DD

Sub-basin: **4DA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	20.82	12.94	12.68	12.20	42.77	19.42	13.51	12.29	11.41	11.52	11.70	15.80
1992	12.84	10.11	10.78	10.61	49.56	22.99	13.50	11.74	10.70	10.71	15.09	29.57
1993	26.45	27.49	16.14	14.83	27.39	15.22	11.84	10.85	10.14	10.25	9.94	17.72
1994	11.71	9.50	9.77	30.92	49.10	16.55	12.66	11.07	10.08	10.54	75.18	25.33
1995	14.21	11.33	14.36	32.58	65.35	17.09	12.77	11.62	10.71	10.93	28.91	23.50
1996	15.49	11.14	11.24	13.73	18.70	16.32	11.79	10.40	9.74	9.83	9.39	10.92
1997	9.70	8.43	9.19	44.11	39.60	13.88	11.25	10.19	9.50	21.30	73.80	62.91
1998	67.38	30.57	20.11	40.43	78.27	26.73	16.33	13.68	12.19	12.02	11.61	12.80
1999	11.65	10.03	10.96	13.53	28.28	13.13	11.26	10.74	10.16	10.26	12.98	44.61
2000	19.05	11.27	10.94	10.27	10.29	9.72	9.84	9.68	9.18	9.36	8.96	11.48
2001	13.68	10.89	9.48	24.01	37.15	12.85	10.44	9.63	8.93	9.05	15.45	17.01
2002	10.92	8.67	8.98	37.21	100.76	15.15	11.44	10.31	9.53	9.57	24.09	18.41
2003	14.68	9.33	9.63	10.72	69.91	21.23	12.22	10.77	9.81	9.76	21.56	22.09
2004	12.40	9.38	9.70	12.44	20.42	10.37	9.54	9.16	8.70	8.87	39.84	22.25
2005	12.26	9.09	9.47	8.87	24.97	24.55	11.85	9.87	8.98	9.00	9.44	10.93
2006	8.96	7.92	8.35	18.25	38.27	12.02	9.43	8.90	8.32	8.44	49.51	40.77
2007	40.64	12.02	10.58	18.81	29.24	23.59	11.67	10.32	9.37	9.33	13.11	12.72
2008	10.96	8.95	8.95	20.89	17.53	10.22	9.10	8.74	8.19	8.60	11.49	9.62
2009	8.30	7.29	7.84	7.58	16.60	10.27	8.04	7.56	7.22	7.39	14.94	12.43
2010	9.33	7.49	14.14	38.40	43.35	12.97	9.50	8.61	7.94	7.90	9.69	10.38

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **4DB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	11.22	5.36	4.84	4.94	29.35	8.96	5.37	4.60	4.14	4.21	11.90	10.08
1992	6.07	3.81	3.68	6.52	34.19	9.48	4.73	3.83	3.37	3.29	13.77	23.54
1993	15.78	14.43	7.01	10.40	16.67	6.06	4.11	3.54	3.15	3.07	7.88	12.92
1994	4.59	3.01	2.77	29.14	28.71	6.59	4.35	3.67	3.00	9.04	58.86	14.90
1995	5.52	3.85	8.23	19.61	37.20	6.95	4.49	3.99	3.61	5.53	23.29	17.53
1996	7.12	4.84	4.15	10.99	12.44	8.43	4.86	3.63	3.08	2.96	5.18	8.05
1997	3.43	2.40	2.45	36.97	24.14	5.21	3.56	2.98	2.67	21.29	52.21	33.12
1998	35.08	17.77	11.84	25.16	45.54	13.66	7.39	5.94	5.19	4.95	7.10	7.35
1999	5.21	4.05	4.45	9.95	16.81	5.79	4.26	3.85	3.50	3.44	12.59	36.66
2000	9.25	4.38	3.80	3.44	3.38	3.09	3.02	2.86	2.61	2.55	8.43	11.45
2001	7.93	4.90	2.91	22.34	23.63	4.75	3.12	2.66	2.35	2.28	14.47	8.64
2002	3.83	2.37	2.21	46.00	53.08	5.81	3.58	3.07	2.76	2.78	21.29	10.91
2003	6.03	2.88	2.61	10.79	45.70	8.83	3.99	3.35	3.15	6.02	21.49	13.37
2004	5.03	3.25	2.95	10.32	11.72	3.60	2.72	2.42	2.18	2.22	34.70	12.51
2005	4.14	2.44	2.36	2.39	17.73	12.33	4.47	3.16	2.64	2.53	8.92	5.52
2006	2.87	2.13	2.43	14.85	28.91	4.21	2.30	1.85	1.61	2.45	46.46	25.93
2007	24.50	4.04	2.86	10.33	17.94	11.02	3.85	3.08	2.75	4.37	15.80	6.23
2008	5.21	3.36	2.42	20.45	8.18	3.25	2.40	2.13	1.88	4.07	10.33	3.48
2009	2.02	1.95	1.60	3.10	12.17	3.51	1.63	1.24	1.12	1.17	14.32	5.91
2010	2.77	1.49	8.16	29.06	22.51	3.94	1.83	1.42	1.20	1.13	4.68	3.19

Sub-basin: **4DC** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	11.05	5.49	5.00	5.09	27.47	9.00	5.53	4.77	4.31	4.38	12.07	10.09
1992	6.23	3.97	3.86	6.68	28.76	9.24	4.89	4.01	3.54	3.48	13.94	22.37
1993	14.76	13.68	7.09	10.29	15.88	6.19	4.28	3.72	3.32	3.25	8.09	13.05
1994	4.76	3.18	2.96	25.10	26.59	6.59	4.49	3.83	3.17	9.24	52.31	14.22
1995	5.65	3.99	8.23	17.70	33.83	6.94	4.65	4.16	3.78	5.76	22.50	16.85
1996	7.24	4.99	4.32	10.71	12.08	8.46	5.03	3.81	3.26	3.15	5.39	8.19
1997	3.61	2.57	2.63	32.91	22.46	5.27	3.70	3.13	2.81	21.22	46.10	29.32
1998	31.08	16.53	11.54	23.75	41.49	13.06	7.49	6.10	5.35	5.12	7.28	7.52
1999	5.39	4.21	4.63	10.13	16.62	5.96	4.44	4.03	3.68	3.62	12.80	33.21
2000	9.21	4.53	3.99	3.62	3.57	3.27	3.21	3.05	2.80	2.74	8.64	11.60
2001	8.10	5.05	3.10	20.51	21.86	4.85	3.28	2.82	2.51	2.45	14.63	8.58
2002	4.01	2.54	2.40	34.04	42.45	5.70	3.67	3.17	2.87	2.89	20.85	10.48
2003	6.16	3.04	2.80	10.84	41.11	8.54	4.14	3.52	3.32	6.23	21.03	12.99
2004	5.20	3.41	3.13	10.24	11.36	3.76	2.90	2.60	2.36	2.41	32.85	12.00
2005	4.27	2.60	2.55	2.57	15.95	11.52	4.15	2.87	2.36	2.25	8.66	5.22
2006	2.58	1.87	2.15	14.29	26.73	4.33	2.47	2.02	1.78	2.64	42.08	23.83
2007	22.80	4.13	3.03	9.73	17.13	10.63	4.00	3.26	2.93	4.57	15.83	6.31
2008	5.26	3.52	2.61	18.97	8.09	3.35	2.51	2.25	1.99	4.20	10.44	3.59
2009	2.15	2.05	1.72	3.23	12.26	3.61	1.75	1.36	1.24	1.29	14.44	6.01
2010	2.88	1.60	7.61	26.52	20.57	3.98	1.97	1.57	1.34	1.28	4.84	3.33

Sub-basin: **4DD** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	2.05	1.18	0.86	0.70	0.38	1.23	0.81	0.71	0.66	0.65	0.48	0.78
1992	0.82	0.64	0.67	0.02	5.01	2.29	1.19	0.83	0.69	0.67	0.52	2.89
1993	4.43	5.55	2.06	1.04	1.13	1.05	0.79	0.71	0.65	0.66	0.24	0.97
1994	0.79	0.70	0.60	0.00	3.94	1.93	1.19	0.86	0.69	0.33	10.64	4.42
1995	1.74	0.94	0.82	0.00	4.77	1.73	1.05	0.78	0.68	0.12	1.05	1.72
1996	1.68	1.07	0.79	0.74	0.59	0.89	0.75	0.67	0.65	0.65	0.35	0.92
1997	0.75	0.54	0.65	4.05	5.24	1.62	1.01	0.75	0.67	0.00	9.41	15.97
1998	13.24	6.14	2.57	5.00	11.45	3.54	1.82	1.09	0.80	0.73	0.57	0.79
1999	0.72	0.63	0.66	0.25	1.60	1.20	0.85	0.72	0.67	0.68	0.00	5.35
2000	2.39	1.16	0.90	0.65	0.70	0.66	0.67	0.68	0.64	0.67	0.36	0.88
2001	0.70	0.84	0.70	0.00	5.03	1.53	0.96	0.75	0.72	0.62	0.26	1.40
2002	1.21	0.79	0.66	0.00	16.77	1.92	1.16	0.81	0.69	0.67	0.54	1.98
2003	1.87	1.02	0.80	0.00	4.86	2.47	1.26	0.84	0.71	0.35	0.53	1.38
2004	1.27	0.87	0.75	0.26	1.03	0.72	0.68	0.66	0.64	0.63	2.56	3.83
2005	1.69	0.92	0.78	0.68	0.00	1.96	0.97	0.75	0.66	0.65	0.49	0.81
2006	0.65	0.62	0.63	0.18	1.32	1.24	0.90	0.65	0.64	0.51	6.14	6.54
2007	9.00	1.66	1.03	0.93	2.30	1.69	1.06	0.77	0.67	0.46	0.67	0.79
2008	0.68	0.73	0.64	0.05	1.36	0.83	0.71	0.65	0.67	0.55	0.56	0.75
2009	0.65	0.58	0.65	0.40	0.67	0.75	0.67	0.68	0.57	0.65	0.34	0.86
2010	0.70	0.63	1.29	6.42	3.11	1.79	1.05	0.72	0.66	0.63	0.48	0.74

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

4EA, 4EB, 4EC & 4ED

Sub-basin: **4EA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	24.76	11.20	11.74	27.93	92.04	18.06	11.93	11.07	10.31	21.99	42.37	45.76
1992	18.75	10.75	10.86	24.31	59.27	18.25	11.75	10.92	10.24	10.44	71.45	118.88
1993	68.17	52.85	14.41	31.81	70.01	14.30	11.67	10.89	10.25	10.46	46.02	62.27
1994	14.02	10.76	10.80	52.30	48.77	13.15	11.69	11.08	10.32	45.69	211.01	70.08
1995	15.23	11.03	24.94	86.20	97.28	13.54	11.68	11.16	10.51	22.87	75.96	65.75
1996	24.45	12.06	16.13	23.60	28.86	22.87	11.89	11.18	10.39	10.55	42.73	30.51
1997	12.10	9.88	10.55	105.64	78.82	12.51	11.40	10.74	10.19	94.69	176.11	121.55
1998	138.36	49.58	29.95	75.46	110.21	25.38	13.25	12.02	11.15	11.13	41.60	18.21
1999	13.16	10.31	22.62	31.83	37.43	12.38	11.41	10.94	10.38	10.63	69.12	111.23
2000	20.28	11.19	11.20	10.87	11.17	10.52	10.67	10.59	10.22	10.54	59.21	58.25
2001	28.19	13.91	11.41	80.38	38.36	12.33	11.39	10.84	10.27	10.55	79.60	35.66
2002	16.54	11.22	19.46	117.64	92.34	12.61	11.39	10.81	10.29	20.49	95.55	51.79
2003	19.37	10.80	11.04	74.53	95.59	17.81	11.99	11.16	10.45	28.40	104.41	45.85
2004	23.87	12.31	11.57	50.59	37.24	11.97	11.17	10.72	10.24	16.99	135.25	54.87
2005	14.10	10.92	11.04	11.03	42.00	25.35	11.81	11.07	10.38	10.56	54.88	20.27
2006	12.21	10.48	11.35	51.40	74.71	12.60	11.28	10.72	10.21	16.79	167.74	82.41
2007	71.34	11.88	11.53	32.05	57.70	19.75	12.08	11.37	10.57	18.97	65.47	26.97
2008	25.18	11.51	11.96	53.14	19.12	11.45	10.88	10.61	10.19	17.42	45.56	12.33
2009	12.30	10.83	10.82	14.36	32.44	11.57	10.77	10.49	9.99	19.36	72.70	32.36
2010	16.20	10.73	32.73	76.59	45.33	12.30	11.11	10.62	10.09	10.23	31.59	16.75

Sub-basin: **4EB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	35.36	14.93	17.22	26.17	115.33	26.92	16.15	15.62	14.56	37.23	61.31	56.04
1992	23.64	13.57	14.62	37.78	98.69	25.88	15.41	14.79	14.24	16.62	94.01	126.53
1993	71.30	63.31	20.80	45.00	87.81	20.29	15.72	15.07	14.36	15.14	59.57	69.52
1994	17.91	13.79	14.93	101.24	77.37	18.53	17.02	15.06	13.96	69.04	246.52	74.66
1995	19.80	15.84	41.11	91.51	141.03	19.73	16.68	16.44	15.40	29.74	102.62	83.39
1996	31.35	17.14	22.99	43.61	42.94	29.30	17.05	15.46	14.39	15.07	55.29	41.25
1997	15.36	12.89	15.59	151.57	97.61	17.31	15.28	14.82	14.00	131.70	196.74	144.06
1998	156.57	68.08	41.11	110.83	151.36	39.59	20.60	18.85	17.59	17.78	49.40	26.84
1999	18.71	15.35	29.29	43.56	56.28	18.24	16.74	16.41	15.56	16.38	89.72	139.46
2000	32.32	15.50	16.05	17.64	16.31	15.16	15.46	15.39	14.67	15.09	88.85	73.56
2001	37.20	20.86	16.36	106.01	64.39	16.50	15.24	14.99	14.08	15.13	109.02	45.17
2002	20.33	13.87	19.72	137.41	124.63	16.93	15.36	15.23	14.45	26.55	119.50	57.97
2003	24.70	13.51	16.69	85.31	146.70	27.15	15.82	16.09	14.71	37.96	121.57	60.34
2004	26.04	15.16	15.66	65.04	49.02	15.54	14.95	14.70	14.08	27.51	154.15	52.70
2005	18.01	13.93	14.75	19.50	57.76	40.55	15.75	14.54	13.64	17.47	71.24	27.44
2006	15.35	12.94	18.02	73.16	109.25	15.87	13.84	13.66	13.17	25.57	210.23	103.71
2007	94.67	14.71	15.81	39.38	78.40	35.72	15.82	16.32	14.06	24.81	87.11	34.22
2008	30.55	14.97	17.30	75.46	28.64	13.90	14.06	13.81	12.97	34.62	66.27	16.42
2009	15.75	12.80	13.07	23.79	46.32	15.34	12.50	12.48	11.64	24.05	82.71	36.80
2010	19.04	12.52	43.53	111.70	66.80	14.44	12.82	12.72	11.82	14.08	54.25	22.40

Sub-basin: **4EC** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	20.17	13.65	13.76	13.41	30.69	17.78	14.44	13.40	12.55	12.91	18.37	21.39
1992	16.24	12.16	12.66	12.90	38.62	17.20	13.71	12.69	11.89	12.08	22.92	41.20
1993	28.09	26.09	16.70	16.22	26.77	15.58	13.38	12.56	11.83	12.03	13.15	25.55
1994	14.66	11.82	11.95	34.34	31.32	15.55	13.35	12.40	11.53	16.27	83.68	29.02
1995	15.58	12.41	15.05	27.69	47.51	16.11	13.84	13.09	12.32	12.66	32.18	30.80
1996	17.66	13.41	13.49	17.36	16.84	15.39	13.18	12.37	11.67	11.89	12.44	19.03
1997	12.98	10.73	11.54	49.08	34.04	14.27	12.75	12.08	11.44	29.79	72.57	60.48
1998	59.16	32.07	21.09	43.49	64.24	23.68	17.15	15.22	13.99	14.09	14.54	16.47
1999	14.42	12.37	13.63	16.83	23.96	15.07	13.69	13.13	12.46	12.69	22.56	51.46
2000	19.11	13.09	13.31	12.50	12.69	12.11	12.36	12.20	11.67	11.92	17.59	25.63
2001	17.83	13.54	12.58	32.86	30.76	14.15	12.73	12.11	11.45	11.66	25.34	20.52
2002	14.61	11.70	11.89	45.14	56.92	14.95	13.09	12.38	11.70	11.93	25.07	24.05
2003	16.69	11.75	12.11	17.41	58.91	17.54	13.58	12.62	11.81	12.04	30.01	27.86
2004	15.85	12.07	12.31	16.39	21.00	13.02	12.13	11.67	11.09	11.38	48.58	23.91
2005	14.14	11.22	11.75	11.19	18.72	18.44	13.01	11.75	10.92	11.07	14.65	15.85
2006	12.11	10.44	10.94	19.10	39.18	13.65	11.72	11.02	10.41	10.61	65.94	41.84
2007	40.88	12.97	12.42	15.56	25.18	18.89	13.27	12.20	11.31	11.52	20.59	16.70
2008	14.58	11.97	11.76	26.01	17.44	12.07	11.43	11.07	10.52	10.97	16.96	13.10
2009	11.24	9.80	10.47	10.20	15.57	11.60	10.38	10.08	9.62	9.92	17.55	16.15
2010	12.19	10.02	16.01	39.56	26.37	12.94	10.97	10.30	9.71	9.88	11.38	12.04

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **4ED** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	38.54	22.37	19.42	23.65	29.48	25.48	18.85	17.34	16.37	16.14	20.00	29.31
1992	21.09	16.13	16.87	11.42	54.51	25.04	19.39	17.40	16.19	15.38	31.22	105.92
1993	97.49	87.37	33.03	24.31	28.93	22.96	19.19	17.43	16.23	16.47	18.27	41.28
1994	23.23	17.39	17.06	16.18	41.42	23.70	18.31	16.90	16.14	16.45	203.81	125.51
1995	32.37	20.58	22.57	35.74	73.92	27.15	20.26	17.95	16.31	14.71	34.59	64.60
1996	31.64	21.25	19.08	20.62	16.32	19.21	17.19	16.50	15.61	16.02	18.31	33.20
1997	19.97	15.56	16.29	60.86	82.19	25.33	19.67	17.50	16.15	19.59	210.73	394.43
1998	427.47	163.90	58.49	166.90	246.43	60.07	30.25	21.89	18.08	17.62	22.73	22.09
1999	18.18	15.43	16.78	18.20	27.09	20.36	17.79	16.93	16.16	16.63	22.29	127.83
2000	38.54	21.84	19.24	16.94	16.49	16.45	16.52	16.42	15.83	16.16	16.51	33.48
2001	18.74	21.00	16.40	25.31	46.30	21.22	17.92	16.94	15.94	16.13	31.46	42.62
2002	26.78	19.68	17.70	37.85	169.50	29.67	21.39	17.91	16.28	15.34	34.48	86.81
2003	42.04	21.89	18.93	11.88	101.42	36.51	22.10	17.37	16.66	13.33	54.90	120.76
2004	44.61	23.39	19.91	18.51	28.53	18.73	16.89	16.29	15.52	15.85	135.39	103.60
2005	30.56	20.70	18.60	16.21	1.49	31.36	17.83	16.35	15.15	15.74	22.92	24.68
2006	17.55	15.18	15.86	27.45	46.04	22.34	18.09	16.47	15.44	15.15	187.64	153.97
2007	187.86	28.39	21.54	16.05	34.41	25.53	19.14	16.20	16.59	12.85	18.44	18.90
2008	18.15	16.19	15.96	22.03	27.80	17.96	16.26	15.74	15.07	13.66	19.44	18.61
2009	15.99	14.05	15.32	14.35	14.74	15.29	15.26	15.08	14.58	14.94	14.94	21.12
2010	17.94	15.77	27.77	85.96	38.02	24.05	18.30	16.26	14.93	15.01	18.11	20.17

4FA & 4FB

Sub-basin: **4FA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	41.10	14.48	17.23	48.63	158.93	39.31	15.05	12.62	11.17	22.47	52.60	75.35
1992	29.95	13.20	11.72	23.95	69.36	25.01	13.57	11.89	11.11	14.04	108.19	269.38
1993	146.10	111.75	22.39	38.67	130.55	23.53	14.46	12.42	11.44	12.77	73.46	137.70
1994	23.52	13.01	12.49	39.72	68.20	18.27	13.86	12.22	11.54	50.69	453.18	171.81
1995	26.62	14.71	23.02	151.03	189.44	20.91	14.96	13.67	12.18	30.67	114.04	123.46
1996	45.48	17.79	17.95	22.43	25.37	31.63	15.93	12.86	11.39	12.78	53.25	52.49
1997	14.68	10.70	12.60	133.79	184.35	17.67	13.40	12.18	11.24	131.79	417.89	299.04
1998	338.28	100.23	47.12	119.91	230.52	38.72	18.89	15.65	13.69	13.75	59.15	27.87
1999	17.57	12.46	25.93	44.56	54.01	16.57	13.93	13.04	12.25	13.24	91.38	229.93
2000	37.05	14.54	13.26	15.80	13.11	12.14	12.41	12.34	11.75	12.15	70.62	90.94
2001	33.18	19.47	14.68	100.71	66.58	17.06	13.26	12.25	11.17	12.08	113.29	67.40
2002	26.44	13.72	31.37	217.07	240.48	18.78	13.90	12.65	12.00	25.83	147.34	101.59
2003	37.92	13.43	14.72	104.16	178.25	33.13	15.34	13.36	12.18	31.75	184.22	109.80
2004	50.19	20.61	14.89	67.63	67.70	15.70	13.23	12.33	11.65	28.25	267.64	160.81
2005	24.28	14.53	13.16	16.70	39.82	41.88	15.23	13.08	11.81	14.59	74.07	32.37
2006	15.56	12.05	14.25	63.33	106.02	17.27	12.76	11.92	11.39	28.58	292.51	160.26
2007	169.85	18.95	16.55	42.37	101.14	24.02	14.77	13.26	11.94	22.19	84.02	42.16
2008	41.28	17.02	15.95	63.71	34.67	13.90	12.19	11.60	10.83	26.05	53.04	17.38
2009	18.10	13.94	11.30	17.27	39.59	15.38	11.33	10.79	9.80	44.57	118.15	54.38
2010	24.52	13.95	41.99	100.44	65.03	15.73	12.34	11.77	10.24	12.57	51.56	25.52

Sub-basin: **4FB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	23.77	8.46	4.67	21.35	77.19	24.91	8.11	4.80	4.17	2.34	11.10	34.59
1992	17.31	7.46	4.53	0.00	26.40	14.43	6.56	4.50	3.91	2.42	55.07	198.34
1993	84.39	70.66	14.96	7.07	56.97	15.10	6.92	4.52	4.01	3.21	19.04	101.06
1994	16.38	6.12	4.31	0.00	33.47	12.51	5.54	4.26	4.03	5.61	415.06	131.21
1995	18.94	7.08	6.52	81.88	137.31	14.86	6.41	4.89	4.22	0.00	58.68	77.18
1996	23.60	11.50	4.75	8.47	3.20	9.13	5.35	4.44	3.84	3.98	3.74	37.94
1997	8.97	4.27	3.49	49.35	154.01	13.37	6.66	4.99	4.32	37.60	367.25	263.44
1998	232.49	58.75	20.16	65.02	120.77	21.13	9.49	5.38	4.31	4.07	19.88	17.31
1999	8.08	4.49	2.28	10.10	29.09	10.06	5.09	4.21	3.98	4.13	40.26	173.44
2000	24.96	7.77	4.92	4.13	3.86	4.31	4.22	4.07	3.92	4.08	19.00	70.72
2001	12.54	12.80	3.79	37.40	44.11	10.72	5.48	4.37	3.93	3.95	48.11	46.22
2002	16.07	7.74	5.01	109.59	229.81	16.75	7.20	4.93	4.33	0.00	73.48	61.57
2003	23.59	7.47	4.42	27.08	121.71	24.17	8.12	4.14	4.50	0.00	103.67	75.42
2004	26.25	11.02	5.74	23.95	37.71	9.62	4.97	4.16	3.91	0.00	201.01	97.09
2005	15.35	7.27	4.85	3.16	0.00	28.52	8.10	4.81	3.68	3.31	24.07	24.41
2006	8.07	4.19	4.03	21.39	67.48	12.51	5.64	4.13	3.60	0.55	232.64	85.70
2007	98.78	13.57	6.24	0.46	48.41	14.75	6.56	3.77	4.63	0.00	16.79	21.80
2008	20.05	11.61	4.68	29.81	26.77	8.41	4.52	4.06	3.70	1.33	10.88	10.99
2009	5.16	4.36	3.58	1.95	7.25	8.62	4.72	3.83	3.63	0.00	90.14	37.91
2010	15.12	6.23	3.44	59.11	32.36	11.07	5.08	3.91	3.61	3.22	9.15	15.70

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

4GA

Sub-basin: **4GA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	21.48	11.61	8.75	9.96	28.48	23.09	11.67	8.69	7.51	5.77	5.12	8.82
1992	9.27	6.78	7.05	0.00	9.88	9.75	7.55	7.07	6.64	5.82	11.68	129.33
1993	76.31	52.66	18.79	8.30	15.98	13.77	9.64	7.95	7.19	6.54	0.01	44.61
1994	16.24	9.24	7.97	0.00	14.91	9.74	7.31	6.91	6.68	0.00	502.66	136.51
1995	26.25	11.97	9.40	66.41	153.67	26.69	12.96	9.66	8.02	2.80	24.12	56.40
1996	22.47	13.30	8.75	9.39	5.40	10.33	8.07	7.55	6.97	7.17	0.00	15.34
1997	8.81	6.83	7.11	8.39	118.91	20.54	11.71	9.10	7.88	0.00	524.07	480.76
1998	204.71	48.43	22.27	22.06	64.29	22.46	13.52	9.81	8.32	8.07	5.61	9.92
1999	8.12	7.04	5.92	4.44	10.65	8.79	7.76	7.52	7.22	7.45	14.17	124.88
2000	26.11	11.97	9.70	8.24	7.71	7.72	7.69	7.52	7.15	7.44	0.76	40.41
2001	13.48	14.31	8.18	0.63	27.04	11.89	9.01	8.07	7.38	7.34	7.26	28.48
2002	15.85	10.36	7.66	32.48	192.23	25.13	12.88	9.48	8.13	3.56	34.69	43.96
2003	24.24	11.50	9.05	3.33	87.42	26.91	13.73	9.28	8.44	1.77	29.76	47.77
2004	19.98	12.25	9.55	1.87	20.14	10.78	8.46	7.86	7.25	3.22	100.93	79.12
2005	18.77	10.80	9.25	7.50	0.00	20.73	8.57	7.68	6.92	6.69	3.91	12.23
2006	7.92	6.48	7.42	3.87	38.22	14.44	9.55	8.07	7.07	5.20	187.32	100.11
2007	69.10	18.79	11.69	2.13	16.31	12.57	9.33	7.45	7.87	3.52	9.05	8.60
2008	8.45	8.91	7.25	6.72	20.48	10.78	8.27	7.64	7.05	4.97	8.04	9.02
2009	7.20	6.65	6.87	5.16	7.86	8.02	7.23	6.98	6.64	1.49	67.42	40.80
2010	19.97	11.22	5.46	42.53	34.00	15.01	9.73	8.07	7.25	6.82	5.60	11.27

6. Ewaso Ngiro Catchment Area (ENCA)**5AA & 5AB**

Sub-basin: **5AA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.86	11.65	0.64	3.57	1.63	5.20	8.95	21.85	18.05	2.96	1.51	1.03
1992	0.73	0.58	0.62	1.22	7.92	1.93	6.85	15.72	15.66	10.59	5.68	5.04
1993	7.94	15.99	3.03	0.98	2.02	5.50	5.37	4.53	2.50	1.13	0.64	0.62
1994	0.59	0.55	0.58	0.63	13.39	6.89	11.65	13.62	4.27	1.16	1.71	2.87
1995	0.81	0.55	1.27	0.90	4.57	1.61	5.97	4.11	6.16	4.36	17.78	3.99
1996	1.19	0.62	0.61	0.57	0.58	14.78	17.76	14.90	16.88	2.88	1.24	1.06
1997	0.64	0.53	0.57	18.97	25.51	3.29	11.97	10.27	2.72	2.37	22.81	25.36
1998	39.48	16.03	4.00	1.64	38.35	12.05	11.84	12.51	9.77	14.28	5.87	2.37
1999	0.83	0.60	0.99	2.41	2.99	0.88	4.54	7.47	4.75	1.22	1.08	1.28
2000	0.77	0.54	0.59	0.57	0.58	0.56	0.64	4.40	4.52	1.21	1.44	1.76
2001	1.35	0.97	0.72	13.50	13.44	8.32	9.22	21.06	17.94	2.81	7.24	4.90
2002	1.28	0.71	1.56	3.27	33.53	3.09	2.12	4.04	2.15	0.83	1.62	7.15
2003	11.95	1.23	0.73	4.83	41.51	7.55	6.58	30.97	11.68	2.58	2.13	4.39
2004	5.01	2.27	0.89	7.30	14.22	2.07	1.99	12.03	3.77	1.46	3.54	2.90
2005	0.98	0.56	0.58	0.56	12.76	13.42	8.92	9.55	20.38	4.66	2.02	1.02
2006	0.65	0.56	3.47	4.86	3.96	1.21	6.02	7.73	7.29	1.94	17.52	19.07
2007	16.14	3.72	1.57	1.77	4.15	22.87	28.78	29.10	39.02	7.94	3.28	1.23
2008	0.75	0.59	0.62	1.52	1.31	0.70	2.01	12.65	12.73	16.62	16.19	2.70
2009	0.93	0.61	0.63	0.59	2.01	2.59	0.72	0.59	0.56	0.57	1.77	1.86
2010	21.79	4.95	14.94	24.76	28.28	8.52	3.17	16.96	25.23	10.85	5.46	1.48

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: **5AB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	0.35	16.80	0.22	1.60	0.60	2.83	3.50	16.54	13.51	0.54	0.38	0.33
1992	0.25	0.19	0.19	0.49	5.01	0.71	3.70	6.59	5.10	4.01	2.03	2.41
1993	3.32	6.21	0.60	0.25	0.27	1.39	1.31	0.89	0.42	0.27	0.21	0.20
1994	0.19	0.17	0.18	0.19	4.63	2.82	3.84	4.22	0.98	0.31	0.36	1.08
1995	0.30	0.20	0.26	0.23	1.84	0.51	2.98	0.97	1.26	3.65	8.06	1.09
1996	0.35	0.20	0.19	0.18	0.18	4.92	7.48	5.77	5.81	0.55	0.27	0.23
1997	0.19	0.16	0.18	8.01	10.56	0.69	4.28	3.46	0.83	0.93	11.01	12.34
1998	19.24	4.60	0.75	0.35	19.87	4.68	4.51	4.23	3.03	5.39	2.01	0.69
1999	0.29	0.21	0.28	1.02	1.72	0.39	1.69	2.88	1.30	0.34	0.27	0.32
2000	0.27	0.20	0.20	0.19	0.20	0.19	0.20	0.30	0.75	0.31	0.24	0.26
2001	0.32	0.28	0.25	7.22	4.51	2.77	3.92	7.35	5.52	0.54	3.49	1.78
2002	0.36	0.23	0.33	2.97	15.58	0.73	0.58	1.99	0.62	0.29	0.43	4.33
2003	4.46	0.33	0.25	4.67	22.14	2.29	2.20	13.29	3.17	0.52	0.67	1.83
2004	3.76	0.96	0.38	4.20	6.05	0.58	0.50	6.17	0.96	0.38	1.64	0.88
2005	0.36	0.23	0.22	0.21	7.21	5.49	2.54	2.28	8.44	0.99	0.52	0.34
2006	0.24	0.21	1.68	3.37	2.08	0.51	1.86	3.75	2.76	0.55	9.33	7.83
2007	6.07	0.53	0.32	0.33	1.45	10.65	9.25	10.19	12.69	1.50	0.70	0.38
2008	0.30	0.24	0.24	0.65	0.81	0.36	0.66	5.11	5.68	7.15	4.42	0.54
2009	0.28	0.21	0.23	0.22	0.26	0.44	0.25	0.23	0.22	0.22	0.65	1.08
2010	8.73	1.30	5.71	7.05	9.44	2.13	0.83	7.65	8.32	4.24	2.08	0.48

5BA, 5BB, 5BC1, 5BD & 5BE

Sub-basin: **5BA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	1.67	17.01	0.37	0.44	11.45	5.04	0.93	12.67	11.30	0.38	0.37	0.43
1992	0.39	0.33	0.37	0.48	3.93	2.77	1.07	0.72	0.47	0.48	1.29	4.73
1993	4.04	3.57	0.88	0.53	1.99	1.50	0.54	0.36	0.34	0.35	0.34	0.41
1994	0.36	0.33	0.35	0.57	12.16	2.64	0.85	0.50	0.39	0.37	6.43	2.65
1995	0.85	0.57	1.18	0.81	7.22	1.49	0.65	0.40	0.35	1.59	8.27	2.15
1996	1.02	0.38	0.35	0.34	0.46	1.99	1.19	0.59	0.58	0.37	0.34	0.45
1997	0.35	0.30	0.33	1.69	7.94	1.02	0.84	0.49	0.34	4.80	19.10	8.83
1998	11.51	5.06	1.63	2.97	12.34	2.76	0.97	0.73	0.52	0.41	0.42	0.43
1999	0.37	0.33	0.36	0.37	3.71	0.86	0.38	0.36	0.35	0.36	0.36	1.73
2000	1.53	0.45	0.35	0.34	0.35	0.33	0.34	0.34	0.33	0.34	0.33	0.35
2001	0.53	0.63	0.40	4.00	7.92	0.95	0.51	0.45	0.34	0.34	1.15	2.03
2002	0.52	0.31	0.33	0.42	8.96	1.13	0.45	0.34	0.32	0.33	2.66	2.56
2003	3.27	0.45	0.33	1.81	14.56	4.00	0.64	0.86	0.96	0.67	4.67	4.76
2004	1.19	0.67	0.37	0.79	5.46	0.69	0.39	0.36	0.32	0.33	3.34	2.71
2005	0.78	0.32	0.33	0.34	3.22	5.27	0.74	0.42	0.79	0.73	1.06	0.71
2006	0.34	0.30	0.56	3.64	7.81	0.80	0.35	0.33	0.32	0.37	10.51	4.52
2007	4.61	0.69	0.39	1.17	3.82	5.15	1.17	1.81	1.58	0.97	2.18	0.80
2008	0.44	0.32	0.33	0.64	1.36	0.60	0.34	0.32	0.31	0.48	2.71	0.90
2009	0.36	0.29	0.31	0.30	0.48	0.46	0.32	0.31	0.30	0.33	1.71	1.12
2010	1.47	0.42	4.26	6.00	7.54	1.15	0.38	0.34	0.36	0.35	2.52	1.48

Sub-basin: **5BB** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	2.02	17.24	0.65	1.85	21.24	9.44	2.33	13.21	11.73	0.72	1.28	1.79
1992	1.02	0.60	0.64	2.76	11.89	4.50	3.72	3.38	2.36	3.54	5.59	8.87
1993	8.58	8.65	1.59	0.81	4.47	3.72	1.23	0.66	0.61	0.62	0.61	0.74
1994	0.66	0.58	0.61	2.06	23.85	5.98	2.36	1.39	1.19	1.40	13.77	4.72
1995	1.25	0.79	3.10	1.90	15.11	2.47	2.76	1.09	1.03	8.24	17.57	4.48
1996	1.71	0.65	0.61	0.59	0.76	6.06	3.53	2.18	4.51	1.40	1.01	2.47
1997	0.77	0.54	0.59	10.35	17.84	1.54	2.75	1.74	0.99	10.99	33.83	18.33
1998	27.24	9.77	2.51	5.37	30.87	7.44	3.03	2.49	1.58	1.84	2.57	1.69
1999	0.70	0.57	0.63	0.83	7.85	1.27	0.66	0.63	0.60	0.62	0.62	3.80
2000	1.85	0.65	0.61	0.59	0.61	0.59	0.60	0.60	0.58	0.60	0.58	0.92
2001	2.04	1.48	0.86	14.82	13.20	1.93	2.00	3.09	1.42	1.35	8.07	4.21
2002	0.84	0.56	0.59	3.73	24.19	1.61	0.97	0.76	0.60	0.60	8.11	6.26
2003	8.22	0.75	0.59	9.48	36.63	6.31	1.62	9.29	4.40	1.80	8.93	7.14
2004	2.77	1.98	0.78	5.55	13.62	1.26	0.73	0.79	0.68	0.69	9.75	5.14
2005	1.55	0.57	0.59	0.61	11.80	10.72	1.59	0.83	6.57	2.44	3.17	1.07
2006	0.60	0.54	3.76	8.85	13.71	1.49	0.65	0.60	0.70	1.10	25.24	9.05
2007	10.83	1.21	0.71	2.82	7.45	13.13	2.76	7.71	5.96	2.96	5.59	1.46
2008	0.81	0.58	0.59	3.77	3.71	0.99	0.62	0.58	0.75	5.85	8.23	1.36
2009	0.62	0.52	0.57	0.55	0.86	1.34	0.66	0.56	0.54	0.61	6.13	2.27
2010	9.27	1.17	11.28	12.74	14.04	2.59	0.89	3.23	9.23	5.96	11.17	2.38

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Sub-basin: SBC1														(Unit: m ³ /s)
Year	Month													
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
1991	6.11	16.96	1.64	2.95	38.64	17.47	5.86	15.30	13.82	2.01	2.33	7.04		
1992	3.01	1.52	1.59	5.02	24.30	7.15	4.96	6.83	5.98	5.85	13.00	22.69		
1993	19.20	24.50	4.02	1.80	4.39	5.52	2.93	2.06	1.67	1.57	1.63	6.73		
1994	2.26	1.45	1.51	1.48	50.40	10.55	4.99	4.31	2.71	1.54	23.63	10.14		
1995	2.53	1.50	2.33	2.61	35.57	4.70	4.39	2.32	2.09	19.55	53.39	9.97		
1996	3.71	1.48	1.47	1.42	1.39	8.80	13.61	9.36	14.87	2.78	1.56	1.79		
1997	1.50	1.30	1.42	25.63	49.32	4.17	7.84	5.83	2.84	19.76	82.96	65.93		
1998	93.42	22.10	5.15	5.97	80.82	16.67	10.25	11.60	8.56	7.69	6.09	3.80		
1999	1.74	1.43	1.67	3.51	16.39	2.85	2.43	3.39	2.55	1.66	1.59	8.10		
2000	5.23	1.70	1.51	1.45	1.50	1.44	1.49	1.57	1.98	1.61	1.57	1.78		
2001	2.67	3.60	1.82	22.78	26.36	4.54	4.37	8.91	7.96	2.20	14.20	11.91		
2002	2.13	1.37	1.56	7.77	66.86	4.99	2.44	2.93	1.87	1.49	11.53	12.62		
2003	18.51	1.90	1.46	24.31	111.54	14.20	3.70	23.37	13.66	2.44	16.88	19.29		
2004	11.69	6.53	1.93	10.86	31.81	3.26	2.15	6.47	3.40	1.77	16.21	10.94		
2005	2.74	1.38	1.47	1.60	28.95	27.61	5.58	3.41	15.61	6.62	4.12	2.61		
2006	1.51	1.36	6.38	16.45	23.53	3.11	2.47	3.11	4.43	2.15	53.39	28.15		
2007	36.18	3.00	1.63	2.75	11.92	29.26	14.61	24.95	23.19	6.59	8.27	3.06		
2008	1.85	1.44	1.50	2.60	6.10	2.06	1.79	4.18	5.68	12.38	24.02	3.95		
2009	1.59	1.33	1.46	1.40	1.54	2.01	1.54	1.45	1.42	1.43	12.27	7.04		
2010	19.57	2.72	24.30	28.43	34.78	7.45	2.31	6.75	18.38	7.33	14.52	5.62		

Sub-basin: SBD														(Unit: m ³ /s)
Year	Month													
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
1991	1.26	17.52	1.01	2.09	1.77	3.57	3.41	15.29	13.89	1.37	1.14	1.19		
1992	1.01	0.89	0.97	1.95	7.15	2.17	3.54	5.07	4.28	4.03	2.95	3.03		
1993	3.26	6.42	1.67	0.96	1.18	2.28	1.81	1.44	1.08	0.97	0.91	0.99		
1994	0.94	0.87	0.92	0.96	8.14	3.99	3.21	3.31	1.82	1.04	1.94	2.30		
1995	1.02	0.83	1.07	1.01	4.06	1.63	3.21	1.60	1.51	3.95	15.82	3.26		
1996	1.18	0.82	0.89	0.85	0.88	4.42	7.86	5.81	8.02	1.56	0.98	1.00		
1997	0.88	0.79	0.87	8.25	16.35	1.93	4.42	3.59	1.85	1.71	15.20	24.09		
1998	30.97	7.05	1.82	1.22	26.76	7.63	5.37	5.48	4.17	5.31	3.02	1.61		
1999	1.00	0.88	1.05	2.00	2.67	1.15	1.78	2.75	1.95	1.06	1.00	1.43		
2000	1.11	0.84	0.92	0.89	0.92	0.88	0.91	1.01	1.42	1.03	1.03	1.24		
2001	1.39	1.07	1.00	6.88	5.90	2.63	3.28	6.13	5.79	1.45	3.92	3.43		
2002	1.06	0.84	1.01	3.72	23.23	2.34	1.55	2.30	1.31	0.95	1.88	3.50		
2003	6.09	0.96	0.92	6.90	41.32	4.49	2.29	12.65	6.28	1.34	1.79	3.54		
2004	5.93	3.02	1.09	4.69	9.39	1.65	1.41	5.10	2.21	1.11	2.67	2.15		
2005	1.13	0.84	0.92	0.90	9.69	8.95	3.25	2.37	8.22	2.93	1.63	1.06		
2006	0.92	0.85	2.70	3.65	3.69	1.32	1.83	2.55	3.57	1.33	12.10	10.88		
2007	12.62	1.41	0.99	1.14	2.29	9.70	8.63	12.68	11.86	3.03	1.91	1.10		
2008	1.04	0.87	0.94	1.66	1.91	1.06	1.22	3.61	4.94	6.80	7.09	1.52		
2009	0.95	0.84	0.93	0.89	0.99	1.31	0.99	0.94	0.91	0.93	3.06	1.81		
2010	9.01	1.69	5.39	6.25	9.59	3.49	1.42	5.78	10.94	5.22	3.59	1.34		

Sub-basin: SBE														(Unit: m ³ /s)
Year	Month													
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
1991	11.27	17.55	0.51	3.99	61.13	10.83	1.26	12.83	11.47	5.49	21.50	28.91		
1992	4.25	0.70	0.47	15.94	23.28	5.67	1.07	0.76	0.65	0.68	34.11	46.71		
1993	40.93	34.17	2.42	3.08	19.73	3.65	0.84	0.49	0.42	0.43	21.38	22.98		
1994	2.08	0.48	0.43	5.75	40.86	5.82	1.24	0.77	0.60	4.39	66.82	22.90		
1995	2.22	1.15	9.52	22.10	50.87	2.30	0.95	0.52	0.47	32.58	38.24	22.93		
1996	4.04	0.76	0.47	0.63	2.48	15.95	5.04	2.63	3.34	0.76	10.03	11.48		
1997	0.97	0.37	0.39	33.60	33.50	1.86	2.09	1.30	0.59	40.69	90.84	57.87		
1998	96.15	23.49	5.08	19.08	47.65	9.81	4.88	6.15	4.55	2.04	11.90	4.59		
1999	0.78	0.42	1.80	8.55	15.91	1.32	0.49	0.49	0.44	0.41	10.39	25.79		
2000	6.11	1.29	0.43	1.93	1.80	0.51	0.39	0.38	0.37	0.37	8.73	14.21		
2001	12.87	6.57	1.09	21.93	15.68	1.33	0.71	0.87	0.65	0.42	32.18	11.81		
2002	1.26	0.38	0.42	18.84	49.73	2.17	0.60	0.47	0.37	0.70	44.58	25.38		
2003	10.38	0.66	0.38	35.36	52.68	6.21	0.79	2.43	2.91	12.79	41.63	22.27		
2004	4.84	2.66	0.70	9.13	22.13	1.21	0.53	0.90	0.58	1.46	47.30	16.35		
2005	1.46	0.40	0.35	1.04	18.76	12.63	1.39	0.67	3.63	2.36	9.90	5.41		
2006	0.61	0.32	6.80	22.98	21.34	1.46	0.45	0.43	0.67	5.16	59.43	32.62		
2007	31.15	1.70	0.48	5.91	14.62	13.03	3.36	4.33	5.84	4.97	21.48	4.84		
2008	2.72	1.11	0.36	4.87	5.16	0.80	0.35	0.41	0.46	11.95	27.50	3.08		
2009	0.54	0.38	0.29	0.27	2.25	1.21	0.32	0.27	0.26	5.83	28.33	13.75		
2010	9.30	0.71	33.91	32.94	29.44	2.81	0.63	0.61	0.71	0.69	17.64	7.17		

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

5DA

Sub-basin: **5DA** (Unit: m³/s)

Year	Month											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1991	26.28	16.41	4.26	26.79	54.01	11.13	3.15	9.08	8.54	0.56	27.46	76.29
1992	18.30	5.36	1.64	22.10	25.24	4.97	1.38	0.81	0.94	0.31	54.25	133.76
1993	105.26	88.16	9.74	16.32	37.45	4.72	1.66	0.80	0.27	0.11	40.30	56.17
1994	6.13	1.79	0.66	17.23	21.83	3.51	1.45	0.89	0.71	18.61	222.32	95.48
1995	10.83	3.40	6.41	67.73	58.79	5.40	2.21	0.93	0.46	29.70	75.56	69.53
1996	16.27	3.72	1.86	2.16	0.89	2.70	2.28	1.05	2.55	0.52	22.10	19.43
1997	2.50	0.75	0.25	92.34	113.16	9.36	3.81	1.66	0.90	63.80	229.43	237.59
1998	273.42	57.79	18.17	39.22	87.75	14.96	4.86	3.27	2.57	0.99	17.06	6.78
1999	1.92	0.70	10.71	14.62	14.79	2.04	0.23	0.66	0.39	0.06	33.77	75.00
2000	8.44	2.43	0.96	1.00	1.01	0.39	0.06	0.00	0.28	0.06	25.92	34.03
2001	14.70	5.06	1.33	40.77	13.63	2.22	0.74	0.61	1.01	0.25	41.21	21.90
2002	5.19	1.56	11.11	78.96	105.88	8.50	2.91	0.79	0.50	3.41	74.43	61.15
2003	20.47	3.15	1.01	60.29	75.80	7.90	2.64	0.00	2.69	17.83	96.65	46.90
2004	13.25	5.29	1.76	22.28	26.67	2.94	0.96	0.00	0.75	11.37	112.61	66.02
2005	7.04	2.11	0.72	0.18	11.83	9.61	1.99	0.88	0.00	0.99	19.44	6.56
2006	1.47	0.52	0.27	31.06	32.32	3.58	1.13	0.00	0.84	14.00	134.53	107.42
2007	95.21	8.42	3.19	20.75	29.46	2.81	1.90	2.14	1.11	0.90	48.18	13.98
2008	20.30	3.46	1.24	21.23	6.43	1.54	0.15	0.21	0.38	0.59	25.69	3.43
2009	1.14	0.96	0.58	1.31	9.63	1.74	0.56	0.10	0.00	21.92	66.84	30.60
2010	12.77	1.88	24.17	60.59	38.05	5.45	1.69	0.00	2.58	0.20	22.91	7.45

END

Annex-2

Regional Area Flood Curve of Major River Basins in NWMP 2030

Catchment Area	Basin Code	River Name	Return Period	Flood Curve
Lake Victoria North	LVN-2	Yala	10-year	$\log_{10} Q = -1.257 + 0.939 \log_{10} A$
			25-year	$\log_{10} Q = -1.227 + 0.945 \log_{10} A$
			50-year	$\log_{10} Q = -1.212 + 0.951 \log_{10} A$
			100-year	$\log_{10} Q = -1.202 + 0.957 \log_{10} A$
	LVN-3	Nzoia	10-year	$\log_{10} Q = -0.866 + 0.776 \log_{10} A$
			25-year	$\log_{10} Q = -0.780 + 0.767 \log_{10} A$
			50-year	$\log_{10} Q = -0.722 + 0.760 \log_{10} A$
			100-year	$\log_{10} Q = -0.669 + 0.752 \log_{10} A$
	LVN-6	Malikisi	10-year	$\log_{10} Q = -1.054 + 0.887 \log_{10} A$
			25-year	$\log_{10} Q = -0.974 + 0.883 \log_{10} A$
			50-year	$\log_{10} Q = -0.915 + 0.876 \log_{10} A$
			100-year	$\log_{10} Q = -0.859 + 0.868 \log_{10} A$
	LVN-7	Malaba	10-year	$\log_{10} Q = -1.233 + 0.998 \log_{10} A$
			25-year	$\log_{10} Q = -1.178 + 0.997 \log_{10} A$
			50-year	$\log_{10} Q = -1.146 + 0.997 \log_{10} A$
			100-year	$\log_{10} Q = -1.120 + 0.997 \log_{10} A$
Lake Victoria South	LVS-2	Asure	10-year	$\log_{10} Q = -1.492 + 1.125 \log_{10} A$
			25-year	$\log_{10} Q = -1.397 + 1.135 \log_{10} A$
			50-year	$\log_{10} Q = -1.341 + 1.142 \log_{10} A$
			100-year	$\log_{10} Q = -1.295 + 1.149 \log_{10} A$
	LVS-5	Mara	10-year	$\log_{10} Q = -1.083 + 0.934 \log_{10} A$
			25-year	$\log_{10} Q = -0.959 + 0.915 \log_{10} A$
			50-year	$\log_{10} Q = -0.874 + 0.899 \log_{10} A$
			100-year	$\log_{10} Q = -0.794 + 0.883 \log_{10} A$
	LVS-6	Migori	10-year	$\log_{10} Q = -0.954 + 0.879 \log_{10} A$
			25-year	$\log_{10} Q = -0.905 + 0.890 \log_{10} A$
			50-year	$\log_{10} Q = -0.875 + 0.898 \log_{10} A$
			100-year	$\log_{10} Q = -0.850 + 0.906 \log_{10} A$
	LVS-10	Kabondo Awach	10-year	$\log_{10} Q = -1.243 + 0.982 \log_{10} A$
			25-year	$\log_{10} Q = -1.184 + 0.982 \log_{10} A$
			50-year	$\log_{10} Q = -1.147 + 0.982 \log_{10} A$
			100-year	$\log_{10} Q = -1.114 + 0.982 \log_{10} A$
	LVS-11	Sondu	10-year	$\log_{10} Q = -1.153 + 0.967 \log_{10} A$
			25-year	$\log_{10} Q = -1.108 + 0.967 \log_{10} A$
			50-year	$\log_{10} Q = -1.083 + 0.967 \log_{10} A$
			100-year	$\log_{10} Q = -1.064 + 0.968 \log_{10} A$
	LVS-12	Nyando	10-year	$\log_{10} Q = -0.842 + 0.874 \log_{10} A$
			25-year	$\log_{10} Q = -0.782 + 0.872 \log_{10} A$
			50-year	$\log_{10} Q = -0.744 + 0.871 \log_{10} A$
			100-year	$\log_{10} Q = -0.710 + 0.869 \log_{10} A$
	LVS-13	Oroba	10-year	$\log_{10} Q = -1.100 + 0.998 \log_{10} A$
			25-year	$\log_{10} Q = -0.975 + 1.021 \log_{10} A$
			50-year	$\log_{10} Q = -0.878 + 1.030 \log_{10} A$
			100-year	$\log_{10} Q = -0.779 + 1.035 \log_{10} A$
LVS-14	Kibos	10-year	$\log_{10} Q = -0.012 + 0.551 \log_{10} A$	
		25-year	$\log_{10} Q = +0.061 + 0.555 \log_{10} A$	
		50-year	$\log_{10} Q = +0.115 + 0.555 \log_{10} A$	
		100-year	$\log_{10} Q = +0.168 + 0.553 \log_{10} A$	
LVS-16	Awach Seme	10-year	$\log_{10} Q = -0.012 + 0.551 \log_{10} A$	
		25-year	$\log_{10} Q = -0.061 + 0.555 \log_{10} A$	
		50-year	$\log_{10} Q = -0.115 + 0.555 \log_{10} A$	
		100-year	$\log_{10} Q = -0.168 + 0.553 \log_{10} A$	

Source: "National Water Master Plan 2030", Volume VII Data Book, conducted by JICA in 2013 (arranged by WG)

Catchment Area	Basin Code	River Name	Return Period	Flood Curve
Rift Valley	RV-2	Ewaso Ngiro(South)	10-year	$\log_{10} Q = -1.619 + 1.016 \log_{10} A$
			25-year	$\log_{10} Q = -1.469 + 0.996 \log_{10} A$
			50-year	$\log_{10} Q = -1.374 + 0.983 \log_{10} A$
			100-year	$\log_{10} Q = -1.290 + 0.969 \log_{10} A$
	RV-12	Kedong	10-year	$\log_{10} Q = -0.206 + 0.593 \log_{10} A$
			25-year	$\log_{10} Q = -0.234 + 0.636 \log_{10} A$
			50-year	$\log_{10} Q = -0.257 + 0.666 \log_{10} A$
			100-year	$\log_{10} Q = -0.282 + 0.693 \log_{10} A$
	RV-14	Lake Naivasha	10-year	$\log_{10} Q = -0.647 + 0.773 \log_{10} A$
			25-year	$\log_{10} Q = -0.585 + 0.781 \log_{10} A$
			50-year	$\log_{10} Q = -0.551 + 0.787 \log_{10} A$
			100-year	$\log_{10} Q = -0.524 + 0.794 \log_{10} A$
	RV-19	Lake Bogoria	10-year	$\log_{10} Q = -1.134 + 0.923 \log_{10} A$
			25-year	$\log_{10} Q = -0.937 + 0.873 \log_{10} A$
			50-year	$\log_{10} Q = -0.802 + 0.835 \log_{10} A$
			100-year	$\log_{10} Q = -0.676 + 0.798 \log_{10} A$
RV-20	Lake Baringo	10-year	$\log_{10} Q = -0.832 + 0.783 \log_{10} A$	
		25-year	$\log_{10} Q = -0.801 + 0.792 \log_{10} A$	
		50-year	$\log_{10} Q = -0.787 + 0.798 \log_{10} A$	
		100-year	$\log_{10} Q = -0.776 + 0.803 \log_{10} A$	
Athi	TA-1	Athi	10-year	$\log_{10} Q = -0.928 + 0.826 \log_{10} A$
			25-year	$\log_{10} Q = -0.902 + 0.895 \log_{10} A$
			50-year	$\log_{10} Q = -0.891 + 0.941 \log_{10} A$
			100-year	$\log_{10} Q = -0.885 + 0.983 \log_{10} A$
Tana	TN-1	Tana	10-year	$\log_{10} Q = -0.589 + 0.854 \log_{10} A$
			25-year	$\log_{10} Q = -0.539 + 0.873 \log_{10} A$
			50-year	$\log_{10} Q = -0.513 + 0.887 \log_{10} A$
			100-year	$\log_{10} Q = -0.493 + 0.901 \log_{10} A$
Ewaso Ngiro	EN-1	Ewaso Ngiro	10-year	$\log_{10} Q = -1.150 + 0.891 \log_{10} A$
			25-year	$\log_{10} Q = -0.957 + 0.889 \log_{10} A$
			50-year	$\log_{10} Q = -0.835 + 0.888 \log_{10} A$
			100-year	$\log_{10} Q = -0.728 + 0.888 \log_{10} A$

END

Brief Explanation of Draft Guideline on MHP

By
Working Group on MHP
Under

The Project for Establishment of Rural
Electrification Model using Renewable Energy



6th November 2014 - Kivi Milimani Hotel, Nairobi

Lighting up rural Kenya

Contents

Marks of the Guideline

Brief explanation

- Chapter 1 General
- Chapter 2 Identification of the project
- Chapter 3 Investigation & Planning
- Chapter 4 Basic Design
- Chapter 5 Economic and Financial Evaluation
- Chapter 6 Environmental and Social Considerations
- Chapter 7 Construction Supervision
- Chapter 8 Operation and Maintenance



Lighting up rural Kenya

2

Marks of the Guideline

Many guidelines and manuals on MHP exists in the world.
The marks of this Guideline may be the following two points.
Other parts are similar to other guidelines or manuals.

Adopting the result of NWMP 2030

Lack of hydrological data is the one of the key challenges for development of MHP.
“NWMP 2030: Natural Water Master Plan 2030” was formulated by 2013. In this master plan study, rainfall-runoff analysis was conducted in national wise, and monthly average naturalized discharge were provided for 204 sub-basins for 20 years period.
The data will be attached in this Guideline. It may contribute preliminary identification & planning.
However, measurement of discharge at the candidate site is essential for detailed planning.

Adopting the Empirical Equations of Japan

In general, there are many alternative approaches, such as location of intake weir, route of power canal and penstock, and location of powerhouse and tailrace, which can be taken in development at a potential site. A comparative study shall be carried out to identify the optimum development plan.
Empirical equations to estimated work quantities were presented in this Guideline for relative evaluation.
Using these equations, comparative study is easily carried out by temporary setting of some major dimensions.



Lighting up rural Kenya


3

Brief Explanation <Chapter 1>

General

1.1 Introduction

- ✓ The Government has given high priority on Rural Electrification.
- ✓ The total MHP potential in Kenya is estimated to be 3,000 MW.
- ✓ Development of MHP has been faced with challenges which included:



- ✓ Technical cooperation with JICA for Solar PV, Biogas, Wind & MHP. → This guideline was prepared.

- ✓ Capacity ranges of this Guideline:

10 kW – 1,000 kW

1.2 Necessity of MHP

- #### Advantages
- ✓ Contribute to practical use of natural water resources,
 - ✓ Safest, cleanest, & cheapest power source, and to its contribute to CO2 emission reduction,
 - ✓ Contribute to regional socio – economic activities.

- #### Disadvantages
- ✓ Potential sites depend on topography & hydrology rather than power demand,
 - ✓ Annual energy generations depend on river condition,
 - ✓ Same O&M activities required for any scale in principle.

Development of MHP system shall be studied carefully taking in to consideration the above.

1.3 Basic of Hydropower

Power output: $P = 9.8 \times \eta \times Q \times H_e$
Annual energy: $E = \xi \times P \times 24 \times 365 = 8,760 \times \xi \times P$
Required generator capacity: $P_d = 0.2N$




Lighting up rural Kenya

4


Attachment K-1-2

Identification of the Project

2.1 Work Flow of Identification



2.2 Potential Area of Hydropower




Lighting up rural Kenya

Identification of the Project

2.4 Estimation of Hydropower Potential

Dependable discharge is estimated as follows:

- ✓ Applying monthly average naturalized discharge by National Water Master Plan 2030,
- ✓ Estimate the discharge at the candidate site by ratio of catchment area,
- ✓ Prepare the flow duration curve,
- ✓ Defined dependable discharge within 90 to 95% of reliable discharge.



Sub-basins (Figure 2.4.3)



Amount of reserve was determined as the 95% value in accordance with WRMA guideline in 2010.

Lighting up rural Kenya

Identification of the Project

2.5 Estimation of Power Demand

Generator capacity can be approximated using the following equation based on the following assumptions:

Required Generator Capacity: $P_d = 20\%$ of Community Size (number of households).

User	Share per household or Number per village	Assumed Demand			
		Lighting	TV	Fan/Heater	Total
Domestic					
Type A	20% of total households	-	-	-	0
Type B	60% of total households	20 W x 2	-	-	40
Type C	20% of total households	20 W x 3	200 W x 1	-	260
Type D	1 per 100 households	40 W x 5	200 W x 1	200 W x 1	600
Public					
Primary School	1 per 100 households	40 W x 15	200 W x 1	200 W x 1	1,000
Community Hall	1 per 100 households	40 W x 15	-	200 W x 2	1,000
Dispensary	1 per village > 100 households	40 W x 5	-	200 W x 2	600
Streetlight	1 per 4 households	40 W x 1	-	-	40
Business					
Battery Charging Station	1 per 50 households	-	-	-	1,200
Posho Mill	1 per 200 households	-	-	-	5,000

2.6 Comparison between Power Demand & Hydropower Potential

$P_d < P_{50}$: Proceed to field investigation,
 $P_d > P_{50}$: Do not proceed with the candidate site.

Lighting up rural Kenya

Investigation & Planning

3.1 Site Investigation



Identification is depending on some assumption & application of limited data & information.

The assumptions in identification stage shall be reviewed through site investigation.

- ✓ The following survey points are explained:
 - Power demand forecasting,
 - Future management capability, and
 - Environmental & social impacts.

- ✓ The following measurement methods are explained:
 - Discharge measurement by float,
 - Discharge measurement by current meter,
 - Available head survey method by water hose,
 - Available head survey method by carpenter's level,
 - Available head survey method by pressure gauge,
 - Available head survey method by distance meter.

- ✓ The following observation points are explained:
 - Site topography, & site geology.



- Required Tools
- Water hose,
 - Water,
 - Timbers or leveling rods,
 - Measurement tape, and
 - Recording note and pen.

Lighting up rural Kenya

Investigation & Planning

3.2 Plan Formulation

- ✓ The longitudinal profile is created,
- ✓ Alternative sites of intake weir & powerhouse are defined to obtain high head within a short length.


- ✓ Alternative layouts are prepared by taking the following steps:

- 1) Define the intake weir site,
- 2) Define the penstock line,
- 3) Define the powerhouse site
- 4) Define the power canal alignment.


- ✓ The following dimensions are defined for each alternative layout:

- 1) Turbine center level,
- 2) Dimension of power canal,
- 3) Crest level of intake weir.

Sample of Alternative Layout (Figure 3.2.1)



Sample Procedure of Preparation of the Alternative Layout (Figure 3.2.2)



enya
9

Investigation & Planning


3.2 Plan Formulation

Example: Excavation volume of weir

- ✓ The project cost of each alternative is estimated as follows:

Estimation of Project Cost (Table 3.2.2)

Description	Estimation Method
I. Preparatory Works	
Access road	By (Assumed length) x (Unit price)
Land compensation	5% of Item II + III
Temporary facilities	20% of Item II + III
Environmental mitigation	3% of Item II.
II. Civil Works	By (Empirical equations) x (Unit prices)
III. Electrical Equipment	By empirical equation
IV. Distribution System	By (Assumed length) x (Unit price)
Sub-total 1 (Direct Cost)	Sum of Item I, II, III, and IV
V. Administration and Engineering Cost	15% of sub-total 1
VI. Physical Contingency	10% of sub-total 1
Sub-total 2 (Indirect Cost)	Sum of Item V and VI
Total	Sum of Sub-total 1 and Sub-total 2



- ✓ The project benefit of each alternative is estimated as follows:

$$\text{Benefit} = (\text{kW benefit}) + (\text{kWh benefit})$$

- ✓ The optimum layout is the layout shows higher B/C.

- ✓ When the optimum layout is selected, it is recommended to commence the application of water use permit.



10

Basic Design

4.1 Civil Structures


- ✓ Components of the civil structures are **various** depending on the topographic conditions at candidate site,
- ✓ Therefore, suitable components & layouts responding to the site condition need to be reflected in the design.

The following points are explained.

- ✓ Functions and requirements,
- ✓ Major types for MHP,
- ✓ Hydraulic design methods, such as:
 - Overflow discharge from weir,
 - Required length of de-silting basin,
 - Uniform flow depth of power canal,
 - Required volume of head pond,
 - Inner diameter & thickness of penstock,
 - Tail water level,
 - Head loss calculation, etc.

Structural design method are not included.

Typical Profile of MHP (Figure 4.1.1)



KI-2-3

11

Basic Design

4.2 Electrical Equipment

- ✓ Detailed characteristics are variable depending on manufactures,
- ✓ They are manufacturing by their individual technical know-how,
- ✓ Package of all electrical equipment exists called as “Water to Wire System”.

➔ The standard types & estimation method of basic technical features are explained.

Turbine

- ✓ Major types for MHP,
- ✓ Selection diagram,
- ✓ Specific speed,
- ✓ Revolving speed,
- ✓ Turbine efficiency.

Generator

- ✓ Major types for MHP,
- ✓ Output & rated capacity,
- ✓ Voltage & current,
- ✓ Excitation system.

Other Equipment & Systems

- ✓ Inlet valve,
- ✓ Power transmission,
- ✓ Governor,
- ✓ Transformers
- ✓ Main circuit,
- ✓ Integrated control panel,
- ✓ Cooling water supply system,
- ✓ Water drainage system,
- ✓ Crane, &
- ✓ Grounding wire.

4.3 Distribution Facilities

The following issues are explained:

Distribution Facilities

- ✓ Distribution methods,
- ✓ Distribution line planning,
- ✓ Electrical design,
- ✓ Mechanical design,
- ✓ Overhead distribution line equipment, and
- ✓ Service drops & watt-hour meter.



12

Attachment K-1-2

Brief Explanation <Chapter 5>

Economic & Financial Evaluation

5.1 Key Comparative Indicators

The following key indicators are explained.

- ✓ Present Value: PV
- ✓ Net Present Value: NPV = (B-C)
- ✓ Benefit-Cost Ratio: B/C
- ✓ Internal Rate of Return: IRR, and
- ✓ Unit Energy Cost: kWh cost.

5.3 Economic Evaluation

Evaluate the project from perspective of Public Interest and National Economy.

5.4 Financial Evaluation


Evaluate the project from perspective of Business Enterprise.

	Economic Evaluation	Financial Evaluation
Benefit	<ul style="list-style-type: none"> ✓ Grit connection, & Electricity consumption. Using consumer's Willingness to Pay (WTP).	<ul style="list-style-type: none"> ✓ Construction cost, ✓ Installation cost, ✓ O&M cost, & ✓ Replacement cost. Using Connection Fee & Electricity Tariff.
Cost	<ul style="list-style-type: none"> ✓ Grit connection, & Electricity consumption. Adjusting for market distortions. Assumption & empirical ratio.	<ul style="list-style-type: none"> ✓ Construction cost, ✓ Installation cost, ✓ O&M cost, & ✓ Replacement cost. As estimated. Assumption & empirical ratio.

Same

5.2 Estimation of Project Cost

General Components and Estimation Method of MHP Project (Figure 5.2.1)



Brief Explanation <Chapter 6>

Environmental & Social Considerations

6.1 Environmental Management System

General environmental management system in Kenya are explained.

6.2 EIA Procedures and License System

- ✓ MHP project is subject to the EIA procedures.
- ✓ The following two steps are specified:
 - EIA "Project Report" (45 days in minimum)
 - EIA "Study Report" (90 days in minimum)
- ✓ The reports shall be prepared by Registered Lead Expert on EIA/EA.
- ✓ The process and required contents are explained.


6.3 Solid Waste Management

Soiled waste management in compliance with the act & regulations in Kenya are explained.

6.4 Individual Subject on MHP Project

- ✓ "Mosquito Emergence Control",
- ✓ "Wastewater Contamination Control", and
- ✓ "Water Quality Control" (at enclosing bunds and weirs).

Overview of EIA Process (Figure 6.2.1)



Explanation <Chapter 7>

Construction Supervision

7.1 Procurement

General procedures of procurement in compliance with the following act & regulations in Kenya are explained:

- ✓ Public procurement and disposal act 2005.
- ✓ Public procurement and disposal regulation 2006.

7.2 Construction Supervision

General work items by the Client are explained.

Overall Management	⇒ Internal management & external correspondence.
Schedule Control	⇒ Monitoring & adjustment of official schedule & actual progress.
Quality Control	⇒ Quality control of construction materials, methods, equipment, facilities, etc.
Document Control	⇒ Control & filing of correspondences, minutes of meetings, approved drawings, etc.
Payment Control	⇒ Checking the work performance & quantity calculation sheets, assuming the total budget.
Variation Order	⇒ Confirming the necessity & available of project budget, and issuing the variation order.
Safety & Health Control	⇒ Preparing the emergency communication network, monitoring the project activities, responding in case of emergency..

Details of inspection items & measurement methods are described in:

- 7.3 Civil Works
 - ✓ Major inspection items, &
 - ✓ Procedure of approval & confirmation.
- 7.4 Electrical Equipment
 - ✓ Measurement methods of efficiencies,
 - ✓ Major items of shop test & site test.
- 7.5 Distribution Facilities
 - ✓ Major inspection items.


Explanation <Chapter 8>

Operation & Maintenance

8.1 Establishment of Management Body

- ✓ O&M of a MHP station has to be executed by local residence.
- ✓ The management body shall be prepared simultaneously with the construction stage.

Example of Management Body (Figure 8.1.1)



8.3 Operation & Maintenance

Administrative Works	Technical Works						
<ul style="list-style-type: none"> ✓ General affairs, ✓ Med-term planning, ✓ Asset management, ✓ Complaint and request response, ✓ Customer support. 	<table border="1"> <thead> <tr> <th>Civil Structures</th> <th>Electrical Equipment</th> <th>Distribution Facilities</th> </tr> </thead> <tbody> <tr> <td> <ul style="list-style-type: none"> ✓ Gate operation, ✓ Water drainage operation, ✓ Water filling operation, ✓ Routine inspection. </td> <td> <ul style="list-style-type: none"> ✓ External inspection, ✓ Internal inspection, ✓ Emergency inspection, ✓ Storing spare parts list. </td> <td> <ul style="list-style-type: none"> ✓ Scheduled outage, ✓ Fault recovery, ✓ Regular measurement, ✓ Periodic patrol. </td> </tr> </tbody> </table>	Civil Structures	Electrical Equipment	Distribution Facilities	<ul style="list-style-type: none"> ✓ Gate operation, ✓ Water drainage operation, ✓ Water filling operation, ✓ Routine inspection. 	<ul style="list-style-type: none"> ✓ External inspection, ✓ Internal inspection, ✓ Emergency inspection, ✓ Storing spare parts list. 	<ul style="list-style-type: none"> ✓ Scheduled outage, ✓ Fault recovery, ✓ Regular measurement, ✓ Periodic patrol.
Civil Structures	Electrical Equipment	Distribution Facilities					
<ul style="list-style-type: none"> ✓ Gate operation, ✓ Water drainage operation, ✓ Water filling operation, ✓ Routine inspection. 	<ul style="list-style-type: none"> ✓ External inspection, ✓ Internal inspection, ✓ Emergency inspection, ✓ Storing spare parts list. 	<ul style="list-style-type: none"> ✓ Scheduled outage, ✓ Fault recovery, ✓ Regular measurement, ✓ Periodic patrol. 					

Operation & Maintenance

8.4 Assistance for Management Body

- ✓ Local residence might not have any experience or knowledge of electrical utility service.
⇒ Assistance for the organization & development of human resources capacities are **essential**.
- ✓ The assistance needs before and after the commencement of the power supply service.

Necessity **before** the Commencement

- ✓ Number of staff is limited...
- ✓ It is difficult to commit a time for training.
- ✓ Therefore, the training is necessary simultaneous with the construction stage.
- ✓ Assistance program with...

OJT

Lecture

Workshop

Necessity **after** the Commencement

- ✓ Initial troubles often occurs within first one year,
- ✓ Some contradictions among the rules are apparent,
- ✓ Operation manner of MHP varies due to rainy seasons & dry seasons & river flow.

Repeat training on Actual situation

Major Assistance Items

For Representative & Manager

- ✓ Establishment of management body & joint steering committee,
- ✓ Arrangements to obtain business license,
- ✓ Start-up of power generation.

For Administrative Staff

- ✓ Outline & function of power facilities,
- ✓ Lecture on electricity charge system,
- ✓ Development of office management manual,
- ✓ Guidance on work procedure.

For Technical Staff

- ✓ Outline & function of power facilities,
- ✓ Guidance on functions & structures of facilities,
- ✓ Preparation of O&M manual,
- ✓ Guidance on inspection, maintenance & repairing,
- ✓ Guidance on documentation of maintenance.



Thank you for your kind attention.



Simple Pre-Feasibility Study on Asurur MHP Scheme

February 2015



Ministry of Energy and Petroleum



Table of Contents

Table of Contents	i
List of Tables	ii
List of Figures	iii
List of Terms and Abbreviations	iv
List of Electrical Terminology.....	iv
CHAPTER 1 GENERAL.....	1
1.1 Background	1
1.2 Outline of the Study.....	1
1.3 Summary of the Study	2
1.4 Recommendations for Subsequent Stages.....	2
CHAPTER 2 SOCIAL CONDITION.....	3
2.1 Location of the Site	3
2.2 Protection and Conservation Area.....	4
2.3 Social and Economic Conditions.....	4
CHAPTER 3 POWER DEMAND FORECAST.....	6
3.1 Estimation of Total Power Demand	6
3.2 Estimation of Peak Power Demand.....	7
3.3 Estimation of Required Generator Output.....	8
CHAPTER 4 HYDROLOGICAL ANALYSIS.....	9
4.1 Available Data for the Analysis.....	9
4.2 Estimation of the Reliable Discharge	10
4.2.1 Estimation by WRMA Discharge Data.....	11
4.2.2 Estimation by KMD Rainfall Data.....	12
4.2.3 Estimation by Simulated Monthly Discharge Data in NWMP 2030	14
4.2.4 Comparison among Estimated Flow Duration Curves.....	15
4.3 Estimation of the Flood Discharge	17
4.3.1 Estimation by WRMA Daily Discharge Data	18
4.3.2 Estimation by Rational Formula	18
4.3.3 Estimation by Regional Area Flood Curve in NWMP 2030.....	21
4.3.4 Confirmation by Creager Envelope Curve.....	21
4.4 Design Discharge.....	23
4.4.1 Design Plant Discharge	23
4.4.2 Plant Factor	23
4.4.3 Design Flood Discharge.....	24
CHAPTER 5 PLAN FORMULATION.....	25
5.1 Preparation of Alternative Layouts.....	25
5.1.1 Position of Intake Weir and Powerhouse	25
5.1.2 Alternative Layouts for Comparison.....	25
5.1.3 Temporary Setting of Major Dimensions.....	26

5.1.4	Major Dimensions of Alternative Layouts.....	28
5.2	Estimation of Project Cost.....	28
5.2.1	Civil Works	29
5.2.2	Electrical Equipment.....	36
5.2.3	Distribution System.....	36
5.2.4	Preparatory Works	36
5.2.5	Project Cost of each Alternative Layout	37
5.3	Selection of Optimum Development Layout.....	37
5.3.1	Estimation of Project Benefit	38
5.3.2	Annualized Project Cost.....	39
5.3.3	Evaluation by Benefit – Cost Method	39
5.3.4	Evaluation by Generation Cost Method	39
5.3.5	Selection of Optimum Layout.....	40
CHAPTER 6 RECOMMENDATIONS FOR THE NEXT STAGE		41

List of Tables

Table 1.1.1	Summary of Comparison of Three (3) Alternative Layouts.....	2
Table 2.3.1	Interview Results to the Asurur Multipurpose Water Project Group	5
Table 3.1.1	Assumed Number of each User.....	6
Table 3.1.2	Assumed Power Demand in Asurur Area	7
Table 4.1.1	Collected Discharge and Rainfall Data around Asurur Site	9
Table 4.1.2	Discharge Measurements Recorded at Asurur Site	10
Table 4.2.1	Monthly Rainfall Data for Asurur Catchment Area (Kabujoi).....	13
Table 4.2.2	Estimated Monthly Average Discharge at Asurur Site based on KMD Rainfall Data.....	14
Table 4.2.3	Estimated Monthly Average Discharge at Asurur Site based on NWMP 2030 Data	15
Table 4.2.4	Observed and Estimated Monthly Discharge at Asurur Site	16
Table 4.3.1	Annual Maximum Discharges at Asurur Site.....	18
Table 4.3.2	Assumed Annual Maximum Daily Rainfall of Asurur Basin	19
Table 4.3.3	Probable Daily Rainfall of Asurur Basin	19
Table 4.3.4	Estimated Average Rainfall Intensity at Asurur Site	21
Table 4.3.5	Estimated Peak Flood Discharge at Asurur Site.....	21
Table 4.3.6	Flood Discharge by Regional Area Flood Curve presented in NWMP 2030	21
Table 4.3.7	Creager’s Coefficient for Hydropower Projects in Western Kenya.....	22
Table 5.1.1	Result of Water Level Calculation against Design Flood Discharge	26
Table 5.1.2	Trial Calculation of Flow Conditions for Power Canal.....	27
Table 5.1.3	Calculation of Intake Water Level	28
Table 5.1.4	Major Dimensions of Alternative Layouts	28
Table 5.2.1	Estimation of Project Cost.....	29
Table 5.2.2	Empirical Equations of Intake Weir	29
Table 5.2.3	Empirical Equations of Intake Structure	30
Table 5.2.4	Empirical Equations of De-silting Basin.....	30
Table 5.2.5	Empirical Equations of Power Canal	30
Table 5.2.6	Empirical Equations of Head Tank	31
Table 5.2.7	Empirical Equations of Spillway Canal	31
Table 5.2.8	Empirical Equations of Penstock	31
Table 5.2.9	Empirical Equations of Powerhouse	31
Table 5.2.10	Empirical Equations of Tailrace.....	32
Table 5.2.11	Applied Unit Prices for the Estimation	32
Table 5.2.12	Direct Cost of Civil Works of Layout A	33
Table 5.2.13	Direct Cost of Civil Works of Layout B	34

Table 5.2.14	Direct Cost of Civil Works of Layout C	35
Table 5.2.15	Direct Costs of Electrical Equipment.....	36
Table 5.2.16	Cost of Preparatory Works	37
Table 5.2.17	Estimation of Project Costs	37
Table 5.3.1	Effective Output and kW Benefit.....	38
Table 5.3.2	Annual Energy Generation and kWh Benefit.....	39
Table 5.3.3	Estimated Annualized Benefit.....	39
Table 5.3.4	Estimated Annualized Cost	39
Table 5.3.5	Benefit and Cost of each Alternative	39
Table 5.3.6	Generation Cost of each Alternative	40

List of Figures

Figure 2.1.1	General Location of the Proposed Asurur Site	3
Figure 2.1.2	Photos of the Asurur Area and Asurur Waterfall.....	3
Figure 3.2.1	Assumed Ratios of Power Demand of Each User.....	8
Figure 3.2.2	Assumed Daily Load Curve for Asurur MHP System.....	8
Figure 4.1.1	Location Map of Data Sources.....	9
Figure 4.2.1	Discharge Hydrograph at 1HA01	11
Figure 4.2.2	Discharge Hydrograph at 1HA02	12
Figure 4.2.3	Flow Duration Curve at Asurur Site based on WRMA Discharge Data.....	12
Figure 4.2.4	Flow Duration Curve at Asurur Site based on KMD Data	14
Figure 4.2.5	Flow Duration Curve at Asurur Site based on NWMP 2030 Data	15
Figure 4.2.6	Comparison between Observed Discharge and Flow Duration Curves.....	16
Figure 4.2.7	Location of Asurur MHP Site on Longitudinal Profile of Great Oroba River.....	17
Figure 4.3.1	Creager's Coefficient for Hydropower Projects in Western Kenya.....	22
Figure 4.4.1	Plant Factor of Asurur MHP	24
Figure 5.1.1	Alternative Head of Asurur Site.....	25
Figure 5.1.2	Alternative Layouts for Comparison.....	26

List of Annexes

Annex 1	Discharge Observation Sheets at Asurur Site
Annex 2	Cross Section Data for Water Level Calculation
Annex 3	Preliminary Drawings of Asurur MHP

Note: All tables, figures, and annexes are prepared by the Working Group otherwise specified.

List of Terms and Abbreviations

Abbreviation	Description
HPP	Hydro Power Project
JICA	Japan International Cooperation Agency
JET	JICA Expert Team
KMD	Kenya Meteorological Department
KSh.	Kenya Shilling
MHP	Micro Hydro Power
MoE&P	Ministry of Energy and Petroleum
NWMP 2030	National Water Master Plan 2030
PMF	Probable Maximum Flood
REA	Rural Electrification Authority
SHER	Similar Hydrological Elements Response
TV	Television
WG	Working Group
WRMA	Water Resources Management Authority

List of Electrical Terminology

Unit	Description
A (Ampere)	Unit of current
V (Volt)	Unit of voltage
kV (kilovolt)	1,000 volts
W (Watt)	Unit of electric power
kW (kilowatt)	1,000 watts
MW (Megawatt)	1,000 kW
Wh (Watt-hour)	Unit of energy
kWh (kilowatt-hour)	1,000 Wh
MWh (Megawatt-hour)	1,000 kWh

CHAPTER 1 GENERAL

1.1 Background

Asurur Micro Hydro Power (MHP) scheme was originally planned and proposed by a local self-help group known as “Asurur Multipurpose Water Project” (the Group). The local community formed the self-help group to improve their livelihood, and the Group was subsequently registered on 20th June 2012 in Nandi South District, Nandi County.

Rural Electrification Authority (REA) and JICA Expert Team (JET) identified Asurur MHP scheme during site visits and investigations to identify a MHP pilot project site under the “Project for Establishment of Rural Electrification Model Using Renewable Energy in the Republic of Kenya” (the Project) under implementation by REA, MOE&P and JET in cooperation with Japan International Cooperation Agency (JICA).

Asurur MHP scheme was initially selected as a pilot project in the Project, in July 2012. However, the pilot project was cancelled in November 2012 due to management issues that arose in the Project. As a result, the Project decided to conduct a simple pre-feasibility study of Asurur MHP scheme in October 2013, as one of four technical transfer activities, based on the same initial project budget allocation.

“The simple pre-feasibility study on Asurur MHP scheme” (the Study) was conducted within the Project activities. However, the assignment period and budget for the Study were constrained, and accordingly the contents of the study are not as exhaustive as common pre-feasibility studies due to the limitations.

1.2 Outline of the Study

The outline of the Study is summarized below.

(1) Scope of the Study

- ✓ Preliminary evaluation of the hydropower potential of Asurur site, and
- ✓ Preliminary formulation of the development plan for Asurur MHP scheme

(2) Study Period

The study period was between November 2013 and December 2014

The actual working period was limited to four months (131 days) corresponding to the assignment period of the JICA Expert as follows:

1 st to 5 th November 2013,	5 days
8 th January to 19 th February 2014,	43 days
2 nd July to 9 th August 2014, and	39 days
3 rd October to 15 th November 2014.	44 days

(3) Study Team

The Study was conducted by the MHP Working Group (WG) of the Project, comprised of the following members:

Ms. Judith Kimeu	Assistant Engineer - Renewable Energy Department, REA
Mr. Semekiah Ongong’ a	Assistant Engineer - Renewable Energy Department, REA
Mr. Anthony Wanjara	Technician - Renewable Energy Department, REA
Mr. Yoshiaki Samejima	JICA Expert for Micro Hydropower Generation

1.3 Summary of the Study

(1) Evaluation of Power Demand

Power demand in the community was unknown, as the community was completely unelectrified. Power demand was therefore forecasted based on the results of interviews and assumptions made by WG as follows:

Peak Power Demand: 190 kWh → Required Generation Output: 250 kW

(2) Evaluation of Hydropower Potential

Reliable discharge and probable flood discharge were estimated using the following four (4) sets of data: i) WRMA discharge data, ii) KMD rainfall data, iii) Simulated discharge data by NWMP 2030, and iv) observed discharge data by WG.

As a result, the design plant discharges and design flood discharge were defined as follows:

Minimum Design Plant Discharge: 0.1 m³/s ($Q_{90\%} - Q_{95\%}$)
 Maximum Design Plant Discharge: 0.7 m³/s ($Q_{50\%} - Q_{95\%}$)
 Design Flood Discharge: 42.0 m³/s (50-year probable discharge)

(3) Plan Formulation

Three (3) alternative sites of intake weir and one (1) site of powerhouse were identified from the topographic map with a scale of 1: 500 of the area surrounding Asurur site. Three (3) alternative layouts, Layout A, Layout B and Layout C, were prepared, and a comparative study of these alternatives carried out as summarized below. As a result, Layout A was selected as the optimum layout.

Table 1.1.1 Summary of Comparison of Three (3) Alternative Layouts

Item	Unit	Layout A	Layout B	Layout C
Maximum Plant Discharge	m ³ /s	0.7	0.7	0.7
Effective Head	m	31.2	25.1	16.3
Maximum Output	kW	154.1	124.0	80.5
Project Cost	KSh.	140,511,000	134,607,000	125,105,000
Annualized Project Cost (C)	KSh./year	15,456,210	14,806,770	13,761,550
Annualized Project Benefit (B)	KSh./year	28,970,442	23,311,698	15,133,850
B / C	-	1.87	1.57	1.10
B – C	KSh./year	13,514,232	8,504,928	1,372,300
Generation Cost	KSh./kWh	15.79	18.80	26.92

1.4 Recommendations for Subsequent Stages

The Study results showed that the estimated power generation was smaller than the forecasted power demand. It was therefore recommended that the following issues be considered and implemented in subsequent stages:

1. Monitoring of the water level at the site continuously in order to improve the accuracy of hydrological analysis by accumulating discharge data,
2. Comparison of alternative heights to determine optimum height of intake weir in order to secure minimum power generation to meet power demand,
3. Obtain quotations for electrical equipment from manufacturers in order to increase the accuracy of estimation of project development costs, and
4. Study other power sources such as hybridization with diesel generator or grid connection in order to provide sufficient electricity to meet the forecasted power demand.


CHAPTER 2 SOCIAL CONDITION

2.1 Location of the Site

The proposed Asurur MHP scheme is located in Nandi county, Aldai constituency, Nandi South district, Aldai division, earlier a part of Rift Valley Province. The project falls within two locations namely Kibwareng and Kapkolei.

The basic concept of Asurur MHP scheme is to develop hydropower potential at Asurur waterfall.

General location of the site, overview of Asurur area and Asurur waterfall are shown below.



Source: "A New County Map in Kenya" published by Tourist Maps Kenya Limited (Presented by WG)

Figure 2.1.1 General Location of the Proposed Asurur Site



Overview of Asurur Area



Asurur Waterfall

Taken by JET and WG

Figure 2.1.2 Photos of the Asurur Area and Asurur Waterfall

(1) Nandi County

Nandi County was formed in 2013 in accordance with the recentralization. The county's major area is covered by the Nandi Hills. Its capital, Kapsabet, is the largest town in the county.

The county has high agricultural potential and human densities. The county's population is some 750,000 according to a 2009 census. Although there are a number of tribal communities in Nandi, the majority of the people belong to the native tribe called Nandi. The county's major business is agriculture, sports and tourism. The major crops are tea, maize, coffee, and sugarcane.

The household electrification rate of Nandi County was 6.4% while the overall national household electrification rate was 22.7% for household numbers as of 2009 based on the National Census 2011. Nandi County ranked twenty-nine (29) out of forty-seven (47) counties in decreasing order according to electrification rate.

(2) Accessibility to the Site

The proposed Asurur site is located between Kapsabet and Kisumu. The site is accessible by car about 1 to 1.5 hours from both town centers.

Asurur Waterfall is 200 m from the Kimaren – Kobujoi Road. There is no access road from the existing culvert bridge on the road to the waterfall, but the site is accessible by foot via left bank of the river. The area is currently under cultivation by the local residences.

(3) Electrification Status surrounding the Site

Kibwareng and Kapkolei locations where the load center for the proposed Asurur MHP scheme targeted are not electrified. But, grid is exists approximately 8 km away on the south, 2.5 km on the north and 4 km to the east.

2.2 Protection and Conservation Area

One protected area called as “South Nandi Forest Reserve” exists a mid-elevation lying west of Kapsabet town and south of the main Kipsegak – Serem Road, and a part of the catchment area is including in the forest reserve.

The forest reserve was specified in 1936 as a trust forest covering 20,200 ha. At most 13,000 ha is closed-canopy forest, 2,200 ha have been excised for settlement, 1,400 ha planted with exotic tree species, 340 ha planted with tea, and the rest being scrub, grassland or cultivation.

The forest reserve has rich rainfall of 1,600 – 1,900 mm/year in average depending on altitude. Major drains from the forest are Kimondi and Sirua rivers, which merge to form the Yala River flowing into Lake Victoria.

Northern part of some 720 ha of the catchment area of Asurur MHP scheme is situated in the forest reserve area. The area is about 3.3% of the forest reserve. Asurur MHP facilities are located about 5 km south side from boundary of the forest reserve. Therefore, any direct influences by the development are not conceivable. It is preferable for the MHP scheme in terms of watershed protection to maintain river discharge.

2.3 Social and Economic Conditions

(1) Local Self-help Group: Asurur Multipurpose Water Project

The inhabitants and villages surrounding the proposed Asurur MHP site unite together to organize a self-help group named as “Asurur Multipurpose Water Project (the Group)” for the purpose of improving livelihood and registered to district office. They started it in 2011 and registered after they heard the pilot project to ensure the realization.

It is the most important social factor for the development of Asurur MHP scheme because the Group will operate and maintain the power generation system and manage the power provision service if Asurur MHP scheme had been developed.

(2) Interview Result to the Asurur Multipurpose Water Project

JET and WG conducted interview survey twice to the Group at the proposed Asurur site. The interview results are summarized in the table below.

Table 2.3.1 Interview Results to the Asurur Multipurpose Water Project Group

Item	Description
Member Community	The Group covers at least 10 communities located in two sub-locations in Nandi South district: <ul style="list-style-type: none"> - Samitui sub-location in Kibwareng location, and - Kimolwo sub-location in Kapkolei location
Member Ethnic Group	The Group is composed only by Nandi (a sub ethnic group of Kalenjin).
Number of Household	About 440 households
Major Occupation	Production of various crops (maize, beans and root crops), Production of milk
Average Annual Income	About Ksh 320,000 as of 2011 (Average of the interviewed 7 households)
Present Energy Source	2 of 7 households: Solar panels (for television and radio for one of them and lighting and mobile phone charging for the other), and 5 of 7 households: Kerosene lamp and firewood (for lighting). They are spending about 840 KSh./month in average for energy (lighting and phone charging).
Expecting Electric Use	The electricity would be used for water pumping in a nearby spring, and industries like milk cooling, coffee processing and juice extraction from passion fruits, battery and phone charging, etc.
Expectation for Electrification	They state that the urgent need for this area is electricity. Until now, there is no any clear plan from Government to supply electricity to this area. They wish to raise living standard by selling more agricultural products (kept in the refrigerator) and reduce time wastage when people travel for energy.

CHAPTER 3 POWER DEMAND FORECAST

3.1 Estimation of Total Power Demand

Power demand in the communities is unknown before electrification. Therefore, power demand was forecasted based on the interview result and the assumptions as explained hereinafter.

(1) Assumption of User

Users in the project area are assumed in three (3) categories as follows:

i) Domestic User

Four (4) types of domestic uses were assumed depending on the difference of household income. Unit power demands were assumed to be lighting, TV and fan or heater. Number of each electric goods is various.

ii) Public User

Primary and secondary schools, dispensaries, trading centers and streetlights were considered as public power users. Unit power demands were also assumed to be lighting, TV and fan or heater except trading centers. Power demand of trading center is variable depending on size and kind of each trading center, so unit demand was assumed as lump sum.

iii) Business User

Posho mill, dairy husbandry and restaurant were considered as business power users. Unit power demands may be variable depending on each owner, so unit demand was assumed as lump sum.

Number of each user was assumed based on the result of interview and assumption by WG as tabulated below.

Table 3.1.1 Assumed Number of each User

User	Number	Remarks
Domestic		
Type A	340	Assumed by WG (20% of total households of 1,700)
Type B	1,000	Assumed by WG (60% of total households of 1,700)
Type C	340	Assumed by WG (20% of total households of 1,700)
Type D	20	Assumed by WG (1 per 100 households)
Public		
School	16	Interview result (11 primary schools and 5 secondary schools)
Dispensary	4	Assumed by WG (1 per 500 households)
Streetlight	170	Assumed by WG (1 per 10 households)
Trading Center	10	Interview result (6 shops per center in estimated average)
Business		
Posho Mill	19	Interview result
Dairy Husbandry	4	Assumed by WG (1 per 500 households)
Restaurant	4	Assumed by WG (1 per 500 households)

(2) Estimation of Power Demand

Based on the above assumptions, the power demand of the project area is calculated to be 305 kW as shown below.

Table 3.1.2 Assumed Power Demand in Asurur Area

User	Assumed Unit Demand				Quantity (nos.)	Power Demand
	Lighting	TV	Fan/Heater	Total		
Domestic User						
Type A	-	-	-	0 W	340	0 W
Type B	40 W (20 W x 2)	-	-	40 W	1,000	40,000 W
Type C	60 W (20 W x 3)	200 W (200 W x 1)	-	260 W	340	88,400 W
Type D	200 W (40 W x 5)	200 W (200 W x 1)	200 W (200 W x 1)	600 W	20	12,000 W
Public User						
School	600 W 40 W x 15	200 W (200 W x 1)	200 W (200 W x 1)	1,000 W	16	16,000 W
Dispensary	200 W (40 W x 5)	-	400 W (200 W x 2)	600 W	4	2,400 W
Streetlight	40 W (40 W x 1)	-	-	40 W	170	6,800 W
Trading Center		(L.S.)		2,000 W	10	20,000 W
Business User						
Posho Mill		(L.S.)		5,000 W	19	95,000 W
Dairy Husbandry		(L.S.)		5,000 W	4	20,000 W
Restaurant		(L.S.)		1,000 W	4	4,000 W
Total						304,600 W = 305 kW

3.2 Estimation of Peak Power Demand

Power demand varies hourly, daily and seasonally depending on each user. It was assumed that power demand of weekday is larger than that of weekend, and power demand of weekday was assumed as follows:

i) Domestic User

Utilizing time was assumed to concentrate in the morning and in the evening.

ii) Public User

Utilizing time was assumed from the morning to evening, except streetlight. Utilizing time of streetlight was assumed from the evening to the early morning.

iii) Business User

Utilizing time was assumed from each business such as daytime for posho mill, daytime to nighttime for restaurant, and 24 hours for dairy husbandry (refrigerator).

Assumed ratios of the power demand of each user in each hour are shown in Figure 3.2.1. Daily power demand curve creates by multiple of these ratios and power demand estimated in Section 3.1 as shown in Figure 3.2.2. The peak power demand was calculated to be 189 kWh.



Figure 3.2.1 Assumed Ratios of Power Demand of Each User




Figure 3.2.2 Assumed Daily Load Curve for Asurur MHP System

3.3 Estimation of Required Generator Output

The required generator output of Asurur MHP station was estimated to be 250 kW by the following formula:

$$\begin{aligned}
 P_r &= P_d + w_1 + w_2 \\
 &= P_d \times (1 + 0.2 + 0.1) = 1.3P_d \\
 &= 1.3 \times 190 = 247 \text{ kW} = 250 \text{ kW}
 \end{aligned}$$

Where, P_r : required generator output (kW)
 P_d : power demand (kW)
 w_1 : losses of distribution line, assumed to be 20% of P_d
 w_2 : reserved power, assumed to be 10% of P_d

CHAPTER 4 HYDROLOGICAL ANALYSIS

4.1 Available Data for the Analysis

The hydrological analysis was carried out using the following three (3) sets of data:

- Collected discharge data from WRMA, and rainfall data from KMD,
- Observed discharge data measured by the Working Group, and
- Simulated discharge data and regional area – flood curve by NWMP 2030.

The location of the planned Asurur site, related gauging stations, and related sub - basin are shown below.




Figure 4.1.1 Location Map of Data Sources

According to WRMA classification Oroba River basin is 1HA2 and Kibos River basin is 1HA1, as shown in the location map above. WRMA data therefore shows that Asurur catchment area is situated in Kibos River basin (1HA1). However, it was confirmed from topographic maps with a scale of 1:50,000 that Asurur catchment area is situated in Oroba River basin.

(1) Collected Data from WRMA and KMD

The collected discharge and rainfall data for the study are listed below.

Table 4.1.1 Collected Discharge and Rainfall Data around Asurur Site

Source	Station ID	Name	Data	Period
WRMA	1HA01	Great Oroba	Daily discharge	Jan. 1932 – Aug. 1999
WRMA	1HA02	Little Oroba	Daily discharge	Aug. 1931 – Dec. 2008
KMD	8934157	Kabujoi Forest Station	Monthly rainfall	Jan. 1993 – Dec. 2012
KMD	8935033	Nandi Hills – Savani Estate	Monthly rainfall	Jan. 1993 – Dec. 2012
KMD	8935161	Kibweri Tea Estate – Nandi Hills	Monthly rainfall	Jan. 1993 – Dec. 2012

(2) Observed Data Measured by the Working Group

River discharge at the planned Asurur site was measured in 2012 and 2014 by WG. The measurement records are attached in Annex-1, and tabulated below.

Table 4.1.2 Discharge Measurements Recorded at Asurur Site

Measurement Date	1 st Measurement (m ³ /s)	2 nd Measurement (m ³ /s)	Daily Average (m ³ /s)	Monthly Average (m ³ /s)
21 Jun. 2012	1.64	-	1.64	1.71
22 Jun. 2012	1.77	-	1.77	
26 Jul. 2012	1.97	-	1.97	1.97
13 Aug. 2012	1.46	1.59	1.53	1.77
14 Aug. 2012	1.45	1.54	1.50	
27 Aug. 2012	2.11	2.46	2.29	
28 Aug. 2012	2.10	1.87	1.99	
29 Aug. 2012	1.57	1.46	1.52	
10 Sep. 2012	2.26	2.13	2.20	1.79
11 Sep. 2012	1.95	2.03	1.99	
12 Sep. 2012	2.04	1.58	1.81	
23 Sep. 2012	1.46	1.47	1.47	
24 Sep. 2012	1.70	1.66	1.68	
25 Sep. 2012	1.60	1.60	1.60	
31 Jan. 2014	1.33	1.22	1.28	1.28
Maximum	-	-	2.29	1.97
Minimum	-	-	1.28	1.28

(3) Simulated Data by NWMP 2030

Hydrological analysis was conducted in “Project on Development of the National Water Master Plan 2030 (NWMP 2030)” by JICA in 2013. The following results of the analysis in NWMP 2030 were adopted for the study.

i) Rainfall - runoff Analysis

Rainfall - runoff analysis was conducted in NWMP 2030 by applying the Similar Hydrological Elements Response model (SHER model) for the entire country. As a result of simulation using SHER model, monthly average naturalized discharge in 204 sub - basins were determined for the period from 1991 to 2010. Naturalized discharge refers to the river runoff that is not affected by any water use in the catchment area.

The monthly average discharge data in sub - basin 1HA1 where the Asurur site is located, were applied.

ii) Flood Analysis

Flood analysis was carried out in NWMP 2030. 18 gauging stations each having over 15 valid years was selected from the collected daily discharge data at 47 gauging stations, for the frequency analysis. A valid year was defined as a year in which the data availability was over 80%. The probable flood discharges of 21 major river basins in Kenya were evaluated based on the simulated river discharge, in the same way as the evaluation based on observed data.

Regional area flood curve in Kibos River where Asurur site is located, were applied.

4.2 Estimation of the Reliable Discharge

Reliable discharge at the planned Asurur site was estimated based on the following three (3) sets of data:

i) Estimation by WRMA Daily Discharge Data

Correlation between the collected WRMA daily discharge data at two (2) stations - 1HA01 and 1HA02 - was checked. The correlation was 0.208, and this was slightly positive, and supplementation of missing data was therefore not executed.

Daily discharge data at 1HA01, located downstream of the planned Asurur site, was used for the analysis. Daily discharges at the planned Asurur site were estimated as a ratio of the catchment area.

ii) Estimation by KMD Monthly Rainfall Data

Correlations among the collected KMD monthly rainfall data at three (3) stations were checked. The correlations were 0.658, 0.689 and 0.809, and these were moderately to strongly positive. Supplementation of missing data was therefore executed.

Monthly rainfall data at Kabujoi Forest station, located on the planned Asurur catchment area, was applied in the analysis. Monthly discharges at the planned Asurur site were estimated based on the assumed runoff coefficient.

iii) Estimation by Simulated Monthly Discharge Data by NWMP 2030


The simulated monthly average discharges in sub - basin 1HA1, which is the location of the planned Asurur catchment area, were converted into the discharges at Asurur site as a ratio of the catchment area.

Discharge hydrograph and flow duration curve were created from the estimated daily or monthly average discharges derived from the three (3) sources of data above, and probability calculated. The results obtained were compared with the observed discharges at the site.

As a result, discharge data estimated by WRMA daily discharge and NWMP 2030 simulated monthly discharge were relatively smaller than the observed discharges. Further, the discharge data estimated by KMD monthly rainfall data was selected for definition of the design discharges.


4.2.1 Estimation by WRMA Discharge Data

Daily discharge data at two (2) gauging stations, 1HA01 and 1HA02, were arranged in discharge hydrographs as shown below.



Note: Both hydrographs show the same data, with different discharge scales.

Figure 4.2.1 Discharge Hydrograph at 1HA01



Source: WRMA daily discharge data (Presentation by WG)

Figure 4.2.2 Discharge Hydrograph at 1HA02

Correlation between daily discharge data at 1HA01 and 1HA02 was 0.208. The correlation was slightly positive. Accordingly, it was determined that supplementation of missing data was meaningless.

Discharge data at 1HA01 between 1956 and 1988 (33 years) were adopted to create the flow duration curve, taking the following points into consideration:

- As shown in Figure 4.2.1, some periods have abnormally large values of discharge in comparison to other periods. (Year 1938 to 1952 and 1989), and
- Data for over half of the year were missing in some instances (Year 1934, 1935, 1945 to 1955, 1990, 1993, 1994 and 1996).

Discharges at 1HA01 are converted into discharges at the planned Asurur site as a ratio of the catchment area ($0.697 = 37.9 \text{ km}^2 / 54.4 \text{ km}^2$), and flow duration curves at Asurur site were estimated using daily discharges and monthly average discharges as shown below.




Figure 4.2.3 Flow Duration Curve at Asurur Site based on WRMA Discharge Data

4.2.2 Estimation by KMD Rainfall Data

Correlations between each monthly rainfall data at three (3) gauging stations are as follows:

- Kabujoi Forest & Nandi Hills – Savani estate : 0.658 = moderately positive
- Kabujoi Forest & Kibweri tea estate : 0.689 = moderately positive
- Nandi Hills – Savani estate & Kibweri tea estate : 0.809 = strongly positive.

Accordingly, missing monthly data at Kabujoi Forest Station were supplemented by others as tabulated below.

Table 4.2.1 Monthly Rainfall Data for Asurur Catchment Area (Kabujoi)

													(Unit: mm)
Year	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual
1993	79.4	74.4	42.2	85.9	176.3	156.4	114.5	65.5	58.2	113.3	85.6	74.4	1,126
1994	15.9	76.0	207.8	273.7	227.2	126.5	140.7	89.9	200.9	90.2	243.8	19.2	1,712
1995	35.4	36.3	122.0	310.8	172.8	137.1	75.4	91.6	149.3	146.0	203.5	52.7	1,533
1996	82.8	87.0	136.8	247.9	241.9	181.0	163.3	230.7	173.5	139.5	210.4	29.3	1,924
1997	93.0	0.0	77.8	327.7	171.4	126.2	89.0	147.1	41.9	172.6	245.3	144.7	1,637
1998	147.7	63.9	51.9	96.4	206.5	101.8	98.0	95.0	90.4	111.1	86.4	13.5	1,163
1999	70.9	14.3	310.2	175.2	227.8	94.7	168.9	173.3	174.1	78.0	79.8	85.5	1,653
2000	8.5	38.0	62.5	92.9	213.4	72.3	105.9	145.5	185.9	153.8	151.0	106.0	1,336
2001	279.2	74.5	118.7	307.1	228.7	184.7	197.1	76.3	140.0	164.6	57.4	19.6	1,848
2002	117.1	16.8	233.6	311.7	149.4	121.1	94.5	147.1	87.5	124.3	188.4	331.6	1,923
2003	51.3	33.7	33.7	238.2	183.4	116.6	128.9	152.0	155.4	190.1	112.6	50.1	1,446
2004	77.0	76.2	208.0	196.1	147.4	105.9	123.0	222.1	255.9	166.4	195.3	92.8	1,866
2005	120.5	44.1	148.5	105.4	368.0	111.6	209.8	2.7	163.7	117.7	34.7	15.6	1,442
2006	54.4	59.7	153.6	290.5	178.3	180.8	215.4	127.7	197.3	77.7	352.6	237.3	2,125
2007	63.0	160.1	85.8	173.7	192.2	135.6	152.0	220.4	212.4	116.2	85.4	43.9	1,641
2008	58.0	52.6	203.7	259.2	159.2	134.3	132.3	221.0	228.5	199.5	128.4	27.8	1,805
2009	118.0	36.7	107.2	194.5	207.2	60.6	119.1	179.8	186.2	185.9	121.5	98.8	1,616
2010	120.0	154.8	117.2	215.1	255.3	165.1	143.8	211.3	247.1	260.5	93.2	128.8	2,112
Average	88.4	61.1	134.5	216.8	205.9	128.5	137.3	144.4	163.8	144.9	148.6	87.3	1,661

Note: 17 Values with ***Italic Bold*** are supplemented values.

Source: KMD data and supplemented data by WG

Monthly average discharges at the planned Asurur site were estimated based on the supplemented monthly rainfall data at Kabujoi using the following formula:


$$Q_{ave} = \frac{C \times R \times 10^{-3} \times CA \times 10^6}{60 \times 60 \times 24 \times D}$$

Where, Q_{ave} : monthly average discharge (m³/s)
 C: runoff ratio (-) = 0.50
 (hilly area with forest, rocky land)
 R: monthly rainfall (mm)
 CA: catchment area (km²) = 37.9 (km²)
 D: days of each month (31, 30, 29 or 28 days)

The estimated monthly average discharges at the planned Asurur site, and discharge hydrograph and flow duration curve from these discharges were as shown below.

Table 4.2.2 Estimated Monthly Average Discharge at Asurur Site based on KMD Rainfall Data

													(Unit: m ³ /s)
Year	Jan.	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Average
1993	0.56	0.53	0.30	0.61	1.25	1.11	0.81	0.46	0.41	0.80	0.61	0.53	0.66
1994	0.11	0.54	1.47	1.94	1.61	0.90	1.00	0.64	1.42	0.64	1.72	0.14	1.01
1995	0.25	0.26	0.86	2.20	1.22	0.97	0.53	0.65	1.06	1.03	1.44	0.37	0.90
1996	0.59	0.62	0.97	1.75	1.71	1.28	1.16	1.63	1.23	0.99	1.49	0.21	1.13
1997	0.66	0.00	0.55	2.32	1.21	0.89	0.63	1.04	0.30	1.22	1.74	1.02	0.96
1998	1.04	0.45	0.37	0.68	1.46	0.72	0.69	0.67	0.64	0.79	0.61	0.10	0.69
1999	0.50	0.10	2.19	1.24	1.61	0.67	1.19	1.23	1.23	0.55	0.56	0.60	0.97
2000	0.06	0.27	0.44	0.66	1.51	0.51	0.75	1.03	1.32	1.09	1.07	0.75	0.79
2001	1.98	0.53	0.84	2.17	1.62	1.31	1.39	0.54	0.99	1.16	0.41	0.14	1.09
2002	0.83	0.12	1.65	2.21	1.06	0.86	0.67	1.04	0.62	0.88	1.33	2.35	1.13
2003	0.36	0.24	0.24	1.69	1.30	0.82	0.91	1.08	1.10	1.34	0.80	0.35	0.85
2004	0.54	0.54	1.47	1.39	1.04	0.75	0.87	1.57	1.81	1.18	1.38	0.66	1.10
2005	0.85	0.31	1.05	0.75	2.60	0.79	1.48	0.02	1.16	0.83	0.25	0.11	0.85
2006	0.38	0.42	1.09	2.06	1.26	1.28	1.52	0.90	1.40	0.55	2.49	1.68	1.25
2007	0.45	1.13	0.61	1.23	1.36	0.96	1.08	1.56	1.50	0.82	0.60	0.31	0.97
2008	0.41	0.37	1.44	1.83	1.13	0.95	0.94	1.56	1.62	1.41	0.91	0.20	1.06
2009	0.83	0.26	0.76	1.38	1.47	0.43	0.84	1.27	1.32	1.32	0.86	0.70	0.95
2010	0.85	1.10	0.83	1.52	1.81	1.17	1.02	1.49	1.75	1.84	0.66	0.91	1.25
Average	0.63	0.43	0.95	1.53	1.46	0.91	0.97	1.02	1.16	1.02	1.05	0.62	0.98


**Figure 4.2.4 Flow Duration Curve at Asurur Site based on KMD Data****4.2.3 Estimation by Simulated Monthly Discharge Data in NWMP 2030**

Simulated monthly discharges in sub-basin 1HA1 were converted into discharge at the planned Asurur site as a ratio of catchment area ($0.109 = 37.9 \text{ km}^2 / 348.8 \text{ km}^2$) as tabulated below. Flow duration curves at Asurur site were also estimated using these discharge data as shown below.

Table 4.2.3 Estimated Monthly Average Discharge at Asurur Site based on NWMP 2030 Data

Year	(Unit: m ³ /s)												Average
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
1991	0.15	0.11	0.10	0.45	0.87	0.59	0.20	0.11	0.11	0.29	0.25	0.11	0.28
1992	0.11	0.11	0.11	0.10	0.28	0.56	0.37	0.28	0.49	0.30	0.20	0.12	0.25
1993	0.12	0.11	0.11	0.11	0.68	0.60	0.16	0.12	0.14	0.10	0.10	0.11	0.20
1994	0.11	0.11	0.30	0.62	0.95	0.36	0.28	0.26	0.18	0.10	0.39	0.37	0.34
1995	0.10	0.10	0.12	0.35	0.84	0.33	0.26	0.18	0.21	0.37	0.36	0.15	0.28
1996	0.12	0.18	0.58	0.95	0.68	0.41	0.37	0.20	0.36	0.22	0.33	0.33	0.39
1997	0.10	0.10	0.11	0.37	0.56	0.18	0.22	0.13	0.11	0.11	0.38	1.78	0.35
1998	1.05	0.24	0.14	0.41	0.52	0.36	0.18	0.11	0.11	0.27	0.21	0.11	0.31
1999	0.00	0.00	0.00	0.15	0.53	0.17	0.05	0.07	0.13	0.22	0.16	0.23	0.14
2000	0.11	0.10	0.10	0.10	0.27	0.20	0.25	0.24	0.21	0.26	0.32	0.48	0.22
2001	0.93	0.24	0.11	0.40	0.43	0.42	0.24	0.23	0.53	0.30	0.46	0.14	0.37
2002	0.13	0.11	0.25	0.84	1.10	0.22	0.11	0.14	0.18	0.14	0.54	0.40	0.35
2003	0.23	0.02	0.00	0.15	0.51	0.26	0.15	0.07	0.10	0.04	0.03	0.02	0.13
2004	0.14	0.12	0.10	0.86	0.63	0.12	0.10	0.15	0.33	0.27	0.29	0.20	0.28
2005	0.15	0.15	0.21	0.29	0.65	0.29	0.16	0.16	0.15	0.11	0.12	0.11	0.21
2006	0.10	0.11	0.10	0.67	0.33	0.27	0.18	0.17	0.18	0.13	0.91	1.08	0.35
2007	0.51	0.20	0.46	0.33	0.58	0.43	0.46	0.59	0.53	0.21	0.11	0.07	0.37
2008	0.05	0.05	0.05	0.43	0.34	0.40	0.27	0.34	0.33	0.76	0.53	0.12	0.31
2009	0.07	0.09	0.05	0.18	0.38	0.16	0.11	0.11	0.30	0.23	0.16	0.26	0.18
2010	0.40	0.13	0.50	0.78	1.09	0.30	0.21	0.16	0.43	0.25	0.17	0.12	0.38
Average	0.23	0.12	0.17	0.43	0.61	0.33	0.22	0.19	0.26	0.23	0.30	0.31	0.28

Source: NWMP 2030 by JICA (Presented by WG)



Source: NWMP 2030 by JICA (Presented by WG)

Figure 4.2.5 Flow Duration Curve at Asurur Site based on NWMP 2030 Data

4.2.4 Comparison among Estimated Flow Duration Curves

Estimated flow duration curves and observed maximum and minimum discharges were compared as shown below. The range of observed discharges showed relatively low probability in the flow duration curves.




Figure 4.2.6 Comparison between Observed Discharge and Flow Duration Curves

- (1) Comparison between Observed Discharge and Estimated Discharge based on KMD Rainfall Data

From all the collected data, only rainfall data at Kabuji Forest Station was available on measurement months. Monthly average discharge on measurement months at the planned Asurur site were estimated from the available KMD monthly rainfall data in 2012, in the same manner as that described in Section 4.2.2. The results obtained were as tabulated below.

Table 4.2.4 Observed and Estimated Monthly Discharge at Asurur Site

Month/Year	Jun. 2012	Jul. 2012	Aug. 2012	Sep. 2012	Jan. 2014
Monthly average of observed Q (m ³ /s)	1.71	1.97	1.77	1.79	1.28
KMD monthly rainfall data (mm/month)	144.5	N.A.	158.5	206.1	N.A.
Estimated monthly average Q (m ³ /s)	1.02	-	1.12	1.46	-

As seen in the above table, the observed discharge values were larger than the estimated monthly average discharges.

Average annual rainfall at Kabuji for 18 years (1993 to 2010) was calculated at 1,661 mm/year. The annual rainfall at Kabuji in 2012 was not available due to missing data in July and December, but it was assumed to be 1,360 mm/year based on the monthly average rainfall in July and December for 18 years (1993 to 2010). Therefore, annual rainfall in 2012 was lower than the average. However, the observed discharges showed higher values than the estimated monthly average discharges.


Accordingly, it is conceivable that the estimated flow duration curves using the three (3) different methods are underestimations.

- (2) Consideration of the Difference between Observed Discharge and Flow Duration Curves

The following possibilities are conceivable as the reason why the flow duration curves showed low discharges.

- i) WRMA discharge data at 1HA01

Asurur River is a tributary of the Great Oroba River. The planned Asurur site is located at the shoulder of Nandi Hills, while 1HA01 gauging station is located at the foot of Kano Plains as shown below. Accordingly, it is conceivable that infiltration is occurring near 1HA01 gauging station, located at the river plain.



Source: Prepared by WG from a topographic map with a scale of 1:50,000

Figure 4.2.7 Location of Asurur MHP Site on Longitudinal Profile of Great Oroba River

ii) NWMP 2030 simulated Discharge Data in Sub - basin 1HA1

The rainfall - runoff analysis was conducted nationally. The planned Asurur catchment area occupies 10% of the sub - basin 1HA1. Accordingly, local characteristics of the Asurur catchment area could not be expressed adequately.

iii) Overestimation of Discharge Measurement at Asurur Site

Discharge measurement has some observation error, and it is conceivable that the observed discharge is overestimated.

Taking into consideration the above and observed results at the site, the flow duration curve prepared using KMD monthly rainfall data was applied for the planning of Asurur MHP.

4.3 Estimation of the Flood Discharge

Probable flood discharge at the planned Asurur site was studied based on three (3) sets of data as summarized below.

i) Estimation by Annual Maximum Discharge in WRMA Daily Discharge Data

Maximum daily discharge for each year from 1956 to 1988 at the 1HA01 station of WRMA was extracted for the estimation. However, these annual maximum discharges showed relatively small values compared with the observed discharge at the planned Asurur site. Accordingly, it was determined that flood discharge data was not indicated in the daily discharge data, and it was not adopted for the probable flood estimation.

ii) Estimation by Rational Formula

The rational formula is commonly applied for the estimation of flood discharge at catchment areas of less than 200 km². The formula is used to estimate the peak flood discharge from runoff coefficient, average rainfall intensity in flood duration, and catchment area. The runoff coefficient was defined by land use condition in the catchment area, and the average rainfall intensity was estimated from KMD monthly rainfall data and characteristics in the catchment area.

iii) Estimation by Regional Area Flood Curve by NWMP 2030

Regional area – flood curves are given by logarithmic functions for each major sub – basin, in the same way as the results of flood analysis in NWMP 2030. According to WRMA’s classification, the planned Asurur catchment area is located in Kibos River basin, and flood discharges were estimated by the regional area flood curve for Kibos River basin.

The probable flood discharges estimated using the first two (2) methods were compared with those of other hydropower projects in Eastern Kenya by Creager’s coefficient (“C” value). As a result, “C” values of the flood discharge estimated by the regional area – flood curve were relatively smaller than the range of “C” values of other projects. The flood discharge estimated by rational formula was therefore selected for definition of the design discharges.

4.3.1 Estimation by WRMA Daily Discharge Data

Annual maximum daily discharge from daily discharge data at 1HA01 during 1956 to 1988 were extracted and converted into discharge at the planned Asurur site as a ratio of the catchment area ($0.697 = 37.9 \text{ km}^2 / 54.4 \text{ km}^2$), and these were compared with the average observed discharge of $1.70 \text{ m}^3/\text{s}$ at the site as tabulated below.

Table 4.3.1 Annual Maximum Discharges at Asurur Site

No.	Date	Q_a (m^3/s)	Q_b (m^3/s)	Q_b/Q_m (-)	No.	Date	Q_a (m^3/s)	Q_b (m^3/s)	Q_b/Q_m (-)
1	06 Sep. 1956	3.35	2.33	1.4	18	16 Jan. 1973	2.28	1.59	0.9
2	27 Jun. 1957	2.61	1.82	1.1	19	02 Jan. 1974	4.53	3.15	1.9
3	27 Jul. 1958	3.35	2.33	1.4	20	25 Jul. 1975	2.96	2.06	1.2
4	03 Nov. 1959	4.45	3.10	1.8	21	22 May 1976	1.99	1.38	0.8
5	17 Nov. 1959	2.96	2.06	1.2	22	06 May 1977	8.04	5.60	3.3
6	27 Nov. 1961	7.68	5.35	3.2	23	08 May 1978	2.78	1.94	1.1
7	19 May 1962	8.78	6.11	3.6	24	12 Apr. 1979	2.61	1.82	1.1
8	09 May 1963	4.70	3.27	1.9	25	22 Nov. 1980	1.36	0.95	0.6
9	24 Apr. 1964	7.34	5.11	3.0	26	12 Oct. 1981	2.28	1.59	0.9
10	03 May 1965	4.22	2.94	1.7	27	29 Nov. 1982	1.47	1.03	0.6
11	25 Apr. 1966	4.22	2.94	1.7	28	11 Oct. 1983	2.13	1.49	0.9
12	27 Nov. 1967	3.35	2.33	1.4	29	09 May 1984	1.36	0.95	0.6
13	29 Apr. 1968	4.45	3.01	1.8	30	16 Apr. 1985	1.36	0.95	0.6
14	10 Feb. 1969	2.13	1.49	0.9	31	07 Mar. 1986	4.92	3.42	2.0
15	24 Apr. 1970	7.68	5.35	3.2	32	09 Nov. 1987	1.60	1.11	0.7
16	18 May 1971	3.15	2.20	1.3	33	04 Dec. 1988	474.60	330.65	194.5
17	20 Nov. 1972	2.28	1.59	0.9	-	-	-	-	-

Note: Q_a means discharge data at 1HA01, Q_b means converted discharge at Asurur ($Q_b = 0.697 Q_a$), and Q_m means average observed discharge at Asurur ($Q_m = 1.70 \text{ m}^3/\text{s}$).

Prepared by WG based on WRMA daily discharge data at 1HA01

As seen in the table, annual maximum discharges were distributed within the range of 0.6 to 3.6 times of the average observed discharge of $1.70 \text{ m}^3/\text{s}$, except for the year 1988. Further, 11 of the 33 values of annual maximum discharges were smaller than the average observed discharge.

Accordingly, it was determined that the daily discharge data at 1HA01 was not indicated discharge during flood, and was therefore not applicable for the estimation of probable flood discharge.

4.3.2 Estimation by Rational Formula

Regional formula is commonly applied for the estimation of flood discharge at catchment areas of less than 200 km^2 . The formula is as follows:

$$Q_p = \frac{1}{3.6} \times f \times R_T \times A \quad [\text{Rational Formula (Lloyd Davies, 1906)}]$$

Where, Q_p : peak discharge (m^3/s)
 f : runoff coefficient (-)
 $= 0.60$ (Intermediate value of undulating land and forest)
 R_T : average rainfall intensity in flood duration (mm/hr)
 A : catchment area (km^2) = 37.9 (km^2)

$$\therefore Q_p = \frac{1}{3.6} \times 0.6 \times R_T \times 37.9$$

Average rainfall intensity in flood duration (R_T) is estimated based on the monthly rainfall and topographic characteristics in the basin as explained below.

(1) Estimation of Average Rainfall Intensity (R_T)

The average rainfall intensity (R_T) is estimated using the following formula:

$$R_T = \frac{R_{24}}{24} \times \left(\frac{24}{T} \right)^{2/3} \quad [\text{Mononobe Formula}]$$

$$R_T = R_{24} \times \left(\frac{347.1}{t^{1.35} + 1,502} \right) \quad [\text{Ito Formula}]$$

Where R_T : average rainfall intensity (mm/hr)
 R_{24} : probable daily rainfall (mm/day)
 T : time to concentration of runoff (hr)
 t : time to concentration of runoff (min)

i) Estimation of Probable Daily Rainfall (R_{24})

Probable daily rainfall is assumed to be 10% of monthly rainfall, where daily rainfall data is not available. Maximum monthly rainfall in each year at Kabujoi Forest station was extracted from KMD monthly rainfall data, and daily maximum rainfall was assumed as listed below.

Table 4.3.2 Assumed Annual Maximum Daily Rainfall of Asurur Basin

Year	1993	1994	1995	1996	1997	1998	1999	2000	2001
Maximum monthly rainfall (mm)	176.3	273.7	310.8	247.9	327.7	206.5	310.2	213.4	307.1
Assumed daily rainfall (mm)	17.6	27.4	31.1	24.8	32.8	20.6	31.0	21.3	30.7
Year	2002	2003	2004	2005	2006	2007	2008	2009	2010
Maximum monthly rainfall (mm)	331.6	238.2	255.9	368.0	352.6	220.4	259.2	207.2	260.5
Assumed daily rainfall (mm)	33.2	23.8	25.6	36.8	35.3	22.0	25.9	20.7	26.0

Prepared by WG based on KMD monthly rainfall data

Probability of daily rainfall was calculated based on the 18 values above. The log Pearson type III was used as the probability distribution function, as recommended by the Engineering Manual (EM1110-2-1417: Flood-runoff Analysis) of the US Army Corps of Engineers. The results of the probable rainfall depth and frequency (return period) are as shown below.

Table 4.3.3 Probable Daily Rainfall of Asurur Basin

Return Period	(Year)	200	100	50	20	10	5
Excess Probability	(%)	0.5	1.0	2.0	5.0	10.0	20.0
Probable Rainfall (R_{24})	(mm/day)	47.1	44.4	41.7	38.0	35.1	31.9

ii) Estimation of Flood Concentration Time

Flood concentration time is generally estimated in two steps, i.e., overland inflow time from the basin to river and river flow time to the site. These values are determined as follows:

Overland Inflow Time

$$T_{OF} = \left(\frac{2}{3} \times 3.28 \times l \times \frac{N}{\sqrt{S}} \right)^{0.467} \quad [\text{Kerby Formula}]$$

Where, T_{OF} : overland inflow time (min)
 l : length between basin crest and top of river (m)
 N : retardance coefficient (-) = 0.60 (Forest area with deciduous trees)
 S : slope of the extreme edge elevation at the most upstream reach (-)

River Flow Time

$$T_{RF} = \frac{L}{W}, \quad W = 20 \times \left(\frac{h}{L} \right)^{0.6} \quad [\text{Rziha Formula}] (L > 1/20)$$

Where, T_{RF} : river flow time (s)

L : horizontal length of river channel from top of river to site (m)

W : flood velocity (m/s)

h : height difference from top of river to site (m)

(2) Basin Characteristics

The topographic characteristics of the planned Asurur catchment area were assumed from a topographic map with scale of 1:50,000 as follows:

Catchment area:	$A = 37.9 \text{ (km}^2\text{)}$
Length between basin crest and top of river:	$l = 860 \text{ (m)}$
Slope of the extreme edge elevation at top of river:	$S = (2,060 - 2,000)/860 = 0.070 \text{ (-)}$
Length of river reach:	$L = 11,270 \text{ (m)} = 11.3 \text{ (km)}$
Height difference from top of basin to site:	$h = 2,060 - 1,740 = 320 \text{ (m)}$
Slope of river reach:	$I = L/H = 1/35.2 = 0.028 \text{ (-)}$

(3) Estimation of Peak Flood Discharge

Peak flood discharges are calculated by the above formula and basin characteristics as explained below.

i) Estimation of Flood Concentration Time ($T = T_{OF} + T_{RF}$)

Overland inflow Time (T_{OF})

$$T_{OF} = \left(\frac{2}{3} \times 3.28 \times l \times \frac{N}{\sqrt{S}} \right)^{0.467} = \left(\frac{2}{3} \times 3.28 \times 860 \times \frac{0.6}{\sqrt{0.070}} \right)^{0.467}$$

$$= 49.6 \text{ (min)} = 0.8 \text{ (hr)}$$

River Flow Time (T_{RF})

$$W = 20 \times \left(\frac{h}{L} \right)^{0.6} = 20 \times \left(\frac{320}{11,270} \right)^{0.6} = 2.36 = 2.4 \text{ (m/s)}$$

$$T_{RF} = \frac{L}{W} = \frac{11,270}{2.4} = 4,696 \text{ (s)} = 78.3 \text{ (min)} = 1.3 \text{ (hr)}$$

Flood Concentration Time (T)

$$T = T_{OF} + T_{RF} = 0.8 + 1.3 = \underline{2.1 \text{ (hr)}}$$

$$t = t_{OF} + t_{RF} = 49.6 + 78.3 = \underline{128 \text{ (min)}}$$

ii) Estimation of average rainfall intensity (R_T)

The average rainfall intensity was calculated using the two (2) formulae and the results were as shown below.

Table 4.3.4 Estimated Average Rainfall Intensity at Asurur Site

Return Period	(Year)	200	100	50	20	10	5
Excess Probability	(%)	0.5	1.0	2.0	5.0	10.0	20.0
R_{24}	(mm/day)	47.1	44.4	41.7	38.0	35.1	31.9
T	(hr)	2.1	2.1	2.1	2.1	2.1	2.1
R_{T1} (Mononobe)	(mm/hr)	9.7	9.1	8.5	7.8	7.2	6.5
T	(min)	128	128	128	128	128	128
R_{T2} (Ito)	(mm/hr)	7.4	7.0	6.6	6.0	5.5	5.0

Note: R_{T1} is average rainfall intensity by Mononobe Formula and R_{T2} is average rainfall intensity by Ito Formula.

iii) Estimation of peak flood discharge (Q_p)

Peak flood discharges for each return period were calculated as summarized below.

Table 4.3.5 Estimated Peak Flood Discharge at Asurur Site

Return Period	(Year)	200	100	50	20	10	5
Excess Probability	(%)	0.5	1.0	2.0	5.0	10.0	20.0
R_{T1} (Mononobe)	(mm/hr)	9.7	9.1	8.5	7.8	7.2	6.5
Q_p	(m ³ /s)	61.0	57.5	54.0	49.2	45.4	41.3
R_{T2} (Ito)	(mm/hr)	7.4	7.0	6.6	6.0	5.5	5.0
Q_p	(m ³ /s)	46.9	44.2	41.5	37.9	35.0	31.8

4.3.3 Estimation by Regional Area Flood Curve in NWMP 2030

The probable flood discharge at the planned Asurur site was calculated by using the regional area – flood curve at Kibos River, which was presented in NWMP 2030, as shown below.

Table 4.3.6 Flood Discharge by Regional Area Flood Curve presented in NWMP 2030

Return Period	Regional Area Flood Curve	$\log_{10}A$	$\log_{10}Q$	Q
10-year	$\log_{10}Q = -0.012 + 0.551 \log_{10}A$	1.579	0.857	7.2 m ³ /s
25-year	$\log_{10}Q = +0.061 + 0.551 \log_{10}A$	1.579	0.937	8.7 m ³ /s
50-year	$\log_{10}Q = +0.115 + 0.551 \log_{10}A$	1.579	0.991	9.8 m ³ /s
100-year	$\log_{10}Q = +0.168 + 0.551 \log_{10}A$	1.579	1.040	11.0 m ³ /s

Note: “A” means catchment area of 37.9 km².

Source: Regional Area Flood Curve: Final Report of NWMP 2030, Sector Report B, Table 6.3.2 LVS-14 Kibos, by JICA (Presented by WG)

4.3.4 Confirmation by Creager Envelope Curve

The adequacy of estimated flood discharges is checked by the Creager envelope curve. The Creager envelope curve is an empirical formula which indicates the relation between catchment area and estimated or recorded flood discharge, in the form of specific discharge.

The Creager envelope curve is given by the following formula:

$$Q_p = 0.503 \times C \times \left(\frac{A}{2.59} \right)^{a-1}$$

$$a = 0.894 \times \left(\frac{A}{2.59} \right)^{-0.048}$$

Where, Q_p : Specific peak discharge (m³/s/km²)

C : Creager’s coefficient (-)

A : catchment area (km²)

The Creager coefficient “C” indicates regional characteristics of catchment area. It therefore varies depending on the location of the basin in question. However, its values become similar for nearby

basins. The “C” value shall therefore be estimated based on the available flood records and/or design flood discharges in existing projects to obtain the appropriate value near the basin in question.

The flood peak specific discharges and the “C” values of hydropower projects in Western Kenya, and 100 - year probable flood peak discharges estimated using two (2) different methods for Asurur site were compared as shown below.

Table 4.3.7 Creager’s Coefficient for Hydropower Projects in Western Kenya

Project Name	County	A (km ²)	Q _d (m ³ /s)	Q _p (m ³ /s/km ²)	C (-)	Remarks
Asurur MHP	Nandi	37.9	61	1.609	5.7	100 - year flood
			47	1.237	4.4	100 - year flood
			11	0.290	1.0	100 - year flood
<i>Proposed MHP</i>						
Greater Orobo	Nandi	50	121	2.407	9.3	Flood during construction
Kiptiget - Itare Conf.	Bomet	186	42	0.227	1.4	Flood during construction
Ainamoi – Kitio	Kericho	333	75	0.227	1.9	Flood during construction
Chemosit - Kabianga	Bomet	1,370	310	0.227	3.8	Flood during construction
Wei Wei - Sighor	Nakuru	203	35	0.172	1.1	Flood during construction
Embobut - Tot	Elegeyo Marakwet	34	496	14.714	50.1	Flood during construction
<i>Large Scale HPP</i>						
Sondur/ Miriu	Kisumu	3,345	1,046	0.313	8.6	PMF
			749	0.224	6.1	1000 - year flood
Magwagwa	Nyamira	3,160	1,920	0.608	16.1	PMF
			1,634	0.517	13.7	1000 - year flood




Figure 4.3.1 Creager’s Coefficient for Hydropower Projects in Western Kenya

The following issues were confirmed as a result of the comparison:

- ✓ Design flood discharges of probable maximum flood (PMF) and 1,000 - year probable flood for Sondu/Miriu HPP and Magwagwa HPP were defined based on international standards of hydrological analysis, and were regarded as rough indicative values,
- ✓ Design flood discharges of MHP projects were defined as flood during construction, and it were conceivably 5 - year to 10 - year probable floods. However, the “C” values seemed relatively large, especially for Embobut -Tot and Greater Orobo which were abnormally large,
- ✓ The “C” values of assumed 100 - year probable flood by Rational Formula for Asurur MHP were smaller than “C” values of PMF and 1,000 - year probable flood. However, they were larger than “C” values of flood during construction. The “C” values therefore seemed reasonable, and
- ✓ The “C” values of assumed 100 - year probable flood from NWMP 2030 regional area – flood curve for Asurur MHP were the smallest among all “C” values, and this seems unreasonable.

Taking the above conditions into consideration, flood discharges estimated by Rational Formula and average rainfall intensity estimated by Ito Formula were adopted for the design discharge of Asurur MHP.

4.4 Design Discharge

Design plant discharges of Asurur MHP were defined in this stage based on the flow duration curve prepared by KMD monthly rainfall data as explained below. The design plant discharge shall be confirmed or reviewed in future based on further observation results of discharge at the site.

4.4.1 Design Plant Discharge

The design plant discharges are defined as follows:

Minimum design plant discharge (Q_{pmin}):

$$Q_{pmin} = Q_{90\%} - Q_{95\%} - Q_{eu} = 0.31 - 0.21 - 0.00 = 0.1 \text{ m}^3/\text{s}$$

Maximum design plant discharge (Q_{pmax}):

$$Q_{pmax} = Q_{50\%} - Q_{95\%} - Q_{eu} = 0.91 - 0.21 - 0.00 = 0.7 \text{ m}^3/\text{s}$$

Where, $Q_{90\%}$: 90% reliable discharge at the site = 0.31 (m^3/s)

$Q_{95\%}$: 95% reliable discharge at the site = 0.21 (m^3/s)

$Q_{50\%}$: 50% reliable discharge at the site = 0.91 (m^3/s)

Q_{eu} : existing water use at upstream of the site = 0.00 (m^3/s)

The amount of reserve, consisting of ecological and basic human needs, was set at 95% of the value of naturalized daily flow for each river, in accordance with “Guidelines for Water Allocation (WRMA, 2010)”. Therefore, the minimum discharge was determined to be 90% reliable discharge minus 95% reliable discharge.

The maximum design plant discharge is generally determined as 50 to 70% of reliability in the flow duration curve. Its value depends on the required power output and available head, with maximum plant discharge of 0.7 m^3/s .

4.4.2 Plant Factor

The plant factor is calculated to be 72.5% as shown below.




Figure 4.4.1 Plant Factor of Asurur MHP

4.4.3 Design Flood Discharge

Design flood discharge is defined as 50 - year probable flood taking into consideration the project scale and project life.

$$Q_f = 41.5 = 42.0 \text{ m}^3/\text{s} \text{ (50 - year probable flood)}$$

Refer to Table 4.3.5.

CHAPTER 5 PLAN FORMULATION

5.1 Preparation of Alternative Layouts

This chapter describes the preparation of alternative layouts, comparison of the alternatives and selection of the optimum layout.

A topographic map with a scale of 1: 500, which was prepared during the preparation stage of the pilot project in 2012, was used to carry out the comparative study.

At first, possible positions of intake weir and powerhouse were determined based on the longitudinal profile of Asurur River, and three (3) intake sites and one (1) powerhouse site were identified. Then, three (3) alternative layouts, Layout A, Layout B and Layout C, were prepared for comparison.

For each of the three (3) alternative layouts, development cost (C) was estimated using empirical equations and benefit (B) was estimated based on the different available heads and the same discharge estimated in Chapter 4. Then, alternative layouts were compared in terms of ratio of cost and benefit, as well as generation power against estimated power demand in Chapter 3.

As a result of comparative study, Layout A was selected as the optimum layout.

5.1.1 Position of Intake Weir and Powerhouse

Alternative positions of intake weir and powerhouse were studied by creating the longitudinal profile of Asurur site from the topographic map as shown below.




Figure 5.1.1 Alternative Head of Asurur Site

As a result, the alternative positions were considered as follows:

- ✓ **Intake weir:** A gentle slope is maintained downstream for 120 m from the existing culvert under the road. Then, the river gradient is rapid from there to Asurur waterfall. Three (3) alternative sites of intake weir were therefore possible along the rapids section, and
- ✓ **Powerhouse:** The river gradient downstream of Asurur waterfall is a gentle slope. Therefore, there are no alternatives for powerhouse site.

5.1.2 Alternative Layouts for Comparison

Taking into consideration the alternative sites of intake weir, and topographic conditions along Asurur River from intake weir sites and powerhouse site, three (3) alternative layouts were prepared as shown below.

It is noted that an alternative layout on the left bank was not prepared because the waterway distance on the left bank was clearly longer than on the right bank due to topographic conditions.




Figure 5.1.2 Alternative Layouts for Comparison

5.1.3 Temporary Setting of Major Dimensions

The following major dimensions were temporarily set in order to define the major dimensions of each alternative layout.

(1) Center Level of Turbine

Turbine center level had to be set to avoid inundation during flooding. The design flood discharge was defined to be 42.0 m³/s (50-year probable flood) as explained in Chapter 4.

Water levels against several discharges along Asurur River were calculated by non-uniform analysis. Thirteen (13) cross sections were prepared from the topographic map as attached in Annex-2, and roughness coefficients defined through some trial calculations as follows:

River channel: 0.060
Left and right bank: 0.080

The analysis was carried out using free software (HEC-RAS), yielding the calculated water levels summarized in the table below.

Table 5.1.1 Result of Water Level Calculation against Design Flood Discharge

Section	Positin	Discharge (m ³ /s)	Riverbed Level (EL.m)	Water Level (EL.m)	Critical WL (EL.m)	Energy Line (EL.m)	Energy Slope (m/m)	Flow Velocity (m/s)	Flow Area (m ²)	Flow Width (m)	Froude Number (-)
CH+340	Culvert	42.00	1,747.80	1,749.76		1,749.96	0.01	2.31	26.32	38.08	0.65
CH+300		42.00	1,747.80	1,749.41		1,749.53	0.01	1.56	27.73	28.37	0.46
CH+262.0		42.00	1,747.00	1,748.48	1,748.48	1,748.98	0.03	3.16	13.96	15.67	0.96
CH+222.0	Intake A	42.00	1,744.60	1,745.71	1,745.71	1,746.08	0.03	2.91	17.47	23.88	0.94
CH+213.0		42.00	1,742.60	1,743.99	1,743.99	1,744.48	0.04	3.10	13.56	14.09	1.01
CH+189.0	Intake B	42.00	1,736.00	1,737.90	1,737.90	1,738.31	0.02	3.16	18.19	22.32	0.82
CH+165.0		42.00	1,730.10	1,731.64	1,731.64	1,732.01	0.02	2.96	18.36	24.33	0.84
CH+143.0	Intake C	42.00	1,728.40	1,729.80	1,729.80	1,730.23	0.03	3.06	16.11	20.63	0.92
CH+110.0		42.00	1,714.40	1,716.26	1,716.26	1,716.84	0.03	3.36	12.65	11.96	0.99
CH+78.0		42.00	1,710.40	1,712.67	1,712.67	1,713.29	0.04	3.48	12.06	9.95	1.01
CH+56.0		42.00	1,708.20	1,711.78		1,711.89	0.00	1.50	27.95	15.36	0.36
CH+28.0	Powerhouse	42.00	1,710.50	1,711.30	1,711.30	1,711.61	0.04	2.45	17.82	32.07	0.97
CH+1.0	Tailrace	42.00	1,708.40	1,709.52	1,709.52	1,709.81	0.03	2.52	20.19	42.15	0.90

Water level against the design flood discharge surrounding powerhouse and tailrace was calculated as EL. 1,709.5 m to EL. 1,711.3 m.

Accordingly, the center level of turbine was defined as follows, taking into consideration margin of freeboard and thickness of floor concrete of powerhouse:

Center level of turbine: EL. 1,712.5 m

(2) Dimensions of Power Canal

Dimensions of the power canal were determined as the economical section against the design maximum discharge. The economical section is that which circumscribes the semicircle of radius equal to the water depth.

Dimensions of the power canal were calculated using Manning's formula:

$$Q = \frac{A}{n} \times R^{2/3} \times I^{1/2}$$

Where,

- Q : discharge (m^3/s)
- A : flow area (m^2)
- n : roughness coefficient = 0.015 (-)
- R : hydraulic radius = A/S (m)
- S : wetted perimeter (m)
- I : gradient of water surface = 0.001 (1/1,000)

Free board of the power canal was calculated using the following formula:

$$F_{br} = 0.05 \times h_d + h_v + h_c$$

$$h_v = \alpha \times V^2 / 2g$$

$$h_c = b \times V^2 / (R \times g)$$

Where,

- F_{br} : required free board (m)
- h_d : design flow depth (m)
- h_v : flow velocity head (m)
- h_c : water rising due to curve (m)
- α : flow coefficient = 1.1 (-)
- g : gravity acceleration = 9.8 (m/s^2)
- b : bottom width (m)
- R : curve radius of canal = 5.0 (m)

Flow depths and required free board against given bottom widths of 10 cm interval were calculated as tabulated below.

Table 5.1.2 Trial Calculation of Flow Conditions for Power Canal

Bottom Width b (m)	Flow Depth h (m)	b/h (-)	Flow Area A (m^2)	Hydraulic Radius R (m)	Discharge Q (m^3/s)	Velocity V (m/s)	Velocity Head h_v (m)	Margin for Curve h_c (m)	Free Board F_{br} (m)
0.50	1.82	0.27	0.91	0.22	0.70	0.77	0.03	0.012	0.14
0.60	1.40	0.43	0.84	0.25	0.70	0.83	0.04	0.014	0.12
0.70	1.14	0.61	0.80	0.27	0.70	0.88	0.04	0.016	0.12
0.80	0.96	0.83	0.77	0.28	0.70	0.91	0.05	0.017	0.11
0.90	0.84	1.07	0.76	0.29	0.70	0.93	0.05	0.018	0.11
1.00	0.74	1.35	0.74	0.30	0.70	0.94	0.05	0.018	0.10
1.10	0.67	1.64	0.74	0.30	0.70	0.95	0.05	0.018	0.10
1.20	0.61	1.97	0.73	0.30	0.70	0.95	0.05	0.018	0.10
1.30	0.57	2.30	0.73	0.30	0.70	0.95	0.05	0.018	0.10
1.40	0.53	2.64	0.74	0.30	0.70	0.95	0.05	0.018	0.10

Economical bottom width against the design maximum discharge was seen to be 0.9 m. However, the following dimensions were adopted taking the required free board against flow velocity into consideration:

Inner width of power canal: 1.0 m
 Inner depth of power canal: 1.0 m

(3) Crest Level of Intake Weir

Crest level of intake weir was defined as follows, and the intake water level defined as the crest level.

$$CL = EL_{RB} + h_{sf} + h_0$$

Where, CL : crest level of intake weir (EL.m)
 EL_{RB} : original riverbed level (EL.m)
 h_{sf} : depth for sand deposit and flushing = 0.75 (m)
 h_0 : design water depth of power canal = 0.74 (m)

Table 5.1.3 Calculation of Intake Water Level

Alternative	EL_{RB}	h_{sf}	H_0	CL
Layout A	1,744.5	0.75	0.74	1,746.0
Layout B	1,737.0	0.75	0.74	1,739.5
Layout C	1,728.5	0.75	0.74	1,730.0

5.1.4 Major Dimensions of Alternative Layouts

Based on the above calculations and the topographic map, major dimensions of the three (3) alternative layouts were set as listed below.

Table 5.1.4 Major Dimensions of Alternative Layouts

Item	Unit	Layout A	Layout B	Layout C
1. Overall Plan				
- Design maximum discharge	(m ³ /s)	0.7	0.7	0.7
- Intake water level	(EL. m)	1,746.0	1,739.5	1,730.0
- Turbine center level	(EL. m)	1,712.5	1,712.5	1,712.5
- Gross head	(m)	33.5	27.0	17.5
- Effective head	(m)	31.2	25.1	16.3
- Number of turbines	(nos.)	2	2	2
- Combined efficiency	(%)	72.0	72.0	72.0
- Maximum output	(kW)	154.1	124.0	80.5
2. Intake Weir				
- Design discharge of flush gate	(m ³ /s)	31.8	31.8	31.8
- Height	(m)	2.0	2.0	2.0
- Crest length	(m)	25.0	27.0	29.0
3. Intake and De-Silting Basin				
- Radius of inlet	(m)	0.7	0.7	0.7
- Height of inlet	(m)	0.5	0.5	0.5
- Radius of drainage gate	(m)	0.3	0.3	0.3
4. Power Canal				
- Inner width	(m)	1.0	1.0	1.0
- Inner height	(m)	1.0	1.0	1.0
- Concrete thickness	(m)	0.2	0.2	0.2
- Length	(m)	120.0	105.0	80.0
5. Spillway Canal				
- Inner radius	(m)	0.2	0.2	0.2
- Length	(m)	70.0	55.0	40.0
6. Penstock				
- Inner diameter	(m)	0.6	0.6	0.6
- Length	(m)	110.0	90.0	65.0
7. Tailrace				
- Radius	(m)	0.7	0.7	0.7

5.2 Estimation of Project Cost

Project cost was estimated based on empirical methods and equations compiled in the following references:

- ✓ “Guide Manual for Development Aid Programs and Studies of Hydro Electric Power Development” published by New Energy Foundation, under Ministry of Economy, Trading and Industry of Japan, in December 1996.
- ✓ “Handbook for Estimation of Hydropower Project Costs” published by Agency for Natural Resources, under Ministry of Economy, Trading and Industry of Japan, in March 2013.

These references describe in an understandable manner, the studies involved from the initial planning stage, to the feasibility study stage of development projects. It is intended for hydropower engineers and is based on the rich experience in MHP accumulated in Japan.

Estimation of MHP project cost hereinafter is for comparative study only. Further detailed estimation is therefore required in the next stages.

Project cost is estimated using the following components and empirical methods.

Table 5.2.1 Estimation of Project Cost

Description	Estimation Method
I. Preparatory Works	Access road: assumed length (km) multiple unit prices. Land compensation: 5% of Item II + Item III. Temporary facilities: 20% of Item II + Item III. Environmental mitigation: 3% of Item II.
II. Civil Works	Estimate work quantity of major works of each structure using empirical equations, and the work quantities using multiple unit prices.
III. Electro-mechanical Equipment	Estimate using empirical equation.
IV. Distribution System	Assumed length (km) multiple unit prices.
Sub-total 1 (Direct Cost)	Sum of Item I, II, III, and IV.
V. Administration and Engineering Cost	15% of sub-total 1 (Direct cost)
VI. Physical Contingency	10% of sub-total 1 (Direct cost)
Sub-total 2 (Indirect Cost)	Sum of Item V and VI.
Total	Sum of Sub-total 1 and Sub-total 2 (direct cost and indirect cost).

Source: “Guide Manual for Development Aid Programmes and Studies of Hydro Electric Power Development” and “Handbook for Estimation of Hydropower Project Costs” (arranged by WG).

5.2.1 Civil Works

(1) Estimation of Major Work Quantities

Major work quantities of each alternative layout are estimated as explained hereinafter based on the empirical equations in the references mentioned above.

i) Intake Weir

Intake weir considered is a concrete gravity type.

The following empirical equations are applied. Height of intake weir and design discharge for sand flushing gate are the same for the three (3) alternative layouts, but crest length of the weir is different for each layout. Therefore, different work quantities are applied for each layout.

Table 5.2.2 Empirical Equations of Intake Weir

Description	Empirical Equation	Remarks
a. Excavation (m ³)	$V_e = 0.181 \times (H \times L)^{1.92}$	H: height of weir (m)
b. Concrete (m ³)	$V_c = 11.9 \times (H^2 \times L)^{0.701}$	L: crest length of weir (m)
c. Re-bar (ton)	$W_r = 0.00893 \times V_c^{1.04}$	Q: design discharge of gate (m ³ /s)
d. Sand flush gate (ton)	$W_g = 0.145 \times Q^{0.692}$	
e. Others (L.S.)	30% of sum of the above costs	Grouting, river diversion, etc.

ii) Intake Structure

Intake structure considered is a non-pressure type.

The following empirical equations are applied. Design maximum discharge and inner radius of inlet are the same for the three (3) alternative layouts. Therefore, same work quantities are applied for the three (3) layouts.

Table 5.2.3 Empirical Equations of Intake Structure

Description	Empirical Equation	Remarks
a. Excavation (m ³)	$V_e = 637 \times (R \times Q)^{0.580}$	R: inner radius of inlet (m) Q: design plant discharge (m ³ /s)
b. Concrete (m ³)	$V_c = 43.6 \times (R \times Q)^{1.01}$	
c. Re-bar (ton)	$W_r = 0.0345 \times V_c^{1.05}$	
d. Intake gate (ton)	$W_g = 2.67 \times (R \times Q)^{0.470}$	
e. Intake screen (ton)	$W_s = 1.04 \times (R \times Q)^{0.534}$	
f. Others (L.S.)	25% of sum of the above costs	River diversion, dust collector, etc.

iii) De-silting Basin

De-silting basin considered is a surface type without slab.

The following empirical equations are applied. Design maximum discharge is the same for the three (3) alternative layouts. Therefore, same work quantities are applied for the three (3) layouts.

Table 5.2.4 Empirical Equations of De-silting Basin

Description	Empirical Equation	Remarks
a. Excavation (m ³)	$V_e = 515 \times Q^{1.07}$	Q: design plant discharge (m ³ /s)
b. Concrete (m ³)	$V_c = 188 \times Q^{1.04}$ (without slab)	
c. Re-bar (ton)	$W_r = 0.150 \times V_c^{0.808}$	
d. Drainage gate (ton)	$W_g = 0.910 \times Q^{0.613}$	
e. Drainage screen (ton)	$W_s = 0.696 \times Q^{1.27}$	
f. Others (L.S.)	20% of sum of the above costs	Slope protection, dust collector, etc.

iv) Power Canal

Power canal considered is an open concrete type.

The following empirical equations are applied. Inner width, inner height and thickness of concrete as well as design maximum discharge are the same for the three (3) alternative layouts, but length is different for each layout. Therefore, different work quantities are applied for the three (3) layouts.

Table 5.2.5 Empirical Equations of Power Canal

Description	Empirical Equation	Remarks
a. Excavation (m ³)	$V_e = 1.66 \times \{(B \times H)^{1/2}\}^{2.40} \times L$	B: inner width of canal (m)
b. Concrete (m ³)	$V_c = \{H \times t \times 2 + (B + 2t) \times t\} \times L$	H: inner height of canal (m)
c. Re-bar (ton)	$W_r = 0.0592 \times V_c^{0.896}$	L: Length of canal (m) t: thickness of concrete (m)
d. Others (L.S.)	30% of sum of the above costs	Slope protection, fence, etc.

v) Head Tank

Head tank considered is a surface type without slab.

The following empirical equations are applied. Design maximum discharge is the same for the three (3) alternative layouts. Therefore, same work quantities are applied for the three (3) layouts.

Table 5.2.6 Empirical Equations of Head Tank

Description	Empirical Equation	Remarks
a. Excavation (m ³)	$V_e = 398 \times Q^{1.07}$	Q: design plant discharge (m ³ /s)
b. Concrete (m ³)	$V_c = 66.0 \times Q^{1.14}$	
c. Re-bar (ton)	$W_r = 0.0724 \times V_c$	Slope protection, gate, screen, etc.
d. Others (L.S.)	40% of sum of the above costs	

vi) Spillway Canal

Spillway canal considered is an open concrete type.

The following empirical equations are applied. Inner radius and design maximum discharge are the same for the three (3) alternative layouts, but length is different for each layout. Therefore, different work quantities are applied for the three (3) layouts.

Table 5.2.7 Empirical Equations of Spillway Canal

Description	Empirical Equation	Remarks
a. Excavation (m ³)	$V_e = 17.4 \times R^{1.01} \times L$	R: inner radius of spillway (m)
b. Concrete (m ³)	$V_c = 3.38 \times R^{1.31} \times L$	L: length of spillway
c. Re-bar (ton)	$W_r = 0.0358 \times V_c$	Slope protection, fence, etc.
d. Others (L.S.)	30% of sum of the above costs	

vii) Penstock

Penstock considered is an open type with single lane.

The following empirical equations are applied. Inner diameter and design maximum discharge are the same for the three (3) alternative layouts, but length and effective head are different for each layout. Therefore, different work quantities are applied for the three (3) layouts.

Table 5.2.8 Empirical Equations of Penstock

Description	Empirical Equation	Remarks
a. Excavation (m ³)	$V_e = 12.2 \times D^{1.26} \times L$	D: inner diameter of penstock (m)
b. Concrete (m ³)	$V_c = 2.92 \times D^{1.26} \times L$	L: length of penstock (m)
c. Re-bar (ton)	$W_r = 0.0178 \times V_c$	H _e : effective head (m)
d. Steel penstock (ton)	$W_p = 0.0003 \times H_e + 0.04$	Q: design plant discharge (m ³ /s)
e. Others (L.S.)	20% of sum of the above costs	Grouting, slope protection, etc.

viii) Powerhouse

Powerhouse considered is a surface type.

The following empirical equations are applied. Design discharge and number of turbines are the same for the three (3) alternative layouts, but effective head is different for each layout. Therefore, different work quantities are applied for each layout.

Table 5.2.9 Empirical Equations of Powerhouse

Description	Empirical Equation	Remarks
a. Excavation (m ³)	$V_e = 11.4 \times (Q \times H_e^{2/3} \times n^{1/2})^{0.952}$	Q: design plant discharge (m ³ /s)
b. Concrete (m ³)	$V_c = 6.79 \times (Q \times H_e^{2/3} \times n^{1/2})^{0.824}$	H _e : effective head (m)
c. Re-bar (ton)	$W_r = 0.0326 \times V_c^{1.04}$	n: number of turbine (nos.)
d. Others (L.S.)	50% of sum of the above costs	Building works, drainage, etc.

ix) Tailrace

Tailrace considered is a non-pressure type without tailrace gate.

The following empirical equations are applied. Design discharge is the same for the three (3) alternative layouts. Therefore, same work quantities are applied for the three (3) layouts.

Table 5.2.10 Empirical Equations of Tailrace

Description	Empirical Equation	Remarks
a. Excavation (m ³)	$V_e = 164 \times (R \times Q)^{0.532}$	R: radius of tailrace (m)
b. Concrete (m ³)	$V_c = 36.4 \times (R \times Q)^{0.353}$	Q: design plant discharge (m ³ /s)
c. Re-bar (ton)	$W_r = 0.113 \times V_c^{0.823}$	
d. Others (L.S.)	25% of sum of the above cost.	River diversion, slope protection, etc.

x) Miscellaneous

5% of the sum of the amounts in items 1) to 9) is budgeted for miscellaneous works.

(2) Applied Unit Prices

The following unit prices are applied for the estimation.

Table 5.2.11 Applied Unit Prices for the Estimation

Work Item	Unit	Unit Price	Source
1. Access Road	KSh./km	2,000,000	Assumed by REA
2. Excavation	KSh./m ³	1,075	Current Construction Costs Handbook 2012/13 (Published by Cost Planning Unit of the Quantities and Contracts Department, Ministry of Public Works)
3. Concrete	KSh./m ³	13,400	
4. Re-bar	KSh./ton	140,000	
5. Metal works (Gate)	KSh./ton	696,000	
6. Metal works (Screen)	KSh./ton	435,000	Assumed by WG (5,000 USD/ton)
7. Metal works (Steel Penstock)	KSh./ton	348,000	Assumed by WG (4,000 USD/ton)
8. Distribution Line	KSh./km	2,500,000	Assumed by REA

Notes: 1. Unit price of excavation is assumed to be the average of common excavation and rock excavation: $(350 + 1,800) / 2 = 1,075$ KSh./m³
2. Applied exchange rate: 1 USD = 87 KSh.

(3) Direct Cost of Civil Works

Direct cost of civil works for each alternative layout is calculated as the work quantities estimated by empirical equations multiplied by the unit prices as shown in the following Table 5.2.12, 5.2.13, and 5.2.14, respectively.

Table 5.2.12 Direct Cost of Civil Works of Layout A

Description	Unit	Unit Price		Quantity	Amount	
		KSh.	USD		KSh.	USD
1 Intake Weir					7,772,900	89,344
a. Excavation	m ³	1,075	(12)	331	355,900	4,091
b. Concrete	m ³	13,400	(154)	301	4,033,400	46,361
c. Re-bar	ton	140,000	(1,609)	3.4	476,000	5,471
d. sand flush gate	ton	(696,000)	8,000	1.6	1,113,600	12,800
e. Others	L.S.				1,794,000	20,621
2 Intake Structure					3,268,500	37,569
a. Excavation	m ³	1,075	(12)	422	453,700	5,215
b. Concrete	m ³	13,400	(154)	22	294,800	3,389
c. Re-bar	ton	140,000	(1,609)	0.9	126,000	1,448
d. Intake gate	ton	(696,000)	8,000	2.0	1,392,000	16,000
e. Intake screen	ton	(435,000)	5,000	0.8	348,000	4,000
f. Others	L.S.				654,000	7,517
3 Settling Basin					4,724,700	54,307
a. Excavation	m ³	1,075	(12)	352	378,400	4,349
b. Concrete	m ³	13,400	(154)	130	1,742,000	20,023
c. Re-bar	ton	140,000	(1,609)	7.7	1,078,000	12,391
d. Drainage gate	ton	(696,000)	8,000	0.8	556,800	6,400
e. Drainage screen	ton	(435,000)	5,000	0.5	217,500	2,500
f. Others	L.S.				752,000	8,644
4 Power Canal					2,272,800	26,124
a. Excavation	m ³	1,075	(12)	200	215,000	2,471
b. Concrete	m ³	13,400	(154)	82	1,098,800	12,630
c. Re-bar	ton	140,000	(1,609)	3.1	434,000	4,989
d. Others	L.S.				525,000	6,034
5 Head Tank					1,862,000	21,402
a. Excavation	m ³	1,075	(12)	272	292,400	3,361
b. Concrete	m ³	13,400	(154)	44	589,600	6,777
c. Re-bar	ton	140,000	(1,609)	3.2	448,000	5,149
d. Others	L.S.				532,000	6,115
6 Spillway channel					519,350	5,970
a. Excavation	m ³	1,075	(12)	18	19,350	222
b. Concrete	m ³	13,400	(154)	20	268,000	3,080
c. Re-bar	ton	140,000	(1,609)	0.8	112,000	1,287
d. Others	L.S.				120,000	1,379
7 Penstock					7,532,350	86,579
a. Excavation	m ³	1,075	(12)	706	758,950	8,724
b. Concrete	m ³	13,400	(154)	169	2,264,600	26,030
c. Re-bar	ton	140,000	(1,609)	3.1	434,000	4,989
d. Steel Penstock	t	(348,000)	4,000	5.5	1,914,000	22,000
e. Inlet gate	ton	(696,000)	8,000	1.3	904,800	10,400
f. Others	L.S.				1,256,000	14,437
8 Powerhouse					1,445,575	16,616
a. Excavation	m ³	1,075	(12)	101	108,575	1,248
b. Concrete	m ³	13,400	(154)	45	603,000	6,931
c. Re-bar	ton	140,000	(1,609)	1.8	252,000	2,897
d. Others	L.S.				482,000	5,540
9 Tailrace					971,075	11,162
a. Excavation	m ³	1,075	(12)	113	121,475	1,396
b. Concrete	m ³	13,400	(154)	29	388,600	4,467
c. Re-bar	ton	140,000	(1,609)	1.9	266,000	3,057
d. Others	L.S.				195,000	2,241
10 Miscellaneous	L.S.				1,519,000	17,460
Total				(Roundup)	31,888,250	366,532
					31,889,000	366,540

Table 5.2.13 Direct Cost of Civil Works of Layout B

Description	Unit	Unit Price		Quantity	Amount	
		KSh.	USD		KSh.	USD
1 Intake Weir					8,162,200	93,818
a. Excavation	m ³	1,075	(12)	384	412,800	4,745
b. Concrete	m ³	13,400	(154)	317	4,247,800	48,825
c. Re-bar	ton	140,000	(1,609)	3.6	504,000	5,793
d. sand flush gate	ton	(696,000)	8,000	1.6	1,113,600	12,800
e. Others	L.S.				1,884,000	21,655
2 Intake Structure					3,268,500	37,569
a. Excavation	m ³	1,075	(12)	422	453,700	5,215
b. Concrete	m ³	13,400	(154)	22	294,800	3,389
c. Re-bar	ton	140,000	(1,609)	0.9	126,000	1,448
d. Intake gate	ton	(696,000)	8,000	2.0	1,392,000	16,000
e. Intake screen	ton	(435,000)	5,000	0.8	348,000	4,000
f. Others	L.S.				654,000	7,517
3 Settling Basin					4,724,700	54,307
a. Excavation	m ³	1,075	(12)	352	378,400	4,349
b. Concrete	m ³	13,400	(154)	130	1,742,000	20,023
c. Re-bar	ton	140,000	(1,609)	7.7	1,078,000	12,391
d. Drainage gate	ton	(696,000)	8,000	0.8	556,800	6,400
e. Drainage screen	ton	(435,000)	5,000	0.5	217,500	2,500
f. Others	L.S.				752,000	8,644
4 Power Canal					2,008,925	23,091
a. Excavation	m ³	1,075	(12)	175	188,125	2,162
b. Concrete	m ³	13,400	(154)	72	964,800	11,090
c. Re-bar	ton	140,000	(1,609)	2.8	392,000	4,506
d. Others	L.S.				464,000	5,333
5 Head Tank					1,862,000	21,402
a. Excavation	m ³	1,075	(12)	272	292,400	3,361
b. Concrete	m ³	13,400	(154)	44	589,600	6,777
c. Re-bar	ton	140,000	(1,609)	3.2	448,000	5,149
d. Others	L.S.				532,000	6,115
6 Spillway channel					409,525	4,707
a. Excavation	m ³	1,075	(12)	15	16,125	185
b. Concrete	m ³	13,400	(154)	16	214,400	2,464
c. Re-bar	ton	140,000	(1,609)	0.6	84,000	966
d. Others	L.S.				95,000	1,092
7 Penstock					6,281,075	72,196
a. Excavation	m ³	1,075	(12)	577	620,275	7,130
b. Concrete	m ³	13,400	(154)	139	1,862,600	21,409
c. Re-bar	ton	140,000	(1,609)	2.5	350,000	4,023
d. Steel Penstock	t	(348,000)	4,000	4.3	1,496,400	17,200
e. Inlet gate	ton	(696,000)	8,000	1.3	904,800	10,400
f. Others	L.S.				1,047,000	12,034
8 Powerhouse					1,282,600	14,743
a. Excavation	m ³	1,075	(12)	88	94,600	1,087
b. Concrete	m ³	13,400	(154)	40	536,000	6,161
c. Re-bar	ton	140,000	(1,609)	1.6	224,000	2,575
d. Others	L.S.				428,000	4,920
9 Tailrace					971,075	11,162
a. Excavation	m ³	1,075	(12)	113	121,475	1,396
b. Concrete	m ³	13,400	(154)	29	388,600	4,467
c. Re-bar	ton	140,000	(1,609)	1.9	266,000	3,057
d. Others	L.S.				195,000	2,241
10 Miscellaneous	L.S.				1,449,000	16,655
Total				(Roundup)	30,419,600	349,651
					30,420,000	349,655

Table 5.2.14 Direct Cost of Civil Works of Layout C

Description	Unit	Unit Price		Quantity	Amount	
		KSh.	USD		KSh.	USD
1 Intake Weir					8,574,300	98,555
a. Excavation	m ³	1,075	(12)	441	474,100	5,449
b. Concrete	m ³	13,400	(154)	334	4,475,600	51,444
c. Re-bar	ton	140,000	(1,609)	3.8	532,000	6,115
d. sand flush gate	ton	(696,000)	8,000	1.6	1,113,600	12,800
e. Others	L.S.				1,979,000	22,747
2 Intake Structure					3,268,500	37,569
a. Excavation	m ³	1,075	(12)	422	453,700	5,215
b. Concrete	m ³	13,400	(154)	22	294,800	3,389
c. Re-bar	ton	140,000	(1,609)	0.9	126,000	1,448
d. Intake gate	ton	(696,000)	8,000	2.0	1,392,000	16,000
e. Intake screen	ton	(435,000)	5,000	0.8	348,000	4,000
f. Others	L.S.				654,000	7,517
3 Settling Basin					4,724,700	54,307
a. Excavation	m ³	1,075	(12)	352	378,400	4,349
b. Concrete	m ³	13,400	(154)	130	1,742,000	20,023
c. Re-bar	ton	140,000	(1,609)	7.7	1,078,000	12,391
d. Drainage gate	ton	(696,000)	8,000	0.8	556,800	6,400
e. Drainage screen	ton	(435,000)	5,000	0.5	217,500	2,500
f. Others	L.S.				752,000	8,644
4 Power Canal					1,544,975	17,758
a. Excavation	m ³	1,075	(12)	133	142,975	1,643
b. Concrete	m ³	13,400	(154)	55	737,000	8,471
c. Re-bar	ton	140,000	(1,609)	2.2	308,000	3,540
d. Others	L.S.				357,000	4,103
5 Head Tank					1,862,000	21,402
a. Excavation	m ³	1,075	(12)	272	292,400	3,361
b. Concrete	m ³	13,400	(154)	44	589,600	6,777
c. Re-bar	ton	140,000	(1,609)	3.2	448,000	5,149
d. Others	L.S.				532,000	6,115
6 Spillway channel					315,625	3,628
a. Excavation	m ³	1,075	(12)	11	11,825	136
b. Concrete	m ³	13,400	(154)	12	160,800	1,848
c. Re-bar	ton	140,000	(1,609)	0.5	70,000	805
d. Others	L.S.				73,000	839
7 Penstock					4,787,075	55,024
a. Excavation	m ³	1,075	(12)	417	448,275	5,153
b. Concrete	m ³	13,400	(154)	100	1,340,000	15,402
c. Re-bar	ton	140,000	(1,609)	1.8	252,000	2,897
d. Steel Penstock	t	(348,000)	4,000	3.0	1,044,000	12,000
e. Inlet gate	ton	(696,000)	8,000	1.3	904,800	10,400
f. Others	L.S.				798,000	9,172
8 Powerhouse					1,003,825	11,538
a. Excavation	m ³	1,075	(12)	67	72,025	828
b. Concrete	m ³	13,400	(154)	32	428,800	4,929
c. Re-bar	ton	140,000	(1,609)	1.2	168,000	1,931
d. Others	L.S.				335,000	3,851
9 Tailrace					971,075	11,162
a. Excavation	m ³	1,075	(12)	113	121,475	1,396
b. Concrete	m ³	13,400	(154)	29	388,600	4,467
c. Re-bar	ton	140,000	(1,609)	1.9	266,000	3,057
d. Others	L.S.				195,000	2,241
10 Miscellaneous	L.S.				1,353,000	15,552
Total				(Roundup)	28,405,075	326,495
					28,406,000	326,506

5.2.2 Electrical Equipment

Electrical equipment is defined as all equipment for MHP including inlet valve, turbine, generator, transformers, and all attachments of these equipments. The direct cost of electro-mechanical equipment is given by the following empirical equation in the references:

$$C_E = 7.09 \times \left(\frac{P_{max}}{\sqrt{H_e}} \right)^{0.774} \times F$$

$$F = 1,000,000 \times 0.3/80 = 3,750$$

Where,

C_E : direct cost of electrical equipment (USD)

P_{max} : maximum output (kW)

H_e : effective head (m)

F : conversion factor from Japanese Yen to US Dollar (USD)

The existing small hydropower projects in Kenya procured electrical equipment from Europe and/or India. The direct cost of equipment from Europe and India is approximately 30% of the direct cost should equipment be procured from Japan, based on interview results and the experience of JICA expert.

Additionally, the original empirical equation in the references gives direct cost of equipment in million Japanese Yen. It is therefore necessary to convert the direct cost into USD by dividing it by the current exchange rate for the JPY. The exchange rate was 1 USD = 80 JPY in 2013 when the empirical equation was created.

Table 5.2.15 Direct Costs of Electrical Equipment

Alternative	P_{max} (kW)	H_e (m)	C_E (USD)	C_E (KSh.)	kW/USD
Layout A	154.1	31.2	346,580	30,153,000	2,249
Layout B	124.0	25.1	318,650	27,723,000	2,570
Layout C	80.5	16.3	269,560	23,452,000	3,349

Note: 1 USD = 87 KSh

5.2.3 Distribution System

Direct cost of distribution system is estimated to be the same for each alternative layout as follows:

Estimated total length of distribution line:	10 km
Estimated unit price per km:	2,500,000 KSh./km
Direct cost of distribution system:	25,000,000 KSh.

5.2.4 Preparatory Works

The preparatory works considered are as explained below.

i) Access Road

Construction cost of access road is estimated to be the same for each alternative layout as follows:

Estimated total length of access road:	6 km
Estimated unit price per km:	2,000,000 KSh./km
Direct cost of access road:	12,000,000 KSh.

ii) Land Compensation

Land compensation cost is not considered as land for the MHP project was already earmarked by the Asurur Multiple Water Project Group.

iii) Temporary Facilities

Cost of temporary facilities is estimated by empirical ratio of direct cost of civil works and electrical equipment as follows:

Cost of temporary facilities = 20% of Direct cost of civil works and electrical equipment

iv) Environmental Mitigation Measures

Cost of environmental mitigation measures during the construction is estimated by empirical ratio of direct cost of civil works as follows:

Cost of environmental mitigation measures = 3% of Direct cost of civil works

The cost of preparatory works of each alternative layout was calculated as follows:

Table 5.2.16 Cost of Preparatory Works

(Unit: KSh.)

Description	Layout A	Layout B	Layout C	Reference
II. Direct cost of Civil Works	31,889,000	30,420,000	28,406,000	T 5.2.12 - 14
III. Direct Cost of Electrical Equipment	30,153,000	27,723,000	23,452,000	T 5.2.15
Sub-total (II + III)	62,042,000	58,143,000	51,858,000	
1. Access Road	12,000,000	12,000,000	12,000,000	
2. Land Compensation	0	0	0	
3. Temporary Facilities	12,409,000	11,629,000	10,372,000	(II+III) x 20%
4. Environmental Mitigation Measures	957,000	913,000	853,000	(II) x 3%
Total of Preparatory Works	25,366,000	24,542,000	23,225,000	

5.2.5 Project Cost of each Alternative Layout

Project cost of each alternative layout is estimated as shown in the following tables.

Table 5.2.17 Estimation of Project Costs

(Unit: KSh.)

Description	Layout A	Layout B	Layout C	Reference
I. Preparatory Works	25,366,000	24,542,000	23,225,000	T 5.2.16
II. Civil Works	31,889,000	30,420,000	28,406,000	T 5.2.12 – 14
III. Electro-mechanical Equipment	30,153,000	27,723,000	23,452,000	T 5.2.15
IV. Distribution System	25,000,000	25,000,000	25,000,000	
Sub-total 1 (Direct Cost)	112,408,000	107,685,000	100,083,000	
V. Administration and Engineering Cost	16,862,000	16,153,000	15,013,000	Direct x 15%
VI. Physical Contingency	11,241,000	10,769,000	10,009,000	Direct x 10%
Sub-total 2 (Indirect Cost)	28,103,000	26,922,000	25,022,000	
Total	140,511,000	134,607,000	125,105,000	

5.3 Selection of Optimum Development Layout

Alternative plans are compared in terms of economic feasibility by the following two indexes.

i) Benefit-Cost Method

$$B/C \geq 1, \text{ or } B - C \geq 0:$$

MHP is economically better than the thermal power alternative

$$B/C < 1, \text{ or } B - C < 0:$$

MHP is economically less attractive than the thermal power alternative.

Where an alternative plan shows higher B/C value than others, the alternative plan is judged to be more economically attractive than the others.

ii) Generation Cost Method

$$C_G = Ch / E \times \alpha$$

Where,

C_G : generation cost (KSh./kWh)

C_h : construction cost (KSh.)

E : annual energy generation (kWh)

α : annual cost factor = 0.10 to 0.12 (-)

Where an alternative layout shows cheaper generation cost value (C_G) than others, the alternative layout is judged to be more economically attractive than the others.

Benefit (B), cost (C) and generation cost (C_G) of each alternative layout were obtained as explained hereinafter.

5.3.1 Estimation of Project Benefit

Benefit of Asurur MHP scheme is estimated to be the cost of an alternative thermal power plant that supplies electricity equivalent to Asurur MHP. A diesel thermal plant is a possible alternative thermal power installation.

The annualized benefit (B) consists of kW benefit and kWh benefits as given by the following formula:

$$B = B_1 + B_2$$

Where,
 B_1 : kW benefit (KSh.)
 B_2 : kWh benefit (KSh.)

(1) Estimation of kW Benefit

The kW benefit (B_1) is the product of effective output, output by the minimum design discharge, and kW value as given by the following formula:

$$B_1 = P_h \times b_1$$

$$P_h = 9.8 \times Q_{min} \times H_e \times \eta$$

$$b_1 = Ct \times \alpha \times \beta$$

$$= 30,000 \times 0.15 \times 1.1$$

$$= 4,950$$

Where,
 P_h : effective output (kW)
 B_1 : kW value (KSh./kW)
 Q_{min} : minimum plant discharge = 0.1 (m³/s)
 H_e : effective head (m)
 η : combined efficiency = 72%
 b_1 : kW value (-)
 C_t : unit construction cost of alternative thermal power 30,000 (KSh./kW)
 α : annual cost factor of alternative thermal power = 15%
 β : kW adjustment factor = 1.1 (-)
 This is the adjustment factor of reliability between hydropower and thermal power (ratio of station use, forced outage and scheduled outage).

The effective output and kW benefit of each alternative layout were calculated as follows:

Table 5.3.1 Effective Output and kW Benefit

Alternative	Q_{min} (m ³ /s)	H_e (m)	η (%)	P_h (kW)	b_1 (KSh./kW)	B_1 (KSh.)
Layout A	0.1	31.2	72.0	22.0	4,950	108,900
Layout B	0.1	25.1	72.0	17.7	4,950	87,615
Layout C	0.1	16.3	72.0	11.5	4,950	56,925

(2) Estimation of kWh Benefit

The kWh benefit (B_2) is the product of annual energy generation and kWh value as given by the following formula:

$$B_2 = E \times b_2$$

$$E = 8,760 \times \xi \times P$$

$$b_2 = R_h \times P_f = \frac{860}{T_e} \times P_f$$

$$= 860 / 0.35 \times 0.012 = 24.49$$

Where,
 E : annual energy generation (kWh)
 b_2 : kWh value (KSh./kWh)
 ξ : plant factor = 72.5%
 P : maximum output (kW)
 R_h : heat consumption rate (kcal/kWh)
 P_f : unit price of fuel (KSh./kcal)
 $= 110$ (KSh./l) / 9,126 (kcal/l) = 0.012 (KSh./kcal)
 T_e : thermal efficiency = 35%

The annual energy generation and kWh benefit of each alternative layout were calculated as follows:

Table 5.3.2 Annual Energy Generation and kWh Benefit

Alternative	ξ (%)	P (kW)	E (kWh)	b_2 (KSh./kWh)	B_2 (KSh.)
Layout A	72.5	154.1	978,689	24.49	28,861,542
Layout B	72.5	124.0	787,524	24.49	23,224,083
Layout C	72.5	80.5	511,256	24.49	15,076,925

(3) Annualized Benefit

The annualized benefit of each alternative layout was the sum of kW benefit and kWh benefit as shown in the table below.

Table 5.3.3 Estimated Annualized Benefit

Item	Layout A	Layout B	Layout C	Reference
kW Benefit (B_1)	108,900	87,615	56,925	T 5.3.1
kWh Benefit (B_2)	28,861,542	23,224,083	15,076,925	T 5.3.2
Benefit ($B = B_1 + B_2$)	28,970,442	23,311,698	15,133,850	

(Unit: KSh./year)

5.3.2 Annualized Project Cost

Annualized project cost is calculated as follows:

Annualized Cost (C)

$$C = Ch \times \alpha$$

$$\alpha = RCF + OM = \frac{i \times (1+i)^n}{(1+i)^n - 1} + OM$$

$$= 0.11$$

Where,

 Ch : project cost RCF : capital recovery factor i : interest rate = 10 % n : service line (year) = 50 years OM : ratio of operation and maintenance cost = 1%**Table 5.3.4 Estimated Annualized Cost**

Item	Layout A	Layout B	Layout C	Reference
Project Cost (C_h)	140,511,000	134,607,000	125,105,000	T 5.2.17
Annual Cost Factor (α)	11.0%	11.0%	11.0%	
Annualized Cost (C)	15,456,210	14,806,770	13,761,550	

5.3.3 Evaluation by Benefit – Cost Method

Benefit (B), cost (C) and their corresponding ratios are summarized in the table below. As seen the table, Layout A and Layout B show B / C values higher than 1.0. Asurur MHP is therefore economically better than the diesel power alternative, and Layout A is the most feasible alternative in economic terms.

Table 5.3.5 Benefit and Cost of each Alternative

Item	Layout A	Layout B	Layout C	Reference
Annualized Project Benefit (B)	28,970,442	23,311,698	15,133,850	T 5.3.3
Annualized Project Cost (C)	15,456,210	14,806,770	13,761,550	T 5.3.4
B / C	1.87	1.57	1.10	
B – C	13,514,232	8,504,928	1,372,300	

(Unit: KSh./year)

5.3.4 Evaluation by Generation Cost Method

The generation cost (C_G) of each alternative is shown below. As seen in the table, Layout A has the cheapest generation cost value (C_G), and is therefore more economically attractive than the others.

Table 5.3.6 Generation Cost of each Alternative

Item				(Unit: KSh./year)
	Layout A	Layout B	Layout C	Reference
Project Cost (Ch)	140,511,000	134,607,000	125,105,000	T 5.2.17
Annual Energy Generation (E)	978,689	787,524	511,256	T 5.3.2
Annual Cost Factor (α)	11.0%	11.0%	11.0%	T 5.3.4
Generation Cost ($C_G = Ch / E \times \alpha$)	15.79	18.80	26.92	

5.3.5 Selection of Optimum Layout

Layout A shows better indicative values through both benefit – cost method and generation cost method. Accordingly, it is judged that Layout A is the most optimum layout amongst the three (3) alternative layouts.

Preliminary drawings of Layout A are included in Annex-3.

CHAPTER 6 RECOMMENDATIONS FOR THE NEXT STAGE

The study was conducted within a context of limited time, data and information. Despite this, it was clearly determined that the selected Layout A is a relatively advantageous development plan. However, the estimated power generation was smaller than the forecasted power demand.

It is recommended that the following issues are considered in the next stage.

(1) Continuous Observation of Water Level

As seen in the hydrological analysis in Chapter 4, there is a discrepancy between the results of analyzed discharges based on the existing data and the observed discharges. It is likely that actual river discharge is larger than the defined design plant discharges.

Therefore, it is recommended to record water level at the site on daily basis in normal conditions and hourly basis during flood conditions. Water level at the site is valuable information for the estimation of flow duration. It is further recommended to review hydrological analysis using the actual water level records in order to increase the accuracy of dependable discharge at the site.

(2) Study on Height of the Intake Weir

The comparative study was carried out based on fixed condition of intake weir at minimum height. It is possible to secure some storage capacity for several hours by increasing the height at which the intake weir is set. In this case, natural environmental impacts due to enlargement of pondage area will increase but power generation appropriately corresponding to power demand will become possible.

Therefore, it is recommended to study the optimum height of the intake weir in terms of power generation, construction cost and environmental impacts.

(3) Obtain Quotation for Electrical Equipment

Cost of electrical equipment was estimated as a lump sum using empirical equation. It is necessary to obtain price quotations for electrical equipment in order to increase the accuracy of estimation of development cost.

(4) Study on Other Power Sources

In case Asurur MHP does not generate adequate electricity to meet forecasted power demand, other power sources shall be studied. Two (2) alternatives; i) hybrid generation of MHP and diesel generator, and ii) grid connection if the area is located near the existing grid, are possible.

It is recommended to carry out a comparative study on the optimum power development plan to satisfy the current forecasted power demand as well as potential future power demand.

Annex 1

Discharge Observation Sheets at Asurur Site

List of Observation Sheet

Observation Sheet on 21 June 2012	43
Observation Sheet on 22 June 2012	44
Observation Sheet on 26 July 2012.....	45
Observation Sheets on 13 August 2012	46
Observation Sheets on 14 August 2012	48
Observation Sheets on 27 August 2012	50
Observation Sheets on 28 August 2012	52
Observation Sheets on 29 August 2012	54
Observation Sheets on 10 September 2012.....	56
Observation Sheets on 11 September 2012.....	58
Observation Sheets on 12 September 2012.....	60
Observation Sheets on 23 September 2012.....	62
Observation Sheets on 24 September 2012.....	64
Observation Sheets on 25 September 2012.....	66
Observation Sheets on 30 January 2014.....	68

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS										
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)					
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds			
							1st	2nd	Average	
1	0	0.00	0.00	0.000						
2	1	0.34	0.33	0.335	0.201	140	=(10 x 14)	31.90		31.900
					0.201	150	=(10 x 15)	32.90		32.900
3	2	0.47	0.46	0.465						
4	3	0.45	0.44	0.445	0.267	70	=(10 x 7)	34.30		34.300
					0.267	100	=(10 x 10)	35.10		35.100
5	4	0.45	0.43	0.440						
6	5	0.34	0.33	0.335	0.201	100	=(10 x 10)	30.90		30.900
					0.201	130	=(10 x 13)	32.10		32.100
7	6	0.29	0.28	0.285						
8	7	0.25	0.25	0.250	0.150	100	=(10 x 10)	31.30		31.300
					0.150	110	=(10 x 11)	31.70		31.700
9	8	0.33	0.33	0.330						
10	9	0.17	0.17	0.170	0.102	100	=(10 x 10)	40.40		40.400
					0.102	90	=(10 x 9)	33.10		33.100
11	9.3	0.00	0.00	0.000						
12										
13										
14										
15										
16										
17										
18										
19										
20										

HOME WORKS							Station No.		Downstream of the culvert		
Velocity		Area of cross section			Discharge (m ³ /s)	Observation Date		Yr: 2012	Mon: 6	Date: 21	
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)		Observer Name	Mesure Wrote	Ezekiel, Reuben Ueda			
0.721	0.735	0.17	1.00	0.17	0.57	0.42	Weather	:clear, :fine, :cloudy, :rain			
0.749		0.40	1.00	0.40			Wind blows	from Down/s, Up/s, Left, Right			
0.341	0.407	0.46	1.00	0.46	0.90	0.37	Measurement Time (Hour, min)	Start			
0.472		0.44	1.00	0.44			Average				
0.534	0.600	0.39	1.00	0.39	0.70	0.42	Water Level at gauging station (m)	Initial Point	No.1 Point		
0.666		0.31	1.00	0.31			Start				
0.528	0.550	0.27	1.00	0.27	0.56	0.31	Current meter	Type of current meter	Digital		
0.572		0.29	1.00	0.29			Table/formula	V = 0.162 * N + 0.010			
0.411	0.431	0.25	1.00	0.25	0.28	0.12	Using method	lods · wire · weight			
0.450		0.09	0.30	0.03			by boat / bridge / walk				
							Calculator	Calculator			
							Checker	Checker			
							Result	Total Discharge (m ³ /s)	1.64		
								Total area cross section(m ²)	3.01		
								Average Velocity (m/s)	0.54		
							Notes	Catchment Area (km ²)= 35.0 Discharge (m ³ /s)= 1.64 Specific Discharge (m ³ /s*100km ²)= 4.69			
							Remark:				

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS									
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)				
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds		
							1st	2nd	Average
1	0	0.00	0.00	0.000					
2	1	0.64	0.64	0.640	0.384	50	=(10 x 5)	34.50	34.500
3	2	0.49	0.48	0.485					
4	3	0.55	0.56	0.555	0.333	50	=(10 x 5)	32.30	32.300
5	4	0.48	0.45	0.465					
6	5	0.48	0.49	0.485	0.291	180	=(10 x 18)	30.80	30.800
7	6	0.44	0.44	0.440					
8	7	0.46	0.45	0.455	0.273	90	=(10 x 9)	31.00	31.000
9	8	0.27	0.22	0.245					
10	8.6	0.00	0.00	0.000	0.000	0	=(10 x 0)	0.00	0.000
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									

HOME WORKS						Station No.		Downstream of the fall		
Velocity		Area of cross section			Discharge (m ³ /s)	Observation Date		Yr: 2012	Mon: 6	Date: 22
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)		Observer Name	Mesure Wrote	Ezekiel, Reuben Ueda		
0.245	0.245	0.32	1.00	0.32	0.88	0.22	Weather	clear, fine, cloudy, rain	Wind blows from Down/s, Up/s, Left, Right	
		0.56	1.00	0.56			Wind power	0=None, 1=light, 2=windy, 3=strong, 4=very strong		
0.261	0.261	0.52	1.00	0.52	1.03	0.27	Mesurement Time (Hour, min)	Start	End	
		0.51	1.00	0.51			Water Level at gauging station (m)	Average	Initial Point	No.1 Point
0.957	0.957	0.48	1.00	0.48	0.94	0.90		Start	End	
		0.46	1.00	0.46				Average		
0.480	0.480	0.45	1.00	0.45	0.80	0.38	Current meter	Type of current meter		Digital
		0.35	1.00	0.35				Table/formula	V = 0.162 * N + 0.010	
		0.12	0.60	0.07			Useing method	lods · wire · weight by boat / bridge / walk		
0.000	0.000						Calculator	Calculator	Checker	
								Total Discharge (m ³ /s)	1.77	
							Result	Total area cross section(m ²)	3.72	
								Average Velocity(m/s)	0.48	
Notes										
								Catchment Area (km ²)=	35.0	
								Discharge (m ³ /s)=	1.77	
								Specific Discharge (m ³ /s*100km ²)=	5.06	
Remark:										

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS										
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)					
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds			
							1st	2nd	Average	
1	0	0.00	0.00	0.000						
2	1	0.33	0.32	0.325	0.195	160	=(10 x 16)	32.10	32.10	32.100
3	2	0.42	0.42	0.420						
4	3	0.50	0.49	0.495	0.297	160	=(10 x 16)	32.00	32.80	32.400
5	4	0.39	0.38	0.385						
6	5	0.23	0.22	0.225	0.135	130	=(10 x 13)	31.40	31.90	31.650
7	6	0.27	0.29	0.280						
8	7	0.21	0.22	0.215	0.129	150	=(10 x 15)	31.50	27.60	29.550
9	8	0.33	0.33	0.330						
10	9.1	0.00	0.00	0.000	0.000	0	=(10 x 0)	0.00	0.00	0.000
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										

HOME WORKS						Station No.		Downstream of the culvert			
Velocity		Area of cross section			Discharge (m ³ /s)	Observation Date		Yr: 2012	Mon: 7	Date: 26	
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)		Observer Name	Mesure Wrote	Ezekiel Ueda			
0.817	0.817	0.16	1.00	0.16	0.53	0.43	Weather	clear	fine	cloudy	rain
		0.37	1.00	0.37			Wind blows	from Down/s, Up/s, Left, Right			
		0.46	1.00	0.46	0.90	0.73	Wind power	0 None, 1 light, 2 windy, 3 strong, 4 very strong			
0.810	0.810	0.44	1.00	0.44			Mesurement Time (Hour, min)	Start			
		0.31	1.00	0.31			End				
		0.25	1.00	0.25			Average				
0.675	0.675	0.25	1.00	0.25			Water Level at gauging station (m)	Initial Point	No.1 Point		
		0.25	1.00	0.25	0.56	0.38		Start			
		0.25	1.00	0.25			End				
0.832	0.832	0.27	1.00	0.27	0.52	0.43	Average				
		0.17	1.10	0.19			Current meter	Type of current meter			
								Digital			
							Table/formula	V = 0.162 * N + 0.010			
							Using method	tods · wire · weight			
							Calculator	by boat / bridge / walk			
							Calculator				
							Checker				
0.000	0.000				0.19	0.00	Result	Total Discharge (m ³ /s)		1.97	
								Total area cross section(m ²)		2.70	
								Average Velocity(m/s)		0.73	
							Notes	Catchment Area (km ²)= 35.0			
								Discharge (m ³ /s)= 1.97			
								Specific Discharge (m ³ /s*100km ²)= 5.63			
							Remark:				

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS										
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)					
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds			
							1st	2nd	Average	
1	0	0.00	0.00	0.000						
2	1	0.32	0.32	0.320	0.192	140	=(10 x 14)	42.26		42.260
					0.192	150	=(10 x 15)	46.37		46.370
3	2	0.38	0.39	0.385						
4	3	0.42	0.44	0.430	0.258	80	=(10 x 8)	14.79		14.790
					0.258	100	=(10 x 10)	18.63		18.630
5	4	0.34	0.33	0.335						
6	5	0.26	0.27	0.265	0.159	100	=(10 x 10)	35.03		35.030
					0.159	130	=(10 x 13)	48.47		48.470
7	6	0.24	0.24	0.240						
8	7	0.23	0.24	0.235	0.141	110	=(10 x 11)	42.67		42.670
					0.141	100	=(10 x 10)	42.40		42.400
9	8	0.17	0.17	0.170						
10	9	0.00	0.00	0.000	0.000	100	=(10 x 10)	32.97		32.970
					0.000	90	=(10 x 9)	29.42		29.420
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										

HOME WORKS							Station No.		Downstream of the culvert		
Velocity		Area of cross section			Discharge (m ³ /s)	Observation Date		Yr: 2012	Mon: 8	Date: 13	
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)		Observer Name	Mesure Wrote	Ezekiel, Reuben			
0.547	0.541	0.16	1.00	0.16	0.51	0.28	Weather	clear	fine	cloudy	rain
0.534		0.35	1.00	0.35			Wind blows	from Down/s, Up/s, Left, Right			
							Wind power	0 None, 1 light, 2 windy, 3 strong, 4 very strong			
							Mesurement Time (Hour, min)	Start	10:30 AM		
								End	12:00 PM		
0.886	0.883	0.41	1.00	0.41	0.79	0.70	Average	11:15 AM			
0.880		0.38	1.00	0.38			Water Level at gauging station (m)	Initial Point	No.1 Point		
								Start			
0.472	0.458	0.30	1.00	0.30	0.55	0.25	End				
0.444		0.25	1.00	0.25			Average				
							Type of current meter	Digital			
							Table/formula	V = 0.162 * N + 0.010			
							Using method	lods + wire + weight			
0.428	0.410	0.24	1.00	0.24	0.44	0.18		by boat / bridge / walk			
0.392		0.20	1.00	0.20			Calculator	Calculator			
							Checker				
0.501	0.504	0.09	1.00	0.09	0.09	0.05	Total Discharge (m ³ /s)	1.46			
0.506							Total area cross section(m ²)	2.38			
							Average Velocity(m/s)	0.61			
							Notes	Catchment Area (km ²)= 35.0 Discharge (m ³ /s)= 1.46 Specific Discharge (m ³ /s*100km ²)= 4.17			
							Remark:				

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS									
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)				
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds		
							1st	2nd	Average
1	0	0.00	0.00	0.000					
2	1	0.32	0.31	0.315	0.189	130	=(10 x 13)	45.62	45.620
					0.189	140	=(10 x 14)	48.44	48.440
3	2	0.38	0.42	0.400					
4	3	0.43	0.45	0.440	0.264	90	=(10 x 9)	15.13	15.130
					0.264	100	=(10 x 10)	17.05	17.050
5	4	0.27	0.32	0.295					
6	5	0.26	0.23	0.245	0.147	100	=(10 x 10)	26.74	26.740
					0.147	130	=(10 x 13)	35.13	35.130
7	6	0.22	0.24	0.230					
8	7	0.22	0.20	0.210	0.126	110	=(10 x 11)	47.28	47.280
					0.126	120	=(10 x 12)	51.86	51.860
9	8	0.28	0.25	0.265					
10	9	0.00	0.00	0.000	0.000	110	=(10 x 11)	28.58	28.580
					0.000	90	=(10 x 9)	21.90	21.900
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									

HOME WORKS						Station No.		Downstream of the culvert		
Velocity		Area of cross section			Discharge (m ³ /s)	Observation Date		Yr: 2012 Mon: 8 Date: 13		
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)		Observer Name	Mesure Wrote	Ezekiel, Reuben		
0.472	0.475	0.16	1.00	0.16	0.52	0.25	Weather	:clear, :fine, :cloudy, :rain		
0.478		0.36	1.00	0.36			Wind blows	from Down/s, Up/s, Left, Right		
							Wind power	0 None, 1 light, 2 windy, 3 strong, 4 very strong		
							Mesurement Time (Hour, min)	Start	2:30 PM	
0.974	0.967	0.42	1.00	0.42	0.79	0.76	End	4:30PM		
0.960		0.37	1.00	0.37			Average	3:30PM		
							Water Level at gauging station (m)	Initial Point	No.1 Point	
0.616	0.613	0.27	1.00	0.27	0.51	0.31	Start			
0.609		0.24	1.00	0.24			End			
							Average			
							Current meter	Type of current meter	Digital	
								Table/formula	V = 0.162 * N + 0.010	
								Using method	lods · wire · weight	
0.387	0.386	0.22	1.00	0.22	0.46	0.18		by boat / bridge / walk		
0.385		0.24	1.00	0.24			Calculator	Calculator		
							Checker			
0.634	0.655	0.13	1.00	0.13	0.13	0.09	Result	Total Discharge (m ³ /s)	1.59	
0.676							Total area cross section(m ²)	2.41		
							Average Velocity (m/s)	0.66		
							Notes	Catchment Area (km ²)=	35.0	
								Discharge (m ³ /s)=	1.59	
								Specific Discharge (m ³ /s*100km ²)=	4.54	
							Remark:			

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS										
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)					
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds			
							1st	2nd	Average	
1	0	0.00	0.00	0.000						
2	1	0.32	0.33	0.325	0.195	130	=(10 x 13)	38.96		38.960
					0.195	140	=(10 x 14)	44.17		44.170
3	2	0.38	0.39	0.385						
4	3	0.45	0.44	0.445	0.267	100	=(10 x 10)	26.03		26.030
					0.267	100	=(10 x 10)	27.34		27.340
5	4	0.32	0.33	0.325						
6	5	0.26	0.27	0.265	0.159	100	=(10 x 10)	24.49		24.490
					0.159	130	=(10 x 13)	30.70		30.700
7	6	0.23	0.23	0.230						
8	7	0.20	0.23	0.215	0.129	110	=(10 x 11)	35.47		35.470
					0.129	120	=(10 x 12)	39.56		39.560
9	8	0.25	0.27	0.260						
10	9	0.00	0.00	0.000	0.000	100	=(10 x 10)	35.95		35.950
					0.000	90	=(10 x 9)	32.53		32.530
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										

HOME WORKS						Station No.		Downstream of the culvert		
Velocity		Area of cross section			Discharge (m ³ /s)	Observation Date		Yr: 2012 Mon: 8 Date: 14		
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)		Observer Name	Mesure Wrote	Ezekiel, Reuben Ezekiel		
0.551	0.537	0.16	1.00	0.16	0.52	0.28	Weather	:clear, :fine, :cloudy, :rain		
		0.523	0.36	1.00			0.36	Wind blows	from Down/s, Up/s, Left, Right	
0.632	0.618	0.42	1.00	0.42	0.81	0.50	Mesurement Time (Hour, min)	Start	10:30 AM	
		0.603	0.39	1.00			0.39	End	12:00 PM	
0.671	0.684	0.30	1.00	0.30	0.55	0.38	Water Level at gauging station (m)	Average	11:15 AM	
		0.696	0.25	1.00				0.25	Initial Point	No.1 Point
0.512	0.507	0.22	1.00	0.22	0.46	0.23	Current meter	Type of current meter	Digital	
		0.501	0.22	1.00				0.22	Table/formula	V = 0.162 * N + 0.010
0.461	0.460	0.13	1.00	0.13	0.13	0.06	Result	Using method	tods · wire · weight by boat / bridge / walk	
		0.458	0.24	1.00				0.24	Calculator	Calculator
								Checker		
								Total Discharge (m ³ /s)	1.45	
								Total area cross section(m ²)	2.47	
								Average Velocity(m/s)	0.59	
								Notes	Catchment Area (km ²)= 35.0 Discharge (m ³ /s)= 1.45 Specific Discharge (m ³ /s*100km ²)= 4.14	
								Remark:		

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS										
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)					
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds			
							1st	2nd	Average	
1	0	0.00	0.00	0.000						
2	1	0.32	0.34	0.330	0.198	130	=(10 x 13)	45.01		45.010
					0.198	100	=(10 x 10)	34.13		34.130
3	2	0.38	0.40	0.390						
4	3	0.40	0.44	0.420	0.252	100	=(10 x 10)	19.51		19.510
					0.252	120	=(10 x 12)	24.02		24.020
5	4	0.38	0.34	0.360						
6	5	0.23	0.25	0.240	0.144	100	=(10 x 10)	22.77		22.770
					0.144	130	=(10 x 13)	29.92		29.920
7	6	0.21	0.23	0.220						
8	7	0.21	0.22	0.215	0.129	90	=(10 x 9)	36.09		36.090
					0.129	100	=(10 x 10)	45.02		45.020
9	8	0.25	0.28	0.265						
10	9	0.00	0.00	0.000	0.000	100	=(10 x 10)	33.95		33.950
					0.000	100	=(10 x 10)	34.44		34.440
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										

HOME WORKS							Station No.		Downstream of the culvert		
Velocity		Area of cross section			Discharge (m ³ /s)	Observation Date		Yr: 2012	Mon: 8	Date: 14	
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)		Observer Name	Mesure Wrote	Ezekiel, Reuben			
0.478	0.482	0.17	1.00	0.17	0.53	0.26	Weather	:clear, :fine, :cloudy, :rain			
0.485		0.36	1.00	0.36			Wind blows	from Down/s, Up/s, Left, Right			
0.840	0.830	0.41	1.00	0.41	0.80	0.66	Measurement Time (Hour, min)	Start	2:30 PM		
0.819		0.39	1.00	0.39			Average	3:30PM			
0.721	0.718	0.30	1.00	0.30	0.53	0.38	Water Level at gauging station (m)	Initial Point	No.1 Point		
0.714		0.23	1.00	0.23			Start				
0.414	0.392	0.22	1.00	0.22	0.46	0.18	Current meter	Type of current meter	Digital		
0.370		0.24	1.00	0.24			Table/formula	V = 0.162 * N + 0.010			
		0.13	1.00	0.13			Using method	:sods · wire · weight			
0.487	0.484				0.13	0.06	Calculator	Calculator			
0.480							Checker				
							Result	Total Discharge (m ³ /s)	1.54		
								Total area cross section(m ²)	2.45		
								Average Velocity(m/s)	0.63		
							Notes	Catchment Area (km ²)=	35.0		
								Discharge (m ³ /s)=	1.54		
								Specific Discharge (m ³ /s*100km ²)=	4.40		
							Remark:				

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS									
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)				
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds		
							1st	2nd	Average
1	0	0.00	0.00	0.000					
2	1	0.42	0.43	0.425	0.255	90	=(10 x 9)	20.70	20.700
					0.255	110	=(10 x 11)	25.95	25.950
3	2	0.53	0.54	0.535					
4	3	0.50	0.51	0.505	0.303	110	=(10 x 11)	20.13	20.130
					0.303	130	=(10 x 13)	25.15	25.150
5	4	0.41	0.43	0.420					
6	5	0.33	0.35	0.340	0.204	100	=(10 x 10)	39.80	39.800
					0.204	120	=(10 x 12)	44.11	44.110
7	6	0.32	0.30	0.310					
8	7	0.34	0.33	0.335	0.201	110	=(10 x 11)	35.48	35.480
					0.201	90	=(10 x 9)	31.40	31.400
9	8	0.43	0.44	0.435					
10	9	0.00	0.00	0.000	0.000	100	=(10 x 10)	34.60	34.600
					0.000	90	=(10 x 9)	30.77	30.770
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									

HOME WORKS						Station No.		Downstream of the culvert	
Velocity		Area of cross section			Discharge (m³/s)	Observation Date		Yr: 2012 Mon: 8 Date: 27	
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m²)		Observer Name	Mesure Wrote	Ezekiel, Reuben	
0.714	0.706	0.21	1.00	0.21	0.69	0.49	Weather	:clear, :fine, :cloudy, :rain	
0.697		0.48	1.00	0.48			Wind blows	from Down/s, Up/s, Left, Right	
0.895	0.871	0.52	1.00	0.52	0.98	0.85	Mesurement Time (Hour, min)	Start 10:30 AM	
							Average 11:15Am		
0.847	0.434	0.46	1.00	0.46	0.71	0.31	Water Level at gauging station (m)	Initial Point No.1 Point	
0.417		0.38	1.00	0.38			Start		
0.451	0.493	0.32	1.00	0.32	0.71	0.35	End		
0.512							0.39	1.00	0.39
0.474	0.481	0.22	1.00	0.22	0.22	0.11	Type of current meter	Digital	
0.478							0.22	1.00	0.22
0.484							Using method	lods · wire · weight	
							Calculator	by boat / bridge / walk	
							Checker		
							Result	Total Discharge (m³/s) 2.11	
								Total area cross section(m²) 3.31	
								Average Velocity(m/s) 0.64	
							Notes	Catchment Area (km²)= 35.0	
								Discharge (m³/s)= 2.11	
								Specific Discharge (m³/s*100km²)= 6.03	
							Remark:	THERE WAS HEAVY RAIN THE PREVIOUS NIGHT	

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS									
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)				
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds		
							1st	2nd	Average
1	0	0.00	0.00	0.000					
2	1	0.42	0.42	0.420	0.252	100	=(10 x 10)	17.61	17.610
					0.252	110	=(10 x 11)	20.12	20.120
3	2	0.48	0.49	0.485					
4	3	0.50	0.51	0.505	0.303	90	=(10 x 9)	15.10	15.100
					0.303	120	=(10 x 12)	20.99	20.990
5	4	0.42	0.44	0.430					
6	5	0.34	0.35	0.345	0.207	100	=(10 x 10)	36.79	36.790
					0.207	120	=(10 x 12)	38.08	38.080
7	6	0.34	0.37	0.355					
8	7	0.31	0.32	0.315	0.189	90	=(10 x 9)	22.60	22.600
					0.189	110	=(10 x 11)	27.49	27.490
9	8	0.40	0.41	0.405					
10	9	0.00	0.00	0.000	0.000	90	=(10 x 9)	28.43	28.430
					0.000	100	=(10 x 10)	29.77	29.770
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									

HOME WORKS						Station No.		Downstream of the culvert		
Velocity		Area of cross section				Discharge (m³/s)	Observation Date			
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m²)	Total Area(m²)		Yr: 2012	Mon: 8	Date: 27	
0.930	0.913	0.21	1.00	0.21		0.66	0.60	Observer		Mesure
0.896		0.45	1.00	0.45				Name		Wrote
		0.50	1.00	0.50				Weather		:clear, :fine, :cloudy :rain
0.976	0.956	0.47	1.00	0.47				Weather		from Down/s, Up/s, Left, Right
0.936		0.39	1.00	0.39				Wind power		0:None, 1:light, 2:windy, 3:strong, 4:very strong
0.450	0.486	0.35	1.00	0.35				Measurement		Start
0.521		0.34	1.00	0.34				Time		End
0.655	0.657	0.36	1.00	0.36				(Hour, min)		Average
0.658		0.20	1.00	0.20				Water Level at gauging station (m)		Initial Point
0.523	0.539							Start		No.1 Point
0.554								End		
								Average		
								Type of current meter		Digital
								Table/formula		V = 0.162 * N + 0.010
								Using method		lods * wire * weight
								Calculator		by boat / bridge / walk
								Calculator		Checker
								Result		Total Discharge (m³/s)
								Total area cross section(m²)		2.46
								Average Velocity(m/s)		3.27
								Notes		Catchment Area (km²)= 35.0
										Discharge (m³/s)= 2.46
										Specific Discharge (m³/s*100km²)= 7.03
								Remark:		There was rain the previous night

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS									
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)				
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds		
							1st	2nd	Average
1	0	0.00	0.00	0.000					
2	1	0.35	0.37	0.360	0.216	100	=(10 x 10)	21.72	21.720
					0.216	110	=(10 x 11)	23.60	23.600
3	2	0.43	0.44	0.435					
4	3	0.45	0.48	0.465	0.279	100	=(10 x 10)	19.95	19.950
					0.279	110	=(10 x 11)	21.92	21.920
5	4	0.39	0.40	0.395					
6	5	0.33	0.36	0.345	0.207	100	=(10 x 10)	28.02	28.020
					0.207	120	=(10 x 12)	34.32	34.320
7	6	0.30	0.33	0.315					
8	7	0.23	0.25	0.240	0.144	90	=(10 x 9)	20.54	20.540
					0.144	110	=(10 x 11)	24.54	24.540
9	8	0.33	0.31	0.320					
10	9	0.00	0.00	0.000	0.000	100	=(10 x 10)	21.34	21.340
					0.000	90	=(10 x 9)	20.56	20.560
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									

HOME WORKS						Station No.		Downstream of the culvert		
Velocity		Area of cross section			Discharge (m ³ /s)	Observation Date		Yr. 2012	Mon: 8	Date: 28
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)		Observer Name	Mesure Wrote	Ezekiel, Reuben		
0.756	0.761	0.18	1.00	0.18	0.58	0.44	Weather	:clear, :fine, :cloudy, :rain		
0.765		0.40	1.00	0.40			Wind blows	from Down/s, Up/s, Left, Right		
							Wind power	0:none, 1:light, 2:windy, 3:strong, 4:very strong		
							Measurement Time (Hour, min)	Start	10:30 AM	
0.822	0.823	0.45	1.00	0.45	0.88	0.72		End	12:00PM	
0.823		0.43	1.00	0.43			Average	11:15Am		
							Water Level at gauging station (m)	Start	Initial Point	No.1 Point
0.588	0.582	0.37	1.00	0.37	0.70	0.41		End		
0.576		0.33	1.00	0.33			Average			
							Current meter	Type of current meter	Digital	
								Table/formula	V = 0.162 * N + 0.010	
								Using method	lods · wire · weight	
0.720	0.728	0.28	1.00	0.28	0.56	0.41		by boat / bridge / walk		
0.736		0.28	1.00	0.28			Calculator	Calculator		
								Checker		
							Result	Total Discharge (m ³ /s)	2.10	
0.769	0.744	0.16	1.00	0.16	0.16	0.12		Total area cross section(m ²)	2.88	
0.719							Average Velocity(m/s)	0.73		
							Notes	Catchment Area (km ²)=	35.0	
								Discharge (m ³ /s)=	2.10	
								Specific Discharge (m ³ /s*100km ²)=	6.00	
							Remark:	THERE WAS RAIN THE PREVIOUS NIGHT		

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS										
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)					
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds			
							1st	2nd	Average	
1	0	0.00	0.00	0.000						
2	1	0.33	0.35	0.340	0.204	100	=(10 x 10)	21.30		21.300
					0.204	110	=(10 x 11)	23.38		23.380
3	2	0.40	0.41	0.405						
4	3	0.44	0.47	0.455	0.273	90	=(10 x 9)	19.15		19.150
					0.273	120	=(10 x 12)	25.29		25.290
5	4	0.38	0.37	0.375						
6	5	0.29	0.30	0.295	0.177	100	=(10 x 10)	27.01		27.010
					0.177	120	=(10 x 12)	32.18		32.180
7	6	0.29	0.30	0.295						
8	7	0.26	0.27	0.265	0.159	90	=(10 x 9)	27.70		27.700
					0.159	110	=(10 x 11)	36.16		36.160
9	8	0.31	0.35	0.330						
10	9	0.00	0.00	0.000	0.000	90	=(10 x 9)	26.54		26.540
					0.000	100	=(10 x 10)	27.61		27.610
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										

HOME WORKS						Station No.		Downstream of the culvert		
Velocity		Area of cross section				Discharge (m³/s)	Observation Date			
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m²)	Total Area(m²)		Yr: 2012	Mon: 8	Date: 28	
		0.17	1.00	0.17			Observer	Mesure Ezekiel, Reuben		
0.771	0.772				0.54	0.42	Name	Wrote Ezekiel		
0.772		0.37	1.00	0.37			Weather	Weather :clear, :fine, :cloudy :rain		
							Wind blows	from Down/s, Up/s, Left, Right		
							Wind power	0:None, 1:light, 2:windy, 3:strong, 4:very strong		
							Measurement Time (Hour, min)	Start	2:30 PM	
0.771	0.775	0.43	1.00	0.43	0.85	0.66		End	4:30PM	
0.779		0.42	1.00	0.42				Average	3:30PM	
							Water Level at gauging station (m)	Initial Point	No.1 Point	
0.610	0.612	0.34	1.00	0.34	0.64	0.39		Start		
0.614								End		
		0.30	1.00	0.30			Current meter	Type of current meter Digital		
								Table/formula V = 0.162 * N + 0.010		
0.536	0.520	0.28	1.00	0.28	0.58	0.30		Using method lods · wire · weight		
0.503								by boat / bridge / walk		
		0.30	1.00	0.30			Calculator	Calculator		
								Checker		
0.559	0.578	0.17	1.00	0.17	0.17	0.10	Result	Total Discharge (m³/s) 1.87		
0.597								Total area cross section(m²) 2.78		
								Average Velocity(m/s) 0.67		
							Notes	Catchment Area (km²)= 35.0		
								Discharge (m³/s)= 1.87		
								Specific Discharge (m³/s*100km²)= 5.34		
							Remark:	THERE WAS HEAVY RAIN THE PREVIOUS NIGHT		

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS										
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)					
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds			
							1st	2nd	Average	
1	0	0.00	0.00	0.000						
2	1	0.33	0.35	0.340	0.204	100	=(10 x 10)	25.98		25.980
					0.204	110	=(10 x 11)	29.55		29.550
3	2	0.40	0.41	0.405						
4	3	0.39	0.43	0.410	0.246	90	=(10 x 9)	18.49		18.490
					0.246	120	=(10 x 12)	24.71		24.710
5	4	0.37	0.40	0.385						
6	5	0.26	0.29	0.275	0.165	100	=(10 x 10)	26.64		26.640
					0.165	120	=(10 x 12)	31.61		31.610
7	6	0.26	0.28	0.270						
8	7	0.20	0.23	0.215	0.129	90	=(10 x 9)	47.39		47.390
					0.129	100	=(10 x 10)	55.32		55.320
9	8	0.27	0.30	0.285						
10	9	0.00	0.00	0.000	0.000	100	=(10 x 10)	39.77		39.770
					0.000	90	=(10 x 9)	38.64		38.640
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										

HOME WORKS						Station No.		Downstream of the culvert		
Velocity		Area of cross section			Discharge (m ³ /s)	Observation Date		Yr: 2012	Mon: 8	Date: 29
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)		Observer Name	Mesure Wrote	Ezekiel, Reuben		
0.634	0.624	0.17	1.00	0.17	0.54	0.34	Observer Name	Ezekiel		
0.613		0.37	1.00	0.37			Weather	:clear, :fine, :cloudy, :rain		
0.799	0.798	0.41	1.00	0.41	0.81	0.65	Wind blows	from Down/s, Up/s, Left, Right		
0.797		0.40	1.00	0.40			Wind power	0 None, 1 light, 2 windy, 3 strong, 4 very strong		
0.618	0.622	0.33	1.00	0.33	0.60	0.37	Measurement Time (Hour, min)	Start	10:30 AM	
0.625		0.27	1.00	0.27			End	12:00PM		
0.318	0.311	0.24	1.00	0.24	0.49	0.15	Water Level at gauging station (m)	Average	11:15Am	
0.303		0.25	1.00	0.25			Initial Point	No.1 Point		
0.417	0.402	0.14	1.00	0.14	0.14	0.06	Start			
0.387		0.27	1.00	0.27			End			
							Average			
							Type of current meter	Digital		
							Table/formula	V = 0.162 * N + 0.010		
							Using method	fods · wire · weight		
							Calculator	by boat / bridge / walk		
							Calculator	Calculator		
							Checker	Checker		
							Total Discharge (m ³ /s)	1.57		
							Total area cross section(m ²)	2.58		
							Average Velocity(m/s)	0.61		
							Notes	Catchment Area (km ²)= 35.0		
								Discharge (m ³ /s)= 1.57		
								Specific Discharge (m ³ /s*100km ²)= 4.49		
							Remark:	There was no rain realised		

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS									
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)				
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds		
							1st	2nd	Average
1	0	0.00	0.00	0.000					
2	1	0.33	0.34	0.335	0.201	100	=(10 x 10)	23.97	23.970
					0.201	110	=(10 x 11)	26.34	26.340
3	2	0.39	0.40	0.395					
4	3	0.39	0.42	0.405	0.243	90	=(10 x 9)	21.17	21.170
					0.243	100	=(10 x 10)	23.34	23.340
5	4	0.33	0.34	0.335					
6	5	0.27	0.30	0.285	0.171	100	=(10 x 10)	31.62	31.620
					0.171	110	=(10 x 11)	35.34	35.340
7	6	0.26	0.27	0.265					
8	7	0.26	0.29	0.275	0.165	90	=(10 x 9)	50.05	50.050
					0.165	110	=(10 x 11)	52.69	52.690
9	8	0.30	0.28	0.290					
10	9	0.00	0.00	0.000	0.000	90	=(10 x 9)	38.59	38.590
					0.000	100	=(10 x 10)	37.79	37.790
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									

HOME WORKS						Station No.		Downstream of the culvert			
Velocity		Area of cross section			Discharge (m³/s)	Observation Date			Yr: 2012	Mon: 8	Date: 29
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m²)		Total Area(m²)	Observer Name	Mesure Wrote	Ezekiel, Reuben		
0.686	0.687	0.17	1.00	0.17			Weather	:clear, :fine, :cloudy, :rain			
0.687		0.37	1.00	0.37	0.54	0.37	Wind blows	from Down/s, Up/s, Left, Right			
		0.40	1.00	0.40			Wind power	0:None, 1:light, 2:windy, 3:strong, 4:very strong			
0.699	0.702	0.37	1.00	0.37	0.77	0.54	Mesurement Time (Hour, min)	Start	2:30 PM		
0.704		0.31	1.00	0.31				End	4:30PM		
		0.27	1.00	0.27			Average	3:30PM			
		0.28	1.00	0.28			Water Level at gauging station (m)	Initial Point	No.1 Point		
0.522	0.518	0.27	1.00	0.27	0.59	0.18		Start			
0.514		0.28	1.00	0.28				End			
		0.15	1.00	0.15			Average				
0.301	0.325						Current meter	Type of current meter	Digital		
0.348								Table/formula	V = 0.162 * N + 0.010		
							Useing method	fods · wire · weight			
							Calculator	by boat / bridge / walk			
							Calculator				
							Checker				
0.388	0.414				0.15	0.06	Result	Total Discharge (m³/s)	1.46		
0.439								Total area cross section(m²)	2.60		
								Average Velocity(m/s)	0.56		
							Notes	Catchment Area (km²)=	35.0		
								Discharge (m³/s)=	1.46		
								Specific Discharge (m³/s*100km²)=	4.17		
							Remark:	There was no rain realized			

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS										
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)					
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds			
							1st	2nd	Average	
1	0	0.00	0.00	0.000						
2	1	0.40	0.40	0.400	0.240	100	=(10 x 10)	18.93		18.930
					0.240	120	=(10 x 12)	22.88		22.880
3	2	0.44	0.48	0.460						
4	3	0.48	0.50	0.490	0.294	90	=(10 x 9)	20.36		20.360
					0.294	100	=(10 x 10)	21.50		21.500
5	4	0.40	0.43	0.415						
6	5	0.37	0.38	0.375	0.225	90	=(10 x 9)	27.11		27.110
					0.225	100	=(10 x 10)	30.36		30.360
7	6	0.33	0.34	0.335						
8	7	0.34	0.37	0.355	0.213	90	=(10 x 9)	18.83		18.830
					0.213	110	=(10 x 11)	24.37		24.370
9	8	0.35	0.35	0.350						
10	9	0.00	0.00	0.000	0.000	100	=(10 x 10)	34.22		34.220
					0.000	110	=(10 x 11)	35.77		35.770
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										

HOME WORKS						Station No.		Downstream of the culvert		
Velocity		Area of cross section			Discharge (m ³ /s)	Observation Date		Yr: 2012	Mon: 9	Date: 10
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)		Observer Name	Mesure Wrote	Ezekiel, Reuben		
0.866	0.863	0.20	1.00	0.20	0.63	0.54	Weather	:clear, :fine, :cloudy, :rain		
0.860		0.43	1.00	0.43			Wind blows	from Down/s, Up/s, Left, Right		
							Wind power	0:None, 1:light, 2:windy, 3:strong, 4:very strong		
							Measurement Time (Hour, min)	Start	10:30 AM	
0.726	0.745	0.48	1.00	0.48	0.93	0.69	End	12:00PM		
0.763		0.45	1.00	0.45			Average	11:15Am		
							Water Level at gauging station (m)	Initial Point	No.1 Point	
0.548	0.546	0.40	1.00	0.40	0.76	0.41	Start			
0.544		0.36	1.00	0.36			End			
							Average			
							Current meter	Type of current meter	Digital	
							Table/formula	V = 0.162 * N + 0.010		
0.784	0.763	0.35	1.00	0.35	0.70	0.53	Using method	fods · wire · weight		
0.741		0.35	1.00	0.35			by boat / bridge / walk			
							Calculator	Calculator		
							Checker			
							Result	Total Discharge (m ³ /s)	2.26	
0.483	0.496	0.18	1.00	0.18	0.18	0.09	Total area cross section(m ²)	3.20		
0.508							Average Velocity(m/s)	0.71		
							Notes	Catchment Area (km ²)= 35.0		
								Discharge (m ³ /s)= 2.26		
								Specific Discharge (m ³ /s*100km ²)= 6.46		
							Remark:	THERE WAS HEAVY RAIN THE PREVIOUS NIGHT-9TH 09-2012		

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS										
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)					
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds			
							1st	2nd	Average	
1	0	0.00	0.00	0.000						
2	1	0.40	0.41	0.405	0.243	100	=(10 x 10)	19.52		19.520
					0.243	110	=(10 x 11)	20.99		20.990
3	2	0.42	0.47	0.445						
4	3	0.50	0.50	0.500	0.300	100	=(10 x 10)	21.32		21.320
					0.300	120	=(10 x 12)	25.83		25.830
5	4	0.44	0.46	0.450						
6	5	0.40	0.41	0.405	0.243	90	=(10 x 9)	29.93		29.930
					0.243	100	=(10 x 10)	33.12		33.120
7	6	0.36	0.36	0.360						
8	7	0.35	0.36	0.355	0.213	80	=(10 x 8)	24.02		24.020
					0.213	100	=(10 x 10)	32.79		32.790
9	8	0.35	0.37	0.360						
10	9	0.00	0.00	0.000	0.000	100	=(10 x 10)	38.76		38.760
					0.000	110	=(10 x 11)	40.44		40.440
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										

HOME WORKS							Station No.		Downstream of the culvert		
Velocity		Area of cross section				Discharge (m ³ /s)	Observation Date		Yr: 2012	Mon: 9	Date: 10
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)	Total Area(m ²)		Observer Name	Mesure Wrote	Ezekiel, Reuben		
0.840	0.850	0.20	1.00	0.20	0.63	0.54	Weather	:clear, :fine, :cloudy, :rain			
0.859		0.43	1.00	0.43			Wind blows	from Down/s, Up/s, Left, Right			
							Wind power	0=None, 1=light, 2=windy, 3=strong, 4=very strong			
							Mesurement Time (Hour, min)	Start	2:30 PM		
0.770	0.767	0.47	1.00	0.47	0.95	0.73	End	4:30PM			
0.763		0.48	1.00	0.48			Average	3:30PM			
							Water Level at gauging station (m)	Initial Point	No.1 Point		
0.497	0.498	0.43	1.00	0.43	0.81	0.40	Start				
0.499		0.38	1.00	0.38			End				
							Average				
							Current meter	Type of current meter	Digital		
0.550	0.527	0.36	1.00	0.36	0.72	0.38	Table/formula	V = 0.162 * N + 0.010			
0.504		0.36	1.00	0.36			Using method	lods · wire · weight by boat / bridge / walk			
							Calculator	Calculator			
							Checker				
							Result	Total Discharge (m ³ /s)	2.13		
0.428	0.440	0.18	1.00	0.18	0.18	0.08	Total area cross section(m ²)	3.29			
0.451							Average Velocity (m/s)	0.65			
							Notes	Catchment Area (km ²)=	35.0		
								Discharge (m ³ /s)=	2.13		
								Specific Discharge (m ³ /s*100km ²)=	6.09		
							Remark:	There was rain the previous night OF 9TH sep 2012			

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS										
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)					
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds			
							1st	2nd	Average	
1	0	0.00	0.00	0.000						
2	1	0.39	0.40	0.395	0.237	100	=(10 x 10)	19.93		19.930
					0.237	120	=(10 x 12)	23.36		23.360
3	2	0.42	0.44	0.430						
4	3	0.47	0.48	0.475	0.285	100	=(10 x 10)	26.64		26.640
					0.285	120	=(10 x 12)	32.63		32.630
5	4	0.40	0.45	0.425						
6	5	0.36	0.37	0.365	0.219	90	=(10 x 9)	27.36		27.360
					0.219	110	=(10 x 11)	32.38		32.380
7	6	0.32	0.34	0.330						
8	7	0.34	0.33	0.335	0.201	90	=(10 x 9)	28.09		28.090
					0.201	100	=(10 x 10)	28.50		28.500
9	8	0.33	0.34	0.335						
10	9	0.00	0.00	0.000	0.000	100	=(10 x 10)	26.06		26.060
					0.000	120	=(10 x 12)	30.46		30.460
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										

HOME WORKS						Station No.		Downstream of the culvert			
Velocity		Area of cross section			Discharge (m ³ /s)	Observation Date		Yr: 2012	Mon: 9	Date: 11	
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)		Observer Name	Mesure Wrote	Ezekiel, Reuben			
0.823	0.833	0.20	1.00	0.20	0.61	0.51	Weather	:clear, :fine, :cloudy, :rain			
0.842		0.41	1.00	0.41			Wind blows	from Down/s, Up/s, Left, Right			
		0.45	1.00	0.45			Wind power	0:None, 1:slight, 2:windy, 3:strong, 4:very strong			
0.618	0.612	0.45	1.00	0.45	0.90	0.55	Mesurement Time (Hour, min)	Start	10:30 AM		
0.606		0.45	1.00	0.45			End	12:00PM			
		0.45	1.00	0.45			Average	11:15Am			
		0.40	1.00	0.40			Water Level at gauging station (m)	Initial Point	No.1 Point		
0.543	0.552	0.35	1.00	0.35	0.75	0.41	Start				
0.560		0.35	1.00	0.35			End				
		0.33	1.00	0.33			Average				
0.529	0.554	0.33	1.00	0.33	0.67	0.37	Type of current meter	Digital			
0.578		0.34	1.00	0.34			Table/formula	V = 0.162 * N + 0.010			
		0.17	1.00	0.17			Using method	fods * wire * weight			
							Calculator	Calculator			
0.632	0.640						Checker				
0.648							Result	Total Discharge (m ³ /s)	1.95		
							Total area cross section(m ²)	3.10			
							Average Velocity(m/s)	0.63			
							Notes	Catchment Area (km ²)= 35.0			
								Discharge (m ³ /s)= 1.95			
								Specific Discharge (m ³ /s*100km ²)= 5.57			
							Remark:	THERE WAS HEAVY RAIN THE PREVIOUS NIGHT-10TH 09-2012			

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS										
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)					
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds			
							1st	2nd	Average	
1	0	0.00	0.00	0.000						
2	1	0.36	0.37	0.365	0.219	100	=(10 x 10)	16.27		16.270
					0.219	120	=(10 x 12)	19.68		19.680
3	2	0.40	0.40	0.400						
4	3	0.48	0.47	0.475	0.285	90	=(10 x 9)	18.61		18.610
					0.285	100	=(10 x 10)	21.53		21.530
5	4	0.40	0.40	0.400						
6	5	0.35	0.36	0.355	0.213	90	=(10 x 9)	26.41		26.410
					0.213	110	=(10 x 11)	34.31		34.310
7	6	0.30	0.31	0.305						
8	7	0.32	0.34	0.330	0.198	90	=(10 x 9)	31.49		31.490
					0.198	100	=(10 x 10)	33.00		33.000
9	8	0.35	0.34	0.345						
10	9	0.00	0.00	0.000	0.000	90	=(10 x 9)	32.05		32.050
					0.000	100	=(10 x 10)	34.27		34.270
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										

HOME WORKS						Station No.		Downstream of the culvert			
Velocity		Area of cross section			Discharge	Observation Date			Yr: 2012 Mon: 9 Date: 11		
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)		Total Area(m ²)	Observer Name	Mesure Wrote	Ezekiel, Reuben		
1.006	1.002	0.18	1.00	0.18		Ezekiel	Weather	:clear, :fine, :cloudy, :rain			
0.998		0.38	1.00	0.38	0.56		Wind blows	from Down/s, Up/s, Left, Right			
		0.44	1.00	0.44	0.88	Wind power	0=None, 1=light, 2=windy, 3=strong, 4=very strong				
0.793	0.778	0.44	1.00	0.44	0.68	Measurement Time (Hour, min)	Start	2:30 PM			
0.762		0.44	1.00	0.44	0.68		End	4:30PM			
		0.38	1.00	0.38	0.71	Water Level at gauging station (m)	Average	3:30PM			
0.562	0.546	0.33	1.00	0.33	0.39		Initial Point	No.1 Point			
0.529		0.32	1.00	0.32	0.66	Current meter	Type of current meter	Digital			
0.473	0.487	0.34	1.00	0.34	0.32		Table/formula	V = 0.162 * N + 0.010			
0.501		0.17	1.00	0.17	0.08	Using method	lods · wire · weight by boat / bridge / walk				
						Calculator	Calculator				
0.465	0.474						Checker				
0.483						Result	Total Discharge (m ³ /s)	2.03			
							Total area cross section(m ²)	2.98			
							Average Velocity(m/s)	0.68			
						Notes	Catchment Area (km ²)=	35.0			
							Discharge (m ³ /s)=	2.03			
							Specific Discharge (m ³ /s*100km ²)=	5.80			
						Remark:	There was rain the previous night				

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS										
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)					
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds			
							1st	2nd	Average	
1	0	0.00	0.00	0.000						
2	1	0.35	0.39	0.370	0.222	100	=(10 x 10)	20.36		20.360
					0.222	120	=(10 x 12)	26.23		26.230
3	2	0.40	0.41	0.405						
4	3	0.46	0.47	0.465	0.279	100	=(10 x 10)	23.11		23.110
					0.279	110	=(10 x 11)	25.10		25.100
5	4	0.40	0.42	0.410						
6	5	0.30	0.32	0.310	0.186	90	=(10 x 9)	22.58		22.580
					0.186	100	=(10 x 10)	24.90		24.900
7	6	0.30	0.32	0.310						
8	7	0.33	0.35	0.340	0.204	80	=(10 x 8)	25.09		25.090
					0.204	110	=(10 x 11)	31.48		31.480
9	8	0.33	0.36	0.345						
10	9	0.00	0.00	0.000	0.000	90	=(10 x 9)	15.21		15.210
					0.000	100	=(10 x 10)	20.18		20.180
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										

HOME WORKS							Station No.		Downstream of the culvert		
Velocity		Area of cross section				Discharge (m ³ /s)	Observation Date		Yr: 2012	Mon: 9	Date: 12
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)	Total Area(m ²)		Observer Name	Mesure	Ezekiel, Reuben		
0.806	0.779	0.19	1.00	0.19	0.58	0.45	Observer Name	Wrote	Ezekiel		
0.751		0.39	1.00	0.39			Weather	Weather	:clear, :fine, :cloudy, :rain		
0.711	0.716	0.44	1.00	0.44	0.88	0.63	Measurement Time (Hour, min)	Start	10:30 AM		
0.720		0.44	1.00	0.44			End	12:00PM			
0.656	0.659	0.36	1.00	0.36	0.67	0.44	Water Level at gauging station (m)	Average	11:15Am		
0.661		0.31	1.00	0.31			Initial Point	No.1 Point			
0.527	0.552	0.33	1.00	0.33	0.67	0.37	Current meter	Type of current meter	Digital		
0.576		0.34	1.00	0.34			Table/formula	V = 0.162 * N + 0.010			
0.969	0.891	0.17	1.00	0.17	0.17	0.15	Using method	lods · wire · weight by boat / bridge / walk			
0.813		0.17	1.00	0.17			Calculator	Calculator			
							Checker				
							Result	Total Discharge (m ³ /s)	2.04		
								Total area cross section(m ²)	2.97		
								Average Velocity(m/s)	0.69		
							Notes	Catchment Area (km ²)=	35.0		
								Discharge (m ³ /s)=	2.04		
								Specific Discharge (m ³ /s*100km ²)=	5.83		
							Remark:	THERE WAS HEAVY RAIN THE PREVIOUS NIGHT-11TH 09-2012			

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS									
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)				
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds		
							1st	2nd	Average
1	0	0.00	0.00	0.000					
2	1	0.35	0.36	0.355	0.213	100	=(10 x 10)	27.44	27.440
					0.213	110	=(10 x 11)	33.02	33.020
3	2	0.43	0.44	0.435					
4	3	0.45	0.46	0.455	0.273	100	=(10 x 10)	26.27	26.270
					0.273	110	=(10 x 11)	28.93	28.930
5	4	0.40	0.41	0.405					
6	5	0.34	0.35	0.345	0.207	90	=(10 x 9)	37.32	37.320
					0.207	100	=(10 x 10)	44.91	44.910
7	6	0.30	0.30	0.300					
8	7	0.32	0.33	0.325	0.195	80	=(10 x 8)	24.36	24.360
					0.195	110	=(10 x 11)	33.49	33.490
9	8	0.31	0.35	0.330					
10	9	0.00	0.00	0.000	0.000	90	=(10 x 9)	29.55	29.550
					0.000	100	=(10 x 10)	34.90	34.900
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									

HOME WORKS						Station No.		Downstream of the culvert				
Velocity		Area of cross section			Discharge (m ³ /s)	Observation Date			Yr: 2012	Mon: 9	Date: 12	
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)		Observer Name	Measure Wrote	Ezekiel, Reuben				
0.600	0.575	0.18	1.00	0.18	0.58	0.33	Weather	:clear, :fine, :cloudy, :rain				
0.550		0.40	1.00	0.40			Wind blows	from Down/s, Up/s, Left, Right				
							Wind power	0=None, 1=light, 2=windy, 3=strong, 4=very strong				
							Measurement Time (Hour, min)	Start	2:30 PM			
0.627	0.627	0.45	1.00	0.45	0.88	0.55	End	4:30PM				
0.626		0.43	1.00	0.43			Average	3:30PM				
							Water Level at gauging station (m)	Initial Point	No.1 Point			
0.401	0.386	0.38	1.00	0.38	0.70	0.27	Start					
0.371		0.32	1.00	0.32			End					
							Average					
							Current meter	Type of current meter	Digital			
							Table/formula	V = 0.162 * N + 0.010				
0.542	0.542	0.31	1.00	0.31	0.64	0.35	Using method	lods · wire · weight				
0.542		0.33	1.00	0.33			by boat / bridge / walk					
							Calculator	Calculator				
							Checker					
							Result	Total Discharge (m ³ /s)	1.58			
0.503	0.489	0.17	1.00	0.17	0.17	0.08	Total area cross section(m ²)	2.97				
0.474							Average Velocity(m/s)	0.53				
							Notes	Catchment Area (km ²)=	35.0			
								Discharge (m ³ /s)=	1.58			
								Specific Discharge (m ³ /s*100km ²)=	4.51			
							Remark	There was rain the previous night				

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS										
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)					
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds			
							1st	2nd	Average	
1	0	0.00	0.00	0.000						
2	1	0.32	0.33	0.325	0.195	100	=(10 x 10)	20.55		20.550
					0.195	110	=(10 x 11)	22.48		22.480
3	2	0.37	0.38	0.375						
4	3	0.41	0.43	0.420	0.252	90	=(10 x 9)	25.19		25.190
					0.252	100	=(10 x 10)	26.17		26.170
5	4	0.36	0.40	0.380						
6	5	0.32	0.35	0.335	0.201	100	=(10 x 10)	33.59		33.590
					0.201	110	=(10 x 11)	36.17		36.170
7	6	0.23	0.24	0.235						
8	7	0.25	0.27	0.260	0.156	100	=(10 x 10)	43.77		43.770
					0.156	110	=(10 x 11)	52.00		52.000
9	8	0.27	0.29	0.280						
10	9	0.00	0.00	0.000	0.000	90	=(10 x 9)	42.79		42.790
					0.000	100	=(10 x 10)	46.30		46.300
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										

HOME WORKS						Station No.		Downstream of the culvert		
Velocity		Area of cross section			Discharge (m ³ /s)	Observation Date		Yr: 2012	Mon: 9	Date: 23
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)		Observer Name	Mesure Wrote	Ezekiel, Reuben		
0.798	0.801	0.16	1.00	0.16	0.51	0.41	Observer Name	Ezekiel, Reuben		
0.803							Weather	:clear, :fine, :cloudy :rain		
		0.35	1.00	0.35			Wind blows	from Down/s, Up/s, Left, Right		
		0.40	1.00	0.40			Wind power	0:none, 1:light, 2:windy, 3:strong, 4:very strong		
0.589	0.609	0.40	1.00	0.40	0.80	0.49	Measurement Time (Hour, min)	Start	10:30 AM	
0.629							End	12:00PM		
		0.40	1.00	0.40			Average	11:15Am		
		0.36	1.00	0.36			Water Level at gauging station (m)	Start		
0.492	0.498	0.29	1.00	0.29	0.65	0.32	End			
0.503							Average			
		0.25	1.00	0.25			Type of current meter	Digital		
0.380	0.367	0.27	1.00	0.27	0.52	0.19	Table/formula	V = 0.162 * N + 0.010		
0.353							Using method	Iods ' wire ' weight by boat / bridge / walk		
		0.14	1.00	0.14			Calculator	Calculator		
0.351	0.356				0.14	0.05	Checker			
0.360							Total Discharge (m ³ /s)	1.46		
							Total area cross section(m ²)	2.62		
							Average Velocity (m/s)	0.56		
							Notes	Catchment Area (km ²)= 35.0		
								Discharge (m ³ /s)= 1.46		
								Specific Discharge (m ³ /s*100km ²)= 4.17		
							Remark:			

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS										
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)					
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds			
							1st	2nd	Average	
1	0	0.00	0.00	0.000						
2	1	0.34	0.37	0.355	0.213	100	=(10 x 10)	31.72		31.720
					0.213	110	=(10 x 11)	36.92		36.920
3	2	0.35	0.37	0.360						
4	3	0.38	0.40	0.390	0.234	100	=(10 x 10)	26.30		26.300
					0.234	110	=(10 x 11)	30.44		30.440
5	4	0.37	0.39	0.380						
6	5	0.30	0.32	0.310	0.186	90	=(10 x 9)	25.55		25.550
					0.186	120	=(10 x 12)	33.84		33.840
7	6	0.25	0.25	0.250						
8	7	0.25	0.27	0.260	0.156	100	=(10 x 10)	31.55		31.550
					0.156	110	=(10 x 11)	35.02		35.020
9	8	0.23	0.25	0.240						
10	9	0.00	0.00	0.000	0.000	100	=(10 x 10)	21.10		21.100
					0.000	110	=(10 x 11)	23.00		23.000
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										

HOME WORKS						Station No.		Downstream of the culvert		
Velocity		Area of cross section			Discharge (m ³ /s)	Observation Date		Yr: 2012	Mon: 9	Date: 23
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)		Observer Name	Mesure Wrote	Ezekiel Reuben		
0.521	0.507	0.18	1.00	0.18	0.54	0.27	Weather	:clear, :fine, :cloudy :rain		
0.493		0.36	1.00	0.36			Wind blows	from Down/s, Up/s, Left, Right		
0.626	0.611	0.38	1.00	0.38	0.77	0.47	Measurement Time (Hour, min)	Start	2:30 PM	
		0.39	1.00	0.39				End	4:30PM	
0.581	0.583	0.35	1.00	0.35	0.63	0.37	Water Level at gauging station (m)	Average	3:30PM	
		0.28	1.00	0.28				Initial Point	No.1 Point	
0.523	0.521	0.26	1.00	0.26	0.51	0.27	Current meter	Type of current meter	Digital	
		0.25	1.00	0.25				Table/formula	V = 0.162 * N + 0.010	
0.778	0.782	0.12	1.00	0.12	0.12	0.09	Result	Using method	fods · wire · weight by boat / bridge / walk	
		0.785						Calculator	Calculator	
							Checker			
							Notes	Total Discharge (m ³ /s)	1.47	
								Total area cross section(m ²)	2.57	
								Average Velocity(m/s)	0.57	
								Catchment Area (km ²)=	35.0	
								Discharge (m ³ /s)=	1.47	
								Specific Discharge (m ³ /s*100km ²)=	4.20	
							Remark:	There was rain the previous night		

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS										
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)					
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds			
							1st	2nd	Average	
1	0	0.00	0.00	0.000						
2	1	0.34	0.34	0.340	0.204	100	=(10 x 10)	23.59		23.590
					0.204	100	=(10 x 10)	26.99		26.990
3	2	0.38	0.40	0.390						
4	3	0.38	0.42	0.400	0.240	90	=(10 x 9)	19.48		19.480
					0.240	130	=(10 x 13)	28.94		28.940
5	4	0.38	0.40	0.390						
6	5	0.29	0.33	0.310	0.186	100	=(10 x 10)	28.39		28.390
					0.186	120	=(10 x 12)	33.34		33.340
7	6	0.24	0.27	0.255						
8	7	0.23	0.27	0.250	0.150	100	=(10 x 10)	28.90		28.900
					0.150	110	=(10 x 11)	33.48		33.480
9	8	0.29	0.30	0.295						
10	9	0.00	0.00	0.000	0.000	100	=(10 x 10)	26.83		26.830
					0.000	120	=(10 x 12)	32.63		32.630
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										

HOME WORKS						Station No.		Downstream of the culvert			
Velocity		Area of cross section				Discharge (m ³ /s)	Observation Date		Yr: 2012	Mon: 9	Date: 24
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)	Total Area(m ²)		Observer Name	Mesure Wrote	Ezekiel, Reuben		
0.697	0.654	0.17	1.00	0.17	0.54	0.35	Weather	clear, fine, cloudy, rain	Ezekiel		
0.610		0.37	1.00	0.37			Wind blows	from Down/s, Up/s, Left, Right	Wind power	0=None, 1=light, 2=windy, 3=strong, 4=very strong	
0.758	0.748	0.40	1.00	0.40	0.80	0.60	Mesurement Time (Hour, min)	Start	10:30 AM		
0.738		0.40	1.00	0.40			End	12:00PM			
0.581	0.587	0.35	1.00	0.35	0.63	0.37	Water Level at gauging station (m)	Initial Point	No.1 Point		
							0.593	0.28	1.00	0.28	End
0.571	0.557	0.25	1.00	0.25	0.52	0.29	Current meter	Type of current meter	Digital		
0.542		0.27	1.00	0.27			Table/formula	V = 0.162 * N + 0.010			
0.614	0.610	0.15	1.00	0.15	0.15	0.09	Using method	Jods · wire · weight			
							0.606	0.15	1.00	0.15	by boat / bridge / walk
							Calculator	Calculator			
							Checker				
							Result	Total Discharge (m ³ /s)	1.70		
								Total area cross section(m ²)	2.64		
								Average Velocity (m/s)	0.64		
							Notes	Catchment Area (km ²)=	35.0		
								Discharge (m ³ /s)=	1.70		
								Specific Discharge (m ³ /s*100km ²)=	4.86		
							Remark:	THERE WAS HEAVY RAIN THE PREVIOUS NIGHT-23 RD .-09-2012			

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS									
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)				
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds		
							1st	2nd	Average
1	0	0.00	0.00	0.000					
2	1	0.32	0.34	0.330	0.198	100	=(10 x 10)	22.51	22.510
					0.198	110	=(10 x 11)	24.72	24.720
3	2	0.39	0.39	0.390					
4	3	0.41	0.45	0.430	0.258	90	=(10 x 9)	21.24	21.240
					0.258	120	=(10 x 12)	26.82	26.820
5	4	0.34	0.36	0.350					
6	5	0.28	0.30	0.290	0.174	100	=(10 x 10)	28.43	28.430
					0.174	120	=(10 x 12)	33.04	33.040
7	6	0.24	0.26	0.250					
8	7	0.26	0.28	0.270	0.162	100	=(10 x 10)	32.41	32.410
					0.162	120	=(10 x 12)	41.16	41.160
9	8	0.26	0.31	0.285					
10	9	0.00	0.00	0.000	0.000	90	=(10 x 9)	25.27	25.270
					0.000	100	=(10 x 10)	27.39	27.390
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									

HOME WORKS						Station No.		Downstream of the culvert			
Velocity		Area of cross section				Discharge (m ³ /s)	Observation Date		Yr: 2012	Mon: 9	Date: 24
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)	Total Area(m ²)		Observer Name	Mesure Wrote	Ezekiel, Reuben		
0.730	0.731	0.17	1.00	0.17	0.53	0.39	Weather	:clear, :fine, :cloudy, :rain			
0.731		0.36	1.00	0.36			Wind blows	from Down/s, Up/s, Left, Right			
0.696	0.716	0.41	1.00	0.41	0.80	0.57	Mesurement Time (Hour, min)	Start	2:30 PM		
0.735		0.39	1.00	0.39			End	4:30PM			
0.580	0.589	0.32	1.00	0.32	0.59	0.35	Water Level at gauging station (m)	Initial Point	No.1 Point		
0.598		0.27	1.00	0.27			Start				
0.510	0.496	0.26	1.00	0.26	0.54	0.27	Type of current meter	Digital			
0.482		0.28	1.00	0.28			Table/formula	V = 0.162 * N + 0.010			
0.587	0.594	0.14	1.00	0.14	0.14	0.08	Using method	lods · wire · weight			
0.601		0.14	1.00	0.14			by boat / bridge / walk				
							Calculator	Calculator			
							Checker				
							Total Discharge (m ³ /s)	1.66			
							Total area cross section(m ²)	2.60			
							Average Velocity (m/s)	0.64			
							Notes	Catchment Area (km ²)= 35.0 Discharge (m ³ /s)= 1.66 Specific Discharge (m ³ /s*100km ²)= 4.74			
							Remark:	There was rain the previous night 23 RD -09-2012			

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS										
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)					
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds			
							1st	2nd	Average	
1	0	0.00	0.00	0.000						
2	1	0.35	0.35	0.350	0.210	100	=(10 x 10)	26.10		26.100
					0.210	110	=(10 x 11)	29.90		29.900
3	2	0.40	0.42	0.410						
4	3	0.42	0.43	0.425	0.255	100	=(10 x 10)	26.62		26.620
					0.255	120	=(10 x 12)	31.25		31.250
5	4	0.38	0.40	0.390						
6	5	0.32	0.36	0.340	0.204	100	=(10 x 10)	24.98		24.980
					0.204	120	=(10 x 12)	29.68		29.680
7	6	0.25	0.27	0.260						
8	7	0.25	0.27	0.260	0.156	90	=(10 x 9)	36.78		36.780
					0.156	100	=(10 x 10)	43.65		43.650
9	8	0.27	0.29	0.280						
10	9	0.00	0.00	0.000	0.000	100	=(10 x 10)	28.80		28.800
					0.000	110	=(10 x 11)	31.03		31.030
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										

HOME WORKS							Station No.		Downstream of the culvert		
Velocity		Area of cross section			Discharge (m ³ /s)	Observation Date					
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)		Yr: 2012	Mon: 9	Date: 25			
0.631	0.619	0.18	1.00	0.18	0.56	0.35	Observer	Mesure	Ezekiel, Reuben		
0.606		0.38	1.00	0.38			Name	Wrote	Ezekiel		
0.619	0.626	0.42	1.00	0.42	0.83	0.52	Weather	Weather	clear, fine, cloudy, rain		
0.632		0.41	1.00	0.41			Wind blows	from Down/s, Up/s, Left, Right			
0.659	0.662	0.37	1.00	0.37	0.67	0.44	Wind power	0:none, 1:light, 2:windy, 3:strong, 4:very strong			
0.665		0.30	1.00	0.30			Measurement Time (Hour, min)	Start	10:30 AM		
0.406	0.394	0.26	1.00	0.26	0.53	0.21	End	12:00PM			
0.381		0.27	1.00	0.27			Average	11:15Am			
0.573	0.579	0.14	1.00	0.14	0.14	0.08	Water Level at gauging station (m)	Start	Initial Point	No.1 Point	
0.584		0.14	1.00	0.14			End				
							Average				
							Current meter	Type of current meter	Digital		
							Table/formula	V = 0.162 * N + 0.010			
							Using method	lods · wire · weight			
							Calculator	by boat / bridge / walk			
							Checker	Calculator			
							Result	Total Discharge (m ³ /s)	1.60		
								Total area cross section(m ²)	2.73		
								Average Velocity(m/s)	0.59		
							Notes	Catchment Area (km ²)= 35.0 Discharge (m ³ /s)= 1.60 Specific Discharge (m ³ /s*100km ²)= 4.57			
							Remark:	THERE WAS RAIN THE PREVIOUS NIGHT-24TH 09-2012			

JICA Expert Team (Field Notebook of Discharge Observation)

FIELD WORKS										
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)					
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds			
							1st	2nd	Average	
1	0	0.00	0.00	0.000						
2	1	0.35	0.35	0.350	0.210	100	=(10 x 10)	33.47		33.470
					0.210	110	=(10 x 11)	35.85		35.850
3	2	0.42	0.43	0.425						
4	3	0.43	0.44	0.435	0.261	90	=(10 x 9)	22.74		22.740
					0.261	100	=(10 x 10)	25.16		25.160
5	4	0.40	0.40	0.400						
6	5	0.32	0.31	0.315	0.189	100	=(10 x 10)	24.61		24.610
					0.189	120	=(10 x 12)	29.46		29.460
7	6	0.27	0.29	0.280						
8	7	0.25	0.26	0.255	0.153	90	=(10 x 9)	34.99		34.990
					0.153	100	=(10 x 10)	37.73		37.730
9	8	0.29	0.29	0.290						
10	9	0.00	0.00	0.000	0.000	100	=(10 x 10)	26.45		26.450
					0.000	110	=(10 x 11)	29.91		29.910
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										

HOME WORKS						Station No.		Downstream of the culvert		
Velocity		Area of cross section				Discharge (m³/s)	Observation Date			
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m²)	Total Area(m²)		Yr: 2012	Mon: 9	Date: 25	
0.494	0.501	0.18	1.00	0.18		0.57	0.29	Observer		
0.507		0.39	1.00	0.39				Mesure		
0.651	0.653	0.43	1.00	0.43		0.85	0.55	Name		
0.654		0.42	1.00	0.42				Wrote		
0.668	0.669	0.36	1.00	0.36		0.66	0.44	Weather		
0.670		0.30	1.00	0.30				Weather		
0.427	0.433	0.27	1.00	0.27		0.54	0.23	Measurement		
0.439		0.27	1.00	0.27				Time		
0.622	0.614	0.15	1.00	0.15		0.15	0.09	(Hour, min)		
0.606								Water Level at gauging station (m)		
								Start	2:30 PM	
								End	4:30PM	
								Average	3:30PM	
								Initial Point	No.1 Point	
								Start		
								End		
								Average		
								Type of current meter	Digital	
								Table/formula	V = 0.162 * N + 0.010	
								Using method	lods · wire · weight	
									by boat / bridge / walk	
								Calculator	Calculator	
								Checker		
								Total Discharge (m³/s)	1.60	
								Total area cross section(m²)	2.77	
								Average Velocity(m/s)	0.58	
								Notes		
								Catchment Area (km²)=	35.0	
								Discharge (m³/s)=	1.60	
								Specific Discharge (m³/s*100km²)=	4.57	
								Remark		
								There was rain the previous night		

(Field Notebook of Discharge Observation)

FIELD WORKS									
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)				
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds		
							1st	2nd	Average
1	0	0.00	0.00	0.000					
2	1	0.22	0.22	0.220	0.090	20	=(10 x 2)	42.50	42.500
					0.120	30	=(10 x 3)	52.70	52.700
3	2.5	0.22	0.23	0.225	0.135	30	=(10 x 3)	44.10	44.100
					0.135	40	=(10 x 4)	55.40	55.400
4	3.5	0.17	0.17	0.170	0.102	40	=(10 x 4)	41.80	41.800
					0.102	30	=(10 x 3)	55.90	55.900
5	4.5	0.31	0.27	0.290	0.174	30	=(10 x 3)	58.80	58.800
					0.174	30	=(10 x 3)	53.00	53.000
6	5.5	0.31	0.28	0.295	0.177	30	=(10 x 3)	49.90	49.900
					0.177	30	=(10 x 3)	47.90	47.900
7	6.5	0.30	0.30	0.300	0.180	70	=(10 x 7)	45.60	45.600
					0.180	70	=(10 x 7)	47.90	47.900
8	7.95	0.24	0.24	0.240	0.144	60	=(10 x 6)	47.00	47.000
					0.144	50	=(10 x 5)	49.60	49.600

HOME WORKS						Station No.		Downstream of the culvert		
Velocity		Area of cross section			Discharge (m ³ /s)	Observation Date		Yr: 2014	Mon: 1	Date: 30
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of sectionm ²		Observer	Mesure	skiel, Reub Judith/Samejimah		
						Name	Wrote	Ezekiel Judith		
						Weather		:clear, :fine, :cloudy :rain		
						Wind blows		from Down/s, Up/s, Left, Right		
						Wind power		0:None, 1:light, 2:windy, 3:strong, 4:very strong		
						Mesurement Time (Hour, min)		Start	10:30 AM	
								End	11:20 AM	
								Average	10:55 AM	
						Water Level at gauging station (m)		Start	Initial Point	
								End	No.1 Point	
								Average		
						Current meter		Type of current meter		Digital
								Table/formula		V = 0.162 * N + 0.010
								Using method		lods · wire · weight by boat / bridge / walk
								Calculator		Calculator
								Checker		
								Total Discharge (m ³ /s)		1.33
								Total area cross section(m ²)		8.11
								Average Velocity(m/s)		0.16
								Notes		Catchment Area (km ²)= 35.0
										Discharge (m ³ /s)= 1.33
										Specific Discharge (m ³ /s*100km ²)= 3.80
								Remark:		

(Field Notebook of Discharge Observation)

FIELD WORKS									
No. of measurement	Distance from bank (m)	Depth of Water. (m)			Velocity Measurement (Flow speed)				
		First (one way)	Second (return)	Average	Depth of observation(m)	Count of current meter	Time in seconds		
							1st	2nd	Average
1	0	0.00	0.00	0.000					
2	7.95	0.21	0.24	0.225	0.090	50	=(10 x 5)	47.80	47.800
					0.120	60	=(10 x 6)	49.20	49.200
3	6.5	0.28	0.36	0.320	0.192	60	=(10 x 6)	54.60	54.600
					0.192	70	=(10 x 7)	48.00	48.000
4	5.5	0.33	0.20	0.265	0.159	50	=(10 x 5)	58.40	58.400
					0.159	60	=(10 x 6)	47.80	47.800
5	4.5	0.32	0.30	0.310	0.186	20	=(10 x 2)	48.30	48.300
					0.186	50	=(10 x 5)	52.20	52.200
6	3.5	0.16	0.18	0.170	0.102	30	=(10 x 3)	65.40	65.400
					0.102	50	=(10 x 5)	45.10	45.100
7	2.5	0.22	0.23	0.225	0.135	20	=(10 x 2)	48.70	48.700
					0.135	30	=(10 x 3)	45.10	45.100
8	1	0.19	0.21	0.200	0.120	20	=(10 x 2)	41.20	41.200
					0.120	40	=(10 x 4)	51.00	51.000

HOME WORKS						Station No.		Downstream of the culvert		
Velocity		Area of cross section			Discharge (m ³ /s)	Observation Date		Yr: 2014	Mon: 1	Date: 30
Mesu. Veloc. at point(m/s)	Mean meas. Veloc.in vert(m/s)	Average depth(m)	Width of section(m)	Area of Section(m ²)		Observer Name	Mesure Wrote	Ezekiel, Reub Judith/Samejimah Judith		
0.179	0.194	0.11	7.95	0.87	0.87	0.17	Weather	:clear, :fine, :cloudy, :rain		
0.208							Wind blows	from Down/s, Up/s, Left, Right		
							Wind power	0:none, 1:light, 2:windy, 3:strong, 4:very strong		
							Measurement Time (Hour, min)	Start	11:30 AM	
0.188	0.217	0.32	6.50	2.08	2.08	0.45	End	12:20 PM		
0.246							Average	11:55 AM		
							Water Level at gauging station (m)	Initial Point	No.1 Point	
0.149	0.181	0.27	5.50	1.49	1.49	0.27	Start			
0.213							End			
							Average			
							Type of current meter	Digital		
							Table/formula	V = 0.162 * N + 0.010		
							Using method	fods · wire · weight		
0.077	0.121	0.31	4.50	1.40	1.40	0.17	by boat / bridge / walk			
0.165							Calculator	Calculator		
							Checker			
							Total Discharge (m ³ /s)	1.22		
0.084	0.137	0.17	3.50	0.60	0.60	0.08	Total area cross section(m ²)	7.22		
0.190							Average Velocity (m/s)	0.17		
							Notes	Catchment Area (km ²)= 35.0		
0.077	0.098	0.23	2.50	0.58	0.58	0.06	Discharge (m ³ /s)=	1.22		
0.118							Specific Discharge (m ³ /s*100km ²)=	3.49		
							Remark:			
0.089	0.113	0.20	1.00	0.20	0.20	0.02				
0.137										

Annex 2

Cross Section Data for Water Level Calculation

List of Data


Cross Section Data 171
Cross Section Data 272
Cross Section Figures73

Simple Pre-F/S on Asurur MHP

Cross Section Data 1

CH+1.0		CH+28.0		CH+56.0		CH+78.0		CH+110.0		CH+143.0		CH+165.0															
Height (EL.m)	Distance (m)	Height (EL.m)	Distance (m)	Height (EL.m)	Distance (m)	Height (EL.m)	Distance (m)	Height (EL.m)	Distance (m)	Height (EL.m)	Distance (m)	Height (EL.m)	Distance (m)														
L	50.0	L	50.0	L	50.0	L	50.0	L	50.0	L	50.0	L	50.0														
	1,710.2		46.2		1,717.6		47.3		1,725.0		49.5		1,729.0		48.5		1,738.0		49.3		1,744.0		49.4		1,744.0		48.8
	1,710.2		44.6		1,717.4		43.2		1,724.8		48.0		1,728.0		46.2		1,737.0		46.6		1,743.0		45.5		1,743.0		43.4
	1,710.2		41.4		1,717.4		36.7		1,724.0		46.9		1,727.0		44.0		1,736.0		43.7		1,742.0		41.8		1,742.0		38.5
	1,710.0		38.5		1,717.6		35.0		1,723.0		45.0		1,726.8		43.6		1,735.0		40.6		1,741.0		38.2		1,741.0		33.7
	1,709.8		35.2		1,717.8		34.1		1,722.0		42.6		1,726.6		42.9		1,734.0		37.1		1,740.0		34.7		1,740.0		29.6
	1,709.6		31.6		1,718.0		33.5		1,721.0		40.2		1,726.6		41.1		1,733.8		36.4		1,739.0		31.3		1,739.0		27.3
	1,709.4		17.7		1,718.2		32.9		1,720.0		37.8		1,726.8		40.2		1,733.6		36.0		1,738.0		28.8		1,738.0		25.0
	1,709.2		10.5		1,718.4		32.5		1,719.0		35.4		1,727.0		39.6		1,733.0		35.6		1,737.0		27.1		1,737.0		22.7
	1,709.0		3.8		1,719.0		31.7		1,718.0		32.9		1,727.2		38.6		1,732.0		35.0		1,736.0		25.2		1,736.0		20.4
C	1,708.9		0.0		1,719.2		31.5		1,717.0		30.3		1,727.4		38.0		1,731.8		34.9		1,735.0		23.3		1,735.0		18.1
	1,708.8		-2.7		1,719.2		31.2		1,716.0		27.3		1,727.6		37.6		1,731.6		34.7		1,734.0		21.4		1,734.0		15.8
	1,708.6		-8.5		1,719.0		31.0		1,715.0		24.4		1,728.0		37.2		1,731.4		34.4		1,733.0		19.4		1,733.0		13.5
	1,708.4		-12.8		1,718.0		30.2		1,714.0		21.3		1,728.6		36.5		1,731.0		33.7		1,732.0		17.5		1,732.0		11.2
	1,708.6		-13.9		1,717.0		29.5		1,713.4		19.1		1,728.6		36.5		1,730.0		32.0		1,731.0		15.2		1,731.0		8.6
	1,708.8		-14.6		1,716.0		29.0		1,713.0		18.4		1,728.0		35.7		1,729.0		30.3		1,730.8		14.6		1,730.4		6.9
	1,709.0		-15.1		1,715.0		28.6		1,712.0		16.3		1,727.8		34.5		1,728.0		28.8		1,730.6		14.0		1,730.2		5.7
	1,710.0		-17.6		1,714.4		28.3		1,712.0		16.2		1,727.0		32.9		1,727.0		27.3		1,730.4		12.8		1,730.1		2.9
	1,711.0		-20.0		1,714.0		27.7		1,713.0		15.7		1,726.0		31.6		1,726.0		25.9		1,730.4		12.2		1,730.2		1.9
	1,712.0		-22.2		1,713.6		27.1		1,714.0		15.3		1,725.0		30.5		1,725.0		24.7		1,730.6		11.3		1,730.4		0.7
	1,713.0		-23.9		1,713.4		26.6		1,715.0		15.0		1,724.0		29.7		1,724.0		23.4		1,730.6		10.3		1,730.6		0.3
	1,714.0		-25.6		1,713.2		25.7		1,716.0		14.6		1,723.0		29.0		1,723.6		22.9		1,730.4		9.5		1,730.8		0.0
	1,715.0		-27.3		1,713.0		24.8		1,716.2		13.9		1,722.0		28.4		1,723.4		22.5		1,730.2		8.9		1,731.0		-0.6
	1,716.0		-28.9		1,712.0		20.6		1,716.4		13.2		1,721.0		27.7		1,723.0		21.4		1,730.0		8.1		1,731.2		-1.5
	1,717.0		-30.6		1,711.8		19.4		1,716.4		12.9		1,720.8		27.5		1,722.0		19.4		1,729.0		2.6		1,731.2		-4.4
	1,718.0		-32.3		1,711.6		17.9		1,716.2		12.6		1,720.4		26.8		1,721.0		17.7	C	1,728.5		0.0		1,731.1		-8.5
	1,719.0		-34.1		1,711.4		15.9		1,716.0		12.3		1,720.2		26.3		1,720.0		16.1		1,728.4		-1.2		1,731.2		-13.1
	1,720.0		-35.9		1,711.2		13.5		1,715.0		10.6		1,720.0		25.6		1,719.0		14.6		1,728.6		-3.8		1,731.4		-13.6
R			-50.0		1,711.0		10.7		1,714.0		9.1		1,719.4		22.8		1,718.0		13.0		1,728.8		-6.1		1,732.0		-14.8
					1,710.8		7.3		1,713.0		7.7		1,719.0		21.2		1,717.0		12.0		1,729.0		-8.4		1,733.0		-16.6
					1,710.6		3.1		1,712.0		6.3		1,718.8		20.2		1,716.8		11.9		1,730.0		-15.0		1,734.0		-18.5
				C	1,710.5		0.0		1,711.0		5.0		1,718.4		19.0		1,716.6		11.1		1,731.0		-17.5		1,735.0		-20.4
					1,710.5		-4.3		1,710.0		3.6		1,718.0		18.5		1,716.6		10.7		1,732.0		-20.3		1,736.0		-22.4
					1,710.6		-10.8		1,709.0		2.3		1,717.0		17.4		1,717.0		10.1		1,733.0		-22.6		1,737.0		-24.3
					1,710.8		-13.3		1,708.2		0.9		1,716.0		16.3		1,717.2		9.7		1,734.0		-24.8		1,738.0		-26.2
					1,711.0		-15.1		1,708.2		0.7		1,715.0		15.3		1,717.2		8.7		1,735.0		-26.9		1,739.0		-28.0
					1,711.2		-16.6	C	1,708.5		0.0		1,714.0		14.3		1,717.0		7.9		1,736.0		-28.9		1,740.0		-29.8
					1,711.4		-18.0		1,709.0		-1.5		1,713.4		13.7		1,716.8		7.4		1,737.0		-30.8		1,741.0		-31.5
					1,711.6		-18.9		1,710.0		-4.2		1,713.2		13.3		1,716.0		5.9		1,738.0		-33.0		1,742.0		-33.2
					1,711.8		-19.6		1,711.0		-7.1		1,713.0		12.7		1,715.0		4.4		1,738.6		-34.6		1,742.4		-33.9
					1,712.0		-20.2		1,712.0		-10.0		1,713.0		11.9		1,714.8		4.1		1,738.8		-35.6		1,742.6		-34.5
					1,713.0		-22.7		1,713.0		-13.0		1,714.0		8.2		1,714.4		3.0		1,739.0		-37.2		1,742.8		-35.3
					1,714.0		-25.0		1,714.0		-16.0		1,714.2		7.4		1,714.6		0.9		1,740.0		-42.4		1,742.0		-36.1
					1,715.0		-27.1		1,714.4		-17.3		1,714.2		6.5	C	1,714.8		0.0		1,741.0		-46.7		1,741.8		-36.2
					1,716.0		-29.2		1,714.6		-18.0		1,714.0		6.0		1,715.0		-0.8		1,741.8		-49.7		1,741.6		-36.5
					1,717.0		-31.3		1,714.8		-18.9		1,713.0		3.7		1,716.0		-4.6	R	0.0		-50.0		1,741.4		-36.9
					1,718.0		-33.2		1,715.0		-20.5		1,712.0		1.6		1,717.0		-8.3						1,741.6		-38.0
					1,719.0		-35.1		1,714.4		-22.1	C	1,711.2		0.0		1,718.0		-12.2						1,741.8		-38.6
					1,720.0		-36.9		1,715.0		-23.4		1,711.0		-0.4		1,719.0		-16.6						1,742.0		-39.1
					1,721.0		-38.6		1,716.0		-25.2		1,710.4		-1.7		1,719.2		-17.6						1,743.0		-41.3
				R	1,721.2		-39.9		1,717.0		-27.0		1,710.4		-2.2		1,719.4		-18.7						1,744.0		-43.3
							-50.0		1,718.0		-28.9		1,711.0		-3.6		1,719.6		-19.9						1,745.0		-45.2
									1,719.0		-30.8		1,712.0		-5.6		1,719.8		-21.3						1,746.0		-47.1
									1,720.0		-32.8		1,713.0		-7.6		1,720.0		-23.3						1,747.0		-49.1
									1,721.0		-34.8		1,714.0		-9.5		1,721.0		-25.1				R	0.0		-50.0	
									1,722.0		-37.0		1,715.0		-11.5		1,722.0		-26.6								
									1,723.0		-39.6		1,716.0		-13.3		1,723.0		-28.2								
									1,724.0		-41.5		1,717.0		-15.2		1,724.0		-29.9								
									1,725.0		-43.6		1,718.0		-17.0		1,725.0		-31.6								
									1,725.2		-44.4		1,719.0		-18.9		1,726.0		-33.5								
									1,725.4		-45.2		1,720.0		-21.0		1,727.0		-35.5								
									1,725.6		-46.2		1,720.6		-22.2		1,728.0		-37.7								
									1,725.8		-47.4		1,720.8		-22.6		1,729.0		-40.4								

Cross Section Figures





Annex 3

Preliminary Drawings of Asurur MHP

List of Drawings

- ASR – 01 Location Map
- ASR – 02 General Layout and Intake Weir
- ASR – 03 Waterway and Powerhouse



Notes


Topographic data are using electric files of the topographic maps with scale of 1:50,000 which were purchased from the Land Survey Department under the Ministry of Land, Housing and Urban Development. The sheet numbers are; 102-4/4, 103/3, 116/2, & 117/1.

Legend


- Proposed Asurur Site
- Town, Gauging Station (G/S)
- Catchment Boundary




RURAL ELECTRIFICATION AUTHORITY (REA)	
SIMPLE PRE-FEASIBILITY STUDY ON ASURUR MHP SCHEME	
Drawing Title:	
LOCATION MAP	
Prepared by: Working Group of MHP under Project for Establishment of Rural Electrification Model Using Renewable Energy	Drawing No: ASR-01 Month Year: February 2015




GENERAL LAYOUT
Scale A




TYPICAL SECTION OF INTAKE WEIR (SECTION A-A)
Scale B



SECTION OF SAND FLUSHING WAY (SECTION B-B)
Scale B




PROFILE OF INTAKE WEIR
Scale B



- Notes**
1. The topographic map was prepared with scale of 1:500 by JICA Expert Team in July 2012.
 2. The contours surrounding the planned head tank were not available. The working group studied and planned the general layout based on the assumed center lines as indicated.
 3. The centerline and cross sections of the river course were defined by the working group for hydraulic analysis.

RURAL ELECTRIFICATION AUTHORITY (REA)	
SIMPLE PRE-FEASIBILITY STUDY ON ASURUR MHP SCHEME	
Drawing Title:	
GENERAL LAYOUT AND INTAKE WEIR	
Prepared by: Working Group of MHP under Project for Establishment of Rural Electrification Model Using Renewable Energy	Drawing No: ASR-02 Month Year: February 2015



RURAL ELECTRIFICATION AUTHORITY (REA)	
SIMPLE PRE-FEASIBILITY STUDY ON ASURUR MHP SCHEME	
Drawing Title: WATERWAY AND POWERHOUSE	
Prepared by: Working Group of MHP under Project for Establishment of Rural Electrification Model Using Renewable Energy	Drawing No: ASR-03 Month Year: February 2015