

## Appendix-4

### WWTP

- 4.1 Design Concept of WWTP
- 4.2 Mass Balance
- 4.3 Hydraulic Profile
- 4.4 Capacity Calculation
- 4.5 Drawings of Facilities
- 4.6 Drawings of Temporary Works and Foundation Works
- 4.7 Construction Cost
- 4.8 Replacement Cost
- 4.9 Operation & Maintenance Cost



## Appendix 4.1 Design Concept of Pluit WWTP

### 1. Basic Design Condition

#### (1) Inflow Waste water Quantity

Inflow Rate based on Revised Master Plan are as follows.

<b>Average Daily Flow Rate</b>	<b>198,000 m<sup>3</sup>/d</b>
<b>Maximum Daily Flow Rate</b>	<b>264,000 m<sup>3</sup>/d</b>
<b>Maximum Hourly Flow Ra</b>	<b>400,000 m<sup>3</sup>/d</b>

According to Pipe construction plan, phased inflow rate are determined as follows

	<b>Final Phase</b>	<b>Phase 1</b>
<b>Average Daily Flow Rate</b>	<b>200,000 m<sup>3</sup>/d</b>	<b>100,000 m<sup>3</sup>/d</b>
<b>Maximum Daily Flow Rate</b>	<b>264,000 m<sup>3</sup>/d</b>	<b>132,000 m<sup>3</sup>/d</b>
<b>Maximum Hourly Flow Ra</b>	<b>350,000 m<sup>3</sup>/d</b>	<b>175,000 m<sup>3</sup>/d</b>

#### (2) Inflow Waste water Quality

The inflow wastewater qualities are determined by actual data in JAKARTA.

<b>BOD</b>	<b>120</b>	<b>mg/L</b>
<b>TSS</b>	<b>120</b>	<b>mg/L</b>
<b>T-N</b>	<b>40</b>	<b>mg/L</b>

#### (3) Effluent Quality

Effluent qualities are in accordance with Effluent Quality Standards established in INDONESIA.

Source: Quality standard of liquid waste (DKI Jakarta Governor decree No.122, 2005)

BOD	<50	mg/L
TSS	<50	mg/L
Ammonia	<10	mg/L

Target treated water qualities are set as follows

<b>BOD</b>	<b>&lt;10</b>	<b>mg/L</b>
<b>TSS</b>	<b>&lt;10</b>	<b>mg/L</b>
<b>Ammonia</b>	<b>&lt;5</b>	<b>mg/L</b>

(4) Wastewater Treatment Process

As No 1 priority of the site constraints, we choose the Treatment Process.  
As a result, to adopt the following treatment process.

**MBR (Membrane Bioreactor) Process**

(5) Sludge Treatment Process

Since adopting the MBR process, the thickening process is omitted.  
Therefore only the Dewatering process is established.

**Excess sludge ----- Dewatering ----- to Dump site**

(6) Inlet Pipe

Dimension	Diameter	2,000 mm
Invert Elevation	About	PP - 27.74 M (GL - 27.92M)

(7) Discharge facility


Discharge Stream	to Pluit Flood Control Pond	
Conduit Dimension	1,500mm <sup>H</sup> x 1,500mm <sup>W</sup> x 2 Lines	
Highest Water Level at Discharge Point	PP + 1.00 M	
Highest Water level in Existing Report *	PP + 0.50 M	
Highest Water Level in Flood History of the Past	PP + 1.00 M (Adopted)	
* Preparatory survey report on the project for urgent reconstruction of east pump station of Pluit in Jakarta, the Republic of Indonesia, JICA Yachiyo Engineering Co.,Ltd., 2010.6		

(8) Site Ground Elevation

Ground Elevation	PP + 0.30 M
------------------	-------------



2. Process Flow Diagram




### 3. Design criteria for each facilities


- (1) Coarse Screen  
 Opening 100 mm  
 Operation Manual
- (2) Fine Screen  
 Opening 15 mm  
 Operation Mechanical
- (3) Lift Pump  
 Type Volute Type Mixed Flow Pump  
 Capacity (No.1-5) Diamater 650 mm 61m<sup>3</sup>/min  
 Pump Head about 33.3 m (assumed value)
- (4) Grit Chamber  
 Type Aerated  
 Surface Loading 1,411 m<sup>3</sup>/m<sup>2</sup>/d (for Maximum Hourly)  
 Grit collector Screw Type  
 Grit lifter Sand pump
- (5) Mesh Drum Screen  
 Opening 1 mm
- (6) Equalization Tank  
 Retention Time 4 hr  
 Having a function of spillway and disinfection
- (7) Membrane Bioreactor Tank  
 Membrane placement inside the MBR Tank  
 MLSS in reactor Tank 9,000 mg/L  
 Design Flux 0.42 m<sup>3</sup>/m<sup>2</sup>/d  
 Excess Sludge Production Rate 72 %  
 BOD Removal Rate 0.12 kg-BOD/kg-SS/d  
 BOD Removal Rate per Unit Volume 1.44 kg-BOD/m<sup>3</sup>/d  
 Nitrification Rate 0.025 kg-N/kg-SS/d  
 Nitrification Rate per Unit Volume 0.3 kg-N/m<sup>3</sup>/d

(8) Oxygen Requirement		
a) for BOD Removal		
Required Unit Oxygen for BOD Removal		0.5 kg-O <sub>2</sub> /kg-BOD
b) for Nitrification		
Required Unit Oxygen for Nitrification		64/14 kg-O <sub>2</sub> /kg-N
c) for Endogenous Respiration		
Required Unit Oxygen for Endogenous Respiration		0.12 kg-O <sub>2</sub> /kg-VSS
MLVSS/MLSS		0.75
(9) Treated water Tank		
a) for back wash		
	about	400 m <sup>3</sup>
b) for recycling (in the future)		
	20,000m <sup>3</sup> /d*8hr	6,700 m <sup>3</sup>
(10) Dewatering Facility		
Dehydrator Type	Pressing Rotary Outer Cylinder-Type Screw Press	
Influent Sludge Concentration	0.9 %	
Dewatered Sludge Concentration	83 %	
Operation Time	23 hr	

# Appendix 4.2 Mass Balance



Appendix 4.3 Hydraulic Profile  
 Appendix 4.3.1 Hydraulic Profile



### Appendix4.3.2 Hydraulic Calculation

Point [Discharge Conduit (1)] ※Gravity flow

Formula:Manning

Content	Symbol	Case		
		QDM	QHM	Remarks
Flowrate (m <sup>3</sup> /d) (m <sup>3</sup> /s)	Q	200,000	350,000	
		2.315	4.051	
Number of pipes (pipe)	n	2	2	
Flowrate/pipe (m <sup>3</sup> /s)	q	1.158	2.026	
Schematic Diagram		Box Culvert 2 series Width 1.5 m Depth 1.5 m		
Length (m)	L	35	n=0.014	
Invert Elevation (M)	FH	-1.800		
Water Depth (m)	H'	1.500	1.500	Ho-FH
Cross Section (m <sup>2</sup> )	A	2.25	2.25	
Wetted Perimeter (m)	P	6.00	6.00	
Hydraulic Radius (m)	R	0.375	0.375	A/P
Velocity (m/s)	V	0.515	0.9	q/A
Hydraulic Gradient (‰)	I	0.192	0.587	$(n*V/R^{2/3})^2$
Down stream WL (M)	Ho	+1.000	+1.000	HHWL
HEAD LOSS	Outflow (m)	0.014	0.041	$1.0*(V^2/2g)*(Nm+1)$
	Friction (m)	0.007	0.021	I*L
LOSS	Inflow (m)	0.007	0.021	$0.5*(V^2/2g)*(Nm+1)$
	Total (m)	0.028	0.083	
Water Level (M)	H	+1.028	+1.083	Ho+h

Point [Discharge Conduit (2)] ※Gravity flow

Formula:Manning

Contents	Symbol	Case		
		QDM	QHM	
Flowrate (m <sup>3</sup> /d) (m <sup>3</sup> /s)	Q	100,000	175,000	
		1.157	2.025	
Number of pipes (pipe)	n	1	1	
Flowrate/pipe (m <sup>3</sup> /s)	q	1.157	2.025	
Schematic Diagram		Box Culvert 1 series Width 1.5 m Depth 1.5 m		
Length (m)	L	60.00	n=0.014	
Invert Elevation (M)	FH	-1.800		
Water Depth (m)	H'	1.500	1.500	Ho-FH
Cross Section (m <sup>2</sup> )	A	2.25	2.25	B*H'
Wetted Perimeter (m)	P	6.00	6.00	2*H'+B
Hydraulic Radius (m)	R	0.375	0.375	A/P
Velocity (m <sup>3</sup> /s)	V	0.514	0.9	p/A
Hydraulic Gradient (%)	I	0.191	0.587	(n*V/R <sup>2/3</sup> ) <sup>2</sup>
Down stream WL (M)	Ho	+1.028	+1.083	
HEAD LOSS	Outflow (m)	0.013	0.041	1.0*(V <sup>2</sup> /2g)*1
	Friction (m)	0.011	0.035	I*L
	Refraction (90°) (m)	0.013	0.041	0.99*(V <sup>2</sup> /2g)*1
	Inflow (m)	0.007	0.021	0.5*(V <sup>2</sup> /2g)*(Nm+1)
	Total (m)	h	0.044	0.138
Water Level (M)	H	+1.072	+1.221	Ho+h

Point [Discharge Channel (1)] ※Gravity flow

Formula:manning

Contents	Symbol	Case		
		QDm	QHm	
Flowrate (m3/d)	Q	0	37,500	
		(m3/s)	0	0.434
Number of pipes (pipe)	n	1	1	
Flowrate/pipe (m3/s)	q	0.000	0.434	
Schematic Diagram		Channel 1 series Width 1.0 m Depth 2.0 m		
Length (m)	L	68.00	n=0.014	
Invert Elevation (m)	FH	-0.800		
Water Depth (m)	H'	1.872	2.021	Ho-FH
Cross Section (m2)	A	1.872	2.021	B*H'
Wetted Perimeter (m)	P	4.74	5.04	2*H'+B
Hydraulic Radius (m)	R	0.395	0.401	A/P
Velocity (m3/s)	V	0	0.215	p/A
Hydraulic Gradient (%)	I	0.000	0.031	$(n*V/R^{2/3})^2$
Down stream WL (m)	Ho	+1.072	+1.221	
HEAD LOSS	Outflow (m)	0.000	0.002	$1.0*(V^2/2g)*1$
	Friction (m)	0.000	0.002	I*L
	Inflow (m)	0.000	0.001	$0.5*(V^2/2g)*(Nm+1)$
	Total (m)	h	0.000	0.005
Water Level (m)	H	+1.072	+1.226	Ho+h



Point [Discharge Channel (2)] ※Gravity flow

Formula:Manning

Contents	Symbol	Case		
		QDM	QHM	
Flowrate (m <sup>3</sup> /d) (m <sup>3</sup> /s)	Q	0	37,500	
		0	0.434	
Number of pipes (pipe)	n	1	1	
Flowrate/pipe (m <sup>3</sup> /s)	q	0.000	0.434	
Schematic Diagram		Channel 1 series Width 1.0 m Depth 2.0 m		
Length (m)	L	34.00	n=0.014	
Invert Elevation (M)	FH	-0.800	+2.500	
Water Depth (m)	H'	1.872	2.026	Ho-FH
Cross Section (m <sup>2</sup> )	A	1.872	2.026	B*H'
Wetted Perimeter (m)	P	4.74	5.05	2*H'+B
Hydraulic Radius (m)	R	0.395	0.401	A/P
Velocity (m <sup>3</sup> /s)	V	0	0.214	p/A
Hydraulic Gradient (%)	I	0.000	0.030	(n*V/R <sup>2/3</sup> ) <sup>2</sup>
Down stream WL (M)	Ho	+1.072	+1.226	
HEAD LOSS	Outflow (m)	0.000	0.002	1.0*(V <sup>2</sup> /2g)*1
	Friction (m)	0.000	0.001	I*L
	Inflow (m)	0.000	0.001	0.5*(V <sup>2</sup> /2g)*(Nm+1)
	Total (m)	h	0	0.004
Water Level (M)	H	+1.072	+1.230	Ho+h

Point [Discharge Channel (3)] ※Gravity flow

Formula:Manning

Contents	Symbol	Case		
		QDM	QHM	
Flowrate (m <sup>3</sup> /d) (m <sup>3</sup> /s)	Q	0	18,750	
		0	0.217	
Number of pipes (pipe)	n	1	1	
Flowrate/pipe (m <sup>3</sup> /s)	q	0.000	0.217	
Schematic Diagram		Channel 1 series Width 1.0 m Depth 2.0 m		
Length (m)	L	34.00	n=0.014	
Invert Elevation (M)	FH	-0.800	+2.500	
Water Depth (m)	H'	1.872	2.030	Ho-FH
Cross Section (m <sup>2</sup> )	A	1.872	2.03	B*H'
Wetted Perimeter (m)	P	4.74	5.06	2*H'+B
Hydraulic Radius (m)	R	0.395	0.401	A/P
Velocity (m <sup>3</sup> /s)	V	0	0.107	p/A
Hydraulic Gradient (%)	I	0.000	0.008	(n*V/R <sup>2/3</sup> ) <sup>2</sup>
Down stream WL (M)	Ho	+1.072	+1.230	
HEAD LOSS	Outflow (m)	0.000	0.001	1.0*(V <sup>2</sup> /2g)*1
	Friction (m)	0.000	0.000	I*L
	Inflow (m)	0.000	0.000	0.5*(V <sup>2</sup> /2g)*(Nm+1)
	Total (m)	h	0	0.001
Water Level (M)	H	+1.072	+1.231	Ho+h

Point [Equalization Tank] Outflow Trough

Formula : Thomas Gump

Contents	Symbol	Case		
		QDM	QHM	
Flowrate (m <sup>3</sup> /d) (m <sup>3</sup> /s)	Q	0	37,500	
		0.000	0.434	
Number of tanks (pipe)	n	8	8	
Flowrate/tank (m <sup>3</sup> /s)	q	0	0.05425	
Schematic Diagram				
Length (m)	L	4.750	m	
Width (m)	B	0.400		
Invert Elevation (M)	FH	+1.400		
Critical depth (m)	hc	0	0.123	$(q^2/9.8*B^2)^{1/3}$
Upper Water Depth (m)	ho	0.000	0.213	$\sqrt{3*hc}$
Lower Water Level (M)	Ho	+1.072	+1.226	
H				
E				
A				
D				
L				
O				
S				
S				
Water Level (M)	H	+1.400	+1.613	FH+ho

Point [Equalization Tank] Inflow gate

Formula:Manning

Contents	Symbol	Case		
		QDM	QHM	
Flowrate (m <sup>3</sup> /d) (m <sup>3</sup> /s)	Q	50,000	87,500	
		0.579	1.013	
Number of tanks (pipe)	n	8	8	
Flowrate/tank (m <sup>3</sup> /s)	q	0.072	0.127	
Schematic Diagram				
Gate Width (M)	B	0.400	m	
Bottom Elevator (M)	FH	+1.100		
Water Depth (m)	H'	0.500	0.548	Ho-FH
Cross Section (m <sup>2</sup> )	A	0.2	0.2192	B*H'
Velocity (m <sup>3</sup> /s)	V	0.362	0.578	q/A
Down stream WL (M)	Ho	+1.600	+1.648	
H E A D L O S S				
	Outflow (m)	0.007	0.017	1.0*(V <sup>2</sup> /2g)*1
Inflow (m)		0.003	0.009	0.5*(V <sup>2</sup> /2g)*(Nm+1)
Total (m)	h	0.010	0.026	
Water Level (M)	H	+1.610	+1.674	FH+h

Point [Equalization Tank] Distribution Channel (1)

Formula:Manning

Contents	Symbol	Case		
		QDM	QHM	
Flowrate (m <sup>3</sup> /d) (m <sup>3</sup> /s)	Q	25,000	30,649	
		0.289	0.355	
Number of pipes (pipe)	n	1	1	
Flowrate/pipe (m <sup>3</sup> /s)	q	0.289	0.355	
Schematic Diagram		Channel 1 series Width 1.5 Depth 2.0		
Length (m)	L	34.00	n=0.014	
Invert Elevation (M)	FH	+0.700	+4.000	
Water Depth (m)	H'	0.910	0.974	Ho-FH
Cross Section (m <sup>2</sup> )	A	1.365	1.461	B*H'
Velocity (m <sup>3</sup> /s)	V	0.212	0.243	q/A
Down stream WL (M)	Ho	+1.610	+1.674	
H E A D L O S S				
	Outflow (m)	0.002	0.003	1.0*(V <sup>2</sup> /2g)*1
Inflow (m)		0.001	0.002	0.5*(V <sup>2</sup> /2g)*(Nm+1)
Total (m)	h	0.003	0.005	
Water Level (M)	H	+1.613	+1.679	FH+h

Point [Equalization Tank] Distribution Channel (2)

Formula:Manning

Contents	Symbol	Case		
		QDM	QHM	
Flowrate (m <sup>3</sup> /d) (m <sup>3</sup> /s)	Q	50,000	61,298	
		0.579	0.709	
Number of pipes (pipe)	n	1	1	
Flowrate/pipe (m <sup>3</sup> /s)	q	0.579	0.709	
Schematic Diagram		Channel 1 series Width 1.5 m Depth 2.0 m		
Length (m)	L	34.00	n=0.014	
Invert Elevation (M)	FH	+0.700		
Water Depth (m)	H'	0.913	0.979	Ho-FH
Cross Section (m <sup>2</sup> )	A	1.3695	1.4685	B*H'
Wetted Perimeter (m)	P	3.33	3.46	2*H'+B
Hydraulic Radius (m)	R	0.412	0.425	A/P
Velocity (m <sup>3</sup> /s)	V	0.423	0.483	p/A
Hydraulic Gradient (%)	I	0.114	0.143	(n*V/R <sup>2/3</sup> ) <sup>2</sup>
Down stream WL (M)	Ho	+1.613	+1.679	
HEAD LOSS				
	Friction (m)		0.004	0.005
LOSS				
	Inflow (m)		0.005	0.006
Total (m)	h	0.009	0.011	
Water Level (M)	H	+1.622	+1.690	Ho+h

Point [Equalization Tank from Grit chamber] Connection conduit (1)

Formula:Manning

Contents	Symbol	Case		
		QDM	QHM	
Flowrate (m <sup>3</sup> /d) (m <sup>3</sup> /s)	Q	100,000	175,000	
		1.157	2.025	
Number of pipes (pipe)	n	1	1	
Flowrate/pipe (m <sup>3</sup> /s)	q	1.157	2.025	
Schematic Diagram		Channel 1 series Width 1.5 m Depth 1.5 m		
Length (m)	L	42.00	n=0.014	
Invert Elevation (M)	FH	-1.800	+1.500	
Water Depth (m)	H'	1.500	1.500	Ho-FH
Cross Section (m <sup>2</sup> )	A	2.25	2.25	B*H'
Wetted Perimeter (m)	P	6.00	6.00	2*H'+B
Hydraulic Radius (m)	R	0.375	0.375	A/P
Velocity (m <sup>3</sup> /s)	V	0.514	0.9	p/A
Hydraulic Gradient (%)	I	0.191	0.587	(n*V/R <sup>2/3</sup> ) <sup>2</sup>
Down stream WL (M)	Ho	+1.622	+1.690	
HEAD LOSS	Outflow (m)	0.013	0.041	1.0*(V <sup>2</sup> /2g)*(Nm+1)
	Friction (m)	0.008	0.025	I*L
	Inflow (m)	0.007	0.021	0.5*(V <sup>2</sup> /2g)*(Nm+1)
	Total (m)	h	0.028	0.087
Water Level (M)	H	+1.650	+1.777	Ho+h

Point [Grit Chamber] Outfall weir

Formula : Francis

Contents	Symbol	Case			
		QDM	QHM		
Flowrate (m <sup>3</sup> /d)	Q	200,000	350,000		
		(m <sup>3</sup> /s)	2.315	4.051	
Number of pipes (pipe)	n	4	4		
Flowrate/pipe (m <sup>3</sup> /s)	q	0.579	1.013		
Schematic Diagram					
Weir Width (m)	B	3.00			
Weir Height (M)	FH	+1.900	+5.200		
Lower Water Level (M)	Ho	+1.650	+1.777		
W D A E T P E T R H	Complete Overflow (m)	h	0.222	0.323	$(q/1.84*L)^{(2/3)}$
Water Level (M)	H	+2.122	+2.223	FH+h	



Point [Grit Chamber] Inflow Channel

Formula:Manning

Contents	Symbol	Case		
		QDM	QHM	
Flowrate (m <sup>3</sup> /d) (m <sup>3</sup> /s)	Q	200,000	350,000	
		2.315	4.051	
Number of pipes (pipe)	n	4	4	
Flowrate/pipe (m <sup>3</sup> /s)	q	0.579	1.013	
Schematic Diagram		Channel 1 series Width 1.0 m Depth 2.0 m		
Length (m)	L	4.50	n=0.014	
Invert Elevation (M)	FH	+0.700	+4.000	
Water Depth (m)	H'	1.422	1.523	Ho-FH
Cross Section (m <sup>2</sup> )	A	1.422	1.523	B*H'
Wetted Perimeter (m)	P	4.34	4.55	2*H'+B
Hydraulic Radius (m)	R	0.327	0.335	A/P
Velocity (m <sup>3</sup> /s)	V	0.407	0.665	p/A
Hydraulic Gradient (%)	I	0.144	0.373	(n*V/R <sup>2/3</sup> ) <sup>2</sup>
Down stream WL (M)	Ho	+2.122	+2.223	
HEAD LOSS	Outflow (m)	0.008	0.023	1.0*(V <sup>2</sup> /2g)*(Nm+1)
	Friction (m)	0.001	0.002	I*L
	Inflow (m)	0.004	0.011	0.5*(V <sup>2</sup> /2g)*(Nm+1)
	Total (m)	h	0.013	0.036
Pump Discharge Well Water Level (M)	H	+2.135	+2.259	Ho+h

Point [MBR Tank] Inflow Channel Inflow Weir

Formula : Francis

Contents	Symbol	Case			
		QDM	QHM		
Flowrate (m <sup>3</sup> /d) (m <sup>3</sup> /s)	Q	150,000		QDM= Q*(1+2)	
		1.736	0.000	Return Sludge 2Q	
Number of pipes (pipe)	n	5	2		
Flowrate/pipe (m <sup>3</sup> /s)	q	0.347	0.000		
Schematic Diagram					
Weir Width (m)	L	1.20			
Weir Height (M)	FH	+0.800	+4.100		
Lower Water Level (M)	Ho	+0.700	+0.700		
W D A E T P E T R H	Complete Overflow (m)	h	0.291	0.000	$(q/1.84*L)^{(2/3)}$
Water Level (M)	H	+1.091	+0.800	FH+h	
Base Level		+0.100			

Point [MBR Tank] Inflow Channel

Formula:Manning

Contents	Symbol	Case		
		QDM	QHM	
Flowrate (m <sup>3</sup> /d) (m <sup>3</sup> /s)	Q	75,000	0	QDM=Q*(1*2)/2
		0.868	0.000	
Number of pipes (pipe)	n	1	2	
Flowrate/pipe (m <sup>3</sup> /s)	q	0.868	0.000	
Schematic Diagram				
Channel				
Width (m)	B	2.000		
Base Level (M)	FH	+0.100	+3.400	
Length (m)	L	44.50	n=0.014	
Water Depth (m)	H'	0.991	0.700	Ho-FH
Cross Section (m <sup>2</sup> )	A	1.982	1.4	B*H'
Wetted Perimeter (m)	P	3.982	3.4	2*H'+B
Hydraulic Radius (m)	R	0.498	0.412	A/P
Velocity (m <sup>3</sup> /s)	V	0.438	0.000	p/A
Hydraulic Gradient (%)	I	0.095	0.000	(n*V/R <sup>2/3</sup> ) <sup>2</sup>
Lower point WL (M)	Ho	+1.091	+0.800	
HEAD LOSS	Refraction (90°) (m)	0.010	0.000	0.99*(V <sup>2</sup> /2g)*1
	Friction (m)	0.004	0.000	I*L
	Total (m)	h	0.014	0
Water Level (M)	H	+1.105	+0.800	Ho+h

Point [AerobicTank] Discharge Weir

Formula : Francis

Contents	Symbol	Case			
		QDM	QHM		
Flowrate (m <sup>3</sup> /d) (m <sup>3</sup> /s)	Q	150,000		QDM= Q*(1+2)	
		1.736	0.000		
Number of pipes (pipe)	n	5	5		
Flowrate/pipe (m <sup>3</sup> /s)	q	0.347	0.000		
Schematic Diagram					
Weir Width (m)	L	6.00			
Weir Height (M)	FH	+1.300			
Lower Water Level (M)	Ho	+1.105	+0.800		
W D A E T P E T R H	Complete Overflow (m)	h	0.100	0.000	$(q/1.84*L)^{(2/3)}$
Water Level (M)	H	+1.400	+1.300	FH+h	
Base Level		-0.400			

Point [Ultra Fine Screen]

Formula : Thomas Gump

Contents	Symbol	Case		
		QDM	QHM	
Flowrate (m <sup>3</sup> /d) (m <sup>3</sup> /s)	Q	50,000	0	
		0.579	0	
Number of pipes (pipe)	n	5	5	
Flowrate/pipe (m <sup>3</sup> /s)	q	0.116	0	
Schematic Diagram				
Lower Water Level (M)	Ho	+1.722	+1.500	
HEAD LOSS	Passing Loss (M)	0.200		Maker Hearing
Water Level (M)	H	+1.922	+1.500	FH+ho

Point [Upstream of Screen] Distribution Weir

Formula : Francis

Contents		Symbol	Case		
			QDM	QHM	
Flowrate	(m <sup>3</sup> /d)	Q	50,000		
	(m <sup>3</sup> /s)		0.579	0.000	
Number of pipes	(pipe)	n	5	5	
Flowrate/pipe	(m <sup>3</sup> /s)	q	0.116	0.000	
Schematic Diagram					
Weir Width	(m)	L	0.60		
Weir Height	(M)	FH	+2.000		
Lower Water Level		Ho	+0.000	+1.400	
W D A E T P E T R H	Complete Overflow	h	0.222	0.000	$(q/1.84*L)^{(2/3)}$
Water Level	(M)	H	+2.222	+2.000	FH+h
Base Level			+3.700		

## Appendix4.4 Capacity Calculation

1. Lift pumping Station	Final Phase Calculation	Phase 1 Calculation
1. Lift Pumping Station		
1.1 Inlet Pipe		
1) Pipe Condition		
Design Flow Rate		
Average Daily Flow Rate	= 200,000 m <sup>3</sup> /d = 2.315 m <sup>3</sup> /s	= 100,000 m <sup>3</sup> /d = 1.157 m <sup>3</sup> /s
Maximum Daily Flow Rate	= 264,000 m <sup>3</sup> /d = 3.056 m <sup>3</sup> /s	= 132,000 m <sup>3</sup> /d = 1.528 m <sup>3</sup> /s
Maximum Hourly Flow Rate	= 350,000 m <sup>3</sup> /d = 4.051 m <sup>3</sup> /s	= 175,000 m <sup>3</sup> /d = 2.025 m <sup>3</sup> /s
Pipe Diameter	= 2,000 mm	= 2,000 mm
Pipe Gradient	= 1.2 permillage	= 1.2 permillage
Invert Level	= -27.740 M	= -27.740 M
Manning's "n" Value	= 0.013	= 0.013
Full Flow Rate	= 5.274 m <sup>3</sup> /s	= 5.274 m <sup>3</sup> /s
Full Flow Velocity	= 1.679 m/s	= 1.679 m/s
Water Depth		
Average Daily Flow Rate	= 0.927 m	= 0.636 m
Maximum Daily Flow Rate	= 1.093 m	= 0.737 m
Maximum Hourly Flow Rate	= 1.314 m	= 0.860 m
Water Level		
Average Daily Flow Rate	= -27.740 + 0.927 = -26.813 M	= -27.740 + 0.636 = -27.104 M
Maximum Daily Flow Rate	= -27.740 + 1.093 = -26.647 M	= -27.740 + 0.737 = -27.003 M
Maximum Hourly Flow Rate	= -27.740 + 1.314 = -26.426 M	= -27.740 + 0.860 = -26.880 M
2) Inlet Chamber		
Invert Elevation	= -28.100 M	= -28.100 M
Water Depth at Upstream of Inlet Gate		
Average Daily Flow Rate	= 1.287 m	= 0.996 m
Maximum Hourly Flow Rate	= 1.674 m	= 1.220 m
1.2 Inlet Gate		
Invert Elevation	= -28.100 M	= -28.100 M
Channel Inlet Width	= 1.0 m    Gate Width → 1.4 m	= 1.0 m    Gate Width → 1.4 m
Channel Inlet Height	= 2.0 m    Gate Height → 3.1 m	= 2.0 m    Gate Height → 3.1 m
Number of Gates	= 4 nos.	= 4 nos.
Passing Velocity		
Average Daily Flow Rate	= 2.315 / ( 1.00 x 1.287 x 4 ) = 0.450 m/s	= 1.157 / ( 1.00 x 0.996 x 4 ) = 0.290 m/s
Maximum Hourly Flow Rate	= 4.051 / ( 1.00 x 1.674 x 4 ) = 0.605 m/s	= 2.025 / ( 1.00 x 1.220 x 4 ) = 0.415 m/s

Lift pumping Station	Final Phase Calculation	Phase 1 Calculation
Headloss at Inlet Gate		
Average Daily Flow Rate	= $1.5 \times 0.450^2 / 19.6 = 0.015$ m	= $1.5 \times 0.290^2 / 19.6 = 0.006$ m
Maximum Hourly Flow Rate	= $1.5 \times 0.605^2 / 19.6 = 0.028$ m	= $1.5 \times 0.415^2 / 19.6 = 0.013$ m
Water Level at Downstream of Inlet Gate		
Average Daily Flow Rate	= $-26.813 - 0.015 = -26.828$ M	= $-27.104 - 0.006 = -27.110$ M
Maximum Hourly Flow Rate	= $-26.426 - 0.028 = -26.454$ M	= $-26.880 - 0.013 = -26.893$ M
1.3 Screen		
1) Coarse Screen		
Opening	= 100 mm	= 100 mm
Type	= Manual Rake	= Manual Rake
Bottom Elevation	= -28.150 M	= -28.150 M
Channel Width	= 2.500 m	= 2.500 m
Number of Screens	= 4 nos.	= 2 nos.
Approach Water Depth		
Average Daily Flow Rate	= $-26.828 - -28.150 = 1.322$ m	= $-27.110 - -28.150 = 1.040$ m
Maximum Hourly Flow Rate	= $-26.454 - -28.150 = 1.696$ m	= $-26.893 - -28.150 = 1.257$ m
Approach Velocity		
Average Daily Flow Rate	= $2.315 / (2.50 \times 1.322 \times 4) = 0.175$ m/s	= $1.157 / (2.50 \times 1.040 \times 2) = 0.222$ m/s
Maximum Hourly Flow Rate	= $4.051 / (2.50 \times 1.696 \times 4) = 0.239$ m/s	= $2.025 / (2.50 \times 1.257 \times 2) = 0.322$ m/s
Headloss at Coarse Screen	= neglect	= neglect
2) Fine Screen		
Opening	= 15 mm	= 15 mm
Type	= Mechanical Rake	= Mechanical Rake
Bottom Elevation	= -28.250 M	= -28.250 M
Channel Width	= 2.500 m	= 2.500 m
Number of Screens	= 4 nos.	= 2 nos.
Approach Water Depth		
Average Daily Flow Rate	= $-26.828 - -28.250 = 1.422$ m	= $-27.110 - -28.250 = 1.140$ m
Maximum Hourly Flow Rate	= $-26.454 - -28.250 = 1.796$ m	= $-26.893 - -28.250 = 1.357$ m
Approach Velocity		
Average Daily Flow Rate	= $2.315 / (2.50 \times 1.422 \times 4) = 0.163$ m/s	= $1.157 / (2.50 \times 1.140 \times 2) = 0.203$ m/s
Maximum Hourly Flow Rate	= $4.051 / (2.50 \times 1.796 \times 4) = 0.226$ m/s	= $2.025 / (2.50 \times 1.357 \times 2) = 0.298$ m/s
Headloss at Fine Screen		
Average Daily Flow Rate	= $2.34 \times \sin 70 \times (9/15)^{(4/3)} \times 0.163 \times 2^2 / 19.6 = 0.005$	= $2.34 \times \sin 70 \times (9/15)^{(4/3)} \times 0.203 \times 2^2 / 19.6 = 0.008$
Maximum Hourly Flow Rate	= $2.34 \times \sin 70 \times (9/15)^{(4/3)} \times 0.226 \times 2^2 / 19.6 = 0.010$	= $2.34 \times \sin 70 \times (9/15)^{(4/3)} \times 0.298 \times 2^2 / 19.6 = 0.017$
Water Level at Downstream of Fine Screen		
Average Daily Flow Rate	= $-26.828 - 0.005 = -26.833$ M	= $-27.110 - 0.008 = -27.118$ M
Maximum Hourly Flow Rate	= $-26.454 - 0.010 = -26.464$ M	= $-26.893 - 0.017 = -26.910$ M



Lift pumping Station	Final Phase Calculation	Phase 1 Calculation
1.4 Lift Pump		
Type	Vertical Shaft Volute Type Mixed Flow Pump	
Design Flow Rate		
Average Daily Flow Rate	= 200,000 m <sup>3</sup> /d = 139 m <sup>3</sup> /min	= 100,000 m <sup>3</sup> /d = 69 m <sup>3</sup> /min
Maximum Daily Flow Rate	= 264,000 m <sup>3</sup> /d = 183 m <sup>3</sup> /min	= 132,000 m <sup>3</sup> /d = 92 m <sup>3</sup> /min
Maximum Hourly Flow Rate	= 350,000 m <sup>3</sup> /d = 243 m <sup>3</sup> /min	= 175,000 m <sup>3</sup> /d = 122 m <sup>3</sup> /min
Pump Capacity		
Number of Pumps	= 4 nos	= 2 nos
Pump Capacity	= 243.0 / 4 = 61 m <sup>3</sup> /min	= 122.0 / 2 = 61 m <sup>3</sup> /min
Pump Diameter	= 146 × ( 61.0 / 3 ) <sup>0.5</sup> = 658 = 650 mm	= 146 × ( 61.0 / 3 ) <sup>0.5</sup> = 658 = 650 mm
Pump Head		
Discharge Water Level	= 2.300 M	= 2.300 M
Suction Water Level	= -29.000 M	= -29.000 M
Actual Pump Head	= 2.300 - -29.000 = 31.300 m	= 2.300 - -29.000 = 31.300 m
Others Headloss	= 2.000 m ( assumed)	= 2.000 m ( assumed)
Total Pump Head	= 31.300 + 2.000 = 33.300 m	= 31.300 + 2.000 = 33.300 m
Motor Output	$P = \frac{\rho \times g \times Q \times H}{60 \times 1000 \times \eta} \times ( 1 + \alpha )$ <p> <math>\rho</math> : Water Density 1,000 kg/m<sup>3</sup>  <math>g</math> : Acceleration of Gravity 9.8 m/sec<sup>2</sup>  <math>Q</math> : Flow Rate 61 m<sup>3</sup>/min  <math>H</math> : Pump Head 33.30 m  <math>\eta</math> : Pump Efficiency 0.8  <math>\alpha</math> : Surplus ratio 0.15 </p> $= \frac{1,000 \times 9.8 \times 61.0 \times 33.3}{60 \times 1,000 \times 0.8} \times ( 1 + 0.15 )$ $= 476.9 \rightarrow 480 \text{ kW}$	= Same as the left
Lift Pump Specification	Type Vertical Shaft Volute Type Mixed Flow Pump Diameter 650 mm Capacity 61 m <sup>3</sup> /min Pump Head 33.30 m Motor Output 480 kW Numbers 5 nos. ( Including 1 standby)	Type Vertical Shaft Volute Type Mixed Flow Pump Diameter 650 mm Capacity 61 m <sup>3</sup> /min Pump Head 33.30 m Motor Output 480 kW Numbers 3 nos. ( Including 1 standby)

Grit Chamber	Final Phase Calculation	Phase 1 Calculation
2. Grit Chamber		
2.1 Chamber		
Type	Aerated Grit Chamber	Aerated Grit Chamber
Design Flow Rate		
Average Daily Flow Rate	= 264,000 m <sup>3</sup> /d	= 132,000 m <sup>3</sup> /d
Maximum Hourly Flow Rate	= 350,000 m <sup>3</sup> /d	= 175,000 m <sup>3</sup> /d
Detention Time (For Maximum Hourly Flow Rate)	= 3 min	= 3 min
Required Volume	= 350,000 ÷ 1,440 × 3 = 730 m <sup>3</sup>	= 175,000 ÷ 1,440 × 3 = 365 m <sup>3</sup>
No. of Channel	= 4 channels	= 2 channels
Required Chamber Volume per each Basin	= 730 ÷ 4 = 183 m <sup>3</sup>	= 365 ÷ 2 = 183 m <sup>3</sup>
Depth	= 3.0 m	= 3.0 m
Width	= 4.0 m	= 4.0 m
Length	= 15.5 m	= 15.5 m
Actual Volume	= 4.0 mW × 3.0 mH × 15.5 mL = 186 m <sup>3</sup>	= 4.0 mW × 3.0 mH × 15.5 mL = 186 m <sup>3</sup>
2.2 Required Air		
Total Air Supply Required	= 15.5 m × 0.3 m <sup>3</sup> /min/m = 4.7 m <sup>3</sup> /min = 4.7 × 4 = 18.8 m <sup>3</sup> /min	= 15.5 m × 0.3 m <sup>3</sup> /min/m = 4.7 m <sup>3</sup> /min = 4.7 × 2 = 9.4 m <sup>3</sup> /min
Aeration Blower		
Number of Blowers	= 2 nos.	= 1 nos.
Blower Capacity	= 11 m <sup>3</sup> /min	= 11 m <sup>3</sup> /min
Discharge Pressure		
Diffuser Depth	= 3,000 mmAq	= 3,000 mmAq
Loss of Diffuser	= 750 mmAq	= 750 mmAq
Other Loss	= 500 mmAq	= 500 mmAq
Total Pressure	= 4,250 mmAq = 42 kpa	= 4,250 mmAq = 42 kpa
Blower Specification		
Type	= Turbo type blower	= Turbo type blower
Diameter	= 150 mm	= 150 mm
Capacity	= 11 m <sup>3</sup> /min	= 11 m <sup>3</sup> m <sup>3</sup> /min
Discharge Pressure	= 42 kpa	= 42 kpa
Motor Output	= 22 kW	= 22 kW
Number of Blowers	= 3 nos. (Including 1 standby)	= 2 nos. (Including 1 standby)

Grit Chamber	Final Phase Calculation	Phase 1 Calculation
2.3 Quantity of Grit at Peak Flow	Assume a value of 0.05m <sup>3</sup> /1000m <sup>3</sup> at peak flow = $350,000 \times 0.05 \div 1,000 = 17.5 \text{ m}^3/\text{d}$	Assume a value of 0.05m <sup>3</sup> /1000m <sup>3</sup> at peak flow = $175,000 \times 0.05 \div 1,000 = 8.8 \text{ m}^3/\text{d}$
Grit Collector	Screw Type Collector	Screw Type Collector
Type		
Number of Collectors	= 4 nos.	= 2 nos.
Required Capacity	= $17.5 \div 4 \div 24 = 0.20 \text{ m}^3/\text{hr}$	= $8.8 \div 2 \div 24 = 0.20 \text{ m}^3/\text{hr}$
Diameter of Screw	= 300 mm	= 300 mm
Diameter of Shaft	= 100 mm	= 100 mm

Equalization Tank	Final Phase Calculation	Phase 1 Calculation
3. Equalization Tank		
3.1 Equalization Tank Volume		
Retention Time	= 4 hour	= 4 hour
Required Volume	= $200,000 / 24 \times 4 = 33,333 \text{ m}^3$	= $100,000 / 24 \times 4 = 16,667 \text{ m}^3$
Number of Channels per Tank	= 4 channels/tank	= 4 channels/tank
Number of Tanks	= 8 tanks	= 4 tanks
Tank Volume (each)	= $33,333 / 8 = 4,167 \text{ m}^3$	= $16,667 / 4 = 4,167 \text{ m}^3$
Surface Loading	= $50 \text{ m}^3/\text{m}^2/\text{d}$	= $50 \text{ m}^3/\text{m}^2/\text{d}$
Required Surface Area	= $200,000 / 50 = 4,000 \text{ m}^2$	= $100,000 / 50 = 2,000 \text{ m}^2$
Tank Depth	= $33,333 / 4,000 = 8.30 \text{ m}$	= $16,667 / 2,000 = 8.30 \text{ m}$
Tank Size		
Width	= 19.0 m	= 19.0 m
Length	= 26.0 m	= 26.0 m
Depth	= 8.5 m	= 8.5 m
Actual Total Surface	= $19.0 \times 26.0 \times 8 = 3,952 \text{ m}^2$	= $19.0 \times 26.0 \times 4 = 1,976 \text{ m}^2$
Actual Total Volume	= $3,952 \times 8.5 = 33,592 \text{ m}^3$	= $1,976 \times 8.5 = 16,796 \text{ m}^3$
3.2 Constant Rate Pump	Install 6 Pumps per 2 tanks (Including 1 standby)	Install 6 Pumps per 2 tanks (Including 1 standby)
Pump Capacity	= $200,000 / 20 / 1,440 = 7.0 \text{ m}^3/\text{min}$	= $100,000 / 10 / 1,440 = 7.0 \text{ m}^3/\text{min}$
Pump Diameter	= $146 \times \sqrt{(7.0 / 2.5)} = 244 \text{ mm}$ = 250 mm	= $146 \times \sqrt{(7.0 / 3)} = 223 \text{ mm}$ = 250 mm
Pump Type	Nonclogging Pump	
Pump Head	Actual Pump Head = 10 m Piping Headloss = 4 m Total Pump Head = 14 m	
Motor Output	$P = \frac{\rho \times g \times Q \times H}{60 \times 1000 \times \eta} (1 + \alpha)$ $= \frac{1,000 \times 9.8 \times 7.0 \times 14}{60.0 \times 1,000 \times 0.6} \times (1 + 0.2)$ $= 32.0 \rightarrow 37 \text{ kW}$	

Equalization Tank	Final Phase Calculation	Phase 1 Calculation
<p>Pump Specification</p> <p>Type</p> <p>Diameter</p> <p>Capacity</p> <p>Head</p> <p>Motor Output</p> <p>Numbers</p>	<p>= Nonclogging Pump</p> <p>= 250 mm</p> <p>= 7.0 m<sup>3</sup>/min</p> <p>= 14 m</p> <p>= 37 kW</p> <p>= 24 nos. (Including 4 standby)</p>	<p>= Nonclogging Pump</p> <p>= 250 mm</p> <p>= 7.0 m<sup>3</sup>/min</p> <p>= 14 m</p> <p>= 37 kW</p> <p>= 12 nos. (Including 2 standby)</p>
<p>3.3 Mixer for Antisetling</p> <p>Type</p> <p>Propeller Diameter</p> <p>Motor Output</p> <p>Numbers</p>	<p>= Submersible propeller Mixer</p> <p>= 500 mm</p> <p>= 5.5 kW</p> <p>= 2 nos./channel × 4 × 8 = 64 nos.</p>	<p>= Submersible propeller Mixer</p> <p>= 500 mm</p> <p>= 5.5 kW</p> <p>= 2 nos./channel × 4 × 4 = 32 nos.</p>

Disinfection Facility	Final Phase Calculation	Phase 1 Calculation
4. Disinfection Facility		
4.1 Disinfection Tank		
Disinfection Tank Volume		
Design Flow (maximum)	= 150,000 m <sup>3</sup> /d	= 75,000 m <sup>3</sup> /d
Retention Time	= 5 min	= 5 min
Required Tank Volume	= 150,000 / 1,440 × 5 = 521 m <sup>3</sup>	= 75,000 / 1,440 × 5 = 260 m <sup>3</sup>
Tank Size		
Width	= 1.20 m	= 1.20 m
Length	= 80.0 m	= 80.0 m
Depth	= 1.50 m	= 1.50 m
Numbers	= 4 tanks	= 2 tanks
Actual Tank Volume	= 576 m <sup>3</sup>	= 288 m <sup>3</sup>
4.2 Disinfection Chemicals	= Sodium hypochlorite	
Effective Chlorine Density (β)	= 10 %	
Specific Gravity	= 1.1 at 10% density	
Dosing Ratio (α)	= 10 mg/L	
Dosage Capacity		
Maximum Consumption q	= $Q \times \alpha \times 10^{-6} \times (100 / \beta) \times (1 / \gamma)$ = 150,000 × 0.00001 × (100 / 10) × (1 / 1.1) = 13.64 m <sup>3</sup> /d = 9.5 L/min	= $Q \times \alpha \times 10^{-6} \times (100 / \beta) \times (1 / \gamma)$ = 75,000 × 0.00001 × (100 / 10) × (1 / 1.1) = 6.82 m <sup>3</sup> /d = 4.7 L/min
Storage Tank	2 days storage. 1 tank/ train	
Required Tank Capacity	= 13.64 × 2 / 4 = 6.8 → 10 m <sup>3</sup>	= 6.82 × 2 / 2 = 6.8 → 10 m <sup>3</sup>
Number of Pumps	1 pump and 1 stanby for 1 train	1 pump and 1 stanby for 1 train
Required Pump Capacity	= 9.5 / 4 = 2.38 L/min	= 4.7 / 2 = 2.35 L/min

Aeration Tank and MBR Tank	Final Phase Calculation	Phase 1 Calculation
<b>5. Aeration Tank &amp; Membrane Bio-Reactor Facility</b>		
<b>5.1 Aeration Tank Volume</b>		
<b>1) BOD Removal in Aeration Tank</b>		
Design Flow Rate	= 200,000 m <sup>3</sup> /d	= 100,000 m <sup>3</sup> /d
Influent BOD Concentration	= 120 mg/L	= 120 mg/L
Influent SS Concentration	= 120 mg/L	= 120 mg/L
BOD Load	= 200,000 × 120 / 1,000 = 24,000 kg/d	= 100,000 × 120 / 1,000 = 12,000 kg/d
BOD Removal Rate	= 0.14 kg-BOD/kg-SS/d (25 degrees C)	= 0.14 kg-BOD/kg-SS/d (25 degrees C)
MLSS in MBR Tank	= 9,000 mg/L	= 9,000 mg/L
BOD Removal Rate per Unit Volume	= 0.14 × 9,000 / 1,000 = 1.26 kg-BOD/m <sup>3</sup>	= 0.14 × 9,000 / 1,000 = 1.26 kg-BOD/m <sup>3</sup>
Required Aeration Tank Volume for BOD	= 24,000 / 1.26 = 19,048 m <sup>3</sup>	= 12,000 / 1.26 = 9,524 m <sup>3</sup>
<b>2) Nitrification in Aeration Tank</b>		
Design Flow Rate	= 200,000 m <sup>3</sup> /d	= 100,000 m <sup>3</sup> /d
Influent BOD Concentration	= 120 mg/L	= 120 mg/L
Influent SS Concentration	= 120 mg/L	= 120 mg/L
Influent T-N Concentration	= 40 mg/L	= 40 mg/L
MLSS in Aeration Tank	= 9,000 mg/L	= 9,000 mg/L
BOD Load	= 200,000 × 120 / 1,000 = 24,000 kg/d	= 100,000 × 120 / 1,000 = 12,000 kg/d
T-N Load	= 200,000 × 40 / 1,000 = 8,000 kg/d	= 100,000 × 40 / 1,000 = 4,000 kg/d
Excess Sludge Production Rate	= 100 %	= 100 %
Nitrogen Concentration in Sludge	= 6 %	= 6 %
Nitrogen in Excess Sludge	= 200,000 × 120 × 0.06 / 1,000 = 1,440 kg/d	= 100,000 × 120 × 0.06 / 1,000 = 720 kg/d
T-N Load for Nitrification	= 8,000 - 1,440 = 6,560 kg/d	= 4,000 - 720 = 3,280 kg/d
Nitrification Rate	= 0.037 kg-N/kg-SS/d (25 degrees C)	= 0.037 kg-N/kg-SS/d (25 degrees C)
MLSS in MBR Tank	= 9,000 mg/L	= 9,000 mg/L
Nitrification Rate per Unit Volume	= 0.037 × 9,000 / 1,000 = 0.33 kg-N/m <sup>3</sup>	= 0.037 × 9,000 / 1,000 = 0.33 kg-N/m <sup>3</sup>
Nitrification in MBR Tank	= 19,200 × 0.33 = 6,394 kg-N/d -OK-	= 7,550 × 0.33 = 2,514 kg-N/d
<b>Channel Size of Aeration Tank</b>		
Length	= 32.0 m	= 32.0 m
Width	= 6.0 m	= 6.0 m
Depth	= 5.0 m	= 5.0 m
Number of Channels	= 20 nos.	= 10 nos
Volume of each Channel	= 960 m <sup>3</sup>	= 960 m <sup>3</sup>
Total Volume of Aeration Tank	= 960 × 20 = 19,200 m <sup>3</sup> > 19,048 m <sup>3</sup> <b>O.K.</b>	= 960 × 10 = 9,600 m <sup>3</sup> > 9,524 m <sup>3</sup> <b>O.K.</b>

Aeration Tank and MBR Tank	Final Phase Calculation	Phase 1 Calculation
5.2 Required Air Volume for Aeration Tank		
1) Required Oxygen for BOD Removal		
Design Flow Rate	= 200,000 m <sup>3</sup> /d	= 100,000 mg/L
Influent BOD Concentration	= 120 mg/L	= 120 mg/L
BOD Load	= 24,000 kg-BOD/d	= 12,000 kg-BOD/d
Required Unit Oxygen for BOD Removal	= 0.5 kg-O <sub>2</sub> /kg-BOD	= 0.5 kg-O <sub>2</sub> /kg-BOD
Required Oxygen for BOD Removal	= 24,000 × 0.5 = 12,000 kg-O <sub>2</sub> /d	= 12,000 × 0.5 = 6,000 kg-O <sub>2</sub> /d
2) Required Oxygen for Nitrification		
T-N Load for Nitrification	= 6,560 kg-N/d	= 3,280 kg-N/d
Required Unit Oxygen for Nitrification	= 64/14 kg-O <sub>2</sub> /kg-N	= 64/14 kg-O <sub>2</sub> /kg-N
Required Oxygen for Nitrification	= 6,560 × 64/14 = 29,989 kg-O <sub>2</sub> /d	= 3,280 × 64/14 = 14,994 kg-O <sub>2</sub> /d
3) Required Oxygen for Endogenous Respiration		
Aeration Tank Volume	= 19,200 m <sup>3</sup>	= 9,600 m <sup>3</sup>
MLSS in Tank	= 9,000 mg/L	= 9,000 mg/L
MLVSS/MLSS	= 0.75	= 0.75
Quantity of MLVSS	= 9,000 × 19,200 × 0.75 / 1,000	= 9,000 × 9,600 × 0.75 / 1,000
Required Unit Oxygen	= 0.12 kg-O <sub>2</sub> /kg-VSS	= 0.12 kg-O <sub>2</sub> /kg-VSS
for Endogenous Respiration		
Required Oxygen	= 129,600 × 0.12 = 15,552 kg-O <sub>2</sub> /d	= 64,800 × 0.12 = 7,776 kg-O <sub>2</sub> /d
for Endogenous Respiration		
4) Total Required Oxygen	= 12,000 + 29,989 + 15,552 = 57,541 kg-O <sub>2</sub> /d	= 6,000 + 14,994 + 7,776 = 28,770 kg-O <sub>2</sub> /d
for Biological Treatment(AOR)		



Aeration Tank and MBR Tank	Final Phase Calculation	Phase 1 Calculation
<p>5) Standard Oxygen Requirement (SOR)</p>	$= \frac{AOR \times C_{sw} \times r \times 760}{1.024^{(T-20)} \times \alpha \times (\beta \cdot C_s \cdot r - CA) \times P}$ <p> <math>C_{sw}</math> ; Oxygen saturation concentration in clean water at 20                      = 8.84 mg/L  <math>Ca</math> ; Average DO                      = 1.5 mg/L  <math>Cs</math> ; Oxygen saturation concentration in clean water at 25                      = 8.39 mg/l  <math>T</math> ; water temperature = 25 degees C  <math>r</math> ; Coefficient of water depth  <math>r = 1 + \frac{(H/2)}{10.332} = 1.23</math>  <math>H</math> ; Average depth of air diffuser = 4.80 m  <math>\alpha</math> ; 0.93  <math>\beta</math> ; 0.97  <math>P</math> ; 760                 </p>	
<p>6) Required Air Volume (Gs)</p>	<p>SOR = 70,189 kg as O<sub>2</sub>/d</p> $Gs = \frac{SOR}{E_A \times \rho \times O_w} \times \frac{273 + T}{273}$ <p> <math>E_A</math> ; Oxygen transfer efficiency ( 28 %)                       <math>\rho</math> ; Air density ( 1.293 kg/m<sup>3</sup>N-Air)                       <math>O_w</math> ; Oxygen content in air ( 0.232 kg-O<sub>2</sub>/m<sup>3</sup>N-Air)                       <math>T</math> ; Water temperature = 25 degees C                 </p> $Gs = \frac{70,189}{28 \times 1.293 \times 0.232} \times 100 \times \frac{273 + 25}{273}$ $= \frac{912,175 \text{ Nm}^3/\text{d}}{633 \text{ Nm}^3/\text{min}}$ $= 32 \text{ Nm}^3/\text{min/channel}$	<p>= 35,095 kg as O<sub>2</sub>/d</p> $Gs = \frac{35,095}{28 \times 1.293 \times 0.232} \times 100 \times \frac{273 + 25}{273}$ $= \frac{456,094 \text{ Nm}^3/\text{d}}{317 \text{ Nm}^3/\text{min}}$ $= 32 \text{ Nm}^3/\text{min/channel}$

Aeration Tank and MBR Tank	Final Phase Calculation	Phase 1 Calculation
5.3 Aeration Blowers for Aeration Tank Required Air Volume per Channel	consider about 10% allowance = 32 × 1.1 = 35 Nm <sup>3</sup> /min/channel	= 32 × 1.1 = 35 Nm <sup>3</sup> /min/ channel
Number of Actual Working Blowers per each Train	N = 2 nos. / train	= 2 nos. / train
Blower Capacity	G = 35 × 5 / 2 = 87.5 m <sup>3</sup> /min → 90 m <sup>3</sup> /min	= 35 × 5 / 2 = 87.5 m <sup>3</sup> /min → 90 m <sup>3</sup> /min
Discharge Pressure		
Diffuser Depth	= 4,800 mmAq	= 4,800 mmAq
Loss of Diffuser	= 1,100 mmAq	= 1,100 mmAq
Other Loss	= 1,000 mmAq	= 1,000 mmAq
Total Pressure	= 6,900 mmAq = 68 kpa	= 6,900 mmAq = 68 kpa
Blower Specification		
Type	Turbo Type Blower	Turbo Type Blower
Capacity	= 90 m <sup>3</sup> /min	= 90 m <sup>3</sup> /min
Discharge Pressure	= 68 kpa	= 68 kpa
Motor Output	= 150 kW	= 150 kW
Outlet Diameter	= 300 mm	= 300 mm
Number of Blowers	= 12 nos. ( Including 4 standby)	= 6 nos. ( Including 2 standby)

Aeration Tank and MBR Tank	Final Phase Calculation	Phase 1 Calculation
<p>5.4 Air Diffuser for Aeration Tank</p> <p>Type</p> <p>Air Flow Rate</p> <p>Oxygen Transfer Efficiency</p> <p>Total Oxygen Requirement</p> <p style="padding-left: 20px;">Oxygen Requirement per Channel</p> <p>Total Air Requirement</p> <p>Channel Size of Aeration Tank</p> <p style="padding-left: 20px;">Length</p> <p style="padding-left: 20px;">Width</p> <p style="padding-left: 20px;">Depth</p> <p style="padding-left: 20px;">Number of Channels</p> <p>Decision of Diffuser Number</p> <p style="padding-left: 100px;">N</p>  <p style="padding-left: 100px;">Per Channel</p>	<p>Fine Bubble Disk Membrane Type</p> <p>= 120~150 L/min</p> <p>= 20 %</p> <p>= 70,189 kg as O<sub>2</sub>/d (SOR)</p> <p>= 70,189 / 20 = 3,510 kg as O<sub>2</sub>/d•tank</p> <p>= 633 Nm<sup>3</sup>/min</p> <p>= 32.0 m</p> <p>= 6.0 m</p> <p>= 5.0 m</p> <p>= 20 nos.</p> <p>= <math>\frac{Gs}{\text{Air Flowrate per piece}} \times \frac{1}{OR} \times 1,000</math></p> <p>= <math>\frac{633}{140} \times \frac{1}{0.5} \times 1,000</math></p> <p>= 9,049 nos.</p> <p>= 452 nos./channel</p>	<p>Fine Bubble Disk Membrane Type</p> <p>= 120~150 L/min</p> <p>= 20 %</p> <p>= 35,095 kg as O<sub>2</sub>/d (SOR)</p> <p>= 35,095 / 10 = 3,510 kg as O<sub>2</sub>/d•tank</p> <p>= 317 Nm<sup>3</sup>/min</p> <p>= 32.0 m</p> <p>= 6.0 m</p> <p>= 5.0 m</p> <p>= 10 nos.</p> <p>= <math>\frac{Gs}{\text{Air Flowrate per piece}} \times \frac{1}{OR} \times 1,000</math></p> <p>= <math>\frac{317}{140} \times \frac{1}{0.5} \times 1,000</math></p> <p>= 4,525 nos.</p> <p>= 452 nos./channel</p>

Aeration Tank and MBR Tank	Final Phase Calculation	Phase 1 Calculation
<b>5.5 Membrane Bioreactor Tank(MBR Tank) Volume</b>		
Design Flow Rate	= 200,000 m <sup>3</sup> /d	= 100,000 m <sup>3</sup> /d
Design Flux	= 0.42 m <sup>3</sup> /m <sup>2</sup> /d	= 0.42 m <sup>3</sup> /m <sup>2</sup> /d
Required Area of Membrane	= 200,000 / 0.42 = 476,190 m <sup>2</sup>	= 100,000 / 0.42 = 238,095 m <sup>2</sup>
Membrane Area per Skid	= 1,200 m <sup>2</sup> /skid	= 1,200 m <sup>2</sup> /skid
Required Number of Membrane Skids	= 476,190 / 1,200 = 397 → 400 nos.	= 238,095 / 1,200 = 199 → 200 nos.
Number of Channels	= 20 channels	= 10 channels
Number of Membrane Skids per Channel	= 400 / 20 = 20 skids	= 200 / 10 = 20 skids
<b>Determined Size of Membrane Skid</b>		
Length	= 2,290 mm	= 2,290 mm
Width	= 1,687 mm	= 1,687 mm
Depth	= 2,852 mm	= 2,852 mm
<b>Determined Channel Size of Membrane Tank</b>		
Length	= 22.2 m (2.20m x 10skids = 22.2m)	= 22.2 m (2.20m x 10skids = 22.2m)
Width	= 6.8 m (3.40m x 2Lines = 6.80m)	= 6.8 m (3.40m x 2Lines = 6.80m)
Depth	= 5.0 m	= 5.0 m
Number of Channels	= 20 nos.	= 10 nos.
Volume of each Channel	= 755 m <sup>3</sup>	= 755 m <sup>3</sup>
Total Volume of Membrane Tank	= 755 × 20 = 15,100 m <sup>3</sup>	= 755 × 10 = 7,550 m <sup>3</sup>
MLSS in Membrane Tank	= 9,000 mg/L	= 9,000 mg/L

Aeration Tank and MBR Tank	Final Phase Calculation	Phase 1 Calculation
<b>5.6 Required Air Volume for Membrane Scrubbing</b>		
Air Volume per Membrane Module	= 0.36 Nm <sup>3</sup> /min/module	= 0.36 Nm <sup>3</sup> /min/module
Number of Modules per Skid	= 20 module/ skid	= 20 module/ skid
Air Volume per Membrane Skid	= 7.2 Nm <sup>3</sup> /min/skid	= 7.2 Nm <sup>3</sup> /min/module
Number of Skids per Channel	= 20 skids/channel	= 20 skids/channel
Number of Channels	= 20 nos.	= 10 nos.
Total Number of Skids	= 400 skids	= 200 skids
Total Required Air Volume for Membrane	= 7.2 × 400 = <b>2,880 Nm<sup>3</sup>/min</b>	= 7.2 × 200 = <b>1,440 Nm<sup>3</sup>/min</b>
Required Air Volume per Channel	= 144 Nm <sup>3</sup> /min/channel	= 144 Nm <sup>3</sup> /min/channel
<b>5.7 Aeration Blowers for MBR</b>		
Required Air Volume per Channel	consider about 10% allowance = 144 × 1.1 = 158 Nm <sup>3</sup> /min/channel	= 144 × 1.1 = 158 Nm <sup>3</sup> /min/channel
Number of Actual Working Blowers	N = 5 nos. / train	= 5 nos. / train
Blower Capacity	G = 158 × 5 / 5 = 158 m <sup>3</sup> /min → 160 m <sup>3</sup> /min	= 158 × 5 / 5 = 158 m <sup>3</sup> /min → 160 m <sup>3</sup> /min
<b>Discharge Pressure</b>		
Diffuser Depth	= 4,800 mmAq	= 4,800 mmAq
Loss of Diffuser	= 750 mmAq	= 750 mmAq
Other Loss	= 1,000 mmAq	= 1,000 mmAq
Total Pressure	= 6,550 mmAq = 64 kpa	= 6,550 mmAq = 64 kpa
<b>Blower Specification</b>		
Type	= Turbo Type Blower	= Turbo Type Blower
Capacity	= 160 m <sup>3</sup> /min	= 160 m <sup>3</sup> /min
Discharge Pressure	= 64 kpa	= 64 kpa
Motor Output	= 188 kW	= 188 kW
Outlet Diameter	= 400 mm	= 400 mm
Number of Blowers	= 24 nos. ( Including 4 standby)	= 12 nos. ( Including 2 standby)

Aeration Tank and MBR Tank	Final Phase Calculation	Phase 1 Calculation
5.8 Circulation Pump		
Circulation sludge rate	= 200 %	= 200 %
Circulation sludge volume	= 400,000 m <sup>3</sup> /day = 280 m <sup>3</sup> /min	= 200,000 m <sup>3</sup> /day = 140 m <sup>3</sup> /min
Number of Actual Working Pumps	= 20 units / 4 trains	= 10 units / 2 trains
Pump Capacity	= 14.0 m <sup>3</sup> /min	= 14.0 m <sup>3</sup> /min
Pump Diameter	= $146 \times \sqrt{(14.0 / 3)} = 315$ mm	= $146 \times \sqrt{(14.0 / 3)} = 315$ mm
Pump Head	Actual Pump Head = 10 m Piping Headloss = 4 m Total Pump Head = 14 m	
Motor Output	$P = \frac{\rho \times g \times Q \times H}{60 \times 1000 \times \eta} (1 + \alpha)$ $= \frac{1,000 \times 9.8 \times \text{###} \times 14}{60.0 \times 1,000 \times 0.6} \times (1 + 0.2)$ $= 64.0 \text{ kW}$	
Pump Specification		
Type	= Submergible axial pump	= Submergible axial pump
Diameter	= 315 mm	= 315 mm
Capacity	= 14 m <sup>3</sup> /min	= 14 m <sup>3</sup> /min
Discharge Pressure	= 14 m	= 14 m
Motor Output	= 64.0 kW	= 64.0 kW
Number of Pumps	= 28 nos. (Including 8 standby)	= 14 nos. (Including 4 standby)
5.9 Excess Sludge Pump		
Drawing Sludge Volume	= 2,000 m <sup>3</sup> /d = 1.4 m <sup>3</sup> /min	= 1,000 m <sup>3</sup> /d = 0.7 m <sup>3</sup> /min
Number of Actual Working Pumps	= 4 units / 4 trains	= 2 units / 2 trains
Pump Capacity	= 0.4 m <sup>3</sup> /min	= 0.4 m <sup>3</sup> /min
Pump Diameter	= $146 \times \sqrt{(0.4 / 3)} = 50$ mm	= $146 \times \sqrt{(0.4 / 3)} = 50$ mm
Pump Head	Actual Pump Head = 10 m Piping Headloss = 4 m Total Pump Head = 14 m	
Motor Output	$P = \frac{\rho \times g \times Q \times H}{60 \times 1000 \times \eta} (1 + \alpha)$ $= \frac{1,000 \times 9.8 \times 0.4 \times 14}{60.0 \times 1,000 \times 0.6} \times (1 + 0.2)$ $= 1.6 \text{ kW}$	

Aeration Tank and MBR Tank	Final Phase Calculation	Phase 1 Calculation
Type	= Non-clog Type Sludge Pump	= Non-clog Type Sludge Pump
Diameter	= 50 mm	= 50 mm
Capacity	= 0.4 m <sup>3</sup> /min	= 0.4 m <sup>3</sup> /min
Discharge Pressure	= 14 m	= 14 m
Motor Output	= 1.6 kW	= 1.6 kW
Number of Pumps	= 8 nos. (Including 4 standby)	= 4 nos. (Including 2 standby)

Dewatering Facility	Final Phase Calculation	Phase 1 Calculation
6. Dewatering Facility		
6.1 Design Condition		
Input Sludge Solids Quantity	= 18.0 t/d	= 9.0 t/d
Input Sludge Solids Concentration	= 0.9 %	= 0.9 %
Input Sludge Volume	= 2,004 m <sup>3</sup> /d	= 1,002 m <sup>3</sup> /d
Operation Time	= 23 hr/d	= 23 hr/d
Dehydrater Type	= Pressing Rotary Outer Cylinder-type Screw Press	= Pressing Rotary Outer Cylinder-type Screw Press
Screen Diameter	= 800 mm	= 800 mm
Filtration Rate	= 320 kg-DS/hr	= 320 kg-DS/hr
6.2 Required Number of Dehydraters	= 18.0352 / 0.32 / 23 = 2.5 = 3 nos.	= 9.01758 / 0.32 / 23 = 1.2 = 2 nos.
6.3 Dehydrater Specifications		
Type	= Pressing Rotary Outer Cylinder-type Screw Press	= Pressing Rotary Outer Cylinder-type Screw Press
Screen Diameter	= 800 mm	= 800 mm
Input Sludge Concentration	= 0.9 %	= 0.9 %
Filtration Rate	= 320 kg-DS/hr	= 320 kg-DS/hr
Operation Time	= 23 hr/d	= 23 hr/d
Dosage Type	= Organic Polymer (Cation)	= Organic Polymer (Cation)
Dosage Rate	= 1.7 %	= 1.7 %
Total Motor Power	= 2.2 kW/unit	= 2.2 kW/unit
Numbers of Dehydrator	= 5 nos. (Including 2 standby)	= 3 nos. (Including 1 standby)
6.4 Sludge Storage Tank		
Excess Sludge Volume	= 2,004 m <sup>3</sup> /d	= 1,002 m <sup>3</sup> /d
Retention Time	= 7.5 hr	= 7.5 hr
Required Tank Volume	= 626 m <sup>3</sup>	= 313 m <sup>3</sup>
Storage Tank Size		
Width	= 8 m	= 8 m
Length	= 8 m	= 8 m
Depth	= 5 m	= 5 m
Number	= 2 nos	= 1 nos
Total Volume	= 640 m <sup>3</sup>	= 320 m <sup>3</sup>




Dewatering Facility	Final Phase Calculation	Phase 1 Calculation
6.5 Sludge Feed Pump	1 pump should be installed in each hydrator.	
Required Pump Capacity (Q)	$= (D \times 100) / (C_0 \times 10^3) \times k$ <p>Where, D: Dehydrate Capacity (kg-DS/hour) = 320 kg-DS/hr  C<sub>0</sub>: Solid Concentration = 0.9 %  k: Coefficient = 0.5-1.0</p>	
Q	$= 320 \times 100 / 0.9 / 1000 \times 0.5-1.0$ $= 17.8 - 53.3 \text{ m}^3/\text{hr}$ $= 0.30 - 0.89 \text{ m}^3/\text{min}$	$= 320 \times 100 / 0.9 / 1000 \times 0.5-1.0$ $= 17.8 - 53.3 \text{ m}^3/\text{hr}$
Pump Head		
Actual Pump Head	= 15 m	= 15 m
Others Headloss	= 5 m	= 5 m
Injection Pressure	= 5 m	= 5 m
Total Pump Head	= 25 m → 30 m	= 25 m → 30 m
Motor Output	$P = \frac{\rho \times g \times Q \times H}{60 \times 1000 \times \eta} (1 + \alpha)$ $= \frac{1.05 \times 9.8 \times 0.9 \times 30}{60.0 \times 0.35 \times 0.95} \times (1 + 0.2)$ $= 16.5 \text{ kW} \rightarrow 18.5 \text{ kW}$	
Pump Specification		
Type	= Progressing Cavity Pump	= Progressing Cavity Pump
Diameter	= 150 mm	= 150 mm
Capacity	= 17.8 - 53.3 m <sup>3</sup> /hr	= 17.8 - 53.3 m <sup>3</sup> /hr
Pump Head	= 30 m	= 30 m
Motor Output	= 18.5 kW	= 18.5 kW
Number of Pumps	= 5 nos. (Including 2 standby)	= 3 nos. (Including 1 standby)









Appendix 4.5.3 Grit Chamber  
 (1) Plan and Section




Grit Chamber Plan (Lower)




Section A - A



Grit Chamber Plan (middle)



Section B - B



Grit Chamber Plan (Upper)

NO.	DATE	DESCRIPTION	APPD. BY
DRAWING TITLE			
FLUIT WASTEWATER TREATMENT PLANT AERATED GRIT CHAMBER (PLAN and SECTION)			
SCALE			
A1	1:200	SHEET	
A3	1:400		
PROJECT			
THE SUPRI EMBRIMENTAL STUDY FOR METROPOLITAN SANITATION MANAGEMENT INVESTMENT PROGRAM SEWERAGE SYSTEM DEVELOPMENT IN DKI JAKARTA (EIS) IN REPUBLIC OF INDONESIA			
DESIGNED BY		DATE	SIGNATURE
DRAWN BY			
CHECKED BY			
APPROVED BY			
DRAWING NO.	005	REV.	
JAPAN INTERNATIONAL COOPERATION AGENCY			













Appendix 4.5.6 Dewatering Building  
 (1) Plan and Section




NO.	DATE	DESCRIPTION	APPRO. BY
DRAWING TITLE			
PLANT WASTEWATER TREATMENT PLANT DEWATERING BUILDING PLAN and SECTION			
SCALE:			
A1	1:200	UNITS	
A3	1:400		
PROJECT:			
THE SUPPLEMENTAL STUDY FOR METROPOLITAN SANITATION MANAGEMENT INVESTMENT PROGRAM SEWERAGE SYSTEM DEVELOPMENT IN DKI JAKARTA (S3) IN REPUBLIC OF INDONESIA			
DESIGNED BY	DATE	SIGNATURE	
DRAWN BY			
CHECKED BY			
APPROVED BY:			
DRAWING NO.	010	REV.	
JAPAN INTERNATIONAL COOPERATION AGENCY			


Appendix 4.5.7 Administration Building  
 (1) Plan and Section




B1 floor Plan




1st. floor Plan



Ground floor Plan




2nd. floor Plan




A - A Section

NO.	DATE	DESCRIPTION	APP'D BY
DRAWING TITLE			
PLUIT WASTEWATER TREATMENT PLANT ADMINISTRATION BUILDING PLAN AND SECTION			
SCALE:	A1	1:200	UNITS
	A2	1:400	
PROJECT			
THE SUPPLEMENTAL STUDY FOR METROPOLITAN SANITATION MANAGEMENT INVESTMENT PROGRAM SEWERAGE SYSTEM DEVELOPMENT IN DKI JAKARTA (ES) IN REPUBLIC OF INDONESIA			
DESIGNED BY:	DATE	SIGNATURE	
DRAWN BY:			
CHECKED BY:			
APPROVED BY:			
DRAWING NO.:	011	REV	
JICA - JAPAN INTERNATIONAL COOPERATION AGENCY			



# Lift Pumping Station

## Temporary Work Plan




### Bill of Quantity (Temporary work)

DIVISION	Size (mm)	Total Length (m)	Unit Weight (kg/ea)	Total (kg)
D-WALL	t=800mm B=5.6m (32ea)	L=43.7m 1997	V = 6,265m <sup>3</sup>	
STRUT	H-350X350X12X19	330	137	45210
	H-400X400X13X21	1815	172	312180
CORNER-STRUT	H-350X350X12X19	815	137	111655
	H-400X400X13X21	4479	172	770314
WALE	H-350X350X12X19	565	137	77405
	H-400X400X13X21	4149	172	713554
POST PILE	H-350X350X12X19	2125	137	291131
BRACKET	-	540		
CHANNEL	I-380X100X10.5X16	528	54.5	28783
	LS-90X90X10	309	17.0	5249
JACK	-	460 ps		
Total(steel)				2,355,481


\* except to welding, drilling, Jack supporting etc.

PROJECT	DESIGN COMPANY	SCALE	DATE	PROJECT ENGINEER	LEADING ENGINEER	CIVIL ENGINEER	TITLE	DRAWING NO.
The Supplemental Study for Metropolitan Sanitation Management Investment Program: Sewerage System Development in DKI Jakarta (E/S) in Republic of INDONESIA		S = 1 : NONE	2014.06				Temporary work plan (Lift Pumping Station)	

Appendix 4.6.2 Lift Pumping Station  
 (2) Temporary Work Section



PROJECT	DESIGN COMPANY	SCALE	DATE	PROJECT ENGINEER	LEADING ENGINEER	CIVIL ENGINEER	TITLE	DRAWING NO.
The Supplemental Study for Metropolitan Sanitation Management Investment Program: Sewerage System Development in DKI Jakarta (E/S) in Republic of INDONESIA		S = 1 : NONE	2014.06				Temporary work section (Lift Pumping Station)	








# Grit Chamber

## Temporary Work Section




PROJECT	DESIGN COMPANY	SCALE	DATE	PROJECT ENGINEER	LEADING ENGINEER	CIVIL ENGINEER	TITLE	DRAWING NO.
The Supplemental Study for Metropolitan Sanitation Management Investment Program: Sewerage System Development in DKI Jakarta (E/S) in Republic of INDONESIA		S = 1 : NONE	2014.06				Temporary work section (Grit Chamber)	

Appendix 4.6.3 Grit Chamber  
(3) Temporary Work Section

Equalization Tank

Foundation Plan



Bill of Quantity (Foundation work)


DIVISION	Reforcement method	Size	Quantity
Shallow foundation	Displacement cobble	t = 30-192cm	V = 8329 m <sup>3</sup>
Pile foundation	Bored pile	Φ 1200 (L = 11m-12.8m)	256 ea (3276m)
		Boring H = 20.8 m	L = 5324.8m

PROJECT	DESIGN COMPANY	SCALE	DATE	PROJECT ENGINEER	LEADING ENGINEER	CIVIL ENGINEER	TITLE	DRAWING NO.
The Supplemental Study for Metropolitan Sanitation Management Investment Program: Sewerage System Development in DKI Jakarta (E/S) in Republic of INDONESIA		S = 1 : NONE	2014.06				Foundation Plan (Equalization Tank)	

Equalization Tank

Temporary Work Plan


Bill of Quantity (Temporary work)




DIVISION	Size (mm)	Total Length (m)	Unit Weight (kg/m)	Total (kg)
D-WALL	t=800mm B=5.6m (90ea)	L=18.6m	1746	V = 7,500 mt
STRUT	H-350X350X12X19	1027	137	140735
	H-400X400X13X21	3082	172	530068
CONER-STRUT	H-350X350X12X19	1206	137	165162
	H-400X400X13X21	3589	172	617248
WALE	H-350X350X12X19	590	137	80830
	H-400X400X13X21	3520	172	605440
POST PILE	H-350X350X12X19	1177	137	161296
BRACKET	-	540		
CHANNEL	I-380X100X10.5X16	990	54.5	53955
	LS-90X90X10	1020	17.0	17334
JACK	-	460 ps		
Total(steel)				2,372,068

\* except welding, drilling, Jack supporting etc.


PROJECT	DESIGN COMPANY	SCALE	DATE	PROJECT ENGINEER	LEADING ENGINEER	CIVIL ENGINEER	TITLE	DRAWING NO.
The Supplemental Study for Metropolitan Sanitation Management Investment Program: Sewerage System Development in DKI Jakarta (E/S) in Republic of INDONESIA		S = 1 : NONE	2014.06				Temporary Plan (Equalization Tank)	





Aeration Tank and MBR Tank

Temporary Work Plan




Bill of Quantity (Temporary work)


DIVISION	Size (mm)	Total Length (m)	Unit Weight (kg/m)	Total (kg)
D-WALL	t=800mm B=5.6m (117ea)	L=16.1m 3189	V = 8,439 m <sup>3</sup>	
STRUT	H-350X350X12X19	1316	137	180356
	H-400X400X13X21	2633	172	452866
CORNER-STRUT	H-350X350X12X19	1822	137	249663
	H-400X400X13X21	3639	172	625928
WALE	H-350X350X12X19	1703	137	233344
	H-400X400X13X21	3394	172	583777
DIVISION	Size (mm)	Total Length (m)	Unit Weight (kg/m)	Total (kg)
POST PILE	H-350X350X12X19	4803	137	658028
BRACKET	-	780		
CHANNEL	I-380X100X10.5X16	1115	54.5	60784
	LS-90X90X10	3880	17.0	65955
JACK	-	535		
Total(steel)				3,110,703

\* except welding, drilling, Jack supporting etc.


PROJECT	DESIGN COMPANY	SCALE	DATE	PROJECT ENGINEER	LEADING ENGINEER	CIVIL ENGINEER	TITLE	DRAWING NO.
The Supplemental Study for Metropolitan Sanitation Management Investment Program: Sewerage System Development in DKI Jakarta (E/S) in Republic of INDONESIA		S = 1 : NONE	2014.06				Temporary work plan (Aeration Tank MBR Tank)	




Appendix 4.6.5 Aeration Tank and MBR Tank Facility  
(3) Temporary Work Section









Appendix 4.6.6 Dewatering Building  
 (1) Temporary Work Section







## Appendix4.7 Construction Cost

### Appendix4.7.1. Civil & Building Works

#### (1) Lift Pump Station

Item	Description	Unit	Qty	Unit Price		Sub-Total Price		Total		
				F/C (USD)	L/C (IDR)	F/C (USD)	L/C (IDR)	IDR	Equivalent to USD	
1. Soil Work										
1)	Excavation	H=33.74m	m <sup>3</sup>	49,070	0	66,411	0	3,258,804,945	3,258,804,945	283,374
2)	Backfill	Imported, Excavation x 10%	m <sup>3</sup>	4,907	0	111,750	0	548,354,797	548,354,797	47,683
3)	Disposal	within 5km	m <sup>3</sup>	49,070	0	29,769	0	1,460,750,109	1,460,750,109	127,022
2. Foundation Work										
	Displacement	Soil Cement(t=220-520cm)	m <sup>3</sup>	5,350	0	113,495	0	607,195,843	607,195,843	52,800
3. Concrete Work										
			m <sup>3</sup>	9,291	0	5,117,742	0	47,548,736,434	47,548,736,434	4,134,673
4. Temporary Work										
1)	Diaphragm Wall									
a.	Guide Wall									
	Excavation		m <sup>3</sup>	190	0	10,162	0	1,930,685	1,930,685	168
	Con'c		m <sup>3</sup>	127	0	741,475	0	94,167,312	94,167,312	8,188
	Form		m <sup>2</sup>	761	0	275,750	0	209,845,522	209,845,522	18,247
	Re-bar	re-use	ton	17	0	9,027,500	0	153,467,500	153,467,500	13,345
	Backfill		m <sup>3</sup>	63	0	31,475	0	1,982,950	1,982,950	172
	Re-Excavation		m <sup>3</sup>	63	0	10,162	0	640,175	640,175	56
	Con'c Waste	re-use	ton	304	0	1,107,000	0	336,528,051	336,528,051	29,263
	Re-Backfill		m <sup>3</sup>	190	0	31,475	0	5,980,326	5,980,326	520
b.	Cap Beam									
	Con'c		m <sup>3</sup>	127	0	741,475	0	94,167,312	94,167,312	8,188
	Form		m <sup>2</sup>	318	0	275,750	0	87,688,405	87,688,405	7,625
	Re-bar		ton	7	0	9,027,500	0	63,192,500	63,192,500	5,495
c.	Deaphragm wall	depth=43.7m, t=0.8								
	Installation	material	m <sup>3</sup>	6,265	0	3,325,750	0	20,835,825,003	20,835,825,003	1,811,811
	Con'c	material	m <sup>3</sup>	6,265	0	680,000	0	4,260,200,000	4,260,200,000	370,452
	Re-bar		ton	940	0	6,800,000	0	6,392,000,000	6,392,000,000	555,826
2)	H-section steel Pipe	400x400x13x21	ton	2,356	0	17,968,000	0	42,332,607,647	42,332,607,647	3,681,096
3)	Post pile									
a.	Pile	Φ1200	m	264	0	18,936,377	0	4,999,203,449	4,999,203,449	434,713
b.	Con'c		m <sup>3</sup>	358	0	680,000	0	243,440,000	243,440,000	21,169
c.	Sand		m <sup>3</sup>	1,678	0	213,000	0	357,414,000	357,414,000	31,079
5. Bulding Work										
			m <sup>2</sup>	880	0	10,752,500	0	9,462,200,000	9,462,200,000	822,800
6. Other Works(Miscellaneous works)										
	10% of Concrete & Building work		LS	1	0	5,701,184,690	0	5,701,184,690	5,701,184,690	495,750
Total								149,057,507,653	149,057,507,653	12,961,517

(2) Grit Chamber

Item	Description	Unit	Qty	Unit Price		Sub-Total Price		Total		
				F/C (USD)	L/C (IDR)	F/C (USD)	L/C (IDR)	IDR	Equivalent to USD	
1. Soil Work										
1)	Excavation	H=4.2m	m <sup>3</sup>	1,692	0	16,545	0	27,994,563	27,994,563	2,434
2)	Backfill	Imported, Excavation x 10%	m <sup>3</sup>	169	0	111,750	0	18,885,666	18,885,666	1,642
3)	Disposal	within 5km	m <sup>3</sup>	1,692	0	29,769	0	50,368,640	50,368,640	4,380
2. Foundation Work										
1)	Bored File									
a.	Pile	Φ1200	m	330	0	18,935,000	0	6,248,549,901	6,248,549,901	543,352
b.	Con'c		m <sup>3</sup>	373	0	680,000	0	253,640,000	253,640,000	22,056
c.	Re-bar		ton	56	0	6,800,000	0	380,800,000	380,800,000	33,113
d.	Sand		m <sup>3</sup>	119	0	212,500	0	25,287,500	25,287,500	2,199
2)	Displacement	Aggregate	m <sup>3</sup>	336	0	113,495	0	38,134,169	38,134,169	3,316
3. Concrete Work										
			m <sup>3</sup>	1,050	0	8,733,367	0	9,169,305,755	9,169,305,755	797,331
4. Temporary Work										
1)	Sheet Pile		ton	290	0	14,372,001	0	4,167,880,261	4,167,880,261	362,424
2)	Post File									
a.	Pile	Φ1200	m	95	0	2,840,000	0	1,798,955,787	1,798,955,787	156,431
b.	Con'c		m <sup>3</sup>	0	0	680,000	0	0	0	0
c.	Sand		m <sup>3</sup>	108	0	213,000	0	23,004,000	23,004,000	2,000
3)	H-section steel Pipe	400x400x13x21	ton	135	0	17,968,000	0	2,425,679,980	2,425,679,980	210,929
5. Other Works(Miscellaneous works)										
	10% of Concrete work		LS	1	0	916,930,576	0	916,930,576	916,930,576	79,730
Total								25,545,416,797	25,545,416,797	2,221,338

### (3) Equalization Tank

Item	Description	Unit	Q'ty	Unit Price		Sub-Total Price		Total		
				F/C (USD)	L/C (IDR)	F/C (USD)	L/C (IDR)	IDR	Equivalent to USD	
<b>1. Soil Work</b>										
1)	Excavation	H=10.1m	m <sup>3</sup>	70,338	0	16,545	0	1,163,759,795	1,163,759,795	101,197
2)	Backfill	Imported, Excavation x 10%	m <sup>3</sup>	7,034	0	111,750	0	786,045,983	786,045,983	68,352
3)	Disposal	within 5km	m <sup>3</sup>	70,338	0	29,769	0	2,093,870,821	2,093,870,821	182,076
<b>2. Foundation Work</b>										
1)	Bored File									
a.	Pile	Φ1200	m	3,277	0	18,935,000	0	62,049,994,017	62,049,994,017	5,395,652
b.	Con'c		m <sup>3</sup>	3,704	0	680,000	0	2,518,720,000	2,518,720,000	219,019
c.	Re-bar		ton	556	0	6,800,000	0	3,780,800,000	3,780,800,000	328,765
d.	Sand		m <sup>3</sup>	2,315	0	212,500	0	491,937,500	491,937,500	42,777
2)	Displacement		0 m <sup>3</sup>	9,700	0	113,495	0	1,100,897,135	1,100,897,135	95,730
<b>3. Concrete Work</b>										
			m <sup>3</sup>	19,033	0	5,517,052	0	105,007,750,912	105,007,750,912	9,131,109
<b>4. Temporary Work</b>										
1)	Diaphragm Wall									
a.	Guide Wall									
	Excavation		m <sup>3</sup>	580	0	10,162	0	5,893,670	5,893,670	512
	Con'c		m <sup>3</sup>	387	0	741,475	0	286,950,786	286,950,786	24,952
	Form		m <sup>2</sup>	2,322	0	275,750	0	640,290,803	640,290,803	55,677
	Re-bar	re-use	ton	53	0	9,027,500	0	478,457,500	478,457,500	41,605
	Backfill		m <sup>3</sup>	193	0	31,475	0	6,074,752	6,074,752	528
	Re-Excavation		m <sup>3</sup>	193	0	10,162	0	1,961,170	1,961,170	171
	Con'c Waste	re-use	ton	928	0	1,107,000	0	1,027,296,155	1,027,296,155	89,330
	Re-Backfill		m <sup>3</sup>	580	0	31,475	0	18,255,732	18,255,732	1,587
b.	Cap Beam			0						
	Con'c		m <sup>3</sup>	387	0	741,475	0	286,950,786	286,950,786	24,952
	Form		m <sup>2</sup>	968	0	275,750	0	266,925,710	266,925,710	23,211
	Re-bar		ton	21	0	9,027,500	0	189,577,500	189,577,500	16,485
c.	Deaphragm wall	depth=43.7m, t=0.8		0						
	Installation	material	m <sup>3</sup>	7,500	0	3,325,750	0	24,943,126,500	24,943,126,500	2,168,968
	Con'c	Φ1200	m <sup>3</sup>	7,500	0	680,000	0	5,100,000,000	5,100,000,000	443,478
	Re-bar		ton	1,125	0	6,800,000	0	7,650,000,000	7,650,000,000	665,217
2)	Post File									
a.	Pile	Φ1200	m	1,904	0	18,936,377	0	36,054,861,237	36,054,861,237	3,135,205
b.	Con'c		m <sup>3</sup>	2,583	0	680,000	0	1,756,440,000	1,756,440,000	152,734
c.	Sand		m <sup>3</sup>	2,557	0	213,000	0	544,641,000	544,641,000	47,360
3)	H-section steel Pipe	400x400x13x21	ton	2,732	0	17,968,000	0	49,088,575,590	49,088,575,590	4,268,572
<b>5. Other Works(Miscellaneous works)</b>										
	10% of Concrete work		LS	1	0	10,500,775,091	0	10,500,775,091	10,500,775,091	913,111
<b>Total</b>								317,840,830,144	317,840,830,144	27,638,333

#### (4) Aeration & MBR Tanks

Item	Description	Unit	Q'ty	Unit Price		Sub-Total Price		Total		
				F/C (USD)	L/C (IDR)	F/C (USD)	L/C (IDR)	IDR	Equivalent to USD	
<b>1. Soil Work</b>										
1)	Excavation	H=6.4m	m <sup>3</sup>	80,361	0	16,545	0	1,329,592,835	1,329,592,835	115,617
2)	Backfill	Imported, Excavation x 10%	m <sup>3</sup>	8,036	0	111,750	0	898,018,982	898,018,982	78,089
3)	Disposal	within 5km	m <sup>3</sup>	80,361	0	29,769	0	2,392,242,501	2,392,242,501	208,021
<b>2. Foundation Work</b>										
1)	Bored File									
a.	Pile	Φ1200	m	4,464	0	18,935,000	0	84,525,838,661	84,525,838,661	7,350,073
b.	Con'c		m <sup>3</sup>	5,046	0	680,000	0	3,431,280,000	3,431,280,000	298,372
c.	Re-bar		ton	757	0	6,800,000	0	5,147,600,000	5,147,600,000	447,617
d.	Sand		m <sup>3</sup>	1,725	0	212,500	0	366,562,500	366,562,500	31,875
2)	Displacement		m <sup>3</sup>	12,820	0	113,495	0	1,455,000,131	1,455,000,131	126,522
<b>3. Concrete Work</b>										
1)	Aeration Tanks		m <sup>3</sup>	15,429	0	5,400,154	0	83,321,045,096	83,321,045,096	7,245,308
2)	MBR Tanks		m <sup>3</sup>	10,722	0	6,444,962	0	69,100,158,068	69,100,158,068	6,008,709
<b>4. Temporary Work</b>										
1)	Diaphragm Wall									
a.	Guide Wall									
	Excavation		m <sup>3</sup>	763	0	10,162	0	7,753,225	7,753,225	674
	Con'c		m <sup>3</sup>	509	0	741,475	0	377,410,724	377,410,724	32,818
	Form		m <sup>2</sup>	3,056	0	275,750	0	842,691,083	842,691,083	73,277
	Re-bar	re-use	ton	70	0	9,027,500	0	631,925,000	631,925,000	54,950
	Backfill		m <sup>3</sup>	254	0	31,475	0	7,994,752	7,994,752	695
	Re-Excavation		m <sup>3</sup>	254	0	10,162	0	2,581,021	2,581,021	224
	Con'c Waste	re-use	ton	1,222	0	1,107,000	0	1,352,754,204	1,352,754,204	117,631
	Re-Backfill		m <sup>3</sup>	763	0	31,475	0	24,015,730	24,015,730	2,088
b.	Cap Beam									
	Con'c		m <sup>3</sup>	509	0	741,475	0	377,410,724	377,410,724	32,818
	Form		m <sup>2</sup>	1,274	0	275,750	0	351,305,118	351,305,118	30,548
	Re-bar		ton	27	0	9,027,500	0	243,742,500	243,742,500	21,195
c.	Deaphragm wall	Φ1200								
	Installation	material	m <sup>3</sup>	8,439	0	3,325,750	0	28,066,005,938	28,066,005,938	2,440,522
	Con'c	material	m <sup>3</sup>	8,439	0	680,000	0	5,738,520,000	5,738,520,000	499,002
	Re-bar		ton	1,266	0	6,800,000	0	8,608,800,000	8,608,800,000	748,591
2)	Post File									
a.	Pile	Φ1200	m	2,173	0	18,936,377	0	41,148,746,569	41,148,746,569	3,578,152
b.	Con'c		m <sup>3</sup>	2,947	0	680,000	0	2,003,960,000	2,003,960,000	174,257
c.	Sand		m <sup>3</sup>	1,621	0	213,000	0	345,273,000	345,273,000	30,024
3)	H-section steel Pipe	400x400x13x21	ton	3,459	0	17,968,000	0	62,151,311,481	62,151,311,481	5,404,462
<b>4. Bulding Work</b>										
1)	Aeration Tanks		m <sup>3</sup>	1,240	0	7,820,000	0	9,696,800,000	9,696,800,000	843,200
2)	MBR Tanks		m <sup>3</sup>	3,310	0	7,820,000	0	25,884,200,000	25,884,200,000	2,250,800
<b>5. Other Works(Miscellaneous works)</b>										
	10% of Concrete work and Building work		LS	1	0	18,800,220,316	0	18,800,220,316	18,800,220,316	1,634,802
<b>Total</b>								<b>458,630,760,158</b>	<b>458,630,760,158</b>	<b>39,880,936</b>



## (5) Dewatering Buildings

Item	Description	Unit	Q'ty	Unit Price		Sub-Total Price		Total		
				F/C (USD)	L/C (IDR)	F/C (USD)	L/C (IDR)	IDR	Equivalent to USD	
1. Soil Work										
1)	Excavation	H=7.4m	m <sup>3</sup>	5,707	0	16,545	0	94,423,742	94,423,742	8,211
2)	Backfill	Imported, Excavation x 10%	m <sup>3</sup>	571	0	111,750	0	63,808,965	63,808,965	5,549
3)	Disposal	within 5km	m <sup>3</sup>	5,707	0	29,769	0	169,889,971	169,889,971	14,773
2. Foundation Work										
1)	Bored File									
a.	Pile	Φ1200	m	295	0	18,935,000	0	5,585,824,912	5,585,824,912	485,724
b.	Con'c		m <sup>3</sup>	333	0	680,000	0	226,440,000	226,440,000	19,690
c.	Re-bar		ton	50	0	6,800,000	0	340,000,000	340,000,000	29,565
d.	Sand		m <sup>3</sup>	209	0	212,500	0	44,412,500	44,412,500	3,862
2)	Displacement		0 m <sup>3</sup>	376	0	113,495	0	42,673,951	42,673,951	3,711
3. Temporary Work										
1)	Sheet Pile	SP-IV 170*400*15.5	ton	430	0	14,372,001	0	6,179,960,387	6,179,960,387	537,388
2)	Post File									
a.	Pile	Φ1200	m	156	0	18,936,377	0	2,954,074,765	2,954,074,765	256,876
b.	Con'c		m <sup>3</sup>	212	0	680,000	0	144,160,000	144,160,000	12,536
c.	Sand		m <sup>3</sup>	167	0	213,000	0	35,571,000	35,571,000	3,093
3)	H-section steel Pipe	400x400x13x21	ton	401	0	17,968,000	0	7,205,167,940	7,205,167,940	626,536
4.	Building Work		m <sup>2</sup>	1,740	0	10,752,500	0	18,709,350,000	18,709,350,000	1,626,900
5.	Other Works(Miscellaneous works)		LS	1	0	1,870,935,000	0	1,870,935,000	1,870,935,000	162,690
	10% of Concrete work and Building work									
Total								43,666,693,132	43,666,693,132	3,797,104

## (6) Administration Buildings

Item	Description	Unit	Q'ty	Unit Price		Sub-Total Price		Total		
				F/C (USD)	L/C (IDR)	F/C (USD)	L/C (IDR)	IDR	Equivalent to USD	
1. Foundation Work										
a.	Pile	Φ1200	m	269	0	18,935,000	0	5,093,514,919	5,093,514,919	442,914
b.	Con'c		m <sup>3</sup>	304	0	680,000	0	206,720,000	206,720,000	17,976
c.	Re-bar		ton	46	0	6,800,000	0	312,800,000	312,800,000	27,200
d.	Sand		m <sup>3</sup>	39	0	212,500	0	8,287,500	8,287,500	721
	0									
2.	Building Work		m <sup>2</sup>	1,140	0	13,196,250	0	15,043,725,000	15,043,725,000	1,308,150
5.	Other Works(Miscellaneous works)		LS	1	0	1,504,372,500	0	1,504,372,500	1,504,372,500	130,815
	10% of Concrete work and Building work									
Total								22,169,419,919	22,169,419,919	1,927,776

Appendix 4.7.2. Machinery & Electricity Facilities  
(1) Lift Pumping Station

No.	Equipment	Brief Spec.	Motor Output (kW)	Quantity				Unit Price			Cost									Remarks	
											Phase I			Phase II			Total				
				Unit	Phase I	Phase II	Total	FC	LC		FC	LC	Total	FC	LC	Total	FC	LC	Total		
								(USD)	(Rp)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)		(Rp)
1.1	Inflow Gate	Electrical motor operation cast iron sluice gate 1.4mW x 3.1mH	3.7	set	4	0	4	25,000	57,500,000	5,000	100,000	20,000	120,000	0	0	0	100,000	20,000	120,000	1,380,000,000	
1.2	Coarse screen	Flat bar screen (manual raking) Spacing 100mm (2.5mW x 4.6mH, 65 deg installation)	-	set	2	2	4	15,000	57,500,000	5,000	30,000	10,000	40,000	30,000	10,000	40,000	60,000	20,000	80,000	920,000,000	
1.3	Fine screen	Single rake automatic Screen Spacing 15mm (2.5mW x 4.6mH, 70 deg installation)	2.2	set	2	2	4	110,000	80,500,000	7,000	220,000	14,000	234,000	220,000	14,000	234,000	440,000	28,000	468,000	5,382,000,000	
1.4	Lift pump	Vertical shaft Volute type mixed flow pump 650mm x 61.0m3/min x 33.3mH	480	set	3	2	5	660,000	345,000,000	30,000	1,980,000	90,000	2,070,000	1,320,000	60,000	1,380,000	3,300,000	150,000	3,450,000	39,675,000,000	Including 1 standby at each Phase
1.5	Flow meter	Ultrasonic type Diameter 650mm	-	set	3	2	5	12,000	55,200,000	4,800	36,000	14,400	50,400	24,000	9,600	33,600	60,000	24,000	84,000	966,000,000	
1.6	Hoist	Electric motor operation hoist Lifting capacity : 10 ton	5.0 (Hoisting) 0.85 (Travelling)	set	1	0	1	18,000	55,200,000	4,800	18,000	4,800	22,800	0	0	0	18,000	4,800	22,800	262,200,000	
1.7	Pump up well connection gate	Manual operation cast iron sluice gate 1.5 mW x 1.5 mH	-	set	1	0	1	138,000	55,200,000	4,800	138,000	4,800	142,800	0	0	0	138,000	4,800	142,800	1,642,200,000	
1.8	Miscellaneous	with piping	-	set	1	1	2	48,000	138,000,000	12,000	48,000	12,000	60,000	48,000	12,000	60,000	96,000	24,000	120,000	1,380,000,000	
Sub Total											2,570,000	170,000	2,740,000	1,642,000	105,600	1,747,600	4,212,000	275,600	<b>4,487,600</b>	<b>51,607,400,000</b>	

(2) Grit Chamber

No.	Equipment	Brief Spec.	Motor Output (kW)	Quantity				Unit Price			Cost									Remarks	
											Phase I			Phase II			Total				
				Unit	Phase I	Phase II	Total	FC	LC		FC	LC	Total	FC	LC	Total	FC	LC	Total		
								(USD)	(Rp)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)		(Rp)
3.1	Inflow weir gate	Manual operation cast iron weir type gate 0.6 mW x 0.6 mH	-	set	16	16	32	8,330	23,920,000	2,080	133,280	33,280	166,560	133,280	33,280	166,560	266,560	66,560	333,120	3,830,880,000	
3.2	Constant rate pump	Nonclogging pump 250mm x 7.0 m3/min x 14m	37	set	12	12	24	55,000	44,275,000	3,850	660,000	46,200	706,200	660,000	46,200	706,200	1,320,000	92,400	1,412,400	16,242,600,000	Phase1 including 2 standbys Final phase including 4 standbys
3.3	Mixer for antisetling	Submersible propeller type Propeller diameter 500mm	5.5	set	32	32	64	21,600	27,600,000	2,400	691,200	76,800	768,000	691,200	76,800	768,000	1,382,400	153,600	1,536,000	17,664,000,000	
3.4	Ultra fine screen	Motorized step screen Spacing 5mm	0.4	set	10	10	20	63,960	13,800,000	1,200	639,600	12,000	651,600	639,600	12,000	651,600	1,279,200	24,000	1,303,200	14,986,800,000	For reducing the burden of drum screen in aeration tank
3.5	Miscellaneous	with piping	-	set	1	1	2	24,330	5,520,000	480	24,330	480	24,810	24,330	480	24,810	48,660	960	49,620	570,630,000	
Sub Total											2,148,410	168,760	2,317,170	2,148,410	168,760	2,317,170	4,296,820	337,520	<b>4,634,340</b>	<b>53,294,910,000</b>	

3) Equalization Tanks

No.	Equipment	Brief Spec.	Motor Output (kW)	Quantity				Unit Price			Cost									Remarks	
				Unit	Phase I	Phase II	Total	FC (USD)	LC (Rp)	LC (USD)	Phase I			Phase II			Total				
											FC (USD)	LC (USD)	Total (USD)	FC (USD)	LC (USD)	Total (USD)	FC (USD)	LC (USD)	Total (USD)		
																					Total (USD)
3.1	Inflow weir gate	Manual operation cast iron weir type gate 0.6 mW x 0.6 mH	-	set	16	16	32	8,330	23,920,000	2,080	133,280	33,280	166,560	133,280	33,280	166,560	266,560	66,560	333,120	3,830,880,000	
3.2	Constant rate pump	Nonclogging pump 250mm x 7.0 m <sup>3</sup> /min x 14m	37	set	12	12	24	55,000	44,275,000	3,850	660,000	46,200	706,200	660,000	46,200	706,200	1,320,000	92,400	1,412,400	16,242,600,000	Phase1 including 2 standbys Final phase including 4 standbys
3.3	Mixer for antisetling	Submersible propeller type Propeller diameter 500mm	5.5	set	32	32	64	21,600	27,600,000	2,400	691,200	76,800	768,000	691,200	76,800	768,000	1,382,400	153,600	1,536,000	17,664,000,000	
3.4	Ultra fine screen	Motorized step screen Spacing 5mm	0.4	set	10	10	20	63,960	13,800,000	1,200	639,600	12,000	651,600	639,600	12,000	651,600	1,279,200	24,000	1,303,200	14,986,800,000	For reducing the burden of drum screen in aeration tank
3.5	Miscellaneous	with piping	-	set	1	1	2	24,330	5,520,000	480	24,330	480	24,810	24,330	480	24,810	48,660	960	49,620	570,630,000	
Sub Total											2,148,410	168,760	2,317,170	2,148,410	168,760	2,317,170	4,296,820	337,520	<b>4,634,340</b>	<b>53,294,910,000</b>	

(4) Disinfection Facility

No.	Equipment	Brief Spec.	Motor Output (kW)	Quantity				Unit Price			Cost									Remarks	
											Phase I			Phase II			Total				
				Unit	Phase I	Phase II	Total	FC	LC		FC	LC	Total	FC	LC	Total	FC	LC	Total		
								(USD)	(Rp)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)		(Rp)
4.1	Sodium hypochlorite storage tank	Fiberglass plastic construction Cylindrical tank 10m3	-	set	2	2	4	14,400	33,120,000	2,880	28,800	5,760	34,560	28,800	5,760	34,560	57,600	11,520	69,120	794,880,000	
4.2	Sodium hypochlorite dosing pump	Diaphragm pump 2.5L/min	0.4	set	3	3	6	4,440	6,210,000	540	13,320	1,620	14,940	13,320	1,620	14,940	26,640	3,240	29,880	343,620,000	Phase1 including 1 standbys Final phase including 2standbys
4.3	Miscellaneous	with piping	-	set	1	1	2	2,880	4,140,000	360	2,880	360	3,240	2,880	360	3,240	5,760	720	6,480	74,520,000	
Sub Total											45,000	7,740	52,740	45,000	7,740	52,740	90,000	15,480	105,480	1,213,020,000	

(5) Aeration & MBR Tanks

No.	Equipment	Brief Spec.	Motor Output (kW)	Quantity				Unit Price			Cost									Remarks	
											Phase I			Phase II			Total				
				Unit	Phase I	Phase II	Total	FC	LC		FC	LC	Total	FC	LC	Total	FC	LC	Total		
								(USD)	(Rp)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)		(Rp)
5.1	Mesh screen	Mesh Drum Screen Spacing 1mm Capacity 2,084m <sup>3</sup> /h or more	9	set	4	4	8	250,000	57,500,000	5,000	1,000,000	20,000	1,020,000	1,000,000	20,000	1,020,000	2,000,000	40,000	2,040,000	23,460,000,000	
5.2	Air diffuser for aeration tank	Fine Bubble Disk Membrane Type Air Flow Rate 120~150 L/min Oxygen Transfer Efficiency 20%	-	ea	4700	4700	9400	70	575,000	50	329,000	235,000	564,000	329,000	235,000	564,000	658,000	470,000	1,128,000	12,972,000,000	Including 1 standby at each phase
5.3	Blower for aeration tank	Turbo type Blower 90m <sup>3</sup> /min x 68kpa	150	set	6	6	12	300,000	34,500,000	3,000	1,800,000	18,000	1,818,000	1,800,000	18,000	1,818,000	3,600,000	36,000	3,636,000	41,814,000,000	Including 2 standbys at each phase
5.4	Membrane unit	Hollow fiber membrane Membrane area 1,200m <sup>2</sup> /unit	-	set	200	200	400	108,000	55,200,000	4,800	21,600,000	960,000	22,560,000	21,600,000	960,000	22,560,000	43,200,000	1,920,000	45,120,000	518,880,000,000	
5.5	Membrane filtration pump	Centrifugal pump 10.6m <sup>3</sup> /min x 10m	22	set	12	12	24	96,000	5,980,000	520	1,152,000	6,240	1,158,240	1,152,000	6,240	1,158,240	2,304,000	12,480	2,316,480	26,639,520,000	Including 2 standbys at each phase Including air-water separator, vacuum pumps
5.6	NaOCl pump for maintenance cleaning	Diaphragm pump 4.2L/min	0.2	set	8	8	16	4,800	6,210,000	540	38,400	4,320	42,720	38,400	4,320	42,720	76,800	8,640	85,440	982,560,000	Including 4 standbys at each phase
5.7	NaOCl pump for recovering cleaning	Diaphragm pump 25.2L/min	1.5	set	8	8	16	6,000	6,900,000	600	48,000	4,800	52,800	48,000	4,800	52,800	96,000	9,600	105,600	1,214,400,000	Including 4 standbys at each phase
5.8	Dilution water pump	Centrifugal pump 1.2m <sup>3</sup> /min	3.7	set	8	8	16	9,600	13,800,000	1,200	76,800	9,600	86,400	76,800	9,600	86,400	153,600	19,200	172,800	1,987,200,000	Including 4 standbys at each phase
5.9	Blower for membrane scrubbing	Turbo type Blower 132m <sup>3</sup> /min x 64kpa	150	set	12	12	24	345,600	20,700,000	1,800	4,147,200	21,600	4,168,800	4,147,200	21,600	4,168,800	8,294,400	43,200	8,337,600	95,882,400,000	Including 2 standbys at each phase
5.10	Circulation pump	Submersible Axial Pump 13.9m <sup>3</sup> /min	11	set	14	14	28	108,000	16,560,000	1,440	1,512,000	20,160	1,532,160	1,512,000	20,160	1,532,160	3,024,000	40,320	3,064,320	35,239,680,000	Including 4 standbys at each phase
5.11	Excess sludge pump	Non-clog type Sludge Pump 1.0m <sup>3</sup> /min Discharge pressure 12m	11	set	4	4	8	16,800	4,140,000	360	67,200	1,440	68,640	67,200	1,440	68,640	134,400	2,880	137,280	1,578,720,000	Including 2 standbys at each phase
5.12	Miscellaneous	with piping	-	set	1	1	2	87,600	358,800,000	31,200	87,600	31,200	118,800	87,600	31,200	118,800	175,200	62,400	237,600	2,732,400,000	
Sub Total											31,858,200	1,332,360	33,190,560	31,858,200	1,332,360	33,190,560	63,716,400	2,664,720	66,381,120	763,382,880,000	

**(6) Dewatering & Deodorization Facility**

No.	Equipment	Brief Spec.	Motor Output (kW)	Quantity				Unit Price			Cost									Remarks	
											Phase I			Phase II			Total				
				Unit	Phase I	Phase II	Total	FC	LC		FC	LC	Total	FC	LC	Total	FC	LC	Total		
								(USD)	(Rp)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)		(Rp)
6.1	Excess sludge mixer	Vertical shaft paddle mixer	11	set	2	0	2	43,200	11,040,000	960	86,400	1,920	88,320	0	0	0	86,400	1,920	88,320	1,015,680,000	including 1 standby
6.2	Excess sludge feed pump	Progressive cavity pump 125mm x 4.3 - 35m <sup>3</sup> /h	11	set	3	2	5	22,320	17,940,000	1,560	66,960	4,680	71,640	44,640	3,120	47,760	111,600	7,800	119,400	1,373,100,000	including 1 standby
6.3	Dehydrator	Pressing Rotary Outer Cylinder -type Screw Press (ISGK-0805) Screen diameter 800 mm	2.2	set	3	2	5	1,462,722	51,060,000	4,440	4,388,165	13,320	4,401,485	2,925,444	8,880	2,934,324	7,313,609	22,200	7,335,809	84,361,803,500	including 1 standby
6.4	Deodorization equipment	Bio-deodorization system	453	set	1	0	1	1,800,000	5,520,000,000	480,000	1,800,000	480,000	2,280,000	0	0	0	1,800,000	480,000	2,280,000	26,220,000,000	
6.5	Miscellaneous	with piping	-	set	1	1	2	6,000	13,800,000	1,200	6,000	1,200	7,200	6,000	1,200	7,200	12,000	2,400	14,400	165,600,000	
Sub Total											6,347,525	501,120	6,848,645	2,976,084	13,200	2,989,284	9,323,609	514,320	<b>9,837,929</b>	<b>113,136,183,500</b>	

(7) Electrical Facility & Control System

No.	Equipment	Brief Spec.	Motor Output (kW)	Quantity				Unit Price			Cost									Remarks	
											Phase I			Phase II			Total				
				Unit	Phase I	Phase II	Total	FC	LC		FC	LC	Total	FC	LC	Total	FC	LC	Total		
								(USD)	(Rp)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(USD)	(Rp)			
7.1	GIS, Transformer	20kV/380V 50Hz 3,000kVA	-	set	2	2	4	1,560,000	5,520,000,000	480,000	3,120,000	960,000	4,080,000	3,120,000	960,000	4,080,000	6,240,000	1,920,000	8,160,000	93,840,000,000	
7.2	Generator	380V 50Hz 3,300kVA Emergency Diesel Generation	-	set	1	0	1	1,485,600	690,000,000	60,000	1,485,600	60,000	1,545,600	0	0	0	1,485,600	60,000	1,545,600	17,774,400,000	
7.3	Monitoring and control system		10	set	0.6	0.4	1	3,000,000	13,800,000,000	1,200,000	1,800,000	720,000	2,520,000	1,200,000	480,000	1,680,000	3,000,000	1,200,000	4,200,000	48,300,000,000	AIO:500 Points DIO:1,800 Points
7.4	Miscellaneous	with Electrical wiring and so on	-	set	0.6	0.4	1	600,000	2,760,000,000	240,000	360,000	144,000	504,000	240,000	96,000	336,000	600,000	240,000	840,000	9,660,000,000	
Sub Total											6,765,600	1,884,000	8,649,600	4,560,000	1,536,000	6,096,000	11,325,600	3,420,000	14,745,600	169,574,400,000	



# Appendix 4.8 Replacement Cost

## Appendix 4.8.1 Replacement Cost in Case 1 (Year 1st to 10th)

Items	1st year		2nd year		3rd year		4th year		5th year		6th year		7th year		8th year		9th year		10th year		Sub-total		
	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	
<b>1. Lift Pumping Facility</b>																							
1.1 Inflow Gate																					0.0	0.0	
1.2 Coarse screen																					0.0	0.0	
1.3 Fine screen																					0.0	0.0	
1.4 Lift pump																					0.0	0.0	
1.5 Flow meter																					0.0	0.0	
1.6 Hoist																					0.0	0.0	
1.7 Pump up well connection gate																					0.0	0.0	
1.8 Miscellaneous																					552.0	138.0	
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	552.0	138.0	552.0	138.0
<b>2. Grit Chamber Facility</b>																							
2.1 Grit collector																					0.0	0.0	
2.2 Grit lifting pump																					0.0	0.0	
2.3 Air blower																					0.0	0.0	
2.4 Miscellaneous																					132.5	19.3	
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	132.5	19.3	0.0	0.0	132.5	19.3	
<b>3. Equalization Tank Facility</b>																							
3.1 Constant rate pump																					0.0	0.0	
3.2 Mixer for antisepting																					0.0	0.0	
3.3 Ultra fine screen																					0.0	0.0	
3.4 Miscellaneous																					0.0	0.0	
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
<b>4. Disinfection Facility</b>																							
4.1 Sodium hypochlorite storage tank										662.4	132.5							662.4	132.5	1,324.8	265.0		
4.2 Sodium hypochlorite dosing pump										306.4	37.3							306.4	37.3	612.7	74.5		
4.3 Miscellaneous												16.6	4.1					66.2	8.3	82.8	12.4		
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	968.8	169.7	16.6	4.1	0.0	0.0	0.0	0.0	0.0	1,035.0	178.0	2,020.3	351.9		
<b>5. Aeration Tank &amp; Membrane Bioreactor Facility</b>																							
5.1 Mesh screen																					0.0	0.0	
5.2 Air diffuser for aeration tank																					7,567.0	5,405.0	
5.3 Blower for aeration tank																					0.0	0.0	
5.4 Membrane unit																248,400.0	2,760.0	248,400.0	2,760.0		496,800.0	5,520.0	
5.5 Membrane filtration pump																					0.0	0.0	
5.6 NaOCl pump for maintenance cleaning												883.2	99.4								883.2	99.4	
5.7 NaOCl pump for recovering cleaning												1,104.0	110.4								1,104.0	110.4	
5.8 Dilution water pump																					0.0	0.0	
5.9 Blower for membrane scrubbing																					0.0	0.0	
5.10 Circulation pump																					0.0	0.0	
5.11 Excess sludge pump																					0.0	0.0	
5.1 Miscellaneous												604.4	143.5								604.4	143.5	
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2,591.6	353.3	0.0	0.0	248,400.0	2,760.0	248,400.0	2,760.0	8,171.4	5,548.5	507,563.1	11,421.8	
<b>6. Dewatering &amp; Deodorization Facility</b>																							
6.1 Excess sludge mixer																					0.0	0.0	
6.2 Excess sludge feed pump																					0.0	0.0	
6.3 Dehydrator																					0.0	0.0	
6.4 Deodorization equipment																					0.0	0.0	
6.5 Miscellaneous																					138.0	27.6	
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	138.0	27.6	138.0	27.6
<b>7. Electrical Facility &amp; Control System</b>																							
7.1 GIS, Transformer																					0.0	0.0	
7.2 Generator																					0.0	0.0	
7.3 Monitoring and control system																6,900.0	2,760.0				6,900.0	2,760.0	
7.4 Miscellaneous																					0.0	0.0	
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6,900.0	2,760.0	0.0	0.0	0.0	0.0	6,900.0	2,760.0	
Total(1-7)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	968.8	169.7	2,608.2	357.4	0.0	0.0	255,300.0	5,520.0	248,532.5	2,779.3	9,896.4	5,892.1	517,305.9	14,718.6	
<b>8. Site Overhead</b>																							
5% of sum of total 1 to 7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	48.4	8.5	130.4	17.9	0.0	0.0	12,765.0	276.0	12,426.6	139.0	494.8	294.6	25,865.3	735.9	
<b>9. General Overhead</b>																							
10% of net replacement cost(sum of 1 to 8)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	101.7	17.8	273.9	37.5	0.0	0.0	26,806.5	579.6	26,095.9	291.8	1,039.1	618.7	54,317.1	1,545.5	
<b>10. Total replacement cost</b>																							
the sum of 1 to 9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1,118.9	196.0	3,012.5	412.8	0.0	0.0	294,871.5	6,375.6	287,055.0	3,210.1	11,430.4	6,805.4	597,488.3	17,000.0	

# Appendix 4.8 Replacement Cost

## Appendix 4.8.1 Replacement Cost in Case 1 (Year 11th to 20th and Total)

Items	11th year		12th year		13th year		14th year		15th year		16th year		17th year		18th year		19th year		20th year		Sub-total		Total				
	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC+LC (Mil. Rp.)	FC+LC (Equiv. to USD)	
<b>1. Lift Pumping Facility</b>																											
1.1 Inflow Gate																						0.0	0.0	0.0	0.0	0.0	0
1.2 Coarse screen																		690.0	230.0	690.0	230.0	690.0	230.0	690.0	230.0	920.0	80,000
1.3 Fine screen																		2,530.0	161.0	2,530.0	161.0	5,060.0	322.0	5,060.0	322.0	5,382.0	468,000
1.4 Lift pump																		37,950.0	1,725.0	37,950.0	1,725.0	37,950.0	1,725.0	37,950.0	1,725.0	39,675.0	3,450,000
1.5 Flow meter					690.0	276.0														690.0	276.0	690.0	276.0	690.0	276.0	966.0	84,000
1.6 Hoist																				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0
1.7 Pump up well connection gate																				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0
1.8 Miscellaneous																		1,104.0	276.0	1,104.0	276.0	1,104.0	276.0	1,656.0	414.0	2,070.0	180,000
Sub-total	0.0	0.0	0.0	0.0	690.0	276.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	4,324.0	667.0	40,480.0	1,886.0	45,494.0	2,829.0	46,046.0	2,967.0	49,013.0	4,262,000
<b>2. Grit Chamber Facility</b>																											
2.1 Grit collector																		2,967.0	118.7	2,967.0	118.7	5,934.0	237.4	5,934.0	237.4	6,171.4	536,640
2.2 Grit lifting pump																		469.2	30.4	469.2	30.4	938.4	60.7	938.4	60.7	999.1	86,880
2.3 Air blower																		1,490.4	60.0	1,490.4	60.0	1,490.4	60.0	1,490.4	60.0	1,550.4	134,820
2.4 Miscellaneous																		132.5	19.3	132.5	19.3	132.5	19.3	265.0	38.6	303.6	26,400
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3,568.7	168.4	4,926.6	209.1	8,495.3	377.4	8,627.8	396.8	9,024.5	784,740
<b>3. Equalization Tank Facility</b>																											
3.1 Constant rate pump																		7,590.0	531.3	7,590.0	531.3	15,180.0	1,062.6	15,180.0	1,062.6	16,242.6	1,412,400
3.2 Mixer for antisepting												7,948.8	883.2	7,948.8	883.2					15,897.6	1,766.4	15,897.6	1,766.4	17,664.0	1,536,000		
3.3 Ultra fine screen																		7,355.4	138.0	7,355.4	138.0	14,710.8	276.0	14,710.8	276.0	14,986.8	1,303,200
3.4 Miscellaneous																		559.6	11.0	559.6	11.0	559.6	11.0	559.6	11.0	570.6	49,620
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	559.6	11.0	7,948.8	883.2	7,948.8	883.2	7,355.4	138.0	14,945.4	669.3	7,590.0	531.3	46,348.0	3,116.0	46,348.0	3,116.0	49,464.0	4,301,220
<b>4. Disinfection Facility</b>																											
4.1 Sodium hypochlorite storage tank																		662.4	132.5	662.4	132.5	1,324.8	265.0	2,649.6	529.9	3,179.5	276,480
4.2 Sodium hypochlorite dosing pump																		306.4	37.3	306.4	37.3	612.7	74.5	1,225.4	149.0	1,374.5	119,520
4.3 Miscellaneous																		66.2	8.3	66.2	8.3	82.8	10.4	165.6	22.8	188.4	16,380
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	968.8	169.7	16.6	2.1	0.0	0.0	0.0	0.0	0.0	0.0	1,035.0	178.0	2,020.3	349.8	4,040.6	701.7	4,742.4	412,380.0
<b>5. Aeration Tank &amp; Membrane Bioreactor Facility</b>																											
5.1 Mesh screen																		11,500.0	230.0	11,500.0	230.0	23,000.0	460.0	23,000.0	460.0	23,460.0	2,040,000
5.2 Air diffuser for aeration tank																		7,567.0	5,405.0	7,567.0	5,405.0	15,134.0	10,810.0	25,944.0	2,256,000		
5.3 Blower for aeration tank																		20,700.0	207.0	20,700.0	207.0	41,400.0	414.0	41,400.0	414.0	41,814.0	3,636,800
5.4 Membrane unit																		248,400.0	2,760.0	248,400.0	2,760.0	496,800.0	5,520.0	993,600.0	11,040.0	1,004,640.0	87,360,000
5.5 Membrane filtration pump																		26,496.0	143.5	26,496.0	143.5	26,496.0	143.5	26,496.0	143.5	26,639.5	2,316,480
5.6 NaOCl pump for maintenance cleaning	883.2	99.4																883.2	99.4	883.2	99.4	2,649.6	298.1	3,532.8	397.4	3,930.2	341,760
5.7 NaOCl pump for recovering cleaning	1,104.0	110.4																1,104.0	110.4	1,104.0	110.4	3,312.0	331.2	4,416.0	441.6	4,857.6	422,400
5.8 Dilution water pump																		1,766.4	220.8	1,766.4	220.8	1,766.4	220.8	1,766.4	220.8	1,987.2	172,800
5.9 Blower for membrane scrubbing																		95,385.6	496.8	95,385.6	496.8	95,385.6	496.8	95,385.6	496.8	95,882.4	8,337,600
5.10 Circulation pump																		34,776.0	463.7	34,776.0	463.7	34,776.0	463.7	34,776.0	463.7	35,239.7	3,064,320
5.11 Excess sludge pump																		1,545.6	33.1	1,545.6	33.1	1,545.6	33.1	1,545.6	33.1	1,578.7	137,280
5.1 Miscellaneous	604.4	143.5																604.4	143.5	604.4	143.5	2,417.8	574.1	3,626.6	861.1	4,487.8	390,240
Sub-total	2,591.6	353.3	0.0	0.0	0.0	0.0	604.4	143.5	26,496.0	143.5	250,387.2	2,969.8	249,004.4	2,903.5	34,776.0	463.7	129,352.0	1,154.6	43,904.2	6,228.4	737,116.0	14,360.3	1,244,679.0	26,782.1	1,270,461.1	110,474,880	
<b>6. Dewatering &amp; Deodorization Facility</b>																											
6.1 Excess sludge mixer																		993.6	22.1	993.6	22.1	1,987.2	44.2	1,987.2	44.2	2,031.4	177,600
6.2 Excess sludge feed pump																		1,283.4	89.7	1,283.4	89.7	2,566.8	279.4	2,566.8	279.4	2,656.2	228,000
6.3 Dehydrator																		42,053.3	127.7	42,053.3	127.7	84,106.5	255.3	84,106.5	255.3	84,361.8	7,335,809
6.4 Deodorization equipment																		20,700.0	5,520.0	20,700.0	5,520.0	20,700.0	5,520.0	20,700.0	5,520.0	21,252.0	1,800,000
6.5 Miscellaneous																		103.5	27.6	103.5	27.6	207.0	55.2	207.0	55.2	207.6	18,000
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	21,693.6	5,542.1	1,283.4	89.7	0.0	0.0	0.0	0.0	42,053.3	127.7	42,156.8	155.3	107,187.0	5,914.7	107,325.0	5,942.3	113,267.3	9,849,329.0	
<b>7. Electrical Facility &amp; Control System</b>																											
7.1 GIS, Transformer																				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0
7.2 Generator																				17,084.4	690.0	17,084.4	690.0	17,084.4	690.0	17,774.4	1,545,600
7.3 Monitoring and control system																				10,350.0	4,140.0	10,350.0	4,140.0	17,250.0	6,900.0	24,150.0	2,100,000
7.4 Miscellaneous																				3,450.0	1,380.0	3,450.0	1,380.0	3,450.0	1,380.0	3,450.0	420,000
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	13,800.0	5,520.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	17,084.4	690.0	30,884.4	6,210.0	37,784.4	8,970.0	46,754.4	4,065,800	
Total(1-7)	2,591.6	353.3	0.0	0.0	690.0	276.0	604.4	143.5	63,518.0	11,386.4	259,636.0	3,944.7	256,953.2	3,786.7	42,131.4	601.7	194,243.3	2,786.9	157,177.0	9,878.0	977,545.0	33,157.3	1,494,850.8	47,875.9	1,542,726.7	134,150,149	
<b>8. Site Overhead</b>																											
5 % of sum of total 1 to 7	129.6	17.7	0.0	0.0	34.5	13.8	30.2	7.2	3,175.9	569.3	12,981.8	197.2	12,847.7	189.3	2,106.6	30.1	9,712.2	139.3	7,858.8	493.9	48,877.2	1,657.9	74,742.5	2,393.8	77,136.3	6,707,507	
<b>9. General Overhead</b>																											
10% of net replacement cost(sum of 1 to 8)	272.1	37.1	0.0	0.0	72.5	29.0	63.5	15.1	6,669.4	1,195.6	27,261.8	414.2	26,980.1	397.6	4,423.8	63.2	20,395.5	292.6	16,503.6	1,037.2	102,642.2	3,481.5	156,959.3	5,027.0	161,986.3	14,085,766	
<b>10. Total replacement cost</b>																											
the sum of 1 to 9	2,993.3	408.0	0.0	0.0	797.0	318.8	698.1	165.8	73,363.2	13,151.3	299,879.5	4,556.2	296,781.0	4,373.7	48,661.8	694.9	224,351.0	3,218.9	181,539.4	11,409.1	1,129,664.4	38,296.6	1,726,552.7	55,296.6	1,781,849.4	154,943,422	

# Appendix 4.8 Replacement Cost

## Appendix 4.8.2 Replacement Cost in Case 2 (Year 1st to 10th)

Items	1st year		2nd year		3rd year		4th year		5th year		6th year		7th year		8th year		9th year		10th year		Sub-total		
	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	
<b>1. Lift Pumping Facility</b>																							
1.1 Inflow Gate																					0.0	0.0	
1.2 Coarse screen																					0.0	0.0	
1.3 Fine screen																					0.0	0.0	
1.4 Lift pump																					0.0	0.0	
1.5 Flow meter																					0.0	0.0	
1.6 Hoist																					0.0	0.0	
1.7 Pump up well connection gate																					0.0	0.0	
1.8 Miscellaneous																					331.2	82.8	
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	331.2	82.8	331.2	82.8
<b>2. Grit Chamber Facility</b>																							
2.1 Grit collector																					0.0	0.0	
2.2 Grit lifting pump																					0.0	0.0	
2.3 Air blower																					0.0	0.0	
2.4 Miscellaneous																					79.5	11.6	
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	79.5	11.6	0.0	0.0	79.5	11.6
<b>3. Equalization Tank Facility</b>																							
3.1 Constant rate pump																					0.0	0.0	
3.2 Mixer for antisepting																					0.0	0.0	
3.3 Ultra fine screen																					0.0	0.0	
3.4 Miscellaneous																					0.0	0.0	
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
<b>4. Disinfection Facility</b>																							
4.1 Sodium hypochlorite storage tank										331.2	66.2									331.2	66.2	662.4	132.5
4.2 Sodium hypochlorite dosing pump										153.2	18.6									153.2	18.6	306.4	37.3
4.3 Miscellaneous												16.6	2.1							16.6	2.1	33.1	4.1
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	484.4	84.9	16.6	2.1	0.0	0.0	0.0	0.0	0.0	0.0	500.9	86.9	1,001.9	173.9	
<b>5. Aeration Tank &amp; Membrane Bioreactor Facility</b>																							
5.1 Mesh screen																					0.0	0.0	
5.2 Air diffuser for aeration tank																					3,783.5	2,702.5	
5.3 Blower for aeration tank																					0.0	0.0	
5.4 Membrane unit																248,400.0	2,760.0				248,400.0	2,760.0	
5.5 Membrane filtration pump																					0.0	0.0	
5.6 NaOCl pump for maintenance cleaning																441.6	49.7				441.6	49.7	
5.7 NaOCl pump for recovering cleaning																					0.0	0.0	
5.8 Dilution water pump																					0.0	0.0	
5.9 Blower for membrane scrubbing																					0.0	0.0	
5.10 Circulation pump																					0.0	0.0	
5.11 Excess sludge pump																					0.0	0.0	
5.1 Miscellaneous												201.5	71.8							201.5	71.8	403.0	143.5
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	201.5	71.8	0.0	0.0	248,841.6	2,809.7	0.0	0.0	3,985.0	2,774.3	253,028.1	5,655.7	
<b>6. Dewatering &amp; Deodorization Facility</b>																							
6.1 Excess sludge mixer																					0.0	0.0	
6.2 Excess sludge feed pump																					0.0	0.0	
6.3 Dehydrator																					0.0	0.0	
6.4 Deodorization equipment																					0.0	0.0	
6.5 Miscellaneous																					138.0	27.6	
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	138.0	27.6	138.0	27.6
<b>7. Electrical Facility &amp; Control System</b>																							
7.1 GIS, Transformer																					0.0	0.0	
7.2 Generator																					0.0	0.0	
7.3 Monitoring and control system																6,900.0	2,760.0				6,900.0	2,760.0	
7.4 Miscellaneous																					0.0	0.0	
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6,900.0	2,760.0	0.0	0.0	0.0	0.0	6,900.0	2,760.0	
Total(1-7)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	484.4	84.9	218.0	73.8	0.0	0.0	255,741.6	5,569.7	79.5	11.6	4,955.1	2,971.6	261,478.6	8,711.6	
<b>8. Site Overhead</b>																							
5% of sum of total 1 to 7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24.2	4.2	10.9	3.7	0.0	0.0	12,787.1	278.5	4.0	0.6	247.8	148.6	13,073.9	435.6	
<b>9. General Overhead</b>																							
10% of net replacement cost(sum of 1 to 8)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	50.9	8.9	22.9	7.8	0.0	0.0	26,852.9	584.8	8.3	1.2	520.3	312.0	27,455.3	914.7	
<b>10. Total replacement cost</b>																							
the sum of 1 to 9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	559.5	98.0	251.8	85.3	0.0	0.0	295,381.5	6,433.0	91.8	13.4	5,723.2	3,432.2	302,007.8	10,061.9	

# Appendix 4.8 Replacement Cost

## Appendix 4.8.2 Replacement Cost in Case2 (Year 11th to 20th and Total)

Items	11th year		12th year		13th year		14th year		15th year		16th year		17th year		18th year		19th year		20th year		Sub-total		Total					
	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC (Mil. Rp.)	LC (Mil. Rp.)	FC+LC (Mil. Rp.)	FC+LC (Equiv. to USD)		
<b>1. Lift Pumping Facility</b>																												
1.1 Inflow Gate																						0.0	0.0	0.0	0.0	0.0	0	
1.2 Coarse screen																		345.0	115.0			345.0	115.0	460.0		460.0	40,000	
1.3 Fine screen																		2,530.0	161.0			2,530.0	161.0	2,691.0		2,691.0	234,000	
1.4 Lift pump																		22,770.0	1,035.0			22,770.0	1,035.0	23,805.0		23,805.0	2,070,000	
1.5 Flow meter					414.0	165.6												414.0	165.6			828.0	331.2	1,159.2		1,159.2	100,800	
1.6 Hoist																		0.0	0.0			0.0	0.0	0.0		0.0	0	
1.7 Pump up well connection gate																		0.0	0.0			0.0	0.0	0.0		0.0	0	
1.8 Miscellaneous																		552.0	138.0			552.0	138.0	690.0		690.0	96,000	
Sub-total	0.0	0.0	0.0	0.0	414.0	165.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3,427.0	414.0	23,184.0	1,200.6	27,025.0	1,780.2	27,356.2	1,863.0	29,219.2	2,540,800	
<b>2. Grit Chamber Facility</b>																												
2.1 Grit collector																		2,967.0	118.7			2,967.0	118.7	3,085.7		3,085.7	268,320	
2.2 Grit lifting pump																		469.2	30.4			469.2	30.4	500.0		500.0	43,440	
2.3 Air blower																		993.6	60.0	993.6	60.0	993.6	60.0	1,053.6		1,053.6	91,620	
2.4 Miscellaneous																		106.0	15.5			106.0	15.5	121.5		121.5	18,480	
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3,542.2	164.5	993.6	60.0	4,065.8	224.5	4,615.3	236.1	4,851.4	421,860	
<b>3. Equalization Tank Facility</b>																												
3.1 Constant rate pump																					7,590.0	531.3	7,590.0	531.3	8,121.3		8,121.3	706,200
3.2 Mixer for antisepting													7,948.8	883.2				7,948.8	883.2			15,897.6	1,766.4	17,664.0		17,664.0	1,536,000	
3.3 Ultra fine screen																		7,355.4	138.0			7,355.4	138.0	7,493.4		7,493.4	651,600	
3.4 Miscellaneous																		447.7	8.8			447.7	8.8	456.5		456.5	39,696	
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	447.7	8.8	7,948.8	883.2	0.0	0.0	0.0	0.0	7,355.4	138.0	15,538.8	1,414.5	31,290.7	2,444.5	31,290.7	2,444.5	33,735.2	2,933,496	
<b>4. Disinfection Facility</b>																												
4.1 Sodium hypochlorite storage tank					331.2	66.2												331.2	66.2			331.2	66.2	397.4		397.4	207,360	
4.2 Sodium hypochlorite dosing pump					153.2	18.6												153.2	18.6			153.2	18.6	172.8		172.8	89,640	
4.3 Miscellaneous																		66.2	8.3			66.2	8.3	74.5		74.5	13,440	
Sub-total	0.0	0.0	484.4	84.9	0.0	0.0	0.0	0.0	484.4	84.9	16.6	2.1	484.4	84.9	0.0	0.0	0.0	550.6	93.2	2,020.3	349.8	3,022.2	523.7	3,545.9		3,545.9	308,340.0	
<b>5. Aeration Tank &amp; Membrane Bioreactor Facility</b>																												
5.1 Mesh screen																					11,500.0	230.0	11,500.0	230.0	11,730.0		11,730.0	1,020,000
5.2 Air diffuser for aeration tank																		3,783.5	2,702.5			3,783.5	2,702.5	6,486.0		6,486.0	562,000	
5.3 Blower for aeration tank																		20,700.0	103.5			20,700.0	103.5	20,803.5		20,803.5	1,809,800	
5.4 Membrane unit																		248,400.0	2,760.0	248,400.0	2,760.0	496,800.0	5,520.0	502,320.0		502,320.0	43,200,000	
5.5 Membrane filtration pump																		13,248.0	71.8			13,248.0	71.8	13,319.8		13,319.8	1,158,240	
5.6 NaOCl pump for maintenance cleaning																		883.2	99.4			883.2	99.4	982.6		982.6	85,440	
5.7 NaOCl pump for recovering cleaning																		552.0	55.2			552.0	55.2	607.2		607.2	52,800	
5.8 Dilution water pump																		883.2	110.4			883.2	110.4	993.6		993.6	86,400	
5.9 Blower for membrane scrubbing																		47,692.8	248.4			47,692.8	248.4	47,941.2		47,941.2	4,168,800	
5.10 Circulation pump																		17,388.0	231.8			17,388.0	231.8	17,619.8		17,619.8	1,532,160	
5.11 Excess sludge pump																		772.8	16.6			772.8	16.6	789.4		789.4	68,640	
5.1 Miscellaneous																		604.4	143.5			604.4	143.5	747.9		747.9	65,160	
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	261,648.0	2,831.8	250,439.6	3,058.1	0.0	0.0	21,171.5	2,934.3	48,576.0	358.8	37,655.1	3,229.2	619,490.3	12,412.2	631,902.5	18,067.9	650,000.4	56,242,280		
<b>6. Dewatering &amp; Deodorization Facility</b>																												
6.1 Excess sludge mixer																					496.8	11.0	496.8	22.1	507.8		507.8	44,280
6.2 Excess sludge feed pump																		641.7	44.9			641.7	44.9	686.6		686.6	59,760	
6.3 Dehydrator																		42,053.3	127.7			42,053.3	127.7	42,181.0		42,181.0	3,667,905	
6.4 Deodorization equipment																		20,700.0	5,520.0			20,700.0	5,520.0	26,220.0		26,220.0	2,280,000	
6.5 Miscellaneous																		103.5	27.6			103.5	27.6	131.1		131.1	11,520	
Sub-total	0.0	0.0	0.0	0.0	21,196.8	5,531.0	0.0	0.0	0.0	0.0	641.7	44.9	0.0	0.0	0.0	0.0	0.0	42,653.6	166.3	64,492.1	5,742.2	64,630.1	5,769.8	70,399.9		70,399.9	6,121,724.5	
<b>7. Electrical Facility &amp; Control System</b>																												
7.1 GIS, Transformer																					0.0	0.0	0.0	0.0	0.0		0.0	0
7.2 Generator																		17,084.4	690.0			17,084.4	690.0	17,774.4		17,774.4	1,545,600	
7.3 Monitoring and control system																		10,350.0	4,140.0			10,350.0	4,140.0	14,490.0		14,490.0	1,248,000	
7.4 Miscellaneous																		3,450.0	1,380.0			3,450.0	1,380.0	3,830.0		3,830.0	328,800	
Sub-total	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	13,800.0	5,520.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	17,084.4	690.0	30,884.4	6,210.0	37,784.4	8,970.0	46,754.4		46,754.4	4,065,800	
Total(1-7)	0.0	0.0	484.4	84.9	21,610.8	5,696.6	0.0	0.0	276,380.1	8,445.5	259,046.7	3,988.2	484.4	84.9	21,171.5	2,934.3	62,900.6	1,075.3	137,660.1	6,853.8	779,738.5	29,163.4	1,041,217.1	37,875.0	1,079,092.2		1,079,092.2	93,834,101
<b>8. Site Overhead</b>																												
5 % of sum of total 1 to 7	0.0	0.0	24.2	4.2	1,080.5	284.8	0.0	0.0	13,819.0	422.3	12,952.3	199.4	24.2	4.2	1,058.6	146.7	3,145.0	53.8	6,883.0	342.7	38,986.9	1,458.2	52,060.9	1,893.8	53,954.6	4,691,705		
<b>9. General Overhead</b>																												
10% of net replacement cost(sum of 1 to 8)	0.0	0.0	50.9	8.9	2,269.1	598.1	0.0	0.0	29,019.9	886.8	27,199.9	418.8	50.9	8.9	2,223.0	308.1	6,604.6	112.9	14,454.3	719.6	81,872.5	3,062.2	109,327.8	3,976.9	113,304.7	9,852,581		
<b>10. Total replacement cost</b>																												
the sum of 1 to 9	0.0	0.0	559.5	98.0	24,960.5	6,579.6	0.0	0.0	319,219.0	9,754.5	299,198.9	4,606.4	559.5	98.0	24,453.1	3,389.2	72,650.2	1,242.0	158,997.4	7,916.1	900,598.0	33,683.8	1,202,605.8	43,745.6	1,246,351.4	108,378,386		