

Japan International Cooperation Agency

**National Power Transmission Network
Development Project
in Myanmar
(Power Network System Plan)
Project Completion Report**

May 2015

Tokyo Electric Power Company Inc.

Contents

Chapter 1.	Introduction	1
Chapter 2.	Situations of Land Acquisition	3
Chapter 3.	Confirmation of the Latest Plans of Power Generation, Transmission lines and Substation	8
Chapter 4.	Power Flow Analysis for the 500 kV System of Phase 2 and 230 kV system in around Yangon	13
Chapter 5.	Recommendations for Future Power System Configuration	30
<Appendix 1>	Questionnaire for the Counterparts during the First Site Survey	
<Appendix 2>	Presentation Material for Explanation of Power System Plan to the Counterparts during the Second Site Survey	
<Appendix 3>	Main Part of the Data for Power System Analysis of Base Case	
<Appendix 4>	Option of the System Configuration with 230 kV Interconnection between East and West and the Eastern 500 kV Substation around Yangon	

Chapter 1. Introduction

1.1 Member of the Mission and His Duty

Masaharu Yogo, TEPCO, Power System Planner

1.2 Name of the Project

National Power Transmission Network Development Project in Myanmar

1.3 Purpose of this Investigation

Myanmar government cited the development of 500 kV transmission lines and substations as a matter of priority and issued a request of their development by utilizing yen loan. According to the request, the Japanese Government informed Myanmar government of a new yen loan project as the donor policy on March 24, 2014 targeting “National Power Transmission Network Development Project Phase 1” in Myanmar. Furthermore, following the Phase 1, the rapid development of Phase 2 are also needed. In this survey, engaged member will carry out the supplementary investigation in cooperation with his counterpart, the Myanmar Electric Power Enterprise, in order to examine and recommend the appropriate power system plan for preparation of yen loan project by collecting and organizing the relevant information based on the current plans and implementation of the transmission lines and substation projects by Myanmar Government, power generation plans utilizing IPP and the support planning and implementation status of other donors.

1.4 Methodology of Investigation

The necessary investigation has been carried out for making the reports required for yen loan appraisal regarding the power system plans of Myanmar by collecting its relevant information and reviewing them through the discussion with JICA Staff and Social & Environmental Specialist who has been also assigned in this task.

1.5 Work Schedule

Contract term: from January 16, 2015 to May 29, 2015

The First Site Survey: From January 18, 2015 to January 28, 2015

The Second Site Survey: From March 16, 2015 to March 21, 2015

1.6 Survey in Myanmar

On January 19, 21 and 22, 2015, the relevant information was collected through the

discussion with Power Transmission Project Department of MEPE and DEP based on the questionnaire listed in Appendix 1.

On January 26, the site surveys of future locations of Phayargyi and Hlaingtayar substations were carried out to confirm the latest situations regarding “Phase 2 Project”. On March 18 and 19, the mission team had a meeting with MEPE’ engineers to discuss the cost of the transmission lines and explain the some recommendations for power network system plan. The following sections describes the relevant information and the results of the study of the power system plans.

Chapter 2. Situations of Land Acquisition

2.1 500 kV Phayargyi Substation

During the first site investigation, it was found out that the location of the candidate site of 500 kV Phayargyi Substation had been moved to the outside of the military land by around 1 km in the south direction because the permission for its land usage had not been given by the military. The new site is a plane land without any hats or buildings, but with containing a wet land even in dry seasons. The 500 kV switch yard will be installed in the north and the 230 kV switch yard will be installed in the south where 230 kV transmission lines will be derived. The route of the transmission line from the original Pharyargyi substation to Hlaingtayar substation has not been changed from the results of the study in 2014. However, the new additional route from the new candidate site to the original site has to be required. The new route has no hats or buildings.

During the second site investigation, it was found out that the location of the candidate site of 500 kV Pharyargyi was moved to the north by around a hundred meter. The situations of the candidate sites of Pharyargyi are depicted in Figure 1 and 2.

2.2 500 kV Hlaingtayar Substation

During the first investigation, it can be found out that the land for the new 500 kV Hlaingtayar Substation was owned by seven households. The six of them had been already paid for land provision, however, one of them would not enter into negotiations with MEPE and it seemed difficult to negotiate him. Lacking of his land would increase in the cost of substation because it requires compact facilities such as Gas Insulated Switchgears (GIS). Thus, the new additional land acquisition neighbor to the original land in the east direction was proposed and MEPE was expected to study its adequacy. (Figure 3) The candidate site is a plain land with only a small hut utilized for agricultural works. The 500 kV switch yard will be installed in the north and the 230 kV switch yard will be installed in the south.

During the second site survey, it was found out that the land depicted in Figure 4 had been acquired.




Figure 1 New Location of 500 kV Phayargyi Substation




Figure 2 Land of 500 kV Phayargyi Substation (Google earth)




Figure 3 Land of Hlaingtaryar




Figure 4 Land of Hlaingtaryar (Google earth)

Chapter 3. Confirmation of the Latest Plans of Power Generation, Transmission lines and Substation

3.1 Power Demand Forecast and Power Generation Plan

The maximum electric power demand during the peak demand period of time (from March to May) in 2015 was forecasted as 1,500 MW for Yangon and 2,500 MW for the system of the whole country. From 2015, the yearly growing ratio of the maximum power demand is expected over 15%. DEP expressed an opinion that the latest demand forecast was the result of its study of the JICA Master Plan. The total generation capacity of Yangon city is currently 370 MW and expected to become 800 MW at the end of 2015.

3.2 Plan of 230 kV Transmission Lines and Substations in Yangon

MEPE planned 230 kV transmission lines and substations in Yangon as shown in the following table.

Table 1 Project Plan for Yangon Division

No.	Name of Projects	Expected Fund
1.	230 kV Ahlone-Thidar Transmission Line & Substation	China Exim Bank
2.	230 kV Tharkata-Kyaikasan Transmission Line & Substation	ADB
3.	230 kV Tharkata -Thidar Transmission Line	ADB
4.	230 kV Ahlone Dala Transmission Line & Substation	MEPE
5.	230 kV (Hlawga-Tharketa) In/Out Transmission Line & South Oakkalar Substation	MEPE
6.	230/66/11 kV, (2x125) MVA Bayintnaung Substation Extension	Deferred
7.	230/33 kV, (2x100) MVA West University Substation	Deferred

The number of circuits between Ahlone - Thidar was assumed two and Thidar - Thaketa single in this study according to the ADB's Report "TA 8342 MYA Preparing the Power Transmission and Distribution Improvement Project" by Fichtner".

The comments raised for the abovementioned list was as follows.

- All the projects were under discussion in the similar situation as "National Power Transmission Network Development Project Phase 2". However, MEPE hoped to complete all the project within two years. That was expected to be completed by the end of 2018.
- The 230 kV Ahlone-Dala transmission line listed in the number 4 probably to be carried out using its own funds of MEPE because the length of this transmission line was very short.
- Bayintnaung substation listed in 6 was expected to be completed in 2017 because this project contained just the expansion of substation.

- The projects of “Deferred” were still opened to the tenders.

The following comments were raised for the Project that were not listed in Table 1.

- The completion year was uncertain of 500 kV Phayargyi - Dawei transmission line because it depended on the plan of the Dawei power station.
- Shweli 3 was scheduled to be completed in 2020. There was an enterprise company that expressed an interest in the installation of 500 kV transmission line from Shweli 3 to Meiktila and said that he might implemented.
- The survey of the transmission line from Mawlamyine to Dawei has been asked to China Exim Bank. Dawei would have large power demand forecast due to its SEZ.

3.3 Transmission Lines connected to New 500 kV Substations of Phase 2 Project just after their completion

According the information gathered during the first site survey, MEPE said that there were no changes from the results of the study in 2014 of the transmission line connection to new 500 kV substations of Phase 2 Project.

However, some 230 kV transmission lines connected to 500 kV substations were changed. Those should be confirmed at the stage of detailed design.

Current status of the progress of 230 kV transmission line connection to 500 kV substations are as follows.

- 500 kV Pharyargyi Substation

In 2019, the 500 kV Pharyargyi substation will be connected to the newly constructed 230 kV transmission line between Tharyargone - Kamarnat where 500 kV Pharyargyi substation is located in the middle of the line. The transmission line between Pharyargyi and East Dagon was not yet decided, however, it would take normally only three years from its plan to its operation in MEPE.

- 500 kV Hlaingtyar Substation

As mentioned later, 230/33 kV West University substation will be constructed in the same location as 500 kV Hlaingtyar Substation by ADB. 230/33 kV West University substation will collect the existing transmission line from Mayungtagar - 230 kV Hlaingtyar. 500 kV Hlaingtyar Substation will be installed as the expanded substation of 230/33 kV West University.

3.4 Main Specifications of Phase 2

The mission team had discussions with Power Transmission Project Department of MEPE regarding the main specifications of Phase 2 Project based on the previous study in 2014.

No main specifications had been changed except for pollution level of insulators.

- MEPE hoped to apply the heavy pollution level to the route around 4 to 5 km before reaching 500 kV Hlaingtayar substation. On the other hand, the light pollution level was recommended to be applied for the whole of the transmission line routes by JICA team side based on the site survey in the 2014 previous study and this study. The applied pollution levels should be discussed with MEPE during the detailed design stage.
- MEPE raised a comment that they hoped to know the O&M methodology for Oil Forced Cooling System to maintain its better insulation. (Some know-hows are considered such as Dissolved Gas Analysis and Reduce Oil Circulator Speed)

3.5 Reviewing ADB's Report (by Fichtner)

The ADB's report "ADB - TA 8342 MYA Preparing the Power Transmission and Distribution Improvement Project" (Fichtner, Feb.2015) has been reviewed unofficially by the mission team (not through MEPE).

The demand forecast of ADB's Report was a little bit lower than that of JICA Master Plan as follows.

- The maximum demand for the whole system in ADB's Report
Year 2020: 3,728 MW, Year 2030: 7,498 MW
- The maximum demand for the whole system in JICA Master Plan
Year 2020: High Case 4,531 MW, Low Case 3,862 MW
Year 2030: High Case 14,542 MW, Low Case 9,100 MW

The following projects in around Yangon were recommended in the ADB's report.

Thida - Thaketa TL, Thaketa SS (extension), Thaketa - Kyaikasan, Kyaikasan SS (new), South Oakkalarpa SS (new), West University SS (new)

The 230/33kV West University Substation that is listed above, was not informed in Table 1. However, this substation would have an effect on the Phase 2 Project because the ADB report described this substation was to be installed at the same location of 500 kV Hlaingtayar substation of Phase 2. JICA mission team had a discussion with MEPE regarding this substation.

3.6 230/33kV West University Substation

MEPE informed that The 230/33 kV West University Substation was planned to be installed

at the same land as the candidate site of the 500 kV Hlaingtayar Substation and the bus bars of 230/33 kV West University Substation would be expanded and connected to the 500 kV Hlaingtayar substation. Its implementation schedule was not yet decided.

Points to note regarding the connection of the 230/33 kV West University Substation and the 500 kV Hlaingtayar Substation are as follows.

(The design of both projects should be coordinated regarding the methodology of the expansion of 230/33 kV West University Substation to 500 kV Hlaingtayar substation at the detailed design stage.)

- The layout of the facilities of the foregoing ADB 230 kV West University substation should be necessarily incorporated with the future layout of Phase 2 500 kV Hlaingtayar Substation.
- It is necessary to study the treatment of the protection relays and supervisory control system of the foregoing ADB 230 kV West University Substation when Phase 2 500 kV Hlaingtayar substation will be installed. Generally, it is not enough for connection of bus bars not only by the connection of bus bars itself. It also requires for changing the connection of the information-telecommunication system utilized for supervisory control system in the substation. (such as the selection of the locations of control rooms for both old and new substations or the selection of the protection scheme against bus fault)

In case of difficulties, an option can be considered that connects new and old buses by installation of the circuit breakers between them to ensure their independent operation as shown in the following figure.




Figure 5 Covering areas of 230/33 kV West University Substation and 500/230 kV Hlaingtayar Substation

3.7 Prioritized Projects of Transmission Lines and Substations Except for the System from 500 kV Taungoo – Hlaingtayar

MEPE identified the study of the plan of the transmission lines from the hydropower stations located in the north of Meiktila substation as the prioritized projects.

3.8 Institutional Structure for O&M

Currently, there are fourteen Transmission Line Offices with 137 staffs per office on the average. One office maintains 700 – 800 km of lines by 30-40 persons. Safety trainings are held by Administration Office.

Chapter 4. Power Flow Analysis for the 500 kV System of Phase 2 and 230 kV system in around Yangon

4.1 500kV and 230kV System in around Yangon

Figure 3 shows the plan of the 500 kV and 230 kV power network system in around Yangon around 2020 after Phase 2 500 kV Project will be completed based on the information from MEPE.

The 230 kV system of Yangon will be divided into east and west, where eastern system will have Hlawga, East Dagon, Thaketa and Thanlyin and western system will have Hlaingtayar, Ywama, Bayintnaun and Ahlone. There will be no direct interconnection of 230 kV between them.

Two 500 MVA transformers of 500/230 kV will be installed in Phayargyi and Hlaingtayar respectively.




Figure 6 500 kV and 230 kV System in around Yangon around 2020

4.2 Load Forecast for 230 kV Substations in Yangon in 2020

The maximum power demand of Yangon in 2020 was set out as 2,869 MW from the result of JICA Master Plan Study. The insufficient energy will be taken from the outside of this area at Myaungtagar, Payargyi and Kamarnat substations and the amount of its required energy will be determined only by the power demand supply balance in Yangon. The power generation plan outside of Yangon was used as the plan obtained in the study in 2014. Loads of 230 kV substations in Yangon were set out as follows.

- There are two ways of power supply from 230 kV substations, one is by 66 kV and another is 33 kV. Thus, the amount of loads of 230 kV substations has to be divided into loads of 66 kV system and 33 kV system. The maximum power demand in 2014 was 917 MW in Yangon. Around 40% (372 MW) was allocated to 66 kV system and around 60% (545 MW) was allocated to 33 kV system based on the current power supply information.
- The growing ratio of the maximum power demand in Yangon was assumed 20% per year for the first 5 years and 10% for the next 5 years and the growing ration of the maximum power demand of 33 kV system was assumed only 4% because the loads of 33 kV system were planned to be gradually switched to 66 kV based on the information obtained from YESB last year. This maximum power demand can be depicted as shown in Figure 7 that lies at the middle point between the high case and the low case in 2020 estimated in JICA Master Plan. The high case maximum power demand of JICA Master Plan was applied as the maximum power demand of this study for 2020.




Figure 7 Maximum Power Demand Forecast in Yangon

- The ratio of the allocated load of 66 kV system was 72.5 % and 33kV system was 27.5%. Using those ratios, the maximum power demand of 66 kV system was calculated as around 2,081 MW and 33 kV was around 788 MW for 2020 based on the high case demand of

JICA Master Plan, 2,869 MW in 2020.

- The capacities of the facilities of 230 kV substations in Yangon in 2020 were estimated as shown in the following table. The information about the expansion of Ahlone, Thakheta, Thanlyin and Iwama was obtained at the end of 2014. It was found out that the 66 kV system could have around 2,200 MW and the 33 kV system around 1,300 MW according to the following table assuming 90% as the power factor of transformers and 80% as the power supply ability ratio to the capacities of the transformers and generators.

Table 2 Capacities of facilities at 230/66 kV Substations

230/66 kV Substation	66 kV Power Supply Facilities	Existing Capacities	Estimated Capacities After Expansion
Ahlone	66 kV Gen.	194 MW	
	230/66 kV Trans.	2 x 100 MVA	3 x 100 MVA
Bayintnaung	230/66 kV Trans.	100 MVA	2 x 125 MVA
Hlawga	230/66 kV Trans.	60 MVA	
Thakheta	66 kV Gen.	84 MW	
	230/66 kV Trans.	2 x 100 MVA	3 x 100 MVA
Iwama	66 kV Gen.	50 MW	
	230/66 kV Trans.	-	2 x 125 MVA
East Dagong	230/66 kV Trans.	-	2 x 125 MVA
South Okkalapa	230/66 kV Trans.	-	2 x 125 MVA
Kyaikkasan	230/66 kV Trans.	-	2 x 125 MVA
Thida	230/66 kV Trans.	-	2 x 125 MVA
Tilawa	66 kV Gen.	50 MW	
	230/66 kV Trans.	-	2 x 100 MVA

Table 3 Capacities of facilities at 230/33 kV Substations

230/33 kV Substation	33 kV Power Supply Facilities	Existing Capacities	Estimated Capacities After Expansion
Ahlone	66/33 kV Trans.	60 MVA	
	33 kV Gen.	100 MVA	
Hlaingtharyar	230/33 kV Trans.	2 x 100 MVA	
Hlawga	230/33 kV Trans.	3 x 100 MVA	
	33 kV Gen.	210 MVA	
Thanlyin	230/33 kV Trans.	100 MVA	2 x 100 MVA
Wartayar	230/33 kV Trans.	100 MVA	
Thakheta	230/33 kV Trans.	100 MVA	
	33 kV Gen.	50 MVA	
Iwama	33 kV Gen.	36 MVA	
West University	230/33 kV Trans.	2 x 100 MVA	

- The maximum load of around 2,081 MW for 66 kV system and the maximum load of around 788 MW for 33 kV system were assumed to be supplied from 230 kV substations in proportion to their power supply capacities. The estimated loads of 230 kV substations were listed as Table 4.

Table 4 Maximum Power Demand Forecast for 230 kV Substations in 2020

66 kV	Load (MW)	33 kV	Load (MW)
Ahlong	391	Ahlong	84
Bayintnaung	189	Hlaingtharyar	99
Hlawga	45	Hlawga	263
Thakheta	298	Thanlyin	99
Iwama	231	Wartayar	49
East Dagong	189	Thakheta1	38
South Okkalapa	189	Thakheta2	38
Kyaikkasan	189	Iwama	20
Thida	189	West University	99
Tilawa	168	Total	788
Total	2,081		

The demand forecast apart from Yangon area was allocated based on the PSSE model used in “JICA Expert for Strengthening of Implementation Capacity for Transmission Line and Substation (2013)”, however, the power demand of Yangon area was revised according to the results of JICA Master Plan and the power system plan of Yangon was updated according to the latest information. The system in the north and the east of Paryagyi and the north and the east of Hlaingtharyar was modeled based on the previous data, however, the system model of the PSSE software by those information is considered enough for the analysis for this study because the system in around Yangon was reviewed reflecting the latest information. The following table shows the comparison of the demand forecasts between this Study and JICA Expert Study in 2013.

Power Demand Data of PSS/E used in JICA Expert Study in 2013

Yangon Total	Other areas	Whole system
1749.374 MW	5686.009 MW	3936.635 MW

Power Demand Data of PSS/E used in this study

Yangon Total	Other areas	Whole system
2869.0001 MW	6529.0927 MW	3660.0926 MW

4.3 Power Generation and Conductor of 230 kV Transmission Line

The power generators in around Yangon area were set out as shown in Table 5. The numerical values of power outputs from Thaketa, Ahlone, Ywama and Hlawga were used that were also used in the previous study.

Table 5 Power Outputs of Generators in around Yangon Area in Base Case

Power Stations	In service	Out of service
Tilawa	50 MW	0 MW
Thakheta	92.2 MW	0 MW
Ahlone	278.4 MW	0 MW
Ywama	223.5 MW	0 MW
Hlawga	104.7 MW	51.1 MW
TWH Thailand	500 MW	0 MW
Ngayotekaung	540 MW	0 MW
Dawei	450 MW	0 MW

This case can be considered as the case with large power outputs of generators in around Yangon area. Thus, this case is the case with small power outputs from the hydropower stations located in the northern side of Myanmar.

The following two types of conductors are mainly used for 230 kV transmission lines in Myanmar.

- Twin bundle conductors of 605 MCM, its capacity is 288 MVA/cct
- Single conductor of 795 MCM and its capacity is 164 MVA/cct

The single of 795 MCM is used for Tharyargone - Hlawga that has a smaller capacity and the twin bundles of 605 MCM is mainly used for other intervals.

The ADB's Report that was mentioned in the previous section described the application of ACCC (Aluminum Conductor Composite Core) for the interval of Thida - Thaketa. This conductor can be used at high temperature with large capacity of 1,576 A (628 MVA) per circuit. Thus, only this interval was assumed to be equipped with this conductor.

(However, the ADB's report also mentioned that this conductor should not be applied for other intervals because it would produce huge losses when the power flow reached closed to its capacity.)

4.4 Base Case

The original plan of Yangon system by MEPE was analyzed with adding the model of part of the system of Yangon using PSS/E software that was also used in "JICA Expert for Strengthening of Implementation Capacity for Transmission Line and Substation". The

main part of the power system analysis data are listed in Appendix 3.

Figure 4 shows the results of power flow calculation of the 500 kV and 230 kV system in around Yangon around 2020 (base case).

According to the original plan made by MEPE, the power flow at the intervals of Hlaingtayar - Ahlon and Kyaiklat-Ahlon exceed the capacity of their transmission lines. Some interval of the 230 kV transmission lines become overloaded around Hlawga, East Dagon and Ahlon when the single circuit is dropped.




Figure 8 Power Flow for Base Case in 2020

4.5 Option of 230 kV Interconnection between East and West in Yangon around 2020

An option of the installation of the 230 kV transmission lines connecting the east and west in Yangon (they may be installed with underground cables due to their locations in a city area) is studied as a countermeasure against overloaded situations in Base Case.

This option assumes the installation of a single circuit between 230 kV Hlaingtayar and Bayintnaung and double circuits between Ywama and South Okkalar

The result of the calculation is shown in the following figure. Blue colored lines indicate newly installed transmission lines. There are no overloaded 230 kV transmission lines in normal operation although its overloaded situation still remains when a single circuit is dropped. Thus, this option can be recommended to avoid overloaded situations at normal operation.




Figure 9 Power Flow in the 230 kV System with East-West Interconnection

4.6 Cases without Phase 2 Project

The power flow was calculated in case of not implementing Phase 2 Project for Base Case. Ngayotekaung and Dawei thermal power stations were assumed to be still connected to 500 kV transmission lines because they were independent from Phase 2 Project.

This case assumed that Phase 1 and the transmission line from Meikhtila to Pharyargyi through Taungoo were implemented.

From the result of the power flow analysis, the power flows at Tharyargone - Hlawga and East Dagone-Thaketa exceeded the capacities of their lines apart from Hlaingtayar - Ahlon and Kyaiklat-Ahlon if Phase 2 was not implemented.




Figure 10 Power Flow in Case of Not Implementing Phase 2 Project for Base Case 2020

4.7 Effects on Loss Reduction of Transmission Lines by Phase 2 Project

The implementation of Phase 2 Project can reduce the loss of transmission lines. The loss of the 500 kV and 230 kV system in Myanmar in 2020 was calculated as shown in the following table.

Table 6 Difference of Transmission System Loss between Before and After Phase 2

Case	Myanmar 500 kV and 230 kV Transmission System Loss
Before Implementation	204.4 MW
After Implementation	179.9 MW
Difference (Effect on Loss Reduction)	24.5 MW
Annual Loss Reduction	64,386 MWh
Conversion for reduction of CO ₂ emission	45,933 tCO ₂ /Year

Annual loss reduction of the system and its conversion for CO₂ emission are estimated as 64,386 MWh and 45,933 tCO₂/year respectively by using the loss reduction of transmission lines at the maximum power demand assuming its annual loss factor 0.3.

- 0.7134 tCO₂/MWh* is used as CO₂ emission factor
 - *) Averaged Grid Emission Factor of China/Myanmar listed in “List of Grid Emission Factor” posted on the Web site of Institute for Global Environmental Strategies in Japan
<http://pub.iges.or.jp/modules/envirolib/view.php?docid=2136>
- Loss factor is often estimated by the following formula. Assuming Load Factor of 0.48 gives a Loss Factor of 0.3.
 Loss Factor = $k \times \text{Loss Factor} + (1-k) \times \text{Loss Factor}^2$ (where k is often used as 0.3 for transmission system and 0.2 for distribution system)

If Phayargyi - Hlaingtayar transmission line is operated at 230 kV, its transmission line loss is increased by 2.7 MW for Base Case according to the power system analysis.

4.8 Power Flow in Case of Lower Power Outputs from Thermal Power Stations in 2020 (Power output from Ngayotekaung in the west is zero)

The power flow would be increased from the northern area where a lot of hydropower stations will be located to Yangon in case of the lower power outputs from the thermal power stations in Yangon. The power flow was calculated for the both cases with and without Phase 2 setting out no power outputs from Ngayotekaung power station located in the west of Yangon. The power outputs were set out as follows.

Table 7 Power Outputs of Generators in around Yagon in Case of Lower Power Outputs from Thermal Power Stations in 2020 (Power output from Ngayotekaung in the west is zero)

Power Station	Operated Power Outputs	Stopping Power Outputs
Tilawa	50 MW	0 MW
Thakheta	92.2 MW	0 MW
Ahlong	278.4 MW	0 MW
Ywama	223.5 MW	0 MW
Hlawga	104.7 MW	51.1 MW
TWH Thailand	500 MW	0 MW
Ngayotekaung	0 MW	540 MW
Dawei	450 MW	0 MW

Figure 10 shows the power flow with Phase 2 in this generation pattern.

In the similar manner to the base case, the power flows between Hlaingtayar - Ahlon and Kyaiklat – Ahlon exceed their capacity of transmission lines. There are some intervals of 230 kV transmission lines that have the over loading power flow in case of a fault of a circuit around Hlawga, East Dagon and Ahlong.

Without Phase 2, the power flow calculation was not converged. This means that the power transmission is not possible at the maximum power demand without Phase 2. Its calculation was converged when the maximum power demand was decreased. The power flow became not to exceed the capacities of the transmission lines when the power demand of Yangon was decreased by around 28%. The Figure 11 shows the results of the power flow calculation for this case.




Figure 11 Case of Lower Power Outputs from Thermal Power Stations in 2020 (Power output from Ngayotekaug in the west is zero)




Figure 12 Case of Lower Power Outputs from Thermal Power Stations in 2020 (Power output from Ngayotekaug in the west is zero) without Phase 2 and decreasing power demand of Yangon by 28%

4.9 Recommendations for Power System Configuration in Yangon

The followings can be raised as the candidates of recommendations for power system configuration in Yangon.

- Implementation of 500 kV and 230 kV transmission lines and substations planned by MEPE including Phase 2 Project on schedule
- Installation of 230 kV transmission lines connecting the east and the west in Yangon through Ywama-S.Oakkalar and Bayintnaung-Kyaikasan and doubling circuits of Hlaingtayar-Bayintnaung and Thaketa-Kyaikasan up to around 2020. It will contribute to secure the power supply to the substations planned by MEPE responding to the rapid growing of power flow from the west to the east in Yangon.

For future power system, the followings can be recommended.

- When the maximum power demand of Yangon will reach 4,000 MW from 2,869 MW that is the maximum power demand of Yangon in 2020, it is considered that more substations at least four will be required even in consideration with the expansion of the existing substations.
- In future, Myanmar power system should become N-1 oriented system. The installation of the new 500 kV substation in the eastern part of Yangon in around East Dagon is recommended to supply power from the east to fulfill the N-1 criteria. (Appendix 4) In order to prepare this, the transmission line from Pharyargi to East Dagon is considered to be constructed as 500 kV design lines. The future 500 kV and 230 kV system in Yangon is shown in the following figure.
- The further detailed studies will be required regarding the future power system in Yangon including the 500 kV new substations and 230 kV new substations from the view point of their optimization.




Figure 13 Option of the Future 500 kV and 230 kV System in Yangon

<Appendix 1>

**Questionnaire for the Counterparts during the First
Site Survey**

Questionnaire (Power System Plan)

JICA 500 kV Phase 2

2015/01/19

M. YOGO, TEPCO

JICA Mission

Purpose of this Study

To carry out the supplementary survey to prepare the JICA appraisal mission of 500 kV Phase II Project by examining and recommending the adequate system plan through reviews of the latest information.

Questionnaire (Power System Plan)

1. The latest nationwide power demand forecast (Maximum power as MW) (also the latest power demand forecast in Yangon)
 2. The latest power generation plan and its on-going projects including their expected donors (also the latest power generation plan in around Yangon)
 3. The latest bulk power transmission line/substation plan and its on-going projects including their expected donors (also the latest 230 kV power transmission line/substation plan in around Yangon))
 4. The prioritized projects except for 500 kV Phase II
 5. Current situations and their main specifications of 500 kV Phase II
 6. Any significant changes in the route of 500 kV Hpharyargyi - Hlainghtaryar transmission line from the Previous Study?
 7. Are there any significant changes in the location of 500 kV Hpharyargyi and Hlainghtaryar substations from the Previous Study?
 8. Are there any significant changes in the main specifications of 500 kV transmission line from the Previous Study?
 9. Are there any significant changes in the main specifications of 500 kV Hpharyargyi and Hlainghtaryar substations from the Previous Study?
 10. Expected institutional arrangement for O&M
 11. Current progress and main specifications of Meikhtila-Taungoo –Pharyargyi 500 kV transmission lines
- JICA 500 kV Phase II Project means “500 kV Phatyargyi and Hleightayar substation and their connecting 500 kV transmission line”.
 - Previous Study means “JICA Expert for Strengthening of Implementation Capacity for Transmission Line and Substation, 2014”.

<Reference>

Main Specifications of the Phase II Project

500 kV Hpharyargyi - Hlaingtharyar transmission line

- Conductor: Drake four (4) bundles
- Pollution level “Light”
- Insulators made in Japan
- Clearances are same as 500 kV Meikhtila – Taungoo Transmission line

500 kV Hpharyargyi substation and 500 kV Hlaingtharyar substation

- Number of Feeders, Transformers and Reactors

	Hpayargyi	Hlaingtharyar
Number of 500 kV Line feeders	6 Taungoo: 2, Hlaingtharyar: 2, Dawei: 2 (Final 8)	4 Hpayargyi: 2, West Yangon: 2 (Final 8)
Number of 230 kV Line feeders	6 Tharyargone: 2, Kamarnat: 2, Dagon East: 2 (Final 12)	6 Myaungtagar: 1, Ywama: 2, Hlaingtharyar: 3 (Final 12)
Number of 500/230/11 kV Transformer banks	2 (Final 4)	2 (Final 4)
Reserved transformer (Single Phase)	1	1
Reactor (100 MVA)	2 (Final 4)	2 (Final 4)

- Specifications of the 500/230/11 kV Transformers

Type	Outdoor type single phase Auto transformer
Capacity	500/3MVA/500/3MVA/75/3MVA
Shipping Mass	Less than 60t (Actual limit weight should be studied in the Detailed Design stage, Site-assembly type would be recommended.)
%Impedance	12.5% (P-S)
Tap	±50 kV 21 tap
Cooling system	OFAF (Oil Forced Air Forced)

- Specification of the 500 kV Reactor

Type	Outdoor type single phase
Capacity	100/3MVA
Cooling system	ONAN (Oil Natural Air Natural)
Shipping Mass	Less than 60t(Actual limit weight should be studied in the Detailed Design stage)
Connected	Bus bar

➤ Telecommunication

Media	Object	Notes
OPGW	PCM current differential relay for transmission line protection	
	SCADA for National Control Center	
	High speed communication line in MEPE	For Intranet, VoIP
PLC	SCADA for National Control Center	For Backup
	Internal telephone line in MEPE	

- Circuit Breaker

500 kV H-GIS50 kA	50 kA
220 kV Gas Circuit Breaker	40 kA

- Protection relay system

500 kV Line	Main	Digital PCM current differential relay with high speed multi-phase re-closing relay system
	Back-up	Distance Relay (2-4 stage)
230 kV line	Main	Digital PCM current differential relay with high speed re-closing relay system
	Back-up	Distance Relay (2-4 stage)
500 kV and 230 kV bus		Current differential relay
Transformer	Main	Ratio Differential Relay, OCR, OCGR (Neutral Protection)
	Back-up	Distance Relay (2-4 stage)
500 kV Reactor		Ratio Differential Relay, OCR, OCGR (Neutral Protection)

- The selection of seismic design standards applied to the 500 kV transmission system in Myanmar should be discussed in the detailed design stage.
- SCS (Substation Control System) of each substation will be connected to the National Control Center (NCC) for the supervision and monitoring done by

<Appendix 2>

**Presentation Material for Explanation of
Power System Plan to the Counterparts
during the Second Site Survey**

Power System Analysis for 230 kV System in Yangon


M. YOGO, TEPCO

JICA Mission

March 2015


1

Existing 230 kV System in Yangon




2

Current 500kV&230 kV Yangon System Plan



3


Power Demand Forecast for Yangon




4

Some Recommendations for 2020-2025 System

5




Original plan in 2020





6

**Option 2
East Dagong 500 kV
substation**



8



Recommendaitons

- Current plans of 500 kV & 230 kV substations by MEPE including JICA Phase 2
- East-west 230 kV connections such as Ywama - N.Oakkalar & Bayintnaung-Kyaikasan by 2020
- After that, 500 kV East Dagong be constructed. (The 500 kV designed line can be considered for Payargyi-East Dagong)
- More 230 kV substations for future

11

Thank you.

12

<Appendix 3>

Main Part of the Data for Power System Analysis of Base Case

Transmission Line Data (1)

From Bus Number	From Bus	To Bus Number	To Bus Name	Id	Line R (pu)	Line X (pu)	Charging B (pu)	Length
1001	NPD33	1002	KBL33	1	0.329913	0.882484	0.00079	25
1001	NPD33	1002	KBL33	2	0.329913	0.882484	0.00079	25
1002	KBL33	1005	TPZ33	1	0.250734	0.670688	0.0006	19
1002	KBL33	1005	TPZ33	2	0.250734	0.670688	0.0006	19
1003	TYG33	1006	YNE33	1	0.361207	1.08041	0.00079	27.36
1003	TYG33	1006	YNE33	2	0.361207	1.08041	0.00079	27.36
1004	TGO33	1007	KAP33	1	0.701326	0.935362	0.00074	24.95
1004	TGO33	1007	KAP33	2	0.165005	0.831254	0.00084	24.95
1012	HLG33	1094	YWA33	1	0	0.0001	0	0
2001	TKT66	2002	THD66	1	0.017976	0.091329	0.00145	10.9
2001	TKT66	2002	THD66	2	0.017976	0.091329	0.00145	10.9
2001	TKT66	2017	SPM66	1	0.02708	0.13758	0.00218	16.42
2001	TKT66	2017	SPM66	2	0.02708	0.13758	0.00218	16.42
2002	THD66	2013	AHL66	1	0.007574	0.016757	0	6.5
2002	THD66	2013	AHL66	2	0.007574	0.016757	0	6.5
2003	BYN66	2015	SML66	1	0.010045	0.039656	0.0006	4.62
2003	BYN66	2015	SML66	2	0.010045	0.039656	0.0006	4.62
2003	BYN66	2017	SPM66	1	0.018436	0.072409	0.00111	8.48
2004	SHD66	2018	PYA66	1	0.037628	0.086691	0.00116	9.64
2006	ATB66	2007	ZGY66-1	1	0.277527	0.678753	0.00971	76.8
2006	ATB66	2031	KLW66	1	0	0.0001	0	0
2007	ZGY66-1	2019	ZGY66-2	1	0.053028	0.130624	0	13.4
2008	THT66	2009	PAN66	1	0.129079	0.315691	0.00452	35.72
2009	PAN66	2020	MLM66	1	0.208218	0.509241	0.00729	57.62
2010	KMN66	2021	ZTU66	1	0.163517	0.399916	0.00557	45.25
2011	OSP66	2037	MYN66	1	0.108288	0.055015	0.00871	65.66
2011	OSP66	2037	MYN66	2	0.108288	0.055015	0.00871	65.66
2012	N-BMW66	2014	N-NBA	1	0.428469	1.04791	0.01499	118.57
2013	AHL66	2015	SML66	1	0.010045	0.039656	0.0006	4.62
2014	N-NBA	2022	KPT66	1	0.267445	0.654095	0.00933	74.01
2014	N-NBA	2039	MHY66	1	0.223042	0.667139	0.007768	67.58
2031	KLW66	2044	U-BAL66	1	0.10621	0.317685	0.003699	32.18
2039	MHY66	2040	MGG66	1	0.30801	0.921287	0.010728	93.32
2040	MGG66	2041	MTY1_66	1	0.223042	0.667139	0.007768	67.58
2041	MTY1_66	2043	WGM66	1	0.159315	0.476528	0.005549	48.27
2045	SID66	2103	PON66	1	0.30801	0.921287	0.010728	93.32
2046	WZZ66	2047	GWL66	1	0.159315	0.476528	0.005549	48.27
2046	WZZ66	2050	HKK66	1	0.053105	0.158843	0.00185	16.49
3001	APL132	3015	SDG132	1	0.047465	0.121698	0.02173	48.6
3001	APL132	3016	TGD132	1	0.010294	0.026393	0.00471	10.54
3001	APL132	3023	APL BLN J	1	0.006838	0.015662	0.003506	7
3002	CHK132	3007	KCH132	1	0.039857	0.102191	0.01825	40.81
3002	CHK132	3010	MGW132	1	0.087357	0.263057	0.04756	105.96
3002	CHK132	3017	TNY132	1	0.01751	0.075269	0.01536	32.19
3002	CHK132	3017	TNY132	2	0.01751	0.075269	0.01536	32.19
3002	CHK132	3018	TZI132	1	0.140675	0.360687	0.06443	144.04
3003	KLW132	3014	PPT132	1	0.053146	0.165746	0.02792	64.41
3003	KLW132	3014	PPT132	2	0.052932	0.165077	0.02781	64.15
3003	KLW132	3019	TKY132	1	0.023192	0.064477	0.01368	28.15
3003	KLW132	3019	TKY132	2	0.023192	0.064477	0.01368	28.15
3003	KLW132	3033	YPS132	1	0.031414	0.087335	0.018534	38.13
3003	KLW132	3033	YPS132	2	0.031414	0.087335	0.018534	38.13
3004	LTP132-2	3028	BHP132	1	0.004378	0.013139	0.0024	5.31
3004	LTP132-2	3101	BAL-3_132	1	0.004773	0.014374	0.002599	5.79
3005	KTG132	3027	NMS132	1	0.098032	0.294207	0.05383	118.9
3005	KTG132	3027	NMS132	2	0.098032	0.294207	0.05383	118.9
3006	KDA132	3018	TZI132	1	0.039666	0.176084	0.03395	73.06
3006	KDA132	3026	ING132	1	0.045834	0.117516	0.02099	46.93
3007	KCH132	3013	NBG132	1	0.120888	0.362772	0.06637	146.61

Transmission Line Data (2)

From Bus Number	From Bus	To Bus Number	To Bus Name	Id	Line R (pu)	Line X (pu)	Charging B (pu)	Length
4003	HLG230	4215	N.OKKALAPA	1	0.000601	0.004038	0.012423	6.685
4004	HTY230	4008	MTG230	1	0.003818	0.02418	0.086078	42.49
4004	HTY230	4034	ATK230	1	0.010315	0.069304	0.21403	114.78
4004	HTY230	4035	BYN230	1	0.000998	0.006708	0.02064	11.11
4004	HTY230	4035	BYN230	2	0.000998	0.006708	0.02064	11.11
4004	HTY230	4044	AHL230	1	0.002016	0.013546	0.04183	22.43
4004	HTY230	4044	AHL230	2	0.002016	0.013546	0.04183	22.43
4004	HTY230	4108	KKL230	1	0.004339	0.027478	0.097817	48.28
4004	HTY230	4154	HTL230	1	0.000578	0.003663	0.01304	6.44
4004	HTY230	4154	HTL230	2	0.000578	0.003663	0.01304	6.44
4004	HTY230	4154	HTL230	3	0.000397	0.003302	0.011454	5.79
4004	HTY230	4235	THANTAPIN	1	0.001591	0.010687	0.032882	17.699
4004	HTY230	4250	KYAIKLATT	1	0.007447	0.050033	0.153947	82.864
4005	MSN230	4018	SSY230	1	0.017439	0.11044	0.3857	194.05
4005	MSN230	4018	SSY230	2	0.017439	0.11044	0.3857	194.05
4005	MSN230	4051	SHW230	1	0.00862	0.054591	0.19064	95.92
4005	MSN230	4051	SHW230	2	0.00862	0.054591	0.19064	95.92
4005	MSN230	4115	TIN230	1	0.008681	0.054978	0.195714	96.6
4006	LPT230	4014	SHM230	1	0.017355	0.10991	0.391266	193.12
4006	LPT230	4017	TGO230	1	0.020983	0.123341	0.21817	154.06
4006	LPT230	4152	TUG230	1	0.010775	0.089648	0.310991	157.28
4006	LPT230	4152	TUG230	2	0.010775	0.089648	0.310991	157.28
4007	KMN230	4008	MTG230	1	0.005781	0.038842	0.11995	64.33
4007	KMN230	4019	TLY230	1	0.00882	0.059101	0.18468	98.43
4007	KMN230	4029	SIT230	1	0.005278	0.035367	0.1114	58.9
4007	KMN230	4153	PYG230	1	0.003326	0.021062	0.074977	37.01
4007	KMN230	4153	PYG230	2	0.003326	0.021062	0.074977	37.01
4008	MTG230	4016	SHD230	1	0.018809	0.119119	0.424047	209.3
4008	MTG230	4016	SHD230	2	0.018809	0.119119	0.424047	209.3
4008	MTG230	4030	MHL230	1	0.012225	0.081923	0.256	136.44
4008	MTG230	4154	HTL230	2	0.00323	0.021646	0.068179	36.5
4008	MTG230	4235	THANTAPIN	1	0.001735	0.011658	0.035871	19.308
4008	MTG230	4245	WARTAYAR	1	0.001797	0.012076	0.037157	0
4009	PMN230	4010	NPT230	1	0.00184	0.012333	0.03885	20.54
4009	PMN230	4011	PLG230	1	0.000882	0.007337	0.025452	12.87
4009	PMN230	4011	PLG230	2	0.000882	0.007337	0.025452	12.87
4009	PMN230	4014	SHM230	1	0.004332	0.025755	0.04389	31.74
4009	PMN230	4024	TPU230	1	0.003752	0.022521	0.06511	35.98
4010	NPT230	4037	TDG230	1	0.00669	0.044829	0.1412	74.66
4011	PLG230	4053	NCO230	1	0.00347	0.021978	0.078237	38.62
4011	PLG230	4055	M-PLG230	1	0.004325	0.028983	0.09129	48.27
4013	OHT230	4027	NBG230	1	0.007883	0.050752	0.17088	87.59
4013	OHT230	4027	NBG230	2	0.007883	0.050752	0.17088	87.59
4013	OHT230	4119	NPD230	1	0.012146	0.076921	0.27383	135.16
4013	OHT230	4119	NPD230	2	0.012146	0.076921	0.27383	135.16
4014	SHM230	4038	TZI230	1	0.014054	0.083554	0.14239	102.97
4014	SHM230	4124	NPT2_230	1	0.001446	0.009157	0.032599	16.09
4016	SHD230	4030	MHL230	1	0.018412	0.123383	0.38556	205.49
4016	SHD230	4037	TDG230	1	0.012852	0.08612	0.26912	143.43
4016	SHD230	4037	TDG230	2	0.012852	0.08612	0.26912	143.43
4016	SHD230	4039	OSP230	1	0.0037	0.024858	0.07649	41.17
4016	SHD230	4152	TUG230	1	0.015916	0.100793	0.358809	177.1
4016	SHD230	4152	TUG230	2	0.015916	0.100793	0.358809	177.1
4017	TGO230	4021	TYG230	1	0.008666	0.058074	0.18147	96.72
4017	TGO230	4024	TPU230	1	0.006759	0.040573	0.117301	64.82
4017	TGO230	4028	KUN230	1	0.008128	0.062928	0.06368	59.68
4017	TGO230	4032	TYK230	1	0.002052	0.013451	0.04343	22.53
4017	TGO230	4152	TUG230	1	0.001772	0.010635	0.030748	17
4017	TGO230	4152	TUG230	2	0.001772	0.010635	0.030748	17
4018	SSY230	4043	MYP230	1	0.002362	0.015789	0.04949	26.17

Transmission Line Data (3)

From Bus Number	From Bus	To Bus Number	To Bus Name	Id	Line R (pu)	Line X (pu)	Charging B (pu)	Length
4018	SSY230	4101	U-YW230	1	0.01157	0.073276	0.260851	128.75
4018	SSY230	4101	U-YW230	2	0.01157	0.073276	0.260851	128.75
4019	TLY230	4033	TKT230	1	0.011135	0.007052	0.02455	12.39
4019	TLY230	4033	TKT230	2	0.011135	0.007052	0.02455	12.39
4019	TLY230	4240	THILAWA	1	0.000827	0.005555	0.017092	9.2
4019	TLY230	4240	THILAWA	2	0.000827	0.005555	0.017092	9.2
4020	TPW230	4025	YYW230	1	0.00769	0.063988	0.22197	112.26
4020	TPW230	4025	YYW230	2	0.00769	0.063988	0.22197	112.26
4020	TPW230	4037	TDG230	1	0.013407	0.090081	0.278188	149.19
4020	TPW230	4038	TZI230	1	0.002257	0.015125	0.04764	25.19
4020	TPW230	4151	MTL230	1	0.002241	0.014194	0.050528	24.94
4020	TPW230	4151	MTL230	3	0.001102	0.009171	0.031815	16.09
4020	TPW230	4151	MTL230	4	0.001102	0.009171	0.031815	16.09
4021	TYG230	4028	KUN230	1	0.006664	0.051593	0.05221	48.93
4021	TYG230	4041	SKY230	1	0.003704	0.024796	0.07658	41.07
4021	TYG230	4057	BWG230	1	0.001591	0.010073	0.035859	32.18
4021	TYG230	4153	PYG230	1	0.011192	0.070878	0.252314	124.54
4021	TYG230	4153	PYG230	2	0.011192	0.070878	0.252314	124.54
4027	NBG230	4042	CHU230	1	0.009467	0.062041	0.2003	103.9
4027	NBG230	4058	SWG230	1	0.001446	0.009157	0.032599	16.09
4027	NBG230	4109	KAL230	1	0.013745	0.087049	0.309881	152.95
4027	NBG230	4109	KAL230	2	0.013745	0.087049	0.309881	152.95
4028	KUN230	4052	PYC230	1	0.001442	0.009661	0.03043	16.09
4029	SIT230	4066	BEL230	1	0.004559	0.030553	0.096235	50.88
4030	MHL230	4106	HTD230	1	0.008681	0.054978	0.195714	96.6
4031	THT230	4045	MLM230	1	0.007209	0.048305	0.15215	80.45
4031	THT230	4063	HTK230	1	0.008676	0.054944	0.195593	96.54
4031	THT230	4063	HTK230	2	0.008676	0.054944	0.195593	96.54
4031	THT230	4066	BEL230	1	0.004559	0.030553	0.096235	50.88
4033	TKT230	4107	EDG230	1	0.001446	0.009157	0.032599	16.09
4033	TKT230	4107	EDG230	2	0.001446	0.009157	0.032599	16.09
4033	TKT230	4200	SOUTH OKK	1	0.000801	0.005383	0.016565	8.92
4033	TKT230	4205	KYAIKKASAN	1	0.000669	0.004492	0.013822	7.44
4033	TKT230	4205	KYAIKKASAN	2	0.000669	0.004492	0.013822	7.44
4033	TKT230	4210	THIDA	1	0.00067	0.004498	0.013841	7.45
4033	TKT230	4210	THIDA	2	0.00067	0.004498	0.013841	7.45
4034	ATK230	4105	PTI230	1	0.005787	0.036652	0.130476	64.4
4034	ATK230	4106	HTD230	1	0.011575	0.073304	0.260952	128.8
4035	BYN230	4200	SOUTH OKK	1	0.000289	0.002471	0.2792	8
4035	BYN230	4200	SOUTH OKK	2	0.000289	0.002471	0.2792	8
4035	BYN230	4205	KYAIKKASAN	1	0.00047	0.004015	0.453699	13
4035	BYN230	4205	KYAIKKASAN	2	0.00047	0.004015	0.453699	13
4037	TDG230	4102	MAN230	1	0.012298	0.077885	0.277262	136.85
4037	TDG230	4102	MAN230	2	0.012298	0.077885	0.277262	136.85
4039	OSP230	4056	THA230	2	0.001212	0.010088	0.034997	17.7
4039	OSP230	4106	HTD230	1	0.013705	0.091837	0.289266	152.95
4040	STM230	4151	MTL230	1	0.007082	0.044847	0.15965	78.8
4044	AHL230	4210	THIDA	1	0.000873	0.005193	0.00885	6.4
4044	AHL230	4210	THIDA	2	0.000873	0.005193	0.00885	6.4
4044	AHL230	4220	YESB OFFIC	1	0.000151	0.001291	0.145882	4.17
4044	AHL230	4220	YESB OFFIC	2	0.000151	0.001291	0.145882	4.17
4044	AHL230	4220	YESB OFFIC	3	0.000151	0.001291	0.145882	4.17
4044	AHL230	4230	KUNCHANKC	1	0.000899	0.006038	0.018578	10
4044	AHL230	4230	KUNCHANKC	2	0.000899	0.006038	0.018578	10
4044	AHL230	4250	KYAIKLATT	1	0.007447	0.050033	0.153947	82.864
4044	AHL230	4265	NEW2	1	0.000361	0.003088	0.349	10
4044	AHL230	4265	NEW2	2	0.000361	0.003088	0.349	10
4045	MLM230	4113	YE230	1	0.011864	0.075137	0.267476	132.02

Transmission Line Data (4)

From Bus Number	From Bus	To Bus Number	To Bus Name	Id	Line R (pu)	Line X (pu)	Charging B (pu)	Length
4045	MLM230	4118	KKR230	1	0.00723	0.045787	0.162994	80.45
4051	SHW230	4127	TGG230	1	0.012146	0.076921	0.27383	135.16
4051	SHW230	4127	TGG230	2	0.012146	0.076921	0.27383	135.16
4053	NCO230	4054	U-PLG230	1	0.001591	0.010073	0.035859	17.7
4056	THA230	4104	TOU230	1	0.001212	0.010088	0.034997	17.7
4059	MYK230	4060	TNT230	1	0.005784	0.036629	0.130395	64.36
4059	MYK230	4114	DWI230	1	0.008676	0.054944	0.195593	96.54
4061	TMT230	4120	NBR230	1	0.024581	0.155674	0.554179	273.53
4061	TMT230	4120	NBR230	2	0.024581	0.155674	0.554179	273.53
4062	MWL230	4109	KAL230	1	0.005061	0.032051	0.114096	56.32
4064	MPR230	4109	KAL230	1	0.005061	0.032051	0.114096	56.32
4065	U-TLW230	4115	TIN230	1	0.011279	0.071427	0.25427	125.5
4065	U-TLW230	4115	TIN230	2	0.011279	0.071427	0.25427	125.5
4067	CBW230	4068	LAZ230	1	0.010122	0.064101	0.228191	112.63
4067	CBW230	4068	LAZ230	2	0.010122	0.064101	0.228191	112.63
4102	MAN230	4110	CHK230	1	0.010128	0.064141	0.228333	112.7
4102	MAN230	4111	KCH230	1	0.013022	0.082467	0.293571	144.9
4102	MAN230	4117	ANN230	1	0.008818	0.07337	0.254522	128.72
4103	PON230	4117	ANN230	1	0.013227	0.110056	0.381783	193.08
4104	TOU230	4125	KKP230	1	0.015906	0.10073	0.358586	176.99
4107	EDG230	4153	PYG230	1	0.008088	0.054342	0.167206	90
4107	EDG230	4153	PYG230	2	0.008088	0.054342	0.167206	90
4107	EDG230	4200	SOUTH OKK	2	0.001114	0.007487	0.023037	12.4
4107	EDG230	4215	N.OKKALAPA	1	0.000719	0.00483	0.014863	8
4107	EDG230	4215	N.OKKALAPA	2	0.000719	0.00483	0.014863	8
4107	EDG230	4260	NEW1	1	0.000253	0.002162	0.2443	7
4107	EDG230	4260	NEW1	2	0.000253	0.002162	0.2443	7
4107	EDG230	4260	NEW1	3	0.000253	0.002162	0.2443	7
4110	CHK230	4151	MTL230	1	0.010852	0.068723	0.244643	120.75
4112	MWD230	4118	KKR230	1	0.004338	0.027472	0.097796	48.27
4113	YE230	4114	DWI230	1	0.007234	0.045815	0.163095	80.5
4117	ANN230	4125	KKP230	1	0.014894	0.09432	0.335767	165.73
4119	NPD230	4120	NBR230	1	0.013737	0.086994	0.309688	152.86
4119	NPD230	4120	NBR230	2	0.013737	0.086994	0.309688	152.86
4120	NBR230	4121	BMO230	1	0.012291	0.077837	0.277089	136.77
4120	NBR230	4121	BMO230	2	0.012291	0.077837	0.277089	136.77
4122	SHW3 230	4123	SHW2 230	1	0.002205	0.018343	0.063631	32.18
4122	SHW3 230	4123	SHW2 230	2	0.002205	0.018343	0.063631	32.18
4126	YWA230	4154	HTL230	1	0.001064	0.00674	0.023993	11.84
4126	YWA230	4154	HTL230	2	0.001064	0.00674	0.023993	11.84
4126	YWA230	4215	N.OKKALAPA	1	0.000361	0.003088	0.349	10
4126	YWA230	4215	N.OKKALAPA	21	0.000361	0.003088	0.349	10
4151	MTL230	4152	TUG230	1	0.008346	0.116148	0.545955	0
4151	MTL230	4152	TUG230	2	0.008346	0.116148	0.545955	0
4152	TUG230	4153	PYG230	1	0.006687	0.093077	0.437512	0
4152	TUG230	4153	PYG230	2	0.006687	0.093077	0.437512	0
4200	SOUTH OKK	4215	N.OKKALAPA	1	0.000601	0.004038	0.012423	6.685
4220	YESB OFFI	4225	TAMWE TOV	1	0.000217	0.001853	0.2094	6
4220	YESB OFFI	4225	TAMWE TOV	2	0.000217	0.001853	0.2094	6
4220	YESB OFFI	4225	TAMWE TOV	3	0.000217	0.001853	0.2094	6
4225	TAMWE TOW	4260	NEW1	1	0.000253	0.002162	0.2443	7
4225	TAMWE TOW	4260	NEW1	2	0.000253	0.002162	0.2443	7
4225	TAMWE TOW	4260	NEW1	3	0.000253	0.002162	0.2443	7
5001	MTL500	5002	TUG500	1	0.001766	0.024577	2.580126	235.6
5001	MTL500	5002	TUG500	2	0.001766	0.024577	2.580126	235.6
5001	MTL500	5006	BLN	1	0.001499	0.020861	2.189979	199.5
5001	MTL500	5006	BLN	2	0.001499	0.020861	2.189979	199.5
5002	TUG500	5003	PYG500	1	0.001415	0.019695	2.067635	188.37
5002	TUG500	5003	PYG500	2	0.001415	0.019695	2.067635	188.37
5003	PYG500	5004	HTL500	1	0.000676	0.00941	0.987881	90
5003	PYG500	5004	HTL500	2	0.000676	0.00941	0.987881	90
5003	PYG500	5008	KMB500	1	0.003215	0.044749	4.697857	427.99
5003	PYG500	5008	KMB500	2	0.003215	0.044749	4.697857	427.99
5003	PYG500	5115	EAST DAGO	1	0.000676	0.00941	0.987881	90
5003	PYG500	5115	EAST DAGO	2	0.000676	0.00941	0.987881	90
5004	HTL500	5007	NYK500	1	0.001692	0.023552	2.472557	225.26
5004	HTL500	5007	NYK500	2	0.001692	0.023552	2.472557	225.26
5004	HTL500	5110	KGYAYOKEK	1	0.001127	0.015683	1.646469	150
5004	HTL500	5110	KGYAYOKEK	2	0.001127	0.015683	1.646469	150
5005	SHW3 500	5006	BLN	1	0.001499	0.020861	2.189979	199.5
5005	SHW3 500	5006	BLN	2	0.001499	0.020861	2.189979	199.5
5005	SHW3 500	5100	CBW500	1	0.002997	0.041721	4.379958	399
5005	SHW3 500	5100	CBW500	2	0.002997	0.041721	4.379958	399

Generator Data (1)

Bus Number	Bus Name	Id	In Service	PGen (MW)	PMax (MW)	Mbase (MVA)	X Source (pu)
1018	KDA11-1 11.000	1	1	22.4	28	32.94	0.25
1019	KDA11-2 11.000	1	1	22.4	28	32.94	0.25
1024	KTG11-1 11.000	1	1	14.72	18.4	23	0.1509
1025	KTG11-2 11.000	1	1	14.72	18.4	23	0.1509
1026	KTG11-3 11.000	1	1	14.72	18.4	23	0.1509
1031	LPT11-1 11.000	1	1	28	28	31.11	0.23
1032	LPT11-2 11.000	1	1	28	28	31.11	0.23
1033	LPT11-3 11.000	1	1	28	28	31.11	0.23
1034	LPT11-4 11.000	1	1	28	28	31.11	0.23
1035	LPT11-5 11.000	1	1	28	28	31.11	0.23
1036	LPT11-6 11.000	1	1	28	28	31.11	0.23
1050	SDG11-1 11.000	1	1	10	12.5	13.89	0.2
1051	SDG11-2 11.000	1	1	10	12.5	13.89	0.2
1054	SHW11-1 11.000	1	1	80	100	117.65	0.2
1055	SHW11-3 11.000	1	1	80	100	117.65	0.2
1056	SHW11-6 11.000	1	1	80	100	117.65	0.2
1057	SKY11-1 11.000	1	1	10.8	13.5	15	0.16
1058	SKY11-2 11.000	1	1	10.8	13.5	15	0.16
1059	SKY11-3 11.000	1	1	10.8	13.5	15	0.16
1060	SKY11-4 11.000	1	1	10.8	13.5	15	0.16
1066	THT11-1 11.000	1	1	19.904	19.9	24.88	0.151
1067	THT11-2 11.000	1	0	19.904	19.9	24.88	0.151
1068	THT11-3 11.000	1	0	20	20	25	0.14
1070	TKT11-1 11.000	1	1	19.1	19.1	23.92	0.12
1071	TKT11-2 11.000	1	1	19.1	19.1	23.92	0.12
1072	TKT11-3 11.000	1	1	19.1	19.1	23.92	0.12
1073	TKT11-4 11.000	1	1	34.9	34.9	43.63	0.13
1083	YYW11-1 11.000	1	1	156.4	195.5	230	0.282
1084	YYW11-2 11.000	1	1	156.4	195.5	230	0.282
1085	YYW11-3 11.000	1	1	156.4	195.5	230	0.282
1086	YYW11-4 11.000	1	1	156.4	195.5	230	0.282
1087	ZGY11-1 11.000	1	1	4.8	6	7.5	0.175
1087	ZGY11-1 11.000	2	1	4.8	6	7.5	0.175
1087	ZGY11-1 11.000	3	1	4.8	6	7.5	0.175
1088	ZGY11-2 11.000	1	1	5.12	6.4	8	0.19
1088	ZGY11-2 11.000	2	1	5.12	6.4	7.5	0.19
1095	MYN11-1 11.000	1	1	20.2	20.2	25.31	0.21
1096	MYN11-2 11.000	1	0	19.9	19.9	24.88	0.12
1101	PLG11-1 11.000	1	1	56.96	71.2	83.82	0.1879
1102	PLG11-2 11.000	1	1	56.96	71.2	83.82	0.1879
1103	PLG11-3 11.000	1	1	56.96	71.2	83.82	0.1879
1104	PLG11-4 11.000	1	1	56.96	71.2	83.82	0.1879
1105	AHL11-1 11.000	1	1	34.4	34.4	43.05	0.1078
1106	AHL11-2 11.000	1	1	34.4	34.4	43.05	0.1078
1107	AHL11-3 11.000	1	1	34.4	34.4	43.05	0.1078
1108	AHL11-4 11.000	1	1	54.3	54.3	67.88	0.13
1109	TKY11-1 11.000	1	0	60	60	75	0.139
1110	TKY11-2 11.000	1	0	60	60	78	0.139
1111	HLG11-1 11.000	1	1	34.9	34.9	43.58	0.1078
1112	HLG11-2 11.000	1	1	34.9	34.9	43.58	0.1078
1113	HLG11-3 11.000	1	1	34.9	34.9	43.58	0.1078
1114	HLG11-4 11.000	1	0	51.1	51.1	63.85	0.13
1115	SHD11-1 11.000	1	0	20	20	25	0.166
1116	SHD11-2 11.000	1	0	20	20	25	0.166
1117	SHD11-3 11.000	1	0	27.3	27.3	34.13	0.15
1118	MAN11-1 11.000	1	0	20	20	25	0.159
1119	MAN11-2 11.000	1	0	20	20	25	0.151
1120	MON11-1 11.000	1	1	20	25	29.41	0.2053
1121	MON11-2 11.000	1	1	20	25	29.41	0.2053
1122	MON11-3 11.000	1	1	20	25	29.41	0.2053
1123	KCH11-1 11.000	1	0	20.5	20.5	25.6	0.14
1124	KCH11-2 11.000	1	0	20.5	20.5	25.6	0.14
1125	KCH11-3 11.000	1	0	20.5	20.5	25.6	0.14
1126	KYE11-1 11.000	1	1	34.8	43.5	51.21	0.261

Generator Data (1)

Bus Number	Bus Name	Id	In Service	PGen (MW)	PMax (MW)	Mbase (MVA)	X Source (pu)
1127	KYE11-2 11.000	1	1	34.8	43.5	51.21	0.261
1128	KUN11-1 11.000	1	1	17.04	21.3	25	0.16
1129	KUN11-2 11.000	1	1	17.04	21.3	25	0.16
1130	KUN11-3 11.000	1	1	16	20	25	0.16
1131	TYK11-1 11.000	1	1	32	40	47.06	0.1879
1132	TYK11-2 11.000	1	1	32	40	47.06	0.1879
1133	TYK11-3 11.000	1	1	32	40	47.06	0.1879
1134	TPZ11-1 11.000	1	1	8	10	12.5	0.19374
1135	TPZ11-2 11.000	1	1	8	10	12.5	0.19374
1136	TPZ11-3 11.000	1	1	8	10	12.5	0.19374
1137	KAP11-1 11.000	1	1	12.4	15.5	19.4	0.166
1138	KAP11-2 11.000	1	1	12.4	15.5	19.4	0.166
1139	BHP11-1 11.000	1	1	14	14	15.56	0.26
1140	BHP11-2 11.000	1	1	14	14	15.56	0.26
1141	YWA11-1 11.000	1	1	20	20	25	0.166
1142	YWA11-2 11.000	1	1	20	20	25	0.166
1143	YWA11-3 11.000	1	1	24.1	24.1	28.3	0.12
1144	YWA11-4 11.000	1	1	9.45	9.5	10.5	0.12
1150	KGAYOKEKAUN11.0	1	1	540	540	635.29	0.12
1155	KUNCHANKONE 11.0	1	1	300	300	470.59	0.12
1160	AHLONE 11.000	1	1	121	121	142.35	0.12
1165	THANTAPIN 11.000	1	1	270	270	317.65	0.12
1170	THILAWA1 11.000	1	1	50	50	58.82	0.12
1175	THILAWA2 11.000	1	1	650	650	764.71	0.12
1180	IWAMA 11.000	1	1	150	150	176.47	0.12
1185	KYAIKLATT 11.000	1	1	500	500	588.24	0.125
2044	U-BAL66 66.000	1	1	23.2	29	34.12	0.25
2045	SID66 66.000	1	1	9.18	11.475	13.5	0.25
2046	WZZ66 66.000	1	1	7.2	9	10.59	0.25
2047	GWL66 66.000	1	1	12	15	17.65	0.25
3044	CWN132 132.00	1	1	11.88	14.85	17.47	0.25
3045	U-KTG132 132.00	1	1	40.8	51	60	0.25
3046	U-BUY132 132.00	1	1	120	150	176.47	0.25
3048	LGD132 132.00	1	1	52.2	65.25	76.76	0.25
3049	TGX132 132.00	1	1	38.4	48	56.47	0.25
3050	HKK132 132.00	1	1	16.8	21	24.71	0.25
3101	BAL-3 132 132.00	1	1	41.6	52	61.18	0.25
3106	TAP132 132.00	1	1	28.8	36	42.35	0.25
3107	TAP2 132 132.00	1	1	20.16	25.2	29.65	0.25
4033	TKT230 230.00	1	0	16.08	53.6	63.06	0.25
4033	TKT230 230.00	2	0	150.9	503	591.76	0.25
4033	TKT230 230.00	3	0	153.9	513	603.53	0.25
4044	AHL230 230.00	1	0	36.3	121	142.35	0.25
4052	PYC230 230.00	1	1	32	40	47.06	0.25
4053	NCO230 230.00	1	1	32	40	47.06	0.25
4054	U-PLG230 230.00	1	1	112	140	164.71	0.25
4055	M-PLG230 230.00	1	1	80	100	117.65	0.25
4056	THA230 230.00	1	1	88.8	111	130.59	0.25
4057	BWG230 230.00	1	1	128	160	188.24	0.25
4058	SWG230 230.00	1	1	79.2	99	116.47	0.25
4060	TNT230 230.00	1	1	72	90	105.88	0.25
4061	TMT230 230.00	1	1	144	180	211.76	0.25
4062	MWL230 230.00	1	1	62.4	78	91.76	0.25
4063	HTK230 230.00	1	0	163.2	204	240	0.25
4064	MPR230 230.00	1	1	45.6	57	67.06	0.25
4065	U-TLW230 230.00	1	1	168	210	247.06	0.25
4066	BEL230 230.00	1	0	224	280	329.41	0.25
4068	LAZ230 230.00	1	1	228	285	335.29	0.25
4101	U-YW230 230.00	1	1	224	280	329.41	0.25
4117	ANN230 230.00	1	1	8	10	11.76	0.25
4123	SHW2 230 230.00	1	1	62.4	78	91.76	0.25
5005	SHW3 500 500.00	1	1	650.58	1050	1235.29	0.25
5007	NYK500 500.00	1	0	-1004	1300	1529.41	0.25
5008	KMB500 500.00	1	1	150	500	588.24	0.25
5008	KMB500 500.00	2	1	300	1000	1176.47	0.25
5100	CBW500 500.00	1	0	408	510	600	0.25

Load Data (1)

Bus Number	Bus Name	Area Num	Pload (MW)	Qload (Mvar)	
1012	HLG33 33.000	2	262.7469	114.5287	Yangon
1014	HTY33 33.000	2	98.5301	42.9483	Yangon
1069	TKT33 33.000	2	38.3173	16.7021	Yangon
1074	TKT33_2 33.000	2	38.3173	16.7021	Yangon
1075	TLY33 33.000	2	98.5301	42.9483	Yangon
1092	AHL33 33.000	2	84.298	36.7446	Yangon
1094	YWA33 33.000	2	19.706	8.5897	Yangon
1190	TILAWA 33.000	2	168.3462	73.3804	Yangon
1210	WEST UNIV 33.000	2	98.5301	42.9483	Yangon
2001	TKT66 66.000	2	297.9728	129.8833	Yangon
2003	BYN66 66.000	2	189.3895	82.553	Yangon
2013	AHL66 66.000	2	390.5632	170.2426	Yangon
2030	HLG66 66.000	2	45.4535	19.8127	Yangon
2107	EDG66 66.000	2	189.3895	82.553	Yangon
2200	IWAMA 66.000	2	231.4761	100.8981	Yangon
2210	SOUTH OKKALA66.000	2	189.3895	82.553	Yangon
2215	KYAIKKASAN 66.000	2	189.3895	82.553	Yangon
2220	THIDA 66.000	2	189.3895	82.553	Yangon
2225	N.OKKALAPA 66.000	2	0	0	Yangon
4245	WARTAYAR 230.00	2	49.265	21.4741	Yangon
1003	TYG33 33.000	1	12.14	5.292	Other areas
1004	TGO33 33.000	1	16.9	7.367	Other areas
1008	ATB33 33.000	1	17	7.41	Other areas
1010	APL33 33.000	1	11	4.795	Other areas
1011	BLN33 33.000	1	15.6	6.8	Other areas
1016	ING33 33.000	1	18	7.846	Other areas
1017	ING33_2 33.000	1	0.98	0.427	Other areas
1020	KLW33 33.000	1	8.19	3.57	Other areas
1021	KMN33 33.000	1	30.1749	14.6144	Other areas
1023	KPT33 33.000	1	9.12	3.975	Other areas
1028	YTB33 33.000	1	1.21	0.527	Other areas
1030	LPH33 33.000	1	12.9	5.623	Other areas
1038	MGW33 33.000	1	7.5	3.269	Other areas
1040	MGW33_2 33.000	1	7.9	3.444	Other areas
1041	MTG33 33.000	1	52.3313	25.3452	Other areas
1043	MYP33 33.000	1	57.7	25.151	Other areas
1043	MYP33 33.000	1	38.32	16.703	Other areas
1045	NPT33 33.000	1	24.41	10.64	Other areas
1047	MTG33_2 33.000	1	15.6994	7.6036	Other areas
1048	PMN33 33.000	1	38	16.564	Other areas
1049	POL33 33.000	1	19.2	8.369	Other areas
1052	PMN33 33.000	1	22	9.59	Other areas
1053	SHM33 33.000	1	12.72	5.545	Other areas
1061	SSY33 33.000	1	43	18.743	Other areas
1062	STM33 33.000	1	42	18.307	Other areas
1063	TGD33 33.000	1	19.1	8.325	Other areas
1064	TGD11 11.000	1	14	6.102	Other areas
1065	THT33 33.000	1	18.7	8.151	Other areas
1076	TPU33 33.000	1	21.58	9.407	Other areas
1077	TPW33 33.000	1	26.31	11.468	Other areas
1077	TPW33 33.000	1	11.24	4.899	Other areas
1081	TZI33 33.000	1	19.9	8.674	Other areas
1082	YPS33 33.000	1	4.3	1.874	Other areas
1099	APL11 11.000	1	16.8	7.323	Other areas
2002	THD66 66.000	1	49.17	21.433	Other areas
2004	SHD66 66.000	1	43	18.743	Other areas
2005	MYA66 66.000	1	13.5	5.885	Other areas
2005	MYA66 66.000	1	12.4	5.405	Other areas
2008	THT66 66.000	1	25.5	11.115	Other areas
2011	OSP66 66.000	1	23.2	10.113	Other areas

Load Data (2)

Bus Number	Bus Name	Area Num	Pload (MW)	Qload (Mvar)	
2016	STTY66 66.000	1	0.86	0.375	Other areas
2020	MLM66 66.000	1	5.72	2.493	Other areas
2026	KCH66 66.000	1	27.3	11.9	Other areas
2027	ATK66 66.000	1	45.6	19.877	Other areas
2028	CHK66 66.000	1	28	12.205	Other areas
2031	KLW66 66.000	1	34	14.82	Other areas
2032	MAN66 66.000	1	1.89	0.824	Other areas
2033	MGN66 66.000	1	17	7.41	Other areas
2034	MSN66 66.000	1	23.1	10.069	Other areas
2035	NMS66 66.000	1	8.71	3.797	Other areas
2036	TDG66 66.000	1	15	6.538	Other areas
2037	MYN66 66.000	1	17.1	7.454	Other areas
2038	TNY66 66.000	1	2.79	1.216	Other areas
2230	YESB OFFICE 66.000	1	242	117.206	Other areas
2235	TAMWE TOWNSH66.000	1	350	169.5127	Other areas
2240	NEW1 66.000	1	323	156.4361	Other areas
2245	NEW2 66.000	1	164	79.4288	Other areas
3001	APL132 132.00	1	78.371	37.96	Other areas
3002	CHK132 132.00	1	78.935	38.23	Other areas
3003	KLW132 132.00	1	166.862	80.81	Other areas
3009	LPH132 132.00	1	36.366	17.61	Other areas
3010	MGW132 132.00	1	43.414	21.03	Other areas
3016	TGD132 132.00	1	93.312	45.19	Other areas
3017	TNY132 132.00	1	7.865	3.81	Other areas
3018	TZI132 132.00	1	56.1	27.17	Other areas
3024	MGN132 132.00	1	47.925	23.21	Other areas
3026	ING132 132.00	1	53.506	25.91	Other areas
3027	NMS132 132.00	1	24.544	11.89	Other areas
3029	TDG132 132.00	1	42.286	20.48	Other areas
3030	MAN132 132.00	1	5.328	2.58	Other areas
3031	KPT132 132.00	1	25.71	12.45	Other areas
3033	YPS132 132.00	1	0.26	0.113	Other areas
3033	YPS132 132.00	1	12.855	6.23	Other areas
3034	POL132 132.00	1	54.127	26.21	Other areas
3036	YTB132 132.00	1	3.411	1.65	Other areas
3037	STTY132 132.00	1	2.424	1.17	Other areas
4001	BLN230 230.00	1	43.978	21.3	Other areas
4005	MSN230 230.00	1	65.121	31.54	Other areas
4009	PMN230 230.00	1	169.146	81.92	Other areas
4010	NPT230 230.00	1	68.814	33.33	Other areas
4013	OHT230 230.00	1	180.46	87.4	Other areas
4014	SHM230 230.00	1	35.859	17.37	Other areas
4016	SHD230 230.00	1	121.221	58.71	Other areas
4017	TGO230 230.00	1	47.643	23.07	Other areas
4018	SSY230 230.00	1	121.221	58.71	Other areas
4019	TLY230 230.00	1	72.25	34.99	Other areas
4020	TPW230 230.00	1	105.875	51.28	Other areas
4021	TYG230 230.00	1	34.224	16.58	Other areas
4024	TPU230 230.00	1	60.836	29.46	Other areas
4027	NBG230 230.00	1	73.015	35.36	Other areas
4031	THT230 230.00	1	124.604	60.35	Other areas
4033	TKT230 230.00	1	301.891	146.21	Other areas
4034	ATK230 230.00	1	128.551	62.26	Other areas
4039	OSP230 230.00	1	65.403	31.68	Other areas
4039	OSP230 230.00	1	48.207	23.35	Other areas
4040	STM230 230.00	1	118.402	57.34	Other areas
4043	MYP230 230.00	1	90.23	43.7	Other areas
4044	AHL230 230.00	1	137.163	66.43	Other areas
4045	MLM230 230.00	1	16.125	7.81	Other areas
4111	KCH230 230.00	1	76.961	37.27	Other areas

<Appendix 4>

**Option of the System Configuration with 230 kV
Interconnection between East and West and the
Eastern 500 kV Substation around Yangon**

- **Option of the System Configuration with 230 kV Interconnection between East and West and the Eastern 500 kV Substation around Yangon**

The original plan of Yangon system by MEPE was analyzed with adding the model of part of the system of Yangon using PSS/E software that was also used in “JICA Expert for Strengthening of Implementation Capacity for Transmission Line and Substation”. The main part of the power system analysis data are listed in Appendix 3.

According to the original plan made by MEPE, the power flow at the intervals of Hlaingtayar – Ahlon and Kyaiklat-Ahlon exceed the capacity of their transmission lines. Some interval of the 230 kV transmission lines become overloaded around Hlawga, East Dagon and Ahlon when the single circuit is dropped. An option of the installation of both the 230 kV Interconnection between east and west in Yangon and the eastern 500 kV substation around Yangon as an countermeasure against overloaded conditions caused by dropping a single circuit of transmission lines as show in the following figure.

This option does not cause overloaded situations even when a 230 kV single circuit is dropped except for the lines from Kyaikalat power station. The loads of 500 kV transformers can be within 120 % of their capacity even when one of their banks is dropped in this option.

Thus, it is recommended that the installation of a new 500 kV substation in the east of Yangon or an equivalent power source to supply the power both from the east and the west of Yangon in addition to the 230 kV interconnection.

The short circuit currents in this system are calculated as under 30 kA that is within their permissible levels of both 500 kV and 230 kV as shown in the following table.

Table A4-1 Three Phase Short Circuit Current for the System with East-West Interconnection and East 500 kV Substation

Bus name	Voltage	3phase shortt circuit current (kA)	Bus name	Voltage	3phase shortt circuit current (kA)
Hlaingtayar	230kV	20.3	South Okkala	230kV	28.2
Kamanat	230kV	16.5	Kyaikkasan	230kV	25.6
Myaungtagar	230kV	18.5	Thida	230kV	23.1
Thaketa	230kV	28.0	Thilawa	230kV	16.6
Ahlon	230kV	22.4	Phyaragyi	500kV	14.4
East Dagog	230kV	27.5	Hlaingtayar	500kV	12.4
Ywama	230kV	27.5	East Dagog	500kV	11.3
Phyaragyi	230kV	21.8			




Figure A4-1 Power Flow in the System Fulfilling N-1 Criteria (East-West Interconnection and East 500 kV substation)