

**S13.3-24 WORKSHOP (HYDRAULIC  
ANALYSIS OF DMAS IN HONIARA)**



# Hydraulic Analysis of DMAs in Honiara

## Purpose .

To Identify specific location which to Installed PRV Devices in Selected DMA with Pressure control and also to determine the sizes of the PRV .  
 Also to give raise to concerning about the existing pipe capacity which might give Negative Pressure to parts of the DMAs.


## Process of identify of pipe Network- for each DMA.

- \* A tentative DMA is selected base on the Network configuration and polygon was drawing to identify it as one DMA.
- \* The isolated DMA with its network was exported to water Gem with all its characteristics and Elevation ( from Contours )Profile for Network Modelling.

## Section of Supply Network



## Polygon Boundary isolating a Supply Zone




## Process of Acquiring of Consumption Data

- \* All customers in each DMA have their co-ordinates been taken and can be feature in the GIS System.
- \* Imported consumption data(1 year) from NCS and average taken for each customer meter in the DMA to provide bases for DMA water Demand projection
- \* This can take a day to compile and pass it to Hydraulic Engineer for Analysis ( for at least 2 DMA)

## Imported Data from NCS

## Customers within a Supply Zone



## NCS and GIS Data Combined

| ACCTID   | ESTR_NAM | ESTR_X   | ESTR_Y   | STATUS   | CONSUM_1 | CONSUM_2 | CONSUM_3 | CONSUM_4 | CONSUM_5 | CONSUM_6 | CONSUM_7 | CONSUM_8 | CONSUM_9 | CONSUM_10 | CONSUM_11 | CONSUM_12 | CONSUM_13 | CONSUM_14 | CONSUM_15 | CONSUM_16 | CONSUM_17 | CONSUM_18 | CONSUM_19 | CONSUM_20 |
|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 00000001 | 00000001 | 00000001 | 00000001 | 00000001 | 00000001 | 00000001 | 00000001 | 00000001 | 00000001 | 00000001 | 00000001 | 00000001 | 00000001 | 00000001  | 00000001  | 00000001  | 00000001  | 00000001  | 00000001  | 00000001  | 00000001  | 00000001  | 00000001  | 00000001  |


# Hydraulic Analysis of the existing distribution and Examination for PRV Specification

- Examination Process
- Water Demand Projection regarding DMAs with Pressure Control
- Clarification of Water flowing System for DMAs with Pressure Control
- Water Demand Allocation
- Development of Network Model and Analysis
- Specifying Location of PRVs
- Summary of PRVs and Bulk Flow Meters to be installed in DMAs with Pressure Control

# Water Demand Projection regarding DMAs with Pressure Control

- The following are the design criteria for water demand projection:
  - Estimating based on the billed water consumption in the past one year.
  - In addition to the above billed water consumption, considering the number of illegal connections based on experienced results of pilot project as this will affect the flow quantity and hence Available Heads( effective Pressure)
  - Applying growth rate of 3.1% based on Master Plan (2006) for water demand for the next five years.
  - Applying 30% of NRW ratio based on overall goal shown in PDM.
  - Applying 0.6\* and 1.4 of low and peak hourly factor respectively
  - \* Factor of 0.6 was applied for verification of a flow range of PRVs.

## Examination Process



# Water Demand Projection regarding DMAs with Pressure Control

L. Calculation Statement of Water Demand in DMAs with assumed Pressure Control (NRW Ratio: 30%) Attachment-1

| DMAs with Pressure Control                  | Actual Average Customer Consumption in Oct. 2013 to Sep. 2014 (m <sup>3</sup> /month) | Daily Water Consumption Rate (L/cd) | Ratio of Illegal Connection (%) | Assumed Water Consumption of the Total existing Households (m <sup>3</sup> /month) | Predicted Water Consumption after five Years | NRW Ratio (in %) | Predicted Water Demand (m <sup>3</sup> /month) | Predicted Water Demand (m <sup>3</sup> /day) | Range of Pipe Size (m <sup>3</sup> /hr) |            | Remarks (Estimated Water Demand (m <sup>3</sup> /day) based on Number of Customers) |
|---|---|-------------------------------------|---------------------------------|--|--|------------------|--|--|---|------------|---|
|   |   |                                     |                                 |  |  |                  |  |  | Min. (0.6)                              | Max. (1.4) |   |
| No.6 Tasabe A&B                             | 5,091   | 172                                 | 20                              | 4,560  | 4,812  | 30               | 3,167  | 257  | 6.9                                     | 16.2       | 212   |
| No.8 Ngososi                                | 15,118  | 490                                 | 10                              | 14,574   | 15,366                                       | 30               | 10,002   | 800  | 20.2                                    | 47.2       | 625   |
| No.9 Mbokoma                                | 12,546  | 390                                 | 3                               | 12,248   | 12,366                                       | 30               | 21,798   | 733  | 18.3                                    | 43.4       | 564   |
| No.11 Vavosa Ridge                          | 12,881  | 419                                 | 10                              | 11,423   | 11,820                                       | 30               | 24,010   | 800  | 20.0                                    | 46.7       | 592   |
| No.13 Mbokonaveru                           | 12,971  | 419                                 | 10                              | 11,412   | 11,799                                       | 30               | 23,980   | 799  | 20.0                                    | 46.0       | 589   |
| No.19 Tama & Mbua Valley                    | 11,488  | 353                                 | 10                              | 10,254   | 10,610                                       | 30               | 21,204   | 767  | 17.7                                    | 41.2       | 498   |
| No.22 Kombita (headline, bison Ridge & Run) | 15,101  | 472                                 | 20                              | 12,231   | 12,891                                       | 30               | 27,044   | 901  | 22.5                                    | 52.6       | 695   |
| <b>Total</b>                                | <b>80,078</b>   | <b>2,513</b>                        |                                 | <b>70,601</b>  | <b>73,543</b>                                |                  | <b>150,775</b>                                 | <b>5,026</b>                                 | <b>126</b>                              | <b>293</b> | <b>4,622</b>  |

Note: \*1. Subject to the constant daily water consumption rate, annual population growth rate of 3.1% was tentatively applied for future water consumption.


# Water Demand Projection regarding DMAs without Pressure Control

Calculation Statement of Water Demand in DMAs without Pressure Control related to DMAs with Pressure Control (NRW Ratio: 30%) Attachment-1

| DMAs with Pressure Control              | Number of Customers in DMAs with Pressure Control (Aug. 2014) | Actual Average Customer Consumption in Oct. 2013 to Sep. 2014 (m <sup>3</sup> /month) | Daily Water Consumption Rate (L/cd) | Ratio of Illegal Connection (%) | Assumed Water Consumption of the Total existing Households (m <sup>3</sup> /month) | Predicted Water Consumption after five Years | NRW Ratio (in %) | Predicted Water Demand (m <sup>3</sup> /month) | Predicted Water Demand (m <sup>3</sup> /day) | Range of Pipe Size (m <sup>3</sup> /hr) |            | Remarks (Estimated Water Demand (m <sup>3</sup> /day) based on Number of Customers) |
|---|---|---|-------------------------------------|---------------------------------|--|--|------------------|--|--|---|------------|---|
|   |   |   |                                     |                                 |  |  |                  |  |  | Min. (0.6)                              | Max. (1.4) |   |
| No.7 Tasabe C                           | 136   | 3,728   | 123                                 | 10                              | 4,187  | 4,475  | 30               | 2,930  | 242  | 5.8                                     | 13.5       | -   |
| No.10 Langgaki                          | 201   | 5,713   | 187                                 | 10                              | 5,222  | 5,461  | 30               | 3,601  | 299  | 7.2                                     | 16.3       | -   |
| No.12 Mboni                             | 143   | 3,614   | 116                                 | 10                              | 3,259  | 3,406  | 30               | 1,924  | 159  | 3.8                                     | 8.7        | -   |
| No.15 Waa Kaha Ridge B                  | 151   | 3,473   | 112                                 | 10                              | 3,041  | 3,159  | 30               | 1,644  | 137  | 3.3                                     | 7.5        | -   |
| No.16 Waa Kaha Ridge B (at Camp Valley) | 54  | 1,494   | 47                                  | 10                              | 1,330  | 1,386  | 30               | 712  | 59   | 1.4                                     | 3.2        | -   |
| No.18 Kombita                           | 111   | 1,413   | 46                                  | 10                              | 1,262  | 1,318  | 30               | 683  | 57   | 1.4                                     | 3.2        | -   |
| No.21 Tama & Mbua Valley                | 442   | 11,625  | 355                                 | 10                              | 10,573   | 10,987                                       | 30               | 21,486   | 717  | 17.9                                    | 41.8       | -   |
| <b>Total</b>                            | <b>1,849</b>  | <b>51,084</b>   | <b>1,522</b>                        |                                 | <b>43,993</b>  | <b>45,624</b>                                |                  | <b>186,447</b>                                 | <b>6,551</b>                                 | <b>89</b>                               | <b>207</b> | -   |

Note: \*1. Subject to the constant daily water consumption rate, annual population growth rate of 3.1% was tentatively applied for future water consumption.


# Clarification of Water flowing System for DMAs with Pressure Control




# Clarification of Water flowing System for DMAs with Pressure Control

- In order to analyze distribution network of DMAs with pressure control, conceptual diagrams of water flowing system is illustrated in Attachment-2.
- Peak hourly factor of 1.4 is applied for hydraulic analysis of distribution network but not that of transmission lines.


# System for DMAs with Pressure Control



## Clarification of Water flowing System for DMAs with Pressure Control



## Water Demand Allocation



## Water Demand Allocation

- Water demand is allocated at each node experientially. Water demand per node for all is constant in a particular DMA but water demand per node depends on water consumed in each DMA .
- Nodes are created by Water Gems as Network was imported from GIS and then Verified by the Hydraulic Engineer with Consultation with the Network Engineer

18

## Water Demand Allocation

**No. 6 Tasahe A & B**

Network Table - Nodes

| Node ID   | Elevation<br>m | Base Demand<br>LPS | Head<br>m | Effective Pressure<br>m | Static Pressure<br>m | Result of analysis by using WaterGEM |                      |
|-----------|----------------|--------------------|-----------|-------------------------|----------------------|--------------------------------------|----------------------|
|           |                |                    |           |                         |                      | Effective Pressure<br>m              | Static Pressure<br>m |
| June J-1  | 55             | 0.068              | 114.4     | 59.28                   | 97                   | 42.28                                | 60                   |
| June J-2  | 55             | 0.068              | 114.58    | 59.47                   | 97                   | 42.47                                | 60                   |
| June J-3  | 50             | 0.068              | 114.55    | 64.42                   | 102                  | 47.42                                | 65                   |
| June J-4  | 50             | 0.068              | 114.56    | 64.43                   | 102                  | 47.43                                | 65                   |
| June J-5  | 72             | 0.068              | 148.86    | 76.70                   | 80                   | 27.7                                 | 28                   |
| June J-6  | 72             | 0.0689             | 148.85    | 76.70                   | 80                   | 27.7                                 | 28                   |
| June J-7  | 72             | 0.05               | 146.66    | 74.51                   | 80                   | 57.51                                | 43                   |
| June J-8  | 72             | 0.05               | 146.65    | 74.50                   | 80                   | 57.5                                 | 43                   |
| June J-9  | 71             | 0.068              | 148.8     | 77.64                   | 81                   | 28.64                                | 29                   |
| June J-10 | 71             | 0.068              | 148.8     | 77.64                   | 81                   | 28.64                                | 29                   |
| June J-11 | 75             | 0.068              | 146.77    | 71.63                   | 77                   | 54.63                                | 40                   |
| June J-12 | 75             | 0.068              | 146.77    | 71.62                   | 77                   | 54.62                                | 40                   |

## Development of Network Model and Analysis

- The existing distribution network drawn in MapInfo is exported to Water GEM for hydraulic analysis. The following are design criteria for hydraulic analysis of the distribution network.
  - Calculation Formula: Hazen-Williams
  - Static head: 70m or less
  - Velocity Coefficient (C) for Galvanized pipe & DI and PVC & polyethylene pipe: 100 and 110 respectively
  - Minimum Residual Pressure: 0.1Mpa at each node (except particular node)
- In the light of reducing pressure with PRVs, some existing pipelines in No.8 Ngossi, No.11 Vavaea Ridge and No.19 Tanuli & Mbua Valley must be replaced with a larger size of pipes because of the encounter of negative pressure.

21


## Development of Network Model and Analysis-Tasahe A & B

**No. 6 Tasahe A & B**


Network Table - Links

| Link ID   | Length<br>m | Diameter<br>mm | Flow<br>LPS | Velocity<br>m/s | Unit Headloss<br>m/km |
|-----------|-------------|----------------|-------------|-----------------|-----------------------|
|           |             |                |             |                 |                       |
| Pipe p-38 | 2           | 30             | -0.14       | 0.19            | 3.2                   |
| Pipe p-30 | 3           | 75             | 0.75        | 0.17            | 0.87                  |
| Pipe p-47 | 3           | 30             | 0.1         | 0.14            | 1.81                  |
| Pipe p-35 | 3           | 50             | -0.2        | 0.1             | 0.56                  |
| Pipe p-11 | 3           | 100            | 1.63        | 0.21            | 0.9                   |
| Pipe p-44 | 3           | 30             | -0.2        | 0.29            | 6.77                  |
| Pipe p-41 | 3           | 30             | 0.14        | 0.19            | 3.19                  |
| Pipe p-43 | 4           | 30             | 0.14        | 0.19            | 3.19                  |
| Pipe p-26 | 3           | 100            | 1.56        | 0.2             | 0.83                  |
| Pipe p-48 | 6           | 30             | -0.14       | 0.19            | 3.2                   |
| Pipe p-16 | 6           | 75             | 0.2         | 0.05            | 0.08                  |
| Pipe p-6  | 8           | 100            | -0.34       | 0.04            | 0.05                  |
| Pipe p-7  | 6           | 100            | -0.07       | 0.01            | 0                     |
| Pipe p-25 | 7           | 75             | 1.49        | 0.34            | 3.11                  |
| Pipe p-5  | 8           | 100            | -0.54       | 0.07            | 0.12                  |
| Pipe p-32 | 8           | 50             | -0.14       | 0.07            | 0.27                  |
| Pipe p-36 | 8           | 50             | -0.14       | 0.07            | 0.27                  |
| Pipe p-21 | 8           | 75             | 1.16        | 0.26            | 1.94                  |


## Development of Network Model and Analysis-Tasahe A & B



## Development of Network Model and Analysis – Tasahe A & B Baseline




## Development of Network Model and Analysis – Tasahe A & B with PRV




25

## Development of Network Model and Analysis – Ngossi Base Line



27

## Development of Network Model and Analysis – Ngossi Base Line



26

## Specifying Location of PRVs

- After identifying location on the network model diagrams tentatively, NRW Action Team has the site reconnaissance to identify exact location of PRVs to be installed properly with GPS.
- Location of PRVs with coordinates measured by using GPS was plotted on the diagrams.




28

## Summary of PRVs and Bulk Flow Meters to be installed in DMAs with Pressure Control

- NRW Project Team suggested seven PRVs in six DMAs. Number of chamber as 'Type-2' and 'Type-3'

29

### V. Types of Chamber for Bulk Flow Meters, PRVs and Valves



Legend  
 Chamber  
 Bulk Flow Meter  
 Pressure Reducing Valve  
 Valve

31

## Summary of PRVs and Bulk Flow Meters to be installed in DMAs with Pressure Control

| DMA                         | Area         | Proportion of Population | Range of Flow Rate (lit/s) In Case of NRW 30% |      |            | D No. of PRV | Size of PRV | Chamber Type | Existing Pipelines |          | By-pass Pipelines |          | Flow Meter | Shut Valve | Pressure Reducing Valve | To be replaced with larger size pipes in the whole network |                 |
|-----------------------------|--------------|--------------------------|---|------|------------|--------------|-------------|--------------|--------------------|----------|-------------------|----------|------------|------------|-------------------------|--|-----------------|
|                             |              |                          | 1)  | 2)   | 3) (+) x2) |              |             |              | Diameter A         | Material | Diameter B        | Material |            |            |                         |  | On the Existing |
| No. 6 Tasahe A&B            | Tasahe A     | 35%                      | Min 6.5                                       | 5.7  | 2.4        | PRV-2H1      | 80mm        | Type2        | 80mm               | PVC      | 80mm              | PVC      | 80 x 40mm  | 80mm       | 80mm                    | 80mm   |                 |
|                             | Tasahe B     | 55%                      | Min 16.2                                      | 8.9  | 5.7        | PRV-2H1      | 80mm        | Type2        | 100mm              | PVC      | 80mm              | PVC      | 100 x 80mm | 80mm       | 80mm                    | 80mm   |                 |
| No. 8 Ngossi                | All areas    | 100%                     | Min 20.2                                      | 20.2 | 20.2       | PRV-2H1      | 80mm        | Type3        | 100mm              | PVC      | 80mm              | PVC      | 100 x 80mm | 80mm       | 80mm                    | 80mm   | 100mm -> 150mm  |
|                             |              |                          | Max 47.2                                      | 47.2 | 47.2       | PRV-2H1      | 80mm        | Type3        | 100mm              | PVC      | 80mm              | PVC      | 100 x 80mm | 80mm       | 80mm                    | 80mm   | 100mm -> 150mm  |
| No. 9 Mbokona               | All areas    | 30%                      | Min 18.3                                      | 5.3  | 5.3        | PRV-2H1      | 80mm        | Type2        | 80mm               | PVC      | 80mm              | PVC      | 80 x 40mm  | 80mm       | 80mm                    | 80mm   |                 |
|                             |              |                          | Max 42.8                                      | 12.1 | 12.1       | PRV-2H1      | 80mm        | Type2        | 80mm               | PVC      | 80mm              | PVC      | 80 x 40mm  | 80mm       | 80mm                    | 80mm   |                 |
| No. 11 Vavaia Ridge         | Upper area   | 85%                      | Min 20.0                                      | 17.0 | 17.0       | PRV-2H1      | 80mm        | Type2        | 100mm              | PVC      | 50mm              | PVC      | 100 x 50mm | 50mm       | 50mm                    | 50mm   | 100mm -> 150mm  |
|                             |              |                          | Max 46.7                                      | 39.1 | 39.1       | PRV-2H1      | 80mm        | Type2        | 100mm              | PVC      | 50mm              | PVC      | 100 x 50mm | 50mm       | 50mm                    | 50mm   | 100mm -> 150mm  |
| No. 13 Mbokonavera          | All areas    | 100%                     | Min 20.0                                      | 20.0 | 20.0       | PRV-2H1      | 80mm        | Type3        | 100mm*             | PVC      | 80mm              | PVC      | 100 x 80mm | 80mm       | 80mm                    | 80mm   |                 |
|                             |              |                          | Max 46.6                                      | 46.6 | 46.6       | PRV-2H1      | 80mm        | Type3        | 100mm*             | PVC      | 80mm              | PVC      | 100 x 80mm | 80mm       | 80mm                    | 80mm   |                 |
| No. 19 Tanali & Mbus Valley | Western area | 100%                     | Min 17.7                                      | 17.7 | 17.7       | PRV-2H1      | 50mm        | Type3        | 100mm              | PVC      | 50mm              | PVC      | 100 x 50mm | 50mm       | 50mm                    | 50mm   | 20mm -> 50mm    |
|                             |              |                          | Max 41.2                                      | 41.2 | 41.2       | PRV-2H1      | 50mm        | Type3        | 100mm              | PVC      | 50mm              | PVC      | 100 x 50mm | 50mm       | 50mm                    | 50mm   | 100mm -> 150mm  |

S133-244

## Result

| DMAs                        | Area                | Size of PRVs | Chamber Type* | Bulk Flow Meter | To be replaced with larger size pipes in the whole network |    |       |
|-----------------------------|---------------------|--------------|---------------|-----------------|--|----|-------|
|                             |                     |              |               |                 | Existing   | to | New   |
| No. 6 Tasahe A&B            | Tasahe A            | 40mm         | Type2         | -               |  |    |       |
|                             | Tasahe B            | 40mm<br>x1   | Type2         | -               |  |    |       |
| No. 8 Ngossi                | All areas           | 80mm<br>x1   | Type3         | 80mm<br>x1      | 100mm  | -> | 150mm |
| No. 9 Mbokona               | Eastern at upstream | 40mm<br>x1   | Type2         | -               |  |    |       |
| No. 11 Vavaia Ridge         | Upper area          | 50mm<br>x1   | Type2         | -               | 100mm  | -> | 150mm |
| No. 13 Mbokonavera          | All areas           | 80mm<br>x1   | Type3         | 80mm<br>x1      |  |    |       |
| No. 19 Tanali & Mbus Valley | All areas           | 50mm<br>x1   | 32 Type3      | 50mm<br>x1      | 25mm   | -> | 50mm  |

Thank you





**S13.3-25 FOLLOW-UP LECTURE ON THE**  
**LEAKAGE DETECTION METHOD IN DMAS**




# Changes of the Leak Detection Method in DMAs

March 13, 2015


JICA Team  
Akihiko OKAZAKI

## 2. Selection of Leakage Control Zone (LCZ)



- NRW ratio is calculated by an inflow of a month and a billed consumption of a month. If MNF ratio is over 30%, leak detection and illegal connection check are to be planned immediately.
- MNF is measured by a bulk meter or an ultrasonic flow meter.
- LCZ with high flow volume is identified by closing valve at the inlet point.
- Leak detection in LCZs is prioritized.

## 1. Procedure of Leak Detection in DMAs



## 3. Step Test of Selected LCZ

**Valve Operation Sheet**

| No. | System | Valve No. | Operating Time (min) | Flow rate (m³/h) | MNF (m³/h) | Remarks         |
|-----|--------|-----------|----------------------|------------------|------------|-----------------|
| 1   |        |           | 2:00                 | 12.0             |            |                 |
| 2   | MNF    |           | 2:15                 | 21.5             |            | Start/Recording |
| 3   | Close  | SV-1      | 2:30                 | 8.0              | 2.0        | SV-1 Pipe end   |
| 4   | Close  | SV-2      | 2:45                 | 4.5              | 1.0        | SV-2 Pipe end   |
| 5   | Close  | SV-3      | 2:50                 | 2.0              | 0.5        | SV-3 Pipe end   |
| 6   | Close  | SV-4      | 2:55                 | 2.1              | 0.6        | SV-4 Pipe end   |
| 7   | Close  | SV-5      | 2:55                 | 1.6              | 0.3        | SV-5 Pipe end   |
| 8   | Close  | SV-6      | 2:55                 | 3.0              | 1.2        | SV-6 Pipe end   |
| 9   | Open   | Meter     |                      |                  | 0.5        | Before SV-3     |
| 10  | Open   | SV-1      | 2:50                 |                  |            |                 |
| 11  | Open   | SV-2      | 2:55                 |                  |            |                 |
| 12  | Open   | SV-3      | 2:55                 |                  |            |                 |
| 13  | Open   | SV-4      | 2:55                 |                  |            |                 |
| 14  | Open   | SV-5      | 2:55                 |                  |            |                 |
| 15  | Open   | SV-6      | 2:55                 |                  |            |                 |


**Valve Number & the Location**

**Step Test**

- In case there are no valves for the step test, this procedure will be skipped.
- Calculate the flow volume on each section from a change of flow.

## 4. Selection of Leakage Section

Leakage Section is Identified by the Step Test



A Standard Water Meter


Flow volume of each service line is measured by a standard water meter at branch points in the selected section.



## 6. Tracing Service Pipes and Visible Leakage Check

- Most of leaks are found on service pipes.
- Most of leaks on service pipes are difficult to find because they are long with many branches, pipes go in another people's property and are covered with grass.
- Illegal connections and parasite water users to flat rate SW customers can be identified by tracing and checking service lines one by one.

## 5. Separation of Service lines



The selected service pipe is separated further at shorter dividable points where connection or branch point is located.

A service pipe is separated into several sections to identify the leakage line whether water flows or not by a standard water meter.



## 7. Leak Detection by Equipment

### Acoustic Survey




Check a leak sound at water meter

### Correlation Check




Check leaks on main pipes

### Pinpoint Survey



Check a leak point from the ground

### Confirmation



Identify the leak point exactly

## 8. Leakage Information Sheet

➤ Leakage information should be recorded on the leakage record sheet when leaks are repaired.

➤ Information of leakage and pipes are to be updated on GIS system.

| Leakage Record Sheet                       |  |   |   | Leak No.  | 18       |
|--|--|---|---|---|----------|
| DATE OF WORK                               | 23/05/2018   | TIME  |   | LOCATION  |          |
| NAME OF PIPES                              | Watermain  | CLASS No.   |   | IN CASE OF DISASTERS                                |          |
| TYPE OF PIPE                               | CPVC   | CONDITION   |   |   |          |
| Main Pipe                                  | 1. CPVC, 2. CPVC, 3. CPVC, 4. PE, 5. Other   | Location  | <input type="radio"/> Pipe, 2. Connection, 3. Service, 4. Valve, 5. Other, 6. Tap, 7. Pressure Tank, 8. Other.  |   |          |
| Diameter                                   | 40 mm  | Condition   | <input type="radio"/> Hole, 2. Crack, 3. Breakage, 4. Packing, 5. Loose Connections, 6. Over Flow, 7. Other   |   |          |
| Service Pipe                               | 1. PE, 2. CPVC, 3. CPVC, 4. Other, 5. Other  | Case  | <input type="radio"/> Corrosion, 2. Disturbance (APR), 3. Traffic Load, 4. Shrinkage/Expansion, 5. Soil Burden, 6. Pressure Fluctuation, 7. Debris in Valve, 8. Vandalism, 9. Other Connections, 10. Unknown, 11. Other |   |          |
| Diameter                                   | mm   |   |   |   |          |
| Depth (Burial)                             | mm   | Height  | mm  | 3. Water, 4. Concrete, 5. Ground, 6. Soil, 7. Other |          |
| Leakage Size                               | <input type="radio"/> mm, 2. 10mm, 3. 15mm, 4. Other, 5. 20mm, 6. 25mm, 7. 30mm, 8. 35mm, 9. 40mm, 10. 45mm, 11. 50mm, 12. 55mm, 13. 60mm, 14. 65mm, 15. 70mm, 16. 75mm, 17. 80mm, 18. 85mm, 19. 90mm, 20. 95mm, 21. 100mm | Direction   | <input type="radio"/> Parallel, 2. Across, 3. Unknown, 4. Other   |   |          |
| <b>Leak Location</b>                       |  |   |   |   |          |
|  |  | <input checked="" type="radio"/> Check Valve (New Seal) |   |   |          |
|  |  |   |   |   |          |
| <b>Remarks:</b><br>Leak Flows into a Drain |  |   |   |   |          |
| <b>Information of Leak Repair</b>          |  |   |   |   |          |
| Repair Date                                | 11/06/18   | 12/06/18  | 13/06/18  | 14/06/18  | 15/06/18 |
| Time                                       | 08:00  | 09:00   | 10:00   | 11:00   | 12:00    |
| Location                                   | 100  | 100   | 100   | 100   | 100      |
| Condition                                  | 100  | 100   | 100   | 100   | 100      |
| Cost                                       | 100  | 100   | 100   | 100   | 100      |
| Material                                   | 100  | 100   | 100   | 100   | 100      |
| Labour                                     | 100  | 100   | 100   | 100   | 100      |
| Other                                      | 100  | 100   | 100   | 100   | 100      |
| Total                                      |  |   |   |   |          |

**S13.3-26 MINI-WORKSHOP (PRESENTATION**  
**ON AGENDA OF 3<sup>RD</sup> JCC AND NRW**  
**STRATEGIC IMPLEMENTATION PLAN**



# PROJECT PROGRESS: 15 pilot projects and DMAs, AND Issues and Challenges.

3<sup>rd</sup> JCC Meeting

Date: 19 March 2015

Venue: Solomon Water Conference Room

1

## Achievement of Project Purpose - 15 Pilot Areas

- **Overall Goal:** SW's Service level are improved and SWs Revenue is Increase.
- **Project Purpose:** SW is assisted to achieve its target of reducing the NRW ratio in Honiara to 30% by 2015
  - **Indicator 1:** The NRW ratio is reduced by 30 points in each pilot project area, selected DMAs and/or LCZs
  - **Indicator 2 :** Regarding the pilot project areas, selected DMAs, and/or LCZs where the NRW ratio before the implementation of NRW reduction measures are less than 30%, the NRW reduction measures are implemented in accordance with features of each area and/or zone, so that effectiveness of the NRW reduction measures are validated.

3

## Contents

- Achievements of the Projects in the 15 pilot areas.
- DMA Progress
- Issues Encountered when Implementing the Non Revenue Water Measures.

2

- All Pilot Areas achieved NRW reduction point of **30 points**.
- Lengkiki and Tuvaruhu 1 went through additional countermeasure to achieve 30 points reduction.
- Mbaranamba Case: NRW ratio before countermeasure was already less then 30 points.
- NRW reduction measure was implemented to satisfied indicator 2.

4

## Output 1 – Planning process of SW for NRW Reduction is Systemized

- Indicator 1-1: Annual Budget for NRW is secured in the pilot project areas and LCZs.
  - Total Cost incurred by NRW in the 15 Pilot Areas is **SBD2.23 Million**.
    - Equate to SBD 148,800 per pilot area, or
    - SBD 152,500 per 100 household
    - SBD 100,400 per km of pipe (total pipe length of pilot area approx. 22km)
  - If converted to whole Honiara City (total pipe length approx. 178km), the total estimated cost is **SBD 17.87 M** in today's value.

5

- **Indicator 1-2: The strategic Implementation (rolling-out) plan for NRW reduction of approved by management of SW**
- Based on the result of the 15 pilot project, the preparation of rolling-out plan has commenced.

7

## Increase in Revenue Water Volume as a result of NRW Reduction Activities in 15 Pilot Areas

- Total Revenue Water **before** NRW Reduction Activities is **1,420.6 m<sup>3</sup>/day**
- Total Revenue Water **after** NRW Reduction Activities has increased to **2,845.4 m<sup>3</sup>/day**
- Daily increase of Revenue Water as a result of the Project is **1,424.8 m<sup>3</sup>/day**
- **Converting to Monetary Value**
  - Honiara's unit water supply price (not tariff price) is SBD 16.89/m<sup>3</sup>
  - The total annual revenue by the NRW Reduction is SBD 8.78 M
  - Annual Benefit by the NRW reduction is **SBD 6.55 M** (Total annual Revenue – Total cost incurred)

6 S13.3-26-1

## Output 2- The procedure for NRW reduction is established through the pilot areas and LCZs

- **Indicator 2-1: A manual for NRW reduction measures is prepared**
  - This manual will consist of 3 components; NRW Reduction Measures; Leakage Detection Techniques; and Update of Database.
  - Manual will be prepared to include forms that are already in use during Phase 4 (Apr 2015-Oct 2015)

8

- **Indicator 2-2: The number of authorizations and disconnections of illegal connections is increased in the pilot project areas and LCZs.**
- 140 Illegal connection found in 15 pilot areas (See Table 5). That is **9.6% of total HH**.
- As a result of project, 38 illegals converted to valid customers (27.1%).
- **102( 72.9%) was disconnected.**

9

### Installation of Customer Meters (See Table 7)

- The Project installed 974 brand new meters to customers within Pilot areas from 1000 meters procured by JICA
  - **378 meters to unmetered customers**
  - **596 meters to replace faulty meters.**

11

- **Indicator 2-3: The number of new service connections and replacement of malfunctioning customer meters is increased in the pilot project areas and LCZs.**

#### Newly Connected Households

- Out of total HH (1464) in Pilot project area, 268 is unconnected. (Not connected to SW service line) =**18.3%** (See table 6)
- As result of the Project, 31 HH (11.6%)connected to SW service. **88.4% remained unconnected**

10

### Output 3- NRW reduction is implemented in accordance with the procedure in pilot area and/or LCZ

- **Indicator 3-1: The number of pipe repairs is increased in the pilot project areas and LCZs**
  - Total of **191 leaks detected in Pilot areas and all of them fixed.**
  - Before Project, rate of leak repair is 46 per month for whole Honiara (baseline).


12

### Output 4- Water meter reading and billing process management are improved.

- **Indicator 4-1: Standard operating procedures (SOP) and training materials are formulated.**
  - Initial SOP for meter reading and billing system prepared in April 2013
  - This will be revised to include lessons learned through routine work.

13

### Demarcation of DMAs- Honiara



15

### District-Metered Area(DMA)

- **Definition.**
  - Its an isolated Metering Area where the Total flow into and out of the area is Monitored for DMA Management

14 S13.3-26-2

### Total No. Of DMA

- Twenty Eight(28) DMA
  - Six (6)DMA with Pressure Management.
  - Twenty two(22) DMA with out Pressure Management.

16




## DMAs- In Progress

- Two DMAs
  - Tasahe A & B- With Pressure Control
- West Kola ridge A- with Out Pressure Control


17

## Base Line Data – Tasahe A & B




19

## Example of a DMA Setting- Tasahe A & B




18

## DMA- West Kola ridge A



20

## West Kolaridge A – NRW Base Line



21

## Issues and Challenges- cont.

Leakages Detections and effective Use of Equipments.

- Most pilot projects & DMA leakages detected by Visual checks and hence pipe routes deep cover with vegetations and hilly terrains.

Remedial.

Effective use of Leakages Detection in areas in town DMAs.( Listening Acoustic Mechanical & electronic & Correlator)

23

## Issues & Challenges

Legalisation of Illegal Connections & New Services and Reconnection & Decrease in Customers – Pilot sites.

- Less customers legalised – 27.1% legalised
- Only 11.6 % of 268 Create new accounts or Reconnected
- 8.4% of the total customers were disconnected in the 15 Pilot.

Remedial.

- Awareness of water Tarrif frequent increase to customers
- Use of beneficiary pay principles.
- User pay policy( pay first before delivery of service)

22

S13.3-26-3

## Issues and Challenges- cont.

NRW Reduction in DMAs and DMA Management.

We have 28 DMA for NRW Reductions

- Challenges is DMA Management
  - Monitoring
  - Maintenance
- Process was not completed and the gap need to be closed to maintain the NRW reduction- Sustainability.
- Remedial.
  - Reorganisation of the Operations &( Finances & Customer Service Team) to do Monitoring and Maintenance of DMA.
  - JICA /DEAT to continue the support for - DMA Management

24

