

6. Processing capacity calculationsheets & drawings of STPs

TABLE OF CONTENTS

1. Dinapur STP (Varanasi)
2. Bhagwanpur STP (Varanasi)
3. Ramna STP (Varanasi)
4. Mirzapur 14MLD STP
5. Mirzapur 18MLD STP
6. Vindhyachal STP (Mirzapur)
7. Ghazipur STP
8. Ramnagar STP
9. Chunar STP

1. Dinapur STP (Varanasi)

Item	Dinapur-STP																																										
1. Desain Condition																																											
(1) Design Flow Rate	<table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="2"></th> <th colspan="3">Flow Rate</th> </tr> <tr> <th>m³/d</th> <th>m³/h</th> <th>m³/sec</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td>80,000</td> <td>3,333</td> <td>0.926</td> </tr> <tr> <td>Max Dayly</td> <td>80,000</td> <td>3,333</td> <td>0.926</td> </tr> <tr> <td>Max Hourly</td> <td>160,000</td> <td>6,667</td> <td>1.852</td> </tr> </tbody> </table>		Flow Rate			m ³ /d	m ³ /h	m ³ /sec	Average Daily	80,000	3,333	0.926	Max Dayly	80,000	3,333	0.926	Max Hourly	160,000	6,667	1.852																							
	Flow Rate																																										
	m ³ /d	m ³ /h	m ³ /sec																																								
Average Daily	80,000	3,333	0.926																																								
Max Dayly	80,000	3,333	0.926																																								
Max Hourly	160,000	6,667	1.852																																								
(2) Design Sewage Quality and Effluent Quality	<p style="text-align: right;">Unit: mg/L</p> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="3"></th> <th colspan="7">Water Quality</th> </tr> <tr> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th rowspan="2">TP</th> </tr> <tr> <th>NH₄-N</th> <th>org-N</th> <th>NOx-N</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td>250</td> <td>450</td> <td>400</td> <td>37</td> <td>13</td> <td>0</td> <td>-</td> </tr> <tr> <td>Outlet</td> <td>10</td> <td>50</td> <td>10</td> <td>5</td> <td>0</td> <td>5</td> <td>-</td> </tr> <tr> <td>Removal rate</td> <td>96.0%</td> <td>88.9%</td> <td>97.5%</td> <td colspan="3">####</td> <td></td> </tr> </tbody> </table>		Water Quality							BOD	COD	SS	T-N			TP	NH ₄ -N	org-N	NOx-N	Inlet	250	450	400	37	13	0	-	Outlet	10	50	10	5	0	5	-	Removal rate	96.0%	88.9%	97.5%	####			
	Water Quality																																										
	BOD		COD	SS	T-N			TP																																			
		NH ₄ -N			org-N	NOx-N																																					
Inlet	250	450	400	37	13	0	-																																				
Outlet	10	50	10	5	0	5	-																																				
Removal rate	96.0%	88.9%	97.5%	####																																							
(3) Inlet Water Quality at Reactor	<p style="text-align: right;">Unit: mg/L</p> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="3"></th> <th colspan="7">Water Quality Item</th> </tr> <tr> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th rowspan="2">TP</th> </tr> <tr> <th>NH₄-N</th> <th>org-N</th> <th>NOx-N</th> </tr> </thead> <tbody> <tr> <td>Inlet at Primary Clarifier</td> <td>250</td> <td>450</td> <td>400</td> <td>37</td> <td>13</td> <td>0</td> <td>-</td> </tr> <tr> <td>Removal rate</td> <td>30%</td> <td>30%</td> <td>60%</td> <td colspan="3">####</td> <td>-</td> </tr> <tr> <td>Inlet at Reactor</td> <td>175</td> <td>315</td> <td>160</td> <td>33.3</td> <td>11.7</td> <td>0</td> <td>-</td> </tr> </tbody> </table>		Water Quality Item							BOD	COD	SS	T-N			TP	NH ₄ -N	org-N	NOx-N	Inlet at Primary Clarifier	250	450	400	37	13	0	-	Removal rate	30%	30%	60%	####			-	Inlet at Reactor	175	315	160	33.3	11.7	0	-
	Water Quality Item																																										
	BOD		COD	SS	T-N			TP																																			
		NH ₄ -N			org-N	NOx-N																																					
Inlet at Primary Clarifier	250	450	400	37	13	0	-																																				
Removal rate	30%	30%	60%	####			-																																				
Inlet at Reactor	175	315	160	33.3	11.7	0	-																																				
2. Inlet Chamber																																											
[1] Design Condition																																											
(1) Design Wastewater Flow	<p style="margin-left: 40px;">Max Hourly = 160,000 m³/day</p> <p style="margin-left: 40px;"> = 1.852 m³/sec</p>																																										
[2] Geometry																																											
(1) Number of Basins	1 Basin																																										
(2) Depth of Basin	2.500 m																																										
(3) Width of Basin	5.500 m																																										
(4) Length of Basin	4.500 m																																										
(5) Volume required of Basin	2.500 × 5.500 × 4.500 = 3.1 m ³																																										
(6) Retention Time	2.500 × 5.500 × 4.500 / 1.852 × 1																																										
(7) Basin Demensions	= 33.4098272 sec																																										
	Width 5.500 m × Length 4.500 m																																										
	× Depth 2.500 m																																										

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Wastewater Flow	<p>Max Hourly = 160,000 m³/day = 1.852 m³/sec</p>
[2] Geometry	
(1) Inlet Gate	
Number	2 Main + 2 Bypass
Width	1.000 m
Height	1.500 m
Floor Level	+ 81.900 m
Bottom	+ 77.900 m
Influent Water Level	+ 79.100 m
Velocity	$= \frac{1.852}{2} = 0.772 \approx 1.000 \text{ m/sec}$
(2) Screen Channel	
Number	2 Main + 1 Standby + 1 Bypass
Width	1.500 m
Side Water Depth	1.300 m
Velocity	$= \frac{1.852}{2} = 0.475 \approx 0.450 \text{ m/sec}$
(3) Channel Dimensions	<p>Width 1.5 m × Length 7.5 m × SWD 1.3 m (Freeboard 0.5m)</p>
[3] Equipment	
(1) Inlet Gate	
Number	2 W + 2 S
Dimension	Width 1.0 m × Height 1.5 m
Design Water Level	4.00 m
(2) Fine Screens (Main Channel)	
Number	2 W + 1 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	1.5 m
Width of side plate	50 mm
Side Water Depth	1.3 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	$= \frac{1.852}{\left(\frac{6}{2} + \frac{2}{6} \right)} = 0.706 < 0.800 \text{ m/sec}$
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	1.5 m
Side Water Depth	1.3 m
Velocity through screen	$= \frac{1.852}{\left(\frac{20}{2} + \frac{9}{20} \right)} = 0.689 < 0.800 \text{ m/sec}$

4. Grit Chamber	
[1] Design Condition	
(1) Design Flow Rate	Max Hourly = 160,000 m ³ /day = 1.852 m ³ /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0521 m/sec = 4500 m ³ /m ² /day
(4) Average Velocity	0.3 m/sec
[2] Grit Chamber	
(1) Required Surface Area	1.852 / 0.0521 = 35.558 m ²
(2) Number of Basins	2 S + 0 W
(3) Surface Area required/Basin	35.558 / 2 = 17.779 m ²
(4) Required Diameter of Basin	$(\frac{4}{\pi} \times 17.779)^{0.5} = 4.758 \text{ m}$ → 5.00 m
(5) Basin Dimensions	Dia. 5.00 m × Depth m (Freeboard 0.3m)
[3] Inlet Gate	
Number	2 Main + 0 Bypass
Width	1.000 m
Height	1.000 m
Floor Level	+ 81.200 m
Bottom	+ 77.700 m
Influent Water Level	+ 78.700 m
Velocity	$\frac{1.852}{1.000 \times 1.000 \times 2} = 0.926 = 1.000 \text{ m/sec}$

5. Primary Clarifier (Existing structure)	
[1] Design Condition	
(1) Design Flow Rate	Average Daily = 80,000 m ³ /day = 0.926 m ³ /sec = 55.56 m ³ /min
(2) Type	Circular Clarifire
(3) Surface Overflow Rate required	35 m ³ /m ² /day
(4) Number of Basins	3 Basins
[2] Design	
(1) Surface Area required	80,000 / 35 = 2,286 m ²
(2) Surface Area required/Basin	2,286 / 3 = 762 m ²
(3) Side Water Depth	3.5 m
(4) Diameter required	31.1 m < Existig structure 31.2 m OK
(5) Basin Demensions	Diameter 31.2 m × Depth 3.5 m
[3] Sludge generated per day	
(1) Inlet TSS	400 mg/L
(2) Reduction in TSS	60%
(3) Outlet TSS	160 mg/L
(4) Solids removed from Primary Clarifiers	23,122 kg/day
(5) Solids Consistency	3.0 %
(6) Volume of Primary Sludge	Solids removed × 100 × 10 ⁻³ Solids Consistency = 771 m ³ /day
[4] Equipment	
(1) Primary Sludge Pumps	
Sludge withdrawal	12 Times/day
Running Time	0.50 hr/Time
Number	3 W + 3 S
Required Capacity	771 m ³ /day / 12.0 / 0.5 / 3 = 42.8 m ³ /Hr ⇒ 50 m ³ /h/unit

	NO_x	$NO_x = 36.000 \text{ mg/l} = \text{Inlet TKN} \cdot 80\%$																									
	$P_{X_{NO_x}, VSS}$	$NO_x = 32.338 \text{ mg/l} \text{ corrected}$																									
		$P_{X_{NO_x}, VSS} = 7107.903 \text{ kg VSS/d} = Q \cdot Y_{n(S_0 \cdot S)} / [1 + b_H(SRT)] + f_{d, b_H} \cdot Q \cdot Y_{n(S_0 \cdot S)SRT} / [1 + b_H(SRT)] + Q \cdot Y_n(NO_x) / [1 + b_{AOb}(SRT)]$																									
		$6337.252 = Q \cdot Y_{n(S_0 \cdot S)} / [1 + b_H(SRT)]$																									
		$558.946 = f_{d, b_H} \cdot Q \cdot Y_{n(S_0 \cdot S)SRT} / [1 + b_H(SRT)]$																									
		$211.705 = Q \cdot Y_n(NO_x) / [1 + b_{AOb}(SRT)]$																									
(5) Nitrogen for nitrifier growth	NO_x	$NO_x = 32.338 \text{ mg/l} = \text{TKN} - N_e - 0.12 P_{X_{NO_x}, VSS} / Q$																									
(6) Components of MLVSS																											
		<table border="1"> <thead> <tr> <th>Item</th> <th>MLVSS kg/d</th> <th>Fraction</th> </tr> </thead> <tbody> <tr> <td>Heterotrophs</td> <td>6,337,252</td> <td>0.782</td> </tr> <tr> <td>Cell debris</td> <td>558,946</td> <td>0.069</td> </tr> <tr> <td>Nitrifiers</td> <td>211,705</td> <td>0.026</td> </tr> <tr> <td>nbVSS</td> <td>995,556</td> <td>0.123</td> </tr> <tr> <td>Inert inorganics</td> <td></td> <td></td> </tr> <tr> <td>total</td> <td>8,103,458</td> <td></td> </tr> </tbody> </table>	Item	MLVSS kg/d	Fraction	Heterotrophs	6,337,252	0.782	Cell debris	558,946	0.069	Nitrifiers	211,705	0.026	nbVSS	995,556	0.123	Inert inorganics			total	8,103,458					
Item	MLVSS kg/d	Fraction																									
Heterotrophs	6,337,252	0.782																									
Cell debris	558,946	0.069																									
Nitrifiers	211,705	0.026																									
nbVSS	995,556	0.123																									
Inert inorganics																											
total	8,103,458																										
(7) Fraction of biomass solids																											
	$X_{VSS} \cdot V_a$	$X_{VSS} \cdot V_a = 39.707 \text{ kg VSS} = P_{X_{VSS}} \cdot SRT$																									
	$X_{TSS} \cdot V_a$	$X_{TSS} \cdot V_a = 64.669 \text{ kg TSS} = P_{X_{TSS}} \cdot SRT$																									
	FractionVSS=	FractionVSS= 0.614																									
(8) Summary of biomass/nitrifier concentrations																											
		<table border="1"> <thead> <tr> <th>Pass</th> <th>MLSS g/m³</th> <th>MLVSS g/m³</th> <th>Nitrifiers gVSS/m³</th> <th>Biomass gVSS/m³</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>3,882</td> <td>2,384</td> <td>62,277</td> <td>1,864</td> </tr> <tr> <td>2</td> <td>3,000</td> <td>1,842</td> <td>48,123</td> <td>1,441</td> </tr> <tr> <td>3</td> <td>3,000</td> <td>1,842</td> <td>48,123</td> <td>1,441</td> </tr> <tr> <td>4</td> <td>3,000</td> <td>1,842</td> <td>48,123</td> <td>1,441</td> </tr> </tbody> </table>	Pass	MLSS g/m ³	MLVSS g/m ³	Nitrifiers gVSS/m ³	Biomass gVSS/m ³	1	3,882	2,384	62,277	1,864	2	3,000	1,842	48,123	1,441	3	3,000	1,842	48,123	1,441	4	3,000	1,842	48,123	1,441
Pass	MLSS g/m ³	MLVSS g/m ³	Nitrifiers gVSS/m ³	Biomass gVSS/m ³																							
1	3,882	2,384	62,277	1,864																							
2	3,000	1,842	48,123	1,441																							
3	3,000	1,842	48,123	1,441																							
4	3,000	1,842	48,123	1,441																							
(9) Summary of flowrate																											
		<table border="1"> <thead> <tr> <th>Pass</th> <th>Influent Flow Q</th> <th>Previous Flow Q</th> <th>Total Flow Q</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>0.500</td> <td>1.200</td> <td>1.700</td> </tr> <tr> <td>2</td> <td>0.500</td> <td>1.700</td> <td>2.200</td> </tr> <tr> <td>3</td> <td>0.000</td> <td>2.200</td> <td>2.200</td> </tr> <tr> <td>4</td> <td>0.000</td> <td>2.200</td> <td>2.200</td> </tr> </tbody> </table>	Pass	Influent Flow Q	Previous Flow Q	Total Flow Q	1	0.500	1.200	1.700	2	0.500	1.700	2.200	3	0.000	2.200	2.200	4	0.000	2.200	2.200					
Pass	Influent Flow Q	Previous Flow Q	Total Flow Q																								
1	0.500	1.200	1.700																								
2	0.500	1.700	2.200																								
3	0.000	2.200	2.200																								
4	0.000	2.200	2.200																								
(10) Summary of step-feed solution for NH4-N																											
		<table border="1"> <thead> <tr> <th>Pass</th> <th>Influent Flow m3/d</th> <th>Previous Flow m3/d</th> <th>NH4-N g/m3</th> <th>Rn g/d</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>40,000</td> <td>96,000</td> <td>0.430</td> <td>1,298,496</td> </tr> <tr> <td>2</td> <td>40,000</td> <td>136,000</td> <td>0.659</td> <td>1,236,085</td> </tr> <tr> <td>3</td> <td>0</td> <td>176,000</td> <td>0.659</td> <td>0</td> </tr> <tr> <td>4</td> <td>0</td> <td>176,000</td> <td>0.659</td> <td>0</td> </tr> </tbody> </table>	Pass	Influent Flow m3/d	Previous Flow m3/d	NH4-N g/m3	Rn g/d	1	40,000	96,000	0.430	1,298,496	2	40,000	136,000	0.659	1,236,085	3	0	176,000	0.659	0	4	0	176,000	0.659	0
Pass	Influent Flow m3/d	Previous Flow m3/d	NH4-N g/m3	Rn g/d																							
1	40,000	96,000	0.430	1,298,496																							
2	40,000	136,000	0.659	1,236,085																							
3	0	176,000	0.659	0																							
4	0	176,000	0.659	0																							

[3] Design for Denitrification Process

(1) Fraction of rbCOD

rbCOD/bCOD= 16.88%

Percent rdCOD(%)	SDNR equation coefficients	
	b ₀	b ₁
10	0.186	0.078
20	0.213	0.118
30	0.235	0.141
40	0.242	0.152
50	0.270	0.162

(2) SDNR_b

SDNR_b= 0.150 g/g·d = b₀+b₁[ln(F/M_b)]

b₀= 0.213

b₁= 0.118

(3) SDNR

SDNR_t = SDNR_b · θ^(t-20) θ= 1.026

Pass	Biomass gVSS/m ³	Influent Flow rate m ³ /d	Anoxic Volume m ³	F/M _b gVSS/m ³	SDNR g/g·d
1	1,864	40,000	6,401	0.587	0.150
2	1,441	40,000	6,401	0.759	0.180
3	1,441	0	0	0.000	0.000
4	1,441	0	0	0.000	0.000

(4) NO₃-N balance

Pass	Total NO ₃ -N g/d	Anoxic removal g/d	NO ₃ -N remaining g/d	NO ₃ -N produced g/d	NO ₃ -N effluent g/d
1	674,228	1,790,619	0	1,298,496	1,298,496
2	1,298,496	1,664,170	0	1,236,085	1,236,085
3	1,236,085	0	1,236,085	0	1,236,085
4	1,236,085	0	1,236,085	0	1,236,085

(5) Effluent NO₃-N

N_e= 7.023 g/m³

(6) Alkalinity to be added to maintain pH7

-165.99 mg/l

Influent Alk 380.00 mg/l

Alk used 230.89 mg/l = 7.14 × Nox

Alk produced 86.89 mg/l = 3.57 × (NOx - NO_xe)

Alk to maintain 70.00 mg/l

[4] Equipment

(1) Ras Pumps

Ras Ratio

60 %

Required Capacity

80,000 m³/day × 60% / 24 / 3

Number

= 667 m³/Hr ⇒ 670 m³/Hr
3 Work + 3 Standby

(2) Circulation Pumps

Circulation Ratio

60 %

Required Capacity

80,000 m³/day × 60% / 24 / 3

Number

= 667 m³/Hr ⇒ 670 m³/Hr
3 Work + 3 Standby

7. Air Requirement at Average Flow	
[1] Design Condition	
(1) AOR : R_0	$R_0 = 18,825 \text{ kg/day}$ $= 784.4 \text{ kg/h}$
Q_{in} : Design Average Flow	80,000 m ³ /d
Inlet bCOD : S ₀	280 mg/l
S =	0.457 mg/l
Nox =	32.338 mg/l
$P_{X,bio} =$	6,896.2 kg VSS/d does not include nitrifying bacteria
$R_0 =$	$Q(S_0 - S - k(NOx - NOx_e)) - 1.42P_{X,bio} + 4.57Q \cdot NOx$
$R_0 =$	18,825 kg O ₂ /d
$k =$	2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{AOR}{\alpha} \times \frac{C_s \cdot a}{F \cdot (\beta \cdot C_{sw} / C_s \cdot (P_b / P_a) a - C_A)}$
C_s	: Saturated DO at sea level and 20 °C 9.09 mg/L
C_{sw}	: Saturated DO at sea level and operating Temperature 6.93 mg/L at 35 °C
20-T	: $-15.0 \cdot 1.024^{20-T}$: 0.7006
C_A	: operating DO in Basin 2.0 mg/L
a	: Correction Factor by the Water Depth $1 + 0.40D_j / P_a$ 1.19357
D_j	: Tank Liquid Depth 5.00 m
P_a	: Standard absolute pressure at s 10.33 m
P_b	: Absolute pressure at Plant Site Elevation m
P_b / P_a	: $\exp[-gM(z_b - z_a) / R \cdot T]$ 0.992
g	: Acceleration due to Gravity 9.80665 m/s ²
M	: Mole of Air 28.97 kg/kg-mole
z_b	: Plant Site Elevation 70 m
z_a	: Sea Elevation 0 m
R	: Universal Gas Constant 8314 Nm/kg-mole.K
T	: Temperature $273.15 + t = 308.15$ Kelvin
α	: relative Transfer Rate to clean W _a 0.65
β	: relative DO Saturation to clean W _e 0.95
F	: Diffuser Fouling Factor 0.90
	$= \frac{143,104}{3.3913} = 42,197.03 \text{ kg/day}$
(3) No. of Basins	3 Basin
(4) Standard O ₂ required at Field Conditions per Bas =	14,066 kg/day
(5) SOTE for the above Effective Aeration Depth	30.5 %
(6) Fraction of O ₂ in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	10%
(9) Air required at Field Conditions per Basins =	181,655 m ³ /day = 7,568.9 m ³ /hr

[2] Equipment	
(1) Air Blower	
Number	6 W + 3 S
Required Capacity	7,569 m ³ /Hr·Basin / 2 unit/Basin
	= 3,784 m ³ /h ⇒ 3,800 m ³ /h/unit
Pressure	65 kPa
Safety Factor	10 %
Heat capacity ratio	1.4
Atmospheric pressure at site elevation	100.542 kPa
Total inlet pressure	98.542 kPa
Volume rate of flow at inlet point	65.106 m ³ /min
Total discharge pressure	165.542 kPa
Overall adiabatic efficiency	0.65
Inlet air temperature (min.)	15 °C
Shaft power	93.580 kW
Rated Output of Motor	102.938 kW ⇒ 110 kW

8. Secondary Clarifier (Existing structure)	
[1] Design Condition	
(1) Design Flow Rate	Average Daily = 80,000 m ³ /day = 0.926 m ³ /sec = 55.56 m ³ /min
(2) Type	Circular Clarifier
(3) Surface Overflow Rate required	25 m ³ /m ² /day
(4) Number of Basins	3 Basins
[2] Geometry	
(1) Surface Area required	80,000 / 25 = 3,200 m ²
(2) Surface Area required per Basin	3,200 / 3 = 1,067 m ²
(3) Side Water Depth	3.5 m
(4) Diameter required	36.9 m < Existing structure 40.0 m
(5) Dimensions	Diameter 40.0 m × Depth 3.5 m OK
[3] Sludge generated per day	
(1) Inlet TSS	400 mg/L
(2) Reduction in TSS	60%
(3) Outlet TSS	160 mg/L
(4) Solids removed from Primary Clarifiers	23,122 kg/day
(5) Solids Consistency	3.0 %
(6) Volume of Primary Sludge	$= \frac{\text{Solids removed} \times 100}{\text{Solids Consistency} \times 10^{-3}}$ = 771 m ³ /day

9. Chlorination Tank (not in scope of project)

[1] Design Condition

(1) Design Flow Rate	Average Daily Flow	80,000	m ³ /day	
(2) Contact Time	30	min		
(3) Type of Chlorine	Chlorine gas			
(4) Design Chlorine Dosage Rate	10	mg/L		
(5) Required Chlorine per day	Average Daily Flow	/	1000	× Design Chlorine Dosage Rate
	=	800.0	kg/d	
	=	33.33	kg/h	

[2] Geometry

(1) Volume required	Average Daily Flow	/	1440	×	Contact Time				
	=	1666.7	m ³						
(2) Nos. of lanes	11	lanes							
(3) Width of lane	2.00	m							
(4) Length of lane	39.00	m							
(5) Side Water Depth	2.00	m							
(6) Nos. of Tanks	1	tank							
(7) Total Width of Tank	27.40	m-Approx.							
(8) Average Velocity	Average Daily Flow	/	86400	/	Width	/	Depth		
	=	80,000	/	86400	/	2.00	/	2.00	
	=	0.231	m/sec						
(9) Total Volume	Width	×	Length	×	Depth	×	Nos. of lanes	×	Nos. of Tanks
	=	2.0	m	×	39.0	m	×	2.0	m
		×	11	×	1				
	=	1,716	m ³	>	1666.7	m ³			

[3] Equipment

(1) Chlorinator					
Number	2	W	±	1	S
Design rate per unit	16.67	kg/h/unit	⇒	17	kg/h/unit
(2) Chlorine Tonner					
Number	13	W	±	2	S
Storage duration	15.00	days			
Available Capacity per unit	928.00	kg/unit			
Required Nos. of tonner	12.93	units	⇒	13	units

10. Sludge Thickener	
[1] Generated Sludge	
(1) Primary Sludge	23,122 kg/day 771 m ³ /day
(2) WAS Sludge	12,020 kg/day 1,502 m ³ /day
[2] Gravity Thickener	
(1) Number	2 W + 0 S
(2) Consistency of Thickened Sludge	5.00 %
(3) Design Solid Loading	120 kg / m ² .d
(4) Required Surface Area	$23,122 \times \frac{1}{120} = 192.70 \text{ m}^2$
(5) Required diameter	$(\frac{4}{\pi} \times 192.70 \times \frac{1}{2})^{1/2} = 11.08 \text{ m}$ $\Rightarrow 11.50 \text{ m}$
(6) Side Water Depth	3.5 m
(7) Actual Volume of Tank	$\frac{\pi}{4} \times 11.50^2 \times 3.5 = 103.87 \text{ m}^3$
(8) Retention Time	$\frac{103.87}{771} \times 4 \times 2 \times 24 = 22.64 \text{ Hr} < 24 \text{ h} > 12 \text{ h}$
[3] Mechanical Thickener	
(1) Type of Thickener	Rotary Drum
(2) Number of thickeners	2 W + 1 S
(3) Design Polyelectrolyte Dosage	1.5 kg/t-D.S · day
(4) Consistency of Thickened Sludge	5.00 %
(5) Operation Time	18 hours/day (7 days per week)
(6) Design Polyelectrolyte Dosage	1.5 kg/t-D.S · day
(7) Required Polyelectrolyte	18.03 kg/day
(8) Dissolving concentration	0.20 %
(9) Volume of Polyelectrolyte solution	9.01 m ³ /day
(10) Capacity of Thickeners	$\frac{\text{Secondary Sludge volume}}{\text{Operation Time} \times \text{No}} = \frac{1,502.5}{18 \times 2} \times \frac{7}{7} = 41.7 \Rightarrow 50 \text{ m}^3/\text{h}$
[4] WAS Sump	
(1) WAS Sludge	62.60 m ³ /h
(2) Sludge feed flow rate to thickener	50 m ³ /h × 2 = 100 m ³ /h
(3) Minimum deteision time	3 hours
(4) Required sludge volume	300.00 m ³
(5) Basin Dimensions	Width 6.0 m × Length 6.5 m × Depth 4.0 m × 2 = 312.0 m ³
[5] Thickened Sludge Sump	
(1) Thickened Sludge	228.38 m ³ /d
(2) Minimum deteision time	12 hours
(3) Required sludge volume	114.19 m ³
(4) Basin Dimensions	Width 6.0 m × Length 6.5 m × Depth 4.0 m × 1 = 156.0 m ³

[5] Equipment	
(1) Gravity Thickened Sludge Pumps	
Transfer Time	12.00 times × 0.75 h/time = 9.00 h/d
Number	2 W + 1 S
Required Capacity	771 m ³ /d / 9.0 / 2 42.8 m ³ /Hr ⇒ 50 m ³ /Hr /Unit
(2) Mixing Blower for WAS/Thickened Sludge Sump	
Required Volume	468.0 m ³
Agitate Rate	1.20 m ³ /Hr·m ³
Number	1 W + 1 S
Required Capacity	468 m ³ × 1.2 / 1 = 561.6 m ³ /h ⇒ 600 m ³ /h/unit
(3) Mechanical Thickener	
Capacity	50 m ³ /hr
Number	2 W + 1 S
(4) Mechanical Thickener Feed Pumps	
Capacity	50 m ³ /hr
Number	2 W + 1 S
(5) Polyelectrolyte Dosing Pumps	
Safety Factor	1.5
Number	2 W + 1 S
Required Capacity	9.01 m ³ /d / 18.0 / 2 × 7 / 7 = 0.25 m ³ /h
Specification Capacity	0.25 m ³ /h × 1.5 = 0.376 m ³ /h ⇒ 0.45 m ³ /h/unit


11. Sludge Digester (existing structure)						
[1] Design Condition						
(1) Generated Thickened Sludge	from Gravity Thickener	20,810	kg/day	416	m ³ /day	
	from Mechanical Thickener	11,419	kg/day	228	m ³ /day	
	Total	32,229	kg/day	645	m ³ /day	
(2) Ratio of VSS		75	%			
(3) Total VSS	=		24,172	kg/day		
(4) Total inorganic sludge	=		8,057	kg/day		
(5) Retention Time		20	days			
(6) % Destruction in VSS		50	%			
(7) VSS destroyed	=		12,086	kg/day		
(8) Generated digested sludge	=		20,143	kg/day		
(9) Solids Consistency		3.1250	%			
(10) Volume of Digested Sludge	Total Solids		$\times \frac{100}{\text{Solids Consistency}}$	$\times 10^{-3}$		
	=	645	m ³ /day			
[2] Geometry						
(1) Volume required		12,891	m ³			
(2) No. of Basins		3	Basins			
(3) Volume required per Basin	=		4,297	m ³		
(4) Depth provided		7.0	m			
(5) Area required per Basin	=		614	m ²		
(6) Diameter required per Basin	=		28.0	m		
(7) Basin Dimensions	Diameter	29.0	m	Depth	7.0 m	
	$\times 3$ Basins	=	13,871	m ³		
[3] Equipment						
(1) Mixers for Digestion Tanks	Capacity	4624	m ³			
	Number	3	W	+ 0	S	
(2) Digested Sludge Transfer Pumps	Transfer Time	12.00	times	$\times 0.5$	h/time = 6.00 h/d	
	Number	3	W	+ 3	S	
	Required Capacity	645	m ³	$\div 6.0$	$\div 3$	
	=	35.8	m ³ /Hr	\Rightarrow	40 m ³ /Hr /Unit	

12. Biogas Power Generation	
[1] Design Condition	
(1) Biogas generated per kg of VSS destroyed	0.9 m ³ /kg
(2) VSS destroyed	12,086 kg/day
(3) Generated biogas	10,877 m ³ /day
[2] Biogas Holder (Existing)	
(1) Required volume	50 % of generated biogas = 5,439 m ³
(2) No. of Biogas Holders	2 Nos.
(3) Required volume per unit	### m ³
(4) Dimension	Diameter 21.0 m × height 8.7 m × 2 Basins = 6,027 m ³ > 5,439 m ³ OK
[3] Equipment	
(1) Biogas Power generators	
Biogas Generation	0.126 m ³ /sec
Biogas Caloric Value	22,000 KJ/m ³
Biogas Engine Conversion Efficiency	40.0 %
Number	2 W + 1 S
Power Generation	0.126 m ³ /sec × 22000 KJ/m ³ × 0.4 / 2 = 553.9 kW ⇒ 600 kW
(2) Desulfurization Equipment	
Biogas Generation	453.22 m ³ /h
Peak Ratio	1.5
Number	2 W + 0 S
Required Capacity	453.22 m ³ /h × 1.5 / 2 = 339.9 m ³ /h ⇒ 360 m ³ /unit
(3) Biogas Blowers	
Biogas Generation	453.22 m ³ /h
Safety Factor	1.5
Number	2 W + 1 S
Required Capacity	453.22 m ³ /h × 1.5 / 2 = 339.9 m ³ /h ⇒ 360 m ³ /unit
(4) Biogas Flare	
Biogas Generation	10,877 m ³ /d
Operating hours	24 Hr
Safety Factor	150.0 %
Number	2 W + 0 S
Power Generation	340 m ³ /hr ⇒ 360 m ³ /hr

13. Centrifuge	
[1] Design Condition	
(1) Type of Dewatering	Centrifuge
(2) Quantity of Digested Sludge generated	20,143 kg/day
(3) Design Polyelectrolyte Dosage	1.5 kg/t-DS·day
(4) Volume of Digested Sludge	644.6 m ³ /day
(5) Consistency of Dewatered Sludge	82.00 %
(6) Operation Time	16 hours/day (6 days per week)
[2] Volume of Centrifuges	
	$\frac{\text{Digested Solids}}{\text{Operation Time} \cdot \text{No}} \times \text{Operation/week}$ $= \frac{644.6}{16 \times 2} \times \frac{7}{6} = 23.5$ $\rightarrow 25 \text{ m}^3/\text{hour}$
[3] Dewatered Solids	
	$\text{Digested Sludge} \times (1 + \text{Injection Rate})$ $= 20,143 \times (1 + 0.0015)$ $= 20,173 \text{ kg/day}$
[4] Dewatered Cake Volume	
	$\text{Dewatered Solids} \times \frac{100}{100 - \text{Moisture Content}}$ $\times \frac{7}{6 \text{ days per week}}$ $= 20,173 \times \frac{100}{100 - 82} \times \frac{7}{6}$ $= 130.75 \text{ t/day}$
[5] Polyelectrolyte	
(1) Design Polyelectrolyte Dosage	1.5 kg/t-DS·day
(2) Required Polyelectrolyte	30.21 kg/day
(3) Dissolving concentration	0.20 %
(4) Volume of Polyelectrolyte solution	15.11 m ³ /day
[6] Equipment	
(1) Centrifuge	
Capacity	25 m ³ /hr
Number	2 W + 1 S
(2) Centrifuge Feed Pumps	
Capacity	25 m ³ /hr
Number	2 W + 1 S
(3) Polyelectrolyte Dosing Pumps	
Volume of Polyelectrolyte solution	15.11 m ³ /day
Operation Time	16 hours/day (6 days per week)
Safety Factor	1.5
Number	2 W + 1 S
Required Capacity	$15.11 \text{ m}^3/\text{d} \times 16.0 / 2 \times 7 / 6$ $= 0.55 \text{ m}^3/\text{h}$
Specification Capacity	$0.55 \text{ m}^3/\text{h} \times 1.5$ $= 0.826 \text{ m}^3/\text{h} \Rightarrow 0.90 \text{ m}^3/\text{h/unit}$
(4) Polyelectrolyte dosing System	
Required chemical volume	$\text{for Mechanical Thickeners } 0.25041375 \text{ m}^3/\text{h} \times 2 \text{ Nos.} \times 18 \text{ h/day}$ $\text{for Centrifuges } 0.55 \text{ m}^3/\text{h} \times 2 \text{ Nos.} \times 16 \text{ h/day}$
Tanks Dimensions	
	$\text{Total } 26.64 \text{ m}^3/\text{day}$ $\text{Width } 2.5 \text{ m} \times \text{Length } 2.5 \text{ m}$ $\times \text{Depth } 2.5 \text{ m} \times 2$ $= 31.3 \text{ m}^3$
Number	2 W + 0 S

14. Centrifuge Feed Sump	
[1] Design Condition	
(1) Quantity of Digested Sludge generated	20,143 kg/day
(2) Solids Consistency	2.5 %
(3) Volume of Thickened Sludge	$\text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3}$ $= 20,143 \times \frac{100}{3} \times 10^{-3}$ $= 806 \text{ m}^3/\text{day}$ $= 33.57 \text{ m}^3/\text{h}$
(4) Sludge feed flow rate	25 m ³ /h × 2 = 50 m ³ /h
(5) Centrifuge Operation Time	16 hours/day (6 days per week)
[2] Geometry	
(1) Required sludge volume for continuation	(50 - 33.57) × 16 = 262.86 m ³
(2) Basin Dimensions	Width 6.0 m × Length 6.0 m × Depth 3.5 m × 2 = 252.0 m ³
[3] Equipment	
(1) Mixers for Centrifuge Feed Sumps	
Required Volume	126.0 m ³
Number	2 W + 0 S

Material Balance Sheet
[Dinapur STP] STEP



凡例 LEGEND

Q	: Water Flow : (m ³ /day)
T	: Solid Matter : (t-DS/day)
S	: Solid Concentration (mg/l)
X	: Ratio for Inlet Solid : (%)
-	: Water
-	: Sludge
-	: Supernatant



Sr. No.	Facility	No.	W/Dia. (m)	L (m)	SWD/H (m)
01	Inlet Chamber	1	5.5 ^W	4.5 ^L	2.5 ^{SWD}
02	Main Screen Channel	3	1.5 ^W	7.5 ^L	1.3 ^{SWD}
03	Bypass Screen Channel	1	1.5 ^W	7.5 ^L	1.5 ^{SWD}
04	Grit Chamber	2	5.0 ^{Dia.}		3.0 ^{SWD}
05	Parshall Flume	1	**** ^W	**** ^L	**** ^{SWD}
06	Distribution Chamber	1	**** ^W	**** ^L	**** ^{SDW}
07	Primary Clarifier	3	31.2 ^{Dia.}		3.5 ^{SWD}
08	Anoxic Tank 1	3	20.0 ^W	15.0 ^L	5.5 ^{SWD}
09	Anoxic Tank 2	3	20.0 ^W	19.5 ^L	4.5 ^{SWD}
10	Aerobic Tank	3	20.0 ^W	40.0 ^L	4.5 ^{SWD}
11	Secondary Clarifier	3	40.0 ^{Dia.}		3.5 ^{SWD}
12	Chlorine Contact Tank	1	Not in scope of project		
13	Primary Sludge Sump	3	3.0 ^W	4.0 ^L	4.0 ^{SWD}
14	Secondary Sludge Sump	3	3.0 ^W	4.0 ^L	4.0 ^{SWD}
15	Sludge Thickener	2	11.5 ^{Dia.}		4.0 ^{SWD}
16	WAS Sump	2	6.0 ^W	6.5 ^L	4.0 ^{SWD}
17	Thickened Sludge Sump	1	6.0 ^W	6.5 ^L	4.0 ^{SWD}
18	Anaerobic Sludge Digester	3	29.0 ^{Dia.}		7.0 ^{SWD}
19	Biogas Holder	2	21.0 ^{Dia.}		8.7 ^{SWD}
20	Centrifuge Feed Sump	2	6.0 ^W	6.0 ^L	3.5 ^H
21	Sludge Drying Bed	*	**** ^W	**** ^L	**** ^H
22	Filtrate Sump House	1	12.7 ^W	13.0 ^L	**** ^H
23	Air Blower Room	1	12.0 ^W	25.0 ^L	6.0 ^H
24	Treated Effluent Pump House	1	12.7 ^W	13.0 ^L	**** ^H
25	Chlorination Building	1	Not in scope of project		
26	Thickened Sludge Pump House	1	6.0 ^W	6.0 ^L	4.0 ^H
27	Mechanical Thickener Building	1	10.0 ^W	15.0 ^L	8.0 ^H
28	Centrifuge Building	1	15.0 ^W	30.0 ^L	10.0 ^H
29	Control Room for Digester	1	4.2 ^W	4.3 ^L	**** ^H
30	Power House	1	29.5 ^W	31.6 ^L	**** ^H
31	Biogas Flare	2			
32	Administration Building	1	12.6 ^W	25.2 ^L	**** ^H
33	Electrical Building	1	15.0 ^W	20.0 ^L	8.0 ^H

- Main Process Line
- Sludge Line
- Other Line
- Proposed structure
- Demolished structure
- Existing structure

Project Name	
PREPARATORY SURVEY ON GANGA REJUVENATION PROJECT IN THE STATE OF UTTAR PRADESH, INDIA インド国ガンジス川浄化事業準備調査	
Drawing Title	Scale: 1:2000
Dinapur STP 80MLD Layout (Alternative 1)	Drawing No. STP-21




Sr. No.	Facility	No.	W/Dia. (m)	L. (m)	SWD/H (m)
01	Inlet Chamber	1	5.5 ^W	4.5 ^L	2.5 ^{SWD}
02	Main Screen Channel	3	1.5 ^W	7.5 ^L	1.3 ^{SWD}
03	Bypass Screen Channel	1	1.5 ^W	7.5 ^L	1.5 ^{SWD}
04	Grit Chamber	2	5.0 ^{Dia.}		3.0 ^{SWD}
05	Parshall Flume	1	**** ^W	**** ^L	**** ^{SWD}
06	Distribution Chamber	1	**** ^W	**** ^L	**** ^{SWD}
07	Primary Clarifier	3	31.2 ^{Dia.}		3.5 ^{SWD}
08	Anoxic Tank 1,2	6	23.0 ^W	17.0 ^L	5.5 ^{SWD}
09					
10	Aerobic Tank 1,2	6	23.0 ^W	25.0 ^L	5.5 ^{SWD}
11	Secondary Clarifier	3	40.0 ^{Dia.}		3.5 ^{SWD}
12	Chlorine Contact Tank	1	Not in scope of project		
13	Primary Sludge Sump	3	3.0 ^W	4.0 ^L	4.0 ^{SWD}
14	Secondary Sludge Sump	3	3.0 ^W	4.0 ^L	4.0 ^{SWD}
15	Sludge Thickener	2	11.5 ^{Dia.}		4.0 ^{SWD}
16	WAS Sump	2	6.0 ^W	6.5 ^L	4.0 ^{SWD}
17	Thickened Sludge Sump	1	6.0 ^W	6.5 ^L	4.0 ^{SWD}
18	Anaerobic Sludge Digester	3	29.0 ^{Dia.}		7.0 ^{SWD}
19	Biogas Holder	2	21.0 ^{Dia.}		6.7 ^{SWD}
20	Centrifuge Feed Sump	2	6.0 ^W	6.0 ^L	3.5 ^H
21	Sludge Drying Bed	•	**** ^W	**** ^L	**** ^H
22	Filtrate Sump House	1	12.7 ^W	13.0 ^L	**** ^H
23	Air Blower Room	1	12.0 ^W	37.0 ^L	6.0 ^H
24	Treated Effluent Pump House	1	12.7 ^W	13.0 ^L	**** ^H
25	Chlorination Building	1	Not in scope of project		
26	Thickened Sludge Pump House	1	6.0 ^W	6.0 ^L	4.0 ^H
27	Mechanical Thickener Building	1	10.0 ^W	15.0 ^L	8.0 ^H
28	Centrifuge Building	1	15.0 ^W	30.0 ^L	10.0 ^H
29	Control Room for Digester	1	4.2 ^W	4.3 ^L	**** ^H
30	Power House	1	29.5 ^W	31.6 ^L	**** ^H
31	Biogas Flare	2			
32	Administration Building	1	12.6 ^W	25.2 ^L	**** ^H
33	Electrical Building	1	15.0 ^W	20.0 ^L	8.0 ^H

- Main Process Line
- Sludge Line
- Other Line
- Proposed structure
- Demolished structure
- Existing structure

Project Name
 PREPARATORY SURVEY ON GANGA REJUVENATION
 PROJECT IN THE STATE OF UTTARPRADESH, INDIA
 インド国ガンガス川浄化事業準備調査


Drawing Title
 Dinapur STP 80MLD layout
 (Alternative 2)

Scale: 1:2000
 Drawing No. STP-22



Main Process ————
 Sludge Line - - - - -
 Other Line
 Existing structure [---]

Project Name		Scale: not
PREPARATORY SURVEY ON GANGA REJUVENATION PROJECT IN THE STATE OF UTTARPRADESH, INDIA インド国ガンジス川浄化事業準備調査		
Drawing Title		Drawing No. STP-01
Dinarpur STP 80MLD Layout (Alternative 1)		



Main Process ————
 Sludge Line - - - - -
 Other Line ————
 Existing structure - - - - -

Project Name		PREPARATORY SURVEY ON GANGA REJUVENATION PROJECT IN THE STATE OF UTTARPRADESH, INDIA
		ノリ、固カソジス川浄化事業者協議会
Drawing Title	Dindarpur STP 80MLD layout (Alternative 2)	Scale: not
Drawing No.	STP-02	

2. Bhagwanpur STP (Varanasi)

Item	Bagwanpur-STP																																																																																																														
<p>1. Desin Condition</p> <p>(1) Design Flow Rate</p> <p>(2) Design Sewage Quality and Effluent Quality</p> <p>(3) Inlet Water Quality at Reactor</p>	<table border="1" data-bbox="608 277 1235 443"> <thead> <tr> <th rowspan="2"></th> <th colspan="3">Flow Rate</th> </tr> <tr> <th>m3/d</th> <th>m3/h</th> <th>m3/sec</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td>8,000</td> <td>333</td> <td>0.093</td> </tr> <tr> <td>Max Daily</td> <td>8,000</td> <td>333</td> <td>0.093</td> </tr> <tr> <td>Max Hourly</td> <td>18,000</td> <td>667</td> <td>0.208</td> </tr> </tbody> </table> <p style="text-align: right;">Unit: mg/L</p> <table border="1" data-bbox="608 510 1409 692"> <thead> <tr> <th rowspan="3"></th> <th colspan="7">Water Quality</th> </tr> <tr> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th rowspan="2">TP</th> </tr> <tr> <th>NH₄-N</th> <th>org-N</th> <th>NOx-N</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td>250</td> <td>450</td> <td>400</td> <td>37</td> <td>13</td> <td>0</td> <td>-</td> </tr> <tr> <td>Outlet</td> <td>10</td> <td>50</td> <td>10</td> <td>2</td> <td>0</td> <td>8</td> <td>-</td> </tr> <tr> <td>Removal rate</td> <td>96.0%</td> <td>88.9%</td> <td>97.5%</td> <td colspan="3">80.0%</td> <td></td> </tr> </tbody> </table> <p style="text-align: right;">Unit: mg/L</p> <table border="1" data-bbox="608 759 1409 969"> <thead> <tr> <th rowspan="3"></th> <th colspan="7">Water Quality Item</th> </tr> <tr> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th rowspan="2">TP</th> </tr> <tr> <th>NH₄-N</th> <th>org-N</th> <th>NOx-N</th> </tr> </thead> <tbody> <tr> <td>Inlet at Primary Clarifier</td> <td>250</td> <td>450</td> <td>400</td> <td>37</td> <td>13</td> <td>0</td> <td>-</td> </tr> <tr> <td>Removal rate</td> <td>30%</td> <td>30%</td> <td>60%</td> <td colspan="3">10.0%</td> <td>-</td> </tr> <tr> <td>Inlet at Reactor</td> <td>175</td> <td>315</td> <td>160</td> <td>33.3</td> <td>11.7</td> <td>0</td> <td>-</td> </tr> </tbody> </table>									Flow Rate			m3/d	m3/h	m3/sec	Average Daily	8,000	333	0.093	Max Daily	8,000	333	0.093	Max Hourly	18,000	667	0.208		Water Quality							BOD	COD	SS	T-N			TP	NH ₄ -N	org-N	NOx-N	Inlet	250	450	400	37	13	0	-	Outlet	10	50	10	2	0	8	-	Removal rate	96.0%	88.9%	97.5%	80.0%					Water Quality Item							BOD	COD	SS	T-N			TP	NH ₄ -N	org-N	NOx-N	Inlet at Primary Clarifier	250	450	400	37	13	0	-	Removal rate	30%	30%	60%	10.0%			-	Inlet at Reactor	175	315	160	33.3	11.7	0	-
	Flow Rate																																																																																																														
	m3/d	m3/h	m3/sec																																																																																																												
Average Daily	8,000	333	0.093																																																																																																												
Max Daily	8,000	333	0.093																																																																																																												
Max Hourly	18,000	667	0.208																																																																																																												
	Water Quality																																																																																																														
	BOD	COD	SS	T-N			TP																																																																																																								
				NH ₄ -N	org-N	NOx-N																																																																																																									
Inlet	250	450	400	37	13	0	-																																																																																																								
Outlet	10	50	10	2	0	8	-																																																																																																								
Removal rate	96.0%	88.9%	97.5%	80.0%																																																																																																											
	Water Quality Item																																																																																																														
	BOD	COD	SS	T-N			TP																																																																																																								
				NH ₄ -N	org-N	NOx-N																																																																																																									
Inlet at Primary Clarifier	250	450	400	37	13	0	-																																																																																																								
Removal rate	30%	30%	60%	10.0%			-																																																																																																								
Inlet at Reactor	175	315	160	33.3	11.7	0	-																																																																																																								
<p>2. Inlet Chamber (existing structure)</p> <p>[1] Design Condition</p> <p>(1) Design Wastewater Flow</p> <p>[2] Geometry</p> <p>(1) Number of Basins</p> <p>(2) Depth of Basin</p> <p>(3) Width of Basin</p> <p>(4) Length of Basin</p>	<p>Max Hourly = 18,000 m3/day</p> <p>= 0.208 m3/day</p> <p>1 Basin</p> <p>- m</p> <p>1.200 m</p> <p>1.200 m</p>																																																																																																														

3. Medium Screen Channel (existing structure)

[1] Design Condition

(1) Design Flow Rate	Max Hourly	=	18,000	m ³ /day
		=	0.208	m ³ /sec

[2] Geometry

(1) Inlet Gate

Number	1	Main	+	0	Bypass
Width	1.000	m			
Height	1.000	m			
Floor Level	+				m
Bottom	+	0.000			m
Influent Water Level	+	0.500			m
Velocity	0.208	/	1.000	/	0.500 / 1
	=	0.416	<	1.000	m/sec

(2) Bypass Gate

Number	0	Main	+	1	Bypass
Width	0.500	m			
Height	1.000	m			
Floor Level	+				m
Bottom	+	0.000			m
Influent Water Level	+	0.500			m
Velocity	0.208	/	0.500	/	0.500 / 1
	=	0.832	≡	1.000	m/sec

(3) Screen Channel

Number	1	Main	+	0	Standby
Width	1.000	m	approx.		
Side Water Depth	0.450	m	approx.		
Velocity	0.208	/	1.000	/	0.450 / 1
	=	0.462	≡	0.450	m/sec
Channel Dimensions	Width	1.0	m	×	Length
		×	SWD	0.5	m (Freeboard 0.5m)

(4) Bypass Screen Channel

Number	0	Main	+	1	Standby
Width	0.500	m	approx.		
Side Water Depth	0.450	m	approx.		
Velocity	0.208	/	0.500	/	0.450 / 1
	=	0.924	>	0.450	m/sec much higher than usual design
Channel Dimensions	Width	0.5	m	×	Length
		×	SWD	0.45	m (Freeboard 0.5m)

(5) Outlet Gate

Number	1	Main	+	0	Bypass
Width	1.000	m			
Height	1.000	m			
Floor Level	+				m
Bottom	+	0.000			m
Influent Water Level	+	0.500			m
Velocity	0.208	/	1.000	/	0.500 / 1
	=	0.416	<	1.000	m/sec

(6) Bypass Outlet Gate

Number	0	Main	+	1	Bypass
Width	0.500	m			
Height	1.000	m			
Floor Level	+				m
Bottom	+	0.000			m
Influent Water Level	+	0.500			m
Velocity	0.208	/	0.500	/	0.500 / 1
	=	0.832	<	1.000	m/sec

[3] Equipment								
(1) Inlet Gate								
Number	1	W	+	0	S			
Dimension	Width	1.0	m	×	Height	1.0	m	
Design Water Level	-	m						
(2) Bypass Gate								
Number	0	W	+	1	S			
Dimension	Width	0.5	m	×	Height	1.0	m	
Design Water Level	-	m						
(3) Medium Screens (Main Channel)								
Number	1	W	+	0	S			
Open Space	20	mm						
Bar Thickness	6	mm						
Channel Width	1.0	m	approx.					
Width of side plate	50	mm						
Side Water Depth	0.45	m						
Height of Blind Plate at the bottom	50	mm	approx.					
Velocity through screen	$0.208 / (20 + 6) / 20$			$0.900 / 6$		$0.400 / 1$		
	=	0.751	<	0.800	m/sec			
(3) Medium Screens (Bypass Channel)								
Number	0	W	+	1	S			
Open Space	50	mm						
Bar Thickness	6	mm						
Channel Width	0.5	m	approx.					
Side Water Depth	0.45	m	approx.					
Velocity through screen	$0.208 / (50 + 6) / 50$			$0.500 / 6$		$0.450 / 1$		
	=	1.035	>	0.800	m/sec			much higher than usual design
(4) Outlet Gate								
Number	1	W	+	0	S			
Dimension	Width	1.0	m	×	Height	1.0	m	
Design Water Level	-	m						
(5) Bypass Gate								
Number	0	W	+	1	S			
Dimension	Width	0.5	m	×	Height	1.0	m	
Design Water Level	-	m						

4. Grit Chamber (existing structure)	
[1] Design Condition	
(1) Design Flow Rate	Max Hourly = 18,000 m ³ /day = 0.208 m ³ /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	1000 m ³ /m ² /day = 0.0116 m/sec
(4) Average Velocity	0.3 m/sec
[2] Grit Chamber	Rectangular Grit Chamber
(1) Required Surface Area	0.208 / 0.0116 = 17.971 m ²
(2) Number of Chambers	1 S + 0 W
(3) Width	2.0 m approx..
(4) Length	7.0 m approx..
(5) Actual Surface Area	2.000 mW × 7.000 m = 14.000 m ² approx.. > 17.971 m ² higher than usual design
[3] Distribution Weir Gate 1	to distribute flow between existing line and new line
(1) Number	2 Main + 0 Bypass
(2) Weir Width	0.500 m
(3) Stroke	0.500 m
(4) Overflow Height as usually operation	(0.208 / 1.840 / 0.500 / 2) ^{2/3} = 0.234 < 0.500 m
(5) Overflow Height at maintenance of one line	(0.208 / 1.840 / 0.500 / 1) ^{2/3} = 0.371 < 0.500 m
[4] Distribution Weir Gate 2	to distribute flow between two existing Primary Clarifiers
(1) Number	2 Main + 0 Bypass
(2) Weir Width	0.300 m
(3) Stroke	0.400 m
(4) Overflow Height as usually operation	(0.104 / 1.840 / 0.300 / 2) ^{2/3} = 0.207 < 0.400 m
(5) Overflow Height at maintenance of one line	(0.104 / 1.840 / 0.300 / 1) ^{2/3} = 0.329 < 0.400 m

5-1. Primary Clarifier (existing structure)	
[1] Design Condition	
(1) Design Flow Rate	Average Daily = 4,000 m ³ /day = 0.046 m ³ /sec = 2.78 m ³ /min
(2) Type	Circular Clarifier
(3) Surface Overflow Rate required	35 m ³ /m ² /day
(4) Number of Basins	2 Basins
[2] Geometry	
(1) Surface Area required	4,000 / 35 = 114 m ²
(2) Surface Area required/Basin	114 / 2 = 57 m ²
(3) Side Water Depth	3.5 m
(4) Diameter required	8.5 m < Existing structure 14.6 m OK
(5) Basin Dimensions	Diameter 14.6 m Depth 3.0 m
[3] Sludge generated per day	
(1) Inlet TSS	450 mg/l
(2) Reduction in TSS	30%
(3) Outlet TSS	315 mg/l
(4) Solids removed from Primary Clarifiers	2,374 kg/day / 2 = 1,187 kg/day
(5) Solids Consistency	3.0 %
(6) Volume of Primary Sludge	Solids removed · $\frac{100}{\text{Solids Consistency}}$ · 10 ⁻³ = 40 m ³ /day
[4] Equipment	
(1) Primary Sludge Pumps	
Sludge withdrawal	12 Times/day
Running Time	0.50 hr/Time
Number	1 W + 1 S
Required Capacity	40 m ³ /day / 12.0 / 0.5 / 1
	= 6.6 m ³ /Hr ⇒ 10 m ³ /Hr /Unit

5-2. Primary Clarifier (new structure)	
[1] Design Condition	
(1) Design Flow Rate	Average Daily = 4,000 m ³ /day = 0.046 m ³ /sec = 2.78 m ³ /min
(2) Type	Circular Clarifier
(3) Surface Overflow Rate required	35 m ³ /m ² /day
(4) Number of Basins	1 Basins
[2] Geometry	
(1) Surface Area required	4,000 / 35 = 114 m ²
(2) Surface Area required/Basin	114 / 1 = 114 m ²
(3) Side Water Depth	3.5 m
(4) Diameter required	12.1 m < 14.6 m
(5) Basin Dimensions	Diameter 14.6 m × Depth 3.0 m OK
[3] Sludge generated per day	
(1) Inlet TSS	450 mg/L
(2) Reduction in TSS	30%
(3) Outlet TSS	315 mg/L
(4) Solids removed from Primary Clarifiers	2,374 kg/day / 2 = 1,187 kg/day
(5) Solids Consistency	3.0 %
(6) Volume of Primary Sludge	Solids removed × $\frac{100}{\text{Solids Consistency}}$ × 10 ⁻³ = 40 m ³ /day
[4] Equipment	
(1) Primary Sludge Pumps	
Sludge withdrawal	12 Times/day
Running Time	0.50 hr/Time
Number	1 W + 1 S
Required Capacity	40 m ³ /day / 12.0 / 0.5 / 1 = 6.6 m ³ /Hr ⇒ 10 m ³ /Hr /Unit

6-1. Reactor (existing Structure)

[1] Design Condition

(1) Design Flow

Q = 4,000 m³/day (summer)
 Q' = 4,000 m³/day (Winter)

(2) Design Sewage Quality

- Inlet BOD
- Outlet BOD
- Inlet S-BOD
- Inlet COD
- Inlet s-COD : sCOD
- Outlet S-COD : nbsCODe
- Inlet rbCOD
- hCOD/BOD
- Inlet bCOD : S_b
- Inlet nbCOD
- Inlet nbpCOD
- Inlet TSS
- Inlet VSS
- VSS_{COD}
- nbVSS
- TSS
- Inlet T-N
- Inlet TKN
- Inlet NH₄-N
- Inlet T-P
- Inlet Alkalinity as CaCO₃
- Outlet Kjeldahl N
- Outlet NH₄-N
- Outlet NO₃-N

175 mg/l
 10.0 mg/l
 117 mg/l assumed as 2/3 of BOD
 315 mg/l
 210 mg/l assumed as 2/3 of BOD
 23 mg/l =sCOD-1.6sBOD
 47 mg/l assumed as 5% of COD
 1.60
 280 mg/l
 35 mg/l
 12 mg/l =TCOD-hCOD-nbsCODe
 160 mg/l
 112 mg/l assumed as 70% of TSS
 0.94 gCOD/gVSS = TCOD-sCOD/VSS
 12.44 gnbVSS/m³ = nbpCOD/VSS_{COD}
 48.00 gnbVSS/m³ = TSS-VSS
 45 mg/l
 45 mg/l
 33.3 mg/l
 6 mg/l
 380 mg/l assumed
 2.0 mg/l
 2.0 mg/l
 8.0 mg/l

(3) Water Temperature

T = 20.0 °C

(4) Safety Factor for Nitrogen

SF = 1.5

(5) Return Sludge Concentration

R_s = 8,000 mg/l

(6) MLSS

X_{TSS} = 3,000 mg/l

(7) DO in the Reactor

2 mg/l

[2] Design of Nitrification Process

(1) Activated sludge design kinetic coefficients at 20°C

Coefficient	Unit	COD oxidation	NH4 oxidation	NO2 oxidation
μ _{max}	gVSS/gVSS · d	6.000	0.900	1.000
K _s , K _{NH4} , K _{NO2}	mg/L	8.000	0.500	0.200
Y	gVSS/g substrate oxidized	0.450	0.150	0.050
b	gVSS/gVSS · d	0.120	0.170	0.170
fd	unitless	0.150	0.150	0.150
K _{O2}	mg/L	0.200	0.500	0.900
θ Value				
μ _{max}	unitless	1.070	1.072	1.063
b	unitless	1.040	1.029	1.029
K _s , K _{NH4} , K _{NO2}	unitless	1.000	1.000	1.000

Wastewater Engineering Treatment and Resource Recovery Fifth Edition (METCALF & EDDY/AECOM)

(2) μ_{AOB}: Specific Growth Rate of Ammonia Oxidizing Bacteria (AOB)

μ_{AOB} = 0.3100 g/g · d = μ_{max, AOB} [S_{NH4} / (S_{NH4} + K_{NH4})] [S_O / (S_O + K_{O, AOB})] - b_{AOB}
 μ_{max, AOB, T} = 0.9000 g/g · d = μ_{max} * 1.072^(T-20) μ_{max} at 20°C = 0.900
 b_{AOB, T} = 0.1700 = b * 1.029^(T-20) b at 20°C = 0.170
 S_{NH4} = 1.0000 mg/l
 DO = 2.0000 mg/l
 K_{O, AOB} = 0.5000 mg/l

(3) Design SRT

SRT = 4.8387 day = 1/μ_{AOB} × SF

(4) Biomass production				
Px,vss	Px,vss=	406.469 kg/d	=Px,bio+Q(nbVSS)	
Px,TSS	Px,TSS=	661.415 kg/d	=Px,bio/0.85+Q(nbVSS)+Q(TSS ₀ -VSS ₀)	
S	S=	0.4606 mg/l	=Ks[1+b _H (SRT)]/[SRT(μ _m -b _H)-1]	
b _H	b _H =	0.1200	=b*1.04 ^(T-20)	b at 20°C = 0.120
Y _H	Y _H =	0.4500 gVSS/g bCOD		
μ _{m,T}	μ _{m,T} =	6.0000 g/g·d	=μ _{max} *1.04 ^(T-20)	μ _{max} at 20°C = 6.000
Y _n	Y _n =	0.150 gVSS/g Nox		
NOx	NOx=	32.300 mg/l	assumed	
P _{X,bio,vss}	P _{X,bio,vss} =	356.692 kg VSS/d	=Q·Y _H (S ₀ -S)/[1+b _H (SRT)]+f _d ·b _H ·QY _H (S ₀ -S)SRT/[1+b _H (SRT)]	
			+QY _n (Nox)/[1+b _{AOB} (SRT)]	
		318.333	=Q·Y _H (S ₀ -S)/[1+b _H (SRT)]	
		27.726	=f _d ·b _H ·QY _H (S ₀ -S)SRT/[1+b _H (SRT)]	
		10.633	=QY _n (Nox)/[1+b _{AOB} (SRT)]	
Nox'	Nox'=	32.299 mg/l	=TKN-Ne-0.12P _{X,bio} /Q	OK
(5) Required Aeration Tank Volume				
V _a	V _a =	1,067 m ³		
τ	τ=	6.40 hr	=V _a /Q×24	
(6) Fraction VSS=				
X _{VSS} ·V _a	X _{VSS} ·V _a =	1,967 kg VSS	=P _{X,vss} ·SRT	
X _{TSS} ·V _a	X _{TSS} ·V _a =	3,200 kg TSS	=P _{X,TSS} ·SRT	
(7) MLVSS				
	MLVSS=	1844 mg/L		
(8) F/M				
	F/M=	0.356 kgBOD/kgMLVSS		
(9) BODloading				
	BODloading	0.656 kg/m ³ ·d		
(10) Observed Yield				
Y _{obs,TSS}	Y _{obs,TSS} =	0.946 gTSS/gBOD		
Y _{obs,VSS}	Y _{obs,VSS} =	0.582 gVSS/gBOD		
bCODremoved	bCODremov	1,118 kg/d		
(11) Effluent NH ₄ -N				
b _{NOB}	b _{NOB} =	0.1700	=Ks[1+b _{NOB} (SRT)]/[SRT(μ _{NOB} -b _{NOB})-1]	
μ _{m,T}	μ _{m,T} =	0.9000 g/g·d	=μ _{max} *1.029 ^(T-20)	b at 20°C = 0.170
μ _{AOB}	μ _{AOB} =	0.7200 g/g·d	=μ _{max} *1.072 ^(T-20)	μ _{max} at 20°C = 0.900
	S ₀ =	2.000 mg/l	=μ _{max,NOB} [S ₀ /(S ₀ +K _{O2,NOB})]	
	K _{O2,NOB} =	0.500 mg/l		
(12) Ratio of Return Sludge				
	8,000·Rr/(1+Rr)=	3,000 mg/L		
	3,000/(8,000-3,000)=	0.60		
	Rr =	0.60		

[3] Design of Denitrification Process																																										
(1)	Active biomass concentration	$X_b = \frac{Q \cdot (SRT) \cdot V \cdot Y_H (S_0 - S) [1 + b_H (SRT)]}{1 + b_H (SRT)}$	=	1,443.87	mg/l																																					
(2)	IR ratio	$IR = \frac{NOx}{Nc} - 1.0 \cdot R$	=	2.44																																						
(3)	The amount of NCG-N fed to the anoxic tank	$Nox\ feed = (IR + R) \cdot Q \cdot Nc$	=	97,197	kg/d																																					
(4)	The anoxic tank volume	$V_{nor} = \frac{Nox\ feed}{F/M_b}$	=	667	m ³	$t_{nor} = 4.000$	h																																			
(5)	F/M _b	$F/M_b = \frac{Nox\ feed}{V_{nor} \cdot X_b}$	=	0.73	g/g·d																																					
(6)	Fraction of rbCOD	$rbCOD/bCOD = \frac{b_0}{b_0 + b_1} \cdot \ln(F/M_b)$	=	16.88%																																						
<table border="1"> <thead> <tr> <th rowspan="2">Percent rbCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b₀</th> <th>b₁</th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>								Percent rbCOD(%)	SDNR equation coefficients		b ₀	b ₁	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162															
Percent rbCOD(%)	SDNR equation coefficients																																									
	b ₀	b ₁																																								
10	0.186	0.078																																								
20	0.213	0.118																																								
30	0.235	0.141																																								
40	0.242	0.152																																								
50	0.270	0.162																																								
(7)	SDNR ₂₀ Specific Denitrification Rate base on biomass concentration at 20 °C	$SDNR_b = b_0 + b_1 \ln(F/M_b)$	=	0.175	g/g·d																																					
		$b_0 = 0.213$																																								
		$b_1 = 0.118$																																								
(8)	SDNR _b corrected SNDR at design temperature and Internal Recycle	$SDNR_b = SDNR_{20} - 0.029 \ln(F/M_b) - 0.012$	=	0.103	g/g·d	IR=3-4																																				
		$= SDNR_{20} - 0.0166 \ln(F/M_b) - 0.078$				IR=2																																				
		$SDNR_t = SDNR_b \cdot \theta^{(t-20)}$	=	0.175	g/g·d	$\theta = 1.026$																																				
(9)	SDNR: base on MLVSS	$SDNR = \frac{SDNR_b \cdot MLVSS_b}{MLVSS}$	=	0.080	g/g·d																																					
(10)	NOR: nitrate-nitrogen removal rate	$NOR = V_{nor} \cdot SDNR_b \cdot X_b$	=	98,857.32	g/d																																					
		$> Nox\ feed = 97,197$					OK																																			
(11)	Alkalinity to be added to maintain pH7	-166.13	mg/l	<	0	No Alkalinity needed	OK																																			
		Influent Alk	380.00	mg/l																																						
		Alk used	230.62	mg/l	=	7.14 × Nox																																				
		Alk produce	86.75	mg/l	=	3.57 × (NOx - NOxe)																																				
		Alk to maint	70.00	mg/l																																						
[4] Geometry																																										
(1)	Determination of Dimensions of Basins																																									
	Anoxic tank	Diameter	15.6	Depth	3.5	Basins	2																																			
	Aerobic tank	Width	9.5	Length	10.5	Depth	5.5																																			
						Basins	2																																			
(2)	Volume and HRT of Basins																																									
		<table border="1"> <thead> <tr> <th>Item</th> <th>unit</th> <th>Anoxic</th> <th>Aerobic</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Cross Section</td> <td>m²</td> <td>191.1</td> <td>51.3</td> <td></td> </tr> <tr> <td>Depth/Length</td> <td>m</td> <td>3.5</td> <td>10.5</td> <td>14.0</td> </tr> <tr> <td>Volume per Basin</td> <td>m³</td> <td>669</td> <td>538</td> <td>1,207</td> </tr> <tr> <td>Total Volume</td> <td>m³</td> <td>1,338</td> <td>1,076</td> <td>2,414</td> </tr> <tr> <td>Actual HRT</td> <td>hour</td> <td>8.03</td> <td>6.46</td> <td>14.49</td> </tr> <tr> <td>Required HRT</td> <td>hour</td> <td>4.00</td> <td>6.40</td> <td>10.40</td> </tr> </tbody> </table>					Item	unit	Anoxic	Aerobic	Total	Cross Section	m ²	191.1	51.3		Depth/Length	m	3.5	10.5	14.0	Volume per Basin	m ³	669	538	1,207	Total Volume	m ³	1,338	1,076	2,414	Actual HRT	hour	8.03	6.46	14.49	Required HRT	hour	4.00	6.40	10.40	OK
Item	unit	Anoxic	Aerobic	Total																																						
Cross Section	m ²	191.1	51.3																																							
Depth/Length	m	3.5	10.5	14.0																																						
Volume per Basin	m ³	669	538	1,207																																						
Total Volume	m ³	1,338	1,076	2,414																																						
Actual HRT	hour	8.03	6.46	14.49																																						
Required HRT	hour	4.00	6.40	10.40																																						

[5] Equipment					
(1)	Ras Pumps				
	Ras Ratio	60	%		
	Required Capacity	4,000	m ³ /day ×	60% / 24 / 2	
		= 50	m ³ /Hr ⇒	50	m ³ /Hr
	Number	2	Work +	1	Standby
(2)	Circulation Pumps				
	Circulation Ratio	244	%		
	Required Capacity	4,000	m ³ /day ×	244% / 24 / 2	
		= 203	m ³ /Hr ⇒	210	m ³ /Hr
	Number	2	Work +	2	Standby

6-2. Reactor (new Structure)

[1] Design Condition

(1) Design Flow

Q = 4,000 m³/day (summer)
 Q' = 4,000 m³/day (Winter)

(2) Design Sewage Quality

- Inlet BOD
- Outlet BOD
- Inlet S-BOD
- Inlet COD
- Inlet S-COD : sCOD
- Outlet S-COD : nbsCODe
- Inlet rbCOD
- bCOD/BOD
- Inlet bCOD : S_b
- Inlet nbCOD : nbpCOD
- Inlet TSS
- Inlet VSS : VSS_{cod}
- :nbVSS
- :tTSS
- Inlet T-N
- Inlet TKN
- Inlet NH₄-N
- Inlet T-P
- Inlet Alkalinity as CaCO₃
- Outlet Kjeldahl N
- Outlet NH₄-N
- Outlet NO₃-N

175 mg/l
 10.0 mg/l
 117 mg/l (assumed as 2/3 of BOD)
 315 mg/l
 210 mg/l (assumed as 2/3 of BOD)
 23 mg/l (=sCOD-1.6sBOD)
 47 mg/l (assumed as 5% of COD)
 1.60
 280 mg/l
 35 mg/l
 12 mg/l (=TCOD-bCOD-nbsCODe)
 160 mg/l
 112 mg/l (assumed as 70% of TSS)
 0.94 gCOD/gVSS = TCOD-sCOD/VSS
 12.44 gnbVSS/m³ = nbpCOD/VSS_{cod}
 48.00 gnbVSS/m³ = TSS-VSS
 45 mg/l
 45 mg/l
 33.3 mg/l
 6 mg/l
 380 mg/l (assumed)
 2.0 mg/l
 2.0 mg/l
 8.0 mg/l
 T = 20.0 °C
 SF = 1.5
 Rv = 8,000 mg/l
 X_{TSS} = 3,000 mg/l
 2 mg/l

(3) Water Temperature

(4) Safety Factor for Nitrogen

(5) Return Sludge Concentration

(6) MLSS

(7) DO in the Reactor

[2] Design of Nitrification Process

(1) Activated sludge design kinetic coefficients at 20 °C

Coefficient	Unit	COD oxidation	NH ₄ oxidation	NO ₂ oxidation
μ _{max}	gVSS/gVSS · d	6.000	0.900	1.000
K _s , K _{NH₄} , K _{NO₂}	mg/L	8.000	0.500	0.200
Y	gVSS/g substrate oxidized	0.450	0.150	0.050
b	gVSS/gVSS · d	0.120	0.170	0.170
fd	unitless	0.150	0.150	0.150
K _{O₂}	mg/L	0.200	0.500	0.900
θ Value				
μ _{max}	unitless	1.070	1.072	1.063
b	unitless	1.040	1.029	1.029
K _s , K _{NH₄} , K _{NO₂}	unitless	1.000	1.000	1.000

Wastewater Engineering Treatment and Resource Recovery Fifth Edition (METCALF & EDDY/AECOM)

(2) μ_{AOB}: Specific Growth Rate of Ammonia Oxidizing Bacteria (AOB)

- μ_{max, AOB, T}
- b_{AOB, T}
- S_{NH₄}
- DO
- K_{0, AOB}

μ_{AOB} = 0.3100 g/g · d = μ_{max, AOB} [S_{NH₄} / (S_{NH₄} + K_{NH₄})] [S_O / (S_O + K_{0, AOB})] - b_{AOB}
 μ_{max, AOB, T} = 0.9000 g/g · d = μ_{max} * 1.072^(T-20) μ_{max} at 20°C = 0.900
 b_{AOB, T} = 0.1700 = b * 1.029^(T-20) b at 20°C = 0.170
 S_{NH₄} = 1.0000 mg/l
 DO = 2.0000 mg/l
 K_{0, AOB} = 0.5000 mg/l

(3) Design SRT

SRT = 4.8387 day = 1/μ_{AOB} × SF

(4) Biomass production				
Px,vss	Px,vss=	406.469 kg /d	=Px,bio+Q(nbVSS)	
Px,TSS	Px,TSS=	661.415 kg /d	=Px,bio/0.85+Q(nbVSS)+Q(TSS ₀ -VSS ₀)	
S	S=	0.4606 mg/l	=K _s [1+b _H (SRT)]/[SRT(μ _m -b _H)-1]	
b _H	b _H =	0.1200	=b*1.04 ^(T-20)	b at20°C= 0.120
Y _H	Y _H =	0.4500 gVSS/g bCOD		
μ _{m,T}	μ _{m,T} =	6.0000 g/g·d	=μ _{max} *1.04 ^(T-20)	μ _{max} at20°C= 6.000
Y _n	Y _n =	0.150 gVSS/g Nox		
NOx	NOx=	32.300 mg/l	assumed	
Px,bio,vss	Px,bio,vss=	356.692 kg VSS/d	=Q·Y _H (S ₀ -S)/[1+b _H (SRT)]+f _d ·b _H ·QY _H (S ₀ -S)SRT/[1+b _H (SRT)] +QY _n (Nox)/[1+b _{AOB} (SRT)]	
		318.333	=Q·Y _H (S ₀ -S)/[1+b _H (SRT)]	
		27.726	=f _d ·b _H ·QY _H (S ₀ -S)SRT/[1+b _H (SRT)]	
		10.633	=QY _n (Nox)/[1+b _{AOB} (SRT)]	
Nox'	Nox'=	32.299 mg/l	=TKN-Ne-0.12Px,bio/Q	NOx OK
(5) Required Aeration Tank Volume				
V _a	V _a =	1,067 m ³		
τ	τ=	6.40 hr	=V _a /Q×24	
(6) FractionVSS=				
X _{VSS} ·V _a	X _{VSS} ·V _a =	1,967 kg VSS	=Px,vss·SRT	
X _{TSS} ·V _a	X _{TSS} ·V _a =	3,200 kg TSS	=Px,TSS·SRT	
(7) MLVSS				
	MLVSS=	1844 mg/L		
(8) F/M				
	F/M=	0.356 kgBOD/kgMLVSS		
(9) BODloading				
	BODloading	0.656 kg/m ³ ·d		
(10) Observed Yield				
Y _{obs,TSS}	Y _{obs,TSS} =	0.946 gTSS/gBOD		
Y _{obs,VSS}	Y _{obs,VSS} =	0.582 gVSS/gBOD		
bCODremoved	bCODremov	1,118 kg/d		
(11) Effluent NH₄-N				
NH ₄ -N	NH ₄ -N=	0.5485 mg/l	=K _s [1+b _{NOB} (SRT)]/[SRT(μ _{NOB} -b _{NOB})-1]	
b _{NOB}	b _{NOB} =	0.1700	=b*1.029 ^(T-20)	b at20°C= 0.170
μ _{m,T}	μ _{max,NOB,T} =	0.9000 g/g·d	=μ _{max} *1.072 ^(T-20)	μ _{max} at20°C= 0.900
μ _{AOB}	μ _{NOB,T} =	0.7200 g/g·d	=μ _{max,NOB} [S ₀ /(S ₀ +K _{O2,NOB})]	
	S ₀ =	2.000 mg/l		
	K _{O2,NOB} =	0.500 mg/l		
(12) Ratio of Return Sludge				
	8,000·R _r /(1+R _r)=	3,000 mg/L		
	3,000/(8,000-3,000)=	0.60		
	R _r =	0.60		

[3] Design of Denitrification Process																																				
(1) Active biomass concentration	$X_b = \frac{Q \cdot (SRT) / V \cdot Y_{11}(S_0 - S) [1 + b_{11}(SRT)]}{1.44387} \text{ mg/l}$																																			
(2) IR ratio	$IR = \frac{NOx}{Nc - 1.0 - R} = 2.44$																																			
(3) The amount of NO ₃ -N fed to the anoxic tank	$\text{Nox feed} = (IR + R) \cdot Q \cdot Nc = 97,197 \text{ kg/d}$																																			
(4) The anoxic tank volume	$V_{anox} = 667 \text{ m}^3 \quad \tau_{anox} = 4.000 \text{ h}$																																			
(5) F/M _b	$F/M_b = 0.73 \text{ g/g} \cdot \text{d}$																																			
(6) Fraction of rbCOD	$rbCOD/bCOD = 16.88\%$ <table border="1" style="margin: 10px auto;"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b₀</th> <th>b₁</th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>	Percent rdCOD(%)	SDNR equation coefficients		b ₀	b ₁	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162															
Percent rdCOD(%)	SDNR equation coefficients																																			
	b ₀	b ₁																																		
10	0.186	0.078																																		
20	0.213	0.118																																		
30	0.235	0.141																																		
40	0.242	0.152																																		
50	0.270	0.162																																		
(7) SDNR _b Specific Denitrification Rate base on biomass concentration at 20 °C	$\text{SDNR}_b = 0.175 \text{ g/g} \cdot \text{d} = b_0 + b_1 [\ln(F/M_b)]$ <p> $b_0 = 0.213$ $b_1 = 0.118$ </p>																																			
(8) SDNR _b corrected SNDR at design temperature and Internal Recycle	$\text{SDNR}_t = 0.103 \text{ g/g} \cdot \text{d} = \text{SDNR}_b - 0.029 \ln(F/M_b) - 0.012$ $= \text{SDNR}_b - 0.0166 \ln(F/M_b) - 0.078$ <p> $\text{SDNR}_t = 0.175 \text{ g/g} \cdot \text{d} = \text{SDNR}_t \cdot \theta^{(T-20)}$ $\theta = 1.026$ </p>																																			
(9) SDNR: base on MLVSS	$\text{SDNR} = 0.080 \text{ g/g} \cdot \text{d} = \text{SDNR}_b (MLVSS_b / MLVSS)$																																			
(10) NOR nitrate-nitrogen removal rate	$\text{NOR} = 98,857.32 \frac{\text{g/d}}{\text{m}^3} = \frac{V_{anox} \cdot \text{SDNR}_b \cdot X_b}{\text{Nox feed}} = 97,197 \frac{\text{g/d}}{\text{m}^3}$																																			
(11) Alkalinity to be added to maintain pH7	$-166.13 \text{ mg/l} < 0 \quad \text{No Alkalinity needed} \quad \text{OK}$ <p> Influent Alk: 380.00 mg/l Alk used: 230.62 mg/l = 7.14 × Nox Alk produce: 86.75 mg/l = 3.57 × (NOx - NO_xe) Alk to maint: 70.00 mg/l </p>																																			
[4] Geometry																																				
(1) Determination of Dimensions of Basins	<table border="1"> <thead> <tr> <th></th> <th>Width</th> <th>Length</th> <th>Depth</th> <th>Basins</th> </tr> </thead> <tbody> <tr> <td>Anoxic tank</td> <td>12.0</td> <td>10.5</td> <td>5.5</td> <td>1</td> </tr> <tr> <td>Aerobic tank</td> <td>12.0</td> <td>16.5</td> <td>5.5</td> <td>1</td> </tr> </tbody> </table>		Width	Length	Depth	Basins	Anoxic tank	12.0	10.5	5.5	1	Aerobic tank	12.0	16.5	5.5	1																				
	Width	Length	Depth	Basins																																
Anoxic tank	12.0	10.5	5.5	1																																
Aerobic tank	12.0	16.5	5.5	1																																
(2) Volume and HRT of Basins	<table border="1"> <thead> <tr> <th>Item</th> <th>unit</th> <th>Anoxic</th> <th>Aerobic</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Cross Section</td> <td>m²</td> <td>65.0</td> <td>65.0</td> <td></td> </tr> <tr> <td>Length</td> <td>m</td> <td>10.5</td> <td>16.5</td> <td>27.0</td> </tr> <tr> <td>Volume per Basin</td> <td>m³</td> <td>683</td> <td>1,073</td> <td>1,755</td> </tr> <tr> <td>Total Volume</td> <td>m³</td> <td>683</td> <td>1,073</td> <td>1,755</td> </tr> <tr> <td>Actual HRT</td> <td>hour</td> <td>4.10</td> <td>6.44</td> <td>10.54</td> </tr> <tr> <td>Required HRT</td> <td>hour</td> <td>4.00</td> <td>6.40</td> <td>10.40</td> </tr> </tbody> </table>	Item	unit	Anoxic	Aerobic	Total	Cross Section	m ²	65.0	65.0		Length	m	10.5	16.5	27.0	Volume per Basin	m ³	683	1,073	1,755	Total Volume	m ³	683	1,073	1,755	Actual HRT	hour	4.10	6.44	10.54	Required HRT	hour	4.00	6.40	10.40
Item	unit	Anoxic	Aerobic	Total																																
Cross Section	m ²	65.0	65.0																																	
Length	m	10.5	16.5	27.0																																
Volume per Basin	m ³	683	1,073	1,755																																
Total Volume	m ³	683	1,073	1,755																																
Actual HRT	hour	4.10	6.44	10.54																																
Required HRT	hour	4.00	6.40	10.40																																

[5] Equipment					
(1) Ras Pumps					
Ras Ratio	60	%			
Required Capacity	4,000	m ³ /day ×	60%	/ 24 / 1	
	= 100	m ³ /Hr ⇒	100	m ³ /Hr	
Number	1	Work +	1	Standby	
(2) Circulation Pumps					
Circulation Ratio	244	%			
Required Capacity	4,000	m ³ /day ×	244%	/ 24 / 1	
	= 406	m ³ /Hr ⇒	410	m ³ /Hr	
Number	1	Work +	1	Standby	

7. Air Requirement at Average Flow	
11 Design Condition	
(1) AOR :R ₀	R ₀ = = 1,878 kg/day = 78.3 kg/h
Q _{in} : Design Average Flow m ³ /d	8,000
Inlet bCOD :S ₀	280 mg/l
S=	S= 0.461 mg/l
N _{ox} =	N _{ox} = 32,300 mg/l
P _{x, bio} =	P _{x, bio} = 692.1 kg VSS/d does not include nitrifying bacteria
R ₀ =	R ₀ = Q(S ₀ -S-k(N _{ox} -NO _{xc}))-1.42P _{x, bio} +4.57Q·NO _x
R ₀ =	R ₀ = 1,878 kg O ₂ /d
	k= 2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{\text{AOR} \times C_s \cdot a \times 1.024^{20-T}}{\alpha \times F \cdot (\beta \cdot C_{sw} / C_s \cdot (P_b / P_a) a - C_A)}$
	C _s : Saturated DO at sea level and 20 °C 9.09 mg/L
	C _{sw} : Saturated DO at sea level and operating Temperature 6.93 mg/L at 35 °C
	20-T : -15.0 1.024 ^{20-T} : 0.7006
	C _A : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1+0.40D _l /Pa 1.19357
	D _l : Tank Liquid Depth 5.00 m
	P _a : Standard absolute pressure at s 10.332 m
	P _b : Absolute pressure at Plant Site Elevation m
	P _l /P _a : exp[-gM(z _b -z _a)/R*T] 0.992
	g : Acceleration due to Gravity 9.80665 m/s ²
	M : Mole of Air 28.97 kg/kg-mole
	z _b : Plant Site Elevation 70 m
	z _a : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 308.15 Kelvin
	α : relative Transfer Rate to clean W _a 0.65
	β : relative DO Saturation to clean W _z 0.95
	F : Diffuser Fouling Factor 0.90
	= $\frac{14,279}{3.3913} = 4,210.52 \text{ kg/day}$
(3) SOTE for the above Effective Aeration Depth	30.5 %
(4) Fraction of O ₂ in Air	23.18 %
(5) Specific Gravity of Air at Standard Condition	1.293
(6) Safety Factor	10%
(7) Air required at Field Conditions	= 54,378 m ³ /day = 2,265.7 m ³ /hr

[2] Equipment					
(1) Air Blower					
Number	2	W	+	1	S
Required Capacity	2265.7	m ³ /Hr	/	2	
	= 1132.9	m ³ /Hr	⇒	1200	m ³ /Hr /Unit
Pressure	65	kPa			
Safety Factor	10	%			
Heat capacity ratio	1.4				
Atmospheric pressure at site elevation	100.542	kPa			
Total inlet pressure	98.542	kPa			
Volume rate of flow at inlet point	20.560	m ³ /min			
Total discharge pressure	165.542	kPa			
Overall adiabatic efficiency	0.65				
Inlet air temperature (min.)	15	°C			
Shaft power	29.552	kW			
Rated Output of Motor	32.507	kW	⇒	37	kW

<p>8-1. Secondary Clarifier (existing structure)</p> <p>[1] Design Condition</p> <p>(1) Design Flow Rate</p> <p>(2) Type</p> <p>(3) Surface Overflow Rate required</p> <p>(4) Number of Basins</p> <p>[2] Geometry</p> <p>(1) Surface Area required</p> <p>(2) Surface Area required/Basin</p> <p>(3) Side Water Depth</p> <p>(4) Diameter required</p> <p>(5) Basin Dimensions</p>	<p>Average Daily = 4,000 m³/day = 0.046 m³/sec = 2.78 m³/min</p> <p>Circular Clarifier 25 m³/m²/day</p> <p>2 Basins</p> <p>4,000 / 25 = 160 m² 160 / 2 = 80 m² 3.5 m 10.1 m < Existing structure 16.0 m Diameter 16.0 m > Depth 3.5 m</p> <p style="text-align: right;">OK</p>
<p>8-2. Secondary Clarifier (New structure)</p> <p>[1] Design Condition</p> <p>(1) Design Flow Rate</p> <p>(2) Type</p> <p>(3) Surface Overflow Rate required</p> <p>(4) Number of Basins</p> <p>[2] Geometry</p> <p>(1) Surface Area required</p> <p>(2) Surface Area required/Basin</p> <p>(3) Side Water Depth</p> <p>(4) Diameter required</p> <p>(5) Basin Dimensions</p>	<p>Average Daily = 4,000 m³/day = 0.046 m³/sec = 2.78 m³/min</p> <p>Circular Clarifier 25 m³/m²/day</p> <p>1 Basins</p> <p>4,000 / 25 = 160 m² 160 / 1 = 160 m² 3.5 m 14.3 m < Existing structure 16.0 m Diameter 16.0 m > Depth 3.5 m</p> <p style="text-align: right;">OK</p>

9. Chlorination	
[1] Design Condition	
(1) Design Flow Rate	Average Daily Flow 8,000 m ³ /day
(2) Contact Time	30 min
(3) Type of Chlorine	Bleaching Powder (Availitive chlorine 70%)
(4) Design Chlorine Dosage Rate	10 mg/L
(5) Required Chlorine per day	Average Daily Flow / 1000 × Design Chlorine Dosage Rate = 80.0 kg/d = 3.33 kg/h
(6) Consumption per day	114.3 kg/d as Bleaching Powder
[2] Chlorination Contact Tank	
(1) Volume required	Average Daily Flow / 1440 × Contact Time = 166.7 m ³
(2) Nos. of lanes	7 lanes
(3) Width of lane	1.00 m
(4) Length of lane	24.00 m
(5) Side Water Depth	1.00 m
(6) Nos. of Tanks	1 tank
(7) Total Width of Tank	10.80 m Approx..
(8) Average Velocity	Average Daily Flow / 86400 / Width / Depth = 8,000 / 86400 / 1.00 / 1.00 = 0.093 m/sec
(9) Total Volume	Width × Length × Depth × Nos. of lanes × Nos. of Tanks = 1.0 m × 24.0 m × 1 × 7 × 1 m = 168 m ³ > 166.7 m ³
[3] Equipment	
(1) Chlorine Solution Tank	
Number	2 W + 0 S
Chlorine concentration	2 %
Gravity of dissolved chlorine	1.10
Required solution volume	80.00 kg/d × 100 / 2 / 1.10 / 1000 = 3.64 m ³ /d = 145 l/h
Dimension of Tank	1.2 mW × 1.2 mL × 1.5 mSWD
Volume of Tank	2.2 m ³ /tank
Total Volume of Tanks	4.3 m ³ (Duration= 1.19 day)
(2) Mixer for Chlorine Solution Tank	
Number	2 W + 0 S
(3) Chlorine Dosing Pump	
Number	1 W + 1 S
Capacity	145 l/h / 1 145 l/h/unit ⇒ 145 l/h/unit

10. Dechlorination	
[1] Design Condition	
(1) Design Flow Rate	Average Daily Flow 8,000 m ³ /day
(2) Contact Time	10 min
(3) Type of Dechlorine	Sodium Thiosulfate (Na ₂ S ₂ O ₃ 5H ₂ O)
(4) Free Residual Chlorine	1.0 mg/L assumed value
(5) Consumption per day	Average Daily Flow / 1000 * Free Residual Chlorine * 1.19
	* 2 (safety factor)
	= 19.0 kg/d
	= 0.79 kg/h
[2] Dechlorination Contact Tank	
(1) Volume required	Average Daily Flow / 1440 * Contact Time
	= 55.6 m ³
(2) Width of lane	Contact Time 10 min
(3) Length of lane	10.00 m
(4) Side Water Depth	8.00 m
(5) Nos. of Tanks	1 tank
(6) Total Volume	Width * Length * Depth * Nos. of lanes * Nos. of Tanks
	= 10.0 m * 6.0 m * 55.6 m ³
	= 60 m ³
[3] Equipment	
(1) Dechlorine Solution Tank	
Number	2 W + 0 S
Dechlorine concentration	10 %
Gravity of dissolved dechlorine	1.10
Required solution volume	19.04 kg/d * 100 / 10 / 1.10 / 1000
	= 0.17 m ³ /d
	= 7 l/h
Volume of Tank	0.5 m ³ /tank
Total Volume of Tanks	1.0 m ³ (Duration= 5.78 day)
(2) Mixer for Dechlorine Solution Tank	
Number	2 W + 0 S
(3) Dechlorine Dosing Pump	
Number	1 W + 1 S
Capacity	6.92 l/h / 1
	6.92 l/h/unit ⇒ 7 l/h/unit

11. Thickened Sump	
[1] Design Condition	
(1) Inlet Solids	3,189 kg/day
(2) Inlet Sludge Volume	80 m ³ /d
[2] Geometry	
(1) Sludge withdraw	12 Times/day
(2) Required Sump Volume	66.4 m ³
(3) Number	1 Basins
(4) Width	2.0 m
(5) Length	2.0 m
(6) Side Water Depth	2.5 m
(7) Actual Sump Volume	2.0 × 2.0 × 2.5 × 1
	= 10.0 m ³
[3] Equipment	
(1) Digested Sludge Feed Pumps	
Transfer Time	6.00 Hr
Number	1 W + 1 S
Required Capacity	80 m ³ / 6.0
	= 13.3 m ³ /h ⇒ 15 m ³ /h/unit


12. Sludge Digester (existing structure)	
[1] Design Condition	
(1) Quantity of Thickened Sludge generated	3,189 kg/day
(2) Inlet Solids Consistency	4.00 %
(3) Volume of Thickened Sludge	$\text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3}$ $= 80 \text{ m}^3/\text{day}$
(4) Ratio of VSS	75 %
(5) Total VSS	= 2,391 kg/day
(6) Total inorganic Sludge	= 797 kg/day
(7) Retention Time	20 days
(8) % Destruction in VSS	50 %
(9) VSS destroyed	= 1,196 kg/day
(10) Quantity of Digested Sludge generated	= 1,993 kg/day
(11) Solids Consistency	2.5000 %
(12) Volume of Digested Sludge	$\text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3}$ $= 80 \text{ m}^3/\text{day}$
[2] Geometry	
(1) Volume required	1,594 m ³
(2) No. of Basins	2 Basins
(3) Volume required per Basin	= 797 m ³
(4) Depth provided	9.8 m
(5) Area required per Basin	= 82 m ²
(6) Diameter required per Basin	= 10.2 m
(7) Basin Dimensions	$\text{Diameter } 18.0 \text{ m} \times \text{Depth } 9.8 \text{ m}$ $\times 2 \text{ Basins} = 4,975 \text{ m}^3$
[3] Equipment	
(1) Mixers for Digestion Tanks	
Capacity	2487 m ³
Number	2 W + 0 S
(2) Digested Sludge Transfer Pumps	
Transfer Time	8.00 Hr
Number	2 W + 2 S
Required Capacity	$\frac{80 \text{ m}^3}{5.0 \text{ m}^3/\text{h}} \Rightarrow \frac{8.0}{5} \text{ m}^3/\text{h/Unit} \times 2$


13. Biogas Power Generation	
[1] Design Condition	
(1) Biogas generated per Kg of VSS destroyed	0.9 m ³ /kg
(2) VSS destroyed	1,196 kg/dny
(3) Biogas generated	1,076 m ³ /day
(4) Gas Holder Volume required	25 %
=	269 m ³
(5) No. of Units provided	2
(6) Volume of each Gas Holder required	= 135 m ³
[2] Biogas Holder (Existing)	
(1) Biogas Holder (Existing)	Diameter 7.5 m × height 4.0 m × 2 Basins
Sphere	$V = \pi/4 \cdot D^2 \cdot h$
=	353 m ³ > 269 m ³ OK
[3] Equipment	
(1) Biogas Power generators	
Biogas Generation	0.012 m ³ /sec
Biogas Caloric Value	22,000 KJ/m ³
Biogas Engine Conversion Efficiency	35.0 %
Number	2 W + 1 S
Power Generation	0.012 m ³ /sec × 22000 KJ/m ³ × 0.35 / 2
=	48.0 kW ⇒ 70 kW
(2) Desulfurization Equipment	
Biogas Generation	44.84 m ³ /hr
Peak Ratio	1.5
Number	1 W + 0 S
Required Capacity	44.84 m ³ /Hr × 1.5 / 1
=	67.3 m ³ /Hr ⇒ 70 m ³ /Hr /Unit
(3) Biogas Blowers	
Biogas Generation	44.84 m ³ /hr
Safety Factor	1.5
Number	1 W + 1 S
Required Capacity	44.84 m ³ /Hr × 1.5 / 1
=	67.3 m ³ /Hr ⇒ 70 m ³ /Hr /Unit
(4) Biogas Flare	
Biogas Generation	1,076 m ³ /sec
Operating hours	24 Hr
Safety Factor	150.0 %
Number	1 W + 0 S
Power Generation	67 m ³ /hr ⇒ 70 m ³ /hr

14. Centrifuge	
[1] Design Condition	
(1) Type of Dewatering	Centrifuge
(2) Quantity of Digested Sludge generated	1,993 kg/day
(3) Design Polyelectrolyte Dosage	1.5 kg/t-DS·day
(4) Volume of Digested Sludge	79.7 m ³ /day
(5) Consistency of Dewatered Sludge	82.00 %
(6) Operation Time	8 hours/day (6 days per week)
[2] Volume of Centrifuges	
	$\frac{\text{Digested Solids}}{\text{Operation Time} \times \text{No.}} \times \text{Operation/week}$ $= \frac{79.7}{8 \times 1} \times \frac{7}{6} = 11.6$ $\rightarrow 12 \text{ m}^3/\text{hour}$
[3] Dewatered Solids	
	$\text{Digested Sludge} \times (1 + \text{Injection Rate})$ $= 1,993 \times (1 + 0.0015)$ $= 1,996 \text{ kg/day}$
[4] Dewatered Cake Volume	
	$\text{Dewatered Solids} \times \frac{100}{100 - \text{Moisture Content}} \times \frac{7}{6 \text{ days per week}}$ $= 1,996 \times \frac{100}{100 - 82} \times \frac{7}{6}$ $= 12.94 \text{ t/day}$
[5] Polyelectrolyte	
(1) Design Polyelectrolyte Dosage	1.5 kg/t-DS·day
(2) Required Polyelectrolyte	2.99 kg/day
(3) Dissolving concentration	0.20 %
(4) Volume of Polyelectrolyte solution	1.49 m ³ /day
[6] Equipment	
(1) Centrifuge	
Capacity	12 m ³ /hr
Number	1 W + 1 S
(2) Centrifuge Feed Pumps	
Capacity	12 m ³ /h
Number	1 W + 1 S
(3) Polyelectrolyte Dosing Pumps	
Volume of Polyelectrolyte solution	1.49 m ³ /day
Operation Time	8 hours/day (6 days per week)
Safety Factor	1.5
Number	1 W + 1 S
Required Capacity	$1.49 \text{ m}^3/\text{d} \times 8.0 \text{ / } 1 \times \frac{7}{6}$ $= 0.22 \text{ m}^3/\text{h}$
Specification Capacity	$0.22 \text{ m}^3/\text{Hr} \times 1.5$ $= 0.327 \text{ m}^3/\text{h} \Rightarrow 0.40 \text{ m}^3/\text{h/unit}$
(4) Polyelectrolyte dosing System	
Tanks Dimensions	$\text{Width} \times \text{Depth} \times \text{Length}$ $= 1.2 \text{ m} \times 1.5 \text{ m} \times 2 \text{ (Freeboard 0.5m)}$ $= 4.3 \text{ m}^3$
Retention Time of Tanks	$4.30 \text{ m}^3 \text{ / } 0.22 \text{ m}^3/\text{h} \text{ / } 1$ $= 19.728 \text{ Hr}$
Number	2 W + 0 S

15. Centrifuge Feed Sump	
[1] Design Condition	
(1) Quantity of Digested Sludge generated	1,993 kg/day
(2) Solids Consistency	2.50 %
(3) Volume of Thickened Sludge	$\frac{\text{Total Solids} \times 100}{\text{Solids Consistency}} \times 10^{-3}$ $= \frac{1,993 \times 100}{2.50} \times 10^{-3}$ $= 80 \text{ m}^3/\text{day}$ $= 3.32 \text{ m}^3/\text{h}$
(4) Sludge feed flow rate	12 m ³ /h
(5) Centrifuge Operation Time	8 hours/day (6 days per week)
[2] Geometry	
(1) Required sludge volume for continuation	$(12 + 3.32) \times 8$ $= 69.43 \text{ m}^3$
(2) Basin Dimensions	Width 4.0 m Length 4.5 m × Depth 3.5 m × 2 $= 126.0 \text{ m}^3$
[3] Equipment	
(1) Mixers for Centrifuge Feed Sumps	
Required Volume	63.0 m ³
Number	2 W + 0 S

Material Balance Sheet
[Bagwanpur STP]






Sr. No.	Facility	No.	W/Dia. (m)	L (m)	SWD/H (m)
01	Inlet Chamber	1	1.2 ^W	1.2 ^L	****H
02	Main Screen Channel	1	****W	****L	****H
03	Bypass Screen Channel	1	****W	****L	****H
04	Grit Chamber	1	****W	****L	****H
05	Parshall Flume	1	0.35 ^W	****L	****SDW
06	Main Distribution Chamber	1	****W	****L	****SDW
07	Sub-distribution Chamber	1	****W	****L	****SDW
08-1	Primary Clarifier 1-1/2	2	14.6 Dia.		3.5 ^{SWD}
08-2	Primary Clarifier 2	1	14.6 Dia.		3.5 ^{SWD}
09-1	Anoxic Tank 1-1/2	2	15.6 Dia.		3.5 ^{SWD}
09-2	Anoxic Tank 2	1	12.0 ^W	10.5 ^L	5.5 ^{SWD}
10-1	Aerobic Tank 1-1/2	2	9.5 ^W	10.5 ^L	5.5 ^{SWD}
10-2	Aerobic Tank 2	1	12.0 ^W	16.5 ^L	5.5 ^{SWD}
11-1	Secondary Clarifier 1-1/2	2	16.0 Dia.		3.5 ^{SWD}
11-2	Secondary Clarifier 2	1	16.0 Dia.		3.5 ^{SWD}
12	Chlorine Contact Tank	1	****W	****L	****H
13	Sludge Thickener	1	9.5 Dia.		3.5 ^{SWD}
14	Thickened Sludge Sump	1	2.0 ^W	2.0 ^L	2.5 ^{SWD}
15	Anaerobic Sludge Digester	2	18.0 Dia.		9.8 ^{SWD}
16	Biogas Holder	2	7.5 Dia.		4.0 ^{SWD}
17	Centrifuge Feed Sump	2	4.0 ^W	4.5 ^L	3.5 ^H
18	Sludge Drying Bed	9	12.0 ^W	28.0 ^L	****H
19	Filtrate Sump	1	****W	****L	****H
20	Primary Sludge Pump House	1	****W	****L	****H
21	Air Blower Room	1	10.0 ^W	10.0 ^L	4.0 ^H
22	RAS Pump House	1	****W	****L	****H
23	Chlorination Building	1	****W	****L	****H
24	Engine Room	1	8.5 ^W	15.0 ^L	****H
25	Biogas Flare	1			
26	Centrifuge Building	1	15.0 ^W	18.0 ^L	8.0 ^H

- Main Process Line
- Sludge Line
- Other Line
- Proposed structure
- Demolished structure
- Existing structure

Project Name	
PREPARATORY SURVEY ON GANGA REJUVENATION PROJECT IN THE STATE OF UTTARPRADESH, INDIA インド国ガンジス川浄化事業準備調査	
Drawing Title	Scale: not
Bagwanpur STP 8MLD Layout (Alternative Plan)	Drawing No. STP-24




INLET CHAMBER
MEDIUM SCREEN

GRIT CHAMBER
PARSHALL FLUME

SBR TANK

CHLORINATION TANK
(exclusion works)



SLUDGE THICKENER

THICKENED SLUDGE SUMP

BIOGAS ENGINE

BIOGAS HOLDER

ANAEROBIC SLUDGE DIGESTER

CENTRIFUGE FEED SUMP

CENTRIFUGE HOUSE

FILTRATE SUMP

SLUDGE DRYING BED


Main Process

Sludge Line

Other Line

Existing structure

Project Name	
PREPARATORY SURVEY ON GANGA REJUVENATION PROJECT IN THE STATE OF UTTARPRADESH, INDIA インテグレーションス川浄化事業準備調査	
Drawing Title	Scale: net
Bagwanpur STP BMLD Layout (DPR plan)	Drawing No: STP-03



Main Process —————
 Sludge line —————
 Other Line —————
 Existing structure - - - - -

Project Name PREPARATORY SURVEY ON GANGA REJUVINATION PROJECT IN THE STATE OF UTTARPRADESH, INDIA インド国ガンジス川浄化事業準備調査	
Drawing Title Bagwanpur STP 8MLD Layout (Alternative 1)	Scale: not Drawing No. STP-04

3. Ramna STP (Varanasi)

I. Desin Condition

Item	Ramna-STP																																				
(1) Design Flow	<table border="1" style="margin: auto;"> <thead> <tr> <th rowspan="2"></th> <th colspan="2">Flow Rate</th> </tr> <tr> <th>m³/d</th> <th>m³/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td>50,000</td> <td>0.579</td> </tr> <tr> <td>Max Dayly</td> <td></td> <td>0.000</td> </tr> <tr> <td>Max Hourly</td> <td>100,000</td> <td>1.157</td> </tr> </tbody> </table>		Flow Rate		m ³ /d	m ³ /s	Average Daily	50,000	0.579	Max Dayly		0.000	Max Hourly	100,000	1.157																						
	Flow Rate																																				
	m ³ /d	m ³ /s																																			
Average Daily	50,000	0.579																																			
Max Dayly		0.000																																			
Max Hourly	100,000	1.157																																			
(2) Design Sewage Quality and Effluent Quality	<p>Unit:mg/L</p> <table border="1" style="margin: auto;"> <thead> <tr> <th rowspan="3"></th> <th colspan="5">Water Quality Item</th> <th rowspan="3">TP</th> </tr> <tr> <th rowspan="2">BOD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> </tr> <tr> <th>NH₄-N</th> <th>org-N</th> <th>NOx-N</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td>200</td> <td>600</td> <td>25</td> <td>15</td> <td>0</td> <td>5</td> </tr> <tr> <td>Outlet</td> <td>10</td> <td>10</td> <td>1</td> <td>0</td> <td>9</td> <td>2</td> </tr> <tr> <td>Removal rate</td> <td>95.0%</td> <td>98.3%</td> <td colspan="3">75.0%</td> <td>60.0%</td> </tr> </tbody> </table>		Water Quality Item					TP	BOD	SS	T-N			NH ₄ -N	org-N	NOx-N	Inlet	200	600	25	15	0	5	Outlet	10	10	1	0	9	2	Removal rate	95.0%	98.3%	75.0%			60.0%
	Water Quality Item					TP																															
	BOD		SS	T-N																																	
		NH ₄ -N		org-N	NOx-N																																
Inlet	200	600	25	15	0	5																															
Outlet	10	10	1	0	9	2																															
Removal rate	95.0%	98.3%	75.0%			60.0%																															
(3) Inlet Quality of Reactor	<p>Unit:mg/L</p> <table border="1" style="margin: auto;"> <thead> <tr> <th rowspan="3"></th> <th colspan="5">Water Quality Item</th> <th rowspan="3">TP</th> </tr> <tr> <th rowspan="2">BOD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> </tr> <tr> <th>NH₄-N</th> <th>org-N</th> <th>NOx-N</th> </tr> </thead> <tbody> <tr> <td>Inlet Of Primary Clarifier</td> <td>200</td> <td>600</td> <td>25</td> <td>15</td> <td>0</td> <td>5</td> </tr> <tr> <td>Removal rate</td> <td>35%</td> <td>60%</td> <td colspan="3">0.0%</td> <td>-</td> </tr> <tr> <td>Inlet of Reactor</td> <td>130</td> <td>240</td> <td>25</td> <td>15</td> <td>0</td> <td>-</td> </tr> </tbody> </table>		Water Quality Item					TP	BOD	SS	T-N			NH ₄ -N	org-N	NOx-N	Inlet Of Primary Clarifier	200	600	25	15	0	5	Removal rate	35%	60%	0.0%			-	Inlet of Reactor	130	240	25	15	0	-
	Water Quality Item					TP																															
	BOD		SS	T-N																																	
		NH ₄ -N		org-N	NOx-N																																
Inlet Of Primary Clarifier	200	600	25	15	0	5																															
Removal rate	35%	60%	0.0%			-																															
Inlet of Reactor	130	240	25	15	0	-																															
2. Inlet Chamber																																					
[1] Design Condition																																					
(1) Design Wastewater Flow	<p>Max Hourly = 100,000 m³/day = 1.157 m³/sec</p>																																				
[2] Geometry																																					
(1) Number of Basins	1 Basin																																				
(2) Depth of Basin	3.000 m																																				
(3) Width of Basin	4.800 m																																				
(4) Length of Basin	5.000 m																																				
(5) Volume required of Basin	3.000 × 4.800 × 5.000 = 2.9 m ³																																				
(6) Retention Time	3.000 × 4.800 × 5.000 / 1.157 × 1 = 62.2299049 sec																																				
(7) Basin Dimensions	<p>Width 4.800 m × Length 5.000 m × Depth 3.000 m</p>																																				

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Wastewater Flow	$\begin{aligned} \text{Max Hourly} &= 100,000 \text{ m}^3/\text{day} \\ &= 1.157 \text{ m}^3/\text{sec} \end{aligned}$
[2] Geometry	
(1) Inlet Gate	
Number	2 Main + 1 Bypass
Width	0.800 m
Height	1.200 m
Floor Level	+ 76.700 m
Bottom	+ 73.700 m
Influent Water Level	+ 74.500 m
Velocity	$\begin{aligned} &1.157 \text{ } / \quad 0.800 \text{ } / \quad 0.800 \text{ } / \quad 2 \\ = &0.904 \approx 1.000 \text{ m/sec} \end{aligned}$
(2) Screen Channel	
Number	2 Main + 1 Bypass
Width	1.400 m
Side Water Depth	0.900 m
Velocity	$\begin{aligned} &1.157 \text{ } / \quad 1.400 \text{ } / \quad 0.900 \text{ } / \quad 2 \\ = &0.459 \approx 0.450 \text{ m/sec} \end{aligned}$
(3) Channel Dimensions	$\begin{aligned} \text{Width} &1.4 \text{ m} \times \text{Length} &8.5 \text{ m} \\ &\times \text{SWD} &0.9 \text{ m} \quad (\text{Freeboard } 0.3\text{m}) \end{aligned}$
[3] Equipment	
(1) Inlet Gate	
Number	2 W + 1 S 0.2
Dimension	Width 0.8 m × Height 1.2 m
Design Water Level	3.00 m
(2) Fine Screens (Main Channel)	
Number	2 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	1.4 m
Width of side plate	50 mm
Side Water Depth	0.9 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	$\begin{aligned} &1.157 \text{ } / \quad 1.300 \text{ } / \quad 0.850 \text{ } / \quad 2 \\ &\times (\quad 6 \quad + \quad 2 \quad) / \quad 6 \\ = &0.698 < 0.800 \text{ m/sec} \end{aligned}$
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	1.2 m
Side Water Depth	0.9 m
Velocity through screen	$\begin{aligned} &1.157 \text{ } / \quad 1.200 \text{ } / \quad 0.900 \text{ } / \quad 2 \\ &\times (\quad 20 \quad + \quad 9 \quad) / \quad 20 \\ = &0.777 < 0.800 \text{ m/sec} \end{aligned}$

4. Grit Chamber	
[1] Design Condition	
(1) Design Flow	Max Hourly = 100,000 m ³ /day = 1,157 m ³ /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.01157407 m/sec = 1000 m ³ /m ² /day
(4) Average Velocity	0.3 m/sec
[2] Grit Chamber	Square Grit Chamber
(1) Surface Area required	1,157 / 0.01157407 = 99,96 m ²
(2) Number of Basins	2 Basins
(3) Surface Area required/Basin	99,96 / 2 = 49,9824 m ²
(4) Length of Basin	49,9824 / 0.5 = 7.1 m → 7.1 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	1,157 × 60 sec / 2 = 34.7 m ³
(7) Depth required	34.7 / 7.1 / 7.1 = 0.689 → 0.8 m
(8) Basin Dimensions	Width 7.1 m · Length 7.1 m Depth 0.8 m (Freeboard 0.3m)
(9) Retention Time	7.1 × 7.1 × 0.8 / 1,157 × 2 = 69.71 sec
(10) Surface Overflow Rate at Peak Flow	100,000 / 7.1 / 7.1 / 2 = 991.866693 < 1000 m ³ /m ² /day
[3] Inlet Weir Gate	
(1) Number	2 Units
(2) Weir Width	2.400 m
(3) Stroke	0.600 m
(4) Overflow Height	0.500 m
(5) Overflow Height (actual)	(1,157 / 1.840 / 2.400 / 2) ^{2/3} = 0.258 < 0.500 m

5. Primary Clarifire	
[1] Design Condition	
(1) Design Wastewater Flow	$\begin{aligned} \text{Average Hourly} &= 50,000 \text{ m}^3/\text{day} \\ &= 0.579 \text{ m}^3/\text{sec} \\ &= 34.72 \text{ m}^3/\text{min} \end{aligned}$
(2) Type	Circular Clarifire
(3) Surface Overflow Rate required	$35 \text{ m}^3/\text{m}^2/\text{day}$
(4) Number of Basins	2 Basins
[2] Design	
(1) Surface Area required	$50,000 \text{ m}^3/\text{day} \div 35 \text{ m}^3/\text{m}^2/\text{day} = 1,429 \text{ m}^2$
(2) Surface Area required/Basin	$1,429 \text{ m}^2 \div 2 = 714 \text{ m}^2$
(3) Depth required	3.0 m
(4) Diameter required	30.2 m
(5) Basin Dimensions	Diameter $34.0 \text{ m} \times$ Depth 3.0 m
[3] Review	
(1) Surface Area	$907.920277 \times 2.0 = 1815.8 \text{ m}^2$
(2) Surface Overflow Rate at Average Flow	$50,000 \text{ m}^3/\text{day} \div 1815.8 \text{ m}^2 = 28 \text{ m}^3/\text{m}^2/\text{day}$
[4] Sludge generated per day	
(1) Inlet TSS	600 mg/L
(2) Reduction in TSS	60%
(3) Outlet TSS	240 mg/L
(4) Solids removed from Primary Clarifiers	21,181 kg/day
(5) Solids Consistency	3 %
(6) Volume of Primary Sludge	$\begin{aligned} &= \frac{\text{Solids removed}}{100} \times \text{Solids Consistency} \times 10^{-3} \\ &= \frac{21,181 \text{ kg/day}}{100} \times 3 \times 10^{-3} \\ &= 706 \text{ m}^3/\text{day} \end{aligned}$
[5] Equipment	
(1) Primary Sludge Pumps	
Sludge withdrawal	12 Times/day
Running Time	0.50 hr/Time
Number	2 W + 1 S
Required Capacity	$\begin{aligned} &= \frac{706 \text{ m}^3/\text{day}}{12 \text{ Times/day} \times 0.5 \text{ hr/Time}} \\ &= 58.8 \text{ m}^3/\text{Hr} \Rightarrow 65 \text{ m}^3/\text{Hr /Unit} \end{aligned}$

6. Reactor	
(1) Design Condition	
(1) Design Flow	Q = 50,000 m ³ /day (summer) Q' = 50,000 m ³ /day (Winter)
(2) Design Sewage Quality	
Inlet BOD	130 mg/l
Outlet BOD	10.0 mg/l
Inlet S-BOD	52 mg/l
Inlet COD	228 mg/l
Inlet S-COD : sCOD	87 mg/l
Outlet S-COD : nbsCODe	4 mg/l = sCOD - 1.6sBOD
Inlet rbCOD	52 mg/l
bCOD/BOD	1.60
Inlet bCOD : S ₀	208 mg/l
Inlet nbCOD	20 mg/l
: nbpCOD	16 mg/l = TCOD - bCOD - nbsCODe
Inlet TSS	240 mg/l
Inlet SS	240 mg/l
Inlet VSS	180 mg/l
: VSS _{COD}	0.78 gCOD/gV = TCOD - sCOD / VSS
: nbVSS	20.68 gnbVSS/ = nbpCOD / VSS _{COD}
: iTSS	60.00 gnbVSS/ = TSS - VSS
Inlet T-N	40 mg/l
Inlet TKN	40 mg/l
Inlet NH ₄ -N	25 mg/l
Inlet T-P	6 mg/l
Inlet Alkalinity as CaCO ₃	380 mg/l
Outlet Kjeldahl N	1.0 mg/l
Outlet NH ₄ -N	1.0 mg/l
Outlet NO ₃ -N	9.0 mg/l
(3) Water Temperature	T = 20.0 °C
(4) Safety Factor for Nitrogen	SF = 1.5
(5) Return Sludge Concentration	R _s = 8,000 mg/l
(6) MLSS MLVSS	X _{TSS} = 3,000 mg/l
(7) DO in the Reactor	2 mg/l

[2] Design Value for perfect Nitrification of Nitrification Process

(1) Activated sludge design kinwtic coefficients at 20°C

Coefficient	Unit	COD oxidatio	NH4 oxidatio	NO2 oxidatio
μ_{max}	gVSS/gVSS · d	0.900	0.900	1.000
K_s, K_{NH4}, K_{NO2}	mg/L	8.000	0.500	0.200
Y	gVSS/g substrate oxidized	0.450	0.150	0.050
b	gVSS/gVSS · d	0.120	0.170	0.170
fd	unitless	0.150	0.150	0.150
K_{O2}	mg/L	0.200	0.500	0.900
θ Value				
μ_{max}	unitless	1.070	1.072	1.063
b	unitless	1.040	1.029	1.029
K_s, K_{NH4}, K_{NO2}	unitless	1.000	1.000	1.000

Wastwater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF & EDDY/AECOM)

(2) μ_{AOB}	$\mu_{AOB} = 0.3100 \text{ g/g} \cdot \text{d} = \mu_{max, AOB} [S_{NH4} / (S_{NH4} + K_{NH4})] [S_0 / (S_0 + K_{O, AOB})] - b_{AOB}$
$\mu_{max, AOB, T}$	$\mu_{max, AOB, T} = 0.9000 \text{ g/g} \cdot \text{d} = \mu_{max} * 1.072^{(T-20)}$ μ_{max} at 20°C = 0.900
$b_{AOB, T}$	$b_{AOB, T} = 0.1700 = b * 1.029^{(T-20)}$ b at 20°C = 0.170
S_{NH4}	$S_{NH4} = 1.0000 \text{ mg/l}$
DO	$DO = 2.0000 \text{ mg/l}$
$K_{O, AOB}$	$K_{O, AOB} = 0.5000 \text{ mg/l}$
(2) Design SRT	$SRT = 4.8387 \text{ day} = 1 / \mu_{AOB} \times SF$

(3) Biomass production			
P _{X,VSS}	4373.175 kg/d	=P _{X,bio} +Q(nbVSS)	
P _{X,TSS}	7962.433 kg/d	=P _{X,bio} /0.85+Q(nbVSS)+Q(TSS _c -VSS ₀)	
S	0.4606 mg/l	=K _s [1+b _H (SRT)]/[SRT(μ _m -b _H)-1]	
b _H	0.1200	=b*1.04 ^(T-20)	b at 20°C = 0.120
Y _H	0.4500 gVSS/g bCOD		
μ _{m,T}	6.0000 g/g·d	=μ _{max} *1.04 ^(T-20)	μ _{max} at 20°C = 6.000
Y _N	0.150 gVSS/g Nox		
NO _x	31.000 mg/l		
P _{X,bio,VSS}	3339.132 kg VSS/c	=Q·Y _H (S ₀ -S)/[1+b _H (SRT)]+f _d ·b _H ·QY _H (S ₀ -S)SRT/[1+b _H (SRT)] +QY _N (Nox)/[1+b _{AOB} (SRT)]	
	2954.259	=Q·Y _H (S ₀ -S)/[1+b _H (SRT)]	
	257.306	=f _d ·b _H ·QY _H (S ₀ -S)SRT/[1+b _H (SRT)]	
	127.566	=QY _N (Nox)/[1+b _{AOB} (SRT)]	
NO _x	30.986 mg/l	=TKN-Ne-0.12P _{X,bio} /Q	
(4) Required Aeration Tank Volume			
V _a	12,843 m ³		
τ	6.16 hr	=V _a /Q×24	
X _{VSS} ·V _a	21,161 kg VSS	=P _{X,VSS} ·SRT	
X _{TSS} ·V _a	38,528 kg TSS	=P _{X,TSS} ·SRT	
F/M	0.307 kgBOD/kgMLVSS		
FractionVSS=	0.549		
MLVSS=	1648 mg/L		
(5) BODloading		BODloading	0.506 kg/m ³ ·d
(6) Observed Yield		Y _{obs,TSS}	1.228 gTSS/gBOD
	Y _{obs,VSS}	0.674 gVSS/gBOD	
	bCODremoved=	bCODremov	10,377 kg/d
(7) effluent NO₂-N		NO ₂ -N=	0.2407 mg/l
	b _{NOB}	0.1700	=b*1.029 ^(T-20) b at 20°C = 0.170
	μ _{m,T}	1.0000 g/g·d	=μ _{max} *1.04 ^(T-20) μ _{max} at 20°C = 1.000
	μ _{AOB}	0.6897 g/g·d	=μ _{max,NOB} [S ₀ /(S ₀ +K _{O₂,NOB})]
	S ₀	2.000 mg/l	
	K _{O₂,NOB}	0.900 mg/l	
(8) effluent NH₄-N		NH ₄ -N=	0.5485 mg/l
	b _{NOB}	0.1700	=b*1.029 ^(T-20) b at 20°C = 0.170
	μ _{m,T}	0.9000 g/g·d	=μ _{max} *1.072 ^(T-20) μ _{max} at 20°C = 0.900
	μ _{AOB}	0.7200 g/g·d	=μ _{max,NOB} [S ₀ /(S ₀ +K _{O₂,NOB})]
	S ₀	2.000 mg/l	
	K _{O₂,NOB}	0.500 mg/l	
(9) Ratio of Return Sludge		8,000·R _r /(1+R _r)=	3,000 mg/L
	3,000/(8,000-3,000)=		0.60
	R _r =		0.60

3] Design for Nitrification and Denitrification Process

- (1) Active biomass concentration $X_b = \frac{Q \cdot (SRT)/V \cdot Y_1(S_0-S)}{1 + b_H(SRT)}$
= 1,113.07 mg/l
- (2) IR ratio $IR = \frac{NOx}{Ne} - 1.0 - R$
= 1.81
- (3) The amount of NO₃-N fed to the anoxic tank $Nox\ feed = (IR+R) \cdot Q \cdot Ne$
= 1,099,304.14 kg/d
- (4) The anoxic tank volume $V_{nor} = 6,250 \text{ m}^3$ $\tau_{nor} = 3.000 \text{ h}$
- (5) F/M_b $F/M_b = 0.93 \text{ g/g} \cdot \text{d}$
- (6) Fraction of rbCOD = 25.00% = rbCOD/bCOD

Percent rbCOD(%)	SDNR equation coefficients	
	b0	b1
10	0.186	0.078
20	0.213	0.118
30	0.235	0.141
40	0.242	0.152
50	0.270	0.162

- (8) SDNRb $SDNR_b = 0.225 \text{ g/g} \cdot \text{d} = b_0 + b_1[\ln(F/M_b)]$
 $b_0 = 0.235$
 $b_1 = 0.141$
- (8) SDNR $SDNR = 0.100 \text{ g/g} \cdot \text{d} = SDNR_b(MLVSS_r/MLVSS)$
 $SDNR_{adj} = 0.149 \text{ g/g} \cdot \text{d} = SDNR_r - 0.029\ln(F/M_b) - 0.012$ IR=3-4
 $= SDNR_r - 0.0166\ln(F/M_b) - 0.078$ IR=2
 $SDNR_t = 0.225 \text{ g/g} \cdot \text{d} = SDNR_b \cdot \theta^{(t-20)}$ $\theta = 1.026$
- (9) NO_r $NO_r = 1,033,438.00 \text{ kg/d} = N_{nox} \cdot SDNR \cdot X_b$
 $>Nox\ feed = ##### \text{ kg/d}$
- (10) Alkalinity to be added to maintain pH7
 -167.15 mg/l
 Influent Alk = 380.00 mg/l
 Alk used = 221.34 mg/l = 7.14 × Nox
 Alk producer = 78.49 mg/l = 3.57 × (NOx-NOxe)
 Alk to maint: 70.00 mg/l

<p>[5] Reactor</p> <p>(1) Coagulant Dosage</p> <p>(2) Total volume of Aeration Basins</p> <p>(3) Total volume of Anoxic Basins</p> <p>[6] Geometry</p> <p>(1) Basin Dimensions</p> <p style="padding-left: 20px;">Aerobic tank</p> <p style="padding-left: 20px;">Anoxic tank</p> <p style="padding-left: 20px;">Cross Section</p> <p style="padding-left: 20px;">Hantzsch Subtraction</p> <p style="padding-left: 20px;">after Subtraction</p> <p style="padding-left: 20px;">Total Volume</p> <p>(2) Partition of Basin</p>	<p style="text-align: center;">0.0 Mol</p> <p>$V_A = Q \cdot \theta_a / 24$ = 12,843 m³</p> <p>$V_{DN} = Q \cdot \theta_{DN} / 24$ = 6,250 m³</p> <table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="2">Item</th> <th rowspan="2">Volume required</th> <th colspan="2">Retention Time required</th> <th rowspan="2">Ratio of Volume</th> </tr> <tr> <th>Summer</th> <th>Winter</th> </tr> <tr> <th>unit</th> <th>m³</th> <th>hour</th> <th>hour</th> <th></th> </tr> </thead> <tbody> <tr> <td>Anaerobic</td> <td>V_{AN}</td> <td>0</td> <td>0.00</td> <td>0.00</td> </tr> <tr> <td>Anoxic</td> <td>V_{DN}</td> <td>6,250</td> <td>3.00</td> <td>3.00</td> </tr> <tr> <td>Aerobic</td> <td>V_A</td> <td>12,840</td> <td>6.16</td> <td>6.16</td> </tr> <tr> <td>Total</td> <td>V</td> <td>19,090</td> <td>9.16</td> <td>9.16</td> </tr> </tbody> </table> <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Width</th> <th style="text-align: left;">Length</th> <th style="text-align: left;">Depth</th> <th style="text-align: left;">Basins</th> </tr> </thead> <tbody> <tr> <td>8.0</td> <td>190.0</td> <td>5.7</td> <td>2</td> </tr> <tr> <td>14.0</td> <td>40.0</td> <td>5.8</td> <td>2</td> </tr> <tr> <td colspan="2">Cross Section</td> <td>8.0*5.7</td> <td>= 45.6 m²/Basin</td> </tr> <tr> <td colspan="2">Hantzsch Subtraction</td> <td></td> <td>= 1.0 m²/Basin</td> </tr> <tr> <td colspan="2">after Subtraction</td> <td>45.6-1.0</td> <td>= 44.6 m²/Basin</td> </tr> <tr> <td colspan="2">Total Volume</td> <td>44.6*190.0</td> <td>= 8,474 m²/Basin 16,948 m³/Total</td> </tr> </tbody> </table> <table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th>Item</th> <th>unit</th> <th>Anaerobic</th> <th>Anoxic</th> <th>Aerobic</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Cross Section</td> <td>m²</td> <td></td> <td>80.2</td> <td>44.6</td> <td></td> </tr> <tr> <td>Length required</td> <td>m</td> <td></td> <td>39.0</td> <td>143.9</td> <td>182.9</td> </tr> <tr> <td>Volume required per Basin</td> <td>m³</td> <td></td> <td>3,125</td> <td>6,420</td> <td>9,545</td> </tr> <tr> <td>Total Volume required</td> <td>m³</td> <td></td> <td>6,250</td> <td>12,840</td> <td>19,090</td> </tr> <tr> <td>Actual Length</td> <td>m</td> <td></td> <td>40.0</td> <td>190.0</td> <td>230.0</td> </tr> <tr> <td>Actual Volume per Basin</td> <td>m³</td> <td></td> <td>3,208</td> <td>8,474</td> <td>11,682</td> </tr> <tr> <td>Actual Total Volume</td> <td>m³</td> <td></td> <td>6,416</td> <td>16,948</td> <td>23,364</td> </tr> <tr> <td>Actual Ratio of Volume</td> <td></td> <td></td> <td>1.00</td> <td>2.64</td> <td></td> </tr> <tr> <td>Actual Retention Time</td> <td>hour</td> <td></td> <td>3.08</td> <td>8.14</td> <td>11.22</td> </tr> </tbody> </table>	Item	Volume required	Retention Time required		Ratio of Volume	Summer	Winter	unit	m ³	hour	hour		Anaerobic	V_{AN}	0	0.00	0.00	Anoxic	V_{DN}	6,250	3.00	3.00	Aerobic	V_A	12,840	6.16	6.16	Total	V	19,090	9.16	9.16	Width	Length	Depth	Basins	8.0	190.0	5.7	2	14.0	40.0	5.8	2	Cross Section		8.0*5.7	= 45.6 m ² /Basin	Hantzsch Subtraction			= 1.0 m ² /Basin	after Subtraction		45.6-1.0	= 44.6 m ² /Basin	Total Volume		44.6*190.0	= 8,474 m ² /Basin 16,948 m ³ /Total	Item	unit	Anaerobic	Anoxic	Aerobic	Total	Cross Section	m ²		80.2	44.6		Length required	m		39.0	143.9	182.9	Volume required per Basin	m ³		3,125	6,420	9,545	Total Volume required	m ³		6,250	12,840	19,090	Actual Length	m		40.0	190.0	230.0	Actual Volume per Basin	m ³		3,208	8,474	11,682	Actual Total Volume	m ³		6,416	16,948	23,364	Actual Ratio of Volume			1.00	2.64		Actual Retention Time	hour		3.08	8.14	11.22
Item	Volume required			Retention Time required			Ratio of Volume																																																																																																																		
		Summer	Winter																																																																																																																						
unit	m ³	hour	hour																																																																																																																						
Anaerobic	V_{AN}	0	0.00	0.00																																																																																																																					
Anoxic	V_{DN}	6,250	3.00	3.00																																																																																																																					
Aerobic	V_A	12,840	6.16	6.16																																																																																																																					
Total	V	19,090	9.16	9.16																																																																																																																					
Width	Length	Depth	Basins																																																																																																																						
8.0	190.0	5.7	2																																																																																																																						
14.0	40.0	5.8	2																																																																																																																						
Cross Section		8.0*5.7	= 45.6 m ² /Basin																																																																																																																						
Hantzsch Subtraction			= 1.0 m ² /Basin																																																																																																																						
after Subtraction		45.6-1.0	= 44.6 m ² /Basin																																																																																																																						
Total Volume		44.6*190.0	= 8,474 m ² /Basin 16,948 m ³ /Total																																																																																																																						
Item	unit	Anaerobic	Anoxic	Aerobic	Total																																																																																																																				
Cross Section	m ²		80.2	44.6																																																																																																																					
Length required	m		39.0	143.9	182.9																																																																																																																				
Volume required per Basin	m ³		3,125	6,420	9,545																																																																																																																				
Total Volume required	m ³		6,250	12,840	19,090																																																																																																																				
Actual Length	m		40.0	190.0	230.0																																																																																																																				
Actual Volume per Basin	m ³		3,208	8,474	11,682																																																																																																																				
Actual Total Volume	m ³		6,416	16,948	23,364																																																																																																																				
Actual Ratio of Volume			1.00	2.64																																																																																																																					
Actual Retention Time	hour		3.08	8.14	11.22																																																																																																																				

[7] Equipment					
(1) Ras Pumps					
Ras Ratio	60	%			
Required Capacity	50,000	m ³ /day	60% / 24	/	4
	= 313	m ³ /hr	=>	320	m ³ /hr
Number	4	Work			
	2	Standby			
(2) Circulation Pumps					
Ras Ratio	184	%			
Required Capacity	50,000	m ³ /day	184% / 24	/	4
	= 958	m ³ /hr	=>	960	m ³ /hr
Number	4	Work			
	2	Standby			
(3) SAS Pumps					
Excess Sludge	1,168	m ³ /day			
Sludge withdraw	12	Times/day			
Running Time	0.5	Hr/Time			
Required Capacity	1,168	m ³ /day /	12 /	0.50 /	2
	= 97.32	m ³ /hr	=>	100	m ³ /hr
Number	2	Work			
	2	Standby			

7. Air Requirement at Average Flow	
[1] Design Condition	
(1) AOR :R ₀	R ₀ = = 9,754 kg/day = 406.4 kg/h
Q _{in} : Design Average Flow m ³ /d	50,000
Inlet bCOD :S ₀	208 mg/l
S=	S= 0.461 mg/l
Nox=	Nox= 31.000 mg/l
P _{X,bio} =	P _{X,b} 3,211.6 kg VSS/ does not include nitrifying bacteria
R ₀ =	R ₀ = Q(S ₀ -S-k(Nox-NOxe))-1.42P _{X,bio} +4.57Q·NOx
R ₀ =	R ₀ = 9,754 kg O2/d
	k= 2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{\text{AOR} \times C_s \cdot a \times 1.024^{20-T}}{\alpha \times F (\beta \cdot C_{sw}/C_s \cdot (P_b/P_a)^a - C_A)}$
	C _s : Saturated DO at sea level and 20 °C 9.09 mg/L
	C _{sw} : Saturated DO at sea level and operating Temperature 6.93 mg/L at 35 °C
	20-T : -15.0 1.024 ^{20-T} : 0.7006
	C _A : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1+0.40D _j /Pa 1.20132
	D _j : Tank Liquid Depth 5.20 m
	P _a : Standard absolute pressure at s 10.332 m
	P _b : Absolute pressure at Plant Site Elevation 500 m
	P _b /P _a : exp[-gM(z _b -z _a)/R*T] 0.992
	g : Acceleration due to Gravity 9.80665 m/s ²
	M : Mole of Air 28.97 kg/kg-mole
	z _b : Plant Site Elevation 74 m
	z _a : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 308.15 Kelvin
	α : relative Transfer Rate to clean W _a 0.65
	β : relative DO Saturation to clean W _a 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{74,629}{3.4189} = 21,828.47 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Standard O2 required at Field Conditions per Bas =	10,914 kg/day
(5) SOTE for the above Effective Aeration Depth	30.5 %
(6) Fraction of O2 in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	15%
(9) Air required at Field Conditions per Basins	= 147.362 m ³ /day = 6,140.1 m ³ /hr

[2] Equipment				
(1) Air Blower				
Number	4	W	+ 2	S
Required Capacity	6140.1	m ³ /hr·Basin	/	2 unit/Basin
	= 3070.0	m ³ /h	⇒	3100 m ³ /h/Unit
Pressure	65	kPa		
Safety Factor	10	%		
Heat capacity ratio	1.4			
Atmospheric pressure at site elevation	100.497	kPa		
Total inlet pressure	98.497	kPa		
Volume rate of flow at inlet point	53.137	m ³ /min		
Total discharge pressure	165.497	kPa		
Overall adiabatic efficiency	0.65			
Inlet air temperature (min.)	15	°C		
Shaft power	76.371	kW		
Rated Output of Motor	84.008	kW	⇒	90 kW

8. Final Clarifire							
[1] Design Condition							
(1) Design Wastewater Flow	Tube settlers $Q = 50,000 \text{ m}^3/\text{day}$						
(2) Water Temperature	$T = 20.0 \text{ }^\circ\text{C}$						
(3) MLSS	$X_{ef} = 3,000 \text{ mg/l}$						
(4) SVI	$SVI = 200$						
(5) Sedimentation Velocity	$v = 4.899 \cdot 10^6 \cdot T^{(0.954)} \cdot X_{ef}^{(-1.354)} \cdot SVI^{(-0.77)}$ $= 4.899 \cdot 10^6 \cdot 20.0^{0.954} \cdot 3,000^{-1.354} \cdot 150^{-0.770}$ $= 28.3 \text{ m/day} \quad \rightarrow \quad 15.0 \text{ m}^3/\text{m}^2 \cdot \text{day}$						
(6) Surface Overflow Rate required	$S' = v / (1.5 \cdot 1) = 28.3 / (1.5 \cdot 1.0) = 18.9 \text{ m}^3/\text{m}^2 \cdot \text{day}$						
[2] Geometry							
(1) Surface Area required	$A = 50,000 / 15.0 = 3,333 \text{ m}^2$						
(2) Demensions	<table style="margin-left: auto; margin-right: auto;"> <tr> <td>Diameter</td> <td>Depth</td> <td>Basin</td> </tr> <tr> <td style="text-align: center;">46.0</td> <td style="text-align: center;">3.2</td> <td style="text-align: center;">2</td> </tr> </table>	Diameter	Depth	Basin	46.0	3.2	2
Diameter	Depth	Basin					
46.0	3.2	2					
(3) Actual Surface Area	$S = 46.0^2 \cdot 3.14 / 4 \cdot 2.0 = 3,324 \text{ m}^2$						
(4) Ture Surface Overflow Rate	$S = 50,000 / 3,324 = 15.0 \text{ m}^3/\text{m}^2 \cdot \text{day}$						

9. Chlorination Tank	
[1] Design Condition	
(1) Design Wastewater Flow	Average Hourly 50,000 m ³ /day
(2) No. Batch Basins	1 Basin
(3) No. of Cycles	- Cycles
(4) Contact Time	30 min
(5) Design Chlorine Dosage	5 mg/l.
[2] Geometry	
(1) Volume required	$\frac{\text{Average Hourly} \times \text{Contact Time}}{\text{Contact Time}} = \frac{1440 \times 1041.7 \text{ m}^3}{30 \text{ min}}$
(2) Tank Dimensions	Width 18.0 m × Length 20.0 m × Depth 3.0 m (Freeboard 0.3m)
(3) No. of Tanks	1 Tank
[3] Review	
(1) Total Volume	$\begin{aligned} & \text{Width} \times \text{Length} \times \text{Depth} \times \text{No. of Tanks} \\ & = 18.0 \text{ m} \times 20.0 \text{ m} \times 3.0 \text{ m} \\ & = 1,080 \text{ m}^3 \end{aligned}$


11. Thickened Sump						
[1] Design Condition						
(1)	Inlet Solids	19,063	kg/day			
(2)	Inlet Sludge Volume	477	m ³ /d			
[2] Geometry						
(1)	Sludge withdrawal	4	Times/day			
(2)	Required Sump Volume	119	m ³			
(3)	Number	2	Basins			
(4)	Width	4.0	m			
(5)	Length	4.5	m			
(6)	Side Water Depth	3.5	m			
(7)	Actual Sump Volume	4.0	×	4.5	×	3.5
		=			×	2
						126.0 m ³
[3] Equipment						
(1)	Mixing Air Blower					
	Agrtate Rate	1.20	m ³ /Hr·m ³			
	Number	1	W	+	1	S
	Required Capacity	126	m ³	×	1.2	/
		=	151.2	m ³ /Hr	⇒	160 m ³ /Hr/Unit
(3)	Digester Feed Pumps					
	Transfer Time	8.00	Hr			
	Number	2	W	+	1	S
	Required Capacity	477	m ³	/	8.0	/
		=	29.8	m ³ /Hr	⇒	30 m ³ /Hr/Unit


12. Sludge Digester	
[1] Design Condition	
(1) Quantity of Thickened Sludge generated	19,063 kg/day
(2) Inlet Solids Consistency	4.00 %
(3) Volume of Thickened Sludge	$\frac{\text{Total Solids}}{\text{Solids Consistency}} \times 100 \times 10^{-3}$ $= \frac{19,063}{4.00} \times 100 \times 10^{-3} = 477 \text{ m}^3/\text{day}$
(4) Ratio of VSS	75 %
(5) Total VSS	= 14,297 kg/day
(6) Total inorganic Sludge	= 4,766 kg/day
(7) Retention Time	20 days
(8) % Destruction in VSS	50 %
(9) VSS destroyed	= 7,149 kg/day
(10) Quantity of Digested Sludge generated	= 11,914 kg/day
(11) Solids Consistency	1.5625 %
(12) Volume of Digested Sludge	$\frac{\text{Total Solids}}{\text{Solids Consistency}} \times 100 \times 10^{-3}$ $= \frac{11,914}{1.5625} \times 100 \times 10^{-3} = 763 \text{ m}^3/\text{day}$
[2] Geometry	
(1) Volume required	9,531 m ³
(2) No. of Basins	2 Basins
(3) Volume required per Basin	= 4,766 m ³
(4) Depth provided	10.0 m
(5) Area required per Basin	= 477 m ²
(6) Diameter required per Basin	= 24.6 m
(7) Basin Dimensions	$\text{Diameter } 25.0 \text{ m} \times \text{Depth } 10.0 \text{ m}$ $\times 2 \text{ Basins} = 9,817 \text{ m}^3 \text{ (Freeboard 0.8m)}$
[3] Equipment	
(1) Mixers for Digestion Tanks	
Capacity	4909 m ³
Number	2 W + 0 S
(2) Digested Sludge Transfer Pumps	
Transfer Time	8.00 Hr
Number	2 W + 2 S
Required Capacity	$\frac{477 \text{ m}^3}{8.00 \text{ Hr}} \Rightarrow 30 \text{ m}^3/\text{Hr /Unit}$

13. Biogas Power Generation	
[1] Design Condition	
(1) Biogas generated per Kg of VSS destroyed	0.9 m ³ /kg
(2) VSS destroyed	7,149 kg/day
(3) Biogas generated	6,434 m ³ /day
(4) Gas Holder Volume required	25 %
=	1,608 m ³
(5) No. of Units provided	2
(6) Volume of each Gas Holder required	= 804 m ³
[2] Geometry	
(1) Biogas Holder	Diameter 12.0 m × height 8.0 m × 2 Basins
Sphere	$V = \pi/4 * D^2 * h$
=	1,810 m ³ (Freeboard 0.8m)
[3] Equipment	
(1) Biogas Power generators	
Biogas Generation	0.074 m ³ /sec
Biogas Caloric Value	22,000 KJ/m ³
Biogas Engine Conversion Efficiency	40.0 %
Number	1 W + 1 S
Power Generation	0.074 m ³ /sec × 22000 KJ/m ³ × 0.4 / 1
=	655.3 kW ⇒ 660 kW
(2) Desulfurization Equipment	
Biogas Generation	268.07 m ³ /hr
Peak Ratio	1.5
Number	2 W + 0 S
Required Capacity	268.07 m ³ /Hr × 1.5 / 2
=	201.1 m ³ /Hr ⇒ 210 m ³ /Hr /Unit
(3) Biogas Blowers	
Biogas Generation	268.07 m ³ /hr
Safety Factor	1.5
Number	2 W + 1 S
Required Capacity	268.07 m ³ /Hr × 1.5 / 2
=	201.1 m ³ /Hr ⇒ 210 m ³ /Hr /Unit
(4) Biogas Flare	
Biogas Generation	6433.73 m ³ /sec
Operating hours	24 Hr
Safety Factor	150.0 %
Number	1 W + 1 S
Power Generation	402 m ³ /hr ⇒ 410 m ³ /hr

14. Sludge Drying Bed	
[1] Design Condition	
(1) Digested Sludge	11,914 kg/day 477 m ³ /day
(2) Secondary Sludge	9,343 kg/day 1,168 m ³ /day
(3) Total Solids	21,257 kg/day 1,644 m ³ /day
(4) Solids Consistency	1.29%
(5) Sludge Drying Period	12.00 days
(6) Sludge Loading	20.00 kg/m ²
(7) Required total area of beds	$21,257 \times \frac{12.00}{30.00}$ $= 8,503 \text{ m}^2$
(8) No. of Sludge drying beds	12 W + 0 S
(9) Basin Dimensions	Width 20.0 m × Length 36.0 m × 12 $= ##### \text{ m}^3$

Material Balance Sheet
[Ramna STP]





List of Main Structures		
Sr. No.	Description	Dimensions (Length/Dia. x Width x Depth/Height (m))
1	Inlet Chamber	5.4 x 4.3 x 3.5
2	Mechanical Fine Screen Channel	8.5 x 1.4 x 1.2
3	Grit Distribution Chamber	6.0 x 2.0 x 1.7
4	Grit Chamber	7.1 x 7.1 x 1.5
5	Parshall Flume	8.5 x 1.3 x 1.3
6	Primary Clarifier Distribution Chamber	4.0 Dia. x 2.0Ht.
7	Primary Clarifier	34.0Dia. x 3.5Ht.
8	Bioreactor Distribution Chamber	4.5 x 2.5 x 2.0
9	Channel for Bioreactor	30.0 x 1.3 x 1.0
10	Anoxic Tank	14.0 x 40.0 x 6.4
11	Aeration Tank	38.0 x 40.0 x 3.3
12	Secondary Clarifier Distribution Chamber	4.0 Dia. x 2.0Ht.
13	Secondary Clarifier	54.0Dia. x 3.7Ht.
14	Chlorine Mixing Tank	5.5 x 4.5 x 3.5
15	Chlorine Contact Tank	18.0 x 20.0 x 3.5
19	Dechlorination Chamber	5.5 x 4.5 x 3.5
17	Sludge Thickener	13.0Dia. x 4.7Ht.
18	Anaerobic Sludge Digester	30.0Dia. x 11.5Ht.
19	Gas Holder	12.0Dia. x 9.2Ht.
20	Sludge Drying Bed	36.0 x 20.0 x 0.6
21	Primary Sludge Sump	5.6Dia. x 2.5Ht.
22	Recirculation Sludge Sump	9.0Dia. x 4.7Ht.
23	Thickened Sludge Sump	2.2Dia. x 3.5Ht.
24	Filterate Sump	5.5Dia. x 2.5Ht.
25	Effluent Pumping Station	15.0Dia. x 6.0Ht.
26	Effluent Overhead Tank	-
27	Gas Engine Building	20.0 x 9.0 x 4.0Ht.
28	Substation & Transformer Yard	33.0 x 16.5 x 4.0Ht.
29	Administration Building & LAB	35.0 x 18.0




Project Name
PREPARATORY SURVEY ON GANGA REJUVENATION PROJECT IN THE STATE OF UTTAR PRADESH, INDIA
 インド国ガンジス川浄化事業準備調査

Drawing Title
Ramna STP Layout

Scale: 1:2000 (A3)

Drawing No. **STP-25**



Main Process ————
 Sludge Line - - - - -
 Other Line
 Existing structure - - - - -

Project Name PREPARATORY SURVEY ON GANGA REJUVENATION PROJECT IN THE STATE OF UTTARPRADESH, INDIA インド国ガンガス川浄化事業準備調査	
Drawing Title Ramnita STP 50MLD layout	Scale: not Drawing No.: STP-05

4. Mirzapur 14MLD STP

Item	Mirzapur-STP																																									
1. Design Condition																																										
(1) Design Flow Rate	<table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th></th> <th>m³/d</th> <th>m³/h</th> <th>m³/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td>14,000</td> <td>583.33</td> <td>0.162</td> </tr> <tr> <td>Max Daily</td> <td>14,000</td> <td>583.33</td> <td>0.162</td> </tr> <tr> <td>Max Hourly Peak factor 2.25</td> <td>31,500</td> <td>1312.50</td> <td>0.365</td> </tr> </tbody> </table>								m ³ /d	m ³ /h	m ³ /s	Average Daily	14,000	583.33	0.162	Max Daily	14,000	583.33	0.162	Max Hourly Peak factor 2.25	31,500	1312.50	0.365																			
	m ³ /d	m ³ /h	m ³ /s																																							
Average Daily	14,000	583.33	0.162																																							
Max Daily	14,000	583.33	0.162																																							
Max Hourly Peak factor 2.25	31,500	1312.50	0.365																																							
(2) Design Water Quality	<div style="text-align: right; font-size: small;">Unit: mg/L</div> <table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th rowspan="2">TP</th> </tr> <tr> <th>NH₄-N</th> <th>org-N</th> <th>NOx-N</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td>250</td> <td>450</td> <td>400</td> <td>25</td> <td>10</td> <td>5</td> <td>5</td> </tr> <tr> <td>Outlet</td> <td>10</td> <td>50</td> <td>20</td> <td>2</td> <td>0</td> <td>8</td> <td>2</td> </tr> <tr> <td>Removal rate</td> <td>96.0%</td> <td>88.9%</td> <td>95.0%</td> <td colspan="3">75.0%</td> <td>60.0%</td> </tr> </tbody> </table>								BOD	COD	SS	T-N			TP	NH ₄ -N	org-N	NOx-N	Inlet	250	450	400	25	10	5	5	Outlet	10	50	20	2	0	8	2	Removal rate	96.0%	88.9%	95.0%	75.0%			60.0%
	BOD	COD	SS	T-N			TP																																			
				NH ₄ -N	org-N	NOx-N																																				
Inlet	250	450	400	25	10	5	5																																			
Outlet	10	50	20	2	0	8	2																																			
Removal rate	96.0%	88.9%	95.0%	75.0%			60.0%																																			
2. Inlet Chamber (existing structure)																																										
[1] Design Condition																																										
(1) Design Wastewater Flow	Max Hourly	=	14,000	m ³ /day																																						
		=	0.162	m ³ /day																																						
[2] Geometry																																										
(1) Number of Basins	1	Basin																																								
(2) Depth of Basin	-	m																																								
(3) Width of Basin	***	m																																								
(4) Length of Basin	***	m																																								

3. Fine Screen Channel (existing structure)	
[1] Design Condition	
(1) Design Wastewater Flow	<p>Max Hourly = 14,000 m³/day = 0.162 m³/sec</p>
[2] Geometry	
(1) Inlet Gate	
Number	1 Main + 1 Bypass
Width	0.800 m
Height	0.800 m
Floor Level	+ *** m
Bottom	+ 85.500 m
Influent Water Level	+ 86.200 m
Velocity	<p>0.162 / 0.800 / 0.700 / 1 = 0.289 < 1.000 m/sec</p>
(2) Screen Channel	
Number	1 Main + 1 Bypass
Width	2.000 m
Side Water Depth	0.600 m
Velocity	<p>0.162 / 2.000 / 0.600 / 1 = 0.135 < 0.450 m/sec</p>
(3) Channel Dimensions	<p>Width 2.0 m × Length 5.0 m × SWD 0.7 m</p>
[3] Equipment	
(1) Inlet Gate	
Number	1 units
Dimension	Width 0.8 m × Height 0.8 m
Design Water Level	m
(2) Fine Screens (Main Channel)	
Number	1 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	2.0 m
Width of side plate	50 mm
Side Water Depth	0.7 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	<p>0.162 / 1.900 / 0.650 / 1 × (6 + 2) / 6 = 0.175 < 0.800 m/sec</p>
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	2.0 m
Side Water Depth	0.7 m
Velocity through screen	<p>0.162 / 2.000 / 0.700 / 1 × (20 + 9) / 20 = 0.168 < 0.800 m/sec</p>

- 4. Grit Chamber**
- [1] Design Condition**
- (1) Design Flow Rate
- (2) Specific gravity of Sand
- (3) Sedimentation Velocity
- (4) Average Velocity
- [2] Grit Chamber**
- (1) Surface Area required
- (2) Number of Basins
- (3) Surface Area required/Basin
- (4) Diameter of Basin
- (5) Basin Dimensions
- [3] Parshall Flume**
- (1) Design Flow Rate
- (2) Throat width
- (3) Water depth Ha
- (4) Crest Level
- (5) Water level at the crest
- (6) Channel bottom level
- (7) Upstream Channel width
- (8) SWD of Upstream Channel
- (9) Average velocity at upstream channel
- (10) Total Length of channel
- 5. UASB (existing)**
- (1) Design Flow Rate
- (2) Design Water Quality
- (3) Design Performance

Max Hourly = 31,500 m³/day
 = 0.365 m³/sec

2.65

0.0521 m/sec = 4,500 m³/m²/day

0.3 m/sec

Vortex Grit Chamber

0.365 / 0.0521 = 7.01 m²

1 S + 1 W

7.0 / 1 = 7.01 m²

(4 / π × 7.01)^{0.5} = 3.0 m
 → 3.0 m

Dia. 3.0 m × Depth m

Q= 365 000 l/sec

W= 0.450 m / W)^{2/3}

Ha= (Q / 2264

Ha= 0.504 m

+ 85.27 m = Minimum water level at downstream channel

+ 85.774 m

+ 85.000 m

1.200 m

0.800 m

0.380 m/sec

10.000 m

	m ³ /d	m ³ /h	m ³ /s
Average Daily	14,000	583.33	0.162
Max Daily	14,000	583.33	0.162
Max Hourly Peak factor 2.25	31,500	1312.50	0.365

Unit: mg/L

	BOD	COD	SS	T-N			TP
				NH ₄ -N	org-N	NO _x -N	
Inlet	250	450	400	25	15	0	5
Outlet	10	50	20	2	0	8	2
Removal rate	96.0%	88.9%	95.0%	75.0%			60.0%

Unit: mg/L

	BOD	COD	SS	T-N			TP
				NH ₄ -N	org-N	NO _x -N	
Inlet of UASB	250	450	400	25	15	0	5
Removal rate	0%	0%	0%	0			-
Outlet of UASB	250.0	450.0	400.0	40.0			-

6. SBR	
[1] Design Condition	
(1) Design Flow	Q = 14,000 m ³ /day (summer) Q' = 14,000 m ³ /day (Winter)
(2) Design Sewage Quality	
Inlet BOD	250 mg/l when UASB process is skipped.
Outlet BOD	10.0 mg/l
Inlet S-BOD	166.7 mg/l assumed as 2/3 of BOD
Inlet COD	450.0 mg/l when UASB process is skipped.
Inlet S-COD :sCOD	300 mg/l assumed as 2/3 of BOD
Outlet S-COD :nbsCODe	33 mg/l =sCOD-1.6sBOD
Inlet rbCOD	68 mg/l assumed as 15% of COD
bCOD/BOD	1.60
Inlet bCOD :S ₀	400 mg/l =1.6BOD
Inlet nbCOD :nbpCOD	50 mg/l =TCOD-bCOD-nbsCODe
Inlet TSS	400 mg/l when UASB process is skipped.
Inlet VSS	280 mg/l assumed as 70% of TSS
:VSS _{cod}	0.54 gCOD/gVSS =TCOD-sCOD/VSS
:nbVSS	31.11 gnbVSS/m ³ =nbpCOD/VSS _{cod}
:iTSS	120.00 gnbVSS/m ³ =TSS-VSS
Inlet T-N	40 mg/l
Inlet TKN	40 mg/l
Inlet NH ₄ -N	25 mg/l
Ammonia oxidized	65.00% of TKN assumed
Inlet T-P	- mg/l
Inlet Alkalinity as CaCO ₃	200 mg/l
Outlet Kjeldahl N	2.0 mg/l
Outlet NH ₄ -N	2.0 mg/l
Outlet NO ₃ -N	8.0 mg/l
(3) Water Temperature	T = 20.0 °C
(4) Safety Factor for Nitrogen	SF = 1.5
(5) Excess Sludge Concentration	R _s = 8,000 mg/l
(6) MLSS	At tank full X _{TSS} = 3,000 mg/l
(7) DO in the Reactor	2 mg/L
(8) Operating Cycle	
T _c Total time	4.80 h
t _f Fill time	2.40 h
t _d Anoxic(denitrification) time	1.05 h
t _a Aeration time	2.00 h
t _s Settlement time	0.75 h
t _p Decanting time	1.00 h
(9) Number of cycles	5.0 cycles/basin * day × 2 tanks total 10 cycles/day
(10) Full volume per cycle	1,400.000 m ³ /fill
(11) Full liquid depth	5.50 m
(12) Decant depth	1.65 m 30.0% of full tank depth
(13) Required aeration tank volume	4666.67 m ³ /tank ra = 0.667 day 16.000 h
(14) Decant flow rate	1,400.000 m ³ /fill / 1.00 h = 1400 m ³ /h
(15) No. of basins receiving flow simultaneously	1 nos.
(16) No. of basins Aerating simultaneously	1 nos.
(17) No. of basins Decanting simultaneously	1 nos.
(18) Flow rate	583.33 m ³ /h
(19) Flow rate to each basin	583.33 m ³ /h

[2] Design for Nitrification Process

(1) Activated sludge design kinetic coefficients at 20°C

Coefficient	Unit	COD oxidation	NH4 oxidation	NO2 oxidation
μ_{max}	gVSS/gVSS · d	6.000	0.900	1.000
K_s, K_{NH4}, K_{NO2}	mg/L	8.000	0.500	0.200
γ	gVSS/g substrate oxidized	0.450	0.150	0.050
b	gVSS/gVSS · d	0.120	0.170	0.170
f_H	unitless	0.150	0.150	0.150
K_{O2}	mg/L	0.200	0.500	0.900
θ_{Value}				
μ_{max}	unitless	1.070	1.072	1.063
b	unitless	1.040	1.029	1.029
K_s, K_{NH4}, K_{NO2}	unitless	1.000	1.000	1.000

Wastewater Engineering Treatment and Resource Recovery Fifth Edition (Metcalf & Eddy/AECOM)

(2) SRT calculated with the assumed operating condition

SRT = 7.0733 day

a. $(P_{X,SS})SRT$	28,000.000 kg	= $V \cdot N_{MLSS}$
b. $(P_{X,SS})SRT$	27,994.272 kg	= SUM(① : ⑤)
① =	11,332.322 kg	= $Q(SRT) \cdot Y_{IF}(S_0 - S) [1 + b_{IF}(SRT)] \cdot 0.85$
② =	3,080.815 kg	= $Q(SRT)nbVSS$
③ =	253.851 kg	= $Q(SRT)Y_{n(NOx)} [1 + b_n(SRT)] \cdot 0.85$
④ =	1,444.140 kg	= $f_H \cdot b_{IF} \cdot Q Y_{IF}(S_0 - S) SRT^2 [1 + b_{IF}(SRT)] \cdot 0.85$
⑤ =	11,883.144 kg	= $Q(SRT)(TSS_0 - VSS_0)$

(3) Sludge production $P_{X,SS}$

$P_{X,SS}$ = 3,957.739 kg/day

(4) Determine MLVSS concentration

$(P_{X,SS})SRT$

$(P_{X,SS})SRT$	14,156.581 kg	= SUM(① : ④)
① =	9,632.474 kg	= $Q(SRT) \cdot Y_{IF}(S_0 - S) [1 + b_{IF}(SRT)]$
② =	3,080.815 kg	= $Q(SRT)nbVSS$
③ =	215.773 kg	= $Q(SRT)Y_{n(NOx)} [1 + b_n(SRT)]$
④ =	1,227.519 kg	= $f_H \cdot b_{IF} \cdot Q Y_{IF}(S_0 - S) SRT^2 / [1 + b_{IF}(SRT)]$

X_{MLVSS}

X_{MLVSS} = 1,517 mg/l

NOx

NOx = 26.000 mg/l = $TKN \times 65.00\%$

S

S = 0.3644 mg/l = $K_s [1 + b_{IF}(SRT)] / [SRT(\mu_{max} - b_{IF}) - 1]$

b_{IF}

b_{IF} = 0.1200 = $b \cdot 1.04^{(T-20)}$ b at 20°C = 0.120

Y_{IF}

Y_{IF} = 0.4500 gVSS/g bCOD

μ_{max}

μ_{max} = 6.0000 g/g · d = $\mu_{max} \cdot 1.04^{(T-20)}$ μ_{max} at 20°C = 6.000

Y_n

Y_n = 0.150 gVSS/g NOx

b_n

b_n = 0.1117 = $b_{NOB1} \cdot (ta/Tc) + b_{NOB2} \cdot (1 - ta/Tc)$

b_{NOB1} at aerobic

b_{NOB1} = 0.1700 = $b \cdot 1.029^{(T-20)}$ b at 20°C = 0.170

b_{NOB2} at anoxic

b_{NOB2} = 0.0700 = $b \cdot 1.029^{(T-20)}$ b at 20°C = 0.070

FractionVSS

FractionVSS = 0.506 = MLVSS/MLSS

(5) Determine amount of NH4-N oxidized

Biomass production $P_{X,bio}$

$P_{X,bio}$	1,565.856 kg	= SUM(① : ③)
① =	1,361.808 kg	= $Q \cdot Y_{IF}(S_0 - S) / [1 + b_{IF}(SRT)]$
② =	30.505 kg	= $Q Y_n(NOx) / [1 + b_{AOB}(SRT)]$
③ =	173.543 kg	= $f_H \cdot b_{IF} \cdot Q Y_{IF}(S_0 - S) SRT / [1 + b_{IF}(SRT)]$

NOx = 24.578 mg/l = $TKN_0 - N_c - 0.12 P_{X,bio} / Q$

< 26.000 mg/l (assumed NOx) OK

(6) NO3-N Produced per cycles	At tank full	NO3-N =	34.410 gNOx/fill	
			7.374 g/m3	concentration
		<	8.0 g/m3	OK
	After decant	NO3-N =	24.087 gNOx/decant	
			7.374 g/m3	concentration
	At tank full	Xb=	1032.051 g/m3	=Px, bio * SRT / V _T
		Biomass=	4.816 kg	
		Q _F =	14,000 m3/d	=V _F /t _F
		Q _F * S _O =	3,500 kg/day	
	(7) Initial NH4-N		N _O =	8.774 mg/l
V _F (NOx)=			34.410 kg	
V _{S(Ne)} =			6.533 kg	
(8) Nitrifier concentration		X _n =	21.9 mg/l	= Q * Y _n * NOx * SRT / [1 + b _{NOB} (SRT)] * V
	b _{NOB}		0.1117	
(9) Review of Aeration time for nitrification		t=	7.512809498	= K _{NH4} ln(N _o /N _i) + (N _o - N _i)
			104.9015798	= X _n (μ _{max, AOB} / Y _n) [S _o / (K _{o, AOB} + S _o)]
		t=	0.072 day	
			1.719 h	
		<	2.00 h (Aeration time)	OK
		μ _{max, NOB, T} =	0.9000 g/g · d	= μ _{max} * 1.072 ^(T-20) μ _{max} at 20°C = 0.900
		μ _{NOB, T} =	0.7200 g/g · d	= μ _{max, NOB} [S _o / (S _o + K _{O2, NOB})]
		S _o =	2.000 mg/l	
		K _{O2, NOB} =	0.500 mg/l	
		K _{NH4} =	0.500 mg/l	
[3] Design for Denitrification Process				
(1) F/M _b		F/M _b =	0.727 g/g · d	
(2) Fraction of rbCOD			16.88%	= rbCOD / bCOD
		Percent rdCOD(%)	SDNR equation coefficients	
			b0	b1
		10	0.186	0.078
		20	0.213	0.118
		30	0.235	0.141
		40	0.242	0.152
		50	0.270	0.162
(3) SDNRb		SDNRt=	0.175 g/g · d	= SDNR _b * θ ^(t-20)
				θ= 1.026
		SDNRb=	0.175 g/g · d	= b ₀ + b ₁ [ln(F/M _b)]
		b ₀ =	0.213	
	b ₁ =	0.118		
(4) NO3-N removal capacity during the fill period (per tank)		NOx=	844.435 g/g · d	= SDNR _t (X _b) (V _T)
		td=	1.050 hr	
(5) NO3-N removal capacity .NOR		NOR=	36,944 g	= NO _x · td / 24
		>Nox feed=	24.087 g	OK

[4] Geometry						
(1) Basin Dimensions	Width	Length	Depth	Basins		
	29.0		30.0	5.5	2	
Cross Section	29.0*5.5		=	159.5 m ² /Basin		
Total Volume	159.5*30.0		=	4,785 m ³ /Basin		4,667 m ³
				9,570 m ³ /Total		
[5] Equipment						
(1) RAS Pumps						
RAS Ratio	10	%				
Required Capacity	583	m ³ /hr		10%		
	= 58	m ³ /Hr		⇒	60	m ³ /Hr
Number	2	Work				
	1	Standby (Spare)				
(2) SAS Pumps						
Excess Sludge	669	m ³ /day				
Sludge withdraw	5	cycles/day				
Running Time	1.0	Hr/Time				
Required Capacity	669	m ³ /day /		5 /	1.00 /	2
	= 66.88	m ³ /Hr		⇒	12	m ³ /Hr
Number	2	Work				
	1	Standby (Spare)				

7. Air Requirement at Average Flow	
[1] Design Condition	
(1) O2 demand	$R_0 = Q(S_0 - S - 2.86(\text{NOx} - \text{NOx}_e)) - 1.42P_{X,\text{bio}} + 4.57Q \cdot \text{NOx}$
$R_0 =$	4,944 kg O2/d
Q_{in} : Design Average Flow	14,000 m ³ /d
Inlet bCOD	$S_0 =$ 400 mg/l
$S =$	0.364 mg/l
$\text{NOx} =$	24.578 mg/l
$P_{X,\text{bio}} =$	1,565.9 kg VSS/d * does not include nitrifying bacteria
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{R_0}{\alpha \times F \left(\beta \cdot C_{sw/cs} \cdot (P_b/P_a)a - C_A \right)}$
	C_S : Saturated DO at sea level and 20 °C degrees Celsius 9.09 mg/L
	C_{sw} : Saturated DO at sea level and operating Temperature 6.93 mg/L at 35 degrees Celsius
	$20 - T$: -15.0 1.024 ^{20-T} : 0.7006
	C_A : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1+0.40D _j /Pa 1.19357
	D_j : Tank Liquid Depth 5.00 m
	P_a : Standard absolute pressure at sea level 10.332 m
	P_b : Absolute pressure at Plant Site Elevation m
	P_b/P_a : exp[-gM(z _b -z _a)/R*T] 0.991
	g : Acceleration due to Gravity 9.80665 m/s ²
	M : Mole of Air 28.97 kg/kg-mole
	z_b : Plant Site Elevation 85 m
	z_a : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 308.15 Kelvin
	α : relative Transfer Rate to clean Water 0.65
	β : relative DO Saturation to clean Water 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{37,582}{3.3837} = 11,106.75 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Number of cycles	5.0 cycles/basin · day × 2
	total 10 cycles/day
(5) Standard O2 required at Field Conditions per cycle =	1,110.7 kg/cycle/basin/day
(6) SOTE for the above Effective Aeration Depth	30.5 %
(7) Fraction of O2 in Air	23.18 %
(8) Specific Gravity of Air at Standard Condition	1.293
(9) Safety Factor	10%
(10) Air required at Field Conditions per cycle =	14,344 m ³ /cycle/basin/day
(11) Aeration time per cycle t _A	2.00 h
	= 7,172.0 m ³ /hr/basin

[2] Equipment					
(1) Air Blower					
Operating No. per basin		4	unit/Basin		
Operating No. per set of blowers		2	basin/set		
Required Capacity		7172.0	m ³ /hr · Basin	÷	4 unit/Basin
	=	1793.0	m ³ /hr	⇒	2000 m ³ /hr /Unit
Number		4	W	+	2 S
Pressure		65	kPa		
Safety Factor		10	%		
Heat capacity ratio		1.4			
Atmospheric pressure at site elevation		100.374	kPa		
Total inlet pressure		98.374	kPa		
Volume rate of flow at inlet point		34.325	m ³ /min		
Total discharge pressure		165.374	kPa		
Overall adiabatic efficiency		0.65			
Inlet air temperature (min)		15	°C		
Shaft power		49.323	kW		
Rated Output of Motor		54.255	kW	⇒	75 kW
8. Equalization Tank					
[1] Geometry					
Design Flow Rate	Peak Flow	1312.5	m ³ /h	=	0.365 m ³ /sec
Design Flow Rate	Average Flow	583.3	m ³ /h	=	0.162 m ³ /sec
Width		7.00	m		
Length		30.00	m		
Pump Operating Depth		1.50	m		
Storage capacity		(7.00 × 30.00 × 1.50) / 4			583.3
	=	0.54	h	>	0.5 h Average Flow
High Water Level		+ 83.600	m		
Pump Off Level		+ 82.100	m		
[2] Equipment					
(1) CCT Feed Pump					
Number		4	W	+	2 S
Discharge Flow		1312.5	m ³ /h	÷	4
Design Flow for the year 2035	=	328	m ³ /h	⇒	330 m ³ /h

9. Chlorination	
[1] Design Condition	
(1) Design Flow Rate	Average Daily Flow 32,000 m ³ /day included 18MLD STP
(2) Contact Time	30 min
(3) Type of Chlorine	Bleaching Powder (Availitive chlorine 70%)
(4) Design Chlorine Dosage Rate	10 mg/L
(5) Required Chlorine per day	Average Daily Flow / 1000 × Design Chlorine Dosage Rate = 320.0 kg/d = 13.33 kg/h
(6) Consumption per day	457.1 kg/d as Bleaching Powder
[2] Chlorination Contact Tank	
(1) Volume required	Average Daily Flow / 1440 × Contact Time = 666.7 m ³
(2) Nos. of lanes	5 lanes
(3) Width of lane	2.00 m
(4) Length of lane	23.00 m
(5) Side Water Depth	3.00 m
(6) Nos. of Tanks	1 tank
(7) Total Width of Tank	13.00 m Approx.
(8) Average Velocity	Average Daily Flow / 86400 / Width / Depth = 32,000 / 86400 / 2.00 / 3.00 = 0.062 m/sec
(9) Total Volume	Width × Length × Depth × Nos. of lanes × Nos. of Tanks = 2.0 m × 23.0 m × 3.0 m × 5 × 1 = 690 m ³ > 666.7 m ³
[3] Equipment	
(1) Chlorine Solution Tank	
Number	2 W + 0 S
Chlorine concentration	2 %
Gravity of dissolved chlorine	1.10
Required solution volume	320.00 kg/d × 100 / 2 / 1.10 / 1000 = 14.55 m ³ /d = 582 l/h
Dimension of Tank	2.0 mW × 2.0 mL × 2.5 mSWD
Volume of Tank	10.0 m ³ /tank
Total Volume of Tanks	20.0 m ³ (Duration= 1.38 day)
(2) Mixer for Chlorine Solution Tank	
Number	2 W + 0 S
(3) Chlorine Dosing Pump	
Number	2 W + 1 S
Capacity	582 l/h / 2 291 l/h/unit ⇒ 300 l/h/unit


10. Dechlorination	
[1] Design Condition	
(1) Design Flow Rate	Average Daily Flow 32,000 m ³ /day
(2) Contact Time	10 min
(3) Type of Dechlorine	Sodium Thiosulfate (Na ₂ S ₂ O ₄ · 5H ₂ O)
(4) Free Residual Chlorine	1.0 mg/L assumed value
(5) Consumption per day	$\begin{aligned} &\text{Average Daily Flow} \quad / \quad 1000 \quad \times \quad \text{Free Residual Chlorine} \quad \times \quad 1.19 \\ &\times \quad 2 \quad (\text{safety factor}) \\ &= \quad 76.2 \quad \text{kg/d} \\ &= \quad 3.17 \quad \text{kg/h} \end{aligned}$
[2] Dechlorination Contact Tank	
(1) Volume required	$\begin{aligned} &\text{Average Daily Flow} \quad / \quad 1440 \quad \times \quad \text{Contact Time} \\ &= \quad 222.2 \quad \text{m}^3 \\ &\text{Contact Time} \quad 10 \text{ min} \end{aligned}$
(2) Width of lane	13.00 m
(3) Length of lane	6.00 m
(4) Side Water Depth	3.00 m
(5) Nos. of Tanks	1 tank
(6) Total Volume	$\begin{aligned} &\text{Width} \quad \times \quad \text{Length} \quad \times \quad \text{Depth} \\ &= \quad 13.0 \quad \text{m} \quad \times \quad 6.0 \quad \text{m} \quad \times \quad 3.0 \quad \text{m} \\ &= \quad 234 \quad \text{m}^3 > \quad 222.2 \quad \text{m}^3 \end{aligned}$
[3] Equipment	
(1) Dechlorine Solution Tank	
Number	2 W + 0 S
Dechlorine concentration	10 %
Gravity of dissolved dechlorine	1.10
Required solution volume	$\begin{aligned} &76.16 \quad \text{kg/d} \quad \times \quad 100 \quad / \quad 10 \quad / \quad 1.10 \quad / \quad 1000 \\ &= \quad 0.69 \quad \text{m}^3/\text{d} \\ &= \quad 27.69 \quad \text{l/h} \end{aligned}$
Volume of Tank	1.0 m ³ /tank
Total Volume of Tanks	2.0 m ³ (Duration= 2.89 day)
(2) Mixer for Dechlorine Solution Tank	
Number	2 W + 0 S
(3) Dechlorine Dosing Pump	
Number	1 W + 1 S
Capacity	27.69 l/h / 1
	27.69 l/h/unit ⇒ 30 l/h/unit

11. Sludge Thickener					
[1] Design Condition					
(1) UASB Sludge (14MLD STP)		0	kg/day		0 m ³ /day
(2) Excess Sludge (14MLD STP)		5,351	kg/day		669 m ³ /day
(2) Excess Sludge (18MLD STP)		5,882	kg/day		735 m ³ /day
(3) Total Solids		11,233	kg/day		1,404 m ³ /day
(4) Operation Time		24	hours/day		
(5) Thickened Sludge Moisture Content		97.5	%		
[2] Geometry					
(1) Type					
(2) Number		2	W	+	0 S
(3) Design Solid Loading		40	kg / m ² /d		
(4) Required Surface Area		11233		$\times \frac{1}{40} =$	280.80 m ²
(5) Required diameter		$(\frac{4}{\pi} \times 280.80 \times \frac{1}{2})^{1/2}$			$= 13.37$ m
					$\rightarrow 13.50$ m
(6) Side Water Depth		4	m		
(7) Actual Volume of Tank		$\frac{\pi}{4} \times 13.50^2 \times 4$		$=$	572.56 m ³
(8) Retention Time		$\frac{572.56}{1404} \times 2 \times 24$		$=$	19.58 Hr
12. Thickened Sludge Sump					
[1] Design Condition					
(1) Inlet Solids		4,816	kg/day	+	5,294 kg/day = 10,109 kg/day
(2) Inlet Sludge Volume		193	m ³ /d	+	212 m ³ /d = 404 m ³ /d
[2] Geometry					
(1) Sludge withdrawal		12	Times/day		
(2) Required Sump Volume		34	m ³ /time		
(3) Number		2	Basins		
(4) Width		2.5	m		
(5) Length		2.5	m		
(6) Side Water Depth		3.0	m		
(7) Actual Sump Volume		$2.5 \times 2.5 \times 3.0 \times 2$		$=$	37.5 m ³
[3] Equipment					
(1) Thickened Sludge Pumps					
Transfer Time		6.00	Hr		
Number		1	W	+	1 S
Required Capacity		$\frac{404}{6.0}$	m ³	\Rightarrow	$\frac{67.4}{70}$ m ³ /Hr /Unit


<p>13 Centrifuge [1] Design Condition (1) Type of Dewatering (2) Quantity of Thickened Sludge generated (3) Design Polyelectrolyte Dosage (4) Volume of Thickened Sludge (5) Consistency of Dewatered Sludge (6) Operation Time</p>	<p>Centrifuge 10,109 kg/day Polyelectrolyte 1.5 kg/t-DS·day 404.4 m³/day 82 % 8 hours/day (6 days per week)</p>
<p>[2] Volume of Centrifuges</p>	$\frac{\text{Digested Solids}}{\text{Operation Time} \times \text{No.}} \times \text{Operation/week}$ $= \frac{404.4}{8 \times 2} \times \frac{7}{6} = 29.5$ <p style="text-align: right;">→ 30 m³/hour</p>
<p>[3] Dewatered Solids</p>	<p>Digested Sludge × (1 + Injection Rate) = 10,109 × (1 + 0.0015) = 10,125 kg/day</p>
<p>[4] Dewatered Cake Volume</p>	<p>Dewatered Solids × $\frac{100}{100 - \text{Moisture Content}}$ × $\frac{7}{6 \text{ days per week}}$</p> $= 10,125 \times \frac{100}{100 - 82} \times \frac{7}{6}$ <p>= 65.63 t/day apparent specific gravity 1.00</p> $\frac{65.63}{1.0} = 65.6 \text{ m}^3/\text{day}$
<p>[5] Polyelectrolyte (1) Design Polyelectrolyte Dosage (2) Required Polyelectrolyte (3) Dissolving concentration (4) Volume of Polyelectrolyte solution</p>	<p>Polyelectrolyte 1.5 kg/t-DS·day 15.16 kg/day 0.20 % 7.58 m³/day</p>
<p>[6] Equipment (1) Centrifuge Capacity Number (2) Centrifuge Feed Pumps Capacity Number (3) Polyelectrolyte Dosing Pumps Volume of Polyelectrolyte solution Operation Time Safety Factor Number Required Capacity Specification Capacity</p>	<p>30 m³/hr 2 W + 1 S 30 m³/hr 2 W + 1 S 7.58 m³/day 8 hours/day (6 days per week) 1.5 2 W + 1 S 7.58 m³/Hr / 8.0 / 2 = 0.47 m³/Hr 0.47 m³/Hr × 1.5 = 0.711 m³/Hr ⇒ 0.80 m³/Hr /Unit</p>
<p>(4) Polyelectrolyte dosing System Tanks Dimensions Retention Time of Tanks Number</p>	<p>Width 2.0 m × Length 2.0 m × Depth 2.0 m × 2 (Freeboard 0.5m) = 16 m³ 16.00 m³ / 0.47 m³/Hr / 2 = 16.882 Hr 2 W + 0 S</p>

14. Centrifuge Feed Sump	
[1] Design Condition	
(1) Generated Thickend Sludge	10,109 kg/day
(2) Solids Consistency	2.50 %
(3) Volume of Thickened Sludge	$\text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3}$ $= 10,109 \times \frac{100}{2.50} \times 10^{-3}$ $= 404 \text{ m}^3/\text{day}$ $= 16.85 \text{ m}^3/\text{h}$
(4) Sludge feed flow rate	30 m ³ /h × 2 = 60 m ³ /h
(5) Centrifuge Operation Time	8 hours/day (6 days per week)
[2] Geometry	
(1) Required sludge volume for continuation	$(60 - 16.85) \times 8$ $= 345.21 \text{ m}^3$
(2) Basin Dimensions	$\text{Width } 5.0 \text{ m} \times \text{Length } 6.0 \text{ m}$ $\times \text{Depth } 3.0 \text{ m} \times 4$ $= 360.0 \text{ m}^3$
[3] Equipment	
(1) Mixers for Centrifuge Feed Sumps	
Required Volume	360.0 m ³
Number	1 W + 1 S

Material Balance Sheet
[Mirzapur 14MLD STP SBR]



MIRZAPUR UPGRADE OF EXISTING 14MLD STP



- Main Process ————
- Sludge Line ————
- Other Line ————
- Existing structure - - - - -

Project Name PREPARATORY SURVEY ON GANGA REJUVENATION PROJECT IN THE STATE OF UTTARPRADESH, INDIA インド国ガンジス川浄化事業準備調査	
Drawing Title Mirzapur STP 14MLD Layout	Scale: not
Drawing No. STP-06	

5. Mirzapur 18MLD STP

Design Condition

Item	Chunar-MPS			
(1) Design Flow for the year 2050	Flow Rate			
		m ³ /d	m ³ /h	m ³ /s
	Average Daily	22,580	941	0.261
	Max Dayly	22,580	941	0.261
	Max Hourly Peak factor 2.25	50,805	2117	0.588
(1) Design Flow for the year 2035	Flow Rate			
		m ³ /d	m ³ /h	m ³ /s
	Average Daily	19,360	807	0.224
	Max Dayly	19,360	807	0.224
	Max Hourly Peak factor 2.25	43,560	1815	0.504

1. Inlet Chamber

Item	Chunar-MPS			
[1] Design Condition				
(1) Design Flow for the year 2050	Max Hourly	=	50,805	m ³ /day
		=	0.588	m ³ /sec
(2) Inlet Pipe				
Pipe Diameter				mm
Gradient				‰
Roughness Coefficient	n=	0.013	(Manning Formula)	
Full Pipe Flow Rate				m ³ /sec
(3) Influent Water Level	+			m
[2] Geometry				
(1) Number of Basins	1	Basin		
(2) Depth of Basin	1.000	m	Approx	
(3) Width of Basin	3.000	m	Approx	
(4) Length of Basin	2.000	m	Approx	
(5) Volume required of Basin	1.000	×	3.000	×
			2.000	= 15 m ³
(6) Retention Time	1.000	×	3.000	×
			2.000	∕ 0.588 × 1
	=	10.20	sec	
(7) Basin Dimensions	Width	3.000	m	×
			Length	2.000
			Depth	1.000
				m

2. Coarse Screen Channel

Item	Chunar-MPS					
[1] Geometry						
(1) Inlet Gate						
Number	1	Main	+	1	Bypass	
Width	0.600	m				
Height	0.900	m				
Floor Level	+	83.300	m			
Bottom	+	71.900	m			
Influent Water Level	+	72.800	m			
Velocity	0.588	/		0.600	/	0.900 / 1
whe Design Flow for the year 2050	=	1.089	<	1.000	m/sec	OK
Velocity	0.504	/		0.600	/	0.900 / 1
whe Design Flow for the year 2035	=	0.933	<	1.000	m/sec	OK
(2) Screen Channel						
Number	1.0	Main	+	1.0	Bypass	
Width	1.200	m				
Side Water Depth	1.000	m				
Velocity	0.588	/		1.200	/	1.000 / 1
whe Design Flow for the year 2050	=	0.490	≐	0.450	m/sec	OK
Velocity	0.504	/		1.200	/	1.000 / 1
whe Design Flow for the year 2035	=	0.420	<	0.450	m/sec	OK
(3) Channel Dimensions	Width	1.2	m	×	Length	8.5 m
					SWD	1.0 m (Freeboard 0.3m)
[3] Equipment						
(1) Inlet Gate						
Number	2	Units				
Dimension	Width	0.6	m	×	Height	0.9 m
Design Water Level		m				
(2) Coarse Screens (Main Channel)						
Number	1	W	+	0	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	1.2	m				
Width of side plate	50	mm				
Side Water Depth	1.0	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.588	/		1.100	/	0.950 / 1
	× (20	+	9)/	20
	=	0.816	≐	0.800	m/sec	OK
Velocity through screen	0.504	/		1.100	/	0.950 / 1
whe Design Flow for the year 2035	× (20	+	9)/	20
	=	0.699	<	0.800	m/sec	OK
(3) Coarse Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	50	mm				
Bar Thickness	9	mm				
Channel Width	1.2	m				
Side Water Depth	1.0	m				
Velocity through screen	0.588	/		1.200	/	1.000 / 1
whe Design Flow for the year 2050	× (50	+	9)/	50
	=	0.578	<	0.800	m/sec	OK
Velocity through screen	0.504	/		1.200	/	1.000 / 1
whe Design Flow for the year 2035	× (50	+	9)/	50
	=	0.496	<	0.800	m/sec	OK

3. Raw Sewage Sump

Item	Chunar-MPS			
[2] Geometry				
(1) Raw Sewage Sump				
Number	1	Basin		
Dia	10.00	m		
Pump Operating Depth	1.700	m		
Retention Time whe Design Flow for the year 2050	$t = 10.00 \times \frac{\pi}{4} \times 1.700 \div 0.588 \div 60$			
	= 3.78	> 3.75	min (=minimum time of one pump cycle 'OK	
Retention Time whe Design Flow for the year 2035	$t = 10.00 \times \frac{\pi}{4} \times 1.700 \div 0.504 \div 60$			
	= 4.42	> 3.75	min (=minimum time of one pump cycle 'OK	
High Water Level	72.600	m		
Pump Off Level	70.900	m		
[3] Equipment				
(1) Sewage Pumps				
Number	4	W	+	2 S
Bore Diameter	150	mm		
Discharge Flow whe Design Flow for the year 2035	$0.504 \times 3600 \div 4$			
	= 454	=	460	m ³ /Hr
Total Head	21.0	m		

Item	Mirzapur-STP 18MLD																																									
1. STP Design Condition																																										
(1) Design Flow Rate	<table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th></th> <th>m³/d</th> <th>m³/h</th> <th>m³/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td>18,000</td> <td>750</td> <td>0.208</td> </tr> <tr> <td>Max Daily</td> <td>18,000</td> <td>750</td> <td>0.208</td> </tr> <tr> <td>Max Hourly Peak factor 2.25</td> <td>40,500</td> <td>1687.5</td> <td>0.469</td> </tr> </tbody> </table>								m ³ /d	m ³ /h	m ³ /s	Average Daily	18,000	750	0.208	Max Daily	18,000	750	0.208	Max Hourly Peak factor 2.25	40,500	1687.5	0.469																			
	m ³ /d	m ³ /h	m ³ /s																																							
Average Daily	18,000	750	0.208																																							
Max Daily	18,000	750	0.208																																							
Max Hourly Peak factor 2.25	40,500	1687.5	0.469																																							
(2) Design Water Quality	<div style="text-align: right;">Unit:mg/L</div> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th rowspan="2">TP</th> </tr> <tr> <th>NH₄-N</th> <th>Org-N</th> <th>NOx-N</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td>250</td> <td>450</td> <td>400</td> <td>25</td> <td>15</td> <td>0</td> <td></td> </tr> <tr> <td>Outlet</td> <td>10</td> <td>50</td> <td>20</td> <td>2</td> <td>0</td> <td>8</td> <td></td> </tr> <tr> <td>Removal rate</td> <td>96.0%</td> <td>88.9%</td> <td>95.0%</td> <td colspan="3">75.0%</td> <td>-</td> </tr> </tbody> </table>								BOD	COD	SS	T-N			TP	NH ₄ -N	Org-N	NOx-N	Inlet	250	450	400	25	15	0		Outlet	10	50	20	2	0	8		Removal rate	96.0%	88.9%	95.0%	75.0%			-
	BOD	COD	SS	T-N			TP																																			
				NH ₄ -N	Org-N	NOx-N																																				
Inlet	250	450	400	25	15	0																																				
Outlet	10	50	20	2	0	8																																				
Removal rate	96.0%	88.9%	95.0%	75.0%			-																																			
2. Inlet Chamber																																										
[1] Design Condition																																										
(1) Design Flow Rate	Max Hourly	=	40,500	m ³ /day																																						
		=	0.469	m ³ /sec																																						
[2] Geometry																																										
(1) Number of Basins	1	Basin																																								
(2) Depth of Basin	2.000	m																																								
(3) Width of Basin	3.200	m																																								
(4) Length of Basin	4.500	m																																								
(5) Volume required of Basin	2.000	×	3.200	×	4.500	=	1.4 m ³																																			
(6) Retention Time	2.000	×	3.200	×	4.500	/	0.469 × 1																																			
	= 61.4072495 sec																																									
(7) Basin Dimensions	Width	3.200	m	×	Length	4.500	m																																			
		×	Depth	2.000	m																																					

3. Fine Screen Channel						
[1] Design Condition						
(1) Design Flow Rate		Max Hourly	=	40,500	m ³ /day	
			=	0.469	m ³ /sec	
[2] Geometry						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Width	0.600	m				
Height	0.900	m				
Floor Level	+ 91.800	m				
Bottom	+ 88.600	m				
Influent Water Level	+ 89.300	m				
Velocity	0.469	/	0.600	/	0.700 / 2	
	=	0.558	<	1.000	m/sec	
(2) Screen Channel						
Number	2	Main	+	1	Bypass	
Width	0.800	m				
Side Water Depth	0.700	m				
Velocity	0.469	/	0.800	/	0.700 / 2	
	=	0.419	<	0.450	m/sec	
(3) Channel Dimensions						
Width	0.8	m	+	Length	6.0 m	
		SWD	0.7	m		
[3] Equipment						
(1) Inlet Gate						
Number	2	Units				
Dimension	Width	0.6	m	-	Height	0.9 m
Design Water Level	3.20	m				
(2) Fine Screens (Main Channel)						
Number	2	W	+	0	S	
Open Space	6	mm				
Bar Thickness	2	mm				
Channel Width	0.8	m				
Width of side plate	50	mm				
Side Water Depth	0.7	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.469	/	0.700	/	0.650 / 2	
	=	0.687	<	0.800	m/sec	
(3) Fine Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	0.8	m				
Side Water Depth	0.7	m				
Velocity through screen	0.469	/	0.800	/	0.700 / 2	
	=	0.607	<	0.800	m/sec	

4. Grit Chamber	
[1] Design Condition	
(1) Design Flow Rate	Max Hourly = 40,500 m ³ /day = 0.469 m ³ /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0111 m/sec = 960 m ³ /m ² /day
(4) Average Velocity	0.3 m/sec
[2] Grit Chamber	
(1) Surface Area required	0.469 / 0.0111 = 42.25 m ²
(2) Number of Basins	2 S + 0 W
(3) Surface Area required/Basin	42.3 / 2 = 21.13 m ²
(4) Length of Basin	21.1261261 [^] 0.5 = 4.6 m → 5.0 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.469 × 60 sec / 2 = 14.1 m ³
(7) Depth required	14.1 / 5.0 / 5.0 = 0.563 m
(8) Basin Dimensions	Width 5.0 m × Length 5.0 m × Depth 0.6 m (Freeboard 0.3m)
(9) Retention Time	5 × 5.0 × 0.6 / 0.469 × 2 = 60.00 sec
(10) Surface Overflow Rate at Peak Flow	40,500 / 5.0 / 5.0 / 2 = 810 < 960 m ³ /m ² /day
[3] Parshall Flume	
(1) Design Flow Rate	Q= 469.000 l/sec
(2) Throat width	W= 0.450 m / W) ^{2/3}
(3) Water depth Ha	Ha= (Q / 2264
	Ha= 0.596 m
(4) Crest Level	+ 86.900 m ≅ Minimum water level at downstream channel
(5) Water level at the crest	+ 87.496 m
(6) Channel bottom level	+ 86.700 m
(7) Upstream Channel width	1.500 m
(8) SWD of Upstream Channel	0.800 m
(9) Average velocity at upstream channel	0.391 m/sec
(10) Total Length of channel	10.000 m

5. SBR		
[1] Design Condition		
(1) Design Flow Rate	$Q = 18,000 \text{ m}^3/\text{day}$ (summer) $\bar{Q} = 18,000 \text{ m}^3/\text{day}$ (Winter)	
(2) Design Sewage Quality		
Inlet BOD	250 mg/l	
Outlet BOD	10.0 mg/l	
Inlet S-BOD	167 mg/l	
Inlet COD	450 mg/l	
Inlet S-COD : sCOD	300 mg/l	
Outlet S-COD : nbsCODe	33 mg/l	=sCOD-1.6sBOD
Inlet rbCOD	60 mg/l	
bCOD/BOD	1.60	
Inlet bCOD : S_b	400 mg/l	=1.6BOD
Inlet nbCOD : nbpCOD	50 mg/l	=TCOD-bCOD-nbsCODe
Inlet TSS	400 mg/l	
Inlet VSS : VSS _{cod}	280 mg/l	
: nbVSS	0.54 gCOD/gVSS	=TCOD-sCOD/VSS
: rTSS	32.11 gnbVSS/m ³	=nbpCOD/VSS _{cod}
	120.00 gnbTSS/m ³	=TSS-VSS
Inlet T-N	40 mg/l	
Inlet TKN	40 mg/l	
Inlet NH ₄ -N	25 mg/l	
Ammonia oxidized	60.00% of TKN assumed	
Inlet T-P	- mg/l	
Inlet Alkalinity as CaCO ₃	200 mg/l	
Outlet Kjeldahl N	2.0 mg/l	
Outlet NH ₄ -N	2.0 mg/l	
Outlet NO ₃ -N	8.0 mg/l	
(3) Water Temperature	T = 20.0 °C	
(4) Excess Sludge Concentration	R _s = 8,000 mg/l	
(5) MLSS	At tank full $X_{TSS} = 3,000 \text{ mg/l}$	
(6) DO in the Reactor	2 mg/L	
(7) Operating Cycle		
T _c Total time	4.80 h	
t _f Fill time	2.40 h	
t _d Anoxic(denitrification) time	0.95 h	
t _a Aeration time	2.10 h	
t _s Settlement time	1.00 h	
t _p Decanting time	0.75 h	
(8) Number of cycles	5.0 cycles/basin · day × 4 tanks	
	total 20 cycles/day	
(9) Full volume per cycle	900,000 m ³ /fill	
(10) Full liquid depth	5.50 m	
(11) Decant depth	1.65 m	30.0% of full tank depth
(12) Required aeration tank volume	3000.00 m ³ /tank	ra = 0.6667 day
		16 h
(13) Decant flow rate	900,000 m ³ /fill / 0.75 h = 1200 m ³ /h	
(14) No. of basins receiving flow simultaneously	2 nos.	
(15) No. of basins Aerating simultaneously	2 nos.	
(16) No. of basins Decanting simultaneously	1 nos.	
(17) Flow rate	750 m ³ /h	
(18) Flow rate to each basin	375 m ³ /h	

[2] Design for Nitrification Process

(1) Activated sludge design kinetic coefficients at 20°C

Coefficient	Unit	COD oxidatio	NH4 oxidatio	NO2 oxidatio
μ_{max}	gVSS/gVSS · d	6.000	0.900	1.000
K_s, K_{NH4}, K_{NO2}	mg/L	8.000	0.500	0.200
Y	gVSS/g substrate oxidized	0.450	0.150	0.050
b	gVSS/gVSS · d	0.120	0.170	0.170
fd	unitless	0.150	0.150	0.150
K_{C2}	mg/L	0.200	0.500	0.900
θ Value				
μ_{max}	unitless	1.070	1.072	1.063
b	unitless	1.040	1.029	1.029
K_s, K_{NH4}, K_{NO2}	unitless	1.000	1.000	1.000

Wastewater Engineering Treatment and Resource Recovery Fifth Edition (METCALF & EDDY/AECOM)

(3) SRT calculated with the assumed operating condition

SRT = 7.0600 day

a: $(P_{X,TSS})SRT = 36,000.000 \text{ kg} = V \cdot X_{MLSS}$
 b: $(P_{X,TSS})SRT = 36,034.873 \text{ kg} = \text{SUM}(\textcircled{1} : \textcircled{5})$
 $\textcircled{1} = 14,555.283 \text{ kg} = Q(SRT) \cdot Y_H(S_0 - S) / [1 + b_H(SRT)] / 0.85$
 $\textcircled{2} = 4,080.115 \text{ kg} = Q(SRT)nbVSS$
 $\textcircled{3} = 298.502 \text{ kg} = Q(SRT)Y_n(NO_x) / [1 + b_n(SRT)] / 0.85$
 $\textcircled{4} = 1,851.374 \text{ kg} = f_d \cdot b_H \cdot Q Y_H(S_0 - S) SRT^2 / [1 + b_H(SRT)] / 0.85$
 $\textcircled{5} = 15,249.600 \text{ kg} = Q(SRT)(TSS_0 - VSS_0)$

(4) Sludge production $P_{X,TSS}$

$P_{X,TSS} = 5,104.090 \text{ kg/day}$

(5) Determine MLVSS concentration

$(P_{X,VSS})SRT =$

$(P_{X,VSS})SRT = 18,279.500 \text{ kg} = \text{SUM}(\textcircled{1} : \textcircled{4})$
 $\textcircled{1} = 12,371.990 \text{ kg} = Q(SRT) \cdot Y_H(S_0 - S) / [1 + b_H(SRT)]$
 $\textcircled{2} = 4,080.115 \text{ kg} = Q(SRT)nbVSS$
 $\textcircled{3} = 253.727 \text{ kg} = Q(SRT)Y_n(NO_x) / [1 + b_n(SRT)]$
 $\textcircled{4} = 1,573.668 \text{ kg} = f_d \cdot b_H \cdot Q Y_H(S_0 - S) SRT^2 / [1 + b_H(SRT)]$

$X_{MLVSS} =$

$X_{MLVSS} = 1,523 \text{ mg/l}$

NOx

NOx = 24.000 mg/l = TKN × 60.00%

S

S = 0.3648 mg/l = $K_s [1 + b_H(SRT)] / [SRT(\mu_m - b_H) - 1]$

b_H

$b_H = 0.1200$ = $b \cdot 1.04^{(T-20)}$ b at 20°C = 0.120

Y_H

$Y_H = 0.4500 \text{ gVSS/g bCOD}$

$\mu_{m,T}$

$\mu_{m,T} = 6.0000 \text{ g/g · d} = \mu_{max} \cdot 1.04^{(T-20)}$ μ_{max} at 20°C = 6.000

Y_n

$Y_n = 0.150 \text{ gVSS/g Nox}$

b_n average

$b_n = 0.1138 = b_{NOB1} \cdot (ta/Tc) + b_{NOB2} \cdot (1 - ta/Tc)$

b_{NOB1} at aerobic

$b_{NOB} = 0.1700 = b \cdot 1.029^{(T-20)}$ b at 20°C = 0.170

b_{NOB2} at anoxic

$b_{NOB} = 0.0700 = b \cdot 1.029^{(T-20)}$ b at 20°C = 0.070

FractionVSS =

FractionVSS = 0.508 = MLVSS/MLSS

(6) Determine amount of NH4-N oxidized

Biomass production $P_{X,bio}$

$P_{X,bio} = 2,011.244 \text{ kg} = \text{SUM}(\textcircled{1} : \textcircled{3})$
 $\textcircled{1} = 1,752.407 \text{ kg} = Q \cdot Y_H(S_0 - S) / [1 + b_H(SRT)]$
 $\textcircled{2} = 35.939 \text{ kg} = Q Y_n(NO_x) / [1 + b_{AOB}(SRT)]$
 $\textcircled{3} = 222.899 \text{ kg} = f_d \cdot b_H \cdot Q Y_H(S_0 - S) SRT / [1 + b_H(SRT)]$

NOx = 24.592 mg/l = $TN_0 - N_c - 0.12 P_{X,bio} / Q$

= 24.000 mg/l (assumed Nox) OK

<p>(7) NO3-N Produced per cycle</p>	<p>At tank fill NO3-N = 22,133 gNOx/fill 7.378 g/m3 concentration < 8.0 g/m3 concentration OK</p> <p>After decant NO3-N = 15,493 gNOx/decant 7.378 g/m3 concentration</p> <p>At tank fill X_b = 1030.999 g/m3 = P_{x,bio} · SRT / V₁ Biomass = 3,093 kg</p> <p>Q_p = 9,000 m3/d = V_p / t_p Q_p · S_O = 2,250 kg/dny</p>																				
<p>(8) Initial NH4-N</p> <p>V_f(NOx) = V_s(Ne) =</p>	<p>N_O = 8,778 mg/l = [V_f(NOx) + V_s(Ne)] / V₁</p> <p>V_f(NOx) = 22,133 kg V_s(Ne) = 4,200 kg</p>																				
<p>(9) Nitrifier concentration</p> <p>b_{NH3}</p>	<p>X_n = 21.7 mg/l = Q · Y_n · NOx · SRT / [1 + b_{NH3}(SRT)] · V</p> <p>b_{NH3} = 0.1138</p>																				
<p>(10) Review of Aeration time for nitrification</p>	<p>t = $\frac{7.517034349}{103.9928076} = \frac{K_{NH4} \ln(N_e/N_f) + (N_e - N_f)}{X_n(\mu_{max,NH3} Y_n) [S_0 / (K_{O2,NH3} + S_0)]}$</p> <p>t = 0.072 day 1.735 h < 2.10 h (Aeration time) OK</p> <p>μ_{max,NH3,T} = 0.9000 g/g·d = μ_{max} · 1.072^(T-20) μ_{max} at 20°C = 0.900 μ_{NH3,T} = 0.7200 g/g·d = μ_{max,NH3,T} [S₀ / (S₀ + K_{O2,NH3})] S₀ = 2,000 mg/l K_{O2,NH3} = 0.500 mg/l K_{NH4} = 0.500 mg/l</p>																				
<p>[3] Design for Denitrification Process</p>																					
<p>(1) F/M_b</p>	<p>F/M_b = 0.727 g/g·d</p>																				
<p>(2) Fraction of rbCOD</p>	<p>15.00% = rbCOD/bCOD</p> <table border="1" data-bbox="702 1321 1117 1534"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b0</th> <th>b1</th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>	Percent rdCOD(%)	SDNR equation coefficients		b0	b1	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162
Percent rdCOD(%)	SDNR equation coefficients																				
	b0	b1																			
10	0.186	0.078																			
20	0.213	0.118																			
30	0.235	0.141																			
40	0.242	0.152																			
50	0.270	0.162																			
<p>(3) SDNR_b</p>	<p>SDNR_t = 0.175 g/g·d = SDNR_b · θ⁽¹⁻²⁰⁾ θ = 1.026</p> <p>SDNR_b = 0.175 g/g·d = b₀ + b₁ [ln(F/M_b)] b₀ = 0.213 b₁ = 0.118</p>																				
<p>(4) NO3-N removal capacity during the fill period (per tank)</p>	<p>NOx = 542,670 g/g·d = SDNR_t(X_b)(V_T)</p>																				
<p>(5) NO3-N removal capacity :NO_r</p>	<p>NO_r = 21,481 g = NO_x · td / 24 > Nox feed = 15,493 g OK td = 0.950 hr</p>																				

[4] Geometry						
(1) Basin Dimensions	Width	Length	Depth	Basins		
	19.0		29.0	5.5	4	
Cross Section	19.0*5.5		=	104.5	m ² /Basin	
Total Volume	104.5*29.0		=	3,031	m ³ /Basin >	3,000 m ³
				12,124	m ³ /Total	
[7] Equipment						
(1) RAS Pumps						
RAS Ratio	10	%				
Required Capacity	375	m ³ /h ×		10%		
	= 38	m ³ /Hr	⇒	40	m ³ /Hr	
Number	4	Work				
	2	Standby (Spare)				
(2) SAS Pumps						
Excess Sludge	735	m ³ /day				
Sludge withdraw	5	cycles/day				
Running Time	1.0	Hr/Time				
Required Capacity	735	m ³ /day /		5 /	1.00 /	4
	= 36.76	m ³ /Hr	⇒	40	m ³ /Hr	
Number	4	Work				
	2	Standby (Spare)				

6. Air Requirement at Average Flow	
(1) Design Condition	
(1) O2 demand	$R_0 = Q(S_0 \cdot S + 2.86(\text{NOx} - \text{NOx}_e)) + 1.42P_{\text{NOx}} + 1.57Q \cdot \text{NOx}$ $R_0 = 6,360 \text{ kg O}_2/\text{d}$
Qin : Design Average Flow	18,000 m ³ /d
Inlet bCOD	S ₀ = 400 mg/l
S =	0.365 mg/l
NOx =	24.592 mg/l
P _{NOx} =	2,011.2 kg VSS/d * does not include nitrifying bacteria
(2) SOR (Standard Oxygen Transfer Rate at site)	$= \frac{R_0}{\alpha \times F \left(\frac{C_{\beta} \cdot \theta}{\beta \cdot C_{\text{gw/cg}} \cdot (P_b/P_a)^{\beta} - C_A} \right)}$
	C_{β} : Saturated DO at sea level and 20 °C degrees Celsius 9.09 mg/L C_{gw} : Saturated DO at sea level and operating Temperature 6.93 mg/L at 35 degrees Celsius $20 - T$: -15.0 1.024^{20-T} 0.7006 C_A : operating DO in Basin 2.0 mg/L α : Correction Factor by the Water Depth $1 + 0.401/P_a$ 1.19357 D_L : Tank Liquid Depth 5.00 m P_a : Standard absolute pressure at sea level 10.332 m P_b : Absolute pressure at Plant Site Elevation m P_b/P_a : $\exp[-gM(z_b - z_a)/R \cdot T]$ 0.991 g : Acceleration due to Gravity 9.80665 m/s ² M : Mole of Air 28.97 kg/kg-mole z_b : Plant Site Elevation 85 m z_a : Sea Elevation 0 m R : Universal Gas Constant 8314 Nm/kg-mole.K T : Temperature 273.15+t = 308.15 Kelvin α : relative Transfer Rate to clean Water 0.65 β : relative DO Saturation to clean Water 0.95 F : Diffuser Fouling Factor 0.90 $= \frac{48,350}{3,3837} = 14,288.93 \text{ kg/day}$
(3) No. of Basins	4 Basin
(4) Number of cycles	5.0 cycles/basin·day × 4 total 20 cycles/day
(5) Standard O2 required at Field Conditions per cycle =	714.4 kg/cycle/basin/day
(6) SOTE for the above Effective Aeration Depth	30.5 %
(7) Fraction of O2 in Air	23.18 %
(8) Specific Gravity of Air at Standard Condition	1.293
(9) Safety Factor	10%
(10) Air required at Field Conditions per cycle =	9,227 m ³ /cycle/basin/day
(11) Aeration time per cycle t _A	2.10 h = 4,393.8 m ³ /hr/basin

[2] Equipment

(1) Air Blower

Operating No. per basin	2	unit/Basin			
Operating No. per set of blowers	2	basin/set			
Required Capacity	4393.8	m ³ /Hr·Basin	/	2	unit/Basin
	= 2196.9	m ³ /Hr	⇒	2200	m ³ /Hr /Unit
Number	4	W	+	2	S
Pressure	65	kPa			
Safety Factor	10	%			
Heat capacity ratio	1.4				
Atmospheric pressure at site elevation	100.374	kPa			
Total inlet pressure	98.374	kPa			
Volume rate of flow at inlet point	37.757	m ³ /min			
Total discharge pressure	165.374	kPa			
Overall adiabatic efficiency	0.65				
Inlet air temperature (min.)	15	°C			
Shaft power	54.255	kW			
Rated Output of Motor	59.681	kW	⇒	75	kW

7. Chlorination

[1] Design Condition

(1) Design Flow Rate	Average Daily Flow	32,000	m ³ /day	included 18MLD STP
(2) Contact Time		30	min	
(3) Type of Chlorine	Bleaching Powder	(Availitive chlorine	70%)
(4) Design Chlorine Dosage Rate		10	mg/L	
(5) Required Chlorine per day	Average Daily Flow	/	1000	× Design Chlorine Dosage Rate
	=	320.0	kg/d	
	=	13.33	kg/h	
(6) Consumption per day	457.1	kg/d		as Bleaching Powder

[2] Chlorination Contact Tank

(1) Volume required	Average Daily Flow	/	1440	× Contact Time
	=	666.7	m ³	
(2) Nos. of lanes	5	lanes		
(3) Width of lane	2.00	m		
(4) Length of lane	23.00	m		
(5) Side Water Depth	3.00	m		
(6) Nos. of Tanks	1	tank		
(7) Total Width of Tank	13.00	m Approx		
(8) Average Velocity	Average Daily Flow	/	86400	/ Width
	=	32,000	/	86400
	=	0.062	m/sec	2.00 / 3.00
(9) Total Volume	Width	×	Length	×
	=	2.0	m	×
		5	×	1
	=	690	m ³	>
				666.7 m ³

[3] Equipment

(1) Chlorine Solution Tank								
Number	2	W	+	0	S			
Chlorine concentration	2	%						
Gravity of dissolved chlorine	1.10							
Required solution volume	320.00	kg/d	×	100	/	2	/	1.10 / 1000
	=	14.55	m ³ /d					
	=	582	l/h					
Dimension of Tank	2.0	mW	×	2.0	mL	×	2.5	mSWD
Volume of Tank	10.0	m ³ /tank						
Total Volume of Tanks	20.0	m ³		(Duration=	1.38	day)		
(2) Mixer for Chlorine Solution Tank								
Number	2	W	+	0	S			
(3) Chlorine Dosing Pump								
Number	2	W	+	1	S			
Capacity	582	l/h	/	2				
	291	l/h/unit	⇒	300	l/h/unit			

8. Dechlorination

[1] Design Condition

(1) Design Flow Rate	Average Daily Flow	32,000	m ³ /day
(2) Contact Time		10	min
(3) Type of Dechlorine	Sodium Thiosulfate (Na ₂ S ₂ O ₃ · 5H ₂ O)		
(4) Free Residual Chlorine		1.0	mg/L assumed value
(5) Consumption per day	Average Daily Flow	1000	× Free Residual Chlorine × 1.19
		× 2 (safety factor)	
	=	76.2	kg/d
	=	3.17	kg/h

[2] Dechlorination Contact Tank

(1) Volume required	Average Daily Flow	1440	× Contact Time
	=	222.2	m ³
(2) Width of lane	Contact Time	10	min
(3) Length of lane		13.00	m
(4) Side Water Depth		6.00	m
(5) Nos. of Tanks		3.00	m
(6) Total Volume		1	tank
	Width × Length × Depth		
	=	13.0 m × 6.0 m × 3.0 m	
	=	234 m ³	> 222.2 m ³

[3] Equipment


(1) Dechlorine Solution Tank							
Number	2	W	+	0	S		
Dechlorine concentration	10	%					
Gravity of dissolved dechlorine	1.10						
Required solution volume	76.16	kg/d	×	100	/	10	/
	=	0.69	m ³ /d			1.10	/
	=	27.69	l/h			1000	
Volume of Tank	1.0	m ³ /tank					
Total Volume of Tanks	2.0	m ³	(Duration=	2.89	day)		
(2) Mixer for Dechlorine Solution Tank							
Number	2	W	+	0	S		
(3) Dechlorine Dosing Pump							
Number	1	W	+	1	S		
Capacity	27.69	l/h	/	1			
	27.69	l/h/unit	⇒	30	l/h/unit		


9. Sludge Thickener						
[1] Design Condition						
(1) UASB Sludge (14MLD STP)	0	kg/day		0	m ³ /day	
(2) Excess Sludge (14MLD STP)	5,351	kg/day		669	m ³ /day	
(2) Excess Sludge (18MLD STP)	5,882	kg/day		735	m ³ /day	
(3) Total Solids	11,233	kg/day		1,404	m ³ /day	
(4) Operation Time	24	hours/day				
(5) Thickened Sludge Moisture Content	97.5	%				
[2] Geometry						
(1) Type						
(2) Number	2	W	+	0	S	
(3) Design Solid Loading	40	kg / m ² /d				
(4) Required Surface Area	11233		$\times \frac{1}{40} =$	280.80	m ²	
(5) Required diameter			$(\frac{4}{\pi} \times 280.80 \times \frac{1}{2})^{1/2} =$	13.37	m	
				→	13.50	m
(6) Side Water Depth	4	m				
(7) Actual Volume of Tank	$\frac{\pi}{4} \times 13.50^2 \times 4 =$			572.56	m ³	
(8) Retention Time	$\frac{572.56}{1404} \times 2 \times 24 =$			19.58	Hr	
10. Thickened Sludge Sump						
[1] Design Condition						
(1) Inlet Solids	4,816	kg/day	+	5,294	kg/day = 10,109 kg/day	
(2) Inlet Sludge Volume	193	m ³ /d	+	212	m ³ /d = 404 m ³ /d	
[2] Geometry						
(1) Sludge withdrawal	12	Times/day				
(2) Required Sump Volume	34	m ³ /time				
(3) Number	2	Basins				
(4) Width	2.5	m				
(5) Length	2.5	m				
(6) Side Water Depth	3.0	m				
(7) Actual Sump Volume	2.5	\times	2.5	\times	3.0 \times 2 = 37.5 m ³	
[3] Equipment						
(1) Thickened Sludge Pumps						
Transfer Time	6.00	Hr				
Number	1	W	+	1	S	
Required Capacity	404	m ³	\div	6.0	\div 1 = 67.4 m ³ /Hr \Rightarrow 70 m ³ /Hr /Unit	

<p>11 Centrifuge [1] Design Condition (1) Type of Dewatering (2) Quantity of Thickened Sludge generated (3) Design Polyelectrolyte Dosage (4) Volume of Thickened Sludge (5) Consistency of Dewatered Sludge (6) Operation Time</p>	<p>Centrifuge 10,109 kg/day Polyelectrolyte 1.5 kg/t-DS·day 404.4 m³/day 82 % 8 hours/day (6 days per week)</p>
<p>[2] Volume of Centrifuges</p>	$\frac{\text{Digested Solids}}{\text{Operation Time} \times \text{No.}} \times \text{Operation/week}$ $= \frac{404.4}{8 \times 2} \times \frac{7}{6} = 29.5$ <p style="text-align: right;">→ 30 m³/hour</p>
<p>[3] Dewatered Solids</p>	<p>Digested Sludge × (1 + Injection Rate) = 10,109 × (1 + 0.0015) = 10,125 kg/day</p>
<p>[4] Dewatered Cake Volume</p>	<p>Dewatered Solids × $\frac{100}{100 - \text{Moisture Content}}$ × $\frac{7}{6 \text{ days per week}}$</p> $= 10,125 \times \frac{100}{100 - 82} \times \frac{7}{6}$ <p>= 65.63 t/day apparent specific gravity 1.00</p> $65.63 / 1.0 = 65.6 \text{ m}^3/\text{day}$
<p>[5] Polyelectrolyte (1) Design Polyelectrolyte Dosage (2) Required Polyelectrolyte (3) Dissolving concentration (4) Volume of Polyelectrolyte solution</p>	<p>Polyelectrolyte 1.5 kg/t-DS·day 15.16 kg/day 0.20 % 7.58 m³/day</p>
<p>[6] Equipment (1) Centrifuge Capacity Number (2) Centrifuge Feed Pumps Capacity Number (3) Polyelectrolyte Dosing Pumps Volume of Polyelectrolyte solution Operation Time Safety Factor Number Required Capacity Specification Capacity (4) Polyelectrolyte dosing System Tanks Dimensions Retention Time of Tanks Number</p>	<p>30 m³/hr 2 W + 1 S 30 m³/hr 2 W + 1 S 7.58 m³/day 8 hours/day (6 days per week) 1.5 2 W + 1 S 7.58 m³/day × $\frac{7}{6}$ / $\frac{6}{8}$ / 2 = 0.55 m³/Hr 0.55 m³/Hr × 1.5 = 0.829 m³/Hr ⇒ 0.83 m³/Hr /Unit Width 2.0 m × Length 2.0 m × Depth 2.0 m × 2 (Freeboard 0.5m) = 16 m³ 16.00 m³ / 0.55 m³/Hr / 2 = 14.470 Hr 2 W + 0 S</p>

12. Centrifuge Feed Sump	
[1] Design Condition	
(1) Generated Thickend Sludge	10,109 kg/day
(2) Solids Consistency	2.50 %
(3) Volume of Thickened Sludge	$\text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3}$ $= 10,109 \times \frac{100}{2.50} \cdot 10^{-3}$ $= 404 \text{ m}^3/\text{day}$ $= 16.85 \text{ m}^3/\text{h}$
(4) Sludge feed flow rate	30 m ³ /h \times 2 = 60 m ³ /h
(5) Centrifuge Operation Time	8 hours/day (6 days per week)
[2] Geometry	
(1) Required sludge volume for continuation	$(60 + 16.85) \times 8$ $= 345.21 \text{ m}^3$
(2) Basin Dimensions	$\text{Width } 5.0 \text{ m} \times \text{Length } 5.0 \text{ m}$ $\times \text{Depth } 3.5 \text{ m} \times 4$ $= 350.0 \text{ m}^3$
[3] Equipment	
(1) Mixers for Centrifuge Feed Sumps	
Required Volume	350.0 m ³
Number	1 W + 1 S

Material Balance Sheet
[Mirzapur 18 STP]






Sr. No.	Facility	No.	W/Dia. (m)	L (m)	SWD/H (m)
14MLD STP					
1-01	Inlet Chamber	1	4.0 ^W	5.5 ^L	4.0 ^{SWD}
1-02	Main Screen Channel	1	2.0 ^W	5.0 ^L	0.7 ^{SWD}
1-03	Bypass Screen Channel	1	*** ^W	*** ^L	*** ^{SWD}
1-04	Grit Chamber	2	3.0 ^{Dia.}		3.0 ^{SWD}
1-05	Parshall Flume	1	1.5 ^W	10.0 ^L	0.8 ^{SWD}
1-06	Division Box	1	*** ^W	*** ^L	*** ^{SWD}
1-07	Distribution Box	4	*** ^W	*** ^L	*** ^{SWD}
1-08	UASB	2	17.0 ^W	28.0 ^L	5.5 ^H
1-09	Equalization Tank	1	7.0 ^W	30.0 ^L	2.0 ^{SWD}
1-10	Distribution Chamber	1	3.0 ^W	3.5 ^L	2.0 ^{SWD}
1-11	SBR	2	29.0 ^W	30.0 ^L	5.5 ^{SWD}
1-12	UASB Sludge Sump	1	*** ^{Dia.}		*** ^{SWD}
1-13	Filtrate Sump	1	*** ^W	*** ^L	*** ^H
1-14	Air Blower Room	1	12.0 ^W	25.0 ^L	6.0 ^H
18MLD STP					
2-01	Inlet Chamber	1	3.2 ^W	4.5 ^L	2.0 ^{SWD}
2-02	Main Screen Channel	2	0.8 ^W	6.0 ^L	0.7 ^{SWD}
2-03	Bypass Screen Channel	1	0.8 ^W	6.0 ^L	0.7 ^{SWD}
2-04	Grit Chamber	2	5.0 ^W	5.0 ^L	0.9 ^{SWD}
2-05	Parshall Flume	1	1.5 ^W	10.0 ^L	0.8 ^{SWD}
2-06	Distribution Chamber	1	2.0 ^W	3.5 ^L	2.0 ^{SWD}
2-07	SBR	4	19.0 ^W	29.0 ^L	5.5 ^{SWD}
2-08	Air Blower Room	1	12.0 ^W	25.0 ^L	6.0 ^H
COMMON					
3-01	Chlorine Contact Tank	1	2.0 ^W	115.0 ^L	3.0 ^{SWD}
3-02	Sludge Thickener	2	13.5 ^{Dia.}		4.0 ^{SWD}
3-03	Thickened Sludge Sump	2	2.5 ^W	2.5 ^L	3.0 ^{SWD}
3-04	Centrifuge Feed Sump	4	5.0 ^W	5.0 ^L	3.5 ^{SWD}
3-05	Sludge Drying Bed	4	*** ^W	*** ^L	*** ^H
3-06	Drain Sump	2	2.0 ^W	2.0 ^L	2.0 ^{SWD}
3-07	Chlorination Building	1	10.0 ^W	14.0 ^L	6.0 ^H
3-08	Centrifuge Building	1	16.0 ^W	30.0 ^L	10.0 ^H
3-09	Electrical Building	1	16.0 ^W	30.0 ^L	10.0 ^H

- Main Process Line
- Sludge Line
- Other Line
- Proposed structure
- Demolished structure
- Existing structure

Project Name PREPARATORY SURVEY ON GANGA REJUVENATION PROJECT IN THE STATE OF UTTARPRADESH, INDIA インド国ガンジス川浄化事業準備調査	
Drawing Title Mirzapur STP 14MLD+18MLD layout	Scale: 1:1000 Drawing No: STP-26

MIRZAPUR PROPOSED 18MLD STP



Main Process ————
 Sludge Line - - - - -
 Other Line ————
 Existing structure - - - - -

Project Name PREPARATORY SURVEY ON GANGA REJUVENATION PROJECT IN THE STATE OF UTTAR PRADESH, INDIA インド国ガンジス川浄化事業準備調査	
Drawing Title Mirzapur STP 18MLD Layout	Scale: not
Drawing No.	Drawing No. STP-07

6. Vindhyachal STP (Mirzapur)

Item	Vindhyaohal-MPS																			
1 Design Condition																				
(1) Design Flow for the year 2050	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th style="text-align: center;">m3/d</th> <th style="text-align: center;">m3/h</th> <th style="text-align: center;">m3/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td style="text-align: center;">8,990</td> <td style="text-align: center;">375</td> <td style="text-align: center;">0.104</td> </tr> <tr> <td>Max Daily</td> <td style="text-align: center;">8,990</td> <td style="text-align: center;">375</td> <td style="text-align: center;">0.104</td> </tr> <tr> <td>Max Hourly Peak factor 2.25</td> <td style="text-align: center;">20,228</td> <td style="text-align: center;">843</td> <td style="text-align: center;">0.234</td> </tr> </tbody> </table>					m3/d	m3/h	m3/s	Average Daily	8,990	375	0.104	Max Daily	8,990	375	0.104	Max Hourly Peak factor 2.25	20,228	843	0.234
	m3/d	m3/h	m3/s																	
Average Daily	8,990	375	0.104																	
Max Daily	8,990	375	0.104																	
Max Hourly Peak factor 2.25	20,228	843	0.234																	
(2) Design Flow for the year 2035	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th style="text-align: center;">m3/d</th> <th style="text-align: center;">m3/h</th> <th style="text-align: center;">m3/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td style="text-align: center;">6,580</td> <td style="text-align: center;">274</td> <td style="text-align: center;">0.076</td> </tr> <tr> <td>Max Daily</td> <td style="text-align: center;">6,580</td> <td style="text-align: center;">274</td> <td style="text-align: center;">0.076</td> </tr> <tr> <td>Max Hourly Peak factor 2.25</td> <td style="text-align: center;">14,805</td> <td style="text-align: center;">617</td> <td style="text-align: center;">0.171</td> </tr> </tbody> </table>					m3/d	m3/h	m3/s	Average Daily	6,580	274	0.076	Max Daily	6,580	274	0.076	Max Hourly Peak factor 2.25	14,805	617	0.171
	m3/d	m3/h	m3/s																	
Average Daily	6,580	274	0.076																	
Max Daily	6,580	274	0.076																	
Max Hourly Peak factor 2.25	14,805	617	0.171																	
2. Inlet Chamber (existing structure)																				
[1] Design Condition																				
(1) Design Flow for the year 2050	Max Hourly	=	20,228	m3/day																
		=	0.234	m3/sec																
[2] Geometry																				
(1) Number of Basins	1	Basin																		
(2) Depth of Basin	1.000	m	Approx																	
(3) Width of Basin	2.000	m	Approx																	
(4) Length of Basin	3.700	m	Approx																	
(5) Volume required of Basin	1.000	×	2.000	×																
(6) Retention Time	1.000	×	2.000	×																
			3.700	=																
				0.5																
				m3																
				/																
				0.234																
				1																
				=																
				31.62																
				sec																
(7) Basin Dimensions	Width	2.000	m	×																
				Length																
				3.700																
				m																
				×																
				Depth																
				1.000																
				m																
3. Raw Sewage Sump (existing structure)																				
[1] Geometry																				
(1) Raw Sewage Sump																				
Number	1	Basin																		
Dia	6.50	m																		
Pump Operating Depth	1.200	m																		
Retention Time	(6.50	² ×	π ×																
whr Design Flow for the year 2050	=	#DIV/0!	>	3.75																
				min (=minimum time of one pump cycle T/4) OK																
Retention Time	(6.50	² ×	π ×																
whr Design Flow for the year 2035	=	#DIV/0!	>	3.75																
				min (=minimum time of one pump cycle T/4) OK																
High Water Level	+	1.200	m																	
Pump Off Level	+	0.000	m																	
[2] Equipment																				
(1) Sewage Pumps																				
Number	2	W	+	2																
Bore Diameter	150	mm																		
Discharge Flow	0.000	×	3600	/																
whr Design Flow for the year 2035	=	0	⇒	310																
Total Head	11.0	m																		

Item	Vindhyachal-STP 6.0MLD						
1. STP Design Condition							
(1) Design Flo			m ³ /d	m ³ /h	m ³ /s		
	Average Daily		6,000	250	0.069		
	Max Daily		6,000	250	0.069		
	Max Hourly	Peak factor	2.25	13,500	563	0.156	
(2) Design Sewage Quality and Effluent Quality	Unit: mg/L						
	BOD	COD	SS	T-N			TP
				NH ₄ -N	Org-N	NO _x -N	
	Inlet	250	450	400	25	10	5
	Outlet	10	50	20	2	0	8
	Removal rate	96.0%	88.9%	95.0%	75.0%		
(3) Inlet Quality of Reactor	Unit: mg/L						
	BOD	COD	SS	T-N = 40			TP
				NH ₄ -N	Org-N	NO _x -N	
	Inlet of Primary clarifier	250	450	400	25	10	5
	Removal rate	0%	0%	0%	0%	0%	0%
	Inlet of Reactor	250	450	400	25	10	5
2. Stilling Chamber							
[1] Design Condition							
(1) Design Flow Rate	Max Hourly	=	13,500	m ³ /day			
		=	0.156	m ³ /sec			
[2] Geometry							
(1) Number of Basins	1	Basin					
(2) Depth of Basin	1.800	m					
(3) Width of Basin	2.100	m					
(4) Length of Basin	2.500	m					
(5) Volume required of Basin	1.800	×	2.100	×	2.500	=	1.5 m ³
(6) Retention Time	1.800	×	2.100	×	2.500	/	0.156 × 1
	=	60.5769231	sec				
(7) Basin Dimensions	Width	2.100	m	×	Length	2.500	m
		×	Depth	1.800	m		

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Flow Rate	<p>Max Hourly = 13,500 m³/day</p> <p>= 0.156 m³/sec</p>
[2] Geometry	
(1) Inlet Gate	
Number	1 Main + 1 Bypass
Width	0.500 m
Height	0.750 m
Floor Level	+ 84.500 m
Bottom	+ 82.900 m
Influent Water Level	+ 83.300 m
Velocity	<p>0.156 / 0.500 / 0.400 / 1</p> <p>= 0.780 < 1.000 m/sec</p>
(2) Screen Channel	
Number	1 Main + 1 Bypass
Width	0.800 m
Side Water Depth	0.500 m
Velocity	<p>0.156 / 0.800 / 0.500 / 1</p> <p>= 0.390 < 0.450 m/sec</p>
(3) Channel Dimensions	<p>Width 0.8 m Length 7.5 m</p> <p>SWD 0.5 m (Freeboard 0.3m)</p>
[3] Equipment	
(1) Inlet Gate	
Number	2 Units
Dimension	Width 0.5 m Height 0.75 m
Design Water Level	1.60 m
(2) Fine Screens (Main Channel)	
Number	1 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	0.8 m
Width of side plate	50 mm
Side Water Depth	0.5 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	<p>0.156 / 0.700 / 0.450 / 1</p> <p>× (6 + 2) / 6</p> <p>= 0.660 < 0.800 m/sec</p>
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	0.8 m
Side Water Depth	0.5 m
Velocity through screen	<p>0.156 / 0.800 / 0.500 / 1</p> <p>× (20 + 9) / 20</p> <p>= 0.566 < 0.800 m/sec</p>

4. Grit Chamber	
[1] Design Condition	
(1) Design Wastewater Flow	Max Hourly = 13,500 m ³ /day = 0.156 m ³ /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.01157 m/sec = 1,000 m ³ /m ² /day
(4) Average Velocity	0.3 m/sec
[2] Grit Chamber	
(1) Surface Area required	0.156 / 0.01157407 = 13.48 m ²
(2) Number of Basins	2 S + 0 W
(3) Surface Area required/Basin	13.5 / 2 = 6.74 m ²
(4) Length of Basin	6.7392 / 0.5 = 2.6 m → 3.0 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.156 × 60 sec / 2 = 4.7 m ³
(7) Depth required	4.7 / 3.0 / 3.0 = 0.520 m
(8) Basin Dimensions	Width 3.0 m × Length 3.0 m × Depth 0.6 m
(9) Retention Time	3 × 3.0 × 0.6 / 0.156 × 2 = 69.23 sec
(10) Surface Overflow Rate at Peak Flow	13,500 / 3.0 / 3.0 / 2 = 750 < 1,000 m ³ /m ² /day
[3] Parshall Flume	
(1) Design Flow Rate	Q= 156.000 l/sec
(2) Throat width	W= 0.225 m
(3) Water depth Ha	Ha= (Q / 2264 / W) ^{2/3}
	Ha= 0.454 m
(4) Crest Level	+ 79 m ≅ Minimum water level at downstream channel
(5) Water level at the crest	+ 79.454 m
(6) Channel bottom level	+ 78.700 m
(7) Upstream Channel width	0.800 m
(8) SWD of Upstream Channel	0.700 m
(9) Average velocity at upstream channel	0.279 m/sec
(10) Total Length of channel	6.000 m
5. Equalization Tank	
[1] Design Condition	
(1) Design Flow Rate	Average Daily = 6,000 m ³ /day = 250.000 m ³ /h
(2) Detention Time	2.00 h
[2] Geometry	
Number	1 Basin
Dia	15.00 m
Effective Depth	3.000 m
Detention Time	(15.00 ² × π / 4 × 3.000) / 250.000
where Design Flow for the year 2050	= 2.12 > 2.00 h OK

6. SBR				
(1) Design Condition				
(1) Design Flow Rate	$Q =$	6,000 m ³ /day (summer)		
	$Q' =$	6,000 m ³ /day (Winter)		
(2) Design Sewage Quality				
Inlet BOD		250 mg/l		
Outlet BOD		10.0 mg/l		
Inlet S-BOD		167 mg/l		
Inlet COD		450 mg/l		
Inlet S-COD : sCOD		290 mg/l		
Outlet S-COD : nbsCODe		23 mg/l	=sCOD-1.6sBOD	
Inlet nbCOD		60 mg/l		
bCOD/BOD		1.60		
Inlet bCOD : S _b		400 mg/l	=1.6BOD	
Inlet nbCOD		50 mg/l		
	=nbpCOD	27 mg/l	=TCOD-bCOD-nbsCODe	
Inlet TSS		400 mg/l		
Inlet VSS		280 mg/l		
	=VSS _{cod}	0.57 gCOD/gVSS	=TCOD-sCOD/VSS	
	=nbVSS	46.67 gnbVSS/m ³	=nbpCOD/VSS _{cod}	
	=TSS	120.00 gnbTSS/m ³	=TSS-VSS	
Inlet T-N		40 mg/l		
Inlet TKN		35 mg/l		
Inlet NH ₄ -N		25 mg/l		
Ammonia oxidized		70.00% of TKN	assumed	
Inlet T-P		mg/l		
Inlet Alkalinity as CaCO ₃		200 mg/l		
Outlet Kjeldahl N		2.0 mg/l		
Outlet NH ₄ -N		2.0 mg/l		
Outlet NO ₃ -N		8.0 mg/l		
(3) Water Temperature	$T =$	20.0 °C		
(4) Excess Sludge Concentration	$R_s =$	8,000 mg/l		
(5) MLSS	At tank full $X_{TSS} =$	3,000 mg/l		
(6) DO in the Reactor		2 mg/L		
(7) Operating Cycle				
T _c Total time		4.80 h		
t _f Fill time		2.40 h		
t _d Anoxic(denitrification) time		0.95 h		
t _A Aeration time		2.10 h		
t _s Settlement time		1.00 h		
t _d Decanting time		0.75 h		
(8) Number of cycles		5.0 cycles/basin·day × 2 tanks		
	total	10 cycles/day		
(9) Full volume per cycle		600.000 m ³ /fill		
(10) Full liquid depth		5.00 m		
(11) Decant depth		1.50 m	30.0% of full tank depth	
(12) Required aeration tank volume		2000.00 m ³ /tank	$\tau_a =$ 0.6667 day	
			16 h	
(13) Decant flow rate	600.000 m ³ /fill	/	0.75 h	= 800 m ³ /h
(14) No. of basins receiving flow simultaneously	2	nos.		
(15) No. of basins Aerating simultaneously	2	nos.		
(16) No. of basins Decanting simultaneously	1	nos.		
(17) Flow rate	250.00	m ³ /h		
(18) Flow rate to each basin	125.00	m ³ /h/basin		

[2] Design for Nitrification Process

(1) Activated sludge design kinetic coefficients at 20°C

Coefficient	Unit	COD oxidatio	NH4 oxidatio	NO2 oxidatio
μ_{max}	gVSS/gVSS · d	6.000	0.900	1.000
K_s, K_{NH_4}, K_{NO_2}	mg/L	8.000	0.500	0.200
Y	gVSS/g substrate oxidized	0.450	0.150	0.050
b	gVSS/gVSS · d	0.120	0.170	0.170
fd	unitless	0.150	0.150	0.150
K_{CO_2}	mg/L	0.200	0.500	0.900
θ Value				
μ_{max}	unitless	1.070	1.072	1.063
b	unitless	1.040	1.029	1.029
K_s, K_{NH_4}, K_{NO_2}	unitless	1.000	1.000	1.000

Wastewater Engineering Treatment and Resource Recovery Fifth Edition (METCALF & EDDY/AECOM)

(3) SRT calculated with the assumed operating condition

SRT = 6.6500 day

a: $(P_{X,TSS})SRT = 12,000.000 \text{ kg} = V \cdot X_{MLSS}$
 b: $(P_{X,TSS})SRT = 12,005.630 \text{ kg} = \text{SUM}(\textcircled{1} : \textcircled{5})$
 $\textcircled{1} = 4,694.904 \text{ kg} = Q(SRT) \cdot Y_H(S_0 - S) / [1 + b_H(SRT)] / 0.85$
 $\textcircled{2} = 1,862.000 \text{ kg} = Q(SRT)nbVSS$
 $\textcircled{3} = 98.215 \text{ kg} = Q(SRT)Y_n(NOx) / [1 + b_n(SRT)] / 0.85$
 $\textcircled{4} = 562.511 \text{ kg} = f_d \cdot b_H \cdot QY_H(S_0 - S)SRT^2 / [1 + b_H(SRT)] / 0.85$
 $\textcircled{5} = 4,788.000 \text{ kg} = Q(SRT)(TSS_0 - VSS_0)$

(4) Sludge production $P_{X,TSS}$

$P_{X,TSS} = 1,805.358 \text{ kg/day}$

(5) Determine MLVSS concentration
 $(P_{X,VSS})SRT =$

$(P_{X,VSS})SRT = 6,414.286 \text{ kg} = \text{SUM}(\textcircled{1} : \textcircled{4})$
 $\textcircled{1} = 3,990.668 \text{ kg} = Q(SRT) \cdot Y_H(S_0 - S) / [1 + b_H(SRT)]$
 $\textcircled{2} = 1,862.000 \text{ kg} = Q(SRT)nbVSS$
 $\textcircled{3} = 83.483 \text{ kg} = Q(SRT)Y_n(NOx) / [1 + b_n(SRT)]$
 $\textcircled{4} = 478.134 \text{ kg} = f_d \cdot b_H \cdot QY_H(S_0 - S)SRT^2 / [1 + b_H(SRT)]$

$X_{MLVSS} =$

$X_{MLVSS} = 1,604 \text{ mg/l}$

NOx

NOx = 24.500 mg/l = TKN × 70.00%

S

S = 0.3775 mg/l = $K_s[1 + b_H(SRT)] / [SRT(\mu_m - b_H) - 1]$

b_H

$b_H = 0.1200 = b \cdot 1.04^{(T-20)}$ b at 20°C = 0.120

Y_H

$Y_H = 0.4500 \text{ gVSS/g bCOD}$

$\mu_{m,T}$

$\mu_{m,T} = 6.0000 \text{ g/g} \cdot \text{d} = \mu_{max} \cdot 1.04^{(T-20)}$ μ_{max} at 20°C = 6.000

Y_n

$Y_n = 0.150 \text{ gVSS/g Nox}$

b_n average

$b_n = 0.1138 = b_{NOB1} \cdot (ta/Tc) + b_{NOB2} \cdot (1 - ta/Tc)$

b_{NOB1} at aerobic

$b_{NOB} = 0.1700 = b \cdot 1.029^{(T-20)}$ b at 20°C = 0.170

b_{NOB2} at anoxic

$b_{NOB} = 0.0700 = b \cdot 1.029^{(T-20)}$ b at 20°C = 0.070

FractionVSS =

FractionVSS = 0.535 = MLVSS/MLSS

(6) Determine amount of NH4-N oxidized
 Biomass production $P_{X,bio} =$

$P_{X,bio} = 684.554 \text{ kg} = \text{SUM}(\textcircled{1} : \textcircled{3})$
 $\textcircled{1} = 600.101 \text{ kg} = Q \cdot Y_H(S_0 - S) / [1 + b_H(SRT)]$
 $\textcircled{2} = 12.554 \text{ kg} = QY_n(NOx) / [1 + b_{AOB}(SRT)]$
 $\textcircled{3} = 71.900 \text{ kg} = f_d \cdot b_H \cdot QY_H(S_0 - S)SRT / [1 + b_H(SRT)]$

NOx = 24.309 mg/l = $TN_0 - N_e - 0.12P_{X,bio}/Q$

< 24.500 mg/l (assumed Nox) **OK**

<p>(7) NO₃-N Produced per cycles</p>	<p>At tank full NO₃-N = 14,585 gNO_x/fill 7,293 g/m³ concentration < 8,0 g/m³ OK</p> <p>After decant NO₃-N = 10,210 gNO_x/decant 7,293 g/m³ concentration</p> <p>At tank full X_b = 997,667 g/m³ = P_x·b₁₀·SRT/V_T Biomass = 1,995 kg</p> <p>Q_p = 6,000 m³/d = V_p/t_p Q_p·S₀ = 1,500 kg/day</p>																				
<p>(8) Initial NH₄-N</p> <p>V_p(NO_x) = V_s(N_e) =</p>	<p>N₀ = 8,693 mg/l = [V_p(NO_x) + V_s(N_e)]/V_T</p> <p>V_p(NO_x) = 14,585 kg V_s(N_e) = 2,800 kg</p>																				
<p>(9) Nitrifier concentration</p> <p>b_{NOB}</p>	<p>X_n = 20,7 mg/l = Q·Y_n·NO_x·SRT/[1 + b_{NOB}(SRT)]/V</p> <p>b_{NOB} = 0,1138</p>																				
<p>(10) Review of Aeration time for nitrification</p>	<p>t = $\frac{7.427341446}{99.39814665} = \frac{K_{NH} \ln(N_0/N_1) + (N_0 - N_1)}{X_n (\mu_{max,NOB}/Y_n) [S_0 / (K_{O_2,NOB} + S_0)]}$</p> <p>t = 0,075 day 1,793 h < 2,10 h (Aeration time) OK</p> <p>μ_{max,NOB,T} = 0,9000 g/g·d = μ_{max}·1,072^(T-20) μ_{max} at 20°C = 0,900 μ_{NOB,T} = 0,7200 g/g·d = μ_{max,NOB} [S₀ / (S₀ + K_{O₂,NOB})] S₀ = 2,000 mg/l K_{O₂,NOB} = 0,500 mg/l K_{NH₄} = 0,500 mg/l}}</p>																				
<p>[3] Design for Denitrification Process</p>																					
<p>(1) F/M_b</p>	<p>F/M_b = 0,752 g/g·d</p>																				
<p>(2) Fraction of rbCOD</p>	<p>15,00% = rbCOD/bCOD</p> <table border="1" data-bbox="710 1321 1125 1534"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b₀</th> <th>b₁</th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0,186</td> <td>0,078</td> </tr> <tr> <td>20</td> <td>0,213</td> <td>0,118</td> </tr> <tr> <td>30</td> <td>0,235</td> <td>0,141</td> </tr> <tr> <td>40</td> <td>0,242</td> <td>0,152</td> </tr> <tr> <td>50</td> <td>0,270</td> <td>0,162</td> </tr> </tbody> </table>	Percent rdCOD(%)	SDNR equation coefficients		b ₀	b ₁	10	0,186	0,078	20	0,213	0,118	30	0,235	0,141	40	0,242	0,152	50	0,270	0,162
Percent rdCOD(%)	SDNR equation coefficients																				
	b ₀	b ₁																			
10	0,186	0,078																			
20	0,213	0,118																			
30	0,235	0,141																			
40	0,242	0,152																			
50	0,270	0,162																			
<p>(3) SDNR_b</p>	<p>SDNR_t = 0,179 g/g·d = SDNR_b·θ⁽⁶⁻²⁰⁾ θ = 1,026</p> <p>SDNR_b = 0,179 g/g·d = b₀ + b₁ [ln(F/M_b)] b₀ = 0,213 b₁ = 0,118</p>																				
<p>(4) NO₃-N removal capacity during the fill period (per tank)</p>	<p>NO_x = 357,822 g/g·d = SDNR_t(X_b)(V_T)</p>																				
<p>(5) NO₃-N removal capacity : NO_r</p>	<p>NO_r = 14,164 g = NO_x·td/24 > NO_x feed = 10,210 g OK td = 0,950 hr</p>																				

[4] Geometry					
(1)	Side slope of pond is 1 V. H	1.25			
(2)	Overall depth of basin	5.50	m		
(3)	Side Water Depth	5.00	m		
(4)	Width at top of basin	24.20	m		
(5)	Width at bottom of basin	17.33	m		
(6)	Width at mid water depth of basin	20.45	m		
(7)	Length at top of basin	27.90	m		
(8)	Length at bottom of basin	14.15	m		
(9)	Length at mid water depth of basin	20.40	m		
(10)	Area at mid water depth	417.18	m ²		
(11)	Volume of basin	2085.90	m ³	>	2,000 m ³
[5] Equipment					
(1)	RAS Pumps				
	RAS Ratio	10	%		
	Required Capacity	125	m ³ /h ×	10%	
		= 12.50	m ³ /Hr ⇒	14	m ³ /Hr
	Number	2	Work		
		1	Standby (Spare)		
(2)	SAS Pumps				
	Excess Sludge	245	m ³ /day		
	Sludge withdraw	5	cycles/day		
	Running Time	1.0	Hr/Time		
	Required Capacity	245	m ³ /day /	5 /	1.00 / 2
		= 24.51	m ³ /Hr ⇒	30	m ³ /Hr
	Number	2	Work		
		1	Standby (Spare)		


7. Air Requirement at Average Flow	
[1] Design Condition	
(1) O ₂ demand	
R _o =	$R_o = Q(S_o - S + 2.86(\text{NOx} - \text{NOx}_e)) + 1.42P_{X_{bio}} + 4.57Q \cdot \text{NOx}$
R _o =	2,092 kg O ₂ /d
Q _{in} : Design Average Flow m ³ /d	6,000
Inlet bCOD	S ₀ = 400 mg/l
S=	S= 0.378 mg/l
Nox=	NOx= 24,309 mg/l
P _{X_{bio}} =	P _{X_{bio}} = 684.6 kg VSS/d *does not include nitrifying bacteria
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{R_o}{\alpha \times F \left(\frac{C_{R^*} - C_A}{\beta \cdot C_{SW/CB} \cdot (P/P_0) - C_A} \right)} \cdot 1.024^{20-T}$
	C _S : Saturated DO at sea level and 20 °C degrees Celsius 9.09 mg/L
	C _{R*} : Saturated DO at sea level and operating Temperature 6.93 mg/L at 35 degrees Celsius
	20-T : -15.0 1.024 ^{20-T} : 0.7006
	C _A : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1 + 0.40D _L /Pa 1.17422
	D _L : Liquid Depth at diffuser installation 4.50 m
	P ₀ : Standard absolute pressure at sea level 10.332 m
	P ₁ : Absolute pressure at Plant Site Elevation m
	P ₁ /P ₀ : exp[-gM(z ₁ -z ₀)/R*T] 0.992
	g : Acceleration due to Gravity 9.80665 m/s ²
	M : Mole of Air 28.97 kg/kg-mole
	z ₁ : Plant Site Elevation 74 m
	z ₀ : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+1 = 308.15 Kelvin
	α : relative Transfer Rate to clean Water 0.65
	β : relative DO Saturation to clean Water 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{15,647}{3.3154} = 4,719.43 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Number of cycles	5.0 cycles/basin·day × 2
	total 10 cycles/day
(5) Standard O ₂ required at Field Conditions per cycle =	471.9 kg/cycle/basin
(6) SOTE for the above Effective Aeration Depth	27.5 %
(7) Fraction of O ₂ in Air	23.18 %
(8) Specific Gravity of Air at Standard Condition	1.293
(9) Safety Factor	10%
(10) Air required at Field Conditions per cycle =	6,760 m ³ /cycle/basin/day
(11) Aeration time per cycle t _A	2.10 h
	= 3,219.0 m ³ /hr/basin


[2] Equipment						
(1) Air Blower						
Operating No. per basin	2	unit/Basin				
Operating No. per set of blowers	2	basin/set				
Required Capacity	3219.0	m ³ /Hr·Basin		2	unit/Basin	
	=	1609.5	m ³ /Hr	⇒	1700	m ³ /Hr/Unit
Number	2	W	+	1	S	
Pressure	60	kPa				
Safety Factor	10	%				
Heat capacity ratio	1.4					
Atmospheric pressure at site elevation	100.497	kPa				
Total inlet pressure	98.497	kPa				
Volume rate of flow at inlet point	29.140	m ³ /min				
Total discharge pressure	160.497	kPa				
Overall adiabatic efficiency	0.65					
Inlet air temperature (min)	15	°C				
Shaft power	39.228	kW				
Rated Output of Motor	43.151	kW	⇒	55	kW	

8. Chlorination Tank	
[1] Design Condition	
(1) Design Flow Rate	Average Daily Flow 6,000 m ³ /day
(2) Contact Time	30 min
(3) Type of Chlorine	Bleaching Powder (Available chlorine 70%)
(3) Design Chlorine Dosage	10 mg/L
(4) No. SBR Basins	2 Basin
(5) No. of cycle per SBR Basin	5 cycles /day /Basin
(6) Decant flow rate from SBR basin	800.00 m ³ /h/cycle/basin
(7) Decant time per cycle	0.75 h/cycle
(5) Required Chlorine per day	Design Flow Rate / 1000 × Design Chlorine Dosage Rate = 60.00 kg/d
(6) Consumption per day	85.7 kg/d as Bleaching Powder
[2] Chlorination Contact Tank	
(1) Volume required	Decant flow rate from SBR basin / 60 × Contact Time = 400.0 m ³
(2) Nos. of lanes	3 lanes
(3) Width of lane	2.00 m
(4) Length of lane	46.00 m
(5) Side Water Depth	1.50 m
(6) Nos. of Tanks	1 tank
(7) Total Width of Tank	8.20 m Approx
(8) Average Velocity	Decant flow rate from SBR basin / 3600 / Width / Depth = 800 / 86400 / 2.00 / 1.50 = 0.003 m/sec
(9) Total Volume	Width × Length × Depth × Nos. of lanes × Nos. of Tanks = 2.0 m × 46.0 m × 1.5 m × 3 × 1 = 414 m ³ ≈ 400.0 m ³
[3] Equipment	
(1) Chlorine Solution Tank	
Number	2 W + 0 S
Dissolved Chlorine concentration	2 %
Gravity of dissolved chlorine	1.10
Required solution volume	60.00 kg/d × 100 / 2 / 1.10 / 1000 = 2.73 m ³ /d
Dimension of Tank	1.0 mW × 1.0 mL × 1.5 mSWD
Volume of Tank	1.5 m ³ /tank
Total Volume of Tanks	3.0 m ³ (Duration= 1.10 day)
(2) Mixer for Chlorine Solution Tank	
Number	2 W + 0 S
(3) Chlorine Dosing Pump	
Number	2 W + 1 S
Capacity	Decant flow rate from SBR basin × Design Chlorine Dosage / 1000 × 100 / Dissolved Chlorine concentration = 400.0 l/h 400 / 2 200 l/h/unit ⇒ 200 l/h/unit

<p>10. Thickened Sludge Sump</p> <p>[1] Design Condition</p> <p>(1) Inlet Solids</p> <p>(2) Inlet Sludge Volume</p> <p>[2] Geometry</p> <p>(1) Sludge withdrawal</p> <p>(2) Required Sump Volume</p> <p>(3) Number</p> <p>(4) Width</p> <p>(5) Length</p> <p>(6) Side Water Depth</p> <p>(7) Actual Sump Volume</p> <p>[3] Equipment</p> <p>(1) Thickened Sludge Pumps</p> <p>Transfer Time</p> <p>Number</p> <p>Required Capacity</p>	<p>1,764 kg/day</p> <p>70.58 m³/d</p> <p>10 Times/day</p> <p>7.058 m³/time</p> <p>1 Basins</p> <p>1.5 m</p> <p>2.0 m</p> <p>2.0 m</p> <p>2.0 × 2.0 × 2.0 = 8.0 m³</p> <p>5.00 Hr</p> <p>1 W + 1 S</p> <p>71 m³ / 5.0 = 14.1 m³/h ⇒ 15 m³/h/unit</p>
<p>10. Sludge Drying Bed</p> <p>[1] Design Condition</p> <p>(1) Secondary Sludge</p> <p>(2) Solids Consistency</p> <p>(3) Sludge Drying Period</p> <p>(6) Sludge Loading</p> <p>[2] Geometry</p> <p>(1) Required total area of beds</p> <p>(2) No. of Sludge drying beds</p> <p>(3) Basin Dimensions</p>	<p>1,764.450 kg/day</p> <p>70.578 m³/day</p> <p>2.50%</p> <p>12.00 days</p> <p>20.00 kg/m²</p> <p>1,764 × $\frac{12.00}{20.00}$</p> <p>= 1,059 m²</p> <p>6 W + 2 S</p> <p>Width 15.0 m × Length 16.0 m × 6</p> <p>= 1440.0 m²</p>

Material Balance Sheet
[Vindhyachal 6.0 STP]





Sr. No.	Facility	No.	W/Dia. (m)	l (m)	SWD/H (m)
MPS					
01	Inlet Chamber	1	1.1 ^V	2.6 ^L	3.4 ^H
02	Distribution Chamber	1	2.6 ^V	2.0 ^L	3.9 ^H
03	Wet Well	1	6.5 ^{Dia.}		6.5 ^H
STP					
04	Inlet Chamber	1	2.1 ^V	2.5 ^L	1.8 ^{SW}
05	Main Screen Channel	1	0.8 ^V	6.0 ^L	0.5 ^{SW}
06	Bypass Screen Channel	1	0.8 ^V	6.0 ^L	0.5 ^{SW}
07	Gril Chamber	2	3.0 ^V	3.0 ^L	0.6 ^{SW}
08	Parshall Flume	1	0.8 ^V	6.0 ^L	0.7 ^{SW}
09	Equalization Tank	1	15.0 ^{Dia.}		3.0 ^{SW}
10	SBR *At middle depth	2	*20.4 ^V	*20.4 ^L	5.0 ^{SW}
11	Decanted Water Pit	1	2.0 ^V	20.0 ^L	2.0 ^{SW}
12	Chlorine Contact Tank	1	2.0 ^V	138.0 ^L	1.5 ^{SW}
13	Sludge Thickener	1	8.0 ^{Dia.}		4.0 ^{SW}
14	Sludge Drying Bed	8	15.0 ^V	16.0 ^L	2.5 ^H
15	Filtrate Sump	1	1.5 ^V	1.5 ^L	1.5 ^H
16	Air Blower Room	1	10.0 ^V	10.0 ^L	4.0 ^H
17	Chlorination Building	1	8.0 ^V	8.0 ^L	5.0 ^H
18	Administration Building	1	12.0 ^V	18.0 ^L	8.0 ^H
19	Staff Quarters	2	6.3 ^V	6.3 ^L	4.0 ^H
20	Laboratory	1	6.3 ^V	6.3 ^L	4.0 ^H


- Main Process Line
- Sludge Line
- Other Line
- Proposed structure
- Demolished structure
- Existing structure

Project Name
PREPARATORY SURVEY ON GANGA REJUVENATION PROJECT IN THE STATE OF UTTAR PRADESH, INDIA
 इन्दु प्रदेश गङ्गा नदी परियोजना की तैयारी

Drawing Title
Vindhyachal STP 6MLD Layout

Scale
 not

Drawing No.
 STP-27



Main Process ————
 Sludge Line ————
 Other Line ————
 Existing structure - - - - -

Project Name PREPARATORY SURVEY ON GANGA REJUVENATION PROJECT IN THE STATE OF UTTARPRADESH, INDIA インド国ガンッス川浄化事業準備調査	
Drawing Title Vindhyaachal STP 6MLD Layout	Scale: not. Drawing No. STP-08

7. Ghazipur STP

Design Condition

Item	Gazipur-MPS			
(1) Design Flow for the year 2045	Flow Rate			
		m ³ /d	m ³ /hr	m ³ /sec
	Average Daily	24,354	1015	0.282
	Max Daily	24,354	1015	0.282
	Max Hourly Peak factor 2.25	54,797	2283	0.634
(1) Design Flow for the year 2030	Flow Rate			
		m ³ /d	m ³ /hr	m ³ /sec
	Average Daily	19,602	817	0.227
	Max Daily	19,602	817	0.227
	Max Hourly Peak factor 2.25	44,105	1838	0.510

1. Inlet Chamber

Item	Gazipur-MPS			
(1) Design Condition				
(1) Design Flow for the year 2045	Max Hourly	=	54,797	m ³ /d
		=	0.634	m ³ /sec
(2) Inlet Pipe				
Pipe Diameter	□	*		mm
Gradient		%		
Roughness Coefficient	n=	0.013	(Manning Formula)	
Full Pipe Flow Rate		m ³ /sec		
(3) Influent Water Level	+		m	
[2] Geometry				
(1) Number of Basins	1	Basin		
(2) Depth of Basin	2.000	m		
(3) Width of Basin	2.500	m		
(4) Length of Basin	3.700	m		
(5) Volume required of Basin	2.000	*	2.500	*
			3.700	= 1.4 m ³
(6) Retention Time	2.000	*	2.500	*
			3.700	/ 0.634 * 1
	=	29.18	sec	
(7) Basin Dimensions	Width	2.500	m	*
			Length	3.700 m
	*	Depth	2.000	m

2. Coarse Screen Channel								
[1] Design Flow Rate								
(1) Design Flow for the year 2045	Max Hourly	=	54,797	m ³ /day				
		=	0.634	m ³ /sec				
(2) Design Flow for the year 2030	Max Hourly	=	44,105	m ³ /day				
		=	0.510	m ³ /sec				
[2] Geometry								
(1) Inlet Gate								
Number	2	Main	+	1	Bypass			
Width	0.600	m						
Height	0.900	m						
Floor Level	+	0.000	m					
Bottom	+	0.000	m					
Influent Water Level	+	0.600	m					
Velocity	0.634	/	0.600	/	0.600	/	2	
whe Design Flow for the year 2045	=	0.881	<	1.000	m/sec			OK
Velocity	0.510	/	0.600	/	0.600	/	2	
whe Design Flow for the year 2030	=	0.708	<	1.000	m/sec			OK
(2) Screen Channel								
Number	2.0	Main	+	1.0	Bypass			
Width	1.000	m						
Side Water Depth	0.700	m						
Velocity	0.634	/	1.000	/	0.700	/	2	
whe Design Flow for the year 2045	=	0.453	≈	0.450	m/sec			OK
Velocity	0.510	/	1.000	/	0.700	/	2	
whe Design Flow for the year 2030	=	0.364	<	0.450	m/sec			OK
(3) Channel Dimensions								
Width	1.0	m	×	Length	7.5	m		
	×	SWD	0.7	m	(Freeboard 0.3m)			
[3] Equipment								
(1) Inlet Gate								
Number	2	Units						
Dimension	Width	0.6	m	×	Height	0.9	m	
Design Water Level		m						
(2) Coarse Screens (Main Channel)								
Number	2	W	+	0	S			
Open Space	20	mm						
Bar Thickness	9	mm						
Channel Width	1.0	m						
Width of side plate	50	mm						
Side Water Depth	0.7	m						
Height of Blind Plate at the bottom	50	mm						
Velocity through screen	0.634	/	0.900	/	0.650	/	2	
	× (20	+	9)/	20		
	=	0.786	≈	0.800	m/sec			OK
Velocity through screen	0.510	/	0.900	/	0.650	/	2	
whe Design Flow for the year 2030	× (20	+	9)/	20		
	=	0.632	<	0.800	m/sec			OK
(3) Coarse Screens (Bypass Channel)								
Number	0	W	+	1	S			
Open Space	50	mm						
Bar Thickness	9	mm						
Channel Width	1.0	m						
Side Water Depth	0.7	m						
Velocity through screen	0.634	/	1.000	/	0.700	/	2	
whe Design Flow for the year 2045	× (50	+	9)/	50		
	=	0.534	<	0.800	m/sec			OK
Velocity through screen	0.510	/	1.000	/	0.700	/	2	
whe Design Flow for the year 2030	× (50	+	9)/	50		
	=	0.430	<	0.800	m/sec			OK

3. Raw Sewage Sump	
[1] Geometry	
(1) Raw Sewage Sump	
Number	1 Basin
Dia	12.00 m
Pump Operating Depth	1.700 m
Retention Time whe Design Flow for the year 2045	$(\frac{12.00^2 \times \pi}{4} \times 1.700) / 0.634 / 60$ = 5.05 > 3.75 min (=minimum time of one pump cycle 'OK
Retention Time whe Design Flow for the year 2030	$(\frac{12.00^2 \times \pi}{4} \times 1.700) / 0.510 / 60$ = 6.28 > 3.75 min (=minimum time of one pump cycle 'OK
High Water Level	+ m
Pump Off Level	+ m
[2] Equipment	
(1) Sewage Pumps	
Number	4 W + 2 S
Bore Diameter	150 mm
Discharge Flow whe Design Flow for the year 2030	$0.510 \times 3600 / 4$ = 459 \Rightarrow 460 m ³ /Hr
Total Head	22.0 m

1. STP Design Condition

Item	Gazipur-STP 18MLD																																									
(1) Design Average Daily Wastewater Flow	<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2"></th> <th colspan="3">Flow Rate</th> </tr> <tr> <th>m³/d</th> <th>m³/h</th> <th>m³/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td>####</td> <td>750</td> <td>0.208</td> </tr> <tr> <td>Max Dayly</td> <td>####</td> <td>750</td> <td>0.208</td> </tr> <tr> <td>Max Hourly Peak factor 2.25</td> <td>####</td> <td>1688</td> <td>0.469</td> </tr> </tbody> </table>		Flow Rate			m ³ /d	m ³ /h	m ³ /s	Average Daily	####	750	0.208	Max Dayly	####	750	0.208	Max Hourly Peak factor 2.25	####	1688	0.469																						
			Flow Rate																																							
		m ³ /d	m ³ /h	m ³ /s																																						
	Average Daily	####	750	0.208																																						
Max Dayly	####	750	0.208																																							
Max Hourly Peak factor 2.25	####	1688	0.469																																							
(2) Design Sewage Quality and Effluent Quality	<p style="margin: 0;">Unit: mg/L</p> <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="3"></th> <th colspan="6">Water Quality Item</th> </tr> <tr> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th rowspan="2">TP</th> </tr> <tr> <th>NH₄-N</th> <th>Org-N</th> <th>NO_x-N</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td>250</td> <td>450</td> <td>250</td> <td>25</td> <td>10</td> <td>5</td> <td></td> </tr> <tr> <td>Outlet</td> <td>10</td> <td>50</td> <td>20</td> <td>2</td> <td>0</td> <td>8</td> <td></td> </tr> <tr> <td>Removal rate</td> <td>96.0%</td> <td>88.9%</td> <td>92.0%</td> <td colspan="3">75.0%</td> <td>####</td> </tr> </tbody> </table>		Water Quality Item						BOD	COD	SS	T-N			TP	NH ₄ -N	Org-N	NO _x -N	Inlet	250	450	250	25	10	5		Outlet	10	50	20	2	0	8		Removal rate	96.0%	88.9%	92.0%	75.0%			####
			Water Quality Item																																							
			BOD	COD	SS	T-N			TP																																	
		NH ₄ -N				Org-N	NO _x -N																																			
Inlet	250	450	250	25	10	5																																				
Outlet	10	50	20	2	0	8																																				
Removal rate	96.0%	88.9%	92.0%	75.0%			####																																			

4. Stilling Chamber

Item	Gazipur-STP 18MLD
[1] Design Condition	
(1) Design Wastewater Flow	<p>Max Hourly = 40,500 m³/day</p> <p>= 0.469 m³/sec</p>
[2] Geometry	
(1) Number of Basins	1 Basin
(2) Depth of Basin	2.000 m
(3) Width of Basin	3.200 m
(4) Length of Basin	4.500 m
(5) Volume required of Basin	2.000 × 3.200 × 4.500 = 14 m ³
(6) Retention Time	<p>2.000 × 3.200 × 4.500 / 0.469 × 1</p> <p>= 61.4072495 sec</p>
(7) Basin Demensions	<p>Width 3.200 m × Length 4.500 m</p> <p>× Depth 2.000 m</p>

5. Fine Screen Channel

Item	Gazipur-STP 18MLD	
[1] Design Condition		
(1) Design Wastewater Flow	Max Hourly	= 40,500 m ³ /day = 0.469 m ³ /sec
[2] Geometry		
(1) Inlet Gate		
Number	2 Main + 1 Bypass	
Width	0.600 m	
Height	0.900 m	
Floor Level	+ 107.100 m	
Bottom	+ 104.600 m	
Influent Water Level	+ 105.200 m	
Velocity	0.469 /	0.600 / 0.600 / 2 = 0.651 < 1.000 m/sec
(2) Screen Channel		
Number	2 Main + 1 Bypass	
Width	0.800 m	
Side Water Depth	0.700 m	
Velocity	0.469 /	0.800 / 0.700 / 2 = 0.419 ≈ 0.450 m/sec
(3) Channel Dimensions		
Width	0.8 m + Length 8.5 m	
	> SWD 0.7 m (Freeboard 0.3m)	
[3] Equipment		
(1) Inlet Gate		
Number	2 Units	
Dimension	Width 0.6 m > Height 0.9 m	
Design Water Level	2.50 m	
(2) Fine Screens (Main Channel)		
Number	2 W + 0 S	
Open Space	6 mm	
Bar Thickness	2 mm	
Channel Width	0.8 m	
Width of side plate	50 mm	
Side Water Depth	0.7 m	
Height of Blind Plate at the bottom	50 mm	
Velocity through screen	0.469 /	0.700 / 0.650 / 2 × (6 + 2) / 6 = 0.687 < 0.800 m/sec
(3) Fine Screens (Bypass Channel)		
Number	0 W + 1 S	
Open Space	20 mm	
Bar Thickness	9 mm	
Channel Width	0.8 m	
Side Water Depth	0.7 m	
Velocity through screen	0.469 /	0.800 / 0.700 / 2 × (20 + 9) / 20 = 0.607 < 0.800 m/sec

6. Grit Chamber

Item	Gazipur-STP 18MLD	
[1] Design Condition		
(1) Design Wastewater Flow	Max Hourly	= 40,500 m ³ /day = 0.469 m ³ /sec
(2) Specific gravity of Sand	2.65	
(3) Sedimentation Velocity	0.0111 m/sec	= 960 m ³ /m ² /day
(4) Average Velocity	0.3 m/sec	
[2] Grit Chamber	Square Grit Chamber	
(1) Surface Area required	0.469 / 0.0111	= 42.25 m ²
(2) Number of Basins	2 S + 0 W	
(3) Surface Area required/Basin	42.3 / 2	= 21.13 m ²
(4) Length of Basin	21.1261261 / 0.5	= 4.6 m → 5.0 m
(5) HRT in Grit Chamber	60 sec	
(6) Volume required of Basin	0.469 × 60 sec / 2	= 14.1 m ³
(7) Depth required	14.1 / 5.0 / 5.0	= 0.563 m
(8) Basin Dimensions	Width 5.0 m × Length 5.0 m × Depth 0.6 m (Freeboard 0.3m)	
(9) Retention Time	5 × 5.0 × 0.6 / 0.469 × 2	= 60.00 sec
(10) Surface Overflow Rate at Peak Flow	40,500 / 5.0 / 5.0 / 2	= 810 < 960 m ³ /m ² /day

[2] Design for Nitrification Process

(1) Activated sludge design kinetic coefficients at 20°C

Coefficient	Unit	COD oxidation	NH4 oxidation	NO2 oxidation
μ_{max}	gVSS/gVSS · d	6.000	0.900	1.000
K_s, K_{NO_4}, K_{NO_2}	mg/L	8.000	0.500	0.200
Y	gVSS/g substrate oxidized	0.450	0.150	0.050
b	gVSS/gVSS · d	0.120	0.170	0.170
f _f	unitless	0.150	0.150	0.150
K_{NO_2}	mg/L	0.200	0.500	0.900
θ Value				
μ_{max}	unitless	1.070	1.072	1.063
b	unitless	1.040	1.029	1.029
F_s, K_{NO_4}, K_{NO_2}	unitless	1.000	1.000	1.000

Wastewater Engineering Treatment and Resource Recovery Fifth Edition (METCALF & EDDY/AECOM)

(3) SRT calculated with the assumed operating condition

SRT = 8.8000 day

a: $(P_{X_{TSS}})SRT = 36,000.000 \text{ kg} = V \cdot X_{MLSS}$
 b: $(P_{X_{TSS}})SRT = 35,869.559 \text{ kg} = \text{SUM}(\text{①} : \text{⑤})$
 ① = 16,301.726 kg = $Q(SRT) \cdot Y_H(S_0 - S) / [1 + b_H(SRT)] \cdot 0.85$
 ② = 4,712.400 kg = $Q(SRT)nbVSS$
 ③ = 391.146 kg = $Q(SRT)Y_H(NO_x) / [1 + b_H(SRT)] \cdot 0.85$
 ④ = 2,584.287 kg = $f_d \cdot b_H \cdot Q Y_H(S_0 - S) SRT^2 / [1 + b_H(SRT)] \cdot 0.85$
 ⑤ = 11,880.000 kg = $Q(SRT)(TSS_0 - VSS_0)$

(4) Sludge production $P_{X_{TSS}}$

$P_{X_{TSS}} = 4,076.086 \text{ kg/day}$

(5) Determine MLVSS concentration
 $(P_{X_{VSS}})SRT =$

$(P_{X_{VSS}})SRT = 21,097.985 \text{ kg} = \text{SUM}(\text{①} : \text{④})$
 ① = 13,856.167 kg = $Q(SRT) \cdot Y_H(S_0 - S) / [1 + b_H(SRT)]$
 ② = 4,712.400 kg = $Q(SRT)nbVSS$
 ③ = 332.474 kg = $Q(SRT)Y_H(NO_x) / [1 + b_H(SRT)]$
 ④ = 2,196.644 kg = $f_d \cdot b_H \cdot Q Y_H(S_0 - S) SRT^2 / [1 + b_H(SRT)]$

$X_{MLVSS} =$

$X_{MLVSS} = 1.758 \text{ mg/l}$

NO_x

NO_x = 28.000 mg/l = TKN × 80.00%

S

S = 0.3241 mg/l = $-K_s[1 + b_H(SRT)] / [SRT(\mu_{max} - b_H) - 1]$

b_H

$b_H = 0.1200$ = $b \cdot 1.04^{(T-20)}$ b at 20°C = 0.120

Y_H

$Y_H = 0.4500$ gVSS/g bCOD

μ_{max}

$\mu_{max} = 6.0000$ g/g · d = $\mu_{max} \cdot 1.04^{(T-20)}$ μ_{max} at 20°C = 6.000

Y_H

$Y_H = 0.150$ gVSS/g Nox

b_H average

$b_H = 0.1138$ = $b_{NOB1} \cdot (t_a/T_c) + b_{NOB2} \cdot (1 - t_a/T_c)$

b_{NOB1} at aerobic

$b_{NOB1} = 0.1700$ = $b \cdot 1.029^{(T-20)}$ b at 20°C = 0.170

b_{NOB2} at anoxic

$b_{NOB2} = 0.0700$ = $b \cdot 1.029^{(T-20)}$ b at 20°C = 0.070

FractionVSS =

FractionVSS = 0.586 = MLVSS/MLSS

(6) Determine amount of NH₄-N oxidized

Biomass production $P_{X_{bio}}$

$P_{X_{bio}} = 1,861.098 \text{ kg} = \text{SUM}(\text{①} : \text{③})$
 ① = 1,574.598 kg = $Q \cdot Y_H(S_0 - S) / [1 + b_H(SRT)]$
 ② = 37.781 kg = $Q Y_H(NO_x) / [1 + b_{NOB}(SRT)]$
 ③ = 249.619 kg = $f_d \cdot b_H \cdot Q Y_H(S_0 - S) SRT / [1 + b_H(SRT)]$

NO_x = 25.587 mg/l = $TN_0 - N_e - 0.12 P_{X_{bio}} / Q$

< 28.000 mg/l (assumed Nox) OK

[5] Geometry					
(1) Basin Dimensions	Width	Length	Depth	Basins	
	17.0		33.0	5.5	4
Cross Section	17.0*5.5		=	93.5	m ² /Basin
Total Volume	93.5*33.0		=	3,086	m ³ /Basin > 3,000 m ³
				12,344	m ³ /Total
[7] Equipment					
(1) RAS Pumps					
RAS Ratio	10	%			
Required Capacity	375	m ³ /h*		10%	
	= 38	m ³ /Hr	⇒	40	m ³ /Hr
Number	4	Work			
	2	Standby (Spare)			
(2) SAS Pumps					
Excess Sludge	431	m ³ /day			
Sludge withdraw	5	cycles/day			
Running Time	1.0	Hr/Time			
Required Capacity	431	m ³ /day /		5 /	1.00 / 4
	= 21.57	m ³ /Hr	⇒	25	m ³ /Hr
Number	4	Work			
	2	Standby (Spare)			

8. Air Requirement at Average Flow

Item	Gasipur-STP HMLD
[1] Design Condition	
(1) O2 demand	
$R_o =$	$Q(S_o - S - 2.86(\text{Nox} - \text{NOx})) + 1.42P_{X_{\text{bio}}} + 4.57Q \cdot \text{NOx}$
$R_o =$	6,655 kg O2/d
Q_m : Design Average Flow	18,000 m ³ /d
Inlet bCOD	$S_o =$ 400 mg/l
$S =$	0.324 mg/l
$\text{Nox} =$	25.587 mg/l
$P_{X_{\text{bio}}} =$	1,862.0 kg VSS/d *does not include nitrifying bacteria
(2) SOR(Standard Oxygen Transfer Rate at site)	$\frac{R_o}{\alpha} \cdot \frac{1}{F} \cdot \frac{C_s - C_a}{(C_s - C_a) \cdot \beta \cdot (P/P_a)^n - C_a}$
	C_s : Saturated DO at sea level and 20 °C degrees Celsius 9.09 mg/L
	C_{sw} : Saturated DO at sea level and operating Temperature 6.93 mg/L at 35 degrees Celsius
	20-T : -15.0 1.024 ^{20-T} : 0.7006
	C_a : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth $1 + 0.40D/P_a$ 1.19357
	D_l : Tank Liquid Depth 5.00 m
	P_a : Standard absolute pressure at sea level 10.332 m
	P_b : Absolute pressure at Plant Site Elevation m
	P_b/P_a : $\exp[-gM(z_s - z_w)/R \cdot T]$ 0.989
	g : Acceleration due to Gravity 9.80665 m/s ²
	M : Mole of Air 28.97 kg/kg-mole
	z_w : Plant Site Elevation 100 m
	z_s : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+1 = 308.15 Kelvin
	α : relative Transfer Rate to clean Water 0.65
	β : relative DO Saturation to clean Water 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{50,589}{3.3762} = 14,984.07 \text{ kg/day}$
(3) No. of Basins	4 Basin
(4) Number of cycles	5.0 cycles/basin·day = 4
	total 20 cycles/day
(5) Standard O2 required at Field Conditions per cycle	= 749.2 kg/cycle/basin/day
(6) SOTE for the above Effective Aeration Depth	30.5 %
(7) Fraction of O2 in Air	23.18 %
(8) Specific Gravity of Air at Standard Condition	1.293
(9) Safety Factor	10%
(10) Air required at Field Conditions per cycle	= 9,676 m ³ /cycle/basin/day
(11) Aeration time per cycle t_a	= 2.10 h
	= 4,607.5 m ³ /hr/basin

[2] Equipment					
(1) Air Blower					
Operating No. per basin		2	unit/Basin		
Operating No. per set of blowers		2	basin/set		
Required Capacity		4607.5	m ³ /Hr·Basin	/	2 unit/Basin
	=	2303.8	m ³ /Hr	⇒	2400 m ³ /Hr/Unit
Number		4	W	+	2 S
Pressure		65	kPa		
Safety Factor		10	%		
Heat capacity ratio		1.4			
Atmospheric pressure at site elevation		100.208	kPa		
Total inlet pressure		98.208	kPa		
Volume rate of flow at inlet point		41.260	m ³ /min		
Total discharge pressure		165.208	kPa		
Overall adiabatic efficiency		0.65			
Inlet air temperature (min.)		15	°C		
Shaft power		59.272	kW		
Rated Output of Motor		65.199	kW	⇒	75 kW

8. Chlorination**[1] Design Condition**

(1) Design Flow Rate	Average Daily Flow	18,000	m ³ /day		
(2) Decant Flow Rate	Decant Flow Rate	1,200	m ³ /h	Decant time	0.75 h/time
(3) Frequency of decant		20	times/ day		
(4) Contact Time		30	min		
(5) Type of Chlorine	Bleaching Powder	(Availtive chlorine	70%)	
(6) Design Chlorine Dosage Rate		10	mg/l		
(7) Required Chlorine per day	Average Daily Flow	/	1000	×	Design Chlorine Dosage Rate
	=	180.0	kg/d		
	=	7.50	kg/h		
(8) Consumption per day	257.1	kg/d		as Bleaching Powder	

[2] Chlorination Contact Tank

(1) Volume required	Average Daily Flow	/	1440	×	Contact Time
	=	375.0	m ³		
	Decant Flow	/	60	×	Contact Time
	=	600.0	m ³		
	Hence required volume is		600.0	m ³	
(2) Nos. of lanes		6	lanes		
(3) Width of lane		2.00	m		
(4) Length of lane		26.00	m		
(5) Side Water Depth		2.00	m		
(6) Nos. of Tanks		1	tank		
(7) Total Width of Tank		15.40	m	Approx.	
(8) Average Velocity	Decant Flow	/	3600	/	Width
	=	1,200	/	3600	/
	=	0.083	m/sec	2.00	/
			2.00		
(9) Total Volume	Width	×	Length	×	Depth
	=	2.0	m	×	26.0
		×	6	×	1
	=	624	m ³	>	600.0
					m ³

[3] Equipment

(1) Chlorine Solution Tank					
Number	2	W	+	0	S
Chlorine concentration	2	%			
Gravity of dissolved chlorine	1.10				
Required solution volume	180.00	kg/d	×	100	/
	=	8.18	m ³ /d	2	/
	=	545	l/h	×	0.75
				h/time	×
				2.0	mSWD
				20	times/d
Dimension of Tank	1.7	mW	×	1.7	mL
Volume of Tank	5.8	m ³ /tank			
Total Volume of Tanks	11.6	m ³	(Duration=	1.41	day)
(2) Mixer for Chlorine Solution Tank					
Number	2	W	+	0	S
(3) Chlorine Dosing Pump					
Number	2	W	+	1	S
Capacity	545	l/h	/	2	
	273	l/h/unit	⇒	300	l/h/unit

9. Dechlorination	
[1] Design Condition	
(1) Design Flow Rate	Average Daily Flow 18,000 m ³ /day
(2) Contact Time	10 min
(3) Type of Dechlorine	Sodium Thiosulfate (Na ₂ S ₂ O ₃ 5H ₂ O)
(4) Free Residual Chlorine	1.0 mg/L assumed value
(5) Consumption per day	$\begin{aligned} &\text{Average Daily Flow} \quad \checkmark \quad 1000 \quad \times \quad \text{Free Residual Chlorine} \quad \times \quad 1.19 \\ &\times \quad 2 \quad (\text{safety factor}) \\ &= \quad 42.8 \quad \text{kg/d} \\ &= \quad 1.79 \quad \text{kg/h} \end{aligned}$
[2] Dechlorination Contact Tank	
(1) Volume required	$\begin{aligned} &\text{Decant Flow Rate} \quad \checkmark \quad 60 \quad \times \quad \text{Contact Time} \\ &= \quad 200.0 \quad \text{m}^3 \end{aligned}$
(2) Width of lane	15.00 m
(3) Length of lane	7.00 m
(4) Side Water Depth	2.00 m
(5) Nos. of Tanks	1 tank
(6) Total Volume	$\begin{aligned} &\text{Width} \quad \times \quad \text{Length} \quad \times \quad \text{Depth} \\ &= \quad 15.0 \quad \text{m} \quad \times \quad 7.0 \quad \text{m} \quad \times \quad 2.0 \quad \text{m} \\ &= \quad 210 \quad \text{m}^3 > \quad 200.0 \quad \text{m}^3 \end{aligned}$
[3] Equipment	
(1) Dechlorine Solution Tank	
Number	2 W + 0 S
Dechlorine concentration	10 %
Gravity of dissolved dechlorine	1.10
Required solution volume	$\begin{aligned} &42.84 \quad \text{kg/d} \quad \times \quad 100 \quad / \quad 10 \quad / \quad 1.10 \quad / \quad 1000 \\ &= \quad 0.39 \quad \text{m}^3/\text{d} \\ &= \quad 25.96 \quad \text{l/h} \quad \times \quad 0.75 \quad \text{h/time} \quad \times \quad 20 \quad \text{times/d} \end{aligned}$
Volume of Tank	1.5 m ³ /tank
Total Volume of Tanks	3.0 m ³ (Duration= 7.70 day)
(2) Mixer for Dechlorine Solution Tank	
Number	2 W + 0 S
(3) Dechlorine Dosing Pump	
Number	1 W + 1 S
Capacity	25.96 l/h / 1
	25.96 l/h/unit \Rightarrow 30 l/h/unit

10. Sludge Thickener

Item	Gazipur-STP 18MLD	
[1] Design Condition		
(1) Primary Sludge	0 kg/day	0 m ³ /day
(2) Secondary Sludge	3,452 kg/day	431 m ³ /day
(3) Total Solids	3,452 kg/day	431 m ³ /day
(4) Operation Time	24 hours/day	
(5) Thickened Sludge Moisture Content	97.5 %	
[2] Geometory		
(1) Type		
(2) Number	2 W + 0 S	
(3) Design Solid Loading	40 kg/m ² /d	
(4) Required Surface Area	$3452 \times \frac{1}{40} = 86.30$	m ²
(5) Required diameter	$(\frac{4}{\pi} \times 86.30 \times \frac{1}{2})^{1/2} = 7.41$	m
		→ 7.50 m
(6) Side Water Depth	4 m	
(7) Actual Volume of Tank	$\frac{\pi}{4} \times 7.50^2 \times 4 = 176.71$	m ³
(8) Retention Time	$\frac{176.71}{431} \times 2 \times 24 = 19.66$	Hr
[3] Volume of Thickened Sludge		
	= 164	m ³ /d
[4] Quantity of Separation Liquid		
	Inlet Sludge Volume	– Thickened Sludge Volume
	= 431.4	– 163.8 = 267.6 m ³ /day

11. Thickened Sludge Sump

Item	Gazipur-STP 18MLD			
(1) Design Condition				
(1) Inlet Solids	3,106	kg/day		
(2) Inlet Sludge Volume	124	m ³ /d		
[2] Geometory				
(1) Sludge withdrawl	12	Times/day		
(2) Required Sump Volume	10	m ³ /time		
(3) Number	2	Basins		
(4) Width	2.0	m		
(5) Length	1.5	m		
(6) Side Water Depth	2.0	m		
(7) Actual Sump Volume	2.0	× 1.5	× 2.0	× 2
	=	12.0	m ³	
[3] Equipment				
(3) Thickened Sludge Pumps				
Transfer Time	6.00	Hr		
Number	2	W	+	2 S
Required Capacity	124	m ³	/	6.0 / 2
	=	10.4	m ³ /Hr	⇒ 11 m ³ /Hr/Unit


13. Centrifuge

Item	Gazipur-STP (8MLD)
(1) Design Condition	Centrifuge
(1) Type of Dewatering	3,106 kg/day
(2) Quantity of Thickend Sludge generated	Polyelectrolyte 1.5 kg/t-DS·day
(3) Design Polyelectrolyte Dosage	124.3 m ³ /day
(4) Volume of Thickend Sludge	82 %
(5) Consistency of Dewatered Sludge	8 hours/day (6 days per week)
(6) Operation Time	
[2] Volume of Centrifuge	$\frac{\text{Digested Solids}}{\text{Operation Time} \times \text{No. Operation week}}$ $= \frac{124.3}{8 \times 2} = \frac{7.77}{10} = 0.777 \rightarrow 10 \text{ m}^3/\text{hour}$
[3] Dewatered Solids	$\text{Digested Sludge} \times \left(1 + \frac{\text{Injection Rate}}{100} \right)$ $= 3,106 \times \left(1 + \frac{0.0015}{100} \right)$ $= 3,111 \text{ kg/day}$
[4] Dewatered Cake Volume	$\text{Dewatered Solids} \times \frac{100 - \text{Moisture Content}}{100}$ $= 3,111 \times \frac{100 - 7}{100} \times \frac{6 \text{ days per week}}{82} \times \frac{7}{6}$ $= 20.16 \text{ t/day}$ $\frac{\text{apparent specific gravity}}{20.16} \times 1.0 = 20.2 \text{ m}^3/\text{day}$
[5] Polyelectrolyte	
(1) Design Polyelectrolyte Dosage	Polyelectrolyte 1.5 kg/t-DS·day
(2) Required Polyelectrolyte	4.66 kg/day
(3) Dissolving concentration	0.20 %
(4) Volume of Polyelectrolyte solution	2.33 m ³ /day


[6] Equipment					
(1) Centrifuge					
Capacity	10	m ³ /hr			
Number	2	W	+	1	S
(2) Centrifuge Feed Pumps					
Capacity	10	m ³ /hr			
Number	2	W	+	1	S
(3) Polyelectrolyte Dosing Pumps					
Volume of Polyelectrolyte solution	2.33	m ³ /day			
Operation Time	8	hours/day		(6 days per week)	
Safety Factor	1.5				
Number	2	W	+	1	S
Required Capacity	2.33	m ³ /Hr	×	7	/
				6	/
				8	/
				2	
	=	0.17	m ³ /Hr		
Specification Capacity	0.17	m ³ /Hr	×	1.5	
	=	0.255	m ³ /Hr	⇒	0.26 m ³ /Hr /Unit
(4) Polyelectrolyte dosing System					
Tanks Dimensions					
Width	1.5	m	×	Length	1.5 m
× Depth	2.0	m	×	2	(Freeboard 0.5m)
	=	9	m ³		
Retention Time of Tanks	9.00	m ³	/	0.17 m ³ /Hr	/
	=	26.490	Hr		2
Number	2	W	+	0	S

<p>14. Centrifuge Feed Sump</p> <p>[1] Design Condition</p> <p>(1) Generated Thickend Sludge</p> <p>(2) Solids Consistency</p> <p>(3) Volume of Thickened Sludge</p>	<p>3,106 kg/day</p> <p>2.50 %</p> <p>Total Solids $\times \frac{100}{\text{Solids Consistency}} \times 10^{-3}$</p> <p>$= \frac{3,106}{2.50} \times 10^{-3}$</p> <p>$= 124 \text{ m}^3/\text{day}$</p> <p>$= 5.18 \text{ m}^3/\text{h}$</p>
<p>(4) Sludge feed flow rate</p> <p>(5) Centrifuge Operation Time</p>	<p>$\frac{10 \text{ m}^3/\text{h} \times 2}{8 \text{ hours/day} \times 6 \text{ days per week}} = 20 \text{ m}^3/\text{h}$</p>
<p>[2] Geometry</p> <p>(1) Required sludge volume for continuation</p> <p>(2) Basin Dimensions</p>	<p>$(20 \times 5.18) \times 8$</p> <p>$= 118.58 \text{ m}^3$</p> <p>Width 4.0 m \times Length 5.0 m</p> <p>\times Depth 3.0 m \times 2</p> <p>$= 120.0 \text{ m}^3$</p>
<p>[3] Equipment</p> <p>(1) Mixers for Centrifuge Feed Sumps</p> <p>Required Volume</p> <p>Number</p>	<p>120.0 m³</p> <p>1 W + 1 S</p>

Material Balance Sheet
[Gazipur 18 STP]



R 例 LEGEND	
G	Water Flow : (m³/day)
T	Solid Matter : (t-DS/day)
D	Solid Concentration(mg/D)
X	Ratio for Inlet Solid : (%)
-	Water
- - -	Sludge
- - - - -	Supernatant



- Main Process ————
- Sludge Line - - - - -
- Other Line ————
- Existing structure - - - - -

Project Name PREPARATORY SURVEY ON GANGA REJUVENATION PROJECT IN THE STATE OF UTTARPRADESH, INDIA インド国ガンダス川浄化事業準備調査	
Drawing Title Gazipur STP 18 MLD layout	Scale: not
Drawing No.	STP-11

8. Ramnagar STP

Design Condition

Item	Ramnagar-MPS			
(1) Design Flow for the year 2050	Flow Rate			
	m ³ /d m ³ /h m ³ /s			
	Average Daily 13,000 542 0.150			
	Max Daily 13,000 542 0.150			
	Max Hourly Peak factor 2.25 29,250 1219 0.339			
	(1) Design Flow for the year 2035	Flow Rate		
		m ³ /d m ³ /h m ³ /s		
		Average Daily 10,000 417 0.116		
		Max Daily 10,000 417 0.116		
		Max Hourly Peak factor 2.25 22,500 938 0.260		

1. Inlet Chamber

Item	Ramnagar-MPS
[1] Design Condition	
(1) Design Flow for the year 2050	Max Hourly = 29,250 m ³ /d = 0.339 m ³ /sec
(2) Inlet Pipe	
Pipe Diameter	□ mm
Gradient	‰
Roughness Coefficient	n = 0.013 (Manning Formula)
Full Pipe Flow Rate	m ³ /sec
(3) Influent Water Level	+ m
[2] Geometry	
(1) Number of Basins	1 Basin
(2) Depth of Basin	1.000 m Approx
(3) Width of Basin	3.000 m Approx
(4) Length of Basin	2.000 m Approx
(5) Volume required of Basin	1.000 × 3.000 × 2.000 = 1.5 m ³
(6) Retention Time	1.000 × 3.000 × 2.000 / 0.339 × 1 = 17.70 sec
(7) Basin Demensions	Width 3.000 m × Length 2.000 m × Depth 1.000 m

2. Coarse Screen Channel

Item	Ramnagar-MPS					
[1] Geometry						
(1) Inlet Gate						
Number	1	Main	+	1	Bypass	
Width	0.600	m				
Height	0.900	m				
Floor Level	+	79.200	m			
Bottom	+	68.600	m			
Influent Water Level	+	69.300	m			
Velocity	0.339	/		0.600	/	0.700 / 1
whr Design Flow for the year 2050	=	0.807	<	1.000	m/sec	OK
Velocity	0.260	/		0.600	/	0.700 / 1
whr Design Flow for the year 2035	=	0.619	<	1.000	m/sec	OK
(2) Screen Channel						
Number	1.0	Main	+	1.0	Bypass	
Width	1.000	m				
Side Water Depth	0.800	m				
Velocity	0.339	/		1.000	/	0.800 / 1
whr Design Flow for the year 2050	=	0.424	≅	0.450	m/sec	OK
Velocity	0.260	/		1.000	/	0.800 / 1
whr Design Flow for the year 2035	=	0.325	<	0.450	m/sec	OK
(3) Channel Dimensions	Width	1.0	m	×	Length	8.5 m
	×	SWD	0.8	m	(Freeboard 0.3m)	
[3] Equipment						
(1) Inlet Gate						
Number	2	Units				
Dimension	Width	0.6	m	×	Height	0.9 m
Design Water Level		m				
(2) Coarse Screens (Main Channel)						
Number	1	W	+	0	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	1.0	m				
Width of side plate	50	mm				
Side Water Depth	0.8	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.339	/		0.900	/	0.750 / 1
	×	(20	+	9) /	20	
	=	0.728	≅	0.800	m/sec	OK
Velocity through screen	0.260	/		0.900	/	0.750 / 1
whr Design Flow for the year 2035	×	(20	+	9) /	20	
	=	0.559	<	0.800	m/sec	OK
(3) Coarse Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	50	mm				
Bar Thickness	9	mm				
Channel Width	1.0	m				
Side Water Depth	0.8	m				
Velocity through screen	0.339	/		1.000	/	0.800 / 1
whr Design Flow for the year 2050	×	(50	+	9) /	50	
	=	0.500	<	0.800	m/sec	OK
Velocity through screen	0.260	/		1.000	/	0.800 / 1
whr Design Flow for the year 2035	×	(50	+	9) /	50	
	=	0.384	<	0.800	m/sec	OK

3. Raw Sewage Sump

Item	Ramnagar-MPS	
[2] Geometry		
(1) Raw Sewage Sump		
Number	1	Basin
Dia	8.00	m
Pump Operating Depth	1.600	m
Retention Time whe Design Flow for the year 2050	$(\frac{8.00^2 \times \pi}{4} \times 1.600) / 0.339$	$/ 60$
	= 3.95	> 3.75 min (=minimum time of one pump cycle ' OK
Retention Time whe Design Flow for the year 2035	$(\frac{8.00^2 \times \pi}{4} \times 1.600) / 0.260$	$/ 60$
	= 5.16	> 3.75 min (=minimum time of one pump cycle ' OK
High Water Level	+ 69.100	m
Pump Off Level	+ 67.500	m
[3] Equipment		
(1) Sewage Pumps 1		
Number	2	W + 1 S
Bore Diameter	150	mm
Discharge Flow Q whe Design Flow for the year 2035	0.260×3600	$/ 2.5$ Q
	= 374	\Rightarrow 375 m ³ /Hr
Total Head	20.0	m
(2) Sewage Pumps 2		
Number	1	W + 1 S
Bore Diameter	150	mm
Discharge Flow 0.5 whe Design Flow for the year 2035	$375.000 / 2.0$	
	= 188	\Rightarrow 188 m ³ /Hr
Total Head	20.0	m

Item	Ramnagar-STP 10MLD																																									
1. STP Design Condition																																										
(1) Design Flow Rate	<table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th></th> <th>m3/d</th> <th>m3/h</th> <th colspan="2">m3/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td>10,000</td> <td>416.67</td> <td colspan="2">0.116</td> </tr> <tr> <td>Max Daily</td> <td>10,000</td> <td>416.67</td> <td colspan="2">0.116</td> </tr> <tr> <td>Max Hourly Peak factor 2.25</td> <td>22,500</td> <td>937.5</td> <td colspan="2">0.260</td> </tr> </tbody> </table>								m3/d	m3/h	m3/s		Average Daily	10,000	416.67	0.116		Max Daily	10,000	416.67	0.116		Max Hourly Peak factor 2.25	22,500	937.5	0.260																
	m3/d	m3/h	m3/s																																							
Average Daily	10,000	416.67	0.116																																							
Max Daily	10,000	416.67	0.116																																							
Max Hourly Peak factor 2.25	22,500	937.5	0.260																																							
(2) Design Water Quality	<div style="text-align: right;">Unit:mg/L</div> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th rowspan="2">TP</th> </tr> <tr> <th>NH₄-N</th> <th>Org-N</th> <th>NOx-N</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td>250</td> <td>450</td> <td>400</td> <td>10</td> <td>20</td> <td>0</td> <td>6</td> </tr> <tr> <td>Outlet</td> <td>10</td> <td>50</td> <td>10</td> <td>2</td> <td>0</td> <td>8</td> <td>2</td> </tr> <tr> <td>Removal rate</td> <td>96.0%</td> <td>88.9%</td> <td>97.5%</td> <td colspan="3">66.7%</td> <td>-</td> </tr> </tbody> </table>								BOD	COD	SS	T-N			TP	NH ₄ -N	Org-N	NOx-N	Inlet	250	450	400	10	20	0	6	Outlet	10	50	10	2	0	8	2	Removal rate	96.0%	88.9%	97.5%	66.7%			-
	BOD	COD	SS	T-N			TP																																			
				NH ₄ -N	Org-N	NOx-N																																				
Inlet	250	450	400	10	20	0	6																																			
Outlet	10	50	10	2	0	8	2																																			
Removal rate	96.0%	88.9%	97.5%	66.7%			-																																			
2. Inlet Chamber																																										
[1] Design Condition																																										
(1) Design Flow Rate	<table style="width:100%; border: none;"> <tr> <td style="width:40%;"></td> <td style="width:10%;">Max Hourly</td> <td style="width:10%;">=</td> <td style="width:10%;">22,500</td> <td style="width:10%;">m3/day</td> <td colspan="2"></td> </tr> <tr> <td></td> <td></td> <td>=</td> <td>0.260</td> <td>m3/sec</td> <td colspan="2"></td> </tr> </table>								Max Hourly	=	22,500	m3/day					=	0.260	m3/sec																							
	Max Hourly	=	22,500	m3/day																																						
		=	0.260	m3/sec																																						
[2] Geometry																																										
(1) Number of Basins	1 Basin																																									
(2) Depth of Basin	2.000 m																																									
(3) Width of Basin	3.200 m																																									
(4) Length of Basin	3.500 m																																									
(5) Volume required of Basin	2.000 × 3.200 × 3.500 = 1.8 m ³																																									
(6) Retention Time	2.000 × 3.200 × 3.500 / 0.260 × 1 = 86.1538462 sec																																									
(7) Basin Dimensions	<table style="width:100%; border: none;"> <tr> <td style="width:40%;"></td> <td style="width:10%;">Width</td> <td style="width:10%;">3.200</td> <td style="width:10%;">m</td> <td style="width:10%;">×</td> <td style="width:10%;">Length</td> <td style="width:10%;">3.500</td> <td style="width:10%;">m</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td>×</td> <td>Depth</td> <td>2.000</td> <td>m</td> </tr> </table>								Width	3.200	m	×	Length	3.500	m					×	Depth	2.000	m																			
	Width	3.200	m	×	Length	3.500	m																																			
				×	Depth	2.000	m																																			

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Wastewater Flow	Max Hourly = 22,500 m ³ /d = 0.260 m ³ /sec
[2] Geometry	
(1) Inlet Gate	
Number	2 Main + 1 Bypass
Width	0.500 m
Height	0.750 m
Floor Level	+ m
Bottom	+ m
Influent Water Level	+ m
Velocity	0.260 / 0.500 / 0.500 / 2 = 0.520 = 1.000 m/sec
(2) Screen Channel	
Number	2 Main + 1 Bypass
Width	0.800 m
Side Water Depth	0.500 m
Velocity	0.260 / 0.800 / 0.500 / 2 = 0.325 = 0.450 m/sec
(3) Channel Dimensions	Width 0.8 m Length 7.5 m SWD 0.5 m (Freeboard 0.3m)
[3] Equipment	
(1) Inlet Gate	
Number	2 W + 1 S
Dimension	Width 0.5 m Height 0.75 m
Design Water Level	0.00 m
(2) Fine Screens (Main Channel)	
Number	2 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	0.8 m
Width of side plate	50 mm
Side Water Depth	0.5 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	0.260 / 0.700 / 0.450 / 2 × (6 + 2) / 6 = 0.550 < 0.800 m/sec
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	0.8 m
Side Water Depth	0.5 m
Velocity through screen	0.260 / 0.800 / 0.500 / 2 × (20 + 9) / 20 = 0.471 < 0.800 m/sec

4. Grit Chamber	
[1] Design Condition	
(1) Design Flow Rate	Max Hourly = 22,500 m ³ /day = 0.260 m ³ /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0111 m/sec = 960 m ³ /m ² /day
(4) Average Velocity	0.3 m/sec
[2] Grit Chamber	
(1) Surface Area required	0.260 / 0.0111 = 23.42 m ²
(2) Number of Basins	2 S + 0 W
(3) Surface Area required/Basin	23.4 / 2 = 11.71 m ²
(4) Length of Basin	11.71 / 0.5 = 3.4 m → 4.0 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.260 × 60 sec / 2 = 7.8 m ³
(7) Depth required	7.8 / 4.0 / 4.0 = 0.488 m
(8) Basin Dimensions	Width 4.0 m × Length 4.0 m × Depth 0.5 m (Freeboard 0.3m)
(9) Retention Time	4 × 4.0 × 0.5 / 0.260 × 2 = 60.00 sec
(10) Surface Overflow Rate at Peak Flow	22,500 / 4.0 / 4.0 / 2 = 703.125 < 960 m ³ /m ² /day
[3] Parshall Flume	
(1) Design Flow Rate	Q = 260.000 l/sec
(2) Throat width	W = 0.450 m / (W) ^{2/3}
(3) Water depth Ha	Ha = (Q / 2264) ^{3/2} Ha = 0.402 m
(4) Crest Level	+ 75.400 m = Minimum water level at downstream channel
(5) Water level at the crest	+ 75.802 m
(6) Channel bottom level	+ m
(7) Upstream Channel width	1.500 m
(8) SWD of Upstream Channel	0.700 m
(9) Average velocity at upstream channel	0.248 m/sec
(10) Total Length of channel	10.000 m
[4] Inlet Weir Gate	
(1) Number	2 Units
(2) Weir Width	0.800 m
(3) Stroke	0.500 m
(4) Overflow Height	0.400 m
(5) Overflow Height (actual)	(0.260 / 1.840 / 0.800 / 2) ^{2/3} = 0.198 < 0.400 m

5. Reactor	
[1] Design Condition	
(1) Design Wastewater Flow	Q = 10,000 m ³ /day (summer) Q' = 10,000 m ³ /day (Winter)
(2) Design Sewage Quality	
Inlet BOD	250 mg/l
Outlet BOD	10.0 mg/l
Inlet S-BOD	167 mg/l assumed as 2/3 of BOD
Inlet COD	450 mg/l
Inlet s-COD	300 mg/l assumed as 2/3 of COD
Outlet s-COD	33 mg/l = sCOD - 1.6sBOD
Inlet nbCOD	68 mg/l assumed as 15% of COD
bcOD/BOD	1.60
Inlet bcCOD	400 mg/l
Inlet nbCOD	50 mg/l
Inlet nbpCOD	17 mg/l = TCOD - bcCOD - nbCOD
Inlet TSS	450 mg/l
Inlet SS	450 mg/l
Inlet VSS	315 mg/l assumed as 70% of TSS
sVSS _{COD}	0.48 gCOD/gVSS = TCOD - sCOD/VSS
nbVSS	35.00 gnbVSS = nbpCOD/VSS _{COD}
TSS	135.00 gnbVSS = TSS - VSS
Inlet T-N	30 mg/l
Inlet TKN	30 mg/l
Inlet NH ₄ -N	10 mg/l
Inlet T-P	6 mg/l
Inlet Alkalinity as CaCO ₃	380 mg/l
Outlet Kjeldahl N	2.0 mg/l
Outlet NH ₄ -N	2.0 mg/l
Outlet NO ₃ -N	8.0 mg/l
(3) Water Temperature	T = 20.0 °C
(4) Safety Factor for Nitrogen	SF = 1.5
(5) Return Sludge Concentration	R _s = 8,000 mg/l
(6) MLSS MLVSS	X _{TSS} = 3,000 mg/l
(7) DO in the Reactor	2 mg/l

[2] Design Value for perfect Nitrification of Nitrification Process

(1) Activated sludge design kinwtic coefficients at 20 °C

Coefficient	Unit	COD oxidatio	NH ₄ oxidatio	NO ₂ oxidatio
μ _{max}	gVSS/gVSS · d	6.000	0.900	1.000
K _s , K _{NH₄} , K _{NO₂}	mg/L	8.000	0.500	0.200
Y	gVSS/g substrate oxidized	0.450	0.150	0.050
b	gVSS/gVSS · d	0.120	0.170	0.170
fd	unitless	0.150	0.150	0.150
K _{O₂}	mg/L	0.200	0.500	0.900
θ Value				
μ _{max}	unitless	1.070	1.072	1.063
b	unitless	1.040	1.029	1.029
K _s , K _{NH₄} , K _{NO₂}	unitless	1.000	1.000	1.000

Wastewater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF & EDDY/AECOM)

(2) μ _{AOB}	μ _{AOB} = 0.3100 g/g · d = μ _{max, AOB} [S _{NH₄} / (S _{NH₄} + K _{NH₄})] [S _o / (S _o + K _{o, AOB})] - b _{AOB}
μ _{max, AOB, T}	μ _{max, AOB, T} = 0.9000 g/g · d = μ _{max} * 1.072 ^(T-20) μ _{max} at 20°C = 0.900
b _{AOB, T}	b _{AOB, T} = 0.1700 = b * 1.029 ^(T-20) b at 20°C = 0.170
S _{NH₄}	S _{NH₄} = 1.0000 mg/l
DO	DO = 2.0000 mg/l
K _{o, AOB}	K _{o, AOB} = 0.5000 mg/l
(2) Design SRT	SRT = 4.8387 day = 1 / μ _{AOB} × SF

(3) Biomass production				
Px,VSS		1597.233	kg/d	=Px,bio+Q(nbVSS)
Px,TSS		3167.333	kg/d	=Px,bio/0.85+Q(nbVSS)+Q(TSS ₀ -VSS ₀)
S		0.4606	mg/l	=Ks[1+b _H (SRT)]/[SRT(μ _m -b _H)-1]
b _H		0.1200		=b*1.04 ^(T-20) b at 20°C = 0.120
Y _H		0.4500	gVSS/g bCOD	
μ _{m,T}		6.0000	g/g·d	=μ _{max} *1.04 ^(T-20) μ _{max} at 20°C = 6.000
Y _n		0.150	gVSS/g NOx	
NOx		13.000	mg/l	
P _{X,bio,VSS}		1247.233	kg VSS/c	=Q·Y _H (S ₀ -S)/[1+b _H (SRT)]+f _d ·b _H ·QY _H (S ₀ -S)SRT/[1+b _H (SRT)] +QY _n (NOx)/[2+b _{AOB} (SRT)]
		1137.464		=Q·Y _H (S ₀ -S)/[1+b _H (SRT)]
		99.069		=f _d ·b _H ·QY _H (S ₀ -S)SRT/[1+b _H (SRT)]
		10.699		=QY _n (NOx)/[1+b _{AOB} (SRT)]
NOx		13.033	mg/l	=TKN-N _e -0.12P _{X,bio} /Q
(4) Required Aeration Tank Volume				
V _a		5,109	m ³	
τ		12.26	hr	=V _a /Q × 24
X _{VSS} ·V _a		7,729	kg VSS	=P _{X,VSS} ·SRT
X _{TSS} ·V _a		15,326	kg TSS	=P _{X,TSS} ·SRT
F/M		0.323	kgBOD/kgMLVSS	
Fraction VSS		0.504		
MLVSS		1513	mg/L	
(5) BODloading				
		0.489	kg/m ³ ·d	
(6) Observed Yield				
Y _{obs,TSS}		1.268	gTSS/gBOD	
Y _{obs,VSS}		0.640	gVSS/gBOD	
bCODremoved		3,995	kg/d	
(7) effluent NO ₂ -N				
NO ₂ -N		0.2407	mg/l	=Ks[1+b _{NOB} (SRT)]/[SRT(μ _{NOB} -b _{NOB})-1]
b _{NOB}		0.1700		=b*1.029 ^(T-20) b at 20°C = 0.170
μ _{m,T}		1.0000	g/g·d	=μ _{max} *1.04 ^(T-20) μ _{max} at 20°C = 1.000
μ _{AOB}		0.6897	g/g·d	=μ _{max,NOB} [S ₀ /(S ₀ +K _{O2,NOB})]
S ₀		2.000	mg/l	
K _{O2,NOB}		0.900	mg/l	
(8) effluent NH ₄ -N				
NH ₄ -N		0.5485	mg/l	=Ks[1+b _{NOB} (SRT)]/[SRT(μ _{NOB} -b _{NOB})-1]
b _{NOB}		0.1700		=b*1.029 ^(T-20) b at 20°C = 0.170
μ _{m,NOB,T}		0.9000	g/g·d	=μ _{max} *1.072 ^(T-20) μ _{max} at 20°C = 0.900
μ _{NOB,T}		0.7200	g/g·d	=μ _{max,NOB} [S ₀ /(S ₀ +K _{O2,NOB})]
S ₀		2.000	mg/l	
K _{O2,NOB}		0.500	mg/l	
(9) Ratio of Return Sludge				
		8,000·Rr/(1+Rr)	=	3,000 mg/L
		3,000/(8,000-3,000)	=	0.60
		Rr	=	0.60

[3] Design for Nitrification and Denitrification Process

(1) Active biomass concentration

$$X_b = \frac{Q \cdot (SRT)^2 \cdot Y_{nl}(S_0 - S) [1 + b_{nl}(SRT)]}{1,077,37 \text{ mg/l}}$$

(2) IR ratio

$$IR = \frac{NO_x/N_e}{1.0 \cdot R} = 0.03$$

(3) The amount of NO₃-N fed to the anoxic tank

$$Nox \text{ feed} = (IR + R) \cdot Q \cdot N_e = 50,332.08 \text{ kg/d}$$

(4) The anoxic tank volume

$$V_{no1} = 511 \text{ m}^3 = V_a \times 10\% \\ V_{no1} = 1,667 \text{ m}^3 \quad \tau_{no1} = 4.000 \text{ h}$$

(5) F/M_b

$$F/M_b = 1.39 \text{ g/g} \cdot \text{d}$$

(6) Fraction of rbCOD

$$16.88\% = \frac{rbCOD}{bCOD}$$

Percent rdCOD(%)	SDNR equation coefficients	
	b0	b1
10	0.186	0.078
20	0.213	0.118
30	0.235	0.141
40	0.242	0.152
50	0.270	0.162

(8) SDNR_b

$$SDNR_b = 0.252 \text{ g/g} \cdot \text{d} = b_0 + b_1 [\ln(F/M_b)]$$

$$b_0 = 0.213$$

$$b_1 = 0.118$$

(8) SDNR

$$SDNR = 0.120 \text{ g/g} \cdot \text{d} = SDNR_b (MLVSS_b / MLVSS)$$

$$SDNR_{adj} = 0.169 \text{ g/g} \cdot \text{d} = SDNR_t - 0.029 \ln(F/M_b) - 0.012 \quad IR=3-4 \\ = SDNR_t - 0.0166 \ln(F/M_b) - 0.078 \quad IR=2$$

$$SDNR_t = 0.252 \text{ g/g} \cdot \text{d} = SDNR_b \cdot \theta^{(1-20)} \quad \theta = 1.026$$

(9) NO_r

$$NO_r = 302,664.85 \text{ kg/d} = N_{max} \cdot SDNR \cdot X_b \\ > Nox \text{ feed} = 50,332 \text{ kg/d}$$

(10) Alkalinity to be added to maintain pH7

$$-235.15 \text{ mg/l}$$

$$\text{Influent Alk} = 380.00 \text{ mg/l}$$

$$\text{Alk used} = 92.82 \text{ mg/l} = 7.14 \times Nox$$

$$\text{Alk produce} = 17.97 \text{ mg/l} = 3.57 \times (NO_x - NO_{xe})$$

$$\text{Alk to maint.} = 70.00 \text{ mg/l}$$

[5] Reactor

- (1) Coagulant Dosage
- (2) Total volume of Aeration Basins
- (3) Total volume of Anoxic Basins

0.0 Mol

$$V_A = Q \cdot \theta_a / 24 = 5,109 \text{ m}^3$$

$$V_{DN} = Q \cdot \theta_{DN} / 24 = 1,667 \text{ m}^3$$

Item	Volume required	Retention Time required		Ratio of Volume
		Summer	Winter	
unit	m ³	hour	hour	
Anaerobic	V _{AN}	0	0.00	0.00
Anoxic	V _{DN}	1,670	4.01	1.00
Aerobic	V _A	5,110	12.26	3.06
Total	V	6,780	16.27	

[6] Geometry

- (1) Basin Dimensions
 - Cross Section
 - Hantzsck Subtraction after Subtraction
 - Total Volume
- (2) Partition of Basin

Width	Length	Depth	Basins
8.0	116.0	5.0	2
Cross Section		=	40.0 m ² /Basin
Hantzsck Subtraction after Subtraction		=	1.0 m ² /Basin
Total Volume		=	39.0 m ² /Basin
39.0*116.0		=	4,524 m ² /Basin 9,048 m ³ /Total

Item	unit	Anaerobic	Anoxic	Aerobic	Total
Cross Section	m ²	39.0			
Length required	m	0.0	21.4	65.5	86.9
Volume required per Basin	m ³	0	835	2,555	3,390
Total Volume required	m ³	0	1,670	5,110	6,780
Actual Cross Section	m ²	39.0	39.0	39.0	
Actual Length	m	0.0	29.0	87.0	116.0
Actual Volume per Basin	m ³	0	1,131	3,393	4,524
Actual Total Volume	m ³	0	2,262	6,786	9,048
Actual Ratio of Volume		0.00	1.00	3.00	
Actual Retention Time	hour	0.00	5.43	16.29	21.72

[7] Equipment

- (1) Ras Pumps
 - Ras Ratio
 - Required Capacity
 - Number
- (2) Circulation Pumps
 - Ras Ratio
 - Required Capacity
 - Number
- (3) SAS Pumps
 - Excess Sludge
 - Sludge withdraw
 - Running Time
 - Required Capacity
 - Number

60	%			
10,000	m ³ /day*	60% / 24	/	2
= 125	m ³ /Hr	⇒	125	m ³ /Hr
2	Work			
2	Stanby			
60	%			
10,000	m ³ /day*	60% / 24	/	2
= 125	m ³ /Hr	⇒	125	m ³ /Hr
2	Work			
2	Stanby			
440	m ³ /day			
12	Times/day			
0.5	Hr/Time			
440	m ³ /day /	12 /	0.50 /	2
= 36.63	m ³ /Hr	⇒	40	m ³ /Hr
2	Work			
2	Stanby			

6. Air Requirement at Average Flow	
[1] Design Condition	
(1) AOR	AOR = 2,691 kg/day = 112.1 kg/h
Q _{in} : Design Average Flow	m ³ /d 10,000
Inlet bCOD : S ₀	400 mg/l
S=	0.461 mg/l
Nox=	13,000 mg/l
P _{X,bio} =	1,236.5 kg VSS/ does not include nitrifying bacteria
R ₀ =	R ₀ = Q(S ₀ - S - k(Nox - NOx)) - 1.42P _{X,bio} + 4.57Q · NOx
R ₀ =	2,691 kg O ₂ /d
k=	2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{AOR \times C_s \cdot a \times 1.024^{20-T}}{\alpha \times F (\beta \cdot C_{sw} / C_s \cdot (P_b/P_a) \alpha - C_A)}$
	C _s : Saturated DO at sea level and 20 °C 9.09 mg/l
	C _{sw} : Saturated DO at sea level and operating Temperature 9.09 mg/L at 20 °C
	20-T : 0.0 1.024 ^{20-T} : 1.0000
	C _A : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1 + 0.40D _j /P _a 1.18196
	D _j : Tank Liquid Depth 4.70 m
	P _a : Standard absolute pressure at s 10.332 m
	P _b : Absolute pressure at Plant Site Elevation m
	P _b /P _a : exp[-gM(z _b -z _a)/R*T] 0.991
	g : Acceleration due to Gravity 9.80665 m/s ²
	M : Mole of Air 28.97 kg/kg-mole
	z _b : Plant Site Elevation 80 m
	z _a : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 293.15 Kelvin
	α : relative Transfer Rate to clean Wa 0.65
	β : relative DO Saturation to clean Wa 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{28.908}{4.7456} = 6,091.59 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Standard O ₂ required at Field Conditions per Bas =	3,046 kg/day
(5) SOTE for the above Effective Aeration Depth	28.5 %
(6) Fraction of O ₂ in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	15%
(9) Air required at Field Conditions per Basins	= 44.010 m ³ /day = 1,833.7 m ³ /hr

[2] Equipment	
(1) Air Blower	
Number	4 W + 2 S
Required Capacity	1833.7 m ³ /Hr·Basin / 2 unit/Basin = 916.9 m ³ /h ⇒ 920 m ³ /h/Unit
Pressure	60 kPa
Safety Factor	10 %
Heat capacity ratio	1.4
Atmospheric pressure at site elevation	100.385 kPa
Total inlet pressure	98.385 kPa
Volume rate of flow at inlet point	15.788 m ³ /min
Total discharge pressure	160.385 kPa
Overall adiabatic efficiency	0.65
Inlet air temperature (min.)	15 °C
Shaft power	21.250 kW
Rated Output of Motor	23.375 kW ⇒ 30 kW

7. Final Clarifire							
[1] Design Condition							
(1) Design Wastewater Flow	$Q = 10,000 \text{ m}^3/\text{day}$						
(2) Water Temperature	$T = 20.0 \text{ }^\circ\text{C}$						
(3) MLSS	$X_{ef} = 3,000 \text{ mg/l}$						
(4) SVI	$SVI = 200$						
(5) Sedimentation Velocity	$v = 4.899 \cdot 10^6 \cdot T^{(0.954)} \cdot X_{ef}^{(-1.354)} \cdot SVI^{(-0.77)}$ $= 4.899 \cdot 10^6 \cdot 20.0^{0.954} \cdot 3,000^{-1.354} \cdot 200^{-0.770}$ $= 28.3 \text{ m/day} \quad \rightarrow \quad 15.0 \text{ m}^3/\text{m}^2 \cdot \text{day}$						
(6) Surface Overflow Rate required	$S' = v/(1.5 \cdot 1) = 28.3/(1.5 \cdot 1.0) = 18.9 \text{ m}^3/\text{m}^2 \cdot \text{day}$						
[2] Geometry							
(1) Surface Area required	$A = 10,000/15.0 = 667 \text{ m}^2$						
(2) Demensions	<table style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th>Diameter</th> <th>Depth</th> <th>Basin</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">24.0</td> <td style="text-align: center;">3.5</td> <td style="text-align: center;">2</td> </tr> </tbody> </table>	Diameter	Depth	Basin	24.0	3.5	2
Diameter	Depth	Basin					
24.0	3.5	2					
(3) Actual Surface Area	$S = 24.0^2 \cdot 3.14 / 4 \cdot 2.0 = 905 \text{ m}^2$						
(4) Surface Overflow Rate	$S = 10,000/905 = 11.0 \text{ m}^3/\text{m}^2 \cdot \text{day}$						

8. Chlorination	
[1] Design Condition	
(1) Design Flow Rate	Average Daily Flow 10,000 m ³ /day 416.67 m ³ /h
(2) Contact Time	30 min
(3) Type of Chlorine	Bleaching Powder (Availtive chlorine 70%)
(4) Design Chlorine Dosage Rate	10 mg/L
(5) Required Chlorine per day	Average Daily Flow / 1000 × Design Chlorine Dosage Rate = 100.0 kg/d = 4.17 kg/h
(6) Consumption per day	142.9 kg/d as Bleaching Powder
[2] Chlorination Contact Tank	
(1) Volume required	Average Daily Flow / 1440 × Contact Time = 208.3 m ³
(2) Nos. of lanes	5 lanes
(3) Width of lane	2.00 m
(4) Length of lane	14.00 m
(5) Side Water Depth	2.00 m
(6) Nos. of Tanks	1 tank
(7) Total Width of Tank	13.00 m Approx..
(8) Average Velocity	Decant Flow / 3600 / Width / Depth = 867 / 3600 / 2.00 / 2.00 = 0.060 m/sec
(9) Total Volume	Width × Length × Depth × Nos. of lanes × Nos. of Tanks = 2.0 m × 14.0 m × 2.0 m × 5 × 1 = 280 m ³ > 208.3 m ³
[3] Equipment	
(1) Chlorine Solution Tank	
Number	2 W + 0 S
Chlorine concentration	2 %
Gravity of dissolved chlorine	1.10
Required solution volume	100.00 kg / d × 100 / 2 / 1.10 / 1000 = 4.55 m3/d
Dimension of Tank	1.5 mW × 1.5 mL × 1.5 mSWD
Volume of Tank	3.4 m3/tank
Total Volume of Tanks	6.8 m3 (Duration= 1.49 day)
(2) Mixer for Chlorine Solution Tank	
Number	2 W + 0 S
(3) Chlorine Dosing Pump	
Number	2 W + 2 S
Capacity	4.55 m3/d / 24 × 1000 / 2 95 l/h/unit ⇒ 100 l/h/unit

<p>9. Dechlorination</p> <p>[1] Design Condition</p> <p>(1) Design Flow Rate</p> <p>(2) Contact Time</p> <p>(3) Type of Dechlorine</p> <p>(4) Free Residual Chlorine</p> <p>(5) Consumption per day</p> <p>[2] Dechlorination Contact Tank</p> <p>(1) Volume required</p> <p>(2) Width of lane</p> <p>(3) Length of lane</p> <p>(4) Side Water Depth</p> <p>(5) Nos. of Tanks</p> <p>(6) Total Volume</p> <p>[3] Equipment</p> <p>(1) Dechlorine Solution Tank</p> <p>Number</p> <p>Dechlorine concentration</p> <p>Gravity of dissolved dechlorine</p> <p>Required solution volume</p> <p>Volume of Tank</p> <p>Total Volume of Tanks</p> <p>(2) Mixer for Dechlorine Solution Tank</p> <p>Number</p> <p>(3) Dechlorine Dosing Pump</p> <p>Number</p> <p>Capacity</p>	<p>Average Daily Flow 10,000 m³/day</p> <p>10 min</p> <p>Sodium Thiosulfate (Na₂S₂O₄ · 5H₂O)</p> <p>1.0 mg/L assumed value</p> <p>Average Daily Flow / 1000 × Free Residual Chlorine × 1.19</p> <p>× 2 (safety factor)</p> <p>= 23.8 kg/d</p> <p>= 0.99 kg/h</p> <p>Average Flow Rate / 60 × Contact Time</p> <p>= 69.4 m³</p> <p>13.00 m</p> <p>4.00 m</p> <p>2.00 m</p> <p>1 tank</p> <p>Width × Length × Depth</p> <p>= 13.0 m × 4.0 m × 2.0 m</p> <p>= 104 m³</p> <p>2 W + 0 S</p> <p>10 ‰</p> <p>1.10</p> <p>23.80 kg/d × 100 / 10 × 1.10 × 1000</p> <p>= 0.22 m³/d</p> <p>0.3 m³ tank</p> <p>0.6 m³ (Duration= 2.77 day)</p> <p>2 W + 0 S</p> <p>1 W + 1 S</p> <p>0.22 m³/d / 24 × 1000 / 1</p> <p>9.02 l/h/unit ⇒ 10 l/h/unit</p>
--	--


11. Thickener Feed Sump	
[1] Design Condition	
(1) Inlet Solids	3,517 kg/day
(2) Inlet Sludge Volume	440 m ³ /d
[2] Geometry	
(1) Sludge withdrawal	12 Times/day
(2) Required Sump Volume	37 m ³ /d
(3) Number	2 Basins
(4) Width	3.0 m
(5) Length	3.0 m
(6) Side Water Depth	3.0 m
(7) Actual Sump Volume	3.0 × 3.0 × 3.0 × 2 = 54.0 m ³
[3] Equipment	
(1) Thickened Sludge Transfer Pumps	
Transfer Time	6.00 Hr
Number	2 W = 2 S
Required Capacity	440 m ³ / 6.0 = 36.6 m ³ /Hr ⇒ 40 m ³ /Hr /Unit

12. Centrifuge	
[1] Design Condition	
(1) Type of Dewatering	Centrifuge
(2) Quantity of Thickend Sludge generated	3,165 kg/day
(3) Design Polyelectrolyte Dosage	Polyelectrolyte 1.5 kg/t-DS·day
(4) Volume of Thickend Sludge	126.6 m ³ /day
(5) Consistency of Dewatered Sludge	82 %
(6) Operation Time	8 hours/day (6 days per week)
[2] Volume of Centrifuges	
	$\frac{\text{Digested Solids}}{\text{Operation Time} \times \text{No.}} \times \text{Operation/week}$ $= \frac{126.6}{8 \times 1} \times \frac{7}{6} = 18.5$ $\rightarrow 19 \text{ m}^3/\text{hour}$
[3] Dewatered Solids	
	$\text{Digested Sludge} \times \left(1 + \frac{\text{Injection Rate}}{100} \right)$ $= 3,165 \times \left(1 + \frac{0.0015}{100} \right)$ $= 3,170 \text{ kg/day}$
[4] Dewatered Cake Volume	
	$\text{Dewatered Solids} \times \frac{100}{100 - \frac{\text{Moisture Content}}{7}} \times \frac{7}{6 \text{ days per week}}$ $= 3,170 \times \frac{100}{100 - 82} \times \frac{7}{6}$ $= 20.55 \text{ t/day}$ $\frac{\text{apparent specific gravity}}{20.55} \times 1.0 = \frac{1.00}{20.5} \text{ m}^3/\text{day}$
[5] Polyelectrolyte	
(1) Design Polyelectrolyte Dosage	1.5 kg/t-DS·day
(2) Required Polyelectrolyte	4.75 kg/day
(3) Dissolving concentration	0.20 %
(4) Volume of Polyelectrolyte solution	2.37 m ³ /day

[6] Equipment						
(1) Centrifuge						
Capacity	19	m ³ /hr				
Number	1	W	+	1	S	
(2) Centrifuge Feed Pumps						
Capacity	19	m ³ /hr				
Number	1	W	+	1	S	
(3) Polyelectrolyte Dosing Pumps						
Volume of Polyelectrolyte solution	2.37	m ³ /day				
Operation Time	8	hours/day			(6 days per week)	
Safety Factor	1.5					
Number	1	W	+	1	S	
Required Capacity	2.37	m ³ /day	>	7	/	6
						8
	=	0.35	m ³ /Hr			1
Specification Capacity	0.35	m ³ /Hr	×		1.5	
	=	0.519	m ³ /Hr	⇒	0.52	m ³ /Hr /Unit
(4) Polyelectrolyte dosing System						
Tanks Dimensions						
Width	1.5	m	×	Length	2.0	m
Depth	2.0	m	×	2	(Freeboard 0.5m)	
	=	12	m ³			
Retention Time of Tanks	12.00	m ³	/	0.35	m ³ /Hr	/
	=	34.665	Hr			1
Number	2	W	+	0	S	


13. Centrifuge Feed Sump	
[1] Design Condition	
(1) Generated Thickend Sludge	3,165 kg/day
(2) Solids Consistency	2.50 %
(3) Volume of Thickened Sludge	$\begin{aligned} & \text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3} \\ = & 3,165 \times \frac{100}{2.50} \times 10^{-3} \\ = & 127 \text{ m}^3/\text{day} \\ = & 5.28 \text{ m}^3/\text{h} \end{aligned}$
(4) Sludge feed flow rate	19 m ³ /h × 1 = 19 m ³ /h
(5) Centrifuge Operation Time	8 hours/day (6 days per week)
[2] Geometry	
(1) Required sludge volume for continuation	(19 - 5.28) × 8 = 109.80 m ³
(2) Basin Dimensions	$\begin{aligned} & \text{Width } 4.0 \text{ m} \times \text{Length } 5.0 \text{ m} \\ & \times \text{Depth } 3.5 \text{ m} \times 2 \\ = & 140.0 \text{ m}^3 \end{aligned}$
[3] Equipment	
(1) Mixers for Centrifuge Feed Sumps	
Required Volume	140.0 m ³
Number	1 W + 1 S

Material Balance Sheet
[Ramnagar STP]






Sr. No.	Facility	No.	W/Dia. (m)	L (m)	SWD/H (m)
01	Inlet Chamber	1	4.0 ^W	5.5 ^L	4.0 ^{SWD}
02	Main Screen Channel	1	2.0 ^W	5.0 ^L	0.7 ^{SWD}
03	Bypass Screen Channel	1	*** ^W	*** ^L	*** ^{SWD}
04	Grit Chamber	2	3.0 ^{Dia.}		3.0 ^{SWD}
05	Parshall Flume	1	1.5 ^W	10.0 ^L	0.8 ^{SWD}
06	Distribution Chamber	4	*** ^W	*** ^L	*** ^{SWD}
07	Anoxic Tank	2	17.0 ^W	28.0 ^L	5.5 ^H
08	Aerobic Tank	1	7.0 ^W	30.0 ^L	2.0 ^{SWD}
09	Secondary Clarifier	1	*** ^{Dia.}		*** ^{SWD}
10	Chlorine Contact Tank	1	2.0 ^W	115.0 ^L	3.0 ^{SWD}
11	Dechlorine Mixing Tank	1	2.0 ^W	115.0 ^L	3.0 ^{SWD}
12	Secondary Sludge Sump	2	2.5 ^W	2.5 ^L	3.0 ^{SWD}
13	Sludge Thickener	2	13.5 ^{Dia.}		4.0 ^{SWD}
14	Thickened Sludge Sump	2	2.5 ^W	2.5 ^L	3.0 ^{SWD}
15	Centrifuge Feed Sump	4	5.0 ^W	5.0 ^L	3.5 ^{SWD}
16	Filtrate Sump	4	5.0 ^W	5.0 ^L	3.5 ^{SWD}
17	Air Blower Room	1	12.0 ^W	25.0 ^L	6.0 ^H
18	Chlorination Building	1	10.0 ^W	14.0 ^L	6.0 ^H
19	Centrifuge Building	1	16.0 ^W	30.0 ^L	10.0 ^H
20	Administration Building	1	16.0 ^W	30.0 ^L	10.0 ^H



- Main Process Line
- Sludge Line
- Other Line
- Proposed structure
- Demolished structure
- Existing structure

Project Name	
PREPARATORY SURVEY ON GANGA REJUVENATION PROJECT IN THE STATE OF UTTAR PRADESH, INDIA インド国ガンジス川浄化事業準備調査	
Drawing Title	Scale: 1:1000 (A3)
Ramnagar STP Layout	Drawing No. STP-28



Main Process ————
 Sludge Line - - - - -
 Other Line - - - - -
 Existing structure [---]

Project Name	
PREPARATORY SURVEY ON GANGA REJUVENATION PROJECT IN THE STATE OF UTTARPRADESH, INDIA ゴッガ川州の再生調査	
Drawing Title	Scale not
Ramnagar STP 10MLD layout	Drawing No STP-09

7. Integration back data

TABLE OF CONTENTS

1. District I (Varanasi)
2. District II (Varanasi)
3. District III (Varanasi)
4. Dinapur STP & Bhagwanpur STP (Varanasi)
5. Ramna STP (Varanasi)
6. Mirzapur
7. Ghazipur
8. Ramnagar
9. Chunar
10. Cost Breakdown for Package

1. District I (Varanasi)

1 INR(India Rupee)= 1.57 JPY
 1 US\$= 105.5 JPY

Summary - Varanasi District 1

Items	Specification	Unit	Qty	FC Portion (Yen)		LC Portion (INR)		Reference
				Unit	Amount	Unit	Amount	
Varanasi District 1		LS	1				2,747,775,976	
Cost of sewer cleaning equipments, Flushing Van		LS	1				4,055,000.00	
Hiring of Godown and Site Office		LS	1				1,020,000.00	
Communication & Public Outreach		LS	1				3,500,000.00	
Environmental and Management Plan		LS	1				1,000,000.00	
Governance and Accountability Action Plan (GAAP)		LS	1				2,000,000.00	
Total							2,759,350,975.57	

Items	Specification	Unit	Qty	FC Portion (Yen)		LC Portion (INR)		Reference
				Unit Price	Amount	Unit Price	Amount	
<Civil/Building work>								
	SEWER LAYING							
	DISMANTLING AND REINSTATEMENT OF EXISTING ROADS							
	DISMANTLING WORK							
	Dismantling manually / by mechanical means including stacking of serviceable material and disposal of unserviceable material within 50 metres lead as per direction of Engineer-in-Charge							
15.43.2 - DSR_2014	a) Bitumen Road	m2	29,864.27			159.05	4,749,911.61	
1266 - SOR_U.P. Jal Nigam Varanasi_2015-16	b) Cement Concrete Road	m3	11,577.44			1,013.71	11,736,165.59	
							0.00	
16.83 - DSR_2014	Taking out existing CC interlocking paver blocks from footpath/ central verge, including removal of rubbish etc., disposal of unserviceable material to the dumping ground, for which payment shall be made separately and stacking of serviceable material within 50 metre lead as per direction of	m2	278,112.89			48.30	13,432,852.65	
							0.00	
	REINSTATEMENT WORK						0.00	
UP PWD 2013	Reinstatement of Existing Bitumen Road - Owned by Nagar Nigam	m2	29,864.27			3,634.00	108,526,745.01	
							0.00	
1323 - SOR_U.P. Jal Nigam Varanasi_2015-16	Providing all Materials, Labours, T & P etc & construct 100mm thick (1:2:4) Cement Concrete Road for Reinstatement of patch & trench cuts in	m3	11,577			2,228.10	25,795,691.61	
							0.00	
16.68 - DSR_2014	Providing and laying 60 mm thick factory made cement concrete interlocking paver block of M-30 grade made by block making machine with strong vibratory compaction, of approved size, design & shape, laid in required colour and pattern over and including 50 mm thick compacted bed of coarse sand, filling the joints with fine sand etc all complete as per the	m2	55,623			602.20	33,495,916.63	
							0.00	
16.84 - DSR_2014	Laying old cement concrete interlocking paver blocks of any design/shape laid in required line, level, curvature, colour and pattern over and including 50 mm thick compacted bed of coarse sand, filling the joints with fine sand etc all complete as per the direction of Engineer-in-charge. (Old CC paver blocks shall be supplied by the	m2	249,615			195.70	48,849,672.93	
							0.00	
	EARTH WORK (SEWER)						0.00	
							0.00	
	Excavation by manually or mechanically up to following depths below G.L. for laying sewer line, in ordinary soil (earth, sand, loam & clay) including cutting of joints pits ramming dressing, leveling by manually or mechanically, refilling of trenches in 15cm layer watering and ramming the same including removal of surplus earth or other dismantled material up to a distance of 50m from the centre of trenches. (Excavation for Manhole is						0.00	
3001 - SOR_U.P. Jal Nigam Varanasi_2015-16	a) 0.0 to 1.5 mtr B.G.L	m3	263,836.84			184.79	48,754,409.73	
3002 - SOR_U.P. Jal Nigam Varanasi_2015-16	b) 1.5 to 3.0 mtr B.G.L	m3	212,645.51			231.98	49,329,506.21	
3003 - SOR_U.P. Jal Nigam Varanasi_2015-16	c) 3.0 to 4.5 mtr B.G.L	m3	104,428.88			291.27	30,417,000.42	
3004 - SOR_U.P. Jal Nigam Varanasi_2015-16	d) 4.5 to 6.0 mtr B.G.L	m3	35,692.33			340.09	12,138,605.18	
3005 - SOR_U.P. Jal Nigam Varanasi_2015-16	e) 6.0 to 7.5 mtr B.G.L	m3	9,377.51			443.48	4,158,739.87	
3006 - SOR_U.P. Jal Nigam Varanasi_2015-16	f) 7.5 to 9.0 mtr B.G.L	m3	5,335.95			583.07	3,111,232.37	
							0.00	
							0.00	

	Items	Specification	Unit	Qty	P/C Portion (Yen)		L/C Portion (INR)		Reference
					Unit Price	Amount	Unit Price	Amount	
RA16	Disposal of excavated excess earth away from the site including conveyance of material up to an average lead for 5km & above away from the site and corresponding required lift, loading, unloading etc complete as directed by the engineer-in-charge. (The quantity is net quantity)							0.00	
	By Mechanical Transport including loading, unloading and stacking (Lead upto 5 Km away from the site)		m ³	21,155.28			366.16	7,744,946.71	
								0.00	
	Filling available excavated earth (excluding rock) in trenches, plinth, sides of foundations etc. in layers not exceeding 20 cm in depth, consolidating each deposited layer by tamping and watering, lead up to 50 m.							0.00	
1003 - SOR U.P. Jal Nigam Varanasi 2014-15	a) 0.0 to 1.5 mtr B.G.L.		m ³				51.86	0.00	
1003 & 1006-SOR U.P. Jal Nigam	b) 1.5 to 3.0 mtr B.G.L.		m ³				74.55	0.00	
1003 & 1006-SOR U.P. Jal Nigam	c) 3.0 to 4.5 mtr B.G.L.		m ³				97.24	0.00	
1003 & 1006-SOR U.P. Jal Nigam	d) 4.5 to 6.0 mtr B.G.L.		m ³				119.93	0.00	
1003 & 1006 -SOR - U.P. Jal Nigam Varanasi 2014-15 and	e) 6.0 to 9.0 mtr B.G.L.		m ³				142.62	0.00	
								0.00	
RA16	Disposal of Road Cutting Rubbish / Malba / similar unserviceable, dismantled or waste material by mechanical means including loading, transportation, unloading to approved municipal dumping ground or as approved by Engineer - in charge, for 5km initial lead, for all leads including		m ³	32,445.21			292.85	9,501,579.66	
								0.00	
Similar Project Exp	Carting of excavated earth to identified place and recarting the same where sufficient width of road is not available for stacking of excavated earth average lead 500 mt.		m ³	62,598.11			158.00	9,890,501.09	
								0.00	
RA13	Bailing out or pumping out water / liquid mud during trench excavation. This includes providing necessary fuel, labour T&P etc. required for proper running of well point equipment of required capacity for lowering the water table during excavation and laying of		m	21,713.96			598.35	12,992,547.97	
	TRENCHLESS								
	Supply of precast RCC NP4 jacking pipes manufactured by centrifugal spinning or vertical casting comply to BSEN 5911, pt. 120 or EN 1916 2002 and also meet the basic concrete testing requirements specified in IS 458, IS 3597 of 1966 and IS 7596 1998. Including supply of suitable couplings (nomally Built in Type collar) made of weldable structural stainless steel conforming to BS 4360 Grade 43, or relevant Code including supply of suitable rubber rings conforming to EN								
		200 mm dia pipe	m	840.00			12,066.11	10,135,534.75	
		250mm dia pipe	m	309.00			12,736.45	3,935,563.79	
		300 mm dia pipe	m				13,406.79	0.00	
		350 mm dia pipe	m	18.00			14,077.13	253,388.37	
		400 mm dia pipe	m	268.00			14,747.47	3,952,322.28	
		450 mm dia pipe	m	30.00			15,417.81	462,534.32	
		500 mm dia pipe	m	99.00			16,088.15	1,592,726.89	
		600 mm dia pipe	m	192.00			18,099.17	3,475,040.49	
		700 mm dia pipe	m	30.00			20,110.19	603,305.64	
		800 mm dia pipe	m	90.00			24,450.00	2,200,500.00	
								0.00	

Items	Specification	Unit	Qty	PC Portion (Yen)		LC Portion (INR)		Reference
				Unit Price	Amount	Unit Price	Amount	
Providing and laying PCC Bedding with 12-20mm gauge approved stone ballast, coarse sand and cement in M-15 (1:2:4) all work up to plinth level, including supply of all materials labour T&P etc. required for proper completion of work and excluding							0.00	
200 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	284		472.76		134,216.56	
1.5 to 3.0 Mtr B.G.L.		m	16,291		484.47		7,892,549.22	
3.0 to 4.5 Mtr B.G.L.		m	29,577		500.08		14,791,091.20	
4.5 to 6.0 Mtr B.G.L.		m	5,540		519.59		2,878,684.48	
6.0 to 7.5 mtr B.G.L.		m	287		550.81		158,247.71	
250 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	44		549.31		24,169.64	
1.5 to 3.0 Mtr B.G.L.		m	2,361		563.02		1,329,290.22	
3.0 to 4.5 Mtr B.G.L.		m	3,457		581.29		2,009,519.53	
4.5 to 6.0 Mtr B.G.L.		m	1,679		604.12		1,014,317.48	
							0.00	
300 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	18		628.77		11,317.86	
1.5 to 3.0 Mtr B.G.L.		m	381		644.54		245,569.74	
3.0 to 4.5 Mtr B.G.L.		m	1,714		665.56		1,140,769.84	
							0.00	
350 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	0		711.13		0.00	
1.5 to 3.0 Mtr B.G.L.		m	616		729.03		449,082.48	
3.0 to 4.5 Mtr B.G.L.		m	175		752.91		131,759.25	
4.5 to 6.0 Mtr B.G.L.		m	74		782.76		57,924.24	
6.0 to 7.5 mtr B.G.L.		m	202		830.51		167,763.02	
7.5 to 9.0 mtr B.G.L.		m	0		890.21		0.00	
							0.00	
400 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	0		796.38		0.00	
1.5 to 3.0 Mtr B.G.L.		m	436		816.50		355,994.00	
3.0 to 4.5 Mtr B.G.L.		m	375		843.33		316,248.75	
4.5 to 6.0 Mtr B.G.L.		m	0		876.86		0.00	
6.0 to 7.5 mtr B.G.L.		m	189		930.51		175,866.39	
7.5 to 9.0 mtr B.G.L.		m	132		997.58		131,680.56	
9.0 to 10.5 mtr B.G.L.		m	0		1,064.64		0.00	
							0.00	
450 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	0		884.54		0.00	
1.5 to 3.0 Mtr B.G.L.		m	148		906.94		134,227.12	
3.0 to 4.5 Mtr B.G.L.		m	466		936.81		436,553.46	
4.5 to 6.0 Mtr B.G.L.		m	502		974.15		489,023.30	
6.0 to 7.5 mtr B.G.L.		m	0		1,033.89		0.00	
7.5 to 9.0 mtr B.G.L.		m	128		1,108.57		141,896.96	
9.0 to 10.5 mtr B.G.L.		m	0		1,183.25		0.00	
							0.00	
500 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	0		975.59		0.00	
1.5 to 3.0 Mtr B.G.L.		m	98		1,000.35		98,034.30	
3.0 to 4.5 Mtr B.G.L.		m	826		1,033.37		853,563.62	
4.5 to 6.0 Mtr B.G.L.		m	496		1,074.63		533,016.48	
6.0 to 7.5 mtr B.G.L.		m	0		1,140.66		0.00	
7.5 to 9.0 mtr B.G.L.		m	79		1,223.19		96,632.01	
							0.00	
600 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	0		1,166.41		0.00	
1.5 to 3.0 Mtr B.G.L.		m	0		1,196.10		0.00	
3.0 to 4.5 Mtr B.G.L.		m	583		1,235.68		720,401.44	
4.5 to 6.0 Mtr B.G.L.		m	655		1,285.16		841,779.80	
							0.00	

Items	Specification	Unit	Qty	FC Portion (Yen)		LC Portion (INR)		Reference
				Unit Price	Amount	Unit Price	Amount	
700 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	0			1,368.82	0.00	
1.5 to 3.0 Mtr B.G.L.		m	0			1,403.73	0.00	
3.0 to 4.5 Mtr B.G.L.		m	114			1,450.27	165,330.78	
							0.00	
750 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	0			1,474.38	0.00	
1.5 to 3.0 Mtr B.G.L.		m	0			1,512.00	0.00	
3.0 to 4.5 Mtr B.G.L.		m	62			1,562.17	96,854.54	
4.5 to 6.0 Mtr B.G.L.		m	87			1,624.87	141,363.69	
							0.00	
800 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	0			1,582.84	0.00	
1.5 to 3.0 Mtr B.G.L.		m	0			1,623.25	0.00	
3.0 to 4.5 Mtr B.G.L.		m	0			1,677.14	0.00	
4.5 to 6.0 Mtr B.G.L.		m	233			1,744.49	406,466.17	
6.0 to 7.5 mtr B.G.L.		m	84			1,852.26	155,589.84	
							0.00	
Providing and laying RCC Bedding with 12-20mm gauge approved stone ballast, coarse sand and cement in M-15 (1:2:4) all work up to plinth level, including supply of all materials labour T&P etc. required for proper completion of work and excluding shuttering and centering with 0.4% of							0.00	
250 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	0			566.79	0.00	
1.5 to 3.0 Mtr B.G.L.		m	0			580.49	0.00	
3.0 to 4.5 Mtr B.G.L.		m	0			598.76	0.00	
4.5 to 6.0 Mtr B.G.L.		m	365			621.59	226,880.35	
6.0 to 7.5 mtr B.G.L.		m	511			658.13	336,304.43	
							0.00	
300 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	0			648.88	0.00	
1.5 to 3.0 Mtr B.G.L.		m	0			664.65	0.00	
3.0 to 4.5 Mtr B.G.L.		m	297			685.67	203,643.99	
4.5 to 6.0 Mtr B.G.L.		m	1,843			711.95	1,312,123.85	
6.0 to 7.5 mtr B.G.L.		m	490			754.00	369,460.00	
							0.00	
							0.00	
350 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	0			733.96	0.00	
1.5 to 3.0 Mtr B.G.L.		m	0			751.87	0.00	
3.0 to 4.5 Mtr B.G.L.		m	171			775.75	132,653.25	
4.5 to 6.0 Mtr B.G.L.		m	790			805.59	636,416.10	
							0.00	
400 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	0			822.04	0.00	
1.5 to 3.0 Mtr B.G.L.		m	0			842.16	0.00	
3.0 to 4.5 Mtr B.G.L.		m	57			868.98	49,531.86	
4.5 to 6.0 Mtr B.G.L.		m	836			902.52	754,506.72	
6.0 to 7.5 mtr B.G.L.		m	312			956.17	298,325.04	
							0.00	
450 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	0			935.51	0.00	
1.5 to 3.0 Mtr B.G.L.		m	0			935.51	0.00	
3.0 to 4.5 Mtr B.G.L.		m	0			965.38	0.00	
4.5 to 6.0 Mtr B.G.L.		m	247			1,002.72	247,671.84	
6.0 to 7.5 mtr B.G.L.		m	140			1,062.46	148,744.40	
7.5 to 9.0 mtr B.G.L.		m	8			1,137.14	9,097.12	
							0.00	
500 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	0			1,007.17	0.00	
1.5 to 3.0 Mtr B.G.L.		m	0			1,031.93	0.00	

Item	Specification	Unit	Qty	FC Portion (Yen)		LC Portion (INR)		Reference
				Unit Price	Amount	Unit Price	Amount	
3.0 to 4.5 Mtr B.G.L.		m	0			1,064.94	0.00	
4.5 to 6.0 Mtr B.G.L.		m	163			1,106.20	180,310.60	
6.0 to 7.5 mtr B.G.L.		m	120			1,172.23	140,667.60	
7.5 to 9.0 mtr B.G.L.		m	330				0.00	
							0.00	
600 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	0			1,204.27	0.00	
1.5 to 3.0 Mtr B.G.L.		m	0			1,233.95	0.00	
3.0 to 4.5 Mtr B.G.L.		m	0			1,273.54	0.00	
4.5 to 6.0 Mtr B.G.L.		m	29			1,323.02	38,367.58	
6.0 to 7.5 mtr B.G.L.		m	322			1,402.19	451,505.18	
7.5 to 9.0 mtr B.G.L.		m	241			1,501.15	361,777.15	
							0.00	
Providing and laying Granular bedding with carefully compacted graded hard crusher broken stone of 100% passing through 20mm sieve, 70-50% passing through 10mm sieve and 100% retained on 6mm sieve and Dimensions are as per Approved Drawing for Following							0.00	
200 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	49,464			576.10	28,496,239.21	
1.5 to 3.0 Mtr B.G.L.		m	91,724			580.34	53,230,815.99	
							0.00	
250 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	297			672.77	199,812.69	
1.5 to 3.0 Mtr B.G.L.		m	1,457			677.68	987,379.76	
							0.00	
300 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	13			777.53	10,107.89	
1.5 to 3.0 Mtr B.G.L.		m	52			783.13	40,722.76	
							0.00	
500 mm Dia Sewer Pipe							0.00	
0.0 to 1.5 Mtr B.G.L.		m	0			1,251.84	0.00	
1.5 to 3.0 Mtr B.G.L.		m	68			1,260.50	85,714.00	
							0.00	
							0.00	
							0.00	
LAYING OF R.C.C. PIPE							0.00	
Supply and carting to site RCC NP3 pipes (with s/s ends) as per IS: 458 - 2003 (Amended up to date) including all taxes (Central and Local) with Rubber gaskets (EPDM/SBR) as per IS: 5382-1985 or (Amended up to date), including cost of Rubber gaskets, labour required, transportation, loading, unloading & stacking etc (excluding cost of laying, jointing, testing and commissioning) The pipe shall be ISI							0.00	
							0.00	
a) 200 mm dia RCC pipe		m	193,293.60			588.57	113,766,512.61	
b) 250 mm dia RCC pipe		m	9,862.00			702.86	6,931,613.21	
c) 300 mm dia RCC pipe		m	4,808.00			985.45	4,738,052.25	
d) 350 mm dia RCC pipe		m	2,010			1,343	2,700,234.80	
e) 400 mm dia RCC pipe		m	2,069.00			1,617.20	3,345,986.14	
f) 450 mm dia RCC pipe		m	1,609.00			1,749.08	2,814,262.45	
g) 500 mm dia RCC pipe		m	2,081.00			2,144.70	4,463,126.69	
h) 600 mm dia RCC pipe		m	1,638.00			2,711.14	4,440,848.70	
i) 700 mm dia RCC pipe		m	84			3,305.21	277,637.63	
j) 750 mm dia RCC pipe		m	0.00			3,500.00	0.00	
k) 800 mm dia RCC pipe		m	466.00			3,977.15	1,853,351.21	
							0.00	
Lowering in trenches, aligning, laying & jointing of RCC pipes NP3 class (with s/s ends) as per IS: 458 - 1988 (Amended up to date) with Rubber gaskets (EPDM/SBR) including cost of all jointing materials, testing, commissioning etc, complete as per specifications and/or as directed by							0.00	

	Items	Specification	Unit	Qty	FC Portion (Yen)		LC Portion (INR)		Reference
					Unit Price	Amount	Unit Price	Amount	
								0.00	
	200 mm dia RCC pipe							0.00	
3198- SOR_U.P. Jal Nigam Varanasi 2014-15	0.0 to 1.5 Mtr B.G.L.		m	49,748.0			356.53	17,736,636.61	
	1.5 to 3.0 Mtr B.G.L.		m	108,015			380	40,994,369.06	
	3.0 to 4.5 Mtr B.G.L.		m	29,577			403	11,921,403.14	
	4.5 to 6.0 Mtr B.G.L.		m	5,540			431	2,385,154.41	
	6.0 to 7.5 mtr B.G.L.		m	287			469	134,748.07	
	7.5 to 9.0 mtr B.G.L.		m	0			521.07	0.00	
								0.00	
								0.00	
	250 mm dia RCC pipe							0.00	
3199- SOR_U.P. Jal Nigam Varanasi 2014-15	0.0 to 1.5 Mtr B.G.L.		m	341			371.62	126,722.42	
	1.5 to 3.0 Mtr B.G.L.		m	3,818			396	1,510,360.67	
	3.0 to 4.5 Mtr B.G.L.		m	3,457			420	1,452,342.43	
	4.5 to 6.0 Mtr B.G.L.		m	2,044.0			448.73	917,206.47	
	6.0 to 7.5 mtr B.G.L.		m	511.00			488.87	249,810.58	
	7.5 to 9.0 mtr B.G.L.		m	0			543	0.00	
								0.00	
								0.00	
								0.00	
	300 mm dia RCC pipe							0.00	
3200 SOR_U.P. Jal Nigam Varanasi 2014-15	0.0 to 1.5 Mtr B.G.L.		m	31.0			461.18	14,296.58	
	1.5 to 3.0 Mtr B.G.L.		m	433			491	212,571.01	
	3.0 to 4.5 Mtr B.G.L.		m	2,011			521	1,048,462.98	
	4.5 to 6.0 Mtr B.G.L.		m	1,843			557	1,026,320.35	
	6.0 to 7.5 mtr B.G.L.		m	490			607	297,274.32	
	7.5 to 9.0 mtr B.G.L.		m	0			674	0.00	
								0.00	
								0.00	
	350 mm dia RCC pipe							0.00	
3201 - SOR_U.P. Jal Nigam Varanasi 2014-15	0.0 to 1.5 Mtr B.G.L.		m	0			517	0.00	
	1.5 to 3.0 Mtr B.G.L.		m	616			551	339,157.71	
	3.0 to 4.5 Mtr B.G.L.		m	346			585	202,312.15	
	4.5 to 6.0 Mtr B.G.L.		m	864			625	539,605.28	
	6.0 to 7.5 mtr B.G.L.		m	202			680	137,441.39	
	7.5 to 9.0 mtr B.G.L.		m	0			756	0.00	
								0.00	
								0.00	
	400 mm dia RCC pipe							0.00	
3202 SOR_U.P. Jal Nigam Varanasi 2014-15	0.0 to 1.5 Mtr B.G.L.		m	0			562	0.00	
	1.5 to 3.0 Mtr B.G.L.		m	436			599	261,054.70	
	3.0 to 4.5 Mtr B.G.L.		m	432			636	274,696.85	
	4.5 to 6.0 Mtr B.G.L.		m	836			679	567,796.59	
	6.0 to 7.5 mtr B.G.L.		m	501			740	370,704.57	
	7.5 to 9.0 mtr B.G.L.		m	132			822	108,510.59	
								0.00	
								0.00	
	450 mm dia RCC pipe							0.00	
3203 SOR_U.P. Jal Nigam Varanasi 2014-15	0.0 to 1.5 Mtr B.G.L.		m	0			667	0.00	
	1.5 to 3.0 Mtr B.G.L.		m	148			710	105,125.72	
	3.0 to 4.5 Mtr B.G.L.		m	466			754	351,526.51	
	4.5 to 6.0 Mtr B.G.L.		m	749			806	603,490.67	
	6.0 to 7.5 mtr B.G.L.		m	140			878	122,891.12	
	7.5 to 9.0 mtr B.G.L.		m	136			975	132,629.25	
								0.00	
								0.00	
	500 mm dia RCC pipe							0.00	
3204 - SOR_U.P. Jal Nigam Varanasi 2014-15	0.0 to 1.5 Mtr B.G.L.		m	0			744	0.00	
	1.5 to 3.0 Mtr B.G.L.		m	166			792	131,496.51	

	Items	Specification	Unit	Qty	PC Portion (Yen)		LC Portion (INR)		Reference
					Unit Price	Amount	Unit Price	Amount	
	3.0 to 4.5 Mtr B.G.L.		m	826			841	694,882.06	
	4.5 to 6.0 Mtr B.G.L.		m	659			899	592,151.78	
	6.0 to 7.5 mtr B.G.L.		m	120			979	117,471.52	
	7.5 to 9.0 mtr B.G.L.		m	409			1,088	444,818.27	
								0.00	
								0.00	
	600 mm dia RCC pipe							0.00	
3205 - SOR_U.P. Jal Nigam Varanasi 2014-15	0.0 to 1.5 Mtr B.G.L.		m	0			841	0.00	
	1.5 to 3.0 Mtr B.G.L.		m	0			895	0.00	
	3.0 to 4.5 Mtr B.G.L.		m	583			950	554,129.36	
	4.5 to 6.0 Mtr B.G.L.		m	684			1,015	694,408.91	
	6.0 to 7.5 mtr B.G.L.		m	322			1,166	356,138.87	
	7.5 to 9.0 mtr B.G.L.		m	241			1,229	296,133.75	
								0.00	
				0				0.00	
	700 mm dia RCC pipe			0				0.00	
3206 - SOR_U.P. Jal Nigam Varanasi 2014-15	0.0 to 1.5 Mtr B.G.L.		m	0			920	0.00	
	1.5 to 3.0 Mtr B.G.L.		m	0			980	0.00	
	3.0 to 4.5 Mtr B.G.L.		m	114			1,050	119,706.11	
	4.5 to 6.0 Mtr B.G.L.		m	0			1,122	0.00	
	6.0 to 7.5 mtr B.G.L.		m	0			1,222	0.00	
	7.5 to 9.0 mtr B.G.L.		m	0			1,357	0.00	
								0.00	
	800 mm dia RCC pipe							0.00	
3207- SOR_U.P. Jal Nigam Varanasi 2014-15	0.0 to 1.5 Mtr B.G.L.		m	0			1,338	0.00	
	1.5 to 3.0 Mtr B.G.L.		m	0			1,425	0.00	
	3.0 to 4.5 Mtr B.G.L.		m	62			1,513	93,811.90	
	4.5 to 6.0 Mtr B.G.L.		m	320			1,616	517,169.35	
	6.0 to 7.5 mtr B.G.L.		m	84			1,761	147,899.19	
	7.5 to 9.0 mtr B.G.L.		m	0			1,956	0.00	
								0.00	
	MANHOLES IN BRICK MASONARY								
	Construction of Brick Circular Manhole in first Class Brick of following Sizes in cement mortar 1:4, C.C. top slab with 1:1.5:3, Bed concrete 1:1.5:3, PCC 1:3:6, inside and outside plastering 12 mm thick with cement mortar 1:3 finished with floating coat of neat cement and making channels in Cement concrete with 1:1.5:3, finished with Floating coat of neat cement complete with including Plastic Encapsulated M.S. foot Rest staggered at 0.375 mtr interval, including excavation, reinforcement and Formwork, SFRC							0.00	
	200 mm dia Sewer Pipe							0.00	
	0.0 to 1.5 mtr ht with 900 mm Manhole Dia		No	2,220			15,752	34,973,171.31	
	1.5 to 3.0 mtr ht with 900 mm Manhole Dia		No	4,598.500			34,397	158,174,257.07	
	3.0 to 4.5 mtr ht with 900 mm Manhole Dia		No	1,265			64,027	80,981,235.20	
	4.5 to 6.0 mtr ht with 900 mm Manhole Dia		No	238			116,838	27,807,476.95	
	6.0 to 7.5 mtr ht with 900 mm Manhole Dia		No	14			150,620	2,048,432.71	
	7.5 to 9.0 mtr ht with 900 mm Manhole Dia		No	0			274,701	0.00	
								0.00	
								0.00	
	250 mm dia Sewer Pipe							0.00	
	0.0 to 1.5 mtr ht with 900 mm Manhole Dia		No	15			15,905	238,568.09	
	1.5 to 3.0 mtr ht with 900 mm Manhole Dia		No	156			34,446	5,373,597.03	
	3.0 to 4.5 mtr ht with 900 mm Manhole Dia		No	155			63,857	9,897,795.13	
	4.5 to 6.0 mtr ht with 900 mm Manhole Dia		No	92			116,527	10,720,480.42	
	6.0 to 7.5 mtr ht with 900 mm Manhole Dia		No	20			149,852	2,997,049.03	

	Items	Specification	Unit	Qty	FC Portion (Yen)		LC Portion (INR)		Reference
					Unit Price	Amount	Unit Price	Amount	
	7.5 to 9.0 mtr ht with 900 mm Manhole Dia		No	0			273,314	0.00	
								0.00	
								0.00	
	300 mm dia Sewer Pipe							0.00	
	0.0 to 1.5 mtr ht with 900 mm Manhole Dia		No	2			16,035	32,070.19	
	1.5 to 3.0 mtr ht with 900 mm Manhole Dia		No	20			34,464	689,283.15	
	3.0 to 4.5 mtr ht with 900 mm Manhole Dia		No	83			63,647	5,282,675.08	
	4.5 to 6.0 mtr ht with 900 mm Manhole Dia		No	81.000			116,191	9,411,443.37	
	6.0 to 7.5 mtr ht with 900 mm Manhole Dia		No	24			149,057	3,577,369.82	
	7.5 to 9.0 mtr ht with 900 mm Manhole Dia		No	0			271,906	0.00	
								0.00	
								0.00	
	350 mm dia Sewer Pipe							0.00	
	0.0 to 1.5 mtr ht with 900 mm Manhole Dia		No	0			16,000	0.00	
	1.5 to 3.0 mtr ht with 900 mm Manhole Dia		No	25			34,344	858,607.22	
	3.0 to 4.5 mtr ht with 900 mm Manhole Dia		No	17			63,242	1,075,108.32	
	4.5 to 6.0 mtr ht with 900 mm Manhole Dia		No	38			115,847	4,402,180.84	
	6.0 to 7.5 mtr ht with 900 mm Manhole Dia		No	11			148,253	1,630,780.99	
	7.5 to 9.0 mtr ht with 900 mm Manhole Dia		No	0			270,496	0.00	
								0.00	
								0.00	
	400 mm dia Sewer Pipe							0.00	
	0.0 to 1.5 mtr ht with 900 mm Manhole Dia		No	0			16,106	0.00	
	1.5 to 3.0 mtr ht with 900 mm Manhole Dia		No	18			34,357	618,431.87	
	3.0 to 4.5 mtr ht with 900 mm Manhole Dia		No	23			62,967	1,448,246.13	
	4.5 to 6.0 mtr ht with 900 mm Manhole Dia		No	40			115,478	4,619,117.78	
	6.0 to 7.5 mtr ht with 900 mm Manhole Dia		No	25			147,421	3,685,519.59	
	7.5 to 9.0 mtr ht with 900 mm Manhole Dia		No	5 000			269,065	1,345,327.07	
								0.00	
								0.00	
	450 mm dia Sewer Pipe							0.00	
	0.0 to 1.5 mtr ht with 900 mm Manhole Dia		No	0			16,048	0.00	
	1.5 to 3.0 mtr ht with 900 mm Manhole Dia		No	6			34,232	205,394.84	
	3.0 to 4.5 mtr ht with 900 mm Manhole Dia		No	20			62,668	1,253,365.60	
	4.5 to 6.0 mtr ht with 900 mm Manhole Dia		No	36			115,102	4,143,655.17	
	6.0 to 7.5 mtr ht with 900 mm Manhole Dia		No	6			146,580	879,479.20	
	7.5 to 9.0 mtr ht with 900 mm Manhole Dia		No	8			267,634	2,141,069.13	
								0.00	

Items	Specification	Unit	Qty	FC Portion (Yen)		LC Portion (INR)		Reference
				Unit Price	Amount	Unit Price	Amount	
							0.00	
500 mm dia Sewer Pipe							0.00	
0.0 to 1.5 mtr ht with 900 mm Manhole Dia		No	0			16,138	0.00	
1.5 to 3.0 mtr ht with 900 mm Manhole Dia		No	7			34,203	239,420.02	
3.0 to 4.5 mtr ht with 900 mm Manhole Dia		No	34			62,338	2,119,487.64	
4.5 to 6.0 mtr ht with 900 mm Manhole Dia		No	28			114,887	3,216,842.84	
6.0 to 7.5 mtr ht with 900 mm Manhole Dia		No	5			145,912	729,559.00	
7.5 to 9.0 mtr ht with 900 mm Manhole Dia		No	17			266,398	4,528,762.91	
							0.00	
							0.00	
600 mm dia Sewer Pipe							0.00	
0.0 to 1.5 mtr ht with 900 mm Manhole Dia		No	0			16,130	0.00	
1.5 to 3.0 mtr ht with 900 mm Manhole Dia		No	6			34,001	0.00	
3.0 to 4.5 mtr ht with 900 mm Manhole Dia		No	22			61,590	1,354,971.72	
4.5 to 6.0 mtr ht with 900 mm Manhole Dia		No	29			114,062	3,307,789.09	
6.0 to 7.5 mtr ht with 900 mm Manhole Dia		No	14			144,148	2,018,068.75	
7.5 to 9.0 mtr ht with 900 mm Manhole Dia		No	10			263,489	2,634,887.08	
							0.00	
							0.00	
700 mm dia Sewer Pipe							0.00	
0.0 to 1.5 mtr ht with 1200 mm Manhole Dia		No	0			19,345	0.00	
1.5 to 3.0 mtr ht with 1200 mm Manhole Dia		No	0			40,541	0.00	
3.0 to 4.5 mtr ht with 1200 mm Manhole Dia		No	4			72,843	291,372.32	
4.5 to 6.0 mtr ht with 1200 mm Manhole Dia		No	0			133,285	0.00	
6.0 to 7.5 mtr ht with 900 mm Manhole Dia		No	0			170,295	0.00	
7.5 to 9.0 mtr ht with 900 mm Manhole Dia		No	0			307,000	0.00	
							0.00	
							0.00	
750 mm dia Sewer Pipe							0.00	
0.0 to 1.5 mtr ht with 1200 mm Manhole Dia		No	0.000			19,388	0.00	
1.5 to 3.0 mtr ht with 1200 mm Manhole Dia		No	0			40,483	0.00	
3.0 to 4.5 mtr ht with 1200 mm Manhole Dia		No				72,350	0.00	

	Items	Specification	Unit	Qty	FC Portion (Yen)		LC Portion (INR)		Reference
					Unit Price	Amount	Unit Price	Amount	
	4.5 to 6.0 mtr ht with 1200 mm Manhole Dia		No				132,793	0.00	
	6.0 to 7.5 mtr ht with 900 mm Manhole Dia		No				168,569	0.00	
	7.5 to 9.0 mtr ht with 900 mm Manhole Dia		No	0			303,915	0.00	
								0.00	
								0.00	
	800 mm dia Sewer Pipe							0.00	
	0.0 to 1.5 mtr ht with 1200 mm Manhole Dia		No	0			19,422	0.00	
	1.5 to 3.0 mtr ht with 1200 mm Manhole Dia		No	0			40,445	0.00	
	3.0 to 4.5 mtr ht with 1200 mm Manhole Dia		No	4			71,823	287,292.37	
	4.5 to 6.0 mtr ht with 1200 mm Manhole Dia		No	15			132,285	1,984,268.04	
	6.0 to 7.5 mtr ht with 900 mm Manhole Dia		No	4			168,270	673,078.48	
	7.5 to 9.0 mtr ht with 900 mm Manhole Dia		No	0			303,814	0.00	
								0.00	
	Providing uPVC drop connection for 60 cm drop from invert level of lateral/branch sewer line to maximum water line of main sewer in manhole including inspection and cleaning eye with chain and lid, drop pipe and bends, tees, encased all around with cement concrete 1:2:4 with all centering and shuttering required, cutting holes in wall and making good with brickwork in cement mortar 1:4, plastered with cement mortar 1:3 on inside of the manhole wall, stiff cement mortar 1:1 joints between uPVC (S/S) and RCC pipe (S/S), making required channels		Nos	100			7,208	720,800.00	
								0.00	
								0.00	
	Additional cost for Manhole Cover for Providing of SFRC Extra HD 35 on Major roads instead of SFRC HD 20		No	2,622			218	572,644.80	
								0.00	
	HOUSE CONNECTING CHAMBER							0.00	
	Construction of road side inspection chamber for multiple property connections including excavation with clear opening of 600x400mm and upto the depth of 900mm in all types of soil with 230 mm thick brick masonry (first class brick) in CM (1:4), 100 mm thick PCC of M15 in foundation. 12mm thick inside and outside plastering with CM (1:3), finished with PCC M15 flooring of 75mm thick as per drawings, including covering of chamber by supplying and fixing SFRC frame and cover as per IS 12592 (Part I and II) including fixing 2 Nos. 110 OD uPVC pipe pieces and plugging the same and providing, laying one no. 150mm RCC NP2 pipe from road side chamber to manhole of required length including granular bedding and cost of materials, labour required, cost of specials, etc., complete as per drawing and directed by Employer's Representative.		unit	4,902			68,760	337,036,833.78	
								0.00	
	BARRICADING							0.00	
16.81 - DSR_2014	Providing and erecting 2.00 metre high temporary barricading at site as per		m	5,000			1,467	7,335,000.00	
								0.00	

	Items	Specification	Unit	Qty	P.C Portion (Yen)		L.C Portion (INR)		Reference
					Unit Price	Amount	Unit Price	Amount	
	Similar project exp	Supply of all material, labour and T&P to provide the barricading along trench during excavation and laying of pipe with eucalyptus ballies of 100mm dia in horizontal section in two rows and vertical post of 125 mm dia at 2 m C/C fastened with Naryal rope including provision of caution board. (50% of	m	8,000			440	3,520,800.00	
								0.00	
								0.00	
		DESILTING OF SEWER PIPE							
	Schedule of rates from Institute of Trenchless Technology 2014_17	Desilting the existing old sewer lines through jetting and suction machines including cleaning, barricading and reconstruction of manholes for section isolation by plugging and flow stoppage, setting up the over-pumping arrangements, traffic management, jetting and dislodging of accumulated silt from the pipelines, removal of silt through suction hose, disposal of removed silt from upto a distance of 20 km, necessary temporary repairs of sewers to stop locational collapses, ingress of ground water in desilted section of the pipelines all complete as per the instructions of the Employer's	m'	95			5,167	491,051.36	
								0.00	
								0.00	
		REPAIRS/REHABILITATION OF EXISTING MANHOLE							
		Refurbishment of existing brick masonry manhole in cement mortar 1:4, inside plastering 12mm thick with cement mortar 1:3 finished with floating coat of neat cement and making channels in cement concrete with 1:2:4, finished with floating coat of neat cement complete with including CI steps (PVC encapsulated) staggered at 0.3 m interval including CI frame and	Nos	88			15,201	1,335,063.08	
								0.00	
								0.00	
		DISMANTELING OF EXISTING SEWERS							
		Excavation by manually or mechanically up to following depths below G.L. for taking out of old sewer line, in ordinary soil (earth, sand, loam & clay) including refilling of trenches in 15cm layer watering and ramming the same including supply of required earth to achieve the existing road level excluding of dismantling of old existing sewer line including supply all material, labour and T&P etc to complete the						0.00	
	3001 - SOR_U.P. Jal Nigam Varanasi 2014-15	a) 0.0 to 1.5 mtr B.G.L.	m3				185	0.00	
	3002 - SOR_U.P. Jal Nigam Varanasi 2014-15	a) 1.5 to 3.0 mtr B.G.L.	m3	4,056			232	940,906.01	
	3003 - SOR_U.P. Jal Nigam Varanasi 2014-15	b) 3.0 to 4.5 mtr B.G.L.	m3	1,799			291	524,118.23	
		Dismantling of old existing sewer including taking out the same from the trench removal and stacking properly at site, as per direction of Engineer-in-charge of following sizes						0.00	
	3117-i- SOR_U.P. Jal Nigam Varanasi 2015-16	250 mm dia	m				245	0.00	
	3118-i- SOR_U.P. Jal Nigam Varanasi 2015-16	300 mm dia	m	795			294	233,465.33	
	3119-i- SOR_U.P. Jal Nigam Varanasi 2015-16	400 mm dia	m				445	0.00	
	3122i- SOR_U.P. Jal Nigam Varanasi 2015-16	500 mm dia	m	664			501	332,360.80	
								0.00	
	3128- SOR_U.P. Jal Nigam Varanasi 2014-15	1200 mm dia	m					0.00	
		Supply of all labour, equipment and T&P for diversion of flow during dismantling work and transportation of dismantled old sewer pipe upto the required site as directed by the Engineer-in-charge.	LS	1			200,000	200,000.00	
								0.00	
		TRANSFER OF EXISTING HOUSE CONNECTIONS TO SEWERS						0.00	

2. District II (Varanasi)

1 INR(India Rupee)= 1.57 JPY
 1 US\$= 105.5 JPY

Summary - Varanasi District 2

Items	Specification	Unit	Qty	EC Portion (Yen)		LC Portion (INR)		Reference
				Unit	Amount	Unit	Amount	
Varanasi District 2		LS	1				4,161,128.431	
Cost of sewer cleaning equipments, Flushing Van		LS	1				4,055,000.00	
Hiring of Godown and Site Office		LS	1				1,020,000.00	
Communication & Public Outreach		LS	1				3,500,000.00	
Environmental and Management Plan		LS	1				1,000,000.00	
Governance and Accountability Action Plan (GAAP)		LS	1				2,000,000.00	
Total							4,172,703.431	

	Items	Specification	Unit	Qty	P.C Portion (Yen)		I.C Portion (INR)		Reference
					Unit Price	Amount	Unit Price	Amount	
<Civil/Building work>									
	1. Sewer work								
	1.1 DISMANTLING AND REINSTATEMENT OF EXISTING ROADS								
	DISMANTLING WORK								
	Dismantling manually / by mechanical means including stacking of serviceable material and disposal of unserviceable material within 50 metres lead as per direction of Engineer-in-Charge								
15.43.2 - DSR_2014	a) Bitumen Road		m ²	36,231.09			159.05	5,762,554.69	
1266 - SOR_U.P. Jal Nigam Varanasi 2015-16	b) Cement Concrete Road		m ²	13,988.64			1,013.71	14,180,421.67	
16.83 - DSR_2014	Taking out existing CC interlocking paver blocks from footpath/ central verge, including removal of rubbish etc., disposal of unserviceable material to the dumping ground, for which payment shall be made separately and stacking of serviceable material within 50 metre lead as per direction of								
	REINSTATEMENT WORK								
UP PWD 2013	Reinstatement of Existing Bitumen Road - Owned by Nagar Nigam								
	Providing all Materials, Labours, T & P etc & construct 100mm thick (1:2:4) Cement Concrete Road for Reinstatement of patch & trench cuts in cement concrete Roads								
1323 - SOR_U.P. Jal Nigam Varanasi 2015-16	Providing and laying 60 mm thick factory made cement concrete interlocking paver block of M-30 grade made by block making machine with strong vibratory compaction of approved size, design & shape, laid in required colour and pattern over and including 50 mm thick compacted bed of coarse sand, filling the joints with fine sand etc. all complete as per the								
	Laying old cement concrete interlocking paver blocks of any design/shape laid in required line, level, curvature, colour and pattern over and including 50 mm thick compacted bed of coarse sand, filling the joints with fine sand etc. all complete as per the direction of Engineer-in-charge (Old CC paver blocks shall be supplied by the								
16.68 - DSR_2014									
	Total								
16.84 - DSR_2014									
	1.2 EARTH WORK (SEWER)								
	Excavation by manually or mechanically up to following depths below G.L. for laying sewer line, in ordinary soil (earth, sand, loam & clay) including cutting of joints pits ramming dressing, leveling by manually or mechanically, refilling of trenches in 15cm layer watering and ramming the same including removal of surplus earth or other dismantled material up to a distance of 50m from the centre of trenches. (Excavation for Manhole is								
3001 - SOR_U.P. Jal Nigam Varanasi 2015-16	0.0 to 1.5 mtr B.G.L								
3002 - SOR_U.P. Jal Nigam Varanasi 2015-16	1.5 to 3.0 mtr B.G.L								
3003 - SOR_U.P. Jal Nigam Varanasi 2015-16	3.0 to 4.5 mtr B.G.L								
3004 - SOR_U.P. Jal Nigam Varanasi 2015-16	4.5 to 6.0 mtr B.G.L								
3005 - SOR_U.P. Jal Nigam Varanasi 2015-16	6.0 to 7.5 mtr B.G.L								
3006 - SOR_U.P. Jal Nigam Varanasi 2015-16	7.5 to 9.0 mtr B.G.L								
3006 i - SOR_U.P. Jal Nigam Varanasi 2015-16	9.0 to 10.5 mtr B.G.L								

	Items	Specification	Unit	Qty	FC Portion (Yen)		LC Portion (INR)		Reference
					Unit Price	Amount	Unit Price	Amount	
	Disposal of excavated excess earth away from the site including conveyance of material up to an average lead for 5km & above away from the site and corresponding required lift, loading, unloading etc complete as directed by the engineer-in-charge (The quantity is net quantity								
		By Mechanical Transport including loading , unloading and stacking (Lead upto 5 Km away from the site)	m ³	34,210.69			366.10	12,524,533.51	
	Filling available excavated earth (excluding rock) in trenches, plinth, sides of foundations etc. in layers not exceeding 20 cm in depth, consolidating each deposited layer by ramming and watering, lead up to 50 m								
1003 - SOR_U.P. Jal Nigam Varanasi 2014-15		0.0 to 1.5 mtr B.G.L	m ³	62,505.00			42.39	2,649,586.95	
1003 & 1006-SOR_U.P. Jal Nigam		1.5 to 3.0 mtr B.G.L	m ³	102,240.00			2,247.07	229,740,436.80	
1003 & 1006-SOR_U.P. Jal Nigam		3.0 to 4.5 mtr B.G.L	m ³	53,477.00			2,266.04	121,181,021.08	
1003 & 1006-SOR_U.P. Jal Nigam		4.5 to 6.0 mtr B.G.L	m ³	11,603.50			2,285.01	26,514,113.54	
1003 & 1006 - SOR - U.P. Jal Nigam Varanasi 2014-15 and		6.0 to 9.0 mtr B.G.L	m ³	6,129.50			2,764.78	16,946,694.49	
	Disposal of Road Cutting Rubbish / Malba / similar unserviceable, dismantled or waste material by mechanical means , including loading ,transportation , unloading to approved municipal dumping ground or as approved by Engineer - in charge, for 5km initial lead, for all leads including		m ³	39,183.00			292.85	11,474,742.87	
	Carting of excavated earth to identified place and recarting the same where sufficient width of road is not available for stacking of excavated earth average lead 500 mtr		m ³	75,095.93			158.00	11,865,157.17	
	Bailing out or pumping out water / liquid mud during trench excavation. This includes providing necessary fuel, labour T&P etc. required for proper running of well point equipment of required capacity for lowering the water table during excavation and laying of		m	26,818.52			598.35	16,046,858.45	
	Total							633,196,303.07	
	1.3 TRENCHLESS								
	Supply of precast RCC NP4 jacking pipes manufactured by centrifugal spinning or vertical casting comply to BSEN 5911, pt 120 or EN 1916 2002 and also meet the basic concrete testing requirements specified in IS 458, IS 3597 of 1966 and IS 7596 1998 Including supply of suitable couplings (normally Built in Type collar) made of weldable structural stainless steel conforming to BS 4360 Grade 43, or relevant Code including supply of suitable rubber rings confirming to EN 681-1 as prescribed in BSEN 1916 or								
	Pipe material	PRR NC4							
	200 mm dia. pipe		m	332.00			12,066.11	4,005,949.45	
	300 mm dia pipe.		m	269.00			13,406.79	3,606,427.05	
	350 mm dia pipe		m	145.00			14,077.13	2,041,184.08	
	400 mm dia pipe		m	499.00			14,747.47	7,358,988.13	
	450 mm dia pipe		m	311.00			15,417.81	4,794,939.16	
	500 mm dia pipe		m	540.00			16,088.15	8,687,601.22	
	600 mm dia pipe		m	368.00			18,099.17	6,660,494.27	
	700 mm dia pipe		m	90.00			20,110.19	1,809,916.92	
	800 mm dia pipe		m	439.00			24,450.00	10,733,550.00	
	900 mm dia pipe		m	918.00			26,813.58	24,614,870.11	

	Items	Specification	Unit	Qty	PC Portion (Yen)		LC Portion (INR)		Reference
					Unit Price	Amount	Unit Price	Amount	
Schedule of rates from Institute of trenchless Tehnology 2014_2 X 2	Installation of product pipe by Trenchless Technology including making of entry and exit pits all related civil works like excavation, shoring/shuttering etc. and Ground to protect any existing utilities at the pipe installation location and restoration of								
	upto 300 mm dia		m	601.00			48,200.00	28,968,200.00	
	300 to 450 mm dia		m	955.00			53,600.00	50,615,000.00	
	450 to 600 mm dia		m	908.00			58,300.00	52,946,400.00	
	600 to 900 mm dia		m	1,447.00			74,500.00	107,801,500.00	
	Total							314,635,020.39	
	1.4 TIMBERING WORK								
3041 - SOR_U.P. Jal Nigam Varanasi_2015-16	Providing and fixing open timbering in trenches up to 3m deep, consisting of 40mm thick approved country wood plank for poling board, 125x75mm Indian Sal wood wales and 100mm diameter Sal wood ballies for shuttering at 1.50m c/c including removal after laying of sewers. (Measurement to be taken of the face area timbered)	1.5 to 3.0 mtr B.G.L.	m ²	649,591.42			393.91	255,880,556.14	
3032 - SOR_U.P. Jal Nigam Varanasi_2015-16	Providing and fixing close timbering in trenches for the following depths below G.L. consisting of 40mm thick approved country wood plank for poling board 125x75mm Indian Sal wood wales and 100mm diameter Sal wood ballies for shuttering at 1.50m c/c including removal after laying of sewers (Measurement to be taken of the	3.0 to 4.5 mtr B.G.L.	m ²	52,844.40			649.06	34,299,122.28	
3033-SOR_U.P. Jal Nigam Varanasi_2015-16		4.5 to 6.0 mtr B.G.L.	m ²	20,670.44			811.40	16,771,994.67	
3034-SOR_U.P. Jal Nigam Varanasi_2015-16		6.0 to 7.5 mtr B.G.L.	m ²	12,218.52			935.01	11,424,442.99	
3034-SOR_U.P. Jal Nigam Varanasi_2015-16		7.5 to 9.0 mtr B.G.L.	m ²	2,712.37			935.01	2,536,092.07	
3034-SOR_U.P. Jal Nigam Varanasi_2015-16		9.0 to 10.5 mtr B.G.L.	m ²	457.54			935.01	427,800.83	
3047 - SOR_U.P. Jal Nigam Varanasi_2015-16	Extra for planking and strutting in open timbering if required to be left permanently in position (Face area of the timber permanently left to be	0.0 to 3.0 mtr B.G.L.	m ²	12,991.83			899.99	11,692,515.64	
3039 - SOR_U.P. Jal Nigam Varanasi_2015-16	Extra for planking and strutting in close timbering if required to be left permanently in position (Face area of the timber permanently left to be	b) 3.0 to 6.0 mtr B.G.L.	m ²	2,308.38			1,879.93	4,339,586.98	
3040 - SOR_U.P. Jal Nigam Varanasi_2015-16		a) 6.0 to 9.0 mtr B.G.L.	m ²	447.93			2,114.32	947,060.62	
	Total							338,319,172.22	
	1.5 BEDDING WORK								
	PCC Bedding								
	200mm	0.0 to 1.5 Mtr B.G.L.	m	15			472.76	7,233.23	
		1.5 to 3.0 Mtr B.G.L.	m	19,704			484.47	9,545,924.21	
		3.0 to 4.5 Mtr B.G.L.	m	23,264			500.08	11,633,686.09	
		4.5 to 6.0 Mtr B.G.L.	m	2,430			519.59	1,262,681.64	
		6.0 to 7.5 mtr B.G.L.	m	29			550.81	15,918.41	
	250mm	1.5 to 3.0 Mtr B.G.L.	m	3,051			563.02	1,717,774.02	
		3.0 to 4.5 Mtr B.G.L.	m	4,047			581.29	2,352,480.63	
		4.5 to 6.0 Mtr B.G.L.	m	1,347			604.12	813,749.64	
	300mm	0.0 to 1.5 Mtr B.G.L.	m	150			628.77	94,315.50	
		1.5 to 3.0 Mtr B.G.L.	m	1,370			644.54	883,019.80	
		3.0 to 4.5 Mtr B.G.L.	m	2,952			665.56	1,964,733.12	
	350mm	1.5 to 3.0 Mtr B.G.L.	m	566			729.03	412,630.98	
		3.0 to 4.5 Mtr B.G.L.	m	490			752.91	368,925.90	
		4.5 to 6.0 Mtr B.G.L.	m	43			782.76	33,658.68	
	400mm	1.5 to 3.0 Mtr B.G.L.	m	254			816.50	207,391.00	
		3.0 to 4.5 Mtr B.G.L.	m	1,493			843.33	1,259,091.69	
	450mm	1.5 to 3.0 Mtr B.G.L.	m	67			906.94	60,764.98	
		3.0 to 4.5 Mtr B.G.L.	m	699			936.81	654,830.19	

	Items	Specification	Unit	Qty	FC Portion (Yen)		LC Portion (INR)		Reference
					Unit Price	Amount	Unit Price	Amount	
		4.5 to 6.0 Mtr B.G.L	m	179			974.15	174,372.85	
		7.5 to 9.0 mtr B.G.L	m	148			1,108.57	164,068.36	
		9.0 to 10.5 mtr B.G.L	m	50			1,183.25	59,162.50	
	500mm	1.5 to 3.0 Mtr B.G.L	m	87			1,000.35	87,030.45	
		3.0 to 4.5 Mtr B.G.L	m	117			1,033.37	120,904.29	
		4.5 to 6.0 Mtr B.G.L	m	113			1,074.63	121,433.19	
		7.5 to 9.0 mtr B.G.L	m	243			1,223.19	297,235.17	
		9.0 to 10.5 mtr B.G.L	m	326			1,305.72	425,664.72	
	600mm	4.5 to 6.0 Mtr B.G.L	m	276			1,285.16	354,704.16	
	900mm	6.0 to 7.5 mtr B.G.L	m	171			2,116.51	361,923.21	
	RCC Bedding								
	250mm	4.5 to 6.0 Mtr B.G.L	m	105			621.59	65,266.95	
	300mm	3.0 to 4.5 Mtr B.G.L	m	178			685.67	122,049.26	
		4.5 to 6.0 Mtr B.G.L	m	1,051			711.95	748,259.45	
		6.0 to 7.5 mtr B.G.L	m	288			754.00	217,152.00	
	350mm	3.0 to 4.5 Mtr B.G.L	m	753			775.75	584,139.75	
		4.5 to 6.0 Mtr B.G.L	m	1,193			805.59	961,068.87	
	400mm	3.0 to 4.5 Mtr B.G.L	m	170			868.98	147,726.60	
		4.5 to 6.0 Mtr B.G.L	m	1,811			902.52	1,634,463.72	
		6.0 to 7.5 mtr B.G.L	m	161			956.17	153,943.37	
	450mm	4.5 to 6.0 Mtr B.G.L	m	1,011			1,002.72	1,013,749.92	
		6.0 to 7.5 mtr B.G.L	m	273			1,062.46	290,051.58	
	500mm	4.5 to 6.0 Mtr B.G.L	m	1,100			1,106.20	1,216,820.00	
		6.0 to 7.5 mtr B.G.L	m	502			1,172.23	588,459.46	
	600mm	6.0 to 7.5 mtr B.G.L	m	776			1,402.19	1,088,099.44	
		7.5 to 9.0 mtr B.G.L	m	314			1,501.15	471,361.10	
	700mm	6.0 to 7.5 mtr B.G.L	m	1,723			1,646.04	2,836,126.92	
		7.5 to 9.0 mtr B.G.L	m	201			1,762.39	354,240.39	
	800mm	6.0 to 7.5 mtr B.G.L	m	413			1,903.79	786,265.27	
		7.5 to 9.0 mtr B.G.L	m	157			2,038.50	320,044.50	
	900mm	6.0 to 7.5 mtr B.G.L	m	345			2,175.44	750,526.80	
		7.5 to 9.0 mtr B.G.L	m	728			2,329.47	1,695,854.16	
	Granular Bedding								
	200mm	0.0 to 1.5 Mtr B.G.L	m	68,584			576.10	39,511,213.60	
		1.5 to 3.0 Mtr B.G.L	m	122,664			580.34	71,187,028.88	
	250mm	0.0 to 1.5 Mtr B.G.L	m	445			672.77	299,382.65	
		1.5 to 3.0 Mtr B.G.L	m	2,067			677.68	1,400,764.56	
	300mm	0.0 to 1.5 Mtr B.G.L	m	29			777.53	22,548.37	
	500mm	1.5 to 3.0 Mtr B.G.L	m	387			1,260.50	487,813.50	
	Total								
								164,409,729.68	
	1.6 LAYING OF R.C.C. PIPE								
	Pipe Material								
	200 mm dia RCC pipe		m	236,690			588.57	139,308,352.35	
	250 mm dia RCC pipe		m	11,062			702.86	7,775,046.17	
	300 mm dia RCC pipe		m	6,018			985.45	5,930,448.93	
	350 mm dia RCC pipe		m	3,788			1,343.40	5,088,800.72	
	400 mm dia RCC pipe		m	4,132			1,617.20	6,682,269.08	
	450 mm dia RCC pipe		m	2,427			1,749.08	4,245,006.19	
	500 mm dia RCC pipe		m	2,875			2,144.70	6,166,020.78	
	600 mm dia RCC pipe		m	1,366			2,711.14	3,703,418.39	
	700 mm dia RCC pipe		m	1,924			3,305.21	6,359,223.89	
	800 mm dia RCC pipe		m	570			3,977.15	2,266,974.66	
	900 mm dia RCC pipe		m	1,244			4,873.90	6,063,136.53	
	Pipe installation								
3198- SOR_U.P. Jal Nigam Varanasi 2014-15	200 mm	0.0 to 1.5 Mtr B.G.L	m	68,671			356.53	24,483,146.84	
		1.5 to 3.0 Mtr B.G.L	m	142,297			379.53	54,005,361.64	
		3.0 to 4.5 Mtr B.G.L	m	23,264			403.06	9,376,580.82	
		4.5 to 6.0 Mtr B.G.L	m	2,430			430.51	1,046,203.82	
		6.0 to 7.5 mtr B.G.L	m	29			469.02	13,554.54	

	Items	Specification	Unit	Qty	FC Portion (Yen)		I.C Portion (INR)		Reference
					Unit Price	Amount	Unit Price	Amount	
		6.0 to 7.5 mtr ht	pc	11			149,057.08	1,639,627.83	
	350mm, MH Dia. 900mm	1.5 to 3.0 mtr ht	pc	22			34,344.29	755,574.35	
		3.0 to 4.5 mtr ht	pc	53			63,241.67	3,351,808.31	
		4.5 to 6.0 mtr ht	pc	52			115,846.86	6,024,036.94	
		6.0 to 7.5 mtr ht	pc	28			148,252.82	4,151,078.88	
		7.5 to 9.0 mtr ht	pc	2			270,496.26	540,992.52	
	400mm, MH Dia. 900mm	1.5 to 3.0 mtr ht	pc	10			34,357.33	343,573.26	
		3.0 to 4.5 mtr ht	pc	69			62,967.22	4,344,738.39	
		4.5 to 6.0 mtr ht	pc	81			115,477.94	9,353,713.51	
		6.0 to 7.5 mtr ht	pc	7			147,420.78	1,031,945.49	
		7.5 to 9.0 mtr ht	pc	10			269,065.41	2,690,654.13	
	450mm, MH Dia. 900mm	1.5 to 3.0 mtr ht	pc	3			34,232.47	102,697.42	
		3.0 to 4.5 mtr ht	pc	27			62,668.28	1,692,043.57	
		4.5 to 6.0 mtr ht	pc	51			115,101.53	5,870,178.16	
		6.0 to 7.5 mtr ht	pc	13			146,579.87	1,905,538.27	
		7.5 to 9.0 mtr ht	pc	7			267,633.64	1,873,435.49	
		9.0 to 10.5 mtr ht	pc	2			339,782.59	679,565.19	
	500mm, MH Dia. 900mm	1.5 to 3.0 mtr ht	pc	21			34,202.86	718,260.07	
		3.0 to 4.5 mtr ht	pc	6			62,337.87	374,027.23	
		4.5 to 6.0 mtr ht	pc	47			114,887.24	5,399,700.48	
		6.0 to 7.5 mtr ht	pc	22			145,911.80	3,210,059.59	
		7.5 to 9.0 mtr ht	pc	9			266,397.82	2,397,580.36	
		9.0 to 10.5 mtr ht	pc	15			338,388.56	5,075,828.39	
	600mm, MH Dia. 900mm	4.5 to 6.0 mtr ht	pc	14			114,061.69	1,596,863.70	
		6.0 to 7.5 mtr ht	pc	37			144,147.77	5,333,467.40	
		7.5 to 9.0 mtr ht	pc	12			263,488.71	3,161,864.50	
	700mm, MH Dia. 900mm	6.0 to 7.5 mtr ht	pc	18			168,269.62	3,028,853.14	
		7.5 to 9.0 mtr ht	pc	6			303,813.56	1,822,881.39	
	800mm, MH Dia. 1200mm	6.0 to 7.5 mtr ht	pc	18			168,269.62	3,028,853.14	
		7.5 to 9.0 mtr ht	pc	6			303,813.56	1,822,881.39	
	900mm, MH Dia. 1200mm	6.0 to 7.5 mtr ht	pc	19			166,352.40	3,160,695.59	
		7.5 to 9.0 mtr ht	pc	28			300,779.65	8,421,831.09	
	uPVC drop connection		No	100			7,208.00	720,800.00	
	MH cover Installation		No	3,151			218.40	688,117.25	
	Total							459,333,727.49	
	3. HOUSE CONNECTING CHAMBER								
	inspection chamber installation		No.	17,108			68,760.00	1,176,315,708	
	4. BARRICADING								
	temporary barricading		m	2,000			1,467.00	2,934,000	
	barricade installation		m	8,000			440.10	3,520,800	
	total							6,454,800	
	5. DESILTING OF SEWER PIPE								
	desilting work		m ³	278			5,167.00	1,438,875	
	6. REPAIRS/REHABILITATION OF EXISTING MANHOLE								
	Repiar and rehabilitation of exsting MH		No.	24			15,200.61	364,814.53	
	7. DISMANTELING OF EXISTING SEWERS								
	excavation	1.5 to 3.0 mtr B.G.L	m ³	40,127			231.98	9,308,733.37	
		3.0 to 4.5 mtr B.G.L	m ³	2,203			291.27	641,799.46	
	dismantling pipe work	250 mm dia	m	3,850			244.60	941,763.81	
		300 mm dia	m	3,451			293.56	1,013,181.24	
		400 mm dia	m	567			445.09	252,152.39	
		600 mm dia	m	813			500.83	407,305.01	

