

## Supporting Report 12.2.3

### STP Process Calculation Sample Flow < 10 MLD

\* Note: All the STP calculations are compiled in the soft copy.

Kindly refer to the data file.

A-1 Process Cal\_ EA&al 7MLD Jakkur STP\_Supporting 12.2.3

**Design Condition**

Item	7MLD STP-TSPS			
(1) Design Flow for the year 2049	Flow Rate			
		m3/d	m3/h	m3/s
	Daily Average	11,000	458	0.127
	Daily Maximum	11,000	458	0.127
	Hourly Max. Peak factor 2.25	24,750	1031	0.286
(1) Design Flow for the year 2034	Flow Rate			
		m3/d	m3/h	m3/s
	Daily Average	7,000	292	0.081
	Daily Maximum	7,000	292	0.081
	Hourly Max. Peak factor 2.25	15,750	656	0.182

**1. Inlet Chamber**

Item	7MLD STP-TSPS			
[1] Design Condition				
(1) Design Flow for the year 2049	Hourly Maximum	=	24,750	m3/d
		=	0.286	m3/sec
(2) Inlet Pipe				
Pipe Diameter	·	×		
Gradient		%		
Roughness Coefficient	n=	0.013	(Manning Formula)	
Full Pipe Flow Rate		m3/s		
(3) Influent Water Level	+	m		
[2] Geometory				
(1) Number of Basins	1	Basin		
(2) Depth of Basin	0.600	m	Approx.	
(3) Width of Basin	2.100	m	Approx.	
(4) Length of Basin	2.500	m	Approx.	
(5) Volume required of Basin	0.600	×	2.100	×
			2.500	= 0.5 m3
(6) Retention Time	0.600	×	2.100	×
			2.500	∕ 0.286 × 1
	=	11.01	sec	
(7) Basin Demensions	Width	2.100	m	×
				Length 2.500 m
	×	Depth	0.600	m

A-1 Process Cal\_EA&amp;al 7MLD Jakkur STP\_Supporting 12.2.3

**2. Coarse Screen Channel**

Item	7MLD STP-TSPS					
[1] Geometry						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Width	0.400	m				
Height	0.600	m				
Floor Level	+	5.000	m			
Bottom	+	0.000	m			
Influent Water Level	+	0.500	m			
Velocity	0.286	/	0.400	/	0.500	/ 2
where Design Flow for the year 2049	=	0.715	<	1.000	m/sec	OK
Velocity	0.182	/	0.400	/	0.500	/ 1
where Design Flow for the year 2034	=	0.910	<	1.000	m/sec	OK
(2) Screen Channel						
Number	2.0	Main	+	1.0	Bypass	
Width	0.800	m				
Side Water Depth	0.600	m				
Velocity	0.286	/	0.800	/	0.600	/ 2
where Design Flow for the year 2049	=	0.298	≐	0.450	m/sec	OK
Velocity	0.182	/	0.800	/	0.600	/ 1
where Design Flow for the year 2034	=	0.379	<	0.450	m/sec	OK
(3) Channel Dimensions	Width	0.8	m	×	Length	6.0 m
	×	SWD	0.6	m		
[3] Equipment						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Dimension	Width	0.4	m	×	Height	0.60 m
Design Water Level		m				
(2) Coarse Screens (Main Channel)						
Number	2	W	+	0	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	0.8	m				
Width of side plate	50	mm				
Side Water Depth	0.6	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.286	/	0.700	/	0.550	/ 2
	×	( 20	+	9 )/	20	
	=	0.539	<	0.800	m/sec	OK
Velocity through screen	0.182	/	0.700	/	0.550	/ 1
where Design Flow for the year 2034	×	( 20	+	9 )/	20	
	=	0.685	<	0.800	m/sec	OK
(3) Coarse Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	50	mm				
Bar Thickness	9	mm				
Channel Width	0.8	m				
Side Water Depth	0.6	m				
Velocity through screen	0.286	/	0.800	/	0.600	/ 2
where Design Flow for the year 2049	×	( 50	+	9 )/	50	
	=	0.352	<	0.800	m/sec	OK
Velocity through screen	0.182	/	0.800	/	0.600	/ 1
where Design Flow for the year 2034	×	( 50	+	9 )/	50	
	=	0.447	<	0.800	m/sec	OK

Coarse Screen 2/21

A-1 Process Cal\_EA&al 7MLD Jakkur STP\_Supporting 12.2.3

**3. Raw Sewage Sump**

Item	7MLD STP-TSPS			
[2] Geometory				
(1) Raw Sewage Sump				
Number	1	Basin		
Dia	9.50	m		
Pump Operating Depth	1.000	m		
Retention Time whe Design Flow for the year 2049	(	$9.50^2 \times \pi / 4$	$\times$	$1.000 / 0.286 / 60$
	=	4.13	>	3.75 min (=minimum time of one pump cycle ' OK
Retention Time whe Design Flow for the year 2034	(	$9.50^2 \times \pi / 4$	$\times$	$1.000 / 0.182 / 60$
	=	6.49	>	3.75 min (=minimum time of one pump cycle ' OK
High Water Level	+	0.000	m	
Pump Off Level	+	-1.000	m	
[3] Equipment				
(1) Sewage Pumps 1				
Number	2	W	+	1 S
Bore Diameter	200	mm		
Discharge Flow : 40% Q* 2 whe Design Flow for the year 2034	=	$0.182 \times 262$	$\Rightarrow$	$3600 \times 40.0\% Q$ 270 m3/Hr
Total Head	15.0	m		
(2) Sewage Pumps 2				
Number	1	W	+	1 S
Bore Diameter	150	mm		
Discharge Flow : 20% Q* 1 whe Design Flow for the year 2034	=	$0.182 \times 131$	$\Rightarrow$	$3600 \times 20.0\% Q$ 135 m3/Hr
Total Head	15.0	m		



A-1 Process Cal\_EA&al 7MLD Jakkur STP\_Supporting 12.2.3

Item	***-STP 7MLD																																																		
<b>1. STP Design Condition</b>																																																			
(1) Design Flow Rate	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th style="text-align: center;">m3/d</th> <th style="text-align: center;">m3/h</th> <th style="text-align: center;">m3/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td style="text-align: center;">7,000</td> <td style="text-align: center;">291.67</td> <td style="text-align: center;">0.081</td> </tr> <tr> <td>Max Daily</td> <td style="text-align: center;">7,000</td> <td style="text-align: center;">291.67</td> <td style="text-align: center;">0.081</td> </tr> <tr> <td>Max Hourly Peak factor 2.25</td> <td style="text-align: center;">15,750</td> <td style="text-align: center;">656.25</td> <td style="text-align: center;">0.182</td> </tr> </tbody> </table>											m3/d	m3/h	m3/s	Average Daily	7,000	291.67	0.081	Max Daily	7,000	291.67	0.081	Max Hourly Peak factor 2.25	15,750	656.25	0.182																									
	m3/d	m3/h	m3/s																																																
Average Daily	7,000	291.67	0.081																																																
Max Daily	7,000	291.67	0.081																																																
Max Hourly Peak factor 2.25	15,750	656.25	0.182																																																
(2) Design Water Quality	<p style="text-align: right;">Unit: mg/L</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th colspan="2">TP</th> </tr> <tr> <th>NH<sub>4</sub>-N</th> <th>Org-N</th> <th>NO<sub>x</sub>-N</th> <th>D-P</th> <th>P-P</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td style="text-align: center;">350</td> <td style="text-align: center;">800</td> <td style="text-align: center;">450</td> <td style="text-align: center;">45.5</td> <td style="text-align: center;">17.5</td> <td style="text-align: center;">7</td> <td style="text-align: center;">5</td> <td style="text-align: center;">2</td> </tr> <tr> <td>Outlet</td> <td style="text-align: center;">10</td> <td style="text-align: center;">50</td> <td style="text-align: center;">10</td> <td style="text-align: center;">1</td> <td style="text-align: center;">0</td> <td style="text-align: center;">9</td> <td style="text-align: center;">1</td> <td style="text-align: center;">1</td> </tr> <tr> <td>Removal rate</td> <td style="text-align: center;">97.1%</td> <td style="text-align: center;">93.7%</td> <td style="text-align: center;">97.8%</td> <td colspan="3" style="text-align: center;">85.7%</td> <td colspan="2" style="text-align: center;">71.4%</td> </tr> </tbody> </table>											BOD	COD	SS	T-N			TP		NH <sub>4</sub> -N	Org-N	NO <sub>x</sub> -N	D-P	P-P	Inlet	350	800	450	45.5	17.5	7	5	2	Outlet	10	50	10	1	0	9	1	1	Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%	
	BOD	COD	SS	T-N			TP																																												
				NH <sub>4</sub> -N	Org-N	NO <sub>x</sub> -N	D-P	P-P																																											
Inlet	350	800	450	45.5	17.5	7	5	2																																											
Outlet	10	50	10	1	0	9	1	1																																											
Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%																																												
<b>2. Inlet Chamber</b>																																																			
<b>[1] Design Condition</b>																																																			
(1) Design Flow Rate	Max Hourly	=	15,750	m3/day																																															
		=	0.182	m3/sec																																															
<b>[2] Geometry</b>																																																			
(1) Number of Basins	1	Basin																																																	
(2) Depth of Basin	1.500	m																																																	
(3) Width of Basin	1.700	m																																																	
(4) Length of Basin	2.000	m																																																	
(5) Volume required of Basin	1.500	×	1.700	×	2.000	=	1.3	m3																																											
(6) Retention Time	1.500	×	1.700	×	2.000	/	0.182	×	1																																										
	=	28.02	sec																																																
(7) Basin Dimensions	Width	1.700	m	×	Length	2.000	m																																												
	×	Depth	1.500	m																																															



A-1 Process Cal\_EA&al 7MLD Jakkur STP\_Supporting 12.2.3

<b>4. Grit Chamber</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Peak flow = 15,750 m <sup>3</sup> /day = 0.182 m <sup>3</sup> /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0111 m/sec = 960 m <sup>3</sup> /m <sup>2</sup> /day
(4) Average Velocity	0.3 m/sec
<b>[2] Grit Chamber</b>	
(1) Surface Area required	0.182 / 0.0111 = 16.40 m <sup>2</sup>
(2) Number of Basins	1 S + 1 W
(3) Surface Area required/Basin	16.4 / 1 = 16.40 m <sup>2</sup>
(4) Length of Basin	16.40 ^0.5 = 4.0 m → 4.5 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.182 × 60 sec / 1 = 10.9 m <sup>3</sup>
(7) Depth required	10.9 / 4.5 / 4.5 = 0.539 m
(8) Basin Dimensions	Width 4.5 m × Length 4.5 m × Depth 0.5 m (Freeboard 0.3m)
(9) Retention Time	4.5 × 4.5 × 0.5 / 0.182 × 1 = 60.00 sec
(10) Surface Overflow Rate at Peak Flow	15,750 / 4.5 / 4.5 / 1 = 777.777778 < 960 m <sup>3</sup> /m <sup>2</sup> /day
<b>[3] Parshall Flume</b>	
(1) Design Flow Rate	Q= 182.000 l/sec
(2) Throat width	W= 0.450 m
(3) Water depth Ha	Ha= ( Q / 2264 / W ) <sup>2/3</sup> Ha= 0.317 m
(4) Crest Level	+ m ≐ Minimum water level at downstream channel
(5) Water level at the crest	+ 0.317 m
(6) Channel bottom level	+ m
(7) Upstream Channel width	1.500 m
(8) SWD of Upstream Channel	0.700 m
(9) Average velocity at upstream channel	0.173 m/sec
(10) Total Length of channel	10.000 m
<b>[4] Inlet Weir Gate</b>	
(1) Number	2 Units
(2) Weir Width	0.600 m
(3) Stroke	0.450 m
(4) Overflow Height	0.400 m
(5) Overflow Height (actual)	( 0.182 / 1.840 / 0.600 / 2 ) <sup>2/3</sup> = 0.189 < 0.400 m

<b>5. Reactor</b>																																																								
<b>[1] Design Condition</b>																																																								
(1) Design Wastewater Flow	Q = 7,000 m <sup>3</sup> /day (summer) Q' = 7,000 m <sup>3</sup> /day (Winter)																																																							
(2) Design Sewage Quality																																																								
Inlet BOD	350 mg/l																																																							
Outlet BOD	10.0 mg/l																																																							
Inlet S-BOD	235 mg/l assumed as 67% of BOD																																																							
Inlet COD	800 mg/l																																																							
Inlet bCOD : S <sub>0</sub>	578 mg/l																																																							
Inlet nbCOD	223 mg/l																																																							
bCOD/BOD	1.65																																																							
Inlet S-COD : sCOD	271 mg/l																																																							
Inlet rbCOD	231 mg/l bCOD*40%																																																							
Inlet sbCOD	347 mg/l bCOD*60%																																																							
Outlet S-COD : nbsCODe	40 mg/l																																																							
Inlet nbpCOD : nbpCOD	183 mg/l =TCOD-bCOD-nbsCODe																																																							
Inlet SS	450 mg/l																																																							
Inlet VSS	383 mg/l assumed as 85% of TSS																																																							
: VSS <sub>COD</sub>	1.38 gCOD/gVSS =TCOD-sCOD/VSS																																																							
: nbVSS	131.96 gnbVSS/m <sup>3</sup> =nbpCOD/VSS <sub>COD</sub>																																																							
: iTSS	67.50 gnbVSS/m <sup>3</sup> =TSS-VSS																																																							
Inlet T-N	70 mg/l																																																							
Inlet TKN	70 mg/l																																																							
Inlet NH <sub>4</sub> -N	45.0 mg/l																																																							
Inlet T-P	7 mg/l																																																							
Inlet D-P	5 mg/l																																																							
Inlet Alkalinity as CaCO <sub>3</sub>	380 mg/l																																																							
Outlet Kjeldahl N	1.0 mg/l																																																							
Outlet NH <sub>4</sub> -N	1.0 mg/l																																																							
Outlet NO <sub>3</sub> -N	9.0 mg/l																																																							
Outlet T-P	2 mg/l																																																							
Outlet D-P	1 mg/l																																																							
(3) Water Temperature	T = 20.0 °C																																																							
(4) Safety Factor for Nitrogen	SF = 1.5																																																							
(5) Return Sludge Concentration	R <sub>s</sub> = 8,000 mg/l																																																							
(6) MLSS MLVSS	X <sub>TSS</sub> = 3,000 mg/l																																																							
(7) DO in the Reactor	2 mg/L																																																							
<b>[2] Design Value for perfect Nitrification of Nitrification Process</b>																																																								
(1) Activated sludge design kinwtic coefficients at 20°C																																																								
	<table border="1"> <thead> <tr> <th>Coefficient</th> <th>Unit</th> <th>COD oxidatio</th> <th>NH4 oxidatio</th> <th>NO2 oxidatio</th> </tr> </thead> <tbody> <tr> <td>μ<sub>max</sub></td> <td>gVSS/gVSS · d</td> <td>6.000</td> <td>0.900</td> <td>1.000</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH4</sub>, K<sub>NO2</sub></td> <td>mg/L</td> <td>8.000</td> <td>0.500</td> <td>0.200</td> </tr> <tr> <td>Y</td> <td>gVSS/g substrate oxidized</td> <td>0.450</td> <td>0.150</td> <td>0.050</td> </tr> <tr> <td>b</td> <td>gVSS/gVSS · d</td> <td>0.120</td> <td>0.170</td> <td>0.170</td> </tr> <tr> <td>fd</td> <td>unitless</td> <td>0.150</td> <td>0.150</td> <td>0.150</td> </tr> <tr> <td>K<sub>O2</sub></td> <td>mg/L</td> <td>0.200</td> <td>0.500</td> <td>0.900</td> </tr> <tr> <td>θ Value</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>μ<sub>max</sub></td> <td>unitless</td> <td>1.070</td> <td>1.072</td> <td>1.063</td> </tr> <tr> <td>b</td> <td>unitless</td> <td>1.040</td> <td>1.029</td> <td>1.029</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH4</sub>, K<sub>NO2</sub></td> <td>unitless</td> <td>1.000</td> <td>1.000</td> <td>1.000</td> </tr> </tbody> </table> <p>Wastwater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF &amp; EDDY/AECOM)</p>	Coefficient	Unit	COD oxidatio	NH4 oxidatio	NO2 oxidatio	μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000	K <sub>s</sub> , K <sub>NH4</sub> , K <sub>NO2</sub>	mg/L	8.000	0.500	0.200	Y	gVSS/g substrate oxidized	0.450	0.150	0.050	b	gVSS/gVSS · d	0.120	0.170	0.170	fd	unitless	0.150	0.150	0.150	K <sub>O2</sub>	mg/L	0.200	0.500	0.900	θ Value					μ <sub>max</sub>	unitless	1.070	1.072	1.063	b	unitless	1.040	1.029	1.029	K <sub>s</sub> , K <sub>NH4</sub> , K <sub>NO2</sub>	unitless	1.000	1.000	1.000
Coefficient	Unit	COD oxidatio	NH4 oxidatio	NO2 oxidatio																																																				
μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000																																																				
K <sub>s</sub> , K <sub>NH4</sub> , K <sub>NO2</sub>	mg/L	8.000	0.500	0.200																																																				
Y	gVSS/g substrate oxidized	0.450	0.150	0.050																																																				
b	gVSS/gVSS · d	0.120	0.170	0.170																																																				
fd	unitless	0.150	0.150	0.150																																																				
K <sub>O2</sub>	mg/L	0.200	0.500	0.900																																																				
θ Value																																																								
μ <sub>max</sub>	unitless	1.070	1.072	1.063																																																				
b	unitless	1.040	1.029	1.029																																																				
K <sub>s</sub> , K <sub>NH4</sub> , K <sub>NO2</sub>	unitless	1.000	1.000	1.000																																																				
(2) μ <sub>AOB</sub>	μ <sub>AOB</sub> = 0.3100 g/g · d = μ <sub>max, AOB</sub> [S <sub>NH4</sub> / (S <sub>NH4</sub> + K <sub>NH4</sub> )] [S <sub>O</sub> / (S <sub>O</sub> + K <sub>O, AOB</sub> )] - b <sub>AOB</sub>																																																							
μ <sub>max, AOB, T</sub>	μ <sub>max, AOB, T</sub> = 0.9000 g/g · d = μ <sub>max</sub> * 1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900																																																							
b <sub>AOB, T</sub>	b <sub>AOB, T</sub> = 0.1700 = b * 1.029 <sup>(T-20)</sup> b at 20°C = 0.170																																																							
S <sub>NH4</sub>	S <sub>NH4</sub> = 1.0000 mg/l																																																							
DO	DO = 2.0000 mg/l																																																							
K <sub>O, AOB</sub>	K <sub>O, AOB</sub> = 0.5000 mg/l																																																							

A-1 Process Cal\_EA&al 7MLD Jakkur STP\_Supporting 12.2.3

(2) Design SRT	SRT= 4.8387 day ⇒ 5.0000 day	=1/μ <sub>AOB</sub> × SF
(3) Biomass production	P <sub>X,VSS</sub> = 2188.927 kg/d P <sub>X,TSS</sub> = 2884.700 kg/d	=P <sub>X,bio</sub> +Q(nbVSS) =P <sub>X,bio</sub> /0.85+Q(nbVSS)+Q(TSS <sub>0</sub> -VSS <sub>0</sub> )+5*Q*Al
S	S= 0.4507 mg/l	=Ks[1+b <sub>H</sub> (SRT)]/[SRT(μ <sub>m</sub> -b <sub>H</sub> )-1]
b <sub>H</sub>	b <sub>H</sub> = 0.1200	=b*1.04 <sup>(T-20)</sup> b at 20°C = 0.120
Y <sub>H</sub>	Y <sub>H</sub> = 0.4500 gVSS/g bCOD	
μ <sub>m,T</sub>	μ <sub>m,T</sub> = 6.0000 g/g·d	=μ <sub>max</sub> *1.04 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 6.000
Y <sub>n</sub>	Y <sub>n</sub> = 0.150 gVSS/g Nox	
NOx	NOx= 47.400 mg/l	
P <sub>X,bio,VSS</sub>	P <sub>X,bio,VSS</sub> = 1265.214 kg VSS/d 1136.066 102.246 26.903	=Q·Y <sub>H</sub> (S <sub>0</sub> -S)/[1+b <sub>H</sub> (SRT)]+f <sub>d</sub> ·b <sub>H</sub> ·QY <sub>H</sub> (S <sub>0</sub> -S)SRT/[1+b <sub>H</sub> (SRT)] +QY <sub>n</sub> (Nox)/[2+b <sub>AOB</sub> (SRT)] =Q·Y <sub>H</sub> (S <sub>0</sub> -S)/[1+b <sub>H</sub> (SRT)] =f <sub>d</sub> ·b <sub>H</sub> ·QY <sub>H</sub> (S <sub>0</sub> -S)SRT/[1+b <sub>H</sub> (SRT)] =QY <sub>n</sub> (Nox)/[1+b <sub>AOB</sub> (SRT)]
NOx	NOx= 47.311 mg/l	=TKN-Ne-0.12P <sub>X,bio</sub> /Q
(4) Required Aeration Tank Volume	V <sub>a</sub> = 4,808 m <sup>3</sup> τ = 16.48 hr ⇒ 18.00 hr	=V <sub>a</sub> /Q × 24
X <sub>VSS</sub> ·V <sub>a</sub>	X <sub>VSS</sub> ·V <sub>a</sub> = 10,945 kg VSS	=P <sub>X,VSS</sub> ·SRT
X <sub>TSS</sub> ·V <sub>a</sub>	X <sub>TSS</sub> ·V <sub>a</sub> = 14,423 kg TSS	=P <sub>X,TSS</sub> ·SRT
F/M	F/M= 0.224 kgBOD/kgMLVSS	
Fraction VSS=	Fraction VSS= 0.759	
MLVSS=	MLVSS= 2276 mg/L	
(5) BODloading	BODloading= 0.510 kg/m <sup>3</sup> ·d	
(6) Observed Yield	Y <sub>obs,TSS</sub> = 1.178 gTSS/gBOD Y <sub>obs,VSS</sub> = 0.894 gVSS/gBOD	
bCODremoved=	bCODremov= 4,039 kg/d	
(7) effluent NO <sub>2</sub> -N	NO <sub>2</sub> -N= 0.2315 mg/l	=Ks[1+b <sub>NOB</sub> (SRT)]/[SRT(μ <sub>NOB</sub> -b <sub>NOB</sub> )-1]
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700	=b*1.029 <sup>(T-20)</sup> b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 1.0000 g/g·d	=μ <sub>max</sub> *1.04 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 1.000
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.6897 g/g·d	=μ <sub>max,NOB</sub> [S <sub>0</sub> /(S <sub>0</sub> +K <sub>O2,NOB</sub> )]
	S <sub>0</sub> = 2.000 mg/l	
	K <sub>O2,NOB</sub> = 0.900 mg/l	
(8) effluent NH <sub>4</sub> -N	NH <sub>4</sub> -N= 0.5286 mg/l	=Ks[1+b <sub>NOB</sub> (SRT)]/[SRT(μ <sub>NOB</sub> -b <sub>NOB</sub> )-1]
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700	=b*1.029 <sup>(T-20)</sup> b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 0.9000 g/g·d	=μ <sub>max</sub> *1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.7200 g/g·d	=μ <sub>max,NOB</sub> [S <sub>0</sub> /(S <sub>0</sub> +K <sub>O2,NOB</sub> )]
	S <sub>0</sub> = 2.000 mg/l	
	K <sub>O2,NOB</sub> = 0.500 mg/l	
(9) Ratio of Return Sludge	8,000*Rr/(1+Rr)= 3,000 mg/L 3,000/(8,000-3,000)= 0.60 Rr = 0.60	

<b>[3] Design for Nitrification and Denitrification Process</b>																					
(1) Active biomass concentration	$X_b = \frac{Q \cdot (SRT) \cdot V \cdot Y_H \cdot (S_0 - S)}{[1 + b_H(SRT)]}$ = 1,181.47 mg/l																				
(2) IR ratio	$IR = \frac{NO_x}{Ne - 1.0 \cdot R}$ = 3.66																				
(3) The amount of NO <sub>3</sub> -N fed to the anoxic tank	$Nox\ feed = (IR + R) \cdot Q \cdot Ne$ = 268,174.27 kg/d																				
(4) The anoxic tank volume	$V_{nor} = 481 \text{ m}^3 = V_a \times 10\%$ $V_{nor} = 1,458 \text{ m}^3 \quad \tau_{DN} = 5.000 \text{ h}$																				
(5) F/M <sub>b</sub>	F/M <sub>b</sub> = 1.42 g/g·d																				
(6) Fraction of rbCOD	40.00% = rbCOD/bCOD																				
	<table border="1"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b0</th> <th>b1</th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>	Percent rdCOD(%)	SDNR equation coefficients		b0	b1	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162
Percent rdCOD(%)	SDNR equation coefficients																				
	b0	b1																			
10	0.186	0.078																			
20	0.213	0.118																			
30	0.235	0.141																			
40	0.242	0.152																			
50	0.270	0.162																			
(8) SDNR <sub>b</sub>	$SDNR_b = 0.296 \text{ g/g} \cdot \text{d} = b_0 + b_1 [\ln(F/M_b)]$ $b_0 = 0.242$ $b_1 = 0.152$																				
(8) SDNR	$SDNR = 0.110 \text{ g/g} \cdot \text{d} = SDNR_b (MLVSS_r / MLVSS)$ $SDNR_{adj} = 0.212 \text{ g/g} \cdot \text{d} = SDNR_r - 0.029 \ln(F/M_b) - 0.012 \quad IR=3-4$ $= SDNR_r - 0.0166 \ln(F/M_b) - 0.078 \quad IR=2$ $SDNR_t = 0.296 \text{ g/g} \cdot \text{d} = SDNR_b \cdot \theta^{(F/M_b - 20)} \quad \theta = 1.026$																				
(9) NO <sub>r</sub>	$NO_r = 364,695.16 \text{ kg/d} = N_{max} \cdot SDNR \cdot X_b$ $> Nox\ feed = 268,174 \text{ kg/d}$																				
(10) Alkalinity to be added to maintain pH7	<p style="text-align: center;">-108.33 mg/l</p> $Influent\ Alk = 380.00 \text{ mg/l}$ $Alk\ used = 338.44 \text{ mg/l} = 7.14 \times Nox$ $Alk\ producec = 136.77 \text{ mg/l} = 3.57 \times (NO_x - NO_{xe})$ $Alk\ to\ maint = 70.00 \text{ mg/l}$																				
<b>[4] Design of Phosphorus Removal Process</b>																					
(1) Removal T-P	3.13 mg/l																				
P in waste sludge	px = 1.00%																				
Generated waste sludge	Px <sub>vss</sub> = 2188.927 kg/d																				
Rwmoval Phosphorus	21.88926619 kg/d																				
(2) Effluent T-P without Al	3.87 mg/l																				
(3) Required Al to initial soluble phosphorus ratio	1.00 mol/mol																				
(4) Required Al dosing rate	3.48 mg/l as Al																				
	42.98 mg/l as crystal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> · 18H <sub>2</sub> O																				
(5) Required Aluminum Sulfate	300.84 kg/d																				
(6) Required Aluminum Sulfate solutic 10%	2.87 m <sup>3</sup> /d																				
	119.38 L/H																				
(7) Additional sludge	121.96 kg/d																				



A-1 Process Cal\_EA&al 7MLD Jakkur STP\_Supporting 12.2.3

(4) Alum Solution Tank										
Number	2	W	+	0	S					
Alum concentration as crystal	10 %									
Gravity of dissolved dechlorine	1.05									
Required solution volume	300.84 kg / d		×	100	/	10	/	1.05	/	1000
	=	2.87								m3/d
Volume of Tank	2.6									m3/tank
Total Volume of Tanks	5.2					(Duration=	1.81			day)
(5) Mixer for Alum Solution Tank										
Number	2	W	+	0	S					
(6) Alum Dosing Pump										
Number	2	W	+	1	S					
Capacity	2.87 m3/d	/	24	×	1000	/	2	×	2	
	119.38 l/h/unit		⇒	120	l/h/unit					



A-1 Process Cal\_EA&a1 7MLD Jakkur STP\_Supporting 12.2.3

<b>6. Air Requirement at Average Flow</b>	
[1] Design Condition	
(1) AOR	AOR = 3,029 kg/day = 126.2 kg/h
Q <sub>in</sub> : Design Average Flow m <sup>3</sup> /d	7,000
Inlet bCOD : S <sub>0</sub>	578 mg/l
S=	S= 0.451 mg/l
No <sub>x</sub> =	No <sub>x</sub> 47.400 mg/l
P <sub>X,bio</sub> =	P <sub>X,b</sub> 1,238.3 kg VSS/d does not include nitrifying bacteria
R <sub>0</sub> =	R <sub>0</sub> = Q(S <sub>0</sub> -S-k(NO <sub>x</sub> -NO <sub>x</sub> ))-1.42P <sub>X,bio</sub> +4.57Q·NO <sub>x</sub>
R <sub>0</sub> =	R <sub>0</sub> = 3,029 kg O <sub>2</sub> /d
k=	k= 2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{AOR}{\alpha \times F} \times \frac{C_S \cdot a \times 1.024^{20-T}}{(\beta \cdot C_{SW}/C_S \cdot (P_b/P_a)a - C_A)}$
	C <sub>S</sub> : Saturated DO at sea level and 20 °C 9.09 mg/L
	C <sub>SW</sub> : Saturated DO at sea level and operating Temperature 9.09 mg/L at 20 °C
	20-T : 0.0 1.024 <sup>20-T</sup> : 1.0000
	C <sub>A</sub> : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1+0.40D <sub>j</sub> /P <sub>a</sub> 1.19357
	D <sub>j</sub> : Tank Liquid Depth 5.00 m
	P <sub>a</sub> : Standard absolute pressure at s 10.332 m
	P <sub>b</sub> : Absolute pressure at Plant Site Elevation m
	P <sub>b</sub> /P <sub>a</sub> : exp[-gM(z <sub>b</sub> -z <sub>a</sub> )/R*T] 0.900
	g : Acceleration due to Gravity 9.80665 m/s <sup>2</sup>
	M : Mole of Air 28.97 kg/kg-mole
	z <sub>b</sub> : Plant Site Elevation 900 m
	z <sub>a</sub> : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 293.15 Kelvin
	α : relative Transfer Rate to clean Water 0.65
	β : relative DO Saturation to clean Water 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{32,858}{4.2591} = 7,714.69 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Standard O <sub>2</sub> required at Field Conditions per Basin =	3,857 kg/day
(5) SOTE for the above Effective Aeration Depth	28.0 %
(6) Fraction of O <sub>2</sub> in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	15%
(9) Air required at Field Conditions per Basins	= 56,731 m <sup>3</sup> /day = 2,363.8 m <sup>3</sup> /hr
[2] Equipment	

Air Requirement at Average Flow 12/21

## A-1 Process Cal\_EA&amp;al 7MLD Jakkur STP\_Supporting 12.2.3

(1) Air Blower					
Number	4	W	+	2	S
Required Capacity	2363.8	m <sup>3</sup> /Hr·Basin	/	2	unit/Basin
	= 1181.9	m <sup>3</sup> /h	⇒	1200	m <sup>3</sup> /h /Unit
Pressure	65	kPa			
Safety Factor	10	%			
Heat capacity ratio	1.4				
Atmospheric pressure at site elevation	91.234	kPa			
Total inlet pressure	89.234	kPa			
Volume rate of flow at inlet point	22.704	m <sup>3</sup> /min			
Total discharge pressure	156.234	kPa			
Overall adiabatic efficiency	0.65				
Inlet air temperature (min.)	15	°C			
Shaft power	32.101	kW			
Rated Output of Motor	35.311	kW	⇒	37	kW

A-1 Process Cal\_ EA&al 7MLD Jakkur STP\_Supporting 12.2.3

<b>7. Final Clarifire</b>							
<b>[1] Design Condition</b>							
(1) Design Wastewater Flow	Q= 7,000 m <sup>3</sup> /day						
(2) Water Temperature	T= 20.0 °C						
(3) MLSS	Xef= 3,000 mg/l						
(4) SVI	SVI= 300						
(5) Sedimentation Velocity	$v = 4.899 \cdot 10^6 \cdot T^{(0.954)} \cdot X_{ef}^{(-1.354)} \cdot SVI^{(-0.77)}$ $= 4.899 \cdot 10^6 \cdot 20.0^{0.954} \cdot 3,000^{-1.354} \cdot 150^{-0.770}$ $= 20.7 \text{ m/day}$						
(6) Surface Overflow Rate required	$S' = v / (1.5 \cdot 1) = 20.7 / (1.5 \cdot 1.0) = 13.8 \text{ m}^3/\text{m}^2 \cdot \text{day}$ $\rightarrow 12.0 \text{ m}^3/\text{m}^2 \cdot \text{day}$						
<b>[2] Geometory</b>							
(1) Surface Area required	A = 7,000/12.0 = 583 m <sup>2</sup>						
(2) Demensions	<table style="margin-left: auto; margin-right: auto;"> <tr> <td>Diameter</td> <td>Depth</td> <td>Basin</td> </tr> <tr> <td style="text-align: center;"><b>19.5</b></td> <td style="text-align: center;"><b>3.5</b></td> <td style="text-align: center;"><b>2</b></td> </tr> </table>	Diameter	Depth	Basin	<b>19.5</b>	<b>3.5</b>	<b>2</b>
Diameter	Depth	Basin					
<b>19.5</b>	<b>3.5</b>	<b>2</b>					
(3) Actual Surface Area	S = 19.5 <sup>2</sup> * 3.14 / 4 * 2.0 = 597 m <sup>2</sup>						
(4) Surface Overflow Rate	S = 7,000/597 = 11.7 m <sup>3</sup> /m <sup>2</sup> ·day						

A-1 Process Cal\_EA&a1 7MLD Jakkur STP\_Supporting 12.2.3

<b>8. Chlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 7,000 m <sup>3</sup> /day 291.67 m <sup>3</sup> /h Peak Flow 15,750 m <sup>3</sup> /day 656.25 m <sup>3</sup> /h
(2) Contact Time	30 min
(3) Type of Chlorine	Cl <sub>2</sub> -GAS
(4) Design Chlorine Dosage Rate	10 mg/L
(5) Required Chlorine per day	Average Daily Flow / 1000 × Design Chlorine Dosage Rate = 70.0 kg/d = 2.92 kg/h
<b>[2] Chlorination Contact Tank</b>	
(1) Volume required	Average Daily Flow / 1440 × Contact Time = 145.8 m <sup>3</sup>
(2) Nos. of lanes	3 lanes
(3) Width of lane	2.00 m
(4) Length of lane	13.00 m
(5) Side Water Depth	2.00 m
(6) Nos. of Tanks	1 tank
(7) Total Width of Tank	6.80 m Approx..
(8) Average Velocity	Decant Flow / 3600 / Width / Depth = 291.67 / 3600 / 2.00 / 2.00 = 0.020 m/sec
(9) Total Volume	Width × Length × Depth × Nos. of lanes × Nos. of Tanks = 2.0 m × 13.0 m × 2.0 m × 3 × 1 = 156 m <sup>3</sup> > 145.8 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Chlorine Dosing Condition	
Operation Dosage Rate -1	DC1 10 mg/L
(2) Chlorine Cylinder	
Type	- Cylindrical Convexsd Container
Cylinder Capacity	Cc 928 kg/cylinder
Average Dosage Rate -1	q1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 70 kg/day
Maximum Dosage Rate -1	q3 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 158 kg/day
Storage day	T More than 15 days
Required Storage Capacity	EC1 D × T = 1,050 kg
Unit Number	EN1 EC1 / Cc = 1.1 cylinders
Maximum Operation Numbers	
Cl <sub>2</sub> -Gas Volatilize Rate	Vr1 #### @ 20 <sup>o</sup> C Standard temperature
Maximum Dosing Rate	DC1 10 mg/L, Q <sub>T-D</sub> × q3 × 10 <sup>-3</sup> / 24 = 6.56 kg/h
Operation Numbers	EN2 DC1 / Vr1 = 0.8sets
Number	2 W + 2 S
(3) Chlorinator	
Type	Solution Feed Vacuum Type
Number	1 W + 1 S
Operation Dosage Rate -1	Dq1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 157.5 kg/day
Required Dosage Rate	Chlorine -1 : Dq1 / (EN1 × 24) = Minimum 0.00 kg/hr Maximum 6.6 kg/hr

A-1 Process Cal\_EA&al 7MLD Jakkur STP\_Supporting 12.2.3

(4) Chlorine Booster Pump	
Type	Branchy on the water supply pipe
Water Demand	Water requiamet for mixed Chlori
Chlorinator Discharge	(kg/hr) 1.0 1.5 2.0 2.5 3.0 4.0
Water Demand	(L/min) 15 20 25 30 35 40
Chlorinator Discharge	(kg/hr) 5.0 6.0 10.0 50.0 100.0 200.0
Water Demand	(L/min) 45 50 60 300 600 1,200
Water requiamet	-
For Chlorin	Qp1 Maximum dosage ra 6.6 kg/hr therefore 60 L/min
Booster Pump Type	Single suction volute pump
Number	1 W + 1 S
<b>9. Dechlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 7,000 m <sup>3</sup> /day
(2) Contact Time	10 min
(3) Type of Dechlorine	Sodium Thiosulfate ( Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 5H <sub>2</sub> O )
(4) Free Residual Chlorine	1.0 mg/L assumed value
(5) Consumption per day	Average Daily Flow / 1000 × Free Residual Chlorine × 1.75 × 1.5 (safety factor) = 18.4 kg/d = 0.77 kg/h
<b>[2] Dechlorination Contact Tank</b>	
(1) Volume required	Average Flow Rate / 60 × Contact Time = 48.6 m <sup>3</sup>
(2) Width of lane	6.80 m
(3) Length of lane	4.00 m
(4) Side Water Depth	2.00 m
(5) Nos. of Tanks	1 tank
(6) Total Volume	Width × Length × Depth = 6.8 m × 4.0 m × 2.0 m = 54 m <sup>3</sup> > 48.6 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Dechlorine Solution Tank	
Number	1 W + 0 S
Dechlorine concentration	10 %
Gravity of dissolved dechlorine	1.10
Required solution volume	18.38 kg/d × 100 / 10 / 1.10 / 1000 = 0.17 m <sup>3</sup> /d
Volume of Tank	0.200 m <sup>3</sup> /tank (= 0.5 mW × 0.5 mL × 0.8 mH)
Total Volume of Tanks	0.200 m <sup>3</sup> (Duration= 1.20 day)
(2) Mixer for Dechlorine Solution Tank	
Number	2 W + 0 S
(3) Dechlorine Dosing Pump	
Number	1 W + 1 S
Capacity	0.38 m <sup>3</sup> /d / 24 × 1000 / 1 15.66 l/h/unit ⇒ 16 l/h/unit

A-1 Process Cal\_ EA&al 7MLD Jakkur STP\_Supporting 12.2.3

<p><b>10. Centrifuge</b>  <b>[1] Design Condition</b>                  (1) Type of Dewatering                  (2) Generated Sludge                  (3) Design Polyelectrolyte Dosage                  (4) Volume of Thickend Sludge                  (5) Consistency of Dewatered Sludge                  (6) Operation Time</p>	<p>Centrifuge                  3,038 kg/day                  Polyelectrolyte 5 kg/t-DS·day                  379.7 m<sup>3</sup>/day                  82 %                  12 hours/day (6 days per week)</p>
<p><b>[2] Volume of Centrifuges</b></p>	<p><math display="block">\frac{\text{Digested Solids}}{\text{Operation Time} \times \text{No.}} \times \text{Operation/week}</math> <math display="block">= \frac{379.7}{12 \times 2} \times \frac{7}{6} = 18.5</math> <p style="text-align: right;">→ 19 m<sup>3</sup>/hour</p> </p>
<p><b>[3] Dewatered Solids</b></p>	<p><math display="block">\text{Digested Sludge} \times (1 + \text{Injection Rate})</math> <math display="block">= 3,038 \times (1 + 0.0050)</math> <math display="block">= 3,053 \text{ kg/day}</math> </p>
<p><b>[4] Dewatered Cake Volume</b></p>	<p><math display="block">\text{Dewatered Solids} \times \frac{100}{100 - \text{Moisture Content}}</math> <math display="block">\times \frac{7}{6 \text{ days per week}}</math> <math display="block">= 3,053 \times \frac{100}{100 - 82} \times \frac{7}{6}</math> <math display="block">= 19.79 \text{ t/day}</math> <p>apparent specific gravity 1.00  <math display="block">\frac{19.79}{1.00} = 19.8 \text{ m}^3/\text{day}</math></p> </p>
<p><b>[5] Polyelectrolyte</b>                  (1) Design Polyelectrolyte Dosage                  (2) Required Polyelectrolyte                  (3) Dissolving concentration                  (4) Volume of Polyelectrolyte solution</p>	<p>Polyelectrolyte 5 kg/t-DS·day                  15.19 kg/day                  0.20 %                  7.59 m<sup>3</sup>/day</p>

A-1 Process Cal\_ EA&al 7MLD Jakkur STP\_Supporting 12.2.3

<b>[6] Equipment</b>	
(1) Centrifuge	
Capacity	19 m <sup>3</sup> /hr
Number	2 W + 1 S
(2) Centrifuge Feed Pumps	
Capacity	19 m <sup>3</sup> /hr
Number	2 W + 1 S
(3) Polyelectrolyte Dosing Pumps	
Volume of Polyelectrolyte solution	7.59 m <sup>3</sup> /day
Operation Time	12 hours/day (6 days per week)
Safety Factor	1.5
Number	2 W + 1 S
Required Capacity	7.59 m <sup>3</sup> /da × 7 / 6 / 12 / 2
	= 0.37 m <sup>3</sup> /Hr
Specification Capacity	0.37 m <sup>3</sup> /Hr × 1.5
	= 0.554 m <sup>3</sup> /Hr ⇒ 0.60 m <sup>3</sup> /Hr /Unit
(4) Polyelectrolyte dosing System	
Preparation time for solution	3 hr
Required dry polymer	15.19 kg/day × 7 / 6 / 12
	= 1.48 kg/hr
	= 4.43 kg per one batch
Feedong time per one batch	30 min
Capacity of Dry polymer Feeder	9 kg/h
Tanks Dimensions	Width 1.0 m × Length 1.5 m × Depth 1.5 m × 2
	= 4.5 m <sup>3</sup>
Retention Time of Tank	2.25 m <sup>3</sup> /tank / 0.37 m <sup>3</sup> /Hr / 2
	= 3.047 Hr > 3 Hr
Number	2 W + 0 S

A-1 Process Cal\_EA&al 7MLD Jakkur STP\_Supporting 12.2.3

<p><b>11. Centrifuge Feed Sump</b></p> <p><b>[1] Design Condition</b></p> <p>(1) Generated Thickend Sludge</p> <p>(2) Solids Consistency</p> <p>(3) Volume of Thickened Sludge</p> <p>(4) Sludge feed flow rate</p> <p>(5) Centrifuge Operation Time</p> <p><b>[2] Geometry</b></p> <p>(1) Basin Dimensions</p> <p><b>[3] Equipment</b></p> <p>(1) Mixers for Centrifuge Feed Sumps</p> <p>Required Volume</p> <p>Number</p>	<p>3,038 kg/day</p> <p>0.80 %</p> $\text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3}$ $= 3,038 \times \frac{100}{0.80} \times 10^{-3}$ $= 380 \text{ m}^3/\text{day}$ $= 15.82 \text{ m}^3/\text{h}$ <p>19 m<sup>3</sup>/h × 2 = 38 m<sup>3</sup>/h</p> <p>12 hours/day ( 6 days per week)</p> <p>Width 6.0 m × Length 6.0 m</p> <p>× Depth 3.5 m × 2</p> $= 252.0 \text{ m}^3$ <p>252.0 m<sup>3</sup></p> <p>1 W + 1 S</p>
---	---



**Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Digestion Tank + Centrifugal Dewatering)**

**Table -1 Input Data**

1. Calculation Manner		2	1.Premise that the quality of supernatants are same level removed with inlet sewage 2.Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency		2	1:Total Removal Ratio 2:Outlet Water Quality(input lor2)
In case of 1 : input data			(%)
In case of 2 : input data		#REF!	(mg/l)
3. Selection of Excess Sludge Generation		2	1:Consideration of Solid Matter Only 2:Consideration of Converting of Solved BOD(input lor2)
In case of 1 :input data (Sludge generation)		0.4	Sludge generation ratio per removal SS(%)
In case of 2 : input data	a	0.5	T2=Q4-S4=(a*S <sub>BOD</sub> +b*S1e+0*XA)*Q3/10 <sup>6</sup> +((Excess sludge generation formula)
	b	0.05	a:Converting ratio of solved BOD(mgMLSS/mgBOD)
	c	0.05	b:Converting ratio of SS(mgMLSS/mgSS)
	SBOD	284.50	c:Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)
	XA	3.000	S <sub>BOD</sub> :Solved BOD quality at inlet reactor
	θ	1	XAMLSS concentration(mg/l) θ:Hydraulic retention time(day)


**Table -2 Basic Conditions**

Sewage Flow and Quality	Sludge Moisture and Recovery Ratio	Digestion Tank Conditions	Chemical Conditions for Dewatering
-Inlet flow : Q <sub>0</sub> (m <sup>3</sup> /D)	7,000	-Primary sludge moisture ratio : W1(%)	0.0
-Inlet quality : S <sub>0</sub> (mg/l)	450	-Excess sludge moisture ratio : W2(%)	99.2
-Total removal ratio : A1(%)	-	-Thickened sludge moisture ratio : W3(%)	99.2
-Effluent quality : S(mg/l)	10.0	-Digested sludge moisture ratio : W4(%)	95.0
-Sludge generation ratio per removal SS : S1(%)	-	-Dewatered sludge moisture ratio : W5(%)	82.0
		-Content of organics in thickened sludge : A6(%)	75.0
		-Digestion ratio : A7(%)	#REF!
		-Digestion gas generation : A8(Nm <sup>3</sup> /kg VS)	
		-Chemical dosage : A9(%)	0.5
		-Chemical dissolve concentration : A10(%)	0.2

**Table -3 Material Balance Calculation**


	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	
Q(m <sup>3</sup> /day)	7,000	7,371	0	7,371	380	6,991	380	0	380	0	380	0	387	16	371	371		6,991	0
T(t-DS/day)	3,150	3,303	0,000	3,303	3,038	0,070	3,038	0,000	3,038	0,000	0,015	3,053	2,900	0,153	0,153	0,153		0,070	0,195
S(mg/l)	450	448	0	448	8,000	10	8,000	#DIV/0!	0	8,000	0	2,000	7,885	180,000	411	411		10	
X(tv-100)	100	104.9	0.0	104.9	96.4	2.2	96.4	0.0	0.0	96.4	0.0	0.5	96.9	92.1	4.8	4.8		2.2	6.2

**Figure -1 Material Balance Model**



Calculation Formula						
Q0=Input Data	Q3=Q1-Q2	Q6=T6*100/(100-W3)	Q9=Q6	Q12=Q9-Q11	Q15=Q7-Q10-Q14	Q5=1-Q5-Q11
T0=Q0*S0/10 <sup>6</sup> (4)	T3=T0*(100-A2)/100	T6=(T2+T4)*A3/100	T9=(T6-T8)*A4/100	T12=T9-T11	T15=T7-T10-T14	T5=1-T5-T11
S0=Input Data	S3=T3*10 <sup>6</sup> /Q3	S6=10 <sup>6</sup> *((100-W3)/100	S9=T9*10 <sup>6</sup> /Q9	S12=T12*10 <sup>6</sup> /Q12	S15=T15*10 <sup>6</sup> /Q15	S5=1-S5
Q1=Q0-Q15	Q4=T4*100/(100-W2)	Q7=Q5-Q4-Q6	Q10=Q6-Q8-Q9	Q13=T13*100/(100-W5)		
T1=T0-T15	T4=余剰汚泥発生式による	T7=(T2+T4)-T6	T10=T6-T8-T9	T13=T12*A5/100		
S1=T1*10 <sup>6</sup> /Q1	S4=10 <sup>6</sup> *((100-W2)/100	S7=T7*10 <sup>6</sup> /Q7	S10=T10*10 <sup>6</sup> /Q10	S13=10 <sup>6</sup> *((100-W5)/100		
Q2=T2*100/(100-W1)	Q5=Q3-Q4*(T3-T5)/T4	Q8=Q0	Q11=T10*A9/A10	Q14=Q12-Q13		
T2=T1-T3	T5=Q5*ST/10 <sup>6</sup>	T8=T6*A6*A7/10 <sup>4</sup>	T11=Q11*S11/10 <sup>6</sup>	T14=T12-T13		
S2=10 <sup>6</sup> *((100-W1)/100	S5=St	#REF!	S11=10 <sup>4</sup> *A10	S14=T14*10 <sup>6</sup> /Q14		

**Material Balance Sheet  
(7MLD STP)**



## Supporting Report 12.2.3

### STP Process Calculation Sample

Flow  $\cong$  10 MLD

\* Note: All the STP calculations are compiled in the soft copy.

Kindly refer to the data file.

**Design Condition**

Item	17MLD STP-TSPS			
(1) Design Flow for the year 2049	Flow Rate			
		m3/d	m3/h	m3/s
	Average Daily	27,000	1125	0.313
	Max Dayly	27,000	1125	0.313
	Max Hourly Peak factor 2.25	60,750	2531	0.703
(1) Design Flow for the year 2034	Flow Rate			
		m3/d	m3/h	m3/s
	Average Daily	17,000	708	0.197
	Max Dayly	17,000	708	0.197
	Max Hourly Peak factor 2.25	38,250	1594	0.443

**1. Inlet Chamber**

Item	17MLD STP-TSPS			
[1] Design Condition				
(1) Design Flow for the year 2049	Max Hourly	=	60,750	m3/d
		=	0.703	m3/sec
(2) Inlet Pipe				
Pipe Diameter	·	×		
Gradient		%		
Roughness Coefficient	n=	0.013	(Manning Formula)	
Full Pipe Flow Rate		m3/s		
(3) Influent Water Level	+	m		
[2] Geometory				
(1) Number of Basins	1	Basin		
(2) Depth of Basin	0.600	m	Approx.	
(3) Width of Basin	2.900	m	Approx.	
(4) Length of Basin	2.500	m	Approx.	
(5) Volume required of Basin	0.600	×	2.900	×
			2.500	=
				0.7
				m3
(6) Retention Time	0.600	×	2.900	×
			2.500	/
				0.703
				×
				1
	=	6.19	sec	
(7) Basin Demensions	Width	2.900	m	×
				Length
				2.500
				m
	×	Depth	0.600	m

2. Coarse Screen Channel

Item	17MLD STP-TSPS					
[1] Geometry						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Width	0.600	m				
Height	0.900	m				
Floor Level	+	5.000	m			
Bottom	+	0.000	m			
Influent Water Level	+	0.600	m			
Velocity	0.703	/		0.600	/	0.600 / 2
where Design Flow for the year 2049	=	0.976	<	1.000	m/sec	OK
Velocity	0.443	/		0.600	/	0.600 / 2
where Design Flow for the year 2034	=	0.615	<	1.000	m/sec	OK
(2) Screen Channel						
Number	2.0	Main	+	1.0	Bypass	
Width	1.200	m				
Side Water Depth	0.700	m				
Velocity	0.703	/		1.200	/	0.700 / 2
where Design Flow for the year 2049	=	0.418	≐	0.450	m/sec	OK
Velocity	0.443	/		1.200	/	0.700 / 2
where Design Flow for the year 2034	=	0.264	<	0.450	m/sec	OK
(3) Channel Dimensions	Width	1.2	m	×	Length	6.0 m
			×	SWD	0.7	m
[3] Equipment						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Dimension	Width	0.6	m	×	Height	0.9 m
Design Water Level	8.0	m				
(2) Coarse Screens (Main Channel)						
Number	2	W	+	0	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	1.2	m				
Width of side plate	50	mm				
Side Water Depth	0.7	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.703	/		1.100	/	0.650 / 2
	× ( 20	+	9 ) /	20		
	=	0.713	<	0.800	m/sec	OK
Velocity through screen	0.443	/		1.100	/	0.650 / 2
where Design Flow for the year 2034	× ( 20	+	9 ) /	20		
	=	0.449	<	0.800	m/sec	OK
(3) Coarse Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	50	mm				
Bar Thickness	9	mm				
Channel Width	1.2	m				
Side Water Depth	0.7	m				
Velocity through screen	0.703	/		1.200	/	0.700 / 2
where Design Flow for the year 2049	× ( 50	+	9 ) /	50		
	=	0.494	<	0.800	m/sec	OK
Velocity through screen	0.443	/		1.200	/	0.700 / 2
where Design Flow for the year 2034	× ( 50	+	9 ) /	50		
	=	0.311	<	0.800	m/sec	OK

**3. Raw Sewage Sump**

Item	17MLD STP-TSPS	
[2] Geometory		
(1) Raw Sewage Sump		
Number	1	Basin
Dia	12.00	m
Pump Operating Depth	1.500	m
Retention Time whe Design Flow for the year 2049	$( \frac{12.00^2 \times \pi}{4} \times 1.500 ) / 0.703$	$/ 60$ = 4.02 > 3.75 min (=minimum time of one pump cycle 'OK
Retention Time whe Design Flow for the year 2034	$( \frac{12.00^2 \times \pi}{4} \times 1.500 ) / 0.443$	$/ 60$ = 6.38 > 3.75 min (=minimum time of one pump cycle 'OK
High Water Level	+ 0.000	m
Pump Off Level	+ -1.500	m
[3] Equipment		
(1) Sewage Pumps 1		
Number	2 W	+ 1 S
Bore Diameter	300	mm
Discharge Flow : 40% Q* 2 whe Design Flow for the year 2034	$0.443 \times 3600$	$\times 40.0\% Q$ = 638 $\Rightarrow$ 640 m <sup>3</sup> /Hr
Total Head	15.0	m
(2) Sewage Pumps 2		
Number	1 W	+ 1 S
Bore Diameter	200	mm
Discharge Flow : 20% Q* 1 whe Design Flow for the year 2034	$0.443 \times 3600$	$\times 20.0\% Q$ = 319 $\Rightarrow$ 320 m <sup>3</sup> /Hr
Total Head	15.0	m

A-4 Process Cal\_EA&al 17MLD Bilishivalli\_Supporting 12.2.3

Item	17MLD STP																																																
<b>1. STP Design Condition</b>																																																	
(1) Design Flow Rate	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th style="text-align: center;">m3/d</th> <th style="text-align: center;">m3/h</th> <th style="text-align: center;">m3/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td style="text-align: center;">17,000</td> <td style="text-align: center;">708.33</td> <td style="text-align: center;">0.197</td> </tr> <tr> <td>Max Daily</td> <td style="text-align: center;">17,000</td> <td style="text-align: center;">708.33</td> <td style="text-align: center;">0.197</td> </tr> <tr> <td>Max Hourly Peak factor 2.25</td> <td style="text-align: center;">38,250</td> <td style="text-align: center;">1593.75</td> <td style="text-align: center;">0.443</td> </tr> </tbody> </table>									m3/d	m3/h	m3/s	Average Daily	17,000	708.33	0.197	Max Daily	17,000	708.33	0.197	Max Hourly Peak factor 2.25	38,250	1593.75	0.443																									
	m3/d	m3/h	m3/s																																														
Average Daily	17,000	708.33	0.197																																														
Max Daily	17,000	708.33	0.197																																														
Max Hourly Peak factor 2.25	38,250	1593.75	0.443																																														
(2) Design Water Quality	<p style="text-align: right;">Unit: mg/L</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th colspan="2">TP</th> </tr> <tr> <th>NH<sub>4</sub>-N</th> <th>Org-N</th> <th>NOx-N</th> <th>D-P</th> <th>P-P</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td style="text-align: center;">350</td> <td style="text-align: center;">800</td> <td style="text-align: center;">450</td> <td style="text-align: center;">45</td> <td style="text-align: center;">25</td> <td style="text-align: center;">0</td> <td style="text-align: center;">5</td> <td style="text-align: center;">2</td> </tr> <tr> <td>Outlet</td> <td style="text-align: center;">10</td> <td style="text-align: center;">50</td> <td style="text-align: center;">10</td> <td style="text-align: center;">1</td> <td style="text-align: center;">0</td> <td style="text-align: center;">9</td> <td style="text-align: center;">1</td> <td style="text-align: center;">1</td> </tr> <tr> <td>Removal rate</td> <td style="text-align: center;">97.1%</td> <td style="text-align: center;">93.7%</td> <td style="text-align: center;">97.8%</td> <td colspan="3" style="text-align: center;">85.7%</td> <td colspan="2" style="text-align: center;">71.4%</td> </tr> </tbody> </table>									BOD	COD	SS	T-N			TP		NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P	Inlet	350	800	450	45	25	0	5	2	Outlet	10	50	10	1	0	9	1	1	Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%	
	BOD	COD	SS	T-N			TP																																										
				NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P																																									
Inlet	350	800	450	45	25	0	5	2																																									
Outlet	10	50	10	1	0	9	1	1																																									
Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%																																										
<b>2. Inlet Chamber</b>																																																	
<b>[1] Design Condition</b>																																																	
(1) Design Flow Rate	Max Hourly	=	38,250	m3/day																																													
		=	0.443	m3/sec																																													
<b>[2] Geometry</b>																																																	
(1) Number of Basins	1	Basin																																															
(2) Depth of Basin	2.000	m																																															
(3) Width of Basin	2.900	m																																															
(4) Length of Basin	2.500	m																																															
(5) Volume required of Basin	2.000	×	2.900	×	2.500	=	2.3	m3																																									
(6) Retention Time	2.000	×	2.900	×	2.500	/	0.443	×	1																																								
	=	32.73		sec																																													
(7) Basin Dimensions	Width	2.900	m	×	Length	2.500	m																																										
	×	Depth	2.000	m																																													

A-4 Process Cal\_EA&al 17MLD Bilishivalli\_Supporting 12.2.3

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Wastewater Flow	$\begin{aligned} \text{Max Hourly} &= 38,250 \text{ m}^3/\text{d} \\ &= 0.443 \text{ m}^3/\text{sec} \end{aligned}$
[2] Geometory	
(1) Inlet Gate	
Number	2 Main + 1 Bypass
Width	0.500 m
Height	0.750 m
Floor Level	+ 2.000 m
Bottom	+ 0.000 m
Influent Water Level	+ 0.500 m
Velocity	$\begin{aligned} &0.443 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 2 \\ = &0.886 \text{ } \neq \quad 1.000 \text{ m/sec} \end{aligned}$
(2) Screen Channel	
Number	2 Main + 1 Bypass
Width	1.000 m
Side Water Depth	0.500 m
Velocity	$\begin{aligned} &0.443 \text{ } \swarrow \quad 1.000 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 2 \\ = &0.443 \text{ } \neq \quad 0.450 \text{ m/sec} \end{aligned}$
(3) Channel Dimensions	$\begin{aligned} \text{Width} &1.0 \text{ m} \times \text{Length} &6.0 \text{ m} \\ &\times \text{SWD} &0.5 \text{ m} \end{aligned}$
[3] Equipment	
(1) Inlet Gate	
Number	2 W + 1 S
Dimension	Width 0.5 m × Height 0.75 m
Design Water Level	2.00 m
(2) Fine Screens (Main Channel)	
Number	2 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	1.0 m
Width of side plate	50 mm
Side Water Depth	0.5 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	$\begin{aligned} &0.443 \text{ } \swarrow \quad 0.900 \text{ } \swarrow \quad 0.450 \text{ } \swarrow \quad 2 \\ &\times ( \frac{6}{6} + \frac{2}{6} ) / 6 \\ = &0.729 < \quad 0.800 \text{ m/sec} \end{aligned}$
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	1.0 m
Side Water Depth	0.5 m
Velocity through screen	$\begin{aligned} &0.443 \text{ } \swarrow \quad 1.000 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 2 \\ &\times ( \frac{20}{20} + \frac{9}{20} ) / 20 \\ = &0.642 < \quad 0.800 \text{ m/sec} \end{aligned}$



A-4 Process Cal\_EA&al 17MLD Bilishivalli\_Supporting 12.2.3

<b>4. Grit Chamber</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Peak flow = 38,250 m <sup>3</sup> /day = 0.443 m <sup>3</sup> /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0111 m/sec = 960 m <sup>3</sup> /m <sup>2</sup> /day
(4) Average Velocity	0.3 m/sec
<b>[2] Grit Chamber</b>	
(1) Surface Area required	0.443 / 0.0111 = 39.91 m <sup>2</sup>
(2) Number of Basins	1 S + 1 W
(3) Surface Area required/Basin	39.9 / 1 = 39.91 m <sup>2</sup>
(4) Length of Basin	39.91 ^0.5 = 6.317 m → 6.5 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.443 × 60 sec / 1 = 26.6 m <sup>3</sup>
(7) Depth required	26.6 / 6.5 / 6.5 = 0.629 m
(8) Basin Dimensions	Width 6.5 m × Length 6.5 m × Depth 0.6 m (Freeboard 0.3m)
(9) Retention Time	6.5 × 6.5 × 0.6 / 0.443 × 1 = 60.00 sec
(10) Surface Overflow Rate at Peak Flow	38,250 / 6.5 / 6.5 / 1 = 905.325444 < 960 m <sup>3</sup> /m <sup>2</sup> /day
<b>[3] Parshall Flume</b>	
(1) Design Flow Rate	Q= 443.000 l/sec
(2) Throat width	W= 0.450 m
(3) Water depth Ha	Ha= ( Q / 2264 / W ) <sup>2/3</sup> Ha= 0.574 m
(4) Crest Level	+ m ≐ Minimum water level at downstream channel
(5) Water level at the crest	+ 0.574 m
(6) Channel bottom level	+ m
(7) Upstream Channel width	1.500 m
(8) SWD of Upstream Channel	0.700 m
(9) Average velocity at upstream channel	0.422 m/sec
(10) Total Length of channel	10.000 m
<b>[4] Inlet Weir Gate</b>	
(1) Number	2 Units
(2) Weir Width	0.800 m
(3) Stroke	0.550 m
(4) Overflow Height	0.500 m
(5) Overflow Height (actual)	( 0.443 / 1.840 / 0.800 / 2 ) <sup>2/3</sup> = 0.283 < 0.500 m

<b>5. Reactor</b>																																																								
<b>[1] Design Condition</b>																																																								
(1) Design Wastewater Flow	Q = 17,000 m <sup>3</sup> /day (summer) Q' = 17,000 m <sup>3</sup> /day (Winter)																																																							
(2) Design Sewage Quality																																																								
Inlet BOD	350 mg/l																																																							
Outlet BOD	10.0 mg/l																																																							
Inlet S-BOD	235 mg/l assumed as 67% of BOD																																																							
Inlet COD	800 mg/l																																																							
Inlet bCOD : S <sub>0</sub>	578 mg/l																																																							
Inlet nbCOD	223 mg/l																																																							
bCOD/BOD	1.65																																																							
Inlet S-COD : sCOD	271 mg/l assumed as 33% of BOD																																																							
Inlet rbCOD	231 mg/l bCOD*40%																																																							
Inlet sbCOD	347 mg/l bCOD*60%																																																							
Outlet S-COD : nbsCODE	40 mg/l																																																							
Inlet nbpCOD : nbpCOD	183 mg/l =TCOD-bCOD-nbsCODE																																																							
Inlet SS	450 mg/l																																																							
Inlet VSS	383 mg/l assumed as 85% of TSS																																																							
: VSS <sub>COD</sub>	1.38 gCOD/gVSS = (TCOD-sCOD)/VSS																																																							
: nbVSS	131.96 gnbVSS/m <sup>3</sup> = nbpCOD/VSS <sub>COD</sub>																																																							
: iTSS	67.50 gnbVSS/m <sup>3</sup> = TSS-VSS																																																							
Inlet T-N	70 mg/l																																																							
Inlet TKN	70 mg/l																																																							
Inlet NH <sub>4</sub> -N	45.0 mg/l																																																							
Inlet T-P	7 mg/l																																																							
Inlet D-P	5 mg/l																																																							
Inlet Alkalinity as CaCO <sub>3</sub>	380 mg/l																																																							
Outlet Kjeldahl N	1.0 mg/l																																																							
Outlet NH <sub>4</sub> -N	1.0 mg/l																																																							
Outlet NO <sub>3</sub> -N	9.0 mg/l																																																							
Outlet T-P	2 mg/l																																																							
Outlet D-P	1 mg/l																																																							
(3) Water Temperature	T = 20.0 °C																																																							
(4) Safety Factor for Nitrogen	SF = 1.5																																																							
(5) Return Sludge Concentration	R <sub>s</sub> = 8,000 mg/l																																																							
(6) MLSS MLVSS	X <sub>TSS</sub> = 3,000 mg/l																																																							
(7) DO in the Reactor	2 mg/L																																																							
<b>[2] Design Value for perfect Nitrification of Nitrification Process</b>																																																								
(1) Activated sludge design kinwtic coefficients at 20°C																																																								
	<table border="1"> <thead> <tr> <th>Coefficient</th> <th>Unit</th> <th>COD oxidatio</th> <th>NH4 oxidatio</th> <th>NO2 oxidatio</th> </tr> </thead> <tbody> <tr> <td>μ<sub>max</sub></td> <td>gVSS/gVSS · d</td> <td>6.000</td> <td>0.900</td> <td>1.000</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH4</sub>, K<sub>NO2</sub></td> <td>mg/L</td> <td>8.000</td> <td>0.500</td> <td>0.200</td> </tr> <tr> <td>Y</td> <td>gVSS/g substrate oxidized</td> <td>0.450</td> <td>0.150</td> <td>0.050</td> </tr> <tr> <td>b</td> <td>gVSS/gVSS · d</td> <td>0.120</td> <td>0.170</td> <td>0.170</td> </tr> <tr> <td>fd</td> <td>unitless</td> <td>0.150</td> <td>0.150</td> <td>0.150</td> </tr> <tr> <td>K<sub>O2</sub></td> <td>mg/L</td> <td>0.200</td> <td>0.500</td> <td>0.900</td> </tr> <tr> <td>θ Value</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>μ<sub>max</sub></td> <td>unitless</td> <td>1.070</td> <td>1.072</td> <td>1.063</td> </tr> <tr> <td>b</td> <td>unitless</td> <td>1.040</td> <td>1.029</td> <td>1.029</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH4</sub>, K<sub>NO2</sub></td> <td>unitless</td> <td>1.000</td> <td>1.000</td> <td>1.000</td> </tr> </tbody> </table> <p>Wastwater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF &amp; EDDY/AECOM)</p>	Coefficient	Unit	COD oxidatio	NH4 oxidatio	NO2 oxidatio	μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000	K <sub>s</sub> , K <sub>NH4</sub> , K <sub>NO2</sub>	mg/L	8.000	0.500	0.200	Y	gVSS/g substrate oxidized	0.450	0.150	0.050	b	gVSS/gVSS · d	0.120	0.170	0.170	fd	unitless	0.150	0.150	0.150	K <sub>O2</sub>	mg/L	0.200	0.500	0.900	θ Value					μ <sub>max</sub>	unitless	1.070	1.072	1.063	b	unitless	1.040	1.029	1.029	K <sub>s</sub> , K <sub>NH4</sub> , K <sub>NO2</sub>	unitless	1.000	1.000	1.000
Coefficient	Unit	COD oxidatio	NH4 oxidatio	NO2 oxidatio																																																				
μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000																																																				
K <sub>s</sub> , K <sub>NH4</sub> , K <sub>NO2</sub>	mg/L	8.000	0.500	0.200																																																				
Y	gVSS/g substrate oxidized	0.450	0.150	0.050																																																				
b	gVSS/gVSS · d	0.120	0.170	0.170																																																				
fd	unitless	0.150	0.150	0.150																																																				
K <sub>O2</sub>	mg/L	0.200	0.500	0.900																																																				
θ Value																																																								
μ <sub>max</sub>	unitless	1.070	1.072	1.063																																																				
b	unitless	1.040	1.029	1.029																																																				
K <sub>s</sub> , K <sub>NH4</sub> , K <sub>NO2</sub>	unitless	1.000	1.000	1.000																																																				
(2) μ <sub>AOB</sub>	μ <sub>AOB</sub> = 0.3100 g/g · d = μ <sub>max, AOB</sub> [S <sub>NH4</sub> / (S <sub>NH4</sub> + K <sub>NH4</sub> )] [S <sub>O</sub> / (S <sub>O</sub> + K <sub>O, AOB</sub> )] - b <sub>AOB</sub>																																																							
μ <sub>max, AOB, T</sub>	μ <sub>max, AOB, T</sub> = 0.9000 g/g · d = μ <sub>max</sub> * 1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900																																																							
b <sub>AOB, T</sub>	b <sub>AOB, T</sub> = 0.1700 = b * 1.029 <sup>(T-20)</sup> b at 20°C = 0.170																																																							
S <sub>NH4</sub>	S <sub>NH4</sub> = 1.0000 mg/l																																																							
DO	DO = 2.0000 mg/l																																																							
K <sub>O, AOB</sub>	K <sub>O, AOB</sub> = 0.5000 mg/l																																																							

A-4 Process Cal. EA&al 17MLD Bilishivalli\_Supporting 12.2.3

(2) Design SRT	SRT= 4.8387 day ⇒ 5.0000 day	=1/μ <sub>AOB</sub> × SF
(3) Biomass production		
P <sub>X,VSS</sub>	P <sub>X,VSS</sub> = 5315.965 kg/d	=P <sub>X,bio</sub> +Q(nbVSS)
P <sub>X,TSS</sub>	P <sub>X,TSS</sub> = 7301.896 kg/d	=P <sub>X,bio</sub> +0.85+Q(nbVSS)+Q(TSS <sub>0</sub> -VSS <sub>0</sub> )+5*Q*Al
S	S= 0.4507 mg/l	=K <sub>s</sub> [1+b <sub>H</sub> (SRT)]/[SRT(μ <sub>m</sub> -b <sub>H</sub> )-1]
b <sub>H</sub>	b <sub>H</sub> = 0.1200	=b*1.04 <sup>(T-20)</sup> b at 20°C = 0.120
Y <sub>H</sub>	Y <sub>H</sub> = 0.4500 gVSS/g bCOD	
μ <sub>m,T</sub>	μ <sub>m,T</sub> = 6.0000 g/g·d	=μ <sub>max</sub> *1.04 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 6.000
Y <sub>n</sub>	Y <sub>n</sub> = 0.150 gVSS/g Nox	
NO <sub>x</sub>	NO <sub>x</sub> = 47.400 mg/l	
P <sub>X,bio,VSS</sub>	P <sub>X,bio,VSS</sub> = 3072.664 kg VSS/ci	=Q·Y <sub>H</sub> (S <sub>0</sub> -S)/[1+b <sub>H</sub> (SRT)]+f <sub>d</sub> ·b <sub>H</sub> ·QY <sub>H</sub> (S <sub>0</sub> -S)SRT/[1+b <sub>H</sub> (SRT)]
	2759.017	+QY <sub>n</sub> (Nox)/[2+b <sub>AOB</sub> (SRT)]
	248.312	=Q·Y <sub>H</sub> (S <sub>0</sub> -S)/[1+b <sub>H</sub> (SRT)]
	65.335	=f <sub>d</sub> ·b <sub>H</sub> ·QY <sub>H</sub> (S <sub>0</sub> -S)SRT/[1+b <sub>H</sub> (SRT)]
		=QY <sub>n</sub> (Nox)/[1+b <sub>AOB</sub> (SRT)]
NO <sub>x</sub>	NO <sub>x</sub> = 47.311 mg/l	=TKN-Ne-0.12P <sub>X,bio</sub> /Q
(4) Required Aeration Tank Volume		
V <sub>a</sub> =	V <sub>a</sub> = 12,170 m <sup>3</sup>	
τ =	τ = 17.18 hr	=V <sub>a</sub> /Q × 24
	⇒ 18.00 hr	
X <sub>VSS</sub> ·V <sub>a</sub>	X <sub>VSS</sub> ·V <sub>a</sub> = 26,580 kg VSS	=P <sub>X,VSS</sub> ·SRT
X <sub>TSS</sub> ·V <sub>a</sub>	X <sub>TSS</sub> ·V <sub>a</sub> = 36,509 kg TSS	=P <sub>X,TSS</sub> ·SRT
F/M	F/M= 0.224 kgBOD/kgMLVSS	
FractionVSS=	FractionVSS 0.728	
MLVSS=	MLVSS= 2184 mg/L	
(5) BODloading	BODloading= 0.489 kg/m <sup>3</sup> ·d	
(6) Observed Yield		
Y <sub>obs,TSS</sub> =	Y <sub>obs,TSS</sub> = 1.228 gTSS/gBOD	
Y <sub>obs,VSS</sub> =	Y <sub>obs,VSS</sub> = 0.894 gVSS/gBOD	
bCODremoved=	bCODremov 9,810 kg/d	
(7) effluent NO <sub>2</sub> -N	NO <sub>2</sub> -N= 0.2315 mg/l	=K <sub>s</sub> [1+b <sub>NOB</sub> (SRT)]/[SRT(μ <sub>NOB</sub> -b <sub>NOB</sub> )-1]
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700	=b*1.029 <sup>(T-20)</sup> b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 1.0000 g/g·d	=μ <sub>max</sub> *1.04 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 1.000
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.6897 g/g·d	=μ <sub>max,NOB</sub> [S <sub>0</sub> /(S <sub>0</sub> +K <sub>O2,NOB</sub> )]
	S <sub>0</sub> = 2.000 mg/l	
	K <sub>O2,NOB</sub> = 0.900 mg/l	
(8) effluent NH <sub>4</sub> -N	NH <sub>4</sub> -N= 0.5286 mg/l	=K <sub>s</sub> [1+b <sub>NOB</sub> (SRT)]/[SRT(μ <sub>NOB</sub> -b <sub>NOB</sub> )-1]
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700	=b*1.029 <sup>(T-20)</sup> b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 0.9000 g/g·d	=μ <sub>max</sub> *1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.7200 g/g·d	=μ <sub>max,NOB</sub> [S <sub>0</sub> /(S <sub>0</sub> +K <sub>O2,NOB</sub> )]
	S <sub>0</sub> = 2.000 mg/l	
	K <sub>O2,NOB</sub> = 0.500 mg/l	
(9) Ratio of Return Sludge	8,000*R <sub>r</sub> /(1+R <sub>r</sub> )= 3,000 mg/L	
	3,000/(8,000-3,000)= 0.60	
	R <sub>r</sub> = 0.60	

[3] Design for Nitrification and Denitrification Process																					
(1) Active biomass concentration	$X_b = Q \cdot (SRT) / V \cdot Y_H (S_0 - S) / [1 + b_H (SRT)]$ = 1,133.55 mg/l																				
(2) IR ratio	$IR = NO_x / Ne - 1.0 - R$ = 3.66																				
(3) The amount of NO <sub>3</sub> -N fed to the anoxic tank	$Nox\ feed = (IR + R) \cdot Q \cdot Ne$ = 651,280.37 kg/d																				
(4) The anoxic tank volume	$V_{nor} = 1,217\ m^3 = V_a \times 10\%$ $V_{nor} = 3,542\ m^3$ $\tau_{DN} = 5.000\ h$																				
(5) F/M <sub>b</sub>	F/M <sub>b</sub> = 1.48 g/g·d																				
(6) Fraction of rbCOD	40.00% = rbCOD/bCOD																				
	<table border="1"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b<sub>0</sub></th> <th>b<sub>1</sub></th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>	Percent rdCOD(%)	SDNR equation coefficients		b <sub>0</sub>	b <sub>1</sub>	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162
Percent rdCOD(%)	SDNR equation coefficients																				
	b <sub>0</sub>	b <sub>1</sub>																			
10	0.186	0.078																			
20	0.213	0.118																			
30	0.235	0.141																			
40	0.242	0.152																			
50	0.270	0.162																			
(8) SDNR <sub>b</sub>	$SDNR_b = 0.302\ g/g \cdot d = b_0 + b_1 [\ln(F/M_b)]$ $b_0 = 0.242$ $b_1 = 0.152$																				
(8) SDNR	$SDNR = 0.113\ g/g \cdot d = SDNR_b (MLVSS_0 / MLVSS)$ $SDNR_{adj} = 0.217\ g/g \cdot d = SDNR_1 - 0.029 \ln(F/M_b) - 0.012$ IR=3-4 $= SDNR_1 - 0.0166 \ln(F/M_b) - 0.078$ IR=2 $SDNR_t = 0.302\ g/g \cdot d = SDNR_b \cdot \theta^{(t-20)}$ $\theta = 1.026$																				
(9) NOR	$NOR = 872,270.70\ kg/d = N_{nox} \cdot SDNR \cdot X_b$ $> Nox\ feed = 651,280\ kg/d$																				
(10) Alkalinity to be added to maintain pH7	<p style="color: red;">-108.33 mg/l</p> $Influent\ Alk = 380.00\ mg/l$ $Alk\ used = 338.44\ mg/l = 7.14 \times Nox$ $Alk\ produced = 136.77\ mg/l = 3.57 \times (NO_x - NO_{xe})$ $Alk\ to\ maint = 70.00\ mg/l$																				
[4] Design of Phosphorus Removal Process																					
(1) Removal T-P	3.13 mg/l																				
P in waste sludge	px = 1.00%																				
Generated waste sludge	Px <sub>vss</sub> = 5315.965 kg/d																				
Removal Phosphorus	53.15964645 kg/d																				
(2) Effluent T-P without Al	3.87 mg/l																				
(3) Required Al to initial soluble phosphorus ratio	1.00 mol/mol																				
(4) Required Al dosing rate	3.48 mg/l as Al																				
	42.98 mg/l as crystal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> ·18H <sub>2</sub> O																				
(5) Required Aluminum Sulfate	730.62 kg/d																				
(6) Required Aluminum Sulfate solution 10%	6.96 m <sup>3</sup> /d																				
	289.93 L/H																				
(7) Additional sludge	296.20 kg/d																				

<p><b>[5] Reactor</b></p> <p>(1) Total volume of Aeration Basins</p> <p>(2) Total volume of Anoxic Basins</p>	$V_A = Q \cdot \theta_a / 24$ $= 12,750 \text{ m}^3$ $V_{DN} = Q \cdot \theta_{DN} / 24$ $= 3,542 \text{ m}^3$ <table border="1"> <thead> <tr> <th rowspan="2">Item</th> <th rowspan="2">Volume required</th> <th colspan="2">Retention Time required</th> <th rowspan="2">Ratio of Volume</th> </tr> <tr> <th>Summer</th> <th>Winter</th> </tr> </thead> <tbody> <tr> <td>unit</td> <td>m<sup>3</sup></td> <td>hour</td> <td>hour</td> <td></td> </tr> <tr> <td>Anaerobic</td> <td>V<sub>AN</sub></td> <td>1,060</td> <td>1.50</td> <td>1.50</td> <td>0.30</td> </tr> <tr> <td>Anoxic</td> <td>V<sub>DN</sub></td> <td>3,542</td> <td>5.00</td> <td>5.00</td> <td>1.00</td> </tr> <tr> <td>Aerobic</td> <td>V<sub>A</sub></td> <td>12,750</td> <td>18.00</td> <td>18.00</td> <td>3.60</td> </tr> <tr> <td>Total</td> <td>V</td> <td>17,352</td> <td>24.50</td> <td>24.50</td> <td></td> </tr> </tbody> </table>	Item	Volume required	Retention Time required		Ratio of Volume	Summer	Winter	unit	m <sup>3</sup>	hour	hour		Anaerobic	V <sub>AN</sub>	1,060	1.50	1.50	0.30	Anoxic	V <sub>DN</sub>	3,542	5.00	5.00	1.00	Aerobic	V <sub>A</sub>	12,750	18.00	18.00	3.60	Total	V	17,352	24.50	24.50																															
Item	Volume required			Retention Time required			Ratio of Volume																																																												
		Summer	Winter																																																																
unit	m <sup>3</sup>	hour	hour																																																																
Anaerobic	V <sub>AN</sub>	1,060	1.50	1.50	0.30																																																														
Anoxic	V <sub>DN</sub>	3,542	5.00	5.00	1.00																																																														
Aerobic	V <sub>A</sub>	12,750	18.00	18.00	3.60																																																														
Total	V	17,352	24.50	24.50																																																															
<p><b>[6] Geometry</b></p> <p>(1) Basin Dimensions</p> <p>Cross Section</p> <p>Hantzschn Subtraction</p> <p>after Subtraction</p> <p>Total Volume</p> <p>(2) Partition of Basin</p>	<p>Width      Length      Depth      Basins</p> <p>8.0                      204.0      5.5      2</p> <p>Cross Section                      =      44.0 m<sup>2</sup>/Basin</p> <p>Hantzschn Subtraction                      =      1.0 m<sup>2</sup>/Basin</p> <p>after Subtraction                      =      43.0 m<sup>2</sup>/Basin</p> <p>Total Volume                      =      8,772 m<sup>2</sup>/Basin      17,544 m<sup>3</sup>/Total</p> <table border="1"> <thead> <tr> <th>Item</th> <th>unit</th> <th>Anaerobic</th> <th>Anoxic</th> <th>Aerobic</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Cross Section</td> <td>m<sup>2</sup></td> <td colspan="3">43.0</td> <td></td> </tr> <tr> <td>Length required</td> <td>m</td> <td><b>12.3</b></td> <td><b>41.2</b></td> <td><b>148.3</b></td> <td><b>201.8</b></td> </tr> <tr> <td>Volume required per Basin</td> <td>m<sup>3</sup></td> <td>530</td> <td>1,771</td> <td>6,375</td> <td>8,676</td> </tr> <tr> <td>Total Volume required</td> <td>m<sup>3</sup></td> <td>1,060</td> <td>3,542</td> <td>12,750</td> <td>17,352</td> </tr> <tr> <td>Actual Cross Section</td> <td>m<sup>2</sup></td> <td>43.0</td> <td>43.0</td> <td>43.0</td> <td></td> </tr> <tr> <td>Actual Length</td> <td>m</td> <td>13.0</td> <td>42.0</td> <td>149.0</td> <td>204.0</td> </tr> <tr> <td>Actual Volume per Basin</td> <td>m<sup>3</sup></td> <td>559</td> <td>1,806</td> <td>6,407</td> <td>8,772</td> </tr> <tr> <td>Actual Total Volume</td> <td>m<sup>3</sup></td> <td>1,118</td> <td>3,612</td> <td>12,814</td> <td>17,544</td> </tr> <tr> <td>Actual Ratio of Volume</td> <td></td> <td>0.31</td> <td>1.00</td> <td>3.55</td> <td></td> </tr> <tr> <td>Actual Retention Time</td> <td>hour</td> <td>1.58</td> <td>5.10</td> <td>18.09</td> <td>24.77</td> </tr> </tbody> </table>	Item	unit	Anaerobic	Anoxic	Aerobic	Total	Cross Section	m <sup>2</sup>	43.0				Length required	m	<b>12.3</b>	<b>41.2</b>	<b>148.3</b>	<b>201.8</b>	Volume required per Basin	m <sup>3</sup>	530	1,771	6,375	8,676	Total Volume required	m <sup>3</sup>	1,060	3,542	12,750	17,352	Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0		Actual Length	m	13.0	42.0	149.0	204.0	Actual Volume per Basin	m <sup>3</sup>	559	1,806	6,407	8,772	Actual Total Volume	m <sup>3</sup>	1,118	3,612	12,814	17,544	Actual Ratio of Volume		0.31	1.00	3.55		Actual Retention Time	hour	1.58	5.10	18.09	24.77
Item	unit	Anaerobic	Anoxic	Aerobic	Total																																																														
Cross Section	m <sup>2</sup>	43.0																																																																	
Length required	m	<b>12.3</b>	<b>41.2</b>	<b>148.3</b>	<b>201.8</b>																																																														
Volume required per Basin	m <sup>3</sup>	530	1,771	6,375	8,676																																																														
Total Volume required	m <sup>3</sup>	1,060	3,542	12,750	17,352																																																														
Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0																																																															
Actual Length	m	13.0	42.0	149.0	204.0																																																														
Actual Volume per Basin	m <sup>3</sup>	559	1,806	6,407	8,772																																																														
Actual Total Volume	m <sup>3</sup>	1,118	3,612	12,814	17,544																																																														
Actual Ratio of Volume		0.31	1.00	3.55																																																															
Actual Retention Time	hour	1.58	5.10	18.09	24.77																																																														
<p><b>[7] Equipment</b></p> <p>(1) Ras Pumps</p> <p>Ras Ratio</p> <p>Required Capacity</p> <p>Number</p> <p>(2) Circulation Pumps</p> <p>Ras Ratio</p> <p>Required Capacity</p> <p>Number</p> <p>(3) SAS Pumps</p> <p>Excess Sludge</p> <p>Sludge withdraw</p> <p>Running Time</p> <p>Required Capacity</p> <p>Number</p>	<p>60%</p> <p>17,000 m<sup>3</sup>/day ×      60% / 24 /      2</p> <p>= 213 m<sup>3</sup>/Hr ⇒      220 m<sup>3</sup>/Hr</p> <p>2 Work</p> <p>2 Stanby</p> <p>366%</p> <p>17,000 m<sup>3</sup>/day ×      366% / 24 /      4</p> <p>= 648 m<sup>3</sup>/Hr ⇒      650 m<sup>3</sup>/Hr</p> <p>4 Work</p> <p>2 Stanby</p> <p>1,068 m<sup>3</sup>/day</p> <p>12 Times/day</p> <p>0.5 Hr/Time</p> <p>1,068 m<sup>3</sup>/day /      12 /      0.5 /      2</p> <p>= 88.98 m<sup>3</sup>/Hr ⇒      90 m<sup>3</sup>/Hr</p> <p>2 Work</p> <p>2 Stanby</p>																																																																		

A-4 Process Cal. EA&al 17MLD Bilishivalli\_Supporting 12.2.3

(4) Alum Solution Tank										
Number	2	W	+	0	S					
Alum concentration as crystal	10	%								
Gravity of dissolved dechlorine	1.05									
Required solution volume	730.62	kg / d	×	100	/	10	/	1.05	/	1000
	=	6.96				m3/d				
Volume of Tank	4.1	m3/tank	(=	1.5	mW×	1.5	mL×	1.8	mH)	
Total Volume of Tanks	8.1		m3	(Duration=		1.16	day)			
(5) Mixer for Alum Solution Tank										
Number	2	W	+	0	S					
(6) Alum Dosing Pump										
Number	2	W	+	1	S					
Capacity	6.96	m3/d	/	24	×	1000	/	2	×	2
	289.93	l/h/unit	⇒	290	l/h/unit					

A-4 Process Cal\_ EA&al 17MLD Bilishivalli\_Supporting 12.2.3

<b>6. Air Requirement at Average Flow</b>	
[1] Design Condition	
(1) AOR	AOR = 7,355 kg/day = 306.5 kg/h
Q <sub>in</sub> : Design Average Flow m <sup>3</sup> /d	17,000
Inlet bCOD : S <sub>0</sub>	578 mg/l
S=	S= 0.451 mg/l
Nox=	Nox 47.400 mg/l
P <sub>X,bio</sub> =	P <sub>X,b</sub> 3,007.3 kg VSS/d does not include nitrifying bacteria
R <sub>0</sub> =	R <sub>0</sub> = Q(S <sub>0</sub> -S-k(NOx-NOxe))-1.42P <sub>X,bio</sub> +4.57Q•NOx
R <sub>0</sub> =	R <sub>0</sub> = 7,355 kg O <sub>2</sub> /d
	k= 2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{\text{AOR} \times C_s \cdot a \times 1.024^{20-T}}{\alpha \times F (\beta \cdot C_{sw}/C_s \cdot (P_b/P_a)a - C_A)}$
	C <sub>S</sub> : Saturated DO at sea level and 20 °C 9.09 mg/L
	C <sub>SW</sub> : Saturated DO at sea level and operating Temperature 9.09 mg/L at 20 °C
	20-T : 0.0 1.024 <sup>20-T</sup> : 1.0000
	C <sub>A</sub> : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1+0.40D <sub>j</sub> /P <sub>a</sub> 1.19357
	D <sub>j</sub> : Tank Liquid Depth 5.00 m
	P <sub>a</sub> : Standard absolute pressure at s 10.332 m
	P <sub>b</sub> : Absolute pressure at Plant Site Elevation m
	P <sub>b</sub> /P <sub>a</sub> : exp[-gM(z <sub>b</sub> -z <sub>a</sub> )/R*T] 0.900
	g : Acceleration due to Gravity 9.80665 m/s <sup>2</sup>
	M : Mole of Air 28.97 kg/kg-mole
	z <sub>b</sub> : Plant Site Elevation 900 m
	z <sub>a</sub> : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 293.15 Kelvin
	α : relative Transfer Rate to clean Water 0.65
	β : relative DO Saturation to clean Water 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{79,798}{4.2591} = 18,735.68 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Standard O <sub>2</sub> required at Field Conditions per Basin =	9,368 kg/day
(5) SOTE for the above Effective Aeration Depth	28.0 %
(6) Fraction of O <sub>2</sub> in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	15%
(9) Air required at Field Conditions per Basins	= 137,776 m <sup>3</sup> /day = 5,740.6 m <sup>3</sup> /hr
[2] Equipment	

## A-4 Process Cal\_ EA&amp;al 17MLD Bilishivalli\_Supporting 12.2.3

(1) Air Blower				
Number	4	W	+	2 S
Required Capacity	5740.6	m <sup>3</sup> /Hr·Basin	/	2 unit/Basin
	= 2870.3	m <sup>3</sup> /h	⇒	2900 m <sup>3</sup> /h /Unit
Pressure	65	kPa		
Safety Factor	10	%		
Heat capacity ratio	1.4			
Atmospheric pressure at site elevation	91.234	kPa		
Total inlet pressure	89.234	kPa		
Volume rate of flow at inlet point	54.869	m <sup>3</sup> /min		
Total discharge pressure	156.234	kPa		
Overall adiabatic efficiency	0.65			
Inlet air temperature (min.)	15	°C		
Shaft power	77.578	kW		
Rated Output of Motor	85.335	kW	⇒	90 kW



A-4 Process Cal\_EA&al 17MLD Bilishivalli\_Supporting 12.2.3

<b>7. Final Clarifire</b>							
<b>[1] Design Condition</b>							
(1) Design Wastewater Flow	Q= 17,000 m <sup>3</sup> /day						
(2) Water Temperature	T= 20.0 °C						
(3) MLSS	Xef= 3,000 mg/l						
(4) SVI	SVI= 300						
(5) Sedimentation Velocity	$v = 4.899 \cdot 10^6 \cdot T^{(0.954)} \cdot X_{ef}^{(-1.354)} \cdot SVI^{(-0.77)}$ $= 4.899 \cdot 10^6 \cdot 20.0^{0.954} \cdot 3,000^{-1.354} \cdot 150^{-0.770}$ $= 20.7 \text{ m/day}$						
(6) Surface Overflow Rate required	$S' = v / (1.5 \cdot 1) = 20.7 / (1.5 \cdot 1.0) = 13.8 \text{ m}^3/\text{m}^2 \cdot \text{day}$ $\rightarrow 12.0 \text{ m}^3/\text{m}^2 \cdot \text{day}$						
<b>[2] Geometory</b>							
(1) Surface Area required	A = 17,000/12.0 = 1,417 m <sup>2</sup>						
(2) Demensions	<table style="margin-left: 40px;"> <tr> <td>Diameter</td> <td>Depth</td> <td>Basin</td> </tr> <tr> <td><b>30.0</b></td> <td><b>3.5</b></td> <td><b>2</b></td> </tr> </table>	Diameter	Depth	Basin	<b>30.0</b>	<b>3.5</b>	<b>2</b>
Diameter	Depth	Basin					
<b>30.0</b>	<b>3.5</b>	<b>2</b>					
(3) Actual Surface Area	S = 30.0 <sup>2</sup> * 3.14 / 4 * 2.0 = 1,414 m <sup>2</sup>						
(4) Surface Overflow Rate	S = 17,000/1,414 = 12.0 m <sup>3</sup> /m <sup>2</sup> ·day						

<b>8. Chlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 17,000 m <sup>3</sup> /day 708.33 m <sup>3</sup> /h Peak Flow 38,250 m <sup>3</sup> /day 1593.75 m <sup>3</sup> /h
(2) Contact Time	30 min
(3) Type of Chlorine	Cl <sub>2</sub> -GAS
(4) Design Chlorine Dosage Rate	10 mg/L
(5) Required Chlorine per day	Average Daily Flow / 1000 × Design Chlorine Dosage Rate = 170.0 kg/d = 7.08 kg/h
<b>[2] Chlorination Contact Tank</b>	
(1) Volume required	Average Daily Flow / 1440 × Contact Time = 354.2 m <sup>3</sup>
(2) Nos. of lanes	3 lanes
(3) Width of lane	2.00 m
(4) Length of lane	30.00 m
(5) Side Water Depth	2.00 m
(6) Nos. of Tanks	1 tank
(7) Total Width of Tank	6.80 m Approx..
(8) Average Velocity	Decant Flow / 3600 / Width / Depth = 708.33 / 3600 / 2.00 / 2.00 = 0.049 m/sec
(9) Total Volume	Width × Length × Depth × Nos. of lanes × Nos. of Tanks = 2.0 m × 30.0 m × 2.0 m × 3 × 1 = 360 m <sup>3</sup> > 354.2 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Chlorine Dosing Condition	
Operation Dosage Rate -1	DC1 10 mg/L
(2) Chlorine Cylinder	
Type	- Cylindrical Convexsd Container
Cylinder Capacity	Cc 928 kg/cylinder
Average Dosage Rate -1	q1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 170 kg/day
Maximum Dosage Rate -1	q3 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 383 kg/day
Storage day	T More than 15 days
Required Storage Capacity	EC1 D × T = 2,550 kg
Unit Number	EN1 EC1 / Cc = 2.7 cylinders
Maximum Operation Numbers	
Cl <sub>2</sub> -Gas Volatilize Rate	Vr1 #### @ 20 <sup>o</sup> C Standard temperature
Maximum Dosing Rate	DC1 10 mg/L, Q <sub>T-D</sub> × q3 × 10 <sup>-3</sup> / 24 = 15.94 kg/h
Operation Numbers	EN2 DC1 / Vr1 = 2.0sets
Number	2 W + 2 S
(3) Chlorinator	
Type	Solution Feed Vacuum Type
Number	1 W + 1 S
Operation Dosage Rate -1	Dq1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 382.5 kg/day
Required Dosage Rate	Chlorine -1 : Dq1 / (EN1 × 24) = Minimum 0.00 kg/hr Maximum 16.0 kg/hr
(4) Chlorine Booster Pump	

A-4 Process Cal\_EA&al 17MLD Bilishivalli\_Supporting 12.2.3

Type	Branchy on the water supply pipe
Water Demand	Water requiamet for mixed Chlori
Chlorinator Discharge	(kg/hr) 1.0 1.5 2.0 2.5 3.0 4.0
Water Demand	(L/min) 15 20 25 30 35 40
Chlorinator Discharge	(kg/hr) 5.0 6.0 10.0 50.0 100.0 200.0
Water Demand	(L/min) 45 50 60 300 600 1,200
Water requiamet	-
For Chlorin	Qp1 Maximum dosage ra 16.0 kg/hr therefore 100 L/min
Booster Pump Type	Single suction volute pump
Number	1 W + 1 S
<b>9. Dechlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 17,000 m <sup>3</sup> /day
(2) Contact Time	10 min
(3) Type of Dechlorine	Sodium Thiosulfate (Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 5H <sub>2</sub> O)
(4) Free Residual Chlorine	1.0 mg/L assumed value
(5) Consumption per day	Average Daily Flow / 1000 × Free Residual Chlorine × 1.75 × 1.5 (safety factor) = 44.6 kg/d = 1.86 kg/h
<b>[2] Dechlorination Contact Tank</b>	
(1) Volume required	Average Flow Rate / 60 × Contact Time = 118.1 m <sup>3</sup>
(2) Width of lane	6.80 m
(3) Length of lane	9.00 m
(4) Side Water Depth	2.00 m
(5) Nos. of Tanks	1 tank
(6) Total Volume	Width × Length × Depth = 6.8 m × 9.0 m × 2.0 m = 122 m <sup>3</sup> > 118.1 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Dechlorine Solution Tank	
Number	2 W + 0 S
Dechlorine concentration	10 %
Gravity of dissolved dechlorine	1.10
Required solution volume	44.63 kg/d × 100 / 10 / 1.10 / 1000 = 0.41 m <sup>3</sup> /d
Volume of Tank	0.288 m <sup>3</sup> /tank (= 0.6 mW × 0.6 mL × 0.8 mH)
Total Volume of Tanks	0.576 m <sup>3</sup> (Duration= 1.42 day)
(2) Mixer for Dechlorine Solution Tank	
Number	2 W + 0 S
(3) Dechlorine Dosing Pump	
Number	2 W + 1 S
Capacity	0.91 m <sup>3</sup> /d / 24 × 1000 / 2 19.02 l/h/unit ⇒ 20 l/h/unit



A-4 Process Cal\_EA&al 17MLD Bilishivalli\_Supporting 12.2.3

<b>11. Thickened Sludge Sump</b>	
<b>[1] Design Condition</b>	
(1) Inlet Solids	8,542 kg/day
(2) Inlet Sludge Volume	1,068 m <sup>3</sup> /d
<b>[2] Geometory</b>	
(1) Sludge withdrawl	12 Times/day
(2) Required Sump Volume	89 m <sup>3</sup> /d
(3) Number	2 Basins
(4) Width	3.5 m
(5) Length	4.0 m
(6) Side Water Depth	3.0 m
(7) Actual Sump Volume	$3.5 \times 4.0 \times 3.0 \times 2$ $= 84.0 \text{ m}^3$
<b>[3] Equipment</b>	
(1) Thickened Sludge Transfer Pumps	
Transfer Time	6.00 Hr
Number	2 W + 2 S
Required Capacity	$\frac{1068 \text{ m}^3}{6.0} \div 2$ $= 89.0 \text{ m}^3/\text{Hr} \Rightarrow 90 \text{ m}^3/\text{Hr}/\text{Unit}$

<p><b>12. Centrifuge</b>  <b>[1] Design Condition</b>                  (1) Type of Dewatering                  (2) Generated Sludge                  (3) Design Polyelectrolyte Dosage                  (4) Volume of Thickend Sludge                  (5) Consistency of Dewatered Sludge                  (6) Operation Time</p>	<p>Centrifuge                  7,688 kg/day                  Polyelectrolyte 5 kg/t-DS·day                  307.5 m<sup>3</sup>/day                  82 %                  12 hours/day (6 days per week)</p>
<p><b>[2] Volume of Centrifuges</b></p>	<p><math display="block">\frac{\text{Digested Solids}}{\text{Operation Time} \times \text{No.}} \times \text{Operation/week}</math> <math display="block">= \frac{307.5}{12 \times 2} \times \frac{7}{6} = 14.9</math> <p style="text-align: right;">→ 15 m<sup>3</sup>/hour</p> </p>
<p><b>[3] Dewatered Solids</b></p>	<p><math display="block">\text{Digested Sludge} \times (1 + \text{Injection Rate})</math> <math display="block">= 7,688 \times (1 + 0.0050)</math> <math display="block">= 7,726 \text{ kg/day}</math> </p>
<p><b>[4] Dewatered Cake Volume</b></p>	<p><math display="block">\text{Dewatered Solids} \times \frac{100}{100 - \frac{\text{Moisture Content}}{7}} \times \frac{7}{6}</math> <math display="block">= 7,726 \times \frac{100}{100 - 82} \times \frac{7}{6}</math> <math display="block">= 50.08 \text{ t/day}</math> <p>apparent specific gravity 1.00  <math display="block">\frac{50.08}{1.00} = 50.1 \text{ m}^3/\text{day}</math></p> </p>
<p><b>[5] Polyelectrolyte</b>                  (1) Design Polyelectrolyte Dosage                  (2) Required Polyelectrolyte                  (3) Dissolving concentration                  (4) Volume of Polyelectrolyte solution</p>	<p>Polyelectrolyte 5 kg/t-DS·day                  38.44 kg/day                  0.20 %                  19.22 m<sup>3</sup>/day</p>

A-4 Process Cal\_EA&al 17MLD Bilishivalli\_Supporting 12.2.3

<b>[6] Equipment</b>	
(1) Centrifuge	
Capacity	15 m <sup>3</sup> /hr
Number	2 W + 1 S
(2) Centrifuge Feed Pumps	
Capacity	15 m <sup>3</sup> /hr
Number	2 W + 1 S
(3) Polyelectrolyte Dosing Pumps	
Volume of Polyelectrolyte solution	19.22 m <sup>3</sup> /day
Operation Time	12 hours/day (6 days per week)
Safety Factor	1.5
Number	2 W + 1 S
Required Capacity	19.22 m <sup>3</sup> /da × 7 / 6 / 12 / 2
	= 0.93 m <sup>3</sup> /Hr
Specification Capacity	0.93 m <sup>3</sup> /Hr × 1.5
	= 1.401 m <sup>3</sup> /Hr ⇒ 1.40 m <sup>3</sup> /Hr /Unit
(4) Polyelectrolyte dosing System	
Preparation time for solution	3 hr
Required dry polymer	38.44 kg/day × 7 / 6 / 12
	= 3.74 kg/hr
	= 11.21 kg per one batch
Feedong time per one batch	30 min
Capacity of Dry polymer Feeder	22 kg/h
Tanks Dimensions	Width 1.5 m × Length 2.0 m × Depth 2.0 m × 2
	= 12 m <sup>3</sup>
Retention Time of Tank	6.00 m <sup>3</sup> /tank / 0.93 m <sup>3</sup> /Hr / 2
	= 3.211 Hr > 3 Hr
Number	2 W + 0 S

A-4 Process Cal\_EA&al 17MLD Bilishivalli\_Supporting 12.2.3

<p><b>11. Centrifuge Feed Sump</b></p> <p><b>[1] Design Condition</b></p> <p>(1) Generated Thickend Sludge</p> <p>(2) Solids Consistency</p> <p>(3) Volume of Thickened Sludge</p> <p>(4) Sludge feed flow rate</p> <p>(5) Centrifuge Operation Time</p> <p><b>[2] Geometry</b></p> <p>(1) Basin Dimensions</p> <p><b>[3] Equipment</b></p> <p>(1) Mixers for Centrifuge Feed Sumps</p> <p>Required Volume</p> <p>Number</p>	<p>7,688 kg/day</p> <p>2.50 %</p> <p>Total Solids <math>\times \frac{100}{\text{Solids Consistency}} \times 10^{-3}</math></p> <p>= 7,688 <math>\times \frac{100}{2.50} \times 10^{-3}</math></p> <p>= 308 m<sup>3</sup>/day</p> <p>= 12.81 m<sup>3</sup>/h</p> <p>15 m<sup>3</sup>/h <math>\times \frac{2}{6 \text{ days per week}} = 30 \text{ m}^3/\text{h}</math></p> <p>12 hours/day</p> <p>Width 6.0 m <math>\times</math> Length 6.5 m</p> <p><math>\times</math> Depth 4.0 m <math>\times</math> 2</p> <p>= 312.0 m<sup>3</sup></p> <p>312.0 m<sup>3</sup></p> <p>1 W + 1 S</p>
---	---



**Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Digestion Tank + Centrifugal Dewatering)**

**Table-1 Input Data**

1. Calculation Manner		2	1:Premise that the quality of supernatants are same level removed with inlet sewage 2:Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency		2	1:Total Removal Ratio 2:Outlet Water Quality(input lor2)
In case of 1 : input data			(%)
In case of 2 : input data		#REF!	(mg/l)
3. Selection of Excess Sludge Generation		2	1:Consideration of Solid Matter Only 2:Consideration of Converting of Solved BOD(input lor2)
In case of 1 : input data (Sludge generation)			Sludge generation ratio per removal SS(%)
		0.4	$T2-Q4 \cdot S4 = (a \cdot S_{000} + b \cdot S1 - c \cdot \theta \cdot XA) \cdot Q3 / 10^6 \cdot \theta$ (Excess sludge generation formula)
In case of 2 : input data		a	a.Converting ratio of solved BOD(mgMLSS/mgBOD)
		b	b.Converting ratio of SS(mgMLSS/mgSS)
		c	c.Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)
		SBOD	$S_{000}$ :Solved BOD quality at inlet reactor
		XA	XAMLSS concentration(mg/l)
		$\theta$	$\theta$ :Hydraulic retention time(day)


**Table-2 Basic Conditions**

Sewage Flow and Quality	Sludge Moisture and Recovery Ratio	Digestion Tank Conditions	Chemical Conditions for Dewatering
• Inlet flow : $Q_0$ (m <sup>3</sup> /D)	• Primary sludge moisture ratio : W1(%)	• Removal ratio in primary tank : A2(%)	• Content of organics in thickened sludge : A6(%)
• Inlet quality : $S_0$ (mg/l)	• Excess sludge moisture ratio : W2(%)	• Recovery ratio in sludge thickener : A3(%)	• Digestion ratio : A7(%)
• Total removal ratio : A1(%)	• Thickened sludge moisture ratio : W3(%)	• Recovery ratio in sludge digester : A4(%)	• Digestion gas generation : A8(Nm <sup>3</sup> /kgVS)
• Effluent quality : $S_t$ (mg/l)	• Dewatered sludge moisture ratio : W4(%)	• Recovery ratio in dewatering : A5(%)	• Chemical dosage : A9(%)
• Sludge generation ratio per removal SS : $S_t$ (%)	• Dewatered sludge moisture ratio : W5(%)		• Chemical dissolve concentration : A10(%)

**Table-3 Material Balance Calculation**

	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
Q(m <sup>3</sup> /day)	17,000	18,046	0	18,046	1,068	16,978	308	760	0	308	0	19	327	41	286	1,046	16,978	0
Tl(-DS/day)	7,650	8,890	0.000	8,890	8,542	0.170	7,688	0.854	0.000	7,688	0.000	0.038	7,726	7,340	0.386	1,240	0.170	0.178
S(mg/l)	450	493	0	493	8,000	10	25,000	1,124	0	25,000	0	2,000	23,647	180,000	1,351	1,186	10	10
Xt/T0*100	100	116.2	0.0	116.2	111.7	2.2	100.5	11.2	0.0	100.5	0.0	0.3	101.0	95.9	5.0	16.2	2.2	2.3


**Figure -1 Material Balance Model**



**Calculation Formula**

• $Q_0$ =Input Data	• $Q_3=Q_1-Q_2$	• $Q_6=T_6 \cdot 100 / (100-W_3)$	• $Q_9=Q_6$	• $Q_{12}=Q_9+Q_{11}$	• $Q_{15}=Q_7+Q_{10}+Q_{14}$	• $Q_5=Q_5-Q_{11}$
• $T_0=Q_0 \cdot S_0 \cdot 10^6 / (-6)$	• $T_3=T_0 \cdot (100-A_2) / 100$	• $T_6=(T_2+T_4) \cdot A_3 / 100$	• $T_9=(T_6-T_8) \cdot A_4 / 100$	• $T_{12}=T_9+T_{11}$	• $T_{15}=T_7+T_{10}+T_{14}$	• $T_5=T_5-T_{11}$
• $S_0$ =Input Data	• $S_3=T_3 \cdot 10^6 / Q_3$	• $S_6=10^6 \cdot (100-W_3) / 100$	• $S_9=T_9 \cdot 10^6 / Q_9$	• $S_{12}=T_{12} \cdot 10^6 / Q_{12}$	• $S_{15}=T_{15} \cdot 10^6 / Q_{15}$	• $S_5=S_5$
• $Q_1=Q_0+Q_{15}$	• $Q_4=T_4 \cdot 100 / (100-W_2)$	• $Q_7=(Q_2+Q_4) \cdot Q_6$	• $Q_{10}=Q_6 \cdot Q_8 \cdot Q_9$	• $Q_{13}=T_{13} \cdot 100 / (100-W_5)$	• $Q_{14}=Q_{12}-Q_{13}$	
• $T_1=T_0+T_{15}$	• $T_4=$ 余剰汚泥発生式による	• $T_7=(T_2+T_4) \cdot T_6$	• $T_{10}=T_6-T_8-T_9$	• $T_{13}=T_{12} \cdot A_5 / 100$	• $T_{14}=T_{12}-T_{13}$	
• $S_1=T_1 \cdot 10^6 / Q_1$	• $S_4=10^6 \cdot (100-W_2) / 100$	• $S_7=T_7 \cdot 10^6 / Q_7$	• $S_{10}=T_{10} \cdot 10^6 / Q_{10}$	• $S_{13}=10^6 \cdot (100-W_5) / 100$	• $S_{14}=T_{14} \cdot 10^6 / Q_{14}$	
• $Q_2=T_2 \cdot 100 / (100-W_1)$	• $Q_5=Q_3-Q_4 \cdot (T_3-T_5) / T_4$	• $Q_8=$	• $Q_{11}=T_{10} \cdot A_3 / A_{10}$			
• $T_2=T_1-T_3$	• $T_5=Q_5 \cdot S_1 \cdot 10^6$	• $T_8=T_6 \cdot A_6 \cdot A_7 / 10^4$	• $T_{11}=Q_{11} \cdot S_{11} / 10^6$			
• $S_2=10^6 \cdot (100-W_1) / 100$	• $S_5=S_1$	#REF!	• $S_{11}=10^4 \cdot A_{10}$			

**Material Balance Sheet**  
**[17MLD STP]**



A-1 Process Cal. EA&al 7MLD Jakkur STP Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

**Design Condition**

Item	7MLD STP-TSPS			
(1) Design Flow for the year 2049	Flow Rate			
		m3/d	m3/h	m3/s
	Daily Average	11,000	458	0.127
	Daily Maximum	11,000	458	0.127
	Hourly Max. Peak factor 2.25	24,750	1031	0.286
(1) Design Flow for the year 2034	Flow Rate			
		m3/d	m3/h	m3/s
	Daily Average	7,000	292	0.081
	Daily Maximum	7,000	292	0.081
	Hourly Max. Peak factor 2.25	15,750	656	0.182

**1. Inlet Chamber**

Item	7MLD STP-TSPS			
[1] Design Condition				
(1) Design Flow for the year 2049	Hourly Maximum	=	24,750	m3/d
		=	0.286	m3/sec
(2) Inlet Pipe				
Pipe Diameter	•	×		
Gradient		%		
Roughness Coefficient	n=	0.013	(Manning Formula)	
Full Pipe Flow Rate		m3/s		
(3) Influent Water Level	+	m		
[2] Geometry				
(1) Number of Basins	1	Basin		
(2) Depth of Basin	0.600	m	Approx.	
(3) Width of Basin	2.100	m	Approx.	
(4) Length of Basin	2.500	m	Approx.	
(5) Volume required of Basin	0.600	×	2.100	×
			2.500	=
				0.5
				m3
(6) Retention Time	0.600	×	2.100	×
			2.500	/
			0.286	×
				11.01
				sec
(7) Basin Demensions	Width	2.100	m	×
				Length
				2.500
				m
	×	Depth	0.600	m

**STP Process Calculation\_Supporting Report 12.2.3**

**2. Coarse Screen Channel**

Item	7MLD STP-TSPS					
[1] Geometry						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Width	0.400	m				
Height	0.600	m				
Floor Level	+	5.000	m			
Bottom	+	0.000	m			
Influent Water Level	+	0.500	m			
Velocity	0.286	/	0.400	/	0.500	/ 2
where Design Flow for the year 2049	=	0.715	<	1.000	m/sec	OK
Velocity	0.182	/	0.400	/	0.500	/ 1
where Design Flow for the year 2034	=	0.910	<	1.000	m/sec	OK
(2) Screen Channel						
Number	2.0	Main	+	1.0	Bypass	
Width	0.800	m				
Side Water Depth	0.600	m				
Velocity	0.286	/	0.800	/	0.600	/ 2
where Design Flow for the year 2049	=	0.298	≐	0.450	m/sec	OK
Velocity	0.182	/	0.800	/	0.600	/ 1
where Design Flow for the year 2034	=	0.379	<	0.450	m/sec	OK
(3) Channel Dimensions	Width	0.8	m	×	Length	6.0 m
	×	SWD	0.6	m		
[3] Equipment						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Dimension	Width	0.4	m	×	Height	0.60 m
Design Water Level		m				
(2) Coarse Screens (Main Channel)						
Number	2	W	+	0	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	0.8	m				
Width of side plate	50	mm				
Side Water Depth	0.6	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.286	/	0.700	/	0.550	/ 2
	×	( 20	+	9 )/	20	
	=	0.539	<	0.800	m/sec	OK
Velocity through screen	0.182	/	0.700	/	0.550	/ 1
where Design Flow for the year 2034	×	( 20	+	9 )/	20	
	=	0.685	<	0.800	m/sec	OK
(3) Coarse Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	50	mm				
Bar Thickness	9	mm				
Channel Width	0.8	m				
Side Water Depth	0.6	m				
Velocity through screen	0.286	/	0.800	/	0.600	/ 2
where Design Flow for the year 2049	×	( 50	+	9 )/	50	
	=	0.352	<	0.800	m/sec	OK
Velocity through screen	0.182	/	0.800	/	0.600	/ 1
where Design Flow for the year 2034	×	( 50	+	9 )/	50	
	=	0.447	<	0.800	m/sec	OK

A-1 Process Cal. EA&al 7MLD Jakkur STP Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

**3. Raw Sewage Sump**

Item	7MLD STP-TSPS	
[2] Geometory		
(1) Raw Sewage Sump		
Number	1	Basin
Dia	9.50	m
Pump Operating Depth	1.000	m
Retention Time whe Design Flow for the year 2049	$( 9.50^2 \times \pi / 4 \times 1.000 ) / 0.286 / 60$ = 4.13	> 3.75 min (=minimum time of one pump cycle) OK
Retention Time whe Design Flow for the year 2034	$( 9.50^2 \times \pi / 4 \times 1.000 ) / 0.182 / 60$ = 6.49	> 3.75 min (=minimum time of one pump cycle) OK
High Water Level	+ 0.000	m
Pump Off Level	+ -1.000	m
[3] Equipment		
(1) Sewage Pumps 1		
Number	2	W + 1 S
Bore Diameter	200	mm
Discharge Flow : 40% Q* 2 whe Design Flow for the year 2034	$0.182 \times 3600 \times 40.0\%$ = 262	$\Rightarrow 270$ m <sup>3</sup> /Hr
Total Head	15.0	m
(2) Sewage Pumps 2		
Number	1	W + 1 S
Bore Diameter	150	mm
Discharge Flow : 20% Q* 1 whe Design Flow for the year 2034	$0.182 \times 3600 \times 20.0\%$ = 131	$\Rightarrow 135$ m <sup>3</sup> /Hr
Total Head	15.0	m

A-1 Process Cal. EA&al 7MLD Jakkur STP Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

Item	***-STP 7MLD																																													
<b>1. STP Design Condition</b>																																														
(1) Design Flow Rate	<table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th></th> <th>m<sup>3</sup>/d</th> <th>m<sup>3</sup>/h</th> <th colspan="2">m<sup>3</sup>/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td>7,000</td> <td>291.67</td> <td colspan="2">0.081</td> </tr> <tr> <td>Max Daily</td> <td>7,000</td> <td>291.67</td> <td colspan="2">0.081</td> </tr> <tr> <td>Max Hourly Peak factor 2.25</td> <td>15,750</td> <td>656.25</td> <td colspan="2">0.182</td> </tr> </tbody> </table>						m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s		Average Daily	7,000	291.67	0.081		Max Daily	7,000	291.67	0.081		Max Hourly Peak factor 2.25	15,750	656.25	0.182																						
	m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s																																											
Average Daily	7,000	291.67	0.081																																											
Max Daily	7,000	291.67	0.081																																											
Max Hourly Peak factor 2.25	15,750	656.25	0.182																																											
(2) Design Water Quality	<p style="text-align: right;">Unit: mg/L</p> <table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th colspan="2">TP</th> </tr> <tr> <th>NH<sub>4</sub>-N</th> <th>Org-N</th> <th>NOx-N</th> <th>D-P</th> <th>P-P</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td>350</td> <td>800</td> <td>450</td> <td>45.5</td> <td>17.5</td> <td>7</td> <td>5</td> <td>2</td> </tr> <tr> <td>Outlet</td> <td>10</td> <td>50</td> <td>10</td> <td>1</td> <td>0</td> <td>9</td> <td>1</td> <td>1</td> </tr> <tr> <td>Removal rate</td> <td>97.1%</td> <td>93.7%</td> <td>97.8%</td> <td colspan="3">85.7%</td> <td colspan="2">71.4%</td> </tr> </tbody> </table>						BOD	COD	SS	T-N			TP		NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P	Inlet	350	800	450	45.5	17.5	7	5	2	Outlet	10	50	10	1	0	9	1	1	Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%	
	BOD	COD	SS	T-N						TP																																				
				NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P																																						
Inlet	350	800	450	45.5	17.5	7	5	2																																						
Outlet	10	50	10	1	0	9	1	1																																						
Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%																																							
<b>2. Inlet Chamber</b>																																														
<b>[1] Design Condition</b>																																														
(1) Design Flow Rate	Max Hourly	=	15,750	m <sup>3</sup> /day																																										
		=	0.182	m <sup>3</sup> /sec																																										
<b>[2] Geometry</b>																																														
(1) Number of Basins	1	Basin																																												
(2) Depth of Basin	1.500	m																																												
(3) Width of Basin	1.700	m																																												
(4) Length of Basin	2.000	m																																												
(5) Volume required of Basin	1.500	×	1.700	×	2.000 = 1.3 m <sup>3</sup>																																									
(6) Retention Time	1.500	×	1.700	×	2.000 / 0.182 × 1 = 28.02 sec																																									
(7) Basin Dimensions	Width	1.700 m	×	Length	2.000 m																																									
		×	Depth	1.500 m																																										

A-1 Process Cal. EA&al 7MLD Jakkur STP. Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Wastewater Flow	$\begin{aligned} \text{Max Hourly} &= 15,750 \text{ m}^3/\text{d} \\ &= 0.182 \text{ m}^3/\text{sec} \end{aligned}$
[2] Geometory	
(1) Inlet Gate	
Number	2 Main + 1 Bypass
Width	0.300 m
Height	0.450 m
Floor Level	+ 2.000 m
Bottom	+ 0.000 m
Influent Water Level	+ 0.300 m
Velocity	$\begin{aligned} &0.182 \text{ } \swarrow \quad 0.300 \text{ } \swarrow \quad 0.300 \text{ } \swarrow \quad 2 \\ = &1.011 \text{ } \div \quad 1.000 \text{ m/sec} \end{aligned}$
(2) Screen Channel	
Number	2 Main + 1 Bypass
Width	0.600 m
Side Water Depth	0.400 m
Velocity	$\begin{aligned} &0.182 \text{ } \swarrow \quad 0.600 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 2 \\ = &0.379 \text{ } \div \quad 0.450 \text{ m/sec} \end{aligned}$
(3) Channel Dimensions	$\begin{aligned} \text{Width} &0.6 \text{ m} \times \text{Length} &6.0 \text{ m} \\ &\times \text{SWD} &0.4 \text{ m} \end{aligned}$
[3] Equipment	
(1) Inlet Gate	
Number	2 W + 1 S
Dimension	Width 0.3 m × Height 0.45 m
Design Water Level	2.00 m
(2) Fine Screens (Main Channel)	
Number	2 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	0.6 m
Width of side plate	50 mm
Side Water Depth	0.4 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	$\begin{aligned} &0.182 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 0.350 \text{ } \swarrow \quad 2 \\ &\times ( \frac{6}{6} + \frac{2}{6} ) \\ = &0.693 < 0.800 \text{ m/sec} \end{aligned}$
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	0.6 m
Side Water Depth	0.4 m
Velocity through screen	$\begin{aligned} &0.182 \text{ } \swarrow \quad 0.600 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 2 \\ &\times ( \frac{20}{20} + \frac{9}{20} ) \\ = &0.550 < 0.800 \text{ m/sec} \end{aligned}$

A-1 Process Cal. EA&al 7MLD Jakkur STP Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>4. Grit Chamber</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Peak flow = 15,750 m <sup>3</sup> /day = 0.182 m <sup>3</sup> /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0111 m/sec = 960 m <sup>3</sup> /m <sup>2</sup> /day
(4) Average Velocity	0.3 m/sec
<b>[2] Grit Chamber</b>	
(1) Surface Area required	0.182 / 0.0111 = 16.40 m <sup>2</sup>
(2) Number of Basins	1 S + 1 W
(3) Surface Area required/Basin	16.4 / 1 = 16.40 m <sup>2</sup>
(4) Length of Basin	16.40 ^0.5 = 4.0 m → 4.5 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.182 × 60 sec / 1 = 10.9 m <sup>3</sup>
(7) Depth required	10.9 / 4.5 / 4.5 = 0.539 m
(8) Basin Dimensions	Width 4.5 m × Length 4.5 m × Depth 0.5 m (Freeboard 0.3m)
(9) Retention Time	4.5 × 4.5 × 0.5 / 0.182 × 1 = 60.00 sec
(10) Surface Overflow Rate at Peak Flow	15,750 / 4.5 / 4.5 / 1 = 777.777778 < 960 m <sup>3</sup> /m <sup>2</sup> /day
<b>[3] Parshall Flume</b>	
(1) Design Flow Rate	Q= 182.000 l/sec
(2) Throat width	W= 0.450 m
(3) Water depth Ha	Ha= ( Q / 2264 / W ) <sup>2/3</sup>
(4) Crest Level	Ha= 0.317 m
(5) Water level at the crest	+ 0.317 m ≐ Minimum water level at downstream channel
(6) Channel bottom level	+ m
(7) Upstream Channel width	1.500 m
(8) SWD of Upstream Channel	0.700 m
(9) Average velocity at upstream channel	0.173 m/sec
(10) Total Length of channel	10.000 m
<b>[4] Inlet Weir Gate</b>	
(1) Number	2 Units
(2) Weir Width	0.600 m
(3) Stroke	0.450 m
(4) Overflow Height	0.400 m
(5) Overflow Height (actual)	( 0.182 / 1.840 / 0.600 / 2 ) <sup>2/3</sup> = 0.189 < 0.400 m



**STP Process Calculation Supporting Report 12.2.3**

<b>5. Reactor</b>																																																								
<b>[1] Design Condition</b>																																																								
(1) Design Wastewater Flow	Q = 7,000 m <sup>3</sup> /day (summer) Q' = 7,000 m <sup>3</sup> /day (Winter)																																																							
(2) Design Sewage Quality																																																								
Inlet BOD	350 mg/l																																																							
Outlet BOD	10.0 mg/l																																																							
Inlet S-BOD	235 mg/l assumed as 67% of BOD																																																							
Inlet COD	800 mg/l																																																							
Inlet bCOD : S <sub>0</sub>	578 mg/l																																																							
Inlet nbCOD	223 mg/l																																																							
bCOD/BOD	1.65																																																							
Inlet S-COD : sCOD	271 mg/l																																																							
Inlet rbCOD	231 mg/l bCOD*40%																																																							
Inlet sbCOD	347 mg/l bCOD*60%																																																							
Outlet S-COD : nbsCODE	40 mg/l																																																							
Inlet nbpCOD : nbpCOD	183 mg/l = TCOD-bCOD-nbsCODE																																																							
Inlet SS	450 mg/l																																																							
Inlet VSS	383 mg/l assumed as 85% of TSS																																																							
: VSS <sub>COD</sub>	1.38 gCOD/gVSS = TCOD-sCOD/VSS																																																							
: nbVSS	131.96 gnbVSS/m <sup>3</sup> = nbpCOD/VSS <sub>COD</sub>																																																							
: iTSS	67.50 gnbVSS/m <sup>3</sup> = TSS-VSS																																																							
Inlet T-N	70 mg/l																																																							
Inlet TKN	70 mg/l																																																							
Inlet NH <sub>4</sub> -N	45.0 mg/l																																																							
Inlet T-P	7 mg/l																																																							
Inlet D-P	5 mg/l																																																							
Inlet Alkalinity as CaCO <sub>3</sub>	380 mg/l																																																							
Outlet Kjeldahl N	1.0 mg/l																																																							
Outlet NH <sub>4</sub> -N	1.0 mg/l																																																							
Outlet NO <sub>3</sub> -N	9.0 mg/l																																																							
Outlet T-P	2 mg/l																																																							
Outlet D-P	1 mg/l																																																							
(3) Water Temperature	T = 20.0 °C																																																							
(4) Safety Factor for Nitrogen	SF = 1.5																																																							
(5) Return Sludge Concentration	R <sub>s</sub> = 8,000 mg/l																																																							
(6) MLSS MLVSS	X <sub>TSS</sub> = 3,000 mg/l																																																							
(7) DO in the Reactor	2 mg/L																																																							
<b>[2] Design Value for perfect Nitrification of Nitrification Process</b>																																																								
(1) Activated sludge design kinwtic coefficients at 20°C																																																								
	<table border="1"> <thead> <tr> <th>Coefficient</th> <th>Unit</th> <th>COD oxidatio</th> <th>NH<sub>4</sub> oxidatio</th> <th>NO<sub>2</sub> oxidatio</th> </tr> </thead> <tbody> <tr> <td>μ<sub>max</sub></td> <td>gVSS/gVSS · d</td> <td>6.000</td> <td>0.900</td> <td>1.000</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>mg/L</td> <td>8.000</td> <td>0.500</td> <td>0.200</td> </tr> <tr> <td>Y</td> <td>gVSS/g substrate oxidized</td> <td>0.450</td> <td>0.150</td> <td>0.050</td> </tr> <tr> <td>b</td> <td>gVSS/gVSS · d</td> <td>0.120</td> <td>0.170</td> <td>0.170</td> </tr> <tr> <td>fd</td> <td>unitless</td> <td>0.150</td> <td>0.150</td> <td>0.150</td> </tr> <tr> <td>K<sub>O<sub>2</sub></sub></td> <td>mg/L</td> <td>0.200</td> <td>0.500</td> <td>0.900</td> </tr> <tr> <td>θ Value</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>μ<sub>max</sub></td> <td>unitless</td> <td>1.070</td> <td>1.072</td> <td>1.063</td> </tr> <tr> <td>b</td> <td>unitless</td> <td>1.040</td> <td>1.029</td> <td>1.029</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>unitless</td> <td>1.000</td> <td>1.000</td> <td>1.000</td> </tr> </tbody> </table> <p>Wastwater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF &amp; EDDY/AECOM)</p>	Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio	μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200	Y	gVSS/g substrate oxidized	0.450	0.150	0.050	b	gVSS/gVSS · d	0.120	0.170	0.170	fd	unitless	0.150	0.150	0.150	K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900	θ Value					μ <sub>max</sub>	unitless	1.070	1.072	1.063	b	unitless	1.040	1.029	1.029	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000
Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio																																																				
μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200																																																				
Y	gVSS/g substrate oxidized	0.450	0.150	0.050																																																				
b	gVSS/gVSS · d	0.120	0.170	0.170																																																				
fd	unitless	0.150	0.150	0.150																																																				
K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900																																																				
θ Value																																																								
μ <sub>max</sub>	unitless	1.070	1.072	1.063																																																				
b	unitless	1.040	1.029	1.029																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000																																																				
(2) μ <sub>AOB</sub>	μ <sub>AOB</sub> = 0.3100 g/g · d = μ <sub>max, AOB</sub> [S <sub>NH<sub>4</sub></sub> / (S <sub>NH<sub>4</sub></sub> + K <sub>NH<sub>4</sub></sub> )] [S <sub>O</sub> / (S <sub>O</sub> + K <sub>O, AOB</sub> )] - b <sub>AOB</sub>																																																							
μ <sub>max, AOB, T</sub>	μ <sub>max, AOB, T</sub> = 0.9000 g/g · d = μ <sub>max</sub> * 1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900																																																							
b <sub>AOB, T</sub>	b <sub>AOB, T</sub> = 0.1700 = b * 1.029 <sup>(T-20)</sup> b at 20°C = 0.170																																																							
S <sub>NH<sub>4</sub></sub>	S <sub>NH<sub>4</sub></sub> = 1.0000 mg/l																																																							
DO	DO = 2.0000 mg/l																																																							
K <sub>O, AOB</sub>	K <sub>O, AOB</sub> = 0.5000 mg/l																																																							

A-1 Process Cal\_EA&al 7MLD Jakkur STP\_Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

(2) Design SRT	SRT= 4.8387 day ⇒ 5.0000 day	$=1/\mu_{AOB} \times SF$
(3) Biomass production		
P <sub>X,VSS</sub>	P <sub>X,VSS</sub> = 2188.927 kg/d	=P <sub>X,bio</sub> +Q(nbVSS)
P <sub>X,TSS</sub>	P <sub>X,TSS</sub> = 2884.700 kg/d	=P <sub>X,bio</sub> /0.85+Q(nbVSS)+Q(TSS <sub>0</sub> -VSS <sub>0</sub> )+5*Q*Al
S	S= 0.4507 mg/l	=K <sub>s</sub> [1+b <sub>H</sub> (SRT)]/[SRT(μ <sub>m</sub> -b <sub>H</sub> )-1]
b <sub>H</sub>	b <sub>H</sub> = 0.1200	=b*1.04 <sup>(T-20)</sup> b at 20°C = 0.120
Y <sub>H</sub>	Y <sub>H</sub> = 0.4500 gVSS/g bCOD	
μ <sub>m,T</sub>	μ <sub>m,T</sub> = 6.0000 g/g·d	=μ <sub>max</sub> *1.04 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 6.000
Y <sub>n</sub>	Y <sub>n</sub> = 0.150 gVSS/g Nox	
NO <sub>x</sub>	NO <sub>x</sub> = 47.400 mg/l	
P <sub>X,bio,VSS</sub>	P <sub>X,bio,VSS</sub> = 1265.214 kg VSS/d	=Q·Y <sub>H</sub> (S <sub>0</sub> -S)/[1+b <sub>H</sub> (SRT)]+f <sub>d</sub> ·b <sub>H</sub> ·QY <sub>H</sub> (S <sub>0</sub> -S)SRT/[1+b <sub>H</sub> (SRT)]
	1136.066	+QY <sub>n</sub> (Nox)[2+b <sub>AOB</sub> (SRT)]
	102.246	=Q·Y <sub>H</sub> (S <sub>0</sub> -S)/[1+b <sub>H</sub> (SRT)]
	26.903	=f <sub>d</sub> ·b <sub>H</sub> ·QY <sub>H</sub> (S <sub>0</sub> -S)SRT/[1+b <sub>H</sub> (SRT)]
		=QY <sub>n</sub> (Nox)[1+b <sub>AOB</sub> (SRT)]
NO <sub>x</sub>	NO <sub>x</sub> = 47.311 mg/l	=TKN-Ne-0.12P <sub>X,bio</sub> /Q
(4) Required Aeration Tank Volume		
V <sub>a</sub>	V <sub>a</sub> = 4,808 m <sup>3</sup>	
τ	τ = 16.48 hr ⇒ 18.00 hr	=V <sub>a</sub> /Q × 24
X <sub>VSS</sub> ·V <sub>a</sub>	X <sub>VSS</sub> ·V <sub>a</sub> = 10,945 kg VSS	=P <sub>X,VSS</sub> ·SRT
X <sub>TSS</sub> ·V <sub>a</sub>	X <sub>TSS</sub> ·V <sub>a</sub> = 14,423 kg TSS	=P <sub>X,TSS</sub> ·SRT
F/M	F/M= 0.224 kgBOD/kgMLVSS	
FractionVSS=	FractionVSS= 0.759	
MLVSS=	MLVSS= 2276 mg/L	
(5) BODloading	BODloading= 0.510 kg/m <sup>3</sup> ·d	
(6) Observed Yield		
Y <sub>obs,TSS</sub>	Y <sub>obs,TSS</sub> = 1.178 gTSS/gBOD	
Y <sub>obs,VSS</sub>	Y <sub>obs,VSS</sub> = 0.894 gVSS/gBOD	
bCODremoved=	bCODremov= 4,039 kg/d	
(7) effluent NO <sub>2</sub> -N	NO <sub>2</sub> -N= 0.2315 mg/l	=K <sub>s</sub> [1+b <sub>NOB</sub> (SRT)]/[SRT(μ <sub>NOB</sub> -b <sub>NOB</sub> )-1]
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700	=b*1.029 <sup>(T-20)</sup> b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 1.0000 g/g·d	=μ <sub>max</sub> *1.04 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 1.000
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.6897 g/g·d	=μ <sub>max,NOB</sub> [S <sub>0</sub> /(S <sub>0</sub> +K <sub>O2,NOB</sub> )]
	S <sub>0</sub> = 2.000 mg/l	
	K <sub>O2,NOB</sub> = 0.900 mg/l	
(8) effluent NH <sub>4</sub> -N	NH <sub>4</sub> -N= 0.5286 mg/l	=K <sub>s</sub> [1+b <sub>NOB</sub> (SRT)]/[SRT(μ <sub>NOB</sub> -b <sub>NOB</sub> )-1]
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700	=b*1.029 <sup>(T-20)</sup> b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 0.9000 g/g·d	=μ <sub>max</sub> *1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.7200 g/g·d	=μ <sub>max,NOB</sub> [S <sub>0</sub> /(S <sub>0</sub> +K <sub>O2,NOB</sub> )]
	S <sub>0</sub> = 2.000 mg/l	
	K <sub>O2,NOB</sub> = 0.500 mg/l	
(9) Ratio of Return Sludge	8,000·Rr/(1+Rr)= 3,000 mg/L 3,000/(8,000-3,000)= 0.60 Rr = 0.60	

A-1 Process Cal\_EA&al 7MLD Jakkur STP Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

<b>[3] Design for Nitrification and Denitrification Process</b>																					
(1) Active biomass concentration	$X_b = Q \cdot (SRT) / V \cdot Y_H \cdot (S_0 - S) [1 + b_H(SRT)]$ = 1,181.47 mg/l																				
(2) IR ratio	$IR = NO_x / Ne - 1.0 - R$ = 3.66																				
(3) The amount of NO <sub>3</sub> -N fed to the anoxic tank	$Nox\ feed = (IR + R) \cdot Q \cdot Ne$ = 268,174.27 kg/d																				
(4) The anoxic tank volume	$V_{nor} = 481\ m^3 = V_a \times 10\%$ $V_{nor} = 1,458\ m^3 \quad \tau_{DN} = 5.000\ h$																				
(5) F/M <sub>b</sub>	F/M <sub>b</sub> = 1.42 g/g·d																				
(6) Fraction of rbCOD	40.00% = rbCOD/bCOD																				
	<table border="1"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b<sub>0</sub></th> <th>b<sub>1</sub></th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>	Percent rdCOD(%)	SDNR equation coefficients		b <sub>0</sub>	b <sub>1</sub>	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162
Percent rdCOD(%)	SDNR equation coefficients																				
	b <sub>0</sub>	b <sub>1</sub>																			
10	0.186	0.078																			
20	0.213	0.118																			
30	0.235	0.141																			
40	0.242	0.152																			
50	0.270	0.162																			
(8) SDNR <sub>b</sub>	$SDNR_b = 0.296\ g/g \cdot d = b_0 + b_1 [\ln(F/M_b)]$ $b_0 = 0.242$ $b_1 = 0.152$																				
(8) SDNR	$SDNR = 0.110\ g/g \cdot d = SDNR_b (MLVSS_r / MLVSS)$ $SDNR_{adj} = 0.212\ g/g \cdot d = SDNR_b - 0.029 \ln(F/M_b) - 0.012 \quad IR=3-4$ $= SDNR_b - 0.0166 \ln(F/M_b) - 0.078 \quad IR=2$ $SDNR_t = 0.296\ g/g \cdot d = SDNR_b \cdot \theta^{(F-20)} \quad \theta = 1.026$																				
(9) NO <sub>r</sub>	$NO_r = 364,695.16\ kg/d = N_{nox} \cdot SDNR \cdot X_b$ $> Nox\ feed = 268,174\ kg/d$																				
(10) Alkalinity to be added to maintain pH7	-108.33 mg/l																				
	Influent Alk 380.00 mg/l Alk used 338.44 mg/l = 7.14 × Nox Alk produced 136.77 mg/l = 3.57 × (NO <sub>x</sub> - NO <sub>xe</sub> ) Alk to maintain 70.00 mg/l																				
<b>[4] Design of Phosphorus Removal Process</b>																					
(1) Removal T-P	3.13 mg/l																				
P in waste sludge	px = 1.00%																				
Generated waste sludge	Px <sub>vss</sub> = 2188.927 kg/d																				
Rmval Phosphorus	21.88926619 kg/d																				
(2) Effluent T-P without Al	3.87 mg/l																				
(3) Required Al to initial soluble phosphorus ratio	1.00 mol/mol																				
(4) Required Al dosing rate	3.48 mg/l as Al																				
	42.98 mg/l as crystal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> · 18H <sub>2</sub> O																				
(5) Required Aluminum Sulfate	300.84 kg/d																				
(6) Required Aluminum Sulfate solution 10%	2.87 m <sup>3</sup> /d																				
	119.38 L/H																				
(7) Additional sludge	121.96 kg/d																				

A-1 Process Cal. EA&al 7MLD Jakkur STP Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**[5] Reactor**

(1) Total volume of Aeration Basins

$$V_A = Q \cdot \theta_a / 24$$

$$= 5,250 \text{ m}^3$$

(2) Total volume of Anoxic Basins

$$V_{DN} = Q \cdot \theta_{DN} / 24$$

$$= 1,458 \text{ m}^3$$

Item	Volume required	Retention Time required		Ratio of Volume	
		Summer	Winter		
unit	m <sup>3</sup>	hour	hour		
Anaerobic	V <sub>AN</sub>	440	1.50	1.50	0.30
Anoxic	V <sub>DN</sub>	1,458	5.00	5.00	1.00
Aerobic	V <sub>A</sub>	5,250	18.00	18.00	3.60
Total	V	7,148	24.50	24.50	

**[6] Geometry**

(1) Basin Dimensions

Width      Length      Depth      Basins  
 8.0            84.0            5.5            2

Cross Section

$$8.0 \times 5.5 = 44.0 \text{ m}^2/\text{Basin}$$

Hantzsch Subtraction

$$= 1.0 \text{ m}^2/\text{Basin}$$

after Subtraction

$$44.0 - 1.0 = 43.0 \text{ m}^2/\text{Basin}$$

Total Volume

$$43.0 \times 84.0 = 3,612 \text{ m}^2/\text{Basin} \quad 7,224 \text{ m}^3/\text{Total}$$

(2) Partition of Basin

Item	unit	Anaerobic	Anoxic	Aerobic	Total
Cross Section	m <sup>2</sup>	43.0			
Length required	m	5.1	17.0	61.0	83.1
Volume required per Basin	m <sup>3</sup>	220	729	2,625	3,574
Total Volume required	m <sup>3</sup>	440	1,458	5,250	7,148
Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0	
Actual Length	m	6.0	17.0	61.0	84.0
Actual Volume per Basin	m <sup>3</sup>	258	731	2,623	3,612
Actual Total Volume	m <sup>3</sup>	516	1,462	5,246	7,224
Actual Ratio of Volume		0.35	1.00	3.59	
Actual Retention Time	hour	1.77	5.01	17.99	24.77

**[7] Equipment**

(1) Ras Pumps

Ras Ratio

60%

Required Capacity

$$7,000 \text{ m}^3/\text{day} \times \frac{60\%}{24} = 175 \text{ m}^3/\text{Hr}$$

$$= 88 \text{ m}^3/\text{Hr} \Rightarrow 90 \text{ m}^3/\text{Hr}$$

Number

2 Work

2 Stanby

(2) Circulation Pumps

Ras Ratio

366%

Required Capacity

$$7,000 \text{ m}^3/\text{day} \times \frac{366\%}{24} = 1050 \text{ m}^3/\text{Hr}$$

$$= 267 \text{ m}^3/\text{Hr} \Rightarrow 270 \text{ m}^3/\text{Hr}$$

Number

4 Work

2 Stanby

(3) SAS Pumps

Excess Sludge

380 m<sup>3</sup>/day

Sludge withdraw

12 Times/day

Running Time

0.5 Hr/Time

Required Capacity

$$380 \text{ m}^3/\text{day} \div \frac{12}{0.5} = 15.8 \text{ m}^3/\text{Hr} \Rightarrow 16 \text{ m}^3/\text{Hr}$$

$$= 31.64 \text{ m}^3/\text{Hr} \Rightarrow 35 \text{ m}^3/\text{Hr}$$

Number

2 Work

2 Stanby

A-1 Process Cal\_EA&al 7MLD Jakkur STP\_Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

(4) Alum Solution Tank										
Number	2	W	+	0	S					
Alum concentration as crystal	10 %									
Gravity of dissolved dechlorine	1.05									
Required solution volume	300.84 kg / d		×	100	/	10	/	1.05	/	1000
	=	2.87		m3/d						
Volume of Tank	2.6			m3/tank						
Total Volume of Tanks	5.2			m3	(Duration=	1.81	day)			
(5) Mixer for Alum Solution Tank										
Number	2	W	+	0	S					
(6) Alum Dosing Pump										
Number	2	W	+	1	S					
Capacity	2.87 m3/d	/	24	×	1000	/	2	×	2	
	119.38 l/h/unit		⇒	120	l/h/unit					

A-1 Process Cal. EA&al 7MLD Jakkur STP Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>6. Air Requirement at Average Flow</b>	
[1] Design Condition	
(1) AOR	AOR = 3,029 kg/day = 126.2 kg/h
Q <sub>in</sub> : Design Average Flow m <sup>3</sup> /d	7,000
Inlet bCOD : S <sub>0</sub>	578 mg/l
S=	0.451 mg/l
Nox=	47.400 mg/l
P <sub>X,bio</sub> =	1,238.3 kg VSS/d does not include nitrifying bacteria
R <sub>0</sub> =	R <sub>0</sub> = Q(S <sub>0</sub> - S - k(Nox - NOx)) - 1.42P <sub>X,bio</sub> + 4.57Q · NOx
R <sub>0</sub> =	3,029 kg O <sub>2</sub> /d
k=	2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{\text{AOR} \times C_s \cdot a \times 1.024^{20-T}}{\alpha \times F (\beta \cdot C_{sw} / C_s \cdot (P_b / P_a) a - C_A)}$
	C <sub>s</sub> : Saturated DO at sea level and 20 °C 9.09 mg/L
	C <sub>sw</sub> : Saturated DO at sea level and operating Temperature 9.09 mg/L at 20 °C
	20-T : 0.0 1.024 <sup>20-T</sup> : 1.0000
	C <sub>A</sub> : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1 + 0.40D <sub>j</sub> /P <sub>a</sub> 1.19357
	D <sub>j</sub> : Tank Liquid Depth 5.00 m
	P <sub>a</sub> : Standard absolute pressure at s 10.332 m
	P <sub>b</sub> : Absolute pressure at Plant Site Elevation m
	P <sub>b</sub> /P <sub>a</sub> : exp[-gM(z <sub>b</sub> -z <sub>a</sub> )/R*T] 0.900
	g : Acceleration due to Gravity 9.80665 m/s <sup>2</sup>
	M : Mole of Air 28.97 kg/kg-mole
	z <sub>b</sub> : Plant Site Elevation 900 m
	z <sub>a</sub> : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 293.15 Kelvin
	α : relative Transfer Rate to clean Water 0.65
	β : relative DO Saturation to clean Water 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{32,858}{4.2591} = 7,714.69 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Standard O <sub>2</sub> required at Field Conditions per Basin =	3,857 kg/day
(5) SOTE for the above Effective Aeration Depth	28.0 %
(6) Fraction of O <sub>2</sub> in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	15%
(9) Air required at Field Conditions per Basins	= 56,731 m <sup>3</sup> /day = 2,363.8 m <sup>3</sup> /hr
[2] Equipment	

Air Requirement at Average Flow 12/21

A-1 Process Cal. EA&amp;al 7MLD Jakkur STP Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

(1) Air Blower					
Number	4	W	+	2	S
Required Capacity	2363.8	m <sup>3</sup> /Hr·Basin	/	2	unit/Basin
	= 1181.9	m <sup>3</sup> /h	⇒	1200	m <sup>3</sup> /h /Unit
Pressure	65	kPa			
Safety Factor	10	%			
Heat capacity ratio	1.4				
Atmospheric pressure at site elevation	91.234	kPa			
Total inlet pressure	89.234	kPa			
Volume rate of flow at inlet point	22.704	m <sup>3</sup> /min			
Total discharge pressure	156.234	kPa			
Overall adiabatic efficiency	0.65				
Inlet air temperature (min.)	15	°C			
Shaft power	32.101	kW			
Rated Output of Motor	35.311	kW	⇒	37	kW

A-1 Process Cal. EA&al 7MLD Jakkur STP\_Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>7. Final Clarifire</b></p>			
<p>[1] <b>Design Condition</b></p>			
<p>(1) Design Wastewater Flow</p>	<p>Q= 7,000 m<sup>3</sup>/day</p>		
<p>(2) Water Temperature</p>	<p>T= 20.0 °C</p>		
<p>(3) MLSS</p>	<p>X<sub>ef</sub>= 3,000 mg/l</p>		
<p>(4) SVI</p>	<p>SVI= 300</p>		
<p>(5) Sedimentation Velocity</p>	$v = 4.899 \cdot 10^6 \cdot T^{(0.954)} \cdot X_{ef}^{(-1.354)} \cdot SVI^{(-0.77)}$ $= 4.899 \cdot 10^6 \cdot 20.0^{0.954} \cdot 3,000^{-1.354} \cdot 150^{-0.770}$ $= 20.7 \text{ m/day}$		
<p>(6) Surface Overflow Rate required</p>	$S' = v / (1.5 \cdot 1) = 20.7 / (1.5 \cdot 1.0) = 13.8 \text{ m}^3/\text{m}^2 \cdot \text{day}$	<p>→</p>	$12.0 \text{ m}^3/\text{m}^2 \cdot \text{day}$
<p>[2] <b>Geometry</b></p>			
<p>(1) Surface Area required</p>	$A = 7,000 / 12.0 = 583 \text{ m}^2$		
<p>(2) Demensions</p>	<p>Diameter                  Depth          Basin</p>		
	<p><b>19.5                          3.5                  2</b></p>		
<p>(3) Actual Surface Area</p>	$S = 19.5^2 \cdot 3.14 / 4 \cdot 2.0 = 597 \text{ m}^2$		
<p>(4) Surface Overflow Rate</p>	$S = 7,000 / 597 = 11.7 \text{ m}^3/\text{m}^2 \cdot \text{day}$		



**STP Process Calculation Supporting Report 12.2.3**

8. Chlorination	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 7,000 m <sup>3</sup> /day 291.67 m <sup>3</sup> /h Peak Flow 15,750 m <sup>3</sup> /day 656.25 m <sup>3</sup> /h
(2) Contact Time	30 min
(3) Type of Chlorine	Cl <sub>2</sub> -GAS
(4) Design Chlorine Dosage Rate	10 mg/L
(5) Required Chlorine per day	Average Daily Flow / 1000 × Design Chlorine Dosage Rate = 70.0 kg/d = 2.92 kg/h
<b>[2] Chlorination Contact Tank</b>	
(1) Volume required	Average Daily Flow / 1440 × Contact Time = 145.8 m <sup>3</sup>
(2) Nos. of lanes	3 lanes
(3) Width of lane	2.00 m
(4) Length of lane	13.00 m
(5) Side Water Depth	2.00 m
(6) Nos. of Tanks	1 tank
(7) Total Width of Tank	6.80 m Approx..
(8) Average Velocity	Decant Flow / 3600 / Width / Depth = 291.67 / 3600 / 2.00 / 2.00 = 0.020 m/sec
(9) Total Volume	Width × Length × Depth × Nos. of lanes × Nos. of Tanks = 2.0 m × 13.0 m × 2.0 m × 3 × 1 = 156 m <sup>3</sup> > 145.8 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Chlorine Dosing Condition	
Operation Dosage Rate -1	DC1 10 mg/L
(2) Chlorine Cylinder	
Type	- Cylindrical Convexsd Container
Cylinder Capacity	Cc 928 kg/cylinder
Average Dosage Rate -1	q1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 70 kg/day
Maximum Dosage Rate -1	q3 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 158 kg/day
Storage day	T More than 15 days
Required Storage Capacity	EC1 D × T = 1,050 kg
Unit Number	EN1 EC1 / Cc = 1.1 cylinders
Maximum Operation Numbers	
Cl <sub>2</sub> -Gas Volatilize Rate	Vr1 ##### @ 20°C Standard temperature
Maximum Dosing Rate	DC1 10 mg/L, Q <sub>T-D</sub> × q3 × 10 <sup>-3</sup> / 24 = 6.56 kg/h
Operation Numbers	EN2 DC1 / Vr1 = 0.8sets
Number	2 W + 2 S
(3) Chlorinator	
Type	Solution Feed Vacuum Type
Number	1 W + 1 S
Operation Dosage Rate -1	Dq1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 157.5 kg/day
Required Dosage Rate	Chlorine -1 : Dq1 / (EN1 × 24) = Minimum 0.00 kg/hr Maximum 6.6 kg/hr

**STP Process Calculation Supporting Report 12.2.3**

(4) Chlorine Booster Pump	Branchy on the water supply pipe
Type	Water requiamet for mixed Chlori
Water Demand	(kg/hr) 1.0 1.5 2.0 2.5 3.0 4.0
Chlorinator Discharge	(L/min) 15 20 25 30 35 40
Water Demand	(kg/hr) 5.0 6.0 10.0 50.0 100.0 200.0
Chlorinator Discharge	(L/min) 45 50 60 300 600 1,200
Water Demand	-
Water requiamet	Qp1 Maximum dosage rate 6.6 kg/hr
For Chlorin	therefore 60 L/min
Booster Pump Type	Single suction volute pump
Number	1 W + 1 S
<b>9. Dechlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 7,000 m <sup>3</sup> /day
(2) Contact Time	10 min
(3) Type of Dechlorine	Sodium Thiosulfate (Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 5H <sub>2</sub> O)
(4) Free Residual Chlorine	1.0 mg/L assumed value
(5) Consumption per day	Average Daily Flow / 1000 × Free Residual Chlorine × 1.75
	× 1.5 (safety factor)
	= 18.4 kg/d
	= 0.77 kg/h
<b>[2] Dechlorination Contact Tank</b>	
(1) Volume required	Average Flow Rate / 60 × Contact Time
	= 48.6 m <sup>3</sup>
(2) Width of lane	6.80 m
(3) Length of lane	4.00 m
(4) Side Water Depth	2.00 m
(5) Nos. of Tanks	1 tank
(6) Total Volume	Width × Length × Depth
	= 6.8 m × 4.0 m × 2.0 m
	= 54 m <sup>3</sup> > 48.6 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Dechlorine Solution Tank	
Number	1 W + 0 S
Dechlorine concentration	10 %
Gravity of dissolved dechlorine	1.10
Required solution volume	18.38 kg/d × 100 / 10 / 1.10 / 1000
	= 0.17 m <sup>3</sup> /d
Volume of Tank	0.200 m <sup>3</sup> /tank (= 0.5 mW × 0.5 mL × 0.8 mH)
Total Volume of Tanks	0.200 m <sup>3</sup> (Duration= 1.20 day)
(2) Mixer for Dechlorine Solution Tank	
Number	2 W + 0 S
(3) Dechlorine Dosing Pump	
Number	1 W + 1 S
Capacity	0.38 m <sup>3</sup> /d / 24 × 1000 / 1
	15.66 l/h/unit ⇒ 16 l/h/unit

**STP Process Calculation Supporting Report 12.2.3**

<p><b>10. Centrifuge</b></p> <p><b>[1] Design Condition</b></p> <p>(1) Type of Dewatering</p> <p>(2) Generated Sludge</p> <p>(3) Design Polyelectrolyte Dosage</p> <p>(4) Volume of Thickend Sludge</p> <p>(5) Consistency of Dewatered Sludge</p> <p>(6) Operation Time</p> <p><b>[2] Volume of Centrifuges</b></p> <p><b>[3] Dewatered Solids</b></p> <p><b>[4] Dewatered Cake Volume</b></p> <p><b>[5] Polyelectrolyte</b></p> <p>(1) Design Polyelectrolyte Dosage</p> <p>(2) Required Polyelectrolyte</p> <p>(3) Dissolving concentration</p> <p>(4) Volume of Polyelectrolyte solution</p>	<p>Centrifuge 3,038 kg/day</p> <p>Polyelectrolyte 5 kg/t-DS·day</p> <p>379.7 m<sup>3</sup>/day</p> <p>82 %</p> <p>12 hours/day (6 days per week)</p> <p><u>Digested Solids</u> Operation Time × No. × Operation/week = <math>\frac{379.7}{12 \times 2} \times \frac{7}{6} = 18.5</math> → 19 m<sup>3</sup>/hour</p> <p>Digested Sludge × ( 1 + Injection Rate) = 3,038 × ( 1 + 0.0050 ) = 3,053 kg/day</p> <p>Dewatered Solids × <math>\frac{100}{100 - \frac{\text{Moisture Content}}{7}}</math> × 6 days per week = 3,053 × <math>\frac{100}{100 - \frac{82}{6}} \times \frac{7}{6}</math> = 19.79 t/day apparent specific gravity 1.00 19.79 / 1.0 = 19.8 m<sup>3</sup>/day</p> <p>Polyelectrolyte 5 kg/t-DS·day 15.19 kg/day 0.20 % 7.59 m<sup>3</sup>/day</p>
--	--

A-1 Process Cal. EA&al 7MLD Jakkur STP Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>[6] Equipment</b>	
(1) Centrifuge	
Capacity	19 m <sup>3</sup> /hr
Number	2 W + 1 S
(2) Centrifuge Feed Pumps	
Capacity	19 m <sup>3</sup> /hr
Number	2 W + 1 S
(3) Polyelectrolyte Dosing Pumps	
Volume of Polyelectrolyte solution	7.59 m <sup>3</sup> /day
Operation Time	12 hours/day (6 days per week)
Safety Factor	1.5
Number	2 W + 1 S
Required Capacity	7.59 m <sup>3</sup> /da × 7 / 6 / 12 / 2
	= 0.37 m <sup>3</sup> /Hr
Specification Capacity	0.37 m <sup>3</sup> /Hr × 1.5
	= 0.554 m <sup>3</sup> /Hr ⇒ 0.60 m <sup>3</sup> /Hr /Unit
(4) Polyelectrolyte dosing System	
Preparation time for solution	3 hr
Required dry polymer	15.19 kg/day × 7 / 6 / 12
	= 1.48 kg/hr
	= 4.43 kg per one batch
Feedong time per one batch	30 min
Capacity of Dry polymer Feeder	9 kg/h
Tanks Dimensions	Width 1.0 m × Length 1.5 m × Depth 1.5 m × 2
	= 4.5 m <sup>3</sup>
Retention Time of Tank	2.25 m <sup>3</sup> /tank / 0.37 m <sup>3</sup> /Hr / 2
	= 3.047 Hr > 3 Hr
Number	2 W + 0 S

A-1 Process Cal. EA&al 7MLD Jakkur STP Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>11. Centrifuge Feed Sump</b>	
<b>[1] Design Condition</b>	
(1) Generated Thickend Sludge	3,038 kg/day
(2) Solids Consistency	0.80 %
(3) Volume of Thickened Sludge	$\text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3}$ $= 3,038 \times \frac{100}{0.80} \times 10^{-3}$ $= 380 \text{ m}^3/\text{day}$ $= 15.82 \text{ m}^3/\text{h}$
(4) Sludge feed flow rate	19 m <sup>3</sup> /h × 2 = 38 m <sup>3</sup> /h
(5) Centrifuge Operation Time	12 hours/day ( 6 days per week)
<b>[2] Geometry</b>	
(1) Basin Dimensions	$\text{Width } 6.0 \text{ m} \times \text{Length } 6.0 \text{ m}$ $\times \text{Depth } 3.5 \text{ m} \times 2$ $= 252.0 \text{ m}^3$
<b>[3] Equipment</b>	
(1) Mixers for Centrifuge Feed Sumps	
Required Volume	252.0 m <sup>3</sup>
Number	1 W + 1 S

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Digestion Tank + Centrifugal Dewatering)

Table -1 Input Data

1. Calculation Manner		1) Premise that the quality of supernatants are same level removed with inlet sewage 2) Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency		1) Total Removal Ratio 2) Outlet Water Quality(input 1or2)
In case of 1 : input data		(%)
In case of 2 : input data		#REF!
3. Selection of Excess Sludge Generation		1) Consideration of Solid Matter Only 2) Consideration of Converting of Solved BOD(input 1or2)
In case of 1 : input data (Sludge generation)		Sludge generation ratio per removal SS(%)
In case of 2 : input data	a	0.4
	b	0.9
	c	0.05
	SBOD	234.50
	XA	3.000
b	-1	#


Table -2 Basic Conditions

Sewage Flow and Quality	Sludge Moisture and Recovery Ratio	Digestion Tank Conditions	Chemical Conditions for Dewatering
-Inlet flow : Q <sub>0</sub> (m <sup>3</sup> /D) : 7,000	-Primary sludge moisture ratio : W1(%) : 0.0	-Content of organics in thickened sludge : A6(%) : 75.0	-Chemical dosage : A9(%) : 0.5
-Inlet quality : S <sub>0</sub> (mg/l) : 450	-Excess sludge moisture ratio : W2(%) : 99.2	-Digestion ratio : A7(%) : #REF!	-Chemical dissolve concentration : A10(%) : 0.2
-Total removal ratio : A1(%) : -	-Thickened sludge moisture ratio : W3(%) : 99.2	-Digestion gas generation : A8(Nm <sup>3</sup> /kgVS) : -	-
-Effluent quality : S1(mg/l) : 10.0	-Digested sludge moisture ratio : W4(%) : 99.2	-Recovery ratio in sludge digester : A4(%) : 100.0	-
-Sludge generation ratio per removal SS : S1(%) : -	-Dewatered sludge moisture ratio : W5(%) : 82.0	-Recovery ratio in dewatering : A5(%) : 95.0	-

Table -3 Material Balance Calculation

	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	
Qm <sup>3</sup> /day	7,000	7,371	0	7,271	380	6,991	380	0	0	380	0	8	387	16	371	371		6,991	0
T(+DS/day)	3,150	3,303	0.000	3,303	3,038	0,070	3,038	0,000	0,000	3,038	0,000	0,015	3,053	2,900	0,153	0,153		0,070	0,195
S(mg/l)	450	448	0	448	8,000	10	8,000	#DIV/0!	0	8,000	0	2,000	7,882	180,000	411	411		10	
W(+%)	100	104.9	0.0	104.9	96.4	2.2	96.4	0.0	0.0	96.4	0.0	0.5	96.9	92.1	4.8	4.8		2.2	6.2


Figure -1 Material Balance Model



Calculation Formula				
-Q <sub>0</sub> =Input Data	-Q <sub>3</sub> =Q <sub>1</sub> -Q <sub>2</sub>	-Q <sub>6</sub> =Q <sub>6</sub> *100/(100-W3)	-Q <sub>9</sub> =Q <sub>6</sub>	-Q <sub>12</sub> =Q <sub>9</sub> -Q <sub>11</sub>
-T <sub>0</sub> =Q <sub>0</sub> *S <sub>0</sub> *(10 <sup>-6</sup> )/(-6)	-T <sub>3</sub> =T <sub>0</sub> *(100-A2)/100	-T <sub>6</sub> =(T <sub>2</sub> -T <sub>4</sub> )*A3/100	-T <sub>9</sub> =(T <sub>6</sub> -T <sub>9</sub> )*A4/100	-T <sub>12</sub> =T <sub>9</sub> -T <sub>11</sub>
-S <sub>0</sub> =Input Data	-S <sub>3</sub> =T <sub>3</sub> *(10 <sup>-6</sup> )/Q <sub>3</sub>	-S <sub>6</sub> =T <sub>6</sub> *(10 <sup>-6</sup> )/(100-W3)/100	-S <sub>9</sub> =T <sub>9</sub> *(10 <sup>-6</sup> )/Q <sub>9</sub>	-S <sub>12</sub> =T <sub>12</sub> *(10 <sup>-6</sup> )/Q <sub>12</sub>
-Q <sub>1</sub> =Q <sub>0</sub> -Q <sub>15</sub>	-Q <sub>4</sub> =(T <sub>4</sub> *100)/(100-W2)	-Q <sub>7</sub> =(Q <sub>2</sub> -Q <sub>4</sub> )-Q <sub>6</sub>	-Q <sub>10</sub> =Q <sub>6</sub> -Q <sub>8</sub> -Q <sub>9</sub>	-Q <sub>13</sub> =T <sub>13</sub> *(100)/(100-W5)
-T <sub>1</sub> =T <sub>0</sub> -T <sub>15</sub>	-T <sub>4</sub> =余剰汚泥発生式による	-T <sub>7</sub> =(T <sub>2</sub> -T <sub>4</sub> )-T <sub>6</sub>	-T <sub>10</sub> =(T <sub>6</sub> -T <sub>8</sub> )-T <sub>9</sub>	-T <sub>13</sub> =(T <sub>12</sub> *A5)/100
-S <sub>1</sub> =T <sub>1</sub> *(10 <sup>-6</sup> )/Q <sub>1</sub>	-S <sub>4</sub> =T <sub>4</sub> *(100-W2)/100	-S <sub>7</sub> =T <sub>7</sub> *(10 <sup>-6</sup> )/Q <sub>7</sub>	-S <sub>10</sub> =T <sub>10</sub> *(10 <sup>-6</sup> )/Q <sub>10</sub>	-S <sub>13</sub> =T <sub>13</sub> *(100-W5)/100
-Q <sub>2</sub> =T <sub>2</sub> *(100)/(100-W1)	-Q <sub>5</sub> =Q <sub>3</sub> -Q <sub>4</sub> *(T <sub>3</sub> -T <sub>5</sub> )/T <sub>4</sub>	-Q <sub>8</sub> =0	-Q <sub>11</sub> =T <sub>10</sub> *A9/A10	-Q <sub>14</sub> =Q <sub>12</sub> -Q <sub>13</sub>
-T <sub>2</sub> =T <sub>1</sub> -T <sub>3</sub>	-T <sub>5</sub> =Q <sub>5</sub> *S <sub>7</sub> *(10 <sup>-6</sup> )/6	-T <sub>8</sub> =T <sub>6</sub> *A6*A7*(10 <sup>-4</sup> )/#REF!	-T <sub>11</sub> =Q <sub>11</sub> *S <sub>11</sub> *(10 <sup>-6</sup> )/6	-T <sub>14</sub> =T <sub>12</sub> -T <sub>13</sub>
-S <sub>2</sub> =T <sub>2</sub> *(10 <sup>-6</sup> )/(100-W1)/100	-S <sub>5</sub> =S <sub>1</sub>		-S <sub>11</sub> =T <sub>11</sub> *(10 <sup>-6</sup> )/A10	-S <sub>14</sub> =T <sub>14</sub> *(10 <sup>-6</sup> )/Q <sub>14</sub>

**STP Process Calculation\_Supporting Report 12.2.3**

**Material Balance Sheet [7MLD STP]**



**凡例 LEGEND**

Q:Water Flow : (m<sup>3</sup>/day)

T:Solid Matter : (+DS/day)

S : Solid Concentration(ng/l)

X: Ratio for Inlet Solid : (%)

— Water

- - - Sludge

· · · · · Supernatant

Material Balance Sheet 21/21

A-2 Process Cal. EA&al 6MLD Yelahankakere, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

**Design Condition**

Item	6MLD STP-TSPS			
(1) Design Flow for the year 2049	Flow Rate			
		m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s
	Average Daily	15,000	625	0.174
	Max Dayly	15,000	625	0.174
	Max Hourly Peak factor 2.25	33,750	1406	0.391
(1) Design Flow for the year 2034	Flow Rate			
		m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s
	Average Daily	6,000	250	0.069
	Max Dayly	6,000	250	0.069
	Max Hourly Peak factor 2.5	15,000	625	0.174

**1. Inlet Chamber**

Item	6MLD STP-TSPS			
[1] Design Condition				
(1) Design Flow for the year 2049	Max Hourly	=	33,750	m <sup>3</sup> /d
		=	0.391	m <sup>3</sup> /sec
(2) Inlet Pipe				
Pipe Diameter	•	×		
Gradient			%	
Roughness Coefficient	n=	0.013	(Manning Formula)	
Full Pipe Flow Rate			m <sup>3</sup> /s	
(3) Influent Water Level	+		m	
[2] Geometory				
(1) Number of Basins	1	Basin		
(2) Depth of Basin	0.600	m	Approx.	
(3) Width of Basin	2.500	m	Approx.	
(4) Length of Basin	2.500	m	Approx.	
(5) Volume required of Basin	0.600	×	2.500	×
			2.500	=
				0.6
				m <sup>3</sup>
(6) Retention Time	0.600	×	2.500	×
			2.500	/
			0.391	×
				1
	=	9.59	sec	
(7) Basin Demensions	Width	2.500	m	×
				Length
				2.500
				m
	×	Depth	0.600	m



**STP Process Calculation\_Supporting Report 12.2.3**

**2. Coarse Screen Channel**

Item	6MLD STP-TSPS					
[1] Geometry						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Width	0.500	m				
Height	0.750	m				
Floor Level	+	5.000	m			
Bottom	+	0.000	m			
Influent Water Level	+	0.500	m			
Velocity	0.391	/	0.500	/	0.500	/ 2
where Design Flow for the year 2049	=	0.782	<	1.000	m/sec	OK
Velocity	0.174	/	0.500	/	0.500	/ 1
where Design Flow for the year 2034	=	0.696	<	1.000	m/sec	OK
(2) Screen Channel						
Number	2.0	Main	+	1.0	Bypass	
Width	1.000	m				
Side Water Depth	0.500	m				
Velocity	0.391	/	1.000	/	0.500	/ 2
where Design Flow for the year 2049	=	0.391	≅	0.450	m/sec	OK
Velocity	0.174	/	1.000	/	0.500	/ 1
where Design Flow for the year 2034	=	0.348	<	0.450	m/sec	OK
(3) Channel Dimensions	Width	1.0	m	×	Length	8.5 m
			×	SWD	0.5	m
[3] Equipment						
(1) Inlet Gate						
Number	3	Units				
Dimension	Width	0.5	m	×	Height	0.8 m
Design Water Level		m				
(2) Coarse Screens (Main Channel)						
Number	2	W	+	0	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	1.0	m				
Width of side plate	50	mm				
Side Water Depth	0.5	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.391	/	0.900	/	0.450	/ 2
	× ( 20	+ 9 )/	20			
	=	0.700	≅	0.800	m/sec	OK
Velocity through screen	0.174	/	0.900	/	0.450	/ 1
where Design Flow for the year 2034	× ( 20	+ 9 )/	20			
	=	0.623	<	0.800	m/sec	OK
(3) Coarse Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	1.0	m				
Side Water Depth	0.5	m				
Velocity through screen	0.391	/	1.000	/	0.500	/ 2
where Design Flow for the year 2049	× ( 20	+ 9 )/	20			
	=	0.567	<	0.800	m/sec	OK
Velocity through screen	0.174	/	1.000	/	0.500	/ 1
where Design Flow for the year 2034	× ( 20	+ 9 )/	20			
	=	0.505	<	0.800	m/sec	OK

**STP Process Calculation\_Supporting Report 12.2.3**

**3. Raw Sewage Sump**

Item	6MLD STP-TSPS	
[2] Geometory		
(1) Raw Sewage Sump		
Number	1	Basin
Dia	11.00	m
Pump Operating Depth	1.000	m
Retention Time whe Design Flow for the year 2049	$( \frac{11.00^2 \times \pi}{4} \times 1.000 ) / 0.391$	$60$
	= 4.05	> 3.75 min (=minimum time of one pump cycle) OK
Retention Time whe Design Flow for the year 2034	$( \frac{11.00^2 \times \pi}{4} \times 1.000 ) / 0.174$	$60$
	= 9.10	> 3.75 min (=minimum time of one pump cycle) OK
High Water Level	+ 0.000	m
Pump Off Level	+ -1.000	m
[3] Equipment		
(1) Sewage Pumps 1		
Number	2	W + 1 S
Bore Diameter	250	mm
Discharge Flow : Q whe Design Flow for the year 2034	$0.174 \times 3600$	$2.0$
	= 313	$\Rightarrow$ 315 m <sup>3</sup> /Hr
Total Head	15.0	m
(2) Sewage Pumps 2		
Number	W	+ S
Bore Diameter	mm	
Discharge Flow : 0.5 whe Design Flow for the year 2034		$\Rightarrow$ m <sup>3</sup> /Hr
Total Head	m	

A-2 Process Cal. EA&al 6MLD Yelahankakere, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

Item	6MLD STP																																														
<b>1. STP Design Condition</b>																																															
(1) Design Flow Rate	<table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th></th> <th>m<sup>3</sup>/d</th> <th>m<sup>3</sup>/h</th> <th>m<sup>3</sup>/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td>6,000</td> <td>250.00</td> <td>0.069</td> </tr> <tr> <td>Max Daily</td> <td>6,000</td> <td>250.00</td> <td>0.069</td> </tr> <tr> <td>Max Hourly Peak factor 2.5</td> <td>15,000</td> <td>625.00</td> <td>0.174</td> </tr> </tbody> </table>							m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s	Average Daily	6,000	250.00	0.069	Max Daily	6,000	250.00	0.069	Max Hourly Peak factor 2.5	15,000	625.00	0.174																									
	m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s																																												
Average Daily	6,000	250.00	0.069																																												
Max Daily	6,000	250.00	0.069																																												
Max Hourly Peak factor 2.5	15,000	625.00	0.174																																												
(2) Design Water Quality	<p style="text-align: right;">Unit: mg/L</p> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th colspan="2">TP</th> </tr> <tr> <th>NH<sub>4</sub>-N</th> <th>Org-N</th> <th>NOx-N</th> <th>D-P</th> <th>P-P</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td>350</td> <td>800</td> <td>450</td> <td>45.5</td> <td>17.5</td> <td>7</td> <td>5</td> <td>2</td> </tr> <tr> <td>Outlet</td> <td>10</td> <td>50</td> <td>10</td> <td>1</td> <td>0</td> <td>9</td> <td>1</td> <td>1</td> </tr> <tr> <td>Removal rate</td> <td>97.1%</td> <td>93.7%</td> <td>97.8%</td> <td colspan="3">85.7%</td> <td colspan="2">71.4%</td> </tr> </tbody> </table>							BOD	COD	SS	T-N			TP		NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P	Inlet	350	800	450	45.5	17.5	7	5	2	Outlet	10	50	10	1	0	9	1	1	Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%	
	BOD	COD	SS	T-N							TP																																				
				NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P																																							
Inlet	350	800	450	45.5	17.5	7	5	2																																							
Outlet	10	50	10	1	0	9	1	1																																							
Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%																																								
<b>2. Inlet Chamber</b>																																															
<b>[1] Design Condition</b>																																															
(1) Design Flow Rate	Max Hourly	=	15,000	m <sup>3</sup> /day																																											
		=	0.174	m <sup>3</sup> /sec																																											
<b>[2] Geometry</b>																																															
(1) Number of Basins	1	Basin																																													
(2) Depth of Basin	1.000	m																																													
(3) Width of Basin	2.100	m																																													
(4) Length of Basin	1.500	m																																													
(5) Volume required of Basin	1.000	×	2.100	×	1.500	= 1.4 m <sup>3</sup>																																									
(6) Retention Time	1.000	×	2.100	×	1.500	∕ 0.174 × 1																																									
	=	18.10	sec																																												
(7) Basin Dimensions	Width	2.100	m	×	Length	1.500 m																																									
		×	Depth	1.000	m																																										

A-2 Process Cal. EA&al 6MLD Yelahankakere, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Wastewater Flow	$\begin{aligned} \text{Max Hourly} &= 15,000 \text{ m}^3/\text{d} \\ &= 0.174 \text{ m}^3/\text{sec} \end{aligned}$
[2] Geometory	
(1) Inlet Gate	
Number	1 Main + 1 Bypass
Width	0.400 m
Height	0.600 m
Floor Level	+ 2.000 m
Bottom	+ 0.000 m
Influent Water Level	+ 0.500 m
Velocity	$\begin{aligned} &0.174 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 1 \\ = &0.870 \text{ } \div \quad 1.000 \text{ m/sec} \end{aligned}$
(2) Screen Channel	
Number	1 Main + 1 Bypass
Width	0.800 m
Side Water Depth	0.500 m
Velocity	$\begin{aligned} &0.174 \text{ } \swarrow \quad 0.800 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 1 \\ = &0.435 \text{ } \div \quad 0.450 \text{ m/sec} \end{aligned}$
(3) Channel Dimensions	$\begin{aligned} \text{Width} &0.8 \text{ m} \times \text{Length} &6.0 \text{ m} \\ &\times \text{SWD} &0.5 \text{ m} \quad (\text{Freeboard } 0.3\text{m}) \end{aligned}$
[3] Equipment	
(1) Inlet Gate	
Number	1 W + 1 S
Dimension	Width 0.4 m $\times$ Height 0.60 m
Design Water Level	2.00 m
(2) Fine Screens (Main Channel)	
Number	1 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	0.8 m
Width of side plate	50 mm
Side Water Depth	0.5 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	$\begin{aligned} &0.174 \text{ } \swarrow \quad 0.700 \text{ } \swarrow \quad 0.450 \text{ } \swarrow \quad 1 \\ &\times ( \quad 6 \quad + \quad 2 \quad ) / \quad 6 \\ = &0.737 < \quad 0.800 \text{ m/sec} \end{aligned}$
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	0.8 m
Side Water Depth	0.5 m
Velocity through screen	$\begin{aligned} &0.174 \text{ } \swarrow \quad 0.800 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 1 \\ &\times ( \quad 20 \quad + \quad 9 \quad ) / \quad 20 \\ = &0.631 < \quad 0.800 \text{ m/sec} \end{aligned}$

A-2 Process Cal. EA&al 6MLD Yelahankakere, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>4. Grit Chamber</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Max Hourly = 15,000 m <sup>3</sup> /day = 0.174 m <sup>3</sup> /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0111 m/sec = 960 m <sup>3</sup> /m <sup>2</sup> /day
(4) Average Velocity	0.3 m/sec
<b>[2] Grit Chamber</b>	
(1) Surface Area required	0.174 / 0.0111 = 15.68 m <sup>2</sup>
(2) Number of Basins	1 S + 1 W
(3) Surface Area required/Basin	15.68 / 1 = 15.68 m <sup>2</sup>
(4) Length of Basin	15.68 ^0.5 = 4.0 m → 4.0 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.174 × 60 sec / 1 = 10.4 m <sup>3</sup>
(7) Depth required	10.4 / 4.0 / 4.0 = 0.653 m
(8) Basin Dimensions	Width 4.0 m × Length 4.0 m × Depth 0.7 m (Freeboard 0.3m)
(9) Retention Time	4 × 4.0 × 0.7 / 0.174 × 1 = 60.00 sec
(10) Surface Overflow Rate at Peak Flow	15,000 / 4.0 / 4.0 / 1 = 937.5 < 960 m <sup>3</sup> /m <sup>2</sup> /day
<b>[3] Parshall Flume</b>	
(1) Design Flow Rate	Q= 174,000 l/sec
(2) Throat width	W= 0.450 m
(3) Water depth Ha	Ha= ( Q / 2264 / W ) <sup>2/3</sup>
(4) Crest Level	Ha= 0.308 m
(5) Water level at the crest	+ 75.400 m ≐ Minimum water level at downstream channel
(6) Channel bottom level	+ 75.708 m
(7) Upstream Channel width	+ m
(8) SWD of Upstream Channel	1.500 m
(9) Average velocity at upstream channel	0.700 m
(10) Total Length of channel	0.166 m/sec
	10.000 m
<b>[4] Inlet Weir Gate</b>	
(1) Number	2 Units
(2) Weir Width	0.400 m
(3) Stroke	0.450 m
(4) Overflow Height	0.400 m
(5) Overflow Height (actual)	( 0.174 / 1.840 / 0.400 / 2 ) <sup>2/3</sup> = 0.241 < 0.400 m

**STP Process Calculation Supporting Report 12.2.3**

<b>5. Reactor</b>																																																								
<b>[1] Design Condition</b>																																																								
(1) Design Wastewater Flow	Q = 6,000 m <sup>3</sup> /day (summer) Q' = 6,000 m <sup>3</sup> /day (Winter)																																																							
(2) Design Sewage Quality																																																								
Inlet BOD	350 mg/l																																																							
Outlet BOD	10.0 mg/l																																																							
Inlet S-BOD	235 mg/l assumed as 67% of BOD																																																							
Inlet COD	800 mg/l																																																							
Inlet bCOD : S <sub>0</sub>	578 mg/l																																																							
Inlet nbCOD	223 mg/l																																																							
bCOD/BOD	1.65																																																							
Inlet S-COD : sCOD	271 mg/l																																																							
Inlet rbCOD	231 mg/l bCOD*40%																																																							
Inlet sbCOD	347 mg/l bCOD*60%																																																							
Outlet S-COD : nbsCODE	40 mg/l																																																							
Inlet nbpCOD : nbpCOD	183 mg/l = TCOD-bCOD-nbsCODE																																																							
Inlet SS	450 mg/l																																																							
Inlet VSS	383 mg/l assumed as 85% of TSS																																																							
: VSS <sub>COD</sub>	1.38 gCOD/gVSS = TCOD-sCOD/VSS																																																							
: nbVSS	131.96 gnbVSS/m <sup>3</sup> = nbpCOD/VSS <sub>COD</sub>																																																							
: iTSS	67.50 gnbVSS/m <sup>3</sup> = TSS-VSS																																																							
Inlet T-N	70 mg/l																																																							
Inlet TKN	70 mg/l																																																							
Inlet NH <sub>4</sub> -N	45 mg/l																																																							
Inlet T-P	7 mg/l																																																							
Inlet D-P	5 mg/l																																																							
Inlet Alkalinity as CaCO <sub>3</sub>	380 mg/l																																																							
Outlet Kjeldahl N	1.0 mg/l																																																							
Outlet NH <sub>4</sub> -N	1.0 mg/l																																																							
Outlet NO <sub>3</sub> -N	9.0 mg/l																																																							
Outlet T-P	2 mg/l																																																							
Outlet D-P	1 mg/l																																																							
(3) Water Temperature	T = 20.0 °C																																																							
(4) Safety Factor for Nitrogen	SF = 1.5																																																							
(5) Return Sludge Concentration	R <sub>s</sub> = 8,000 mg/l																																																							
(6) MLSS MLVSS	X <sub>TSS</sub> = 3,000 mg/l																																																							
(7) DO in the Reactor	2 mg/L																																																							
<b>[2] Design Value for perfect Nitrification of Nitrification Process</b>																																																								
(1) Activated sludge design kinwtic coefficients at 20°C																																																								
	<table border="1"> <thead> <tr> <th>Coefficient</th> <th>Unit</th> <th>COD oxidatio</th> <th>NH<sub>4</sub> oxidatio</th> <th>NO<sub>2</sub> oxidatio</th> </tr> </thead> <tbody> <tr> <td>μ<sub>max</sub></td> <td>gVSS/gVSS · d</td> <td>6.000</td> <td>0.900</td> <td>1.000</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>mg/L</td> <td>8.000</td> <td>0.500</td> <td>0.200</td> </tr> <tr> <td>Y</td> <td>gVSS/g substrate oxidized</td> <td>0.450</td> <td>0.150</td> <td>0.050</td> </tr> <tr> <td>b</td> <td>gVSS/gVSS · d</td> <td>0.120</td> <td>0.170</td> <td>0.170</td> </tr> <tr> <td>fd</td> <td>unitless</td> <td>0.150</td> <td>0.150</td> <td>0.150</td> </tr> <tr> <td>K<sub>O<sub>2</sub></sub></td> <td>mg/L</td> <td>0.200</td> <td>0.500</td> <td>0.900</td> </tr> <tr> <td>θ Value</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>μ<sub>max</sub></td> <td>unitless</td> <td>1.070</td> <td>1.072</td> <td>1.063</td> </tr> <tr> <td>b</td> <td>unitless</td> <td>1.040</td> <td>1.029</td> <td>1.029</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>unitless</td> <td>1.000</td> <td>1.000</td> <td>1.000</td> </tr> </tbody> </table> <p>Wastwater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF &amp; EDDY/AECOM)</p>	Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio	μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200	Y	gVSS/g substrate oxidized	0.450	0.150	0.050	b	gVSS/gVSS · d	0.120	0.170	0.170	fd	unitless	0.150	0.150	0.150	K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900	θ Value					μ <sub>max</sub>	unitless	1.070	1.072	1.063	b	unitless	1.040	1.029	1.029	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000
Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio																																																				
μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200																																																				
Y	gVSS/g substrate oxidized	0.450	0.150	0.050																																																				
b	gVSS/gVSS · d	0.120	0.170	0.170																																																				
fd	unitless	0.150	0.150	0.150																																																				
K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900																																																				
θ Value																																																								
μ <sub>max</sub>	unitless	1.070	1.072	1.063																																																				
b	unitless	1.040	1.029	1.029																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000																																																				
(2) μ <sub>AOB</sub>	μ <sub>AOB</sub> = 0.3100 g/g · d = μ <sub>max, AOB</sub> [S <sub>NH<sub>4</sub></sub> / (S <sub>NH<sub>4</sub></sub> + K <sub>NH<sub>4</sub></sub> )] [S <sub>O</sub> / (S <sub>O</sub> + K <sub>O, AOB</sub> )] - b <sub>AOB</sub>																																																							
μ <sub>max, AOB, T</sub>	μ <sub>max, AOB, T</sub> = 0.9000 g/g · d = μ <sub>max</sub> * 1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900																																																							
b <sub>AOB, T</sub>	b <sub>AOB, T</sub> = 0.1700 = b * 1.029 <sup>(T-20)</sup> b at 20°C = 0.170																																																							
S <sub>NH<sub>4</sub></sub>	S <sub>NH<sub>4</sub></sub> = 1.0000 mg/l																																																							
DO	DO = 2.0000 mg/l																																																							
K <sub>O, AOB</sub>	K <sub>O, AOB</sub> = 0.5000 mg/l																																																							

**STP Process Calculation Supporting Report 12.2.3**

(2) Design SRT	SRT= 4.8387 day = $1/\mu_{AOB} \times SF$ ⇒ 5.0000 day
(3) Biomass production	
P <sub>X,VSS</sub>	1876.223 kg/d = P <sub>X,bio</sub> +Q(nbVSS)
P <sub>X,TSS</sub>	2472.600 kg/d = P <sub>X,bio</sub> /0.85+Q(nbVSS)+Q(TSS <sub>0</sub> -VSS <sub>0</sub> )+5*Q*Al
S	S= 0.4507 mg/l = $K_s[1+b_H(SRT)]/[SRT(\mu_m-b_H)-1]$
b <sub>H</sub>	b <sub>H</sub> = 0.1200 = $b*1.04^{(T-20)}$ b at 20°C = 0.120
Y <sub>H</sub>	Y <sub>H</sub> = 0.4500 gVSS/g bCOD
μ <sub>m,T</sub>	μ <sub>m,T</sub> = 6.0000 g/g·d = $\mu_{max} * 1.04^{(T-20)}$ μ max at 20°C = 6.000
Y <sub>n</sub>	Y <sub>n</sub> = 0.150 gVSS/g Nox
NO <sub>x</sub>	NO <sub>x</sub> = 47.400 mg/l
P <sub>X,bio,VSS</sub>	P <sub>X,bio,VSS</sub> = 1084.470 kg VSS/d = $Q \cdot Y_H(S_0-S)/[1+b_H(SRT)] + f_d \cdot b_H \cdot QY_H(S_0-S)SRT/[1+b_H(SRT)]$ + QY <sub>n</sub> (Nox)[2+b <sub>AOB</sub> (SRT)] 973.771 = $Q \cdot Y_H(S_0-S)/[1+b_H(SRT)]$ 87.639 = $f_d \cdot b_H \cdot QY_H(S_0-S)SRT/[1+b_H(SRT)]$ 23.059 = $QY_n(Nox)[1+b_{AOB}(SRT)]$
NO <sub>x</sub>	NO <sub>x</sub> = 47.311 mg/l = $TKN - Ne - 0.12P_{X,bio}/Q$
(4) Required Aeration Tank Volume	
V <sub>a</sub>	V <sub>a</sub> = 4,121 m <sup>3</sup>
τ	τ = 16.48 hr = V <sub>a</sub> /Q × 24 ⇒ 18.00 hr
X <sub>VSS</sub> · V <sub>a</sub>	X <sub>VSS</sub> · V <sub>a</sub> = 9,381 kg VSS = P <sub>X,VSS</sub> · SRT
X <sub>TSS</sub> · V <sub>a</sub>	X <sub>TSS</sub> · V <sub>a</sub> = 12,363 kg TSS = P <sub>X,TSS</sub> · SRT
F/M	F/M= 0.224 kgBOD/kgMLVSS
FractionVSS	FractionVSS= 0.759
MLVSS	MLVSS= 2276 mg/L
(5) BODloading	BODloading= 0.510 kg/m <sup>3</sup> ·d
(6) Observed Yield	
Y <sub>obs,TSS</sub>	Y <sub>obs,TSS</sub> = 1.178 gTSS/gBOD
Y <sub>obs,VSS</sub>	Y <sub>obs,VSS</sub> = 0.894 gVSS/gBOD
bCODremoved	bCODremov= 3,462 kg/d
(7) effluent NO <sub>2</sub> -N	NO <sub>2</sub> -N= 0.2315 mg/l = $K_s[1+b_{NOB}(SRT)]/[SRT(\mu_{NOB}-b_{NOB})-1]$
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700 = $b*1.029^{(T-20)}$ b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 1.0000 g/g·d = $\mu_{max} * 1.04^{(T-20)}$ μ max at 20°C = 1.000
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.6897 g/g·d = $\mu_{max,NOB}[S_0/(S_0+K_{O2,NOB})]$
	S <sub>0</sub> = 2.000 mg/l
	K <sub>O2,NOB</sub> = 0.900 mg/l
(8) effluent NH <sub>4</sub> -N	NH <sub>4</sub> -N= 0.5286 mg/l = $K_s[1+b_{NOB}(SRT)]/[SRT(\mu_{NOB}-b_{NOB})-1]$
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700 = $b*1.029^{(T-20)}$ b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 0.9000 g/g·d = $\mu_{max} * 1.072^{(T-20)}$ μ max at 20°C = 0.900
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.7200 g/g·d = $\mu_{max,NOB}[S_0/(S_0+K_{O2,NOB})]$
	S <sub>0</sub> = 2.000 mg/l
	K <sub>O2,NOB</sub> = 0.500 mg/l
(9) Ratio of Return Sludge	8,000·Rr/(1+Rr)= 3,000 mg/L 3,000/(8,000-3,000)= 0.60 Rr = 0.60

A-2 Process Cal. EA&al 6MLD Yelahankakere, Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

[3] Design for Nitrification and Denitrification Process																					
(1) Active biomass concentration	$X_b = \frac{Q \cdot (SRT) \cdot V \cdot Y_H \cdot (S_0 - S)}{1 + b_H(SRT)}$ = 1,181.47 mg/l																				
(2) IR ratio	$IR = \frac{NOx}{Ne} - 1.0 - R$ = 3.66																				
(3) The amount of NO3-N fed to the anoxic tank	$Nox\ feed = (IR + R) \cdot Q \cdot Ne$ = 229,863.66 kg/d																				
(4) The anoxic tank volume	$V_{nor} = 412\ m^3 = V_a \times 10\%$ $V_{nor} = 1,250\ m^3 \quad \tau_{DN} = 5.000\ h$																				
(5) F/M <sub>b</sub>	F/M <sub>b</sub> = 1.42 g/g · d																				
(6) Fraction of rbCOD	40.00% = rbCOD/bCOD																				
	<table border="1"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b0</th> <th>b1</th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>	Percent rdCOD(%)	SDNR equation coefficients		b0	b1	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162
Percent rdCOD(%)	SDNR equation coefficients																				
	b0	b1																			
10	0.186	0.078																			
20	0.213	0.118																			
30	0.235	0.141																			
40	0.242	0.152																			
50	0.270	0.162																			
(8) SDNR <sub>b</sub>	$SDNR_b = 0.296\ g/g \cdot d = b_0 + b_1 [\ln(F/M_b)]$ $b_0 = 0.242$ $b_1 = 0.152$																				
(8) SDNR	$SDNR = 0.110\ g/g \cdot d = SDNR_b (MLVSS_b / MLVSS)$ $SDNR_{adj} = 0.212\ g/g \cdot d = SDNR_i - 0.029 \ln(F/M_b) - 0.012 \quad IR = 3-4$ $= SDNR_i - 0.0166 \ln(F/M_b) - 0.078 \quad IR = 2$ $SDNR_t = 0.296\ g/g \cdot d = SDNR_b \cdot \theta^{(4-20)} \quad \theta = 1.026$																				
(9) NO <sub>r</sub>	$NO_r = 312,595.85\ kg/d = N_{nox} \cdot SDNR \cdot X_b$ $> Nox\ feed = 229,864\ kg/d$																				
(10) Alkalinity to be added to maintain pH7	-108.33 mg/l Influent Alk = 380.00 mg/l Alk used = 338.44 mg/l = 7.14 × Nox Alk produced = 136.77 mg/l = 3.57 × (NOx - NO <sub>x</sub> e) Alk to maintain = 70.00 mg/l																				
[4] Design of Phosphorous Removal Process																					
(1) Removal T-P	3.13 mg/l																				
P in waste sludge	px = 1.00%																				
Generated waste sludge	Px <sub>vss</sub> = 1876.223 kg/d																				
Rwmoval Phosphorus	18.76222816 kg/d																				
(2) Effluent T-P without Al	3.87 mg/l																				
(3) Required Al to initial soluble phosphorous ratio	1.00 mol/mol																				
(4) Required Al dosing rate	3.48 mg/l as Al																				
	42.98 mg/l as crystal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> · 18H <sub>2</sub> O																				
(5) Required Aluminium Sulphate	257.87 kg/d																				
(6) Required Aluminium Sulphate sol 10%	2.46 m <sup>3</sup> /d																				
	102.33 L/H																				
(7) Additional sludge	104.54 kg/d																				



A-2 Process Cal. EA&al 6MLD Yelahankakere, Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<b>[5] Reactor</b>																																																																				
(1) Total volume of Aeration Basins	$V_A = Q \cdot \theta_a / 24$ = 4,500 m <sup>3</sup>																																																																			
(2) Total volume of Anoxic Basins	$V_{DN} = Q \cdot \theta_{DN} / 24$ = 1,250 m <sup>3</sup>																																																																			
	<table border="1"> <thead> <tr> <th rowspan="2">Item</th> <th rowspan="2">Volume required</th> <th colspan="2">Retention Time required</th> <th rowspan="2">Ratio of Volume</th> </tr> <tr> <th>Summer</th> <th>Winter</th> </tr> <tr> <th colspan="2">unit</th> <th>m<sup>3</sup></th> <th>hour</th> <th>hour</th> <th></th> </tr> </thead> <tbody> <tr> <td>Anaerobic</td> <td><math>V_{AN}</math></td> <td>380</td> <td>1.50</td> <td>1.50</td> <td>0.30</td> </tr> <tr> <td>Anoxic</td> <td><math>V_{DN}</math></td> <td>1,250</td> <td>5.00</td> <td>5.00</td> <td>1.00</td> </tr> <tr> <td>Aerobic</td> <td><math>V_A</math></td> <td>4,500</td> <td>18.00</td> <td>18.00</td> <td>3.60</td> </tr> <tr> <td>Total</td> <td>V</td> <td>6,130</td> <td>24.50</td> <td>24.50</td> <td></td> </tr> </tbody> </table>	Item	Volume required	Retention Time required		Ratio of Volume	Summer	Winter	unit		m <sup>3</sup>	hour	hour		Anaerobic	$V_{AN}$	380	1.50	1.50	0.30	Anoxic	$V_{DN}$	1,250	5.00	5.00	1.00	Aerobic	$V_A$	4,500	18.00	18.00	3.60	Total	V	6,130	24.50	24.50																															
Item	Volume required			Retention Time required			Ratio of Volume																																																													
		Summer	Winter																																																																	
unit		m <sup>3</sup>	hour	hour																																																																
Anaerobic	$V_{AN}$	380	1.50	1.50	0.30																																																															
Anoxic	$V_{DN}$	1,250	5.00	5.00	1.00																																																															
Aerobic	$V_A$	4,500	18.00	18.00	3.60																																																															
Total	V	6,130	24.50	24.50																																																																
<b>[6] Geometry</b>																																																																				
(1) Basin Dimensions	Width 8.0 Length 75.0 Depth 5.5 Basins 2																																																																			
Cross Section	8.0*5.5 = 44.0 m <sup>2</sup> /Basin																																																																			
Hantzsch Subtraction	= 1.0 m <sup>2</sup> /Basin																																																																			
after Subtraction	44.0-1.0 = 43.0 m <sup>2</sup> /Basin																																																																			
Total Volume	43.0*75.0 = 3,225 m <sup>2</sup> /Basin 6,450 m <sup>3</sup> /Total																																																																			
(2) Partition of Basin	<table border="1"> <thead> <tr> <th>Item</th> <th>unit</th> <th>Anaerobic</th> <th>Anoxic</th> <th>Aerobic</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Cross Section</td> <td>m<sup>2</sup></td> <td colspan="3">43.0</td> <td></td> </tr> <tr> <td>Length required</td> <td>m</td> <td>4.4</td> <td>14.5</td> <td>52.3</td> <td>71.3</td> </tr> <tr> <td>Volume required per Basin</td> <td>m<sup>3</sup></td> <td>190</td> <td>625</td> <td>2,250</td> <td>3,065</td> </tr> <tr> <td>Total Volume required</td> <td>m<sup>3</sup></td> <td>380</td> <td>1,250</td> <td>4,500</td> <td>6,130</td> </tr> <tr> <td>Actual Cross Section</td> <td>m<sup>2</sup></td> <td>43.0</td> <td>43.0</td> <td>43.0</td> <td></td> </tr> <tr> <td>Actual Length</td> <td>m</td> <td>6.0</td> <td>15.0</td> <td>54.0</td> <td>75.0</td> </tr> <tr> <td>Actual Volume per Basin</td> <td>m<sup>3</sup></td> <td>258</td> <td>645</td> <td>2,322</td> <td>3,225</td> </tr> <tr> <td>Actual Total Volume</td> <td>m<sup>3</sup></td> <td>516</td> <td>1,290</td> <td>4,644</td> <td>6,450</td> </tr> <tr> <td>Actual Ratio of Volume</td> <td></td> <td>0.40</td> <td>1.00</td> <td>3.60</td> <td></td> </tr> <tr> <td>Actual Retention Time</td> <td>hour</td> <td>2.06</td> <td>5.16</td> <td>18.58</td> <td>25.80</td> </tr> </tbody> </table>	Item	unit	Anaerobic	Anoxic	Aerobic	Total	Cross Section	m <sup>2</sup>	43.0				Length required	m	4.4	14.5	52.3	71.3	Volume required per Basin	m <sup>3</sup>	190	625	2,250	3,065	Total Volume required	m <sup>3</sup>	380	1,250	4,500	6,130	Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0		Actual Length	m	6.0	15.0	54.0	75.0	Actual Volume per Basin	m <sup>3</sup>	258	645	2,322	3,225	Actual Total Volume	m <sup>3</sup>	516	1,290	4,644	6,450	Actual Ratio of Volume		0.40	1.00	3.60		Actual Retention Time	hour	2.06	5.16	18.58	25.80	
Item	unit	Anaerobic	Anoxic	Aerobic	Total																																																															
Cross Section	m <sup>2</sup>	43.0																																																																		
Length required	m	4.4	14.5	52.3	71.3																																																															
Volume required per Basin	m <sup>3</sup>	190	625	2,250	3,065																																																															
Total Volume required	m <sup>3</sup>	380	1,250	4,500	6,130																																																															
Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0																																																																
Actual Length	m	6.0	15.0	54.0	75.0																																																															
Actual Volume per Basin	m <sup>3</sup>	258	645	2,322	3,225																																																															
Actual Total Volume	m <sup>3</sup>	516	1,290	4,644	6,450																																																															
Actual Ratio of Volume		0.40	1.00	3.60																																																																
Actual Retention Time	hour	2.06	5.16	18.58	25.80																																																															
<b>[7] Equipment</b>																																																																				
(1) Ras Pumps																																																																				
Ras Ratio	60%																																																																			
Required Capacity	6,000 m <sup>3</sup> /day × 60% / 24 / 2 = 75 m <sup>3</sup> /Hr ⇒ 75 m <sup>3</sup> /Hr																																																																			
Number	2 Work 2 Standby																																																																			
(2) Circulation Pumps																																																																				
Ras Ratio	366%																																																																			
Required Capacity	6,000 m <sup>3</sup> /day × 366% / 24 / 4 = 229 m <sup>3</sup> /Hr ⇒ 230 m <sup>3</sup> /Hr																																																																			
Number	4 Work 2 Standby																																																																			
(3) SAS Pumps																																																																				
Excess Sludge	325 m <sup>3</sup> /day																																																																			
Sludge withdraw	12 Times/day																																																																			
Running Time	0.5 Hr/Time																																																																			
Required Capacity	325 m <sup>3</sup> /day / 12 / 0.5 / 2 = 27.12 m <sup>3</sup> /Hr ⇒ 28 m <sup>3</sup> /Hr																																																																			
Number	2 Work 2 Standby																																																																			

A-2 Process Cal. EA&al 6MLD Yelahankakere, Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

(4) Alum Solution Tank										
Number	2	W	+	0	S					
Alum concentration as crystal	10	%								
Gravity of dissolved dechlorine	1.05									
Required solution volume	257.87	kg / d		×	100	/	10	/	1.05 / 1000	
	=	2.46			m <sup>3</sup> /d					
Volume of Tank	1.5				m <sup>3</sup> /tank					
Total Volume of Tanks	3.0				m <sup>3</sup>		(Duration=	1.22	day)	
(5) Mixer for Alum Solution Tank										
Number	2	W	+	0	S					
(6) Alum Dosing Pump										
Number	2	W	+	1	S					
Capacity	2.46	m <sup>3</sup> /d	/	24	×	1000	/	2	×	2
	102.33	l/h/unit	⇒		110	l/h/unit				

**STP Process Calculation Supporting Report 12.2.3**

<b>6. Air Requirement at Average Flow</b>	
[1] Design Condition	
(1) AOR	AOR = 2,596 kg/day = 108.2 kg/h
Q <sub>in</sub> : Design Average Flow m <sup>3</sup> /d	6,000
Inlet bCOD : S <sub>0</sub>	578 mg/l
S=	S= 0.451 mg/l
Nox=	Nox 47.400 mg/l
P <sub>X,bio</sub> =	P <sub>X,b</sub> 1,061.4 kg VSS/d does not include nitrifying bacteria
R <sub>0</sub> =	R <sub>0</sub> = Q(S <sub>0</sub> -S-k(NOx-NOx <sub>e</sub> ))-1.42P <sub>X,bio</sub> +4.57Q·NOx
R <sub>0</sub> =	R <sub>0</sub> = 2,596 kg O <sub>2</sub> /d
	k= 2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{AOR \times C_s \cdot a \times 1.024^{20-T}}{\alpha \times F (\beta \cdot C_{sw}/C_s \cdot (P_b/P_a)a - C_A)}$
	C <sub>s</sub> : Saturated DO at sea level and 20 °C 9.09 mg/L
	C <sub>sw</sub> : Saturated DO at sea level and operating Temperature 9.09 mg/L at 20 °C
	20-T : 0.0 1.024 <sup>20-T</sup> : 1.0000
	C <sub>A</sub> : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1+0.40D <sub>j</sub> /P <sub>a</sub> 1.19357
	D <sub>j</sub> : Tank Liquid Depth 5.00 m
	P <sub>a</sub> : Standard absolute pressure at s 10.332 m
	P <sub>b</sub> : Absolute pressure at Plant Site Elevation m
	P <sub>b</sub> /P <sub>a</sub> : exp[-gM(z <sub>b</sub> -z <sub>a</sub> )/R*T] 0.900
	g : Acceleration due to Gravity 9.80665 m/s <sup>2</sup>
	M : Mole of Air 28.97 kg/kg-mole
	z <sub>b</sub> : Plant Site Elevation 900 m
	z <sub>a</sub> : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 293.15 Kelvin
	α : relative Transfer Rate to clean Water 0.65
	β : relative DO Saturation to clean Water 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{28,164}{4.2591} = 6,612.59 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Standard O <sub>2</sub> required at Field Conditions per Basin =	3,306 kg/day
(5) SOTE for the above Effective Aeration Depth	28.0 %
(6) Fraction of O <sub>2</sub> in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	15%
(9) Air required at Field Conditions per Basins	= 48,627 m <sup>3</sup> /day = 2,026.1 m <sup>3</sup> /hr
[2] Equipment	

A-2 Process Cal. EA&amp;al 6MLD Yelahankakere\_Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

(1) Air Blower					
Number	2	W	+	1	S
Required Capacity	2026.1	m <sup>3</sup> /Hr·Basin	/	1	unit/Basin
	= 2026.1	m <sup>3</sup> /h	⇒	2100	m <sup>3</sup> /h /Unit
Pressure	65	kPa			
Safety Factor	10	%			
Heat capacity ratio	1.4				
Atmospheric pressure at site elevation	91.234	kPa			
Total inlet pressure	89.234	kPa			
Volume rate of flow at inlet point	39.733	m <sup>3</sup> /min			
Total discharge pressure	156.234	kPa			
Overall adiabatic efficiency	0.65				
Inlet air temperature (min.)	15	°C			
Shaft power	56.177	kW			
Rated Output of Motor	61.795	kW	⇒	75	kW

Air Requirement at Average Flow13/21

A-2 Process Cal. EA&a1 6MLD Yelahankakere Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>7. Final Clarifire</b></p>									
<p>[1] <b>Design Condition</b></p>									
<p>(1) Design Wastewater Flow</p>	<p>Q= 6,000 m<sup>3</sup>/day</p>								
<p>(2) Water Temperature</p>	<p>T= 20.0 °C</p>								
<p>(3) MLSS</p>	<p>X<sub>ef</sub>= 3,000 mg/l</p>								
<p>(4) SVI</p>	<p>SVI= 300</p>								
<p>(5) Sedimentation Velocity</p>	$v = 4.899 \cdot 10^6 \cdot T^{(0.954)} \cdot X_{ef}^{(-1.354)} \cdot SVI^{(-0.77)}$ $= 4.899 \cdot 10^6 \cdot 20.0^{0.954} \cdot 3,000^{-1.354} \cdot 150^{-0.770}$ $= 20.7 \text{ m/day}$								
<p>(6) Surface Overflow Rate required</p>	$S' = v / (1.5 \cdot 1) = \frac{20.7}{(1.5 \cdot 1.0)} = 13.8 \text{ m}^3/\text{m}^2 \cdot \text{day}$	<p>→</p>	<p>12.0 m<sup>3</sup>/m<sup>2</sup>·day</p>						
<p>[2] <b>Geometry</b></p>									
<p>(1) Surface Area required</p>	$A = 6,000 / 12.0 = 500 \text{ m}^2$								
<p>(2) Demensions</p>	<table style="margin-left: auto; margin-right: auto;"> <tr> <td style="text-align: center;">Diameter</td> <td style="text-align: center;">Depth</td> <td style="text-align: center;">Basin</td> </tr> <tr> <td style="text-align: center;"><b>18.0</b></td> <td style="text-align: center;"><b>3.5</b></td> <td style="text-align: center;"><b>2</b></td> </tr> </table>	Diameter	Depth	Basin	<b>18.0</b>	<b>3.5</b>	<b>2</b>		
Diameter	Depth	Basin							
<b>18.0</b>	<b>3.5</b>	<b>2</b>							
<p>(3) Actual Surface Area</p>	$S = 18.0^2 \cdot \frac{3.14}{4} \cdot 2.0 = 509 \text{ m}^2$								
<p>(4) Surface Overflow Rate</p>	$S = 6,000 / 509 = 11.8 \text{ m}^3/\text{m}^2 \cdot \text{day}$								

A-2 Process Cal. EA&al 6MLD Yelahankakere, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>8. Chlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Flow      6,000    m <sup>3</sup> /day      250.00    m <sup>3</sup> /h Peak Flow          15,000    m <sup>3</sup> /day      625.00    m <sup>3</sup> /h
(2) Contact Time	30    min
(3) Type of Chlorine	Cl <sub>2</sub> -GAS
(4) Design Chlorine Dosage Rate	10    mg/L
(5) Required Chlorine per day	Average Daily Flow    /    1000    ×      Design Chlorine Dosage Rate =      60.0    kg/d =      2.50    kg/h
<b>[2] Chlorination Contact Tank</b>	
(1) Volume required	Average Daily Flow    /    1440    ×      Contact Time =      125.0    m <sup>3</sup>
(2) Nos. of lanes	3      lanes
(3) Width of lane	1.50    m
(4) Length of lane	19.00    m
(5) Side Water Depth	1.50    m
(6) Nos. of Tanks	1      tank
(7) Total Width of Tank	5.30    m Approx..
(8) Average Velocity	Decant Flow          /      3600    /      Width      /      Depth =      250.00    /      3600    /      1.50      /      1.50 =      0.031    m/sec
(9) Total Volume	Width      ×      Length      ×      Depth      ×      Nos. of lanes      ×      Nos. of Tanks =      1.5      m      ×      19.0      m      ×      1.5      m ×      3      ×      1 =      128    m <sup>3</sup> >      125.0    m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Chlorine Dosing Condition	
Operation Dosage Rate -1	DC1      1 mg/L    10 mg/L
Average Dosage Rate -1	DC2      10 mg/L
(2) Chlorine Cylinder	
Type	-      Cylindrical Convexsd Container
Cylinder Capacity	Cc      928 kg/cylinder
Average Dosage Rate -1	q1      Chlorine -1 : Q <sub>T-D</sub> × DC2 × 10 <sup>-6</sup> × 10 <sup>3</sup> =    60 kg/day
Storage day	T      More than      15 days
Required Storage Capacity	EC1      D × T =      900 kg
Unit Number	EN1      EC1 / Cc =      1.0 cylinders
Maximum Operation Numbers	
Cl <sub>2</sub> -Gas Volatilize Rate	Vr1      ##### @ 20°C Standard temperature
Maximum Dosing Rate	DC1      10 mg/L, Q <sub>T-D</sub> × q3 × 10 <sup>-3</sup> / 24 =    #####
Operation Numbers	EN2      DC1 / Vr1 =    0.8sets
(3) Chlorinator	
Type	Solution Feed Vacuum Type
Number	1      W      +      1      S
Operation Dosage Rate -1	Dq1      Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 6    kg/day to    150    kg/day
Required Dosage Rate	Chlorine -1 : Dq1 / (EN1 × 24) = Minimum                      Maximum 0.25    kg/hr                      6.3    kg/hr

A-2 Process Cal. EA&al 6MLD Yelahankakere, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p>(4) Chlorine Booster Pump</p> <p>Type</p> <p>Water Demand</p> <p>Chlorinator Discharge</p> <p>Water Demand</p> <p>Chlorinator Discharge</p> <p>Water Demand</p> <p>Water requiamet</p> <p>For Chlorin</p> <p>Booster Pump Type</p> <p>Number</p>	<p>Branchy on the water supply pipe</p> <p>Water requiamet for mixed Chlori</p> <table border="0"> <tr> <td>(kg/hr)</td> <td>1.0</td> <td>1.5</td> <td>2.0</td> <td>2.5</td> <td>3.0</td> <td>4.0</td> </tr> <tr> <td>(L/min)</td> <td>15</td> <td>20</td> <td>25</td> <td>30</td> <td>35</td> <td>40</td> </tr> <tr> <td>(kg/hr)</td> <td>5.0</td> <td>6.0</td> <td>10.0</td> <td>50.0</td> <td>100.0</td> <td>200.0</td> </tr> <tr> <td>(L/min)</td> <td>45</td> <td>50</td> <td>60</td> <td>300</td> <td>600</td> <td>1,200</td> </tr> </table> <p>Water requiamet -</p> <p>Qp1 Maximum dosage rate 6.3 kg/hr therefore 50 L/min</p> <p>Single suction volute pump</p> <p>1 W + 1 S</p>	(kg/hr)	1.0	1.5	2.0	2.5	3.0	4.0	(L/min)	15	20	25	30	35	40	(kg/hr)	5.0	6.0	10.0	50.0	100.0	200.0	(L/min)	45	50	60	300	600	1,200
(kg/hr)	1.0	1.5	2.0	2.5	3.0	4.0																							
(L/min)	15	20	25	30	35	40																							
(kg/hr)	5.0	6.0	10.0	50.0	100.0	200.0																							
(L/min)	45	50	60	300	600	1,200																							
<p><b>9. Dechlorination</b></p> <p><b>[1] Design Condition</b></p> <p>(1) Design Flow Rate</p> <p>(2) Contact Time</p> <p>(3) Type of Dechlorine</p> <p>(4) Free Residual Chlorine</p> <p>(5) Consumption per day</p> <p><b>[2] Dechlorination Contact Tank</b></p> <p>(1) Volume required</p> <p>(2) Width of lane</p> <p>(3) Length of lane</p> <p>(4) Side Water Depth</p> <p>(5) Nos. of Tanks</p> <p>(6) Total Volume</p> <p><b>[3] Equipment</b></p> <p>(1) Dechlorine Solution Tank</p> <p>Number</p> <p>Dechlorine concentration</p> <p>Gravity of dissolved dechlorine</p> <p>Required solution volume</p> <p>Volume of Tank</p> <p>Total Volume of Tanks</p> <p>(2) Mixer for Dechlorine Solution Tank</p> <p>Number</p> <p>(3) Dechlorine Dosing Pump</p> <p>Number</p> <p>Capacity</p>	<p>Average Daily Flow 6,000 m<sup>3</sup>/day</p> <p>10 min</p> <p>Sodium Thiosulfate (Na<sub>2</sub>S<sub>2</sub>O<sub>3</sub> · 5H<sub>2</sub>O)</p> <p>1.0 mg/L assumed value</p> <p>Average Daily Flow / 1000 × Free Residual Chlorine × 1.75</p> <p>× 1.5 (safety factor)</p> <p>= 15.75 kg/d</p> <p>= 0.656 kg/h</p> <p>Average Flow Rate / 60 × Contact Time</p> <p>= 41.7 m<sup>3</sup></p> <p>5.30 m</p> <p>6.00 m</p> <p>1.50 m</p> <p>1 tank</p> <p>Width × Length × Depth</p> <p>= 5.3 m × 6.0 m × 1.5 m</p> <p>= 48 m<sup>3</sup> &gt; 41.7 m<sup>3</sup></p> <p>1 W + 0 S</p> <p>10 %</p> <p>1.10</p> <p>15.75 kg/d × 100 / 10 / 1.10 / 1000</p> <p>= 0.14 m<sup>3</sup>/d</p> <p>0.2 m<sup>3</sup>/tank</p> <p>0.2 m<sup>3</sup> (Duration= 1.40 day)</p> <p>1 W + 0 S</p> <p>1 W + 1 S</p> <p>0.36 m<sup>3</sup>/d / 24 × 1000 / 1</p> <p>14.91 l/h/unit ⇒ 15.0 l/h/unit</p>																												

A-2 Process Cal. EA&al 6MLD Yelahankakere Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>10. Centrifuge</b>  <b>[1] Design Condition</b>                  (1) Type of Dewatering                  (2) Generated Sludge                  (3) Design Polyelectrolyte Dosage                  (4) Volume of Thickend Sludge                  (5) Consistency of Dewatered Sludge                  (6) Operation Time</p>	<p>Centrifuge                  2,604 kg/day                  Polyelectrolyte 5 kg/t-DS·day                  325.4 m<sup>3</sup>/day                  82 %                  12 hours/day (6 days per week)</p>
<p><b>[2] Volume of Centrifuges</b></p>	<p><math display="block">\frac{\text{Digested Solids}}{\text{Operation Time} \times \text{No.}} \times \text{Operation/week}</math> <math display="block">= \frac{325.4}{12 \times 1} \times \frac{7}{6} = 31.6</math> <p style="text-align: right;">→ 32 m<sup>3</sup>/hour</p> </p>
<p><b>[3] Dewatered Solids</b></p>	<p><math display="block">\text{Digested Sludge} \times \left( \frac{1}{1} + \frac{\text{Injection Rate}}{0.0050} \right)</math> <math display="block">= 2,604 \times \left( \frac{1}{1} + \frac{0.0050}{0.0050} \right)</math> <math display="block">= 2,617 \text{ kg/day}</math> </p>
<p><b>[4] Dewatered Cake Volume</b></p>	<p><math display="block">\text{Dewatered Solids} \times \frac{100}{100 - \frac{\text{Moisture Content}}{7}}</math> <math display="block">\times \frac{6 \text{ days per week}}{6}</math> <math display="block">= 2,617 \times \frac{100}{100 - \frac{82}{6}} \times \frac{7}{6}</math> <math display="block">= 16.96 \text{ t/day}</math> <p>apparent specific gravity 1.00  <math display="block">\frac{16.96}{1.00} = 17.0 \text{ m}^3/\text{day}</math></p> </p>
<p><b>[5] Polyelectrolyte</b>                  (1) Design Polyelectrolyte Dosage                  (2) Required Polyelectrolyte                  (3) Dissolving concentration                  (4) Volume of Polyelectrolyte solution</p>	<p>Polyelectrolyte 5 kg/t-DS·day                  13.02 kg/day                  0.20 %                  6.51 m<sup>3</sup>/day</p>



A-2 Process Cal. EA&al 6MLD Yelahankakere Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>[6] Equipment</b>						
(1) Centrifuge						
Capacity	32	m <sup>3</sup> /hr				
Number	1	W	+	1	S	
(2) Centrifuge Feed Pumps						
Capacity	32	m <sup>3</sup> /hr				
Number	1	W	+	1	S	
(3) Polyelectrolyte Dosing Pumps						
Volume of Polyelectrolyte solution	6.51	m <sup>3</sup> /day				
Operation Time	12	hours/day		(6 days per week)		
Safety Factor	1.5					
Number	1	W	+	1	S	
Required Capacity	6.51	m <sup>3</sup> /da	×	7	/	6
						12
						1
	=	0.63	m <sup>3</sup> /Hr			
Specification Capacity	0.63	m <sup>3</sup> /Hr	×	1.5		
	=	0.949	m <sup>3</sup> /Hr	⇒	1.00	m <sup>3</sup> /Hr /Unit
(4) Polyelectrolyte dosing System						
Tanks Dimensions						
Width	1.5	m	×	Length	1.5	m
× Depth				1.8	m	×
						2
	=	8.1	m <sup>3</sup>			
Retention Time of Tanks	8.10	m <sup>3</sup>	/	0.63	m <sup>3</sup> /Hr	/
	=	12.800	Hr			1
Number	2	W	+	0	S	

A-2 Process Cal. EA&al 6MLD Yelahankakere Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>11. Centrifuge Feed Sump</b>	
<b>[1] Design Condition</b>	
(1) Generated Thickend Sludge	2,604 kg/day
(2) Solids Consistency	0.80 %
(3) Volume of Excess Sludge	$\begin{aligned} & \text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3} \\ = & 2,604 \times \frac{100}{0.80} \times 10^{-3} \\ = & 325 \text{ m}^3/\text{day} \\ = & 13.56 \text{ m}^3/\text{h} \end{aligned}$
(4) Sludge feed flow rate	32 m <sup>3</sup> /h × 1 = 32 m <sup>3</sup> /h
(5) Centrifuge Operation Time	12 hours/day ( 6 days per week)
<b>[2] Geometry</b>	
(1) Basin Dimensions	$\begin{aligned} & \text{Width } 5.0 \text{ m} \times \text{Length } 5.0 \text{ m} \\ & \times \text{Depth } 4.0 \text{ m} \times 2 \\ = & 200.0 \text{ m}^3 \end{aligned}$
<b>[3] Equipment</b>	
(1) Mixers for Centrifuge Feed Sumps	200.0 m <sup>3</sup>
Required Volume	200.0 m <sup>3</sup>
Number	1 W + 1 S

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Digestion Tank + Centrifugal Dewatering)

Table -1 Input Data

1. Calculation Manner	2	1:Premise that the quality of supernatants are same level removed with inlet sewage 2:Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency	2	1:Total Removal Ratio 2:Outlet Water Quality(input 1or2)
In case of 1 : input data		(%)
In case of 2 : input data	#REF!	(mg/l)
3. Selection of Excess Sludge Generation	2	1:Consideration of Solid Matter Only 2:Consideration of Converting of Solved BOD(input 1or2)
In case of 1 : input data (Sludge generation)		Sludge generation ratio per removal SS(%)
	a	0.4 T2=Q4·S4=(a·S <sub>BOD</sub> +b·S1-c·θ·XA)·Q3/10 <sup>6</sup> · (Excess sludge generation formula)
	b	0.9 a:Converting ratio of solved BOD(mgMLSS/mgBOD)
	c	0.05 b:Converting ratio of SS(mgMLSS/mgSS)
In case of 2 : input data	SBOD	234.50 c:Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)
	XA	3,000 S <sub>BOD</sub> :Solved BOD quality at inlet reactor
	θ	1 XA:MLSS concentration(mg/l)
		θ:Hydraulic retention time(day)


Table -2 Basic Conditions

Sewage Flow and Quality		Sludge Moisture and Recovery Ratio		Digestion Tank Conditions		Chemical Conditions for Dewatering	
·Inlet flow : Q <sub>0</sub> (m <sup>3</sup> /D)	6,000	·Primary sludge moisture ratio : W1(%)	0.0	·Removal ratio in primary tank : A2(%)	0.0	·Content of organics in thickened sludge : A6(%)	75.0
·Inlet quality : S <sub>0</sub> (mg/l)	450	·Excess sludge moisture ratio : W2(%)	99.2	·Recovery ratio in sludge thickener : A3(%)	100.0	·Digestion ratio : A7(%)	#REF!
·Total removal ratio : A1(%)	-	·Thickened sludge moisture ratio : W3(%)	99.2	·Recovery ratio in sludge digester : A4(%)	100.0	·Digestion gas generation : A8(Nm <sup>3</sup> /kgVS)	
·Effluent quality : S1(mg/l)	10.0	·Digested sludge moisture ratio : W4(%)	99.2	·Recovery ratio in dewatering : A5(%)	95.0		
·Sludge generation ratio per removal SS : S1(%)	-	·Dewatered sludge moisture ratio : W5(%)	82.0				

Table -3 Material Balance Calculation

	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	手入力(要取束)	16	17	
Q(m <sup>3</sup> /day)	6,000	6,318	0	6,318	325	5,993	325	0	0	325	0	7	332	14	318	318		5,993	0	
T(t·DS/day)	2,700	2,831	0.000	2,831	2,604	0.060	2,604	0.000	0.000	2,604	0.000	0.013	2,617	2,486	0.131	0.131	0.131		0.060	0.167
S(mg/l)	450	448	0	448	8,000	10	8,000	#DIV/0!	0	8,000	0	2,000	7,882	180,000	411	411			10	
X(T5/T0*100)	100	104.9	0.0	104.9	96.4	2.2	96.4	0.0	0.0	96.4	0.0	0.5	96.9	92.1	4.8	4.8			2.2	6.2

Figure -1 Material Balance Model




Calculation Formula						
·Q0=Input Data	·Q3=Q1-Q2	·Q6=T6*100/(100-W3)	·Q9=Q6	·Q12=Q9+Q11	·Q15=Q7+Q10+Q14	·Q5-1=Q5-Q11
·T0=Q0*S0*10 <sup>-6</sup>	·T3=T0*(100-A2)/100	·T6=(T2+T4)*A3/100	·T9=(T6-T8)*A4/100	·T12=T9+T11	·T15=T7+T10+T14	·T5-1=T5-T11
·S0=Input Data	·S3=T3*10 <sup>-6</sup> /Q3	·S6=10 <sup>-6</sup> *Q3/(100-W3)/100	·S9=T9*10 <sup>-6</sup> /Q9	·S12=T12*10 <sup>-6</sup> /Q12	·S15=T15*10 <sup>-6</sup> /Q15	·S5-1=S5
·Q1=Q0+Q15	·Q4=T4*100/(100-W2)	·Q7=(Q2+Q4)-Q6	·Q10=Q6-Q8-Q9	·Q13=T13*100/(100-W5)		
·T1=T0+T15	·T4=余剰汚泥発生式による	·T7=(T2+T4)-T6	·T10=T6-T8-T9	·T13=T12*A5/100		
·S1=T1*10 <sup>-6</sup> /Q1	·S4=10 <sup>-6</sup> *Q4/(100-W2)/100	·S7=T7*10 <sup>-6</sup> /Q7	·S10=T10*10 <sup>-6</sup> /Q10	·S13=10 <sup>-6</sup> *Q13/(100-W5)/100		
·Q2=T2*100/(100-W1)	·Q5=Q3-Q4*(T3-T5)/T4	·Q8=0	·Q11=T10*A9/A10	·Q14=Q12-Q13		
·T2=T1-T3	·T5=Q5*ST/10 <sup>-6</sup>	·T8=T6*A6*A7/10 <sup>-4</sup>	·T11=Q11*S11/10 <sup>-6</sup>	·T14=T12-T13		
·S2=10 <sup>-6</sup> *Q2/(100-W1)/100	·S5=St	#REF!	·S11=10 <sup>-4</sup> *A10	·S14=T14*10 <sup>-6</sup> /Q14		

Material Balance Sheet SD4

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Sheet  
[3MLD STP]



A-3 Process Cal. EA&aI 7MLD Doddabettahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

**Design Condition**

Item	7MLD STP-TSPS				
(1) Design Flow for the year 2049	Flow Rate				
		m3/d	m3/h	m3/s	
	Average Daily	11,000	458	0.127	
	Max Dayly	11,000	458	0.127	
	Max Hourly Peak factor	2.25	24,750	1031	0.286
(1) Design Flow for the year 2034	Flow Rate				
		m3/d	m3/h	m3/s	
	Average Daily	7,000	292	0.081	
	Max Dayly	7,000	292	0.081	
	Max Hourly Peak factor	2.25	15,750	656	0.182

**1. Inlet Chamber**

Item	7MLD STP-TSPS			
[1] Design Condition				
(1) Design Flow for the year 2049	Max Hourly	=	24,750	m3/d
		=	0.286	m3/sec
(2) Inlet Pipe				
Pipe Diameter	•	×		
Gradient			%	
Roughness Coefficient	n=	0.013	(Manning Formula)	
Full Pipe Flow Rate			m3/s	
(3) Influent Water Level	+		m	
[2] Geometory				
(1) Number of Basins	1	Basin		
(2) Depth of Basin	0.600	m	Approx.	
(3) Width of Basin	2.100	m	Approx.	
(4) Length of Basin	2.500	m	Approx.	
(5) Volume required of Basin	0.600	×	2.100	×
			2.500	=
				0.5
				m3
(6) Retention Time	0.600	×	2.100	×
			2.500	/
				0.286
				×
				1
	=	11.01	sec	
(7) Basin Demensions	Width	2.100	m	×
				Length
				2.500
				m
	×	Depth	0.600	m

A-3 Process Cal. EA&amp;al 7MLD Doddabettahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3****2. Coarse Screen Channel**

Item	7MLD STP-TSPS					
[1] Geometry						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Width	0.400	m				
Height	0.600	m				
Floor Level	+	5.000	m			
Bottom	+	0.000	m			
Influent Water Level	+	0.500	m			
Velocity	0.286	/	0.400	/	0.500	/ 2
where Design Flow for the year 2049	=	0.715	<	1.000	m/sec	OK
Velocity	0.182	/	0.400	/	0.500	/ 1
where Design Flow for the year 2034	=	0.910	<	1.000	m/sec	OK
(2) Screen Channel						
Number	2.0	Main	+	1.0	Bypass	
Width	0.800	m				
Side Water Depth	0.600	m				
Velocity	0.286	/	0.800	/	0.600	/ 2
where Design Flow for the year 2049	=	0.298	≐	0.450	m/sec	OK
Velocity	0.182	/	0.800	/	0.600	/ 1
where Design Flow for the year 2034	=	0.379	<	0.450	m/sec	OK
(3) Channel Dimensions	Width	0.8	m	×	Length	6.0 m
	×	SWD	0.6	m		
[3] Equipment						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Dimension	Width	0.4	m	×	Height	0.60 m
Design Water Level		m				
(2) Coarse Screens (Main Channel)						
Number	2	W	+	0	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	0.8	m				
Width of side plate	50	mm				
Side Water Depth	0.6	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.286	/	0.700	/	0.550	/ 2
	×	( 20	+	9 )/	20	
	=	0.539	<	0.800	m/sec	OK
Velocity through screen	0.182	/	0.700	/	0.550	/ 1
where Design Flow for the year 2034	×	( 20	+	9 )/	20	
	=	0.685	<	0.800	m/sec	OK
(3) Coarse Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	50	mm				
Bar Thickness	9	mm				
Channel Width	0.8	m				
Side Water Depth	0.6	m				
Velocity through screen	0.286	/	0.800	/	0.600	/ 2
where Design Flow for the year 2049	×	( 50	+	9 )/	50	
	=	0.352	<	0.800	m/sec	OK
Velocity through screen	0.182	/	0.800	/	0.600	/ 1
where Design Flow for the year 2034	×	( 50	+	9 )/	50	
	=	0.447	<	0.800	m/sec	OK

A-3 Process Cal. EA&al 7MLD Doddabettahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

**3. Raw Sewage Sump**

Item	7MLD STP-TSPS	
[2] Geometory		
(1) Raw Sewage Sump		
Number	1	Basin
Dia	9.50	m
Pump Operating Depth	1.000	m
Retention Time whe Design Flow for the year 2049	$( \frac{9.50^2 \times \pi}{4} \times 1.000 ) / 0.286$	$/ 60$ = 4.13 > 3.75 min (=minimum time of one pump cycle) OK
Retention Time whe Design Flow for the year 2034	$( \frac{9.50^2 \times \pi}{4} \times 1.000 ) / 0.182$	$/ 60$ = 6.49 > 3.75 min (=minimum time of one pump cycle) OK
High Water Level	+ 0.000	m
Pump Off Level	+ -1.000	m
[3] Equipment		
(1) Sewage Pumps 1		
Number	2 W	+ 1 S
Bore Diameter	200	mm
Discharge Flow : 40% Q* 2 whe Design Flow for the year 2034	$0.182 \times 2$	$3600 \times 40.0\% Q$ = 262 ⇒ 270 m <sup>3</sup> /Hr
Total Head	15.0	m
(2) Sewage Pumps 2		
Number	1 W	+ 1 S
Bore Diameter	150	mm
Discharge Flow : 20% Q* 1 whe Design Flow for the year 2034	$0.182 \times 1$	$3600 \times 20.0\% Q$ = 131 ⇒ 135 m <sup>3</sup> /Hr
Total Head	15.0	m

A-3 Process Cal. EA&al 7MLD Doddabettahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

Item	7MLD STP																																																		
<b>1. STP Design Condition</b>																																																			
(1) Design Flow Rate	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th style="text-align: center;">m3/d</th> <th style="text-align: center;">m3/h</th> <th style="text-align: center;">m3/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td style="text-align: center;">7,000</td> <td style="text-align: center;">291.67</td> <td style="text-align: center;">0.081</td> </tr> <tr> <td>Max Daily</td> <td style="text-align: center;">7,000</td> <td style="text-align: center;">291.67</td> <td style="text-align: center;">0.081</td> </tr> <tr> <td>Max Hourly Peak factor 2.25</td> <td style="text-align: center;">15,750</td> <td style="text-align: center;">656.25</td> <td style="text-align: center;">0.182</td> </tr> </tbody> </table>											m3/d	m3/h	m3/s	Average Daily	7,000	291.67	0.081	Max Daily	7,000	291.67	0.081	Max Hourly Peak factor 2.25	15,750	656.25	0.182																									
	m3/d	m3/h	m3/s																																																
Average Daily	7,000	291.67	0.081																																																
Max Daily	7,000	291.67	0.081																																																
Max Hourly Peak factor 2.25	15,750	656.25	0.182																																																
(2) Design Water Quality	<p style="text-align: right;">Unit: mg/L</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th colspan="2">TP</th> </tr> <tr> <th>NH<sub>4</sub>-N</th> <th>Org-N</th> <th>NOx-N</th> <th>D-P</th> <th>P-P</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td style="text-align: center;">350</td> <td style="text-align: center;">800</td> <td style="text-align: center;">450</td> <td style="text-align: center;">45.5</td> <td style="text-align: center;">17.5</td> <td style="text-align: center;">7</td> <td style="text-align: center;">5</td> <td style="text-align: center;">2</td> </tr> <tr> <td>Outlet</td> <td style="text-align: center;">10</td> <td style="text-align: center;">50</td> <td style="text-align: center;">10</td> <td style="text-align: center;">1</td> <td style="text-align: center;">0</td> <td style="text-align: center;">9</td> <td style="text-align: center;">1</td> <td style="text-align: center;">1</td> </tr> <tr> <td>Removal rate</td> <td style="text-align: center;">97.1%</td> <td style="text-align: center;">93.7%</td> <td style="text-align: center;">97.8%</td> <td colspan="3" style="text-align: center;">85.7%</td> <td colspan="2" style="text-align: center;">71.4%</td> </tr> </tbody> </table>											BOD	COD	SS	T-N			TP		NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P	Inlet	350	800	450	45.5	17.5	7	5	2	Outlet	10	50	10	1	0	9	1	1	Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%	
	BOD	COD	SS	T-N			TP																																												
				NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P																																											
Inlet	350	800	450	45.5	17.5	7	5	2																																											
Outlet	10	50	10	1	0	9	1	1																																											
Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%																																												
<b>2. Inlet Chamber</b>																																																			
<b>[1] Design Condition</b>																																																			
(1) Design Flow Rate	Max Hourly	=	15,750	m3/day																																															
		=	0.182	m3/sec																																															
<b>[2] Geometry</b>																																																			
(1) Number of Basins	1	Basin																																																	
(2) Depth of Basin	1.500	m																																																	
(3) Width of Basin	1.700	m																																																	
(4) Length of Basin	2.000	m																																																	
(5) Volume required of Basin	1.500	×	1.700	×	2.000	=	1.3	m3																																											
(6) Retention Time	1.500	×	1.700	×	2.000	/	0.182	×	1																																										
	=	28.02	sec																																																
(7) Basin Dimensions	Width	1.700	m	×	Length	2.000	m																																												
	×	Depth	1.500	m																																															



A-3 Process Cal. EA&al 7MLD Doddabettahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Wastewater Flow	$\begin{aligned} \text{Max Hourly} &= 15,750 \text{ m}^3/\text{d} \\ &= 0.182 \text{ m}^3/\text{sec} \end{aligned}$
[2] Geometory	
(1) Inlet Gate	
Number	2 Main + 1 Bypass
Width	0.300 m
Height	0.450 m
Floor Level	+ 2.000 m
Bottom	+ 0.000 m
Influent Water Level	+ 0.300 m
Velocity	$\begin{aligned} &0.182 \text{ } \swarrow \quad 0.300 \text{ } \swarrow \quad 0.300 \text{ } \swarrow \quad 2 \\ = &1.011 \text{ } \div \quad 1.000 \text{ m/sec} \end{aligned}$
(2) Screen Channel	
Number	2 Main + 1 Bypass
Width	0.600 m
Side Water Depth	0.400 m
Velocity	$\begin{aligned} &0.182 \text{ } \swarrow \quad 0.600 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 2 \\ = &0.379 \text{ } \div \quad 0.450 \text{ m/sec} \end{aligned}$
(3) Channel Dimensions	$\begin{aligned} \text{Width} &0.6 \text{ m} \times \text{Length} &6.0 \text{ m} \\ &\times \text{SWD} &0.4 \text{ m} \end{aligned}$
[3] Equipment	
(1) Inlet Gate	
Number	2 W + 1 S
Dimension	Width 0.3 m × Height 0.45 m
Design Water Level	2.00 m
(2) Fine Screens (Main Channel)	
Number	2 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	0.6 m
Width of side plate	50 mm
Side Water Depth	0.4 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	$\begin{aligned} &0.182 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 0.350 \text{ } \swarrow \quad 2 \\ &\times ( \quad 6 \quad + \quad 2 \quad ) / \quad 6 \\ = &0.693 < \quad 0.800 \text{ m/sec} \end{aligned}$
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	0.6 m
Side Water Depth	0.4 m
Velocity through screen	$\begin{aligned} &0.182 \text{ } \swarrow \quad 0.600 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 2 \\ &\times ( \quad 20 \quad + \quad 9 \quad ) / \quad 20 \\ = &0.550 < \quad 0.800 \text{ m/sec} \end{aligned}$

A-3 Process Cal. EA&al 7MLD Doddabettahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>4. Grit Chamber</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Peak flow = 15,750 m <sup>3</sup> /day = 0.182 m <sup>3</sup> /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0111 m/sec = 960 m <sup>3</sup> /m <sup>2</sup> /day
(4) Average Velocity	0.3 m/sec
<b>[2] Grit Chamber</b>	
(1) Surface Area required	0.182 / 0.0111 = 16.40 m <sup>2</sup>
(2) Number of Basins	1 S + 1 W
(3) Surface Area required/Basin	16.4 / 1 = 16.40 m <sup>2</sup>
(4) Length of Basin	16.40 ^0.5 = 4.0 m → 4.5 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.182 × 60 sec / 1 = 10.9 m <sup>3</sup>
(7) Depth required	10.9 / 4.5 / 4.5 = 0.539 m
(8) Basin Dimensions	Width 4.5 m × Length 4.5 m × Depth 0.5 m (Freeboard 0.3m)
(9) Retention Time	4.5 × 4.5 × 0.5 / 0.182 × 1 = 60.00 sec
(10) Surface Overflow Rate at Peak Flow	15,750 / 4.5 / 4.5 / 1 = 777.777778 < 960 m <sup>3</sup> /m <sup>2</sup> /day
<b>[3] Parshall Flume</b>	
(1) Design Flow Rate	Q= 182.000 l/sec
(2) Throat width	W= 0.450 m
(3) Water depth Ha	Ha= ( Q / 2264 / W ) <sup>2/3</sup> Ha= 0.317 m
(4) Crest Level	+ m ≐ Minimum water level at downstream channel
(5) Water level at the crest	+ 0.317 m
(6) Channel bottom level	+ m
(7) Upstream Channel width	1.500 m
(8) SWD of Upstream Channel	0.700 m
(9) Average velocity at upstream channel	0.173 m/sec
(10) Total Length of channel	10.000 m
<b>[4] Inlet Weir Gate</b>	
(1) Number	2 Units
(2) Weir Width	0.600 m
(3) Stroke	0.450 m
(4) Overflow Height	0.400 m
(5) Overflow Height (actual)	( 0.182 / 1.840 / 0.600 / 2 ) <sup>2/3</sup> = 0.189 < 0.400 m

A-3 Process Cal. EA&al 7MLD Doddabettahalli Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<b>5. Reactor</b>																																																								
<b>[1] Design Condition</b>																																																								
(1) Design Wastewater Flow	Q = 7,000 m <sup>3</sup> /day (summer) Q' = 7,000 m <sup>3</sup> /day (Winter)																																																							
(2) Design Sewage Quality																																																								
Inlet BOD	350 mg/l																																																							
Outlet BOD	10.0 mg/l																																																							
Inlet S-BOD	235 mg/l assumed as 67% of BOD																																																							
Inlet COD	800 mg/l																																																							
Inlet bCOD : S <sub>0</sub>	578 mg/l																																																							
Inlet nbCOD	223 mg/l																																																							
bCOD/BOD	1.65																																																							
Inlet S-COD : sCOD	271 mg/l																																																							
Inlet rbCOD	231 mg/l bCOD*40%																																																							
Inlet sbCOD	347 mg/l bCOD*60%																																																							
Outlet S-COD : nbsCODE	40 mg/l																																																							
Inlet nbpCOD : nbpCOD	183 mg/l = TCOD-bCOD-nbsCODE																																																							
Inlet SS	450 mg/l																																																							
Inlet VSS	383 mg/l assumed as 85% of TSS																																																							
: VSS <sub>COD</sub>	1.38 gCOD/gVSS = TCOD-sCOD/VSS																																																							
: nbVSS	131.96 gnbVSS/m <sup>3</sup> = nbpCOD/VSS <sub>COD</sub>																																																							
: iTSS	67.50 gnbVSS/m <sup>3</sup> = TSS-VSS																																																							
Inlet T-N	70 mg/l																																																							
Inlet TKN	70 mg/l																																																							
Inlet NH <sub>4</sub> -N	45.0 mg/l																																																							
Inlet T-P	7 mg/l																																																							
Inlet D-P	5 mg/l																																																							
Inlet Alkalinity as CaCO <sub>3</sub>	380 mg/l																																																							
Outlet Kjeldahl N	1.0 mg/l																																																							
Outlet NH <sub>4</sub> -N	1.0 mg/l																																																							
Outlet NO <sub>3</sub> -N	9.0 mg/l																																																							
Outlet T-P	2 mg/l																																																							
Outlet D-P	1 mg/l																																																							
(3) Water Temperature	T = 20.0 °C																																																							
(4) Safety Factor for Nitrogen	SF = 1.5																																																							
(5) Return Sludge Concentration	R <sub>s</sub> = 8,000 mg/l																																																							
(6) MLSS MLVSS	X <sub>TSS</sub> = 3,000 mg/l																																																							
(7) DO in the Reactor	2 mg/L																																																							
<b>[2] Design Value for perfect Nitrification of Nitrification Process</b>																																																								
(1) Activated sludge design kinwtic coefficients at 20°C																																																								
	<table border="1"> <thead> <tr> <th>Coefficient</th> <th>Unit</th> <th>COD oxidatio</th> <th>NH<sub>4</sub> oxidatio</th> <th>NO<sub>2</sub> oxidatio</th> </tr> </thead> <tbody> <tr> <td>μ<sub>max</sub></td> <td>gVSS/gVSS · d</td> <td>6.000</td> <td>0.900</td> <td>1.000</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>mg/L</td> <td>8.000</td> <td>0.500</td> <td>0.200</td> </tr> <tr> <td>Y</td> <td>gVSS/g substrate oxidized</td> <td>0.450</td> <td>0.150</td> <td>0.050</td> </tr> <tr> <td>b</td> <td>gVSS/gVSS · d</td> <td>0.120</td> <td>0.170</td> <td>0.170</td> </tr> <tr> <td>fd</td> <td>unitless</td> <td>0.150</td> <td>0.150</td> <td>0.150</td> </tr> <tr> <td>K<sub>O<sub>2</sub></sub></td> <td>mg/L</td> <td>0.200</td> <td>0.500</td> <td>0.900</td> </tr> <tr> <td>θ Value</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>μ<sub>max</sub></td> <td>unitless</td> <td>1.070</td> <td>1.072</td> <td>1.063</td> </tr> <tr> <td>b</td> <td>unitless</td> <td>1.040</td> <td>1.029</td> <td>1.029</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>unitless</td> <td>1.000</td> <td>1.000</td> <td>1.000</td> </tr> </tbody> </table> <p>Wastwater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF &amp; EDDY/AECOM)</p>	Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio	μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200	Y	gVSS/g substrate oxidized	0.450	0.150	0.050	b	gVSS/gVSS · d	0.120	0.170	0.170	fd	unitless	0.150	0.150	0.150	K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900	θ Value					μ <sub>max</sub>	unitless	1.070	1.072	1.063	b	unitless	1.040	1.029	1.029	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000
Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio																																																				
μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200																																																				
Y	gVSS/g substrate oxidized	0.450	0.150	0.050																																																				
b	gVSS/gVSS · d	0.120	0.170	0.170																																																				
fd	unitless	0.150	0.150	0.150																																																				
K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900																																																				
θ Value																																																								
μ <sub>max</sub>	unitless	1.070	1.072	1.063																																																				
b	unitless	1.040	1.029	1.029																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000																																																				
(2) μ <sub>AOB</sub>	μ <sub>AOB</sub> = 0.3100 g/g · d = μ <sub>max, AOB</sub> [S <sub>NH<sub>4</sub></sub> / (S <sub>NH<sub>4</sub></sub> + K <sub>NH<sub>4</sub></sub> )] [S <sub>O</sub> / (S <sub>O</sub> + K <sub>O, AOB</sub> )] - b <sub>AOB</sub>																																																							
μ <sub>max, AOB, T</sub>	μ <sub>max, AOB, T</sub> = 0.9000 g/g · d = μ <sub>max</sub> * 1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900																																																							
b <sub>AOB, T</sub>	b <sub>AOB, T</sub> = 0.1700 = b * 1.029 <sup>(T-20)</sup> b at 20°C = 0.170																																																							
S <sub>NH<sub>4</sub></sub>	S <sub>NH<sub>4</sub></sub> = 1.0000 mg/l																																																							
DO	DO = 2.0000 mg/l																																																							
K <sub>O, AOB</sub>	K <sub>O, AOB</sub> = 0.5000 mg/l																																																							

A-3 Process Cal. EA&al 7MLD Doddabettahalli Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

(2) Design SRT	SRT= 4.8387 day ⇒ 5.0000 day	$=1/\mu_{AOB} \times SF$
(3) Biomass production		
P <sub>X,VSS</sub>	P <sub>X,VSS</sub> = 2188.927 kg/d	=P <sub>X,bio</sub> +Q(nbVSS)
P <sub>X,TSS</sub>	P <sub>X,TSS</sub> = 2884.700 kg/d	=P <sub>X,bio</sub> /0.85+Q(nbVSS)+Q(TSS <sub>0</sub> -VSS <sub>0</sub> )+5*Q*Al
S	S= 0.4507 mg/l	=K <sub>s</sub> [1+b <sub>H</sub> (SRT)]/[SRT(μ <sub>m</sub> -b <sub>H</sub> )-1]
b <sub>H</sub>	b <sub>H</sub> = 0.1200	=b*1.04 <sup>(T-20)</sup> b at 20°C = 0.120
Y <sub>H</sub>	Y <sub>H</sub> = 0.4500 gVSS/g bCOD	
μ <sub>m,T</sub>	μ <sub>m,T</sub> = 6.0000 g/g·d	=μ <sub>max</sub> *1.04 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 6.000
Y <sub>n</sub>	Y <sub>n</sub> = 0.150 gVSS/g Nox	
NO <sub>x</sub>	NO <sub>x</sub> = 47.400 mg/l	
P <sub>X,bio,VSS</sub>	P <sub>X,bio,VSS</sub> = 1265.214 kg VSS/d	=Q·Y <sub>H</sub> (S <sub>0</sub> -S)/[1+b <sub>H</sub> (SRT)]+f <sub>d</sub> ·b <sub>H</sub> ·QY <sub>H</sub> (S <sub>0</sub> -S)SRT/[1+b <sub>H</sub> (SRT)]
	1136.066	+QY <sub>n</sub> (Nox)[2+b <sub>AOB</sub> (SRT)]
	102.246	=Q·Y <sub>H</sub> (S <sub>0</sub> -S)/[1+b <sub>H</sub> (SRT)]
	26.903	=f <sub>d</sub> ·b <sub>H</sub> ·QY <sub>H</sub> (S <sub>0</sub> -S)SRT/[1+b <sub>H</sub> (SRT)]
		=QY <sub>n</sub> (Nox)[1+b <sub>AOB</sub> (SRT)]
NO <sub>x</sub>	NO <sub>x</sub> = 47.311 mg/l	=TKN-Ne-0.12P <sub>X,bio</sub> /Q
(4) Required Aeration Tank Volume		
V <sub>a</sub>	V <sub>a</sub> = 4,808 m <sup>3</sup>	
τ	τ = 16.48 hr ⇒ 18.00 hr	=V <sub>a</sub> /Q × 24
X <sub>VSS</sub> ·V <sub>a</sub>	X <sub>VSS</sub> ·V <sub>a</sub> = 10,945 kg VSS	=P <sub>X,VSS</sub> ·SRT
X <sub>TSS</sub> ·V <sub>a</sub>	X <sub>TSS</sub> ·V <sub>a</sub> = 14,423 kg TSS	=P <sub>X,TSS</sub> ·SRT
F/M	F/M= 0.224 kgBOD/kgMLVSS	
FractionVSS=	FractionVSS= 0.759	
MLVSS=	MLVSS= 2276 mg/L	
(5) BODloading	BODloading= 0.510 kg/m <sup>3</sup> ·d	
(6) Observed Yield		
Y <sub>obs,TSS</sub>	Y <sub>obs,TSS</sub> = 1.178 gTSS/gBOD	
Y <sub>obs,VSS</sub>	Y <sub>obs,VSS</sub> = 0.894 gVSS/gBOD	
bCODremoved=	bCODremoved= 4,039 kg/d	
(7) effluent NO <sub>2</sub> -N	NO <sub>2</sub> -N= 0.2315 mg/l	=K <sub>s</sub> [1+b <sub>NOB</sub> (SRT)]/[SRT(μ <sub>NOB</sub> -b <sub>NOB</sub> )-1]
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700	=b*1.029 <sup>(T-20)</sup> b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 1.0000 g/g·d	=μ <sub>max</sub> *1.04 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 1.000
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.6897 g/g·d	=μ <sub>max,NOB</sub> [S <sub>0</sub> /(S <sub>0</sub> +K <sub>O2,NOB</sub> )]
	S <sub>0</sub> = 2.000 mg/l	
	K <sub>O2,NOB</sub> = 0.900 mg/l	
(8) effluent NH <sub>4</sub> -N	NH <sub>4</sub> -N= 0.5286 mg/l	=K <sub>s</sub> [1+b <sub>NOB</sub> (SRT)]/[SRT(μ <sub>NOB</sub> -b <sub>NOB</sub> )-1]
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700	=b*1.029 <sup>(T-20)</sup> b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 0.9000 g/g·d	=μ <sub>max</sub> *1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.7200 g/g·d	=μ <sub>max,NOB</sub> [S <sub>0</sub> /(S <sub>0</sub> +K <sub>O2,NOB</sub> )]
	S <sub>0</sub> = 2.000 mg/l	
	K <sub>O2,NOB</sub> = 0.500 mg/l	
(9) Ratio of Return Sludge	8,000·Rr/(1+Rr)= 3,000 mg/L 3,000/(8,000-3,000)= 0.60 Rr = 0.60	

A-3 Process Cal. EA&al 7MLD Doddabettahalli Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

<b>[3] Design for Nitrification and Denitrification Process</b>																					
(1) Active biomass concentration	$X_b = Q \cdot (SRT) / V \cdot Y_H \cdot (S_0 - S) [1 + b_H(SRT)]$ = 1,181.47 mg/l																				
(2) IR ratio	$IR = NO_x / Ne - 1.0 - R$ = 3.66																				
(3) The amount of NO <sub>3</sub> -N fed to the anoxic tank	$Nox\ feed = (IR + R) \cdot Q \cdot Ne$ = 268,174.27 kg/d																				
(4) The anoxic tank volume	$V_{nor} = 481\ m^3 = V_a \times 10\%$ $V_{nor} = 1,458\ m^3 \quad \tau_{DN} = 5.000\ h$																				
(5) F/M <sub>b</sub>	F/M <sub>b</sub> = 1.42 g/g·d																				
(6) Fraction of rbCOD	40.00% = rbCOD/bCOD																				
	<table border="1"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b<sub>0</sub></th> <th>b<sub>1</sub></th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>	Percent rdCOD(%)	SDNR equation coefficients		b <sub>0</sub>	b <sub>1</sub>	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162
Percent rdCOD(%)	SDNR equation coefficients																				
	b <sub>0</sub>	b <sub>1</sub>																			
10	0.186	0.078																			
20	0.213	0.118																			
30	0.235	0.141																			
40	0.242	0.152																			
50	0.270	0.162																			
(8) SDNR <sub>b</sub>	$SDNR_b = 0.296\ g/g \cdot d = b_0 + b_1 [\ln(F/M_b)]$ $b_0 = 0.242$ $b_1 = 0.152$																				
(8) SDNR	$SDNR = 0.110\ g/g \cdot d = SDNR_b (MLVSS_r / MLVSS)$ $SDNR_{adj} = 0.212\ g/g \cdot d = SDNR_b - 0.029 \ln(F/M_b) - 0.012$ IR=3-4 $= SDNR_b - 0.0166 \ln(F/M_b) - 0.078$ IR=2 $SDNR_t = 0.296\ g/g \cdot d = SDNR_b \cdot \theta^{(F/M_b - 20)}$ $\theta = 1.026$																				
(9) NO <sub>r</sub>	$NO_r = 364,695.16\ kg/d = N_{nox} \cdot SDNR \cdot X_b$ $> Nox\ feed = 268,174\ kg/d$																				
(10) Alkalinity to be added to maintain pH7	-108.33 mg/l																				
	Influent Alk 380.00 mg/l Alk used 338.44 mg/l = 7.14 × Nox Alk produced 136.77 mg/l = 3.57 × (NO <sub>x</sub> - NO <sub>xe</sub> ) Alk to maint 70.00 mg/l																				
<b>[4] Design of Phosphorus Removal Process</b>																					
(1) Removal T-P	3.13 mg/l																				
P in waste sludge	px = 1.00%																				
Generated waste sludge	Px <sub>vss</sub> = 2188.927 kg/d																				
Rmval Phosphorus	21.88926619 kg/d																				
(2) Effluent T-P without Al	3.87 mg/l																				
(3) Required Al to initial soluble phosphorus ratio	1.00 mol/mol																				
(4) Required Al dosing rate	3.48 mg/l as Al																				
	42.98 mg/l as crystal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> · 18H <sub>2</sub> O																				
(5) Required Aluminum Sulfate	300.84 kg/d																				
(6) Required Aluminum Sulfate solutic 10%	2.87 m <sup>3</sup> /d																				
	119.38 L/H																				
(7) Additional sludge	121.96 kg/d																				

A-3 Process Cal. EA&al 7MLD Doddabettahalli Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

<b>[5] Reactor</b>																																																																			
(1) Total volume of Aeration Basins	$V_A = Q \cdot \theta_a / 24$ $= 5,250 \text{ m}^3$																																																																		
(2) Total volume of Anoxic Basins	$V_{DN} = Q \cdot \theta_{DN} / 24$ $= 1,458 \text{ m}^3$																																																																		
	<table border="1"> <thead> <tr> <th rowspan="2">Item</th> <th rowspan="2">Volume required</th> <th colspan="2">Retention Time required</th> <th rowspan="2">Ratio of Volume</th> </tr> <tr> <th>Summer</th> <th>Winter</th> </tr> <tr> <th>unit</th> <th>m<sup>3</sup></th> <th>hour</th> <th>hour</th> <th></th> </tr> </thead> <tbody> <tr> <td>Anaerobic</td> <td>V<sub>AN</sub></td> <td>440</td> <td>1.50</td> <td>1.50</td> <td>0.30</td> </tr> <tr> <td>Anoxic</td> <td>V<sub>DN</sub></td> <td>1,458</td> <td>5.00</td> <td>5.00</td> <td>1.00</td> </tr> <tr> <td>Aerobic</td> <td>V<sub>A</sub></td> <td>5,250</td> <td>18.00</td> <td>18.00</td> <td>3.60</td> </tr> <tr> <td>Total</td> <td>V</td> <td>7,148</td> <td>24.50</td> <td>24.50</td> <td></td> </tr> </tbody> </table>	Item	Volume required	Retention Time required		Ratio of Volume	Summer	Winter	unit	m <sup>3</sup>	hour	hour		Anaerobic	V <sub>AN</sub>	440	1.50	1.50	0.30	Anoxic	V <sub>DN</sub>	1,458	5.00	5.00	1.00	Aerobic	V <sub>A</sub>	5,250	18.00	18.00	3.60	Total	V	7,148	24.50	24.50																															
Item	Volume required			Retention Time required			Ratio of Volume																																																												
		Summer	Winter																																																																
unit	m <sup>3</sup>	hour	hour																																																																
Anaerobic	V <sub>AN</sub>	440	1.50	1.50	0.30																																																														
Anoxic	V <sub>DN</sub>	1,458	5.00	5.00	1.00																																																														
Aerobic	V <sub>A</sub>	5,250	18.00	18.00	3.60																																																														
Total	V	7,148	24.50	24.50																																																															
<b>[6] Geometry</b>																																																																			
(1) Basin Dimensions	<table border="1"> <thead> <tr> <th>Width</th> <th>Length</th> <th>Depth</th> <th>Basins</th> </tr> </thead> <tbody> <tr> <td>8.0</td> <td>84.0</td> <td>5.5</td> <td>2</td> </tr> </tbody> </table>	Width	Length	Depth	Basins	8.0	84.0	5.5	2																																																										
Width	Length	Depth	Basins																																																																
8.0	84.0	5.5	2																																																																
Cross Section	8.0*5.5 = 44.0 m <sup>2</sup> /Basin																																																																		
Hantzsch Subtraction	= 1.0 m <sup>2</sup> /Basin																																																																		
after Subtraction	44.0-1.0 = 43.0 m <sup>2</sup> /Basin																																																																		
Total Volume	43.0*84.0 = 3,612 m <sup>2</sup> /Basin 7,224 m <sup>3</sup> /Total																																																																		
(2) Partition of Basin																																																																			
	<table border="1"> <thead> <tr> <th>Item</th> <th>unit</th> <th>Anaerobic</th> <th>Anoxic</th> <th>Aerobic</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Cross Section</td> <td>m<sup>2</sup></td> <td colspan="3">43.0</td> <td></td> </tr> <tr> <td>Length required</td> <td>m</td> <td>5.1</td> <td>17.0</td> <td>61.0</td> <td>83.1</td> </tr> <tr> <td>Volume required per Basin</td> <td>m<sup>3</sup></td> <td>220</td> <td>729</td> <td>2,625</td> <td>3,574</td> </tr> <tr> <td>Total Volume required</td> <td>m<sup>3</sup></td> <td>440</td> <td>1,458</td> <td>5,250</td> <td>7,148</td> </tr> <tr> <td>Actual Cross Section</td> <td>m<sup>2</sup></td> <td>43.0</td> <td>43.0</td> <td>43.0</td> <td></td> </tr> <tr> <td>Actual Length</td> <td>m</td> <td>6.0</td> <td>17.0</td> <td>61.0</td> <td>84.0</td> </tr> <tr> <td>Actual Volume per Basin</td> <td>m<sup>3</sup></td> <td>258</td> <td>731</td> <td>2,623</td> <td>3,612</td> </tr> <tr> <td>Actual Total Volume</td> <td>m<sup>3</sup></td> <td>516</td> <td>1,462</td> <td>5,246</td> <td>7,224</td> </tr> <tr> <td>Actual Ratio of Volume</td> <td></td> <td>0.35</td> <td>1.00</td> <td>3.59</td> <td></td> </tr> <tr> <td>Actual Retention Time</td> <td>hour</td> <td>1.77</td> <td>5.01</td> <td>17.99</td> <td>24.77</td> </tr> </tbody> </table>	Item	unit	Anaerobic	Anoxic	Aerobic	Total	Cross Section	m <sup>2</sup>	43.0				Length required	m	5.1	17.0	61.0	83.1	Volume required per Basin	m <sup>3</sup>	220	729	2,625	3,574	Total Volume required	m <sup>3</sup>	440	1,458	5,250	7,148	Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0		Actual Length	m	6.0	17.0	61.0	84.0	Actual Volume per Basin	m <sup>3</sup>	258	731	2,623	3,612	Actual Total Volume	m <sup>3</sup>	516	1,462	5,246	7,224	Actual Ratio of Volume		0.35	1.00	3.59		Actual Retention Time	hour	1.77	5.01	17.99	24.77
Item	unit	Anaerobic	Anoxic	Aerobic	Total																																																														
Cross Section	m <sup>2</sup>	43.0																																																																	
Length required	m	5.1	17.0	61.0	83.1																																																														
Volume required per Basin	m <sup>3</sup>	220	729	2,625	3,574																																																														
Total Volume required	m <sup>3</sup>	440	1,458	5,250	7,148																																																														
Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0																																																															
Actual Length	m	6.0	17.0	61.0	84.0																																																														
Actual Volume per Basin	m <sup>3</sup>	258	731	2,623	3,612																																																														
Actual Total Volume	m <sup>3</sup>	516	1,462	5,246	7,224																																																														
Actual Ratio of Volume		0.35	1.00	3.59																																																															
Actual Retention Time	hour	1.77	5.01	17.99	24.77																																																														
<b>[7] Equipment</b>																																																																			
(1) Ras Pumps																																																																			
Ras Ratio	60%																																																																		
Required Capacity	7,000 m <sup>3</sup> /day × 60% / 24 / 2																																																																		
= 88	m <sup>3</sup> /Hr ⇒ 90 m <sup>3</sup> /Hr																																																																		
Number	2 Work																																																																		
	2 Stanby																																																																		
(2) Circulation Pumps																																																																			
Ras Ratio	366%																																																																		
Required Capacity	7,000 m <sup>3</sup> /day × 366% / 24 / 4																																																																		
= 267	m <sup>3</sup> /Hr ⇒ 270 m <sup>3</sup> /Hr																																																																		
Number	4 Work																																																																		
	2 Stanby																																																																		
(3) SAS Pumps																																																																			
Excess Sludge	380 m <sup>3</sup> /day																																																																		
Sludge withdraw	12 Times/day																																																																		
Running Time	0.5 Hr/Time																																																																		
Required Capacity	380 m <sup>3</sup> /day / 12 / 0.5 / 2																																																																		
= 31.64	m <sup>3</sup> /Hr ⇒ 35 m <sup>3</sup> /Hr																																																																		
Number	2 Work																																																																		
	2 Stanby																																																																		

A-3 Process Cal. EA&al 7MLD Doddabettahalli Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

(4) Alum Solution Tank										
Number	2	W	+	0	S					
Alum concentration as crystal	10 %									
Gravity of dissolved dechlorine	1.05									
Required solution volume	300.84 kg / d		×	100	/	10	/	1.05	/	1000
	=	2.87		m3/d						
Volume of Tank	2.6			m3/tank						
Total Volume of Tanks	5.2			m3	(Duration=	1.81	day)			
(5) Mixer for Alum Solution Tank										
Number	2	W	+	0	S					
(6) Alum Dosing Pump										
Number	2	W	+	1	S					
Capacity	2.87 m3/d	/	24	×	1000	/	2	×	2	
	119.38 l/h/unit		⇒	120	l/h/unit					

**STP Process Calculation Supporting Report 12.2.3**

<b>6. Air Requirement at Average Flow</b>	
[1] Design Condition	
(1) AOR	AOR = 3,029 kg/day = 126.2 kg/h
Q <sub>in</sub> : Design Average Flow m <sup>3</sup> /d	7,000
Inlet bCOD : S <sub>0</sub>	578 mg/l
S=	0.451 mg/l
Nox=	47.400 mg/l
P <sub>X,bio</sub> =	1,238.3 kg VSS/d does not include nitrifying bacteria
R <sub>0</sub> =	R <sub>0</sub> = Q(S <sub>0</sub> - S - k(Nox - NOx)) - 1.42P <sub>X,bio</sub> + 4.57Q · NOx
R <sub>0</sub> =	3,029 kg O <sub>2</sub> /d
k=	2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{\text{AOR} \times C_s \cdot a \times 1.024^{20-T}}{\alpha \times F (\beta \cdot C_{sw} / C_s \cdot (P_b / P_a) a - C_A)}$
	C <sub>s</sub> : Saturated DO at sea level and 20 °C 9.09 mg/L
	C <sub>sw</sub> : Saturated DO at sea level and operating Temperature 9.09 mg/L at 20 °C
	20-T : 0.0 1.024 <sup>20-T</sup> : 1.0000
	C <sub>A</sub> : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1 + 0.40D <sub>j</sub> /P <sub>a</sub> 1.19357
	D <sub>j</sub> : Tank Liquid Depth 5.00 m
	P <sub>a</sub> : Standard absolute pressure at s 10.332 m
	P <sub>b</sub> : Absolute pressure at Plant Site Elevation m
	P <sub>b</sub> /P <sub>a</sub> : exp[-gM(z <sub>b</sub> -z <sub>a</sub> )/R*T] 0.900
	g : Acceleration due to Gravity 9.80665 m/s <sup>2</sup>
	M : Mole of Air 28.97 kg/kg-mole
	z <sub>b</sub> : Plant Site Elevation 900 m
	z <sub>a</sub> : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 293.15 Kelvin
	α : relative Transfer Rate to clean Water 0.65
	β : relative DO Saturation to clean Water 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{32,858}{4.2591} = 7,714.69 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Standard O <sub>2</sub> required at Field Conditions per Basin =	3,857 kg/day
(5) SOTE for the above Effective Aeration Depth	28.0 %
(6) Fraction of O <sub>2</sub> in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	15%
(9) Air required at Field Conditions per Basins	= 56,731 m <sup>3</sup> /day = 2,363.8 m <sup>3</sup> /hr
[2] Equipment	



A-3 Process Cal EA&al 7MLD Doddabettahalli Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

(1) Air Blower					
Number	4	W	+	2	S
Required Capacity	2363.8	m <sup>3</sup> /Hr·Basin	/	2	unit/Basin
	= 1181.9	m <sup>3</sup> /h	⇒	1200	m <sup>3</sup> /h /Unit
Pressure	65	kPa			
Safety Factor	10	%			
Heat capacity ratio	1.4				
Atmospheric pressure at site elevation	91.234	kPa			
Total inlet pressure	89.234	kPa			
Volume rate of flow at inlet point	22.704	m <sup>3</sup> /min			
Total discharge pressure	156.234	kPa			
Overall adiabatic efficiency	0.65				
Inlet air temperature (min.)	15	°C			
Shaft power	32.101	kW			
Rated Output of Motor	35.311	kW	⇒	37	kW

A-3 Process Cal. EA&al 7MLD Doddabettahalli Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>7. Final Clarifire</b></p>			
<p>[1] <b>Design Condition</b></p>			
<p>(1) Design Wastewater Flow</p>	<p>Q= 7,000 m<sup>3</sup>/day</p>		
<p>(2) Water Temperature</p>	<p>T= 20.0 °C</p>		
<p>(3) MLSS</p>	<p>X<sub>ef</sub>= 3,000 mg/l</p>		
<p>(4) SVI</p>	<p>SVI= 300</p>		
<p>(5) Sedimentation Velocity</p>	$v = 4.899 \cdot 10^6 \cdot T^{(0.954)} \cdot X_{ef}^{(-1.354)} \cdot SVI^{(-0.77)}$ $= 4.899 \cdot 10^6 \cdot 20.0^{0.954} \cdot 3,000^{-1.354} \cdot 150^{-0.770}$ $= 20.7 \text{ m/day}$		
<p>(6) Surface Overflow Rate required</p>	$S' = v / (1.5 \cdot 1) = 20.7 / (1.5 \cdot 1.0) = 13.8 \text{ m}^3/\text{m}^2 \cdot \text{day}$	<p>→</p>	$12.0 \text{ m}^3/\text{m}^2 \cdot \text{day}$
<p>[2] <b>Geometry</b></p>			
<p>(1) Surface Area required</p>	$A = 7,000 / 12.0 = 583 \text{ m}^2$		
<p>(2) Demensions</p>	<p style="text-align: center;">Diameter                  Depth          Basin</p>		
<p>(3) Actual Surface Area</p>	$S = 19.5^2 \cdot 3.14 / 4 \cdot 2.0 = 597 \text{ m}^2$		
<p>(4) Surface Overflow Rate</p>	$S = 7,000 / 597 = 11.7 \text{ m}^3/\text{m}^2 \cdot \text{day}$		

A-3 Process Cal. EA&al 7MLD Doddabettahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

8. Chlorination	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 7,000 m <sup>3</sup> /day 291.67 m <sup>3</sup> /h Peak Flow 15,750 m <sup>3</sup> /day 656.25 m <sup>3</sup> /h
(2) Contact Time	30 min
(3) Type of Chlorine	Cl <sub>2</sub> -GAS
(4) Design Chlorine Dosage Rate	10 mg/L
(5) Required Chlorine per day	Average Daily Flow / 1000 × Design Chlorine Dosage Rate = 70.0 kg/d = 2.92 kg/h
<b>[2] Chlorination Contact Tank</b>	
(1) Volume required	Average Daily Flow / 1440 × Contact Time = 145.8 m <sup>3</sup>
(2) Nos. of lanes	3 lanes
(3) Width of lane	2.00 m
(4) Length of lane	13.00 m
(5) Side Water Depth	2.00 m
(6) Nos. of Tanks	1 tank
(7) Total Width of Tank	6.80 m Approx..
(8) Average Velocity	Decant Flow / 3600 / Width / Depth = 291.67 / 3600 / 2.00 / 2.00 = 0.020 m/sec
(9) Total Volume	Width × Length × Depth × Nos. of lanes × Nos. of Tanks = 2.0 m × 13.0 m × 2.0 m × 3 × 1 = 156 m <sup>3</sup> > 145.8 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Chlorine Dosing Condition	
Operation Dosage Rate -1	DC1 10 mg/L
(2) Chlorine Cylinder	
Type	- Cylindrical Convexsd Container
Cylinder Capacity	Cc 928 kg/cylinder
Average Dosage Rate -1	q1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 70 kg/day
Maximum Dosage Rate -1	q3 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 158 kg/day
Storage day	T More than 15 days
Required Storage Capacity	EC1 D × T = 1,050 kg
Unit Number	EN1 EC1 / Cc = 1.1 cylinders
Maximum Operation Numbers	
Cl <sub>2</sub> -Gas Volatilize Rate	Vr1 ##### @ 20°C Standard temperature
Maximum Dosing Rate	DC1 10 mg/L, Q <sub>T-D</sub> × q3 × 10 <sup>-3</sup> / 24 = 6.56 kg/h
Operation Numbers	EN2 DC1 / Vr1 = 0.8sets
Number	2 W + 2 S
(3) Chlorinator	
Type	Solution Feed Vacuum Type
Number	1 W + 1 S
Operation Dosage Rate -1	Dq1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 157.5 kg/day
Required Dosage Rate	Chlorine -1 : Dq1 / (EN1 × 24) = Minimum 0.00 kg/hr Maximum 6.6 kg/hr

A-3 Process Cal. EA&amp;al 7MLD Doddabettahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

(4) Chlorine Booster Pump	Branchy on the water supply pipe
Type	Water requiamet for mixed Chlori
Water Demand	(kg/hr) 1.0 1.5 2.0 2.5 3.0 4.0
Chlorinator Discharge	(L/min) 15 20 25 30 35 40
Water Demand	(kg/hr) 5.0 6.0 10.0 50.0 100.0 200.0
Chlorinator Discharge	(L/min) 45 50 60 300 600 1,200
Water Demand	-
Water requiamet	Qp1 Maximum dosage rate 6.6 kg/hr
For Chlorin	therefore 60 L/min
Booster Pump Type	Single suction volute pump
Number	1 W + 1 S
<b>9. Dechlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 7,000 m <sup>3</sup> /day
(2) Contact Time	10 min
(3) Type of Dechlorine	Sodium Thiosulfate (Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 5H <sub>2</sub> O)
(4) Free Residual Chlorine	1.0 mg/L assumed value
(5) Consumption per day	Average Daily Flow / 1000 × Free Residual Chlorine × 1.75
	× 1.5 (safety factor)
	= 18.4 kg/d
	= 0.77 kg/h
<b>[2] Dechlorination Contact Tank</b>	
(1) Volume required	Average Flow Rate / 60 × Contact Time
	= 48.6 m <sup>3</sup>
(2) Width of lane	6.80 m
(3) Length of lane	4.00 m
(4) Side Water Depth	2.00 m
(5) Nos. of Tanks	1 tank
(6) Total Volume	Width × Length × Depth
	= 6.8 m × 4.0 m × 2.0 m
	= 54 m <sup>3</sup> > 48.6 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Dechlorine Solution Tank	
Number	1 W + 0 S
Dechlorine concentration	10 %
Gravity of dissolved dechlorine	1.10
Required solution volume	18.38 kg/d × 100 / 10 / 1.10 / 1000
	= 0.17 m <sup>3</sup> /d
Volume of Tank	0.200 m <sup>3</sup> /tank (= 0.5 mW × 0.5 mL × 0.8 mH)
Total Volume of Tanks	0.200 m <sup>3</sup> (Duration= 1.20 day)
(2) Mixer for Dechlorine Solution Tank	
Number	2 W + 0 S
(3) Dechlorine Dosing Pump	
Number	1 W + 1 S
Capacity	0.38 m <sup>3</sup> /d / 24 × 1000 / 1
	15.66 l/h/unit ⇒ 16 l/h/unit

A-3 Process Cal. EA&al 7MLD Doddabettahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>10. Centrifuge</b>  <b>[1] Design Condition</b>                  (1) Type of Dewatering                  (2) Generated Sludge                  (3) Design Polyelectrolyte Dosage                  (4) Volume of Thickend Sludge                  (5) Consistency of Dewatered Sludge                  (6) Operation Time</p>	<p>Centrifuge                  3,038 kg/day                  Polyelectrolyte 5 kg/t-DS·day                  379.7 m<sup>3</sup>/day                  82 %                  12 hours/day (6 days per week)</p>
<p><b>[2] Volume of Centrifuges</b></p>	<p><math display="block">\frac{\text{Digested Solids}}{\text{Operation Time} \times \text{No.}} \times \text{Operation/week}</math> <math display="block">= \frac{379.7}{12 \times 2} \times \frac{7}{6} = 18.5</math> <p style="text-align: right;">→ 19 m<sup>3</sup>/hour</p> </p>
<p><b>[3] Dewatered Solids</b></p>	<p><math display="block">\text{Digested Sludge} \times (1 + \text{Injection Rate})</math> <math display="block">= 3,038 \times (1 + 0.0050)</math> <math display="block">= 3,053 \text{ kg/day}</math> </p>
<p><b>[4] Dewatered Cake Volume</b></p>	<p><math display="block">\text{Dewatered Solids} \times \frac{100}{100 - \frac{\text{Moisture Content}}{7}}</math> <math display="block">\times \frac{6 \text{ days per week}}{6}</math> <math display="block">= 3,053 \times \frac{100}{100 - 82} \times \frac{7}{6}</math> <math display="block">= 19.79 \text{ t/day}</math> <p>apparent specific gravity 1.00  <math display="block">\frac{19.79}{1.00} = 19.8 \text{ m}^3/\text{day}</math></p> </p>
<p><b>[5] Polyelectrolyte</b>                  (1) Design Polyelectrolyte Dosage                  (2) Required Polyelectrolyte                  (3) Dissolving concentration                  (4) Volume of Polyelectrolyte solution</p>	<p>Polyelectrolyte 5 kg/t-DS·day                  15.19 kg/day                  0.20 %                  7.59 m<sup>3</sup>/day</p>

A-3 Process Cal. EA&al 7MLD Doddabettahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>11. Centrifuge Feed Sump</b></p>	
<p><b>[1] Design Condition</b></p>	
<p>(1) Generated Thickend Sludge</p>	<p>3,038 kg/day</p>
<p>(2) Solids Consistency</p>	<p>0.80 %</p>
<p>(3) Volume of Thickened Sludge</p>	$\begin{aligned} & \text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3} \\ = & 3,038 \times \frac{100}{0.80} \times 10^{-3} \\ = & 380 \text{ m}^3/\text{day} \\ = & 15.82 \text{ m}^3/\text{h} \end{aligned}$
<p>(4) Sludge feed flow rate</p>	<p>19 m<sup>3</sup>/h × 2 = 38 m<sup>3</sup>/h</p>
<p>(5) Centrifuge Operation Time</p>	<p>12 hours/day ( 6 days per week)</p>
<p><b>[2] Geometry</b></p>	
<p>(1) Basin Dimensions</p>	$\begin{aligned} & \text{Width } 6.0 \text{ m} \times \text{Length } 6.0 \text{ m} \\ & \times \text{Depth } 3.5 \text{ m} \times 2 \\ = & 252.0 \text{ m}^3 \end{aligned}$
<p><b>[3] Equipment</b></p>	
<p>(1) Mixers for Centrifuge Feed Sumps</p>	
<p>Required Volume</p>	<p>252.0 m<sup>3</sup></p>
<p>Number</p>	<p>1 W + 1 S</p>

A-3 Process Cal. EA&al 7MLD Doddabettahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

<b>[6] Equipment</b>	
(1) Centrifuge	
Capacity	19 m <sup>3</sup> /hr
Number	2 W + 1 S
(2) Centrifuge Feed Pumps	
Capacity	19 m <sup>3</sup> /hr
Number	2 W + 1 S
(3) Polyelectrolyte Dosing Pumps	
Volume of Polyelectrolyte solution	7.59 m <sup>3</sup> /day
Operation Time	12 hours/day (6 days per week)
Safety Factor	1.5
Number	2 W + 1 S
Required Capacity	7.59 m <sup>3</sup> /da; × 7 / 6 / 12 / 2
	= 0.37 m <sup>3</sup> /Hr
Specification Capacity	0.37 m <sup>3</sup> /Hr × 1.5
	= 0.554 m <sup>3</sup> /Hr ⇒ 0.60 m <sup>3</sup> /Hr /Unit
(4) Polyelectrolyte dosing System	
Preparation time for solution	3 hr
Required dry polymer	15.19 kg/day × 7 / 6 / 12
	= 1.48 kg/hr
	= 4.43 kg per one batch
Feedong time per one batch	30 min
Capacity of Dry polymer Feeder	9 kg/h
Tanks Dimensions	Width 1.0 m × Length 1.5 m × Depth 1.5 m × 2
	= 4.5 m <sup>3</sup>
Retention Time of Tank	2.25 m <sup>3</sup> /tank / 0.37 m <sup>3</sup> /Hr / 2
	= 3.047 Hr > 3 Hr
Number	2 W + 0 S

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Digestion Tank + Centrifugal Dewatering)

Table -1 Input Data

1. Calculation Manner	2	1:Premise that the quality of supernatants are same level removed with inlet sewage 2:Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency	2	1:Total Removal Ratio 2:Outlet Water Quality(input 1or2)
In case of 1 : input data		(%)
In case of 2 : input data	#REF!	(mg/l)
3. Selection of Excess Sludge Generation	2	1:Consideration of Solid Matter Only 2:Consideration of Converting of Solved BOD(input 1or2)
In case of 1 : input data (Sludge generation)		Sludge generation ratio per removal SS(%)
	a	0.4 T2=Q4·S4=(a·S <sub>BOD</sub> +b·S1-c·θ·XA)·Q3/10 <sup>6</sup> · (Excess sludge generation formula)
	b	0.9 a:Converting ratio of solved BOD(mgMLSS/mgBOD)
	c	0.05 b:Converting ratio of SS(mgMLSS/mgSS)
In case of 2 : input data	SBOD	234.50 c:Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)
	XA	3,000 S <sub>BOD</sub> :Solved BOD quality at inlet reactor
	θ	1 XA:MLSS concentration(mg/l)
		θ:Hydraulic retention time(day)


Table -2 Basic Conditions

Sewage Flow and Quality	Sludge Moisture and Recovery Ratio	Digestion Tank Conditions	Chemical Conditions for Dewatering
· Inlet flow : Q <sub>0</sub> (m <sup>3</sup> /D)	7,000	· Primary sludge moisture ratio : W1(%)	0.0
· Inlet quality : S <sub>0</sub> (mg/l)	450	· Excess sludge moisture ratio : W2(%)	99.2
· Total removal ratio : A1(%)	-	· Thickened sludge moisture ratio : W3(%)	99.2
· Effluent quality : S1(mg/l)	10.0	· Digested sludge moisture ratio : W4(%)	99.2
· Sludge generation ratio per removal SS : S1(%)	-	· Dewatered sludge moisture ratio : W5(%)	82.0
		· Removal ratio in primary tank : A2(%)	0.0
		· Recovery ratio in sludge thickener : A3(%)	100.0
		· Recovery ratio in sludge digester : A4(%)	100.0
		· Recovery ratio in dewatering : A5(%)	95.0
		· Content of organics in thickened sludge : A6(%)	75.0
		· Digestion ratio : A7(%)	#REF!
		· Digestion gas generation : A8(Nm <sup>3</sup> /kgVS)	
		· Chemical dosage : A9(%)	0.5
		· Chemical dissolve concentration : A10(%)	0.2

Table -3 Material Balance Calculation

	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	手入力(要取束)			16	17
Q(m <sup>3</sup> /day)	7,000	7,371	0	7,371	380	6,991	380	0	0	380	0	8	387	16	371	371				6,991	0
T(t·DS/day)	3,150	3,303	0,000	3,303	3,038	0,070	3,038	0,000	0,000	3,038	0,000	0,015	3,053	2,900	0,153	0,153	0,153			0,070	0,195
S(mg/l)	450	448	0	448	8,000	10	8,000	#DIV/0!	0	8,000	0	2,000	7,882	180,000	411	411				10	
X(T5/T0*100)	100	104.9	0.0	104.9	96.4	2.2	96.4	0.0	0.0	96.4	0.0	0.5	96.9	92.1	4.8	4.8				2.2	6.2

Figure -1 Material Balance Model




Calculation Formula						
· Q0=Input Data	· Q3=Q1-Q2	· Q6=Q5*100/(100-W3)	· Q9=Q6	· Q12=Q9+Q11	· Q15=Q7+Q10+Q14	· Q5-1=Q5-Q11
· T0=Q0*S0*10 <sup>-6</sup>	· T3=T0*(100-A2)/100	· T6=(T2+T4)*A3/100	· T9=(T6-T8)*A4/100	· T12=T9+T11	· T15=T7+T10+T14	· T5-1=T5-T11
· S0=Input Data	· S3=T3*10 <sup>-6</sup> /Q3	· S6=10 <sup>-6</sup> *Q6/(100-W3)/100	· S9=T9*10 <sup>-6</sup> /Q9	· S12=T12*10 <sup>-6</sup> /Q12	· S15=T15*10 <sup>-6</sup> /Q15	· S5-1=S5
· Q1=Q0+Q15	· Q4=T4*100/(100-W2)	· Q7=(Q2+Q4)-Q6	· Q10=Q6-Q8-Q9	· Q13=T13*100/(100-W5)		
· T1=T0+T15	· T4=余剰汚泥発生式による	· T7=(T2+T4)-T6	· T10=T6-T8-T9	· T13=T12*A5/100		
· S1=T1*10 <sup>-6</sup> /Q1	· S4=10 <sup>-6</sup> *Q4/(100-W2)/100	· S7=T7*10 <sup>-6</sup> /Q7	· S10=T10*10 <sup>-6</sup> /Q10	· S13=10 <sup>-6</sup> *Q13/(100-W5)/100		
· Q2=T2*100/(100-W1)	· Q5=Q3-Q4*(T3-T5)/T4	· Q8=0	· Q11=T10*A9/A10	· Q14=Q12-Q13		
· T2=T1-T3	· T5=Q5*ST/10 <sup>-6</sup>	· T8=T6*A6*A7/10 <sup>-4</sup>	· T11=Q11*S11/10 <sup>-6</sup>	· T14=T12-T13		
· S2=10 <sup>-6</sup> *Q2/(100-W1)/100	· S5=St	#REF!	· S11=10 <sup>-4</sup> *A10	· S14=T14*10 <sup>-6</sup> /Q14		



Material Balance Sheet SD4

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Sheet  
[7MLD STP]



凡例	LEGEND
Q:	Water Flow : (m <sup>3</sup> /day)
T:	Solid Matter : (t-DS/day)
S:	Solid Concentration(mg/l)
X:	Ratio for Inlet Solid : (%)
-	Water
-	Sludge
-	Supernatant

A-4 Process Cal. EA&al 17MLD Bilishivalli, Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**Design Condition**

Item	17MLD STP-TSPS				
(1) Design Flow for the year 2049	Flow Rate				
		m3/d	m3/h	m3/s	
	Average Daily	27,000	1125	0.313	
	Max Dayly	27,000	1125	0.313	
	Max Hourly Peak factor	2.25	60,750	2531	0.703
(1) Design Flow for the year 2034	Flow Rate				
		m3/d	m3/h	m3/s	
	Average Daily	17,000	708	0.197	
	Max Dayly	17,000	708	0.197	
	Max Hourly Peak factor	2.25	38,250	1594	0.443

**1. Inlet Chamber**

Item	17MLD STP-TSPS								
[1] Design Condition									
(1) Design Flow for the year 2049	Max Hourly	=	60,750	m3/d					
		=	0.703	m3/sec					
(2) Inlet Pipe									
Pipe Diameter	•	×							
Gradient			%						
Roughness Coefficient	n=	0.013	(Manning Formula)						
Full Pipe Flow Rate			m3/s						
(3) Influent Water Level	+		m						
[2] Geometory									
(1) Number of Basins	1	Basin							
(2) Depth of Basin	0.600	m	Approx.						
(3) Width of Basin	2.900	m	Approx.						
(4) Length of Basin	2.500	m	Approx.						
(5) Volume required of Basin	0.600	×	2.900	×	2.500	=	0.7	m3	
(6) Retention Time	0.600	×	2.900	×	2.500	/	0.703	×	1
	=	6.19	sec						
(7) Basin Demensions	Width	2.900	m	×	Length	2.500	m		
	×	Depth	0.600	m					

**STP Process Calculation\_Supporting Report 12.2.3**

**2. Coarse Screen Channel**

Item	17MLD STP-TSPS					
[1] Geometry						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Width	0.600	m				
Height	0.900	m				
Floor Level	+	5.000	m			
Bottom	+	0.000	m			
Influent Water Level	+	0.600	m			
Velocity	0.703	/		0.600	/	0.600 / 2
where Design Flow for the year 2049	=	0.976	<	1.000	m/sec	OK
Velocity	0.443	/		0.600	/	0.600 / 2
where Design Flow for the year 2034	=	0.615	<	1.000	m/sec	OK
(2) Screen Channel						
Number	2.0	Main	+	1.0	Bypass	
Width	1.200	m				
Side Water Depth	0.700	m				
Velocity	0.703	/		1.200	/	0.700 / 2
where Design Flow for the year 2049	=	0.418	≠	0.450	m/sec	OK
Velocity	0.443	/		1.200	/	0.700 / 2
where Design Flow for the year 2034	=	0.264	<	0.450	m/sec	OK
(3) Channel Dimensions	Width	1.2	m	×	Length	6.0 m
			×	SWD	0.7	m
[3] Equipment						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Dimension	Width	0.6	m	×	Height	0.9 m
Design Water Level	8.0	m				
(2) Coarse Screens (Main Channel)						
Number	2	W	+	0	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	1.2	m				
Width of side plate	50	mm				
Side Water Depth	0.7	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.703	/		1.100	/	0.650 / 2
	× (	20	+	9	)/	20
	=	0.713	<	0.800	m/sec	OK
Velocity through screen	0.443	/		1.100	/	0.650 / 2
where Design Flow for the year 2034	× (	20	+	9	)/	20
	=	0.449	<	0.800	m/sec	OK
(3) Coarse Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	50	mm				
Bar Thickness	9	mm				
Channel Width	1.2	m				
Side Water Depth	0.7	m				
Velocity through screen	0.703	/		1.200	/	0.700 / 2
where Design Flow for the year 2049	× (	50	+	9	)/	50
	=	0.494	<	0.800	m/sec	OK
Velocity through screen	0.443	/		1.200	/	0.700 / 2
where Design Flow for the year 2034	× (	50	+	9	)/	50
	=	0.311	<	0.800	m/sec	OK

A-4 Process Cal. EA&al 17MLD Bilishivalli, Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**3. Raw Sewage Sump**

Item	17MLD STP-TSPS	
[2] Geometory		
(1) Raw Sewage Sump		
Number	1	Basin
Dia	12.00	m
Pump Operating Depth	1.500	m
Retention Time whe Design Flow for the year 2049	$( \frac{12.00^2 \times \pi}{4} \times 1.500 ) / 0.703$	$/ 60$ = 4.02 > 3.75 min (=minimum time of one pump cycle) OK
Retention Time whe Design Flow for the year 2034	$( \frac{12.00^2 \times \pi}{4} \times 1.500 ) / 0.443$	$/ 60$ = 6.38 > 3.75 min (=minimum time of one pump cycle) OK
High Water Level	+ 0.000	m
Pump Off Level	+ -1.500	m
[3] Equipment		
(1) Sewage Pumps 1		
Number	2 W	+ 1 S
Bore Diameter	300	mm
Discharge Flow : 40% Q* 2 whe Design Flow for the year 2034	$0.443 \times 3600$	$\times 40.0\% Q$ = 638 $\Rightarrow$ 640 m <sup>3</sup> /Hr
Total Head	15.0	m
(2) Sewage Pumps 2		
Number	1 W	+ 1 S
Bore Diameter	200	mm
Discharge Flow : 20% Q* 1 whe Design Flow for the year 2034	$0.443 \times 3600$	$\times 20.0\% Q$ = 319 $\Rightarrow$ 320 m <sup>3</sup> /Hr
Total Head	15.0	m

A-4 Process Cal. EA&al 17MLD Bilishivalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

Item	17MLD STP																																																		
<b>1. STP Design Condition</b>																																																			
(1) Design Flow Rate	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th style="text-align: center;">m3/d</th> <th style="text-align: center;">m3/h</th> <th style="text-align: center;">m3/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td style="text-align: center;">17,000</td> <td style="text-align: center;">708.33</td> <td style="text-align: center;">0.197</td> </tr> <tr> <td>Max Daily</td> <td style="text-align: center;">17,000</td> <td style="text-align: center;">708.33</td> <td style="text-align: center;">0.197</td> </tr> <tr> <td>Max Hourly Peak factor 2.25</td> <td style="text-align: center;">38,250</td> <td style="text-align: center;">1593.75</td> <td style="text-align: center;">0.443</td> </tr> </tbody> </table>											m3/d	m3/h	m3/s	Average Daily	17,000	708.33	0.197	Max Daily	17,000	708.33	0.197	Max Hourly Peak factor 2.25	38,250	1593.75	0.443																									
	m3/d	m3/h	m3/s																																																
Average Daily	17,000	708.33	0.197																																																
Max Daily	17,000	708.33	0.197																																																
Max Hourly Peak factor 2.25	38,250	1593.75	0.443																																																
(2) Design Water Quality	<p style="text-align: right;">Unit: mg/L</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th colspan="2">TP</th> </tr> <tr> <th>NH<sub>4</sub>-N</th> <th>Org-N</th> <th>NOx-N</th> <th>D-P</th> <th>P-P</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td style="text-align: center;">350</td> <td style="text-align: center;">800</td> <td style="text-align: center;">450</td> <td style="text-align: center;">45</td> <td style="text-align: center;">25</td> <td style="text-align: center;">0</td> <td style="text-align: center;">5</td> <td style="text-align: center;">2</td> </tr> <tr> <td>Outlet</td> <td style="text-align: center;">10</td> <td style="text-align: center;">50</td> <td style="text-align: center;">10</td> <td style="text-align: center;">1</td> <td style="text-align: center;">0</td> <td style="text-align: center;">9</td> <td style="text-align: center;">1</td> <td style="text-align: center;">1</td> </tr> <tr> <td>Removal rate</td> <td style="text-align: center;">97.1%</td> <td style="text-align: center;">93.7%</td> <td style="text-align: center;">97.8%</td> <td colspan="3" style="text-align: center;">85.7%</td> <td colspan="2" style="text-align: center;">71.4%</td> </tr> </tbody> </table>											BOD	COD	SS	T-N			TP		NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P	Inlet	350	800	450	45	25	0	5	2	Outlet	10	50	10	1	0	9	1	1	Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%	
	BOD	COD	SS	T-N			TP																																												
				NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P																																											
Inlet	350	800	450	45	25	0	5	2																																											
Outlet	10	50	10	1	0	9	1	1																																											
Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%																																												
<b>2. Inlet Chamber</b>																																																			
<b>[1] Design Condition</b>																																																			
(1) Design Flow Rate	Max Hourly	=	38,250	m3/day																																															
		=	0.443	m3/sec																																															
<b>[2] Geometry</b>																																																			
(1) Number of Basins	1	Basin																																																	
(2) Depth of Basin	2.000	m																																																	
(3) Width of Basin	2.900	m																																																	
(4) Length of Basin	2.500	m																																																	
(5) Volume required of Basin	2.000	×	2.900	×	2.500	=	2.3	m3																																											
(6) Retention Time	2.000	×	2.900	×	2.500	/	0.443	×	1																																										
	=	32.73	sec																																																
(7) Basin Dimensions	Width	2.900	m	×	Length	2.500	m																																												
	×	Depth	2.000	m																																															

A-4 Process Cal. EA&al 17MLD Bilishivalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Wastewater Flow	$\begin{aligned} \text{Max Hourly} &= 38,250 \text{ m}^3/\text{d} \\ &= 0.443 \text{ m}^3/\text{sec} \end{aligned}$
[2] Geometory	
(1) Inlet Gate	
Number	2 Main + 1 Bypass
Width	0.500 m
Height	0.750 m
Floor Level	+ 2.000 m
Bottom	+ 0.000 m
Influent Water Level	+ 0.500 m
Velocity	$\begin{aligned} &0.443 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 2 \\ = &0.886 \text{ } \div \quad 1.000 \text{ m/sec} \end{aligned}$
(2) Screen Channel	
Number	2 Main + 1 Bypass
Width	1.000 m
Side Water Depth	0.500 m
Velocity	$\begin{aligned} &0.443 \text{ } \swarrow \quad 1.000 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 2 \\ = &0.443 \text{ } \div \quad 0.450 \text{ m/sec} \end{aligned}$
(3) Channel Dimensions	$\begin{aligned} \text{Width} &1.0 \text{ m} \times \text{Length} &6.0 \text{ m} \\ &\times \text{SWD} &0.5 \text{ m} \end{aligned}$
[3] Equipment	
(1) Inlet Gate	
Number	2 W + 1 S
Dimension	Width 0.5 m × Height 0.75 m
Design Water Level	2.00 m
(2) Fine Screens (Main Channel)	
Number	2 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	1.0 m
Width of side plate	50 mm
Side Water Depth	0.5 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	$\begin{aligned} &0.443 \text{ } \swarrow \quad 0.900 \text{ } \swarrow \quad 0.450 \text{ } \swarrow \quad 2 \\ &\times ( \quad 6 \quad + \quad 2 \quad ) / \quad 6 \\ = &0.729 < \quad 0.800 \text{ m/sec} \end{aligned}$
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	1.0 m
Side Water Depth	0.5 m
Velocity through screen	$\begin{aligned} &0.443 \text{ } \swarrow \quad 1.000 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 2 \\ &\times ( \quad 20 \quad + \quad 9 \quad ) / \quad 20 \\ = &0.642 < \quad 0.800 \text{ m/sec} \end{aligned}$

A-4 Process Cal. EA&al 17MLD Bilishivalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>4. Grit Chamber</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Peak flow = 38,250 m <sup>3</sup> /day = 0.443 m <sup>3</sup> /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0111 m/sec = 960 m <sup>3</sup> /m <sup>2</sup> /day
(4) Average Velocity	0.3 m/sec
<b>[2] Grit Chamber</b>	
(1) Surface Area required	0.443 / 0.0111 = 39.91 m <sup>2</sup>
(2) Number of Basins	1 S + 1 W
(3) Surface Area required/Basin	39.9 / 1 = 39.91 m <sup>2</sup>
(4) Length of Basin	39.91 ^0.5 = 6.317 m → 6.5 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.443 × 60 sec / 1 = 26.6 m <sup>3</sup>
(7) Depth required	26.6 / 6.5 / 6.5 = 0.629 m
(8) Basin Dimensions	Width 6.5 m × Length 6.5 m × Depth 0.6 m (Freeboard 0.3m)
(9) Retention Time	6.5 × 6.5 × 0.6 / 0.443 × 1 = 60.00 sec
(10) Surface Overflow Rate at Peak Flow	38,250 / 6.5 / 6.5 / 1 = 905.325444 < 960 m <sup>3</sup> /m <sup>2</sup> /day
<b>[3] Parshall Flume</b>	
(1) Design Flow Rate	Q= 443.000 l/sec
(2) Throat width	W= 0.450 m
(3) Water depth Ha	Ha= ( Q / 2264 / W ) <sup>2/3</sup> Ha= 0.574 m
(4) Crest Level	+ m ≐ Minimum water level at downstream channel
(5) Water level at the crest	+ 0.574 m
(6) Channel bottom level	+ m
(7) Upstream Channel width	1.500 m
(8) SWD of Upstream Channel	0.700 m
(9) Average velocity at upstream channel	0.422 m/sec
(10) Total Length of channel	10.000 m
<b>[4] Inlet Weir Gate</b>	
(1) Number	2 Units
(2) Weir Width	0.800 m
(3) Stroke	0.550 m
(4) Overflow Height	0.500 m
(5) Overflow Height (actual)	( 0.443 / 1.840 / 0.800 / 2 ) <sup>2/3</sup> = 0.283 < 0.500 m

**STP Process Calculation Supporting Report 12.2.3**

<b>5. Reactor</b>																																																								
<b>[1] Design Condition</b>																																																								
(1) Design Wastewater Flow	Q = 17,000 m <sup>3</sup> /day (summer) Q' = 17,000 m <sup>3</sup> /day (Winter)																																																							
(2) Design Sewage Quality																																																								
Inlet BOD	350 mg/l																																																							
Outlet BOD	10.0 mg/l																																																							
Inlet S-BOD	235 mg/l assumed as 67% of BOD																																																							
Inlet COD	800 mg/l																																																							
Inlet bCOD :S <sub>0</sub>	578 mg/l																																																							
Inlet nbCOD	223 mg/l																																																							
bCOD/BOD	1.65																																																							
Inlet S-COD :sCOD	271 mg/l assumed as 33% of BOD																																																							
Inlet rbCOD	231 mg/l bCOD*40%																																																							
Inlet sbCOD	347 mg/l bCOD*60%																																																							
Outlet S-COD :nbsCODE	40 mg/l																																																							
Inlet nbpCOD :nbpCOD	183 mg/l =TCOD-bCOD-nbsCODE																																																							
Inlet SS	450 mg/l																																																							
Inlet VSS	383 mg/l assumed as 85% of TSS																																																							
:VSS <sub>COD</sub>	1.38 gCOD/gVSS =(TCOD-sCOD)/VSS																																																							
:nbVSS	131.96 gnbVSS/m <sup>3</sup> =nbpCOD/VSS <sub>COD</sub>																																																							
:iTSS	67.50 gnbVSS/m <sup>3</sup> =TSS-VSS																																																							
Inlet T-N	70 mg/l																																																							
Inlet TKN	70 mg/l																																																							
Inlet NH <sub>4</sub> -N	45.0 mg/l																																																							
Inlet T-P	7 mg/l																																																							
Inlet D-P	5 mg/l																																																							
Inlet Alkalinity as CaCO <sub>3</sub>	380 mg/l																																																							
Outlet Kjeldahl N	1.0 mg/l																																																							
Outlet NH <sub>4</sub> -N	1.0 mg/l																																																							
Outlet NO <sub>3</sub> -N	9.0 mg/l																																																							
Outlet T-P	2 mg/l																																																							
Outlet D-P	1 mg/l																																																							
(3) Water Temperature	T = 20.0 °C																																																							
(4) Safety Factor for Nitrogen	SF = 1.5																																																							
(5) Return Sludge Concentration	R <sub>s</sub> = 8,000 mg/l																																																							
(6) MLSS MLVSS	X <sub>TSS</sub> = 3,000 mg/l																																																							
(7) DO in the Reactor	2 mg/L																																																							
<b>[2] Design Value for perfect Nitrification of Nitrification Process</b>																																																								
(1) Activated sludge design kinwtic coefficients at 20°C																																																								
	<table border="1"> <thead> <tr> <th>Coefficient</th> <th>Unit</th> <th>COD oxidatio</th> <th>NH4 oxidatio</th> <th>NO2 oxidatio</th> </tr> </thead> <tbody> <tr> <td>μ<sub>max</sub></td> <td>gVSS/gVSS · d</td> <td>6.000</td> <td>0.900</td> <td>1.000</td> </tr> <tr> <td>K<sub>s</sub>,K<sub>NH4</sub>,K<sub>NO2</sub></td> <td>mg/L</td> <td>8.000</td> <td>0.500</td> <td>0.200</td> </tr> <tr> <td>Y</td> <td>gVSS/g substrate oxidized</td> <td>0.450</td> <td>0.150</td> <td>0.050</td> </tr> <tr> <td>b</td> <td>gVSS/gVSS · d</td> <td>0.120</td> <td>0.170</td> <td>0.170</td> </tr> <tr> <td>fd</td> <td>unitless</td> <td>0.150</td> <td>0.150</td> <td>0.150</td> </tr> <tr> <td>K<sub>O2</sub></td> <td>mg/L</td> <td>0.200</td> <td>0.500</td> <td>0.900</td> </tr> <tr> <td>θ Value</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>μ<sub>max</sub></td> <td>unitless</td> <td>1.070</td> <td>1.072</td> <td>1.063</td> </tr> <tr> <td>b</td> <td>unitless</td> <td>1.040</td> <td>1.029</td> <td>1.029</td> </tr> <tr> <td>K<sub>s</sub>,K<sub>NH4</sub>,K<sub>NO2</sub></td> <td>unitless</td> <td>1.000</td> <td>1.000</td> <td>1.000</td> </tr> </tbody> </table> <p>Wastwater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF &amp; EDDY/AECOM)</p>	Coefficient	Unit	COD oxidatio	NH4 oxidatio	NO2 oxidatio	μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000	K <sub>s</sub> ,K <sub>NH4</sub> ,K <sub>NO2</sub>	mg/L	8.000	0.500	0.200	Y	gVSS/g substrate oxidized	0.450	0.150	0.050	b	gVSS/gVSS · d	0.120	0.170	0.170	fd	unitless	0.150	0.150	0.150	K <sub>O2</sub>	mg/L	0.200	0.500	0.900	θ Value					μ <sub>max</sub>	unitless	1.070	1.072	1.063	b	unitless	1.040	1.029	1.029	K <sub>s</sub> ,K <sub>NH4</sub> ,K <sub>NO2</sub>	unitless	1.000	1.000	1.000
Coefficient	Unit	COD oxidatio	NH4 oxidatio	NO2 oxidatio																																																				
μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000																																																				
K <sub>s</sub> ,K <sub>NH4</sub> ,K <sub>NO2</sub>	mg/L	8.000	0.500	0.200																																																				
Y	gVSS/g substrate oxidized	0.450	0.150	0.050																																																				
b	gVSS/gVSS · d	0.120	0.170	0.170																																																				
fd	unitless	0.150	0.150	0.150																																																				
K <sub>O2</sub>	mg/L	0.200	0.500	0.900																																																				
θ Value																																																								
μ <sub>max</sub>	unitless	1.070	1.072	1.063																																																				
b	unitless	1.040	1.029	1.029																																																				
K <sub>s</sub> ,K <sub>NH4</sub> ,K <sub>NO2</sub>	unitless	1.000	1.000	1.000																																																				
(2) μ <sub>AOB</sub>	$\mu_{AOB} = 0.3100 \text{ g/g} \cdot \text{d} = \mu_{max, AOB} [S_{NH4} / (S_{NH4} + K_{NH4})] [S_O / (S_O + K_{O, AOB})] - b_{AOB}$ $\mu_{max, AOB, T} = 0.9000 \text{ g/g} \cdot \text{d} = \mu_{max} * 1.072^{(T-20)} \mu_{max} \text{ at } 20^\circ\text{C} = 0.900$ $b_{AOB, T} = 0.1700 = b * 1.029^{(T-20)} \quad b \text{ at } 20^\circ\text{C} = 0.170$ $S_{NH4} = 1.0000 \text{ mg/l}$ $DO = 2.0000 \text{ mg/l}$ $K_{O, AOB} = 0.5000 \text{ mg/l}$																																																							



A-4 Process Cal. EA&al 17MLD Bilishivalli Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

(2) Design SRT	SRT= 4.8387 day ⇒ 5.0000 day	$= 1/\mu_{AOB} \times SF$
(3) Biomass production		
P <sub>x,VSS</sub>	P <sub>x,VSS</sub> = 5315.965 kg/d	= P <sub>x,bio</sub> + Q(nbVSS)
P <sub>x,TSS</sub>	P <sub>x,TSS</sub> = 7301.896 kg/d	= P <sub>x,bio</sub> × 0.85 + Q(nbVSS) + Q(TSS <sub>0</sub> -VSS <sub>0</sub> ) + 5*Q*Al
S	S= 0.4507 mg/l	= K <sub>s</sub> [1+b <sub>H</sub> (SRT)]/[SRT(μ <sub>m</sub> -b <sub>H</sub> )-1]
b <sub>H</sub>	b <sub>H</sub> = 0.1200	= b*1.04 <sup>(T-20)</sup> b at 20°C = 0.120
Y <sub>H</sub>	Y <sub>H</sub> = 0.4500 gVSS/g bCOD	
μ <sub>m,T</sub>	μ <sub>m,T</sub> = 6.0000 g/g·d	= μ <sub>max</sub> *1.04 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 6.000
Y <sub>n</sub>	Y <sub>n</sub> = 0.150 gVSS/g Nox	
NO <sub>x</sub>	NO <sub>x</sub> = 47.400 mg/l	
P <sub>x,bio,VSS</sub>	P <sub>x,bio,VSS</sub> = 3072.664 kg VSS/d	= Q·Y <sub>H</sub> (S <sub>0</sub> -S)/[1+b <sub>H</sub> (SRT)] + f <sub>d</sub> ·b <sub>H</sub> ·QY <sub>H</sub> (S <sub>0</sub> -S)SRT/[1+b <sub>H</sub> (SRT)]
	2759.017	= Q·Y <sub>n</sub> (Nox)[2+bAOB(SRT)]
	248.312	= Q·Y <sub>H</sub> (S <sub>0</sub> -S)/[1+b <sub>H</sub> (SRT)]
	65.335	= f <sub>d</sub> ·b <sub>H</sub> ·QY <sub>H</sub> (S <sub>0</sub> -S)SRT/[1+b <sub>H</sub> (SRT)]
		= QY <sub>n</sub> (Nox)[1+b <sub>AOB</sub> (SRT)]
NO <sub>x</sub>	NO <sub>x</sub> = 47.311 mg/l	= TKN-N <sub>e</sub> -0.12P <sub>x,bio</sub> /Q
(4) Required Aeration Tank Volume		
V <sub>a</sub>	V <sub>a</sub> = 12,170 m <sup>3</sup>	
τ	τ = 17.18 hr ⇒ 18.00 hr	= V <sub>a</sub> /Q × 24
X <sub>VSS</sub> ·V <sub>a</sub>	X <sub>VSS</sub> ·V <sub>a</sub> = 26,580 kg VSS	= P <sub>x,VSS</sub> ·SRT
X <sub>TSS</sub> ·V <sub>a</sub>	X <sub>TSS</sub> ·V <sub>a</sub> = 36,509 kg TSS	= P <sub>x,TSS</sub> ·SRT
F/M	F/M= 0.224 kgBOD/kgMLVSS	
FractionVSS=	FractionVSS= 0.728	
MLVSS=	MLVSS= 2184 mg/L	
(5) BODloading	BODloading= 0.489 kg/m <sup>3</sup> ·d	
(6) Observed Yield		
Y <sub>obs,TSS</sub>	Y <sub>obs,TSS</sub> = 1.228 gTSS/gBOD	
Y <sub>obs,VSS</sub>	Y <sub>obs,VSS</sub> = 0.894 gVSS/gBOD	
bCODremoved=	bCODremov= 9,810 kg/d	
(7) effluent NO <sub>2</sub> -N	NO <sub>2</sub> -N= 0.2315 mg/l	= K <sub>s</sub> [1+b <sub>NOB</sub> (SRT)]/[SRT(μ <sub>NOB</sub> -b <sub>NOB</sub> )-1]
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700	= b*1.029 <sup>(T-20)</sup> b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 1.0000 g/g·d	= μ <sub>max</sub> *1.04 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 1.000
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.6897 g/g·d	= μ <sub>max,NOB</sub> [S <sub>0</sub> /(S <sub>0</sub> +K <sub>O2,NOB</sub> )]
	S <sub>0</sub> = 2.000 mg/l	
	K <sub>O2,NOB</sub> = 0.900 mg/l	
(8) effluent NH <sub>4</sub> -N	NH <sub>4</sub> -N= 0.5286 mg/l	= K <sub>s</sub> [1+b <sub>NOB</sub> (SRT)]/[SRT(μ <sub>NOB</sub> -b <sub>NOB</sub> )-1]
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700	= b*1.029 <sup>(T-20)</sup> b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 0.9000 g/g·d	= μ <sub>max</sub> *1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.7200 g/g·d	= μ <sub>max,NOB</sub> [S <sub>0</sub> /(S <sub>0</sub> +K <sub>O2,NOB</sub> )]
	S <sub>0</sub> = 2.000 mg/l	
	K <sub>O2,NOB</sub> = 0.500 mg/l	
(9) Ratio of Return Sludge	8,000·R <sub>r</sub> /(1+R <sub>r</sub> )= 3,000 mg/L 3,000/(8,000-3,000)= 0.60 R <sub>r</sub> = 0.60	

**STP Process Calculation\_Supporting Report 12.2.3**

[3] Design for Nitrification and Denitrification Process																					
(1) Active biomass concentration	$X_b = Q \cdot (SRT) / V \cdot Y_H (S_0 - S) [1 + b_H (SRT)]$ = 1,133.55 mg/l																				
(2) IR ratio	$IR = NO_x / Ne - 1.0 - R$ = 3.66																				
(3) The amount of NO3-N fed to the anoxic tank	$Nox\ feed = (IR + R) \cdot Q \cdot Ne$ = 651,280.37 kg/d																				
(4) The anoxic tank volume	$V_{nor} = 1,217\ m^3 = V_a \times 10\%$ $V_{nor} = 3,542\ m^3 \quad \tau_{DN} = 5.000\ h$																				
(5) F/M <sub>b</sub>	F/M <sub>b</sub> = 1.48 g/g · d																				
(6) Fraction of rbCOD	40.00% = rbCOD/bCOD																				
<table border="1"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b<sub>0</sub></th> <th>b<sub>1</sub></th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>		Percent rdCOD(%)	SDNR equation coefficients		b <sub>0</sub>	b <sub>1</sub>	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162
Percent rdCOD(%)	SDNR equation coefficients																				
	b <sub>0</sub>	b <sub>1</sub>																			
10	0.186	0.078																			
20	0.213	0.118																			
30	0.235	0.141																			
40	0.242	0.152																			
50	0.270	0.162																			
(8) SDNR <sub>b</sub>	$SDNR_b = 0.302\ g/g \cdot d = b_0 + b_1 [\ln(F/M_b)]$ $b_0 = 0.242$ $b_1 = 0.152$																				
(8) SDNR	$SDNR = 0.113\ g/g \cdot d = SDNR_b (MLVSS_0 / MLVSS)$ $SDNR_{adj} = 0.217\ g/g \cdot d = SDNR_t - 0.029 \ln(F/M_b) - 0.012 \quad IR=3-4$ $= SDNR_t - 0.0166 \ln(F/M_b) - 0.078 \quad IR=2$ $SDNR_t = 0.302\ g/g \cdot d = SDNR_b \cdot \theta^{(t-20)} \quad \theta = 1.026$																				
(9) NO <sub>r</sub>	$NO_r = 872,270.70\ kg/d = N_{nox} \cdot SDNR \cdot X_b$ $> Nox\ feed = 651,280\ kg/d$																				
(10) Alkalinity to be added to maintain pH7	-108.33 mg/l																				
	Influent Alk 380.00 mg/l Alk used 338.44 mg/l = 7.14 × Nox Alk produced 136.77 mg/l = 3.57 × (NOx - NO <sub>x</sub> e) Alk to maint: 70.00 mg/l																				
[4] Design of Phosphorus Removal Process																					
(1) Removal T-P	3.13 mg/l																				
P in waste sludge	p <sub>x</sub> = 1.00%																				
Generated waste sludge	P <sub>x, VSS</sub> = 5315.965 kg/d																				
Removal Phosphorus	53.15964645 kg/d																				
(2) Effluent T-P without Al	3.87 mg/l																				
(3) Required Al to initial soluble phosphorus ratio	1.00 mol/mol																				
(4) Required Al dosing rate	3.48 mg/l as Al																				
	42.98 mg/l as crystal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> · 18H <sub>2</sub> O																				
(5) Required Aluminum Sulfate	730.62 kg/d																				
(6) Required Aluminum Sulfate solution 10%	6.96 m <sup>3</sup> /d																				
	289.93 L/H																				
(7) Additional sludge	296.20 kg/d																				

**STP Process Calculation\_Supporting Report 12.2.3**

<b>[5] Reactor</b>																																																																			
(1) Total volume of Aeration Basins	$V_A = Q \cdot \theta_a / 24$ $= 12,750 \text{ m}^3$																																																																		
(2) Total volume of Anoxic Basins	$V_{DN} = Q \cdot \theta_{DN} / 24$ $= 3,542 \text{ m}^3$																																																																		
	<table border="1"> <thead> <tr> <th rowspan="2">Item</th> <th rowspan="2">Volume required</th> <th colspan="2">Retention Time required</th> <th rowspan="2">Ratio of Volume</th> </tr> <tr> <th>Summer</th> <th>Winter</th> </tr> </thead> <tbody> <tr> <td>unit</td> <td>m<sup>3</sup></td> <td>hour</td> <td>hour</td> <td></td> </tr> <tr> <td>Anaerobic</td> <td>V<sub>AN</sub></td> <td>1,060</td> <td>1.50</td> <td>1.50</td> <td>0.30</td> </tr> <tr> <td>Anoxic</td> <td>V<sub>DN</sub></td> <td>3,542</td> <td>5.00</td> <td>5.00</td> <td>1.00</td> </tr> <tr> <td>Aerobic</td> <td>V<sub>A</sub></td> <td>12,750</td> <td>18.00</td> <td>18.00</td> <td>3.60</td> </tr> <tr> <td>Total</td> <td>V</td> <td>17,352</td> <td>24.50</td> <td>24.50</td> <td></td> </tr> </tbody> </table>	Item	Volume required	Retention Time required		Ratio of Volume	Summer	Winter	unit	m <sup>3</sup>	hour	hour		Anaerobic	V <sub>AN</sub>	1,060	1.50	1.50	0.30	Anoxic	V <sub>DN</sub>	3,542	5.00	5.00	1.00	Aerobic	V <sub>A</sub>	12,750	18.00	18.00	3.60	Total	V	17,352	24.50	24.50																															
Item	Volume required			Retention Time required			Ratio of Volume																																																												
		Summer	Winter																																																																
unit	m <sup>3</sup>	hour	hour																																																																
Anaerobic	V <sub>AN</sub>	1,060	1.50	1.50	0.30																																																														
Anoxic	V <sub>DN</sub>	3,542	5.00	5.00	1.00																																																														
Aerobic	V <sub>A</sub>	12,750	18.00	18.00	3.60																																																														
Total	V	17,352	24.50	24.50																																																															
<b>[6] Geometry</b>																																																																			
(1) Basin Dimensions	<p>Width      Length      Depth      Basins</p> <p>8.0                      204.0      5.5      2</p> <p>Cross Section      8.0*5.5      =      44.0 m<sup>2</sup>/Basin</p> <p>Hantzsck Subtraction      =      1.0 m<sup>2</sup>/Basin</p> <p>after Subtraction      44.0-1.0      =      43.0 m<sup>2</sup>/Basin</p> <p>Total Volume      43.0*204.0      =      8,772 m<sup>2</sup>/Basin      17,544 m<sup>3</sup>/Total</p>																																																																		
(2) Partition of Basin	<table border="1"> <thead> <tr> <th>Item</th> <th>unit</th> <th>Anaerobic</th> <th>Anoxic</th> <th>Aerobic</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Cross Section</td> <td>m<sup>2</sup></td> <td colspan="3">43.0</td> <td></td> </tr> <tr> <td>Length required</td> <td>m</td> <td><b>12.3</b></td> <td><b>41.2</b></td> <td><b>148.3</b></td> <td><b>201.8</b></td> </tr> <tr> <td>Volume required per Basin</td> <td>m<sup>3</sup></td> <td>530</td> <td>1,771</td> <td>6,375</td> <td>8,676</td> </tr> <tr> <td>Total Volume required</td> <td>m<sup>3</sup></td> <td>1,060</td> <td>3,542</td> <td>12,750</td> <td>17,352</td> </tr> <tr> <td>Actual Cross Section</td> <td>m<sup>2</sup></td> <td>43.0</td> <td>43.0</td> <td>43.0</td> <td></td> </tr> <tr> <td>Actual Length</td> <td>m</td> <td>13.0</td> <td>42.0</td> <td>149.0</td> <td>204.0</td> </tr> <tr> <td>Actual Volume per Basin</td> <td>m<sup>3</sup></td> <td>559</td> <td>1,806</td> <td>6,407</td> <td>8,772</td> </tr> <tr> <td>Actual Total Volume</td> <td>m<sup>3</sup></td> <td>1,118</td> <td>3,612</td> <td>12,814</td> <td>17,544</td> </tr> <tr> <td>Actual Ratio of Volume</td> <td></td> <td>0.31</td> <td>1.00</td> <td>3.55</td> <td></td> </tr> <tr> <td>Actual Retention Time</td> <td>hour</td> <td>1.58</td> <td>5.10</td> <td>18.09</td> <td>24.77</td> </tr> </tbody> </table>	Item	unit	Anaerobic	Anoxic	Aerobic	Total	Cross Section	m <sup>2</sup>	43.0				Length required	m	<b>12.3</b>	<b>41.2</b>	<b>148.3</b>	<b>201.8</b>	Volume required per Basin	m <sup>3</sup>	530	1,771	6,375	8,676	Total Volume required	m <sup>3</sup>	1,060	3,542	12,750	17,352	Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0		Actual Length	m	13.0	42.0	149.0	204.0	Actual Volume per Basin	m <sup>3</sup>	559	1,806	6,407	8,772	Actual Total Volume	m <sup>3</sup>	1,118	3,612	12,814	17,544	Actual Ratio of Volume		0.31	1.00	3.55		Actual Retention Time	hour	1.58	5.10	18.09	24.77
Item	unit	Anaerobic	Anoxic	Aerobic	Total																																																														
Cross Section	m <sup>2</sup>	43.0																																																																	
Length required	m	<b>12.3</b>	<b>41.2</b>	<b>148.3</b>	<b>201.8</b>																																																														
Volume required per Basin	m <sup>3</sup>	530	1,771	6,375	8,676																																																														
Total Volume required	m <sup>3</sup>	1,060	3,542	12,750	17,352																																																														
Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0																																																															
Actual Length	m	13.0	42.0	149.0	204.0																																																														
Actual Volume per Basin	m <sup>3</sup>	559	1,806	6,407	8,772																																																														
Actual Total Volume	m <sup>3</sup>	1,118	3,612	12,814	17,544																																																														
Actual Ratio of Volume		0.31	1.00	3.55																																																															
Actual Retention Time	hour	1.58	5.10	18.09	24.77																																																														
<b>[7] Equipment</b>																																																																			
(1) Ras Pumps																																																																			
Ras Ratio	60%																																																																		
Required Capacity	17,000 m <sup>3</sup> /day × 60% / 24 / 2 = 213 m <sup>3</sup> /Hr ⇒ 220 m <sup>3</sup> /Hr																																																																		
Number	2 Work 2 Stanby																																																																		
(2) Circulation Pumps																																																																			
Ras Ratio	366%																																																																		
Required Capacity	17,000 m <sup>3</sup> /day × 366% / 24 / 4 = 648 m <sup>3</sup> /Hr ⇒ 650 m <sup>3</sup> /Hr																																																																		
Number	4 Work 2 Stanby																																																																		
(3) SAS Pumps																																																																			
Excess Sludge	1,068 m <sup>3</sup> /day																																																																		
Sludge withdraw	12 Times/day																																																																		
Running Time	0.5 Hr/Time																																																																		
Required Capacity	1,068 m <sup>3</sup> /day / 12 / 0.5 / 2 = 88.98 m <sup>3</sup> /Hr ⇒ 90 m <sup>3</sup> /Hr																																																																		
Number	2 Work 2 Stanby																																																																		

A-4 Process Cal. EA&al 17MLD Bilishivalli Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

(4) Alum Solution Tank										
Number	2	W	+	0	S					
Alum concentration as crystal	10	%								
Gravity of dissolved dechlorine	1.05									
Required solution volume	730.62	kg / d	×	100	/	10	/	1.05	/	1000
	=	6.96			m <sup>3</sup> /d					
Volume of Tank	4.1	m <sup>3</sup> /tank	(=	1.5	mW×	1.5	mL×	1.8	mH)	
Total Volume of Tanks	8.1		m <sup>3</sup>	(Duration=		1.16	day)			
(5) Mixer for Alum Solution Tank										
Number	2	W	+	0	S					
(6) Alum Dosing Pump										
Number	2	W	+	1	S					
Capacity	6.96	m <sup>3</sup> /d	/	24	×	1000	/	2	×	2
	289.93	l/h/unit	⇒	290	l/h/unit					

A-4 Process Cal. EA&al 17MLD Bilishivalli Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>6. Air Requirement at Average Flow</b>	
[1] Design Condition	
(1) AOR	AOR = 7,355 kg/day = 306.5 kg/h
Q <sub>in</sub> : Design Average Flow m <sup>3</sup> /d	17,000
Inlet bCOD : S <sub>0</sub>	578 mg/l
S=	S= 0.451 mg/l
Nox=	Nox 47.400 mg/l
P <sub>X,bio</sub> =	P <sub>X,b</sub> 3,007.3 kg VSS/d does not include nitrifying bacteria
R <sub>0</sub> =	R <sub>0</sub> = Q(S <sub>0</sub> -S-k(NOx-NO <sub>x</sub> ))-1.42P <sub>X,bio</sub> +4.57Q•NO <sub>x</sub>
R <sub>0</sub> =	R <sub>0</sub> = 7,355 kg O <sub>2</sub> /d
k=	k= 2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{\text{AOR} \times C_s \cdot a \times 1.024^{20-T}}{\alpha \times F (\beta \cdot C_{sw}/C_s \cdot (P_b/P_a)a - C_A)}$
	C <sub>s</sub> : Saturated DO at sea level and 20 °C 9.09 mg/L
	C <sub>sw</sub> : Saturated DO at sea level and operating Temperature 9.09 mg/L at 20 °C
	20-T : 0.0 1.024 <sup>20-T</sup> : 1.0000
	C <sub>A</sub> : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1+0.40D <sub>j</sub> /P <sub>a</sub> 1.19357
	D <sub>j</sub> : Tank Liquid Depth 5.00 m
	P <sub>a</sub> : Standard absolute pressure at s 10.332 m
	P <sub>b</sub> : Absolute pressure at Plant Site Elevation m
	P <sub>b</sub> /P <sub>a</sub> : exp[-gM(z <sub>b</sub> -z <sub>a</sub> )/R*T] 0.900
	g : Acceleration due to Gravity 9.80665 m/s <sup>2</sup>
	M : Mole of Air 28.97 kg/kg-mole
	z <sub>b</sub> : Plant Site Elevation 900 m
	z <sub>a</sub> : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 293.15 Kelvin
	α : relative Transfer Rate to clean W <sub>a</sub> 0.65
	β : relative DO Saturation to clean W <sub>ε</sub> 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{79,798}{4.2591} = 18,735.68 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Standard O <sub>2</sub> required at Field Conditions per Bas =	9,368 kg/day
(5) SOTE for the above Effective Aeration Depth	28.0 %
(6) Fraction of O <sub>2</sub> in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	15%
(9) Air required at Field Conditions per Basins	= 137,776 m <sup>3</sup> /day = 5,740.6 m <sup>3</sup> /hr
[2] Equipment	

A-4 Process Cal\_ EA&amp;al 17MLD Bilishivalli Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

(1) Air Blower					
Number	4	W	+	2	S
Required Capacity	5740.6	m <sup>3</sup> /Hr·Basin	/	2	unit/Basin
	= 2870.3	m <sup>3</sup> /h	⇒	2900	m <sup>3</sup> /h /Unit
Pressure	65	kPa			
Safety Factor	10	%			
Heat capacity ratio	1.4				
Atmospheric pressure at site elevation	91.234	kPa			
Total inlet pressure	89.234	kPa			
Volume rate of flow at inlet point	54.869	m <sup>3</sup> /min			
Total discharge pressure	156.234	kPa			
Overall adiabatic efficiency	0.65				
Inlet air temperature (min.)	15	°C			
Shaft power	77.578	kW			
Rated Output of Motor	85.335	kW	⇒	90	kW

Air Requirement at Average Flow 13/23

A-4 Process Cal. EA&al 17MLD Bilishivalli Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>7. Final Clarifire</b></p>		
<p>[1] <b>Design Condition</b></p>		
<p>(1) Design Wastewater Flow</p>	<p>Q= 17,000 m<sup>3</sup>/day</p>	
<p>(2) Water Temperature</p>	<p>T= 20.0 °C</p>	
<p>(3) MLSS</p>	<p>Xef= 3,000 mg/l</p>	
<p>(4) SVI</p>	<p>SVI= 300</p>	
<p>(5) Sedimentation Velocity</p>	<p><math>v = 4.899 \cdot 10^6 \cdot T^{(0.954)} \cdot X_{ef}^{(-1.354)} \cdot SVI^{(-0.77)}</math>  <math>= 4.899 \cdot 10^6 \cdot 20.0^{0.954} \cdot 3,000^{-1.354} \cdot 150^{-0.770}</math>  <math>= 20.7 \text{ m/day}</math></p>	
<p>(6) Surface Overflow Rate required</p>	<p><math>S' = v / (1.5 \cdot 1) = 20.7 / (1.5 \cdot 1.0) = 13.8 \text{ m}^3/\text{m}^2 \cdot \text{day}</math></p>	<p>→ 12.0 m<sup>3</sup>/m<sup>2</sup>·day</p>
<p>[2] <b>Geometry</b></p>		
<p>(1) Surface Area required</p>	<p>A = 17,000/12.0 = 1,417 m<sup>2</sup></p>	
<p>(2) Demensions</p>	<p>Diameter                  Depth          Basin</p>	
	<p><b>30.0                          3.5                  2</b></p>	
<p>(3) Actual Surface Area</p>	<p>S = 30.0<sup>2</sup> * 3.14 /4 * 2.0 = 1,414 m<sup>2</sup></p>	
<p>(4) Surface Overflow Rate</p>	<p>S = 17,000/1,414 = 12.0 m<sup>3</sup>/m<sup>2</sup>·day</p>	

A-4 Process Cal. EA&al 17MLD Bilishivalli, Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<b>8. Chlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 17,000 m <sup>3</sup> /day 708.33 m <sup>3</sup> /h Peak Flow 38,250 m <sup>3</sup> /day 1593.75 m <sup>3</sup> /h
(2) Contact Time	30 min
(3) Type of Chlorine	Cl <sub>2</sub> -GAS
(4) Design Chlorine Dosage Rate	10 mg/L
(5) Required Chlorine per day	Average Daily Flow / 1000 × Design Chlorine Dosage Rate = 170.0 kg/d = 7.08 kg/h
<b>[2] Chlorination Contact Tank</b>	
(1) Volume required	Average Daily Flow / 1440 × Contact Time = 354.2 m <sup>3</sup>
(2) Nos. of lanes	3 lanes
(3) Width of lane	2.00 m
(4) Length of lane	30.00 m
(5) Side Water Depth	2.00 m
(6) Nos. of Tanks	1 tank
(7) Total Width of Tank	6.80 m Approx..
(8) Average Velocity	Decant Flow / 3600 / Width / Depth = 708.33 / 3600 / 2.00 / 2.00 = 0.049 m/sec
(9) Total Volume	Width × Length × Depth × Nos. of lanes × Nos. of Tanks = 2.0 m × 30.0 m × 2.0 m × 3 × 1 = 360 m <sup>3</sup> > 354.2 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Chlorine Dosing Condition	
Operation Dosage Rate -1	DC1 10 mg/L
(2) Chlorine Cylinder	
Type	- Cylindrical Convexsd Container
Cylinder Capacity	Cc 928 kg/cylinder
Average Dosage Rate -1	q1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 170 kg/day
Maximum Dosage Rate -1	q3 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 383 kg/day
Storage day	T More than 15 days
Required Storage Capacity	EC1 D × T = 2,550 kg
Unit Number	EN1 EC1 / Cc = 2.7 cylinders
Maximum Operation Numbers	
Cl <sub>2</sub> -Gas Volatilize Rate	Vr1 ##### @ 20°C Standard temperature
Maximum Dosing Rate	DC1 10 mg/L, Q <sub>T-D</sub> × q3 × 10 <sup>-3</sup> / 24 = 15.94 kg/h
Operation Numbers	EN2 DC1 / Vr1 = 2.0sets
Number	2 W + 2 S
(3) Chlorinator	
Type	Solution Feed Vacuum Type
Number	1 W + 1 S
Operation Dosage Rate -1	Dq1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 382.5 kg/day
Required Dosage Rate	Chlorine -1 : Dq1 / (EN1 × 24) = Minimum 0.00 kg/hr Maximum 16.0 kg/hr
(4) Chlorine Booster Pump	



A-4 Process Cal. EA&al 17MLD Bilishivalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

Type	Branchy on the water supply pipe
Water Demand	Water requiamet for mixed Chlori
Chlorinator Discharge	(kg/hr) 1.0 1.5 2.0 2.5 3.0 4.0
Water Demand	(L/min) 15 20 25 30 35 40
Chlorinator Discharge	(kg/hr) 5.0 6.0 10.0 50.0 100.0 200.0
Water Demand	(L/min) 45 50 60 300 600 1,200
Water requiamet	-
For Chlorin	Qp1 Maximum dosage rate 16.0 kg/hr therefore 100 L/min
Booster Pump Type	Single suction volute pump
Number	1 W + 1 S
<b>9. Dechlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 17,000 m <sup>3</sup> /day
(2) Contact Time	10 min
(3) Type of Dechlorine	Sodium Thiosulfate (Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> · 5H <sub>2</sub> O)
(4) Free Residual Chlorine	1.0 mg/L assumed value
(5) Consumption per day	Average Daily Flow / 1000 × Free Residual Chlorine × 1.75 × 1.5 (safety factor) = 44.6 kg/d = 1.86 kg/h
<b>[2] Dechlorination Contact Tank</b>	
(1) Volume required	Average Flow Rate / 60 × Contact Time = 118.1 m <sup>3</sup>
(2) Width of lane	6.80 m
(3) Length of lane	9.00 m
(4) Side Water Depth	2.00 m
(5) Nos. of Tanks	1 tank
(6) Total Volume	Width × Length × Depth = 6.8 m × 9.0 m × 2.0 m = 122 m <sup>3</sup> > 118.1 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Dechlorine Solution Tank	
Number	2 W + 0 S
Dechlorine concentration	10 %
Gravity of dissolved dechlorine	1.10
Required solution volume	44.63 kg/d × 100 / 10 / 1.10 / 1000 = 0.41 m <sup>3</sup> /d
Volume of Tank	0.288 m <sup>3</sup> /tank (= 0.6 mW × 0.6 mL × 0.8 mH)
Total Volume of Tanks	0.576 m <sup>3</sup> (Duration= 1.42 day)
(2) Mixer for Dechlorine Solution Tank	
Number	2 W + 0 S
(3) Dechlorine Dosing Pump	
Number	2 W + 1 S
Capacity	0.91 m <sup>3</sup> /d / 24 × 1000 / 2 19.02 l/h/unit ⇒ 20 l/h/unit



A-4 Process Cal. EA&al 17MLD Bilishivalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>11. Thickened Sludge Sump</b>	
<b>[1] Design Condition</b>	
(1) Inlet Solids	8,542 kg/day
(2) Inlet Sludge Volume	1,068 m <sup>3</sup> /d
<b>[2] Geometory</b>	
(1) Sludge withdrawl	12 Times/day
(2) Required Sump Volume	89 m <sup>3</sup> /d
(3) Number	2 Basins
(4) Width	3.5 m
(5) Length	4.0 m
(6) Side Water Depth	3.0 m
(7) Actual Sump Volume	$3.5 \times 4.0 \times 3.0 \times 2$ $= 84.0 \text{ m}^3$
<b>[3] Equipment</b>	
(1) Thickened Sludge Transfer Pumps	
Transfer Time	6.00 Hr
Number	2 W + 2 S
Required Capacity	$= \frac{1068 \text{ m}^3}{89.0 \text{ m}^3/\text{Hr}} \Rightarrow \frac{6.0}{90} \times 2 \text{ m}^3/\text{Hr}/\text{Unit}$

A-4 Process Cal. EA&al 17MLD Bilishivalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>12. Centrifuge</b>  <b>[1] Design Condition</b>                  (1) Type of Dewatering                  (2) Generated Sludge                  (3) Design Polyelectrolyte Dosage                  (4) Volume of Thickend Sludge                  (5) Consistency of Dewatered Sludge                  (6) Operation Time</p>	<p>Centrifuge                  7,688 kg/day                  Polyelectrolyte 5 kg/t-DS·day                  307.5 m<sup>3</sup>/day                  82 %                  12 hours/day (6 days per week)</p>
<p><b>[2] Volume of Centrifuges</b></p>	<p><math display="block">\frac{\text{Digested Solids}}{\text{Operation Time} \times \text{No.}} \times \text{Operation/week}</math> <math display="block">= \frac{307.5}{12 \times 2} \times \frac{7}{6} = 14.9</math> <p style="text-align: right;">→ 15 m<sup>3</sup>/hour</p> </p>
<p><b>[3] Dewatered Solids</b></p>	<p><math display="block">\text{Digested Sludge} \times (1 + \text{Injection Rate})</math> <math display="block">= 7,688 \times (1 + 0.0050)</math> <math display="block">= 7,726 \text{ kg/day}</math> </p>
<p><b>[4] Dewatered Cake Volume</b></p>	<p><math display="block">\text{Dewatered Solids} \times \frac{100}{100 - \frac{\text{Moisture Content}}{7}}</math> <math display="block">\times \frac{6 \text{ days per week}}{6}</math> <math display="block">= 7,726 \times \frac{100}{100 - 82} \times \frac{7}{6}</math> <math display="block">= 50.08 \text{ t/day}</math> <p>apparent specific gravity 1.00  <math display="block">\frac{50.08}{1.00} = 50.1 \text{ m}^3/\text{day}</math></p> </p>
<p><b>[5] Polyelectrolyte</b>                  (1) Design Polyelectrolyte Dosage                  (2) Required Polyelectrolyte                  (3) Dissolving concentration                  (4) Volume of Polyelectrolyte solution</p>	<p>Polyelectrolyte 5 kg/t-DS·day                  38.44 kg/day                  0.20 %                  19.22 m<sup>3</sup>/day</p>

A-4 Process Cal. EA&al 17MLD Bilishivalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

<b>[6] Equipment</b>	
(1) Centrifuge	
Capacity	15 m <sup>3</sup> /hr
Number	2 W + 1 S
(2) Centrifuge Feed Pumps	
Capacity	15 m <sup>3</sup> /hr
Number	2 W + 1 S
(3) Polyelectrolyte Dosing Pumps	
Volume of Polyelectrolyte solution	19.22 m <sup>3</sup> /day
Operation Time	12 hours/day (6 days per week)
Safety Factor	1.5
Number	2 W + 1 S
Required Capacity	19.22 m <sup>3</sup> /da × 7 / 6 / 12 / 2
	= 0.93 m <sup>3</sup> /Hr
Specification Capacity	0.93 m <sup>3</sup> /Hr × 1.5
	= 1.401 m <sup>3</sup> /Hr ⇒ 1.40 m <sup>3</sup> /Hr /Unit
(4) Polyelectrolyte dosing System	
Preparation time for solution	3 hr
Required dry polymer	38.44 kg/day × 7 / 6 / 12
	= 3.74 kg/hr
	= 11.21 kg per one batch
Feedong time per one batch	30 min
Capacity of Dry polymer Feeder	22 kg/h
Tanks Dimensions	Width 1.5 m × Length 2.0 m × Depth 2.0 m × 2
	= 12 m <sup>3</sup>
Retention Time of Tank	6.00 m <sup>3</sup> /tank / 0.93 m <sup>3</sup> /Hr / 2
	= 3.211 Hr > 3 Hr
Number	2 W + 0 S

A-4 Process Cal. EA&al 17MLD Bilishivalli, Appendix 12.2.3


**STP Process Calculation Supporting Report 12.2.3**

<b>11. Centrifuge Feed Sump</b>	
<b>[1] Design Condition</b>	
(1) Generated Thickend Sludge	7,688 kg/day
(2) Solids Consistency	2.50 %
(3) Volume of Thickened Sludge	$\begin{aligned} & \text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3} \\ = & 7,688 \times \frac{100}{2.50} \times 10^{-3} \\ = & 308 \text{ m}^3/\text{day} \\ = & 12.81 \text{ m}^3/\text{h} \end{aligned}$
(4) Sludge feed flow rate	15 m <sup>3</sup> /h × 2 = 30 m <sup>3</sup> /h
(5) Centrifuge Operation Time	12 hours/day ( 6 days per week)
<b>[2] Geometry</b>	
(1) Basin Dimensions	$\begin{aligned} & \text{Width } 6.0 \text{ m} \times \text{Length } 6.5 \text{ m} \\ & \times \text{Depth } 4.0 \text{ m} \times 2 \\ = & 312.0 \text{ m}^3 \end{aligned}$
<b>[3] Equipment</b>	
(1) Mixers for Centrifuge Feed Sumps	
Required Volume	312.0 m <sup>3</sup>
Number	1 W + 1 S

Material Balance Sheet SD4

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Sheet  
[17MLD STP]



STP Process Calculation\_Supporting Report 12.2.3

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Digestion Tank + Centrifugal Dewatering)

Table -1 Input Data

1. Calculation Manner	2	1:Premise that the quality of supernatants are same level removed with inlet sewage 2:Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency	2	1:Total Removal Ratio 2:Outlet Water Quality(input 1or2)
In case of 1 : input data		(%)
In case of 2 : input data	#REF!	(mg/l)
3. Selection of Excess Sludge Generation	2	1:Consideration of Solid Matter Only 2:Consideration of Converting of Solved BOD(input 1or2)
In case of 1 : input data (Sludge generation)		Sludge generation ratio per removal SS(%)
	a	0.4 T2=Q4·S4=(a·S <sub>BOD</sub> +b·S1-c·θ·XA)·Q3/10 <sup>6</sup> · (Excess sludge generation formula)
	b	0.9 a:Converting ratio of solved BOD(mgMLSS/mgBOD)
	c	0.05 b:Converting ratio of SS(mgMLSS/mgSS)
In case of 2 : input data	SBOD	234.50 c:Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)
	XA	3,000 S <sub>BOD</sub> :Solved BOD quality at inlet reactor
	θ	1 XA:MLSS concentration(mg/l)
		θ:Hydraulic retention time(day)


Table -2 Basic Conditions

Sewage Flow and Quality	Sludge Moisture and Recovery Ratio	Digestion Tank Conditions	Chemical Conditions for Dewatering
·Inlet flow : Q <sub>0</sub> (m <sup>3</sup> /D)	17,000	·Primary sludge moisture ratio : W1(%)	0.0
·Inlet quality : S <sub>0</sub> (mg/l)	450	·Excess sludge moisture ratio : W2(%)	99.2
·Total removal ratio : A1(%)	-	·Thickened sludge moisture ratio : W3(%)	97.5
·Effluent quality : S1(mg/l)	10.0	·Digested sludge moisture ratio : W4(%)	97.5
·Sludge generation ratio per removal SS : S1(%)	-	·Dewatered sludge moisture ratio : W5(%)	82.0
		·Removal ratio in primary tank : A2(%)	0.0
		·Recovery ratio in sludge thickener : A3(%)	90.0
		·Recovery ratio in sludge digester : A4(%)	100.0
		·Recovery ratio in dewatering : A5(%)	95.0
		·Content of organics in thickened sludge : A6(%)	75.0
		·Digestion ratio : A7(%)	#REF!
		·Digestion gas generation : A8(Nm <sup>3</sup> /kgVS)	
		·Chemical dosage : A9(%)	0.5
		·Chemical dissolve concentration : A10(%)	0.2

Table -3 Material Balance Calculation

	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	手入力(要取束)				16	17	
Q(m <sup>3</sup> /day)	17,000	18,046	0	18,046	1,068	16,978	308	760	0	308	0	19	327	41	286	1,046	1,046					16,978	0
T(t·DS/day)	7,650	8,890	0.000	8,890	8,542	0.170	7,688	0.854	0.000	7,688	0.000	0.038	7,726	7,340	0.386	1,240	1,240					0.170	0.178
S(mg/l)	450	493	0	493	8,000	10	25,000	1,124	0	25,000	0	2,000	23,647	180,000	1,351	1,186					10		
X(T5/T0*100)	100	116.2	0.0	116.2	111.7	2.2	100.5	11.2	0.0	100.5	0.0	0.5	101.0	95.9	5.0	16.2					2.2	2.3	

Figure -1 Material Balance Model



Calculation Formula						
·Q0=Input Data	·Q3=Q1-Q2	·Q6=T6*100/(100-W3)	·Q9=Q6	·Q12=Q9+Q11	·Q15=Q7+Q10+Q14	·Q5-1=Q5-Q11
·T0=Q0*S0*10 <sup>-6</sup>	·T3=T0*(100-A2)/100	·T6=(T2+T4)*A3/100	·T9=(T6-T8)*A4/100	·T12=T9+T11	·T15=T7+T10+T14	·T5-1=T5-T11
·S0=Input Data	·S3=T3*10 <sup>-6</sup> /Q3	·S6=10 <sup>-6</sup> *Q6*(100-W3)/100	·S9=T9*10 <sup>-6</sup> /Q9	·S12=T12*10 <sup>-6</sup> /Q12	·S15=T15*10 <sup>-6</sup> /Q15	·S5-1=S5
·Q1=Q0+Q15	·Q4=T4*100/(100-W2)	·Q7=(Q2+Q4)-Q6	·Q10=Q6-Q8-Q9	·Q13=T13*100/(100-W5)		
·T1=T0+T15	·T4=余剰汚泥発生式による	·T7=(T2+T4)-T6	·T10=T6-T8-T9	·T13=T12*A5/100		
·S1=T1*10 <sup>-6</sup> /Q1	·S4=10 <sup>-6</sup> *Q4*(100-W2)/100	·S7=T7*10 <sup>-6</sup> /Q7	·S10=T10*10 <sup>-6</sup> /Q10	·S13=10 <sup>-6</sup> *Q13*(100-W5)/100		
·Q2=T2*100/(100-W1)	·Q5=Q3-Q4*(T3-T5)/T4	·Q8=0	·Q11=T10*A9/A10	·Q14=Q12-Q13		
·T2=T1-T3	·T5=Q5*ST/10 <sup>-6</sup>	·T8=T6*A6*A7/10 <sup>-4</sup>	·T11=Q11*S11/10 <sup>-6</sup>	·T14=T12-T13		
·S2=10 <sup>-6</sup> *Q2*(100-W1)/100	·S5=St	#REF!	·S11=10 <sup>-4</sup> *A10	·S14=T14*10 <sup>-6</sup> /Q14		



B-1 Process Cal. EA&al 15MLD Varthur Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**Design Condition**

Item	15MLD STP-TSPS			
(1) Design Flow for the year 2049	Flow Rate			
		m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s
	Average Daily	24,000	1000	0.278
	Max Dayly	24,000	1000	0.278
	Max Hourly Peak factor 2.25	54,000	2250	0.625
(1) Design Flow for the year 2034	Flow Rate			
		m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s
	Average Daily	15,000	625	0.174
	Max Dayly	15,000	625	0.174
	Max Hourly Peak factor 2.25	33,750	1406	0.391

**1. Inlet Chamber**

Item	15MLD STP-TSPS		
[1] Design Condition			
(1) Design Flow for the year 2049	Max Hourly	=	54,000 m <sup>3</sup> /d
		=	0.625 m <sup>3</sup> /sec
(2) Inlet Pipe			
Pipe Diameter	•	×	
Gradient		%	
Roughness Coefficient	n=	0.013	(Manning Formula)
Full Pipe Flow Rate		m <sup>3</sup> /s	
(3) Influent Water Level	+	m	
[2] Geometory			
(1) Number of Basins	1	Basin	
(2) Depth of Basin	0.600	m	Approx.
(3) Width of Basin	2.900	m	Approx.
(4) Length of Basin	2.500	m	Approx.
(5) Volume required of Basin	0.600	×	2.900
		×	2.500
		=	0.7 m <sup>3</sup>
(6) Retention Time	0.600	×	2.900
		×	2.500
		/	0.625
	=	6.96	sec
(7) Basin Demensions	Width	2.900	m
	×	Length	2.500
		×	Depth
		0.600	m

B-1 Process Cal. EA&al 15MLD Varthur Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**2. Coarse Screen Channel**

Item	15MLD STP-TSPS					
[1] Geometry						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Width	0.600	m				
Height	0.900	m				
Floor Level	+	5.000	m			
Bottom	+	0.000	m			
Influent Water Level	+	0.600	m			
Velocity	0.625	/		0.600	/	0.600 / 2
where Design Flow for the year 2049	=	0.868	<	1.000	m/sec	OK
Velocity	0.391	/		0.600	/	0.600 / 2
where Design Flow for the year 2034	=	0.543	<	1.000	m/sec	OK
(2) Screen Channel						
Number	2.0	Main	+	1.0	Bypass	
Width	1.200	m				
Side Water Depth	0.600	m				
Velocity	0.625	/		1.200	/	0.600 / 2
where Design Flow for the year 2049	=	0.434	≠	0.450	m/sec	OK
Velocity	0.391	/		1.200	/	0.600 / 2
where Design Flow for the year 2034	=	0.272	<	0.450	m/sec	OK
(3) Channel Dimensions	Width	1.2	m	×	Length	6.0 m
			×	SWD	0.6	m
[3] Equipment						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Dimension	Width	0.6	m	×	Height	0.9 m
Design Water Level	8.0	m				
(2) Coarse Screens (Main Channel)						
Number	2	W	+	0	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	1.2	m				
Width of side plate	50	mm				
Side Water Depth	0.6	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.625	/		1.100	/	0.550 / 2
	× (	20	+	9	) /	20
	=	0.749	<	0.800	m/sec	OK
Velocity through screen	0.391	/		1.100	/	0.550 / 2
where Design Flow for the year 2034	× (	20	+	9	) /	20
	=	0.469	<	0.800	m/sec	OK
(3) Coarse Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	50	mm				
Bar Thickness	9	mm				
Channel Width	1.2	m				
Side Water Depth	0.6	m				
Velocity through screen	0.625	/		1.200	/	0.600 / 2
where Design Flow for the year 2049	× (	50	+	9	) /	50
	=	0.512	<	0.800	m/sec	OK
Velocity through screen	0.391	/		1.200	/	0.600 / 2
where Design Flow for the year 2034	× (	50	+	9	) /	50
	=	0.320	<	0.800	m/sec	OK

B-1 Process Cal. EA&aI 15MLD Varthur Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**3. Raw Sewage Sump**

Item	15MLD STP-TSPS	
[2] Geometory		
(1) Raw Sewage Sump		
Number	1	Basin
Dia	11.00	m
Pump Operating Depth	1.500	m
Retention Time whe Design Flow for the year 2049	$( \frac{11.00^2 \times \pi}{4} \times 1.500 ) / 0.625$	$/ 60 = 3.80 > 3.75$
		min (=minimum time of one pump cycle) OK
Retention Time whe Design Flow for the year 2034	$( \frac{11.00^2 \times \pi}{4} \times 1.500 ) / 0.391$	$/ 60 = 6.08 > 3.75$
		min (=minimum time of one pump cycle) OK
High Water Level	+ 0.000	m
Pump Off Level	+ -1.500	m
[3] Equipment		
(1) Sewage Pumps 1		
Number	2	W + 1 S
Bore Diameter	300	mm
Discharge Flow : 40% Q* 2 whe Design Flow for the year 2034	$0.391 \times 3600 \times 40.0\%$	$Q = 563 \Rightarrow 570$
		m <sup>3</sup> /Hr
Total Head	15.0	m
(2) Sewage Pumps 2		
Number	1	W + 1 S
Bore Diameter	200	mm
Discharge Flow : 20% Q* 1 whe Design Flow for the year 2034	$0.391 \times 3600 \times 20.0\%$	$Q = 282 \Rightarrow 285$
		m <sup>3</sup> /Hr
Total Head	15.0	m

B-1 Process Cal. EA&aI 15MLD Varthur Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

Item	15MLD STP																																																		
<b>1. STP Design Condition</b>																																																			
(1) Design Flow Rate	<table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th></th> <th>m3/d</th> <th>m3/h</th> <th>m3/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td>15,000</td> <td>625.00</td> <td>0.174</td> </tr> <tr> <td>Max Daily</td> <td>15,000</td> <td>625.00</td> <td>0.174</td> </tr> <tr> <td>Max Hourly Peak factor 2.25</td> <td>33,750</td> <td>1406.25</td> <td>0.391</td> </tr> </tbody> </table>											m3/d	m3/h	m3/s	Average Daily	15,000	625.00	0.174	Max Daily	15,000	625.00	0.174	Max Hourly Peak factor 2.25	33,750	1406.25	0.391																									
	m3/d	m3/h	m3/s																																																
Average Daily	15,000	625.00	0.174																																																
Max Daily	15,000	625.00	0.174																																																
Max Hourly Peak factor 2.25	33,750	1406.25	0.391																																																
(2) Design Water Quality	<p style="text-align: right;">Unit: mg/L</p> <table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th colspan="2">TP</th> </tr> <tr> <th>NH<sub>4</sub>-N</th> <th>Org-N</th> <th>NOx-N</th> <th>D-P</th> <th>P-P</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td>350</td> <td>800</td> <td>450</td> <td>45</td> <td>25</td> <td>0</td> <td>5</td> <td>2</td> </tr> <tr> <td>Outlet</td> <td>10</td> <td>50</td> <td>10</td> <td>1</td> <td>0</td> <td>9</td> <td>1</td> <td>1</td> </tr> <tr> <td>Removal rate</td> <td>97.1%</td> <td>93.7%</td> <td>97.8%</td> <td colspan="3">85.7%</td> <td colspan="2">71.4%</td> </tr> </tbody> </table>											BOD	COD	SS	T-N			TP		NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P	Inlet	350	800	450	45	25	0	5	2	Outlet	10	50	10	1	0	9	1	1	Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%	
	BOD	COD	SS	T-N			TP																																												
				NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P																																											
Inlet	350	800	450	45	25	0	5	2																																											
Outlet	10	50	10	1	0	9	1	1																																											
Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%																																												
<b>2. Inlet Chamber</b>																																																			
<b>[1] Design Condition</b>																																																			
(1) Design Flow Rate	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;"></td> <td style="width: 10%;">Max Hourly</td> <td style="width: 10%;">=</td> <td style="width: 10%;">33,750</td> <td style="width: 10%;">m3/day</td> <td colspan="5"></td> </tr> <tr> <td></td> <td></td> <td>=</td> <td>0.391</td> <td>m3/sec</td> <td colspan="5"></td> </tr> </table>											Max Hourly	=	33,750	m3/day								=	0.391	m3/sec																										
	Max Hourly	=	33,750	m3/day																																															
		=	0.391	m3/sec																																															
<b>[2] Geometry</b>																																																			
(1) Number of Basins	1 Basin																																																		
(2) Depth of Basin	2.000 m																																																		
(3) Width of Basin	2.900 m																																																		
(4) Length of Basin	2.500 m																																																		
(5) Volume required of Basin	2.000 × 2.900 × 2.500 = 2.3 m3																																																		
(6) Retention Time	2.000 × 2.900 × 2.500 / 0.391 × 1 = 37.08 sec																																																		
(7) Basin Dimensions	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;"></td> <td style="width: 10%;">Width</td> <td style="width: 10%;">2.900</td> <td style="width: 10%;">m</td> <td style="width: 10%;">×</td> <td style="width: 10%;">Length</td> <td style="width: 10%;">2.500</td> <td style="width: 10%;">m</td> <td colspan="2"></td> </tr> <tr> <td></td> <td>×</td> <td>Depth</td> <td>2.000</td> <td>m</td> <td colspan="5"></td> </tr> </table>											Width	2.900	m	×	Length	2.500	m				×	Depth	2.000	m																										
	Width	2.900	m	×	Length	2.500	m																																												
	×	Depth	2.000	m																																															

B-1 Process Cal. EA&al 15MLD Varthur.Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Wastewater Flow	$\begin{aligned} \text{Max Hourly} &= 33,750 \text{ m}^3/\text{d} \\ &= 0.391 \text{ m}^3/\text{sec} \end{aligned}$
[2] Geometory	
(1) Inlet Gate	
Number	2 Main + 1 Bypass
Width	0.500 m
Height	0.750 m
Floor Level	+ 2.000 m
Bottom	+ 0.000 m
Influent Water Level	+ 0.500 m
Velocity	$\begin{aligned} &0.391 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 2 \\ = &0.782 \text{ } \div \quad 1.000 \text{ m/sec} \end{aligned}$
(2) Screen Channel	
Number	2 Main + 1 Bypass
Width	1.000 m
Side Water Depth	0.500 m
Velocity	$\begin{aligned} &0.391 \text{ } \swarrow \quad 1.000 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 2 \\ = &0.391 \text{ } \div \quad 0.450 \text{ m/sec} \end{aligned}$
(3) Channel Dimensions	$\begin{aligned} \text{Width} &1.0 \text{ m} \times \text{Length} &6.0 \text{ m} \\ &\times \text{SWD} &0.5 \text{ m} \end{aligned}$
[3] Equipment	
(1) Inlet Gate	
Number	2 W + 1 S
Dimension	Width 0.5 m × Height 0.75 m
Design Water Level	2.00 m
(2) Fine Screens (Main Channel)	
Number	2 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	1.0 m
Width of side plate	50 mm
Side Water Depth	0.5 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	$\begin{aligned} &0.391 \text{ } \swarrow \quad 0.900 \text{ } \swarrow \quad 0.450 \text{ } \swarrow \quad 2 \\ &\times ( \quad 6 \quad + \quad 2 \quad ) / \quad 6 \\ = &0.644 < \quad 0.800 \text{ m/sec} \end{aligned}$
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	1.0 m
Side Water Depth	0.5 m
Velocity through screen	$\begin{aligned} &0.391 \text{ } \swarrow \quad 1.000 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 2 \\ &\times ( \quad 20 \quad + \quad 9 \quad ) / \quad 20 \\ = &0.567 < \quad 0.800 \text{ m/sec} \end{aligned}$

B-1 Process Cal. EA&aI 15MLD Varthur.Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<b>4. Grit Chamber</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Peak flow = 33,750 m <sup>3</sup> /day = 0.391 m <sup>3</sup> /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0111 m/sec = 960 m <sup>3</sup> /m <sup>2</sup> /day
(4) Average Velocity	0.3 m/sec
<b>[2] Grit Chamber</b>	
(1) Surface Area required	0.391 / 0.0111 = 35.23 m <sup>2</sup>
(2) Number of Basins	1 S + 1 W
(3) Surface Area required/Basin	35.23 / 1 = 35.23 m <sup>2</sup>
(4) Length of Basin	35.23 ^0.5 = 5.935 m → 6.0 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.391 × 60 sec / 1 = 23.5 m <sup>3</sup>
(7) Depth required	23.5 / 6.0 / 6.0 = 0.652 m
(8) Basin Dimensions	Width 6.0 m × Length 6.0 m × Depth 0.7 m (Freeboard 0.3m)
(9) Retention Time	6 × 6.0 × 0.7 / 0.391 × 1 = 60.00 sec
(10) Surface Overflow Rate at Peak Flow	33,750 / 6.0 / 6.0 / 1 = 937.5 < 960 m <sup>3</sup> /m <sup>2</sup> /day
<b>[3] Parshall Flume</b>	
(1) Design Flow Rate	Q= 391.000 l/sec
(2) Throat width	W= 0.450 m
(3) Water depth Ha	Ha= ( Q / 2264 / W ) <sup>2/3</sup> Ha= 0.528 m
(4) Crest Level	+ m ≐ Minimum water level at downstream channel
(5) Water level at the crest	+ 0.528 m
(6) Channel bottom level	+ m
(7) Upstream Channel width	1.500 m
(8) SWD of Upstream Channel	0.700 m
(9) Average velocity at upstream channel	0.372 m/sec
(10) Total Length of channel	10.000 m
<b>[4] Inlet Weir Gate</b>	
(1) Number	2 Units
(2) Weir Width	0.800 m
(3) Stroke	0.550 m
(4) Overflow Height	0.500 m
(5) Overflow Height (actual)	( 0.391 / 1.840 / 0.800 / 2 ) <sup>2/3</sup> = 0.260 < 0.500 m

**STP Process Calculation\_Supporting Report 12.2.3**

<b>5. Reactor</b>																																																								
<b>[1] Design Condition</b>																																																								
(1) Design Wastewater Flow	Q= 15,000 m <sup>3</sup> /day (summer) Q'= 15,000 m <sup>3</sup> /day(Winter)																																																							
(2) Design Sewage Quality																																																								
Inlet BOD	350 mg/l																																																							
Outlet BOD	10.0 mg/l																																																							
Inlet S-BOD	235 mg/l assumed as 67% of BOD																																																							
Inlet COD	800 mg/l																																																							
Inlet bCOD :S <sub>0</sub>	578 mg/l																																																							
Inlet nbCOD	223 mg/l																																																							
bCOD/BOD	1.65																																																							
Inlet S-COD :sCOD	271 mg/l assumed as 33% of BOD																																																							
Inlet rbCOD	231 mg/l bCOD*40%																																																							
Inlet sbCOD	347 mg/l bCOD*60%																																																							
Outlet S-COD :nbsCODe	40 mg/l																																																							
Inlet nbpCOD :nbpCOD	183 mg/l =TCOD-bCOD-nbsCODe																																																							
Inlet SS	450 mg/l																																																							
Inlet VSS	383 mg/l assumed as 85% of TSS																																																							
:VSS <sub>COD</sub>	1.38 gCOD/gVSS =(TCOD-sCOD)/VSS																																																							
:nbVSS	131.96 gnbVSS/m <sup>3</sup> =nbpCOD/VSS <sub>COD</sub>																																																							
:iTSS	67.50 gnbVSS/m <sup>3</sup> =TSS-VSS																																																							
Inlet T-N	70 mg/l																																																							
Inlet TKN	70 mg/l																																																							
Inlet NH <sub>4</sub> -N	45.0 mg/l																																																							
Inlet T-P	7 mg/l																																																							
Inlet D-P	5 mg/l																																																							
Inlet Alkalinity as CaCO <sub>3</sub>	380 mg/l																																																							
Outlet Kjeldahl N	1.0 mg/l																																																							
Outlet NH <sub>4</sub> -N	1.0 mg/l																																																							
Outlet NO <sub>3</sub> -N	9.0 mg/l																																																							
Outlet T-P	2 mg/l																																																							
Outlet D-P	1 mg/l																																																							
(3) Water Temperature	T= 20.0 °C																																																							
(4) Safety Factor for Nitrogen	SF= 1.5																																																							
(5) Return Sludge Concentration	R <sub>s</sub> = 8,000 mg/l																																																							
(6) MLSS MLVSS	X <sub>TSS</sub> = 3,000 mg/l																																																							
(7) DO in the Reactor	2 mg/L																																																							
<b>[2] Design Value for perfect Nitrification of Nitrification Process</b>																																																								
(1) Activated sludge design kinwtic coefficients at 20°C																																																								
	<table border="1"> <thead> <tr> <th>Coefficient</th> <th>Unit</th> <th>COD oxidatio</th> <th>NH4 oxidatio</th> <th>NO2 oxidatio</th> </tr> </thead> <tbody> <tr> <td>μ<sub>max</sub></td> <td>gVSS/gVSS · d</td> <td>6.000</td> <td>0.900</td> <td>1.000</td> </tr> <tr> <td>K<sub>a</sub>,K<sub>NH4</sub>,K<sub>NO2</sub></td> <td>mg/L</td> <td>8.000</td> <td>0.500</td> <td>0.200</td> </tr> <tr> <td>Y</td> <td>gVSS/g substrate oxidized</td> <td>0.450</td> <td>0.150</td> <td>0.050</td> </tr> <tr> <td>b</td> <td>gVSS/gVSS · d</td> <td>0.120</td> <td>0.170</td> <td>0.170</td> </tr> <tr> <td>fd</td> <td>unitless</td> <td>0.150</td> <td>0.150</td> <td>0.150</td> </tr> <tr> <td>K<sub>O2</sub></td> <td>mg/L</td> <td>0.200</td> <td>0.500</td> <td>0.900</td> </tr> <tr> <td>θ Value</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>μ<sub>max</sub></td> <td>unitless</td> <td>1.070</td> <td>1.072</td> <td>1.063</td> </tr> <tr> <td>b</td> <td>unitless</td> <td>1.040</td> <td>1.029</td> <td>1.029</td> </tr> <tr> <td>K<sub>a</sub>,K<sub>NH4</sub>,K<sub>NO2</sub></td> <td>unitless</td> <td>1.000</td> <td>1.000</td> <td>1.000</td> </tr> </tbody> </table> <p>Wastwater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF &amp; EDDY/AECOM)</p>	Coefficient	Unit	COD oxidatio	NH4 oxidatio	NO2 oxidatio	μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000	K <sub>a</sub> ,K <sub>NH4</sub> ,K <sub>NO2</sub>	mg/L	8.000	0.500	0.200	Y	gVSS/g substrate oxidized	0.450	0.150	0.050	b	gVSS/gVSS · d	0.120	0.170	0.170	fd	unitless	0.150	0.150	0.150	K <sub>O2</sub>	mg/L	0.200	0.500	0.900	θ Value					μ <sub>max</sub>	unitless	1.070	1.072	1.063	b	unitless	1.040	1.029	1.029	K <sub>a</sub> ,K <sub>NH4</sub> ,K <sub>NO2</sub>	unitless	1.000	1.000	1.000
Coefficient	Unit	COD oxidatio	NH4 oxidatio	NO2 oxidatio																																																				
μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000																																																				
K <sub>a</sub> ,K <sub>NH4</sub> ,K <sub>NO2</sub>	mg/L	8.000	0.500	0.200																																																				
Y	gVSS/g substrate oxidized	0.450	0.150	0.050																																																				
b	gVSS/gVSS · d	0.120	0.170	0.170																																																				
fd	unitless	0.150	0.150	0.150																																																				
K <sub>O2</sub>	mg/L	0.200	0.500	0.900																																																				
θ Value																																																								
μ <sub>max</sub>	unitless	1.070	1.072	1.063																																																				
b	unitless	1.040	1.029	1.029																																																				
K <sub>a</sub> ,K <sub>NH4</sub> ,K <sub>NO2</sub>	unitless	1.000	1.000	1.000																																																				
(2) μ <sub>AOB</sub>	$\mu_{AOB} = 0.3100 \text{ g/g} \cdot \text{d} = \mu_{max, AOB} [S_{NH4} / (S_{NH4} + K_{NH4})] [S_0 / (S_0 + K_{O, AOB})] - b_{AOB}$ $\mu_{max, AOB, T} = 0.9000 \text{ g/g} \cdot \text{d} = \mu_{max} * 1.072^{(T-20)} \mu_{max} \text{ at } 20^\circ\text{C} = 0.900$ $b_{AOB, T} = 0.1700 = b * 1.029^{(T-20)} \quad b \text{ at } 20^\circ\text{C} = 0.170$ $S_{NH4} = 1.0000 \text{ mg/l}$ $DO = 2.0000 \text{ mg/l}$ $K_{O, AOB} = 0.5000 \text{ mg/l}$																																																							

B-1 Process Cal. EA&al 15MLD Varthur.Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

(2) Design SRT	SRT= 4.8387 day ⇒ 5.0000 day	$= 1/\mu_{AOB} \times SF$
(3) Biomass production		
P <sub>x,VSS</sub>	P <sub>x,VSS</sub> = 4690.557 kg/d	= P <sub>x,bio</sub> +Q(nbVSS)
P <sub>x,TSS</sub>	P <sub>x,TSS</sub> = 6442.849 kg/d	= P <sub>x,bio</sub> +0.85+Q(nbVSS)+Q(TSS <sub>0</sub> -VSS <sub>0</sub> )+5*Q*Al
S	S= 0.4507 mg/l	= K <sub>s</sub> [1+b <sub>H</sub> (SRT)]/[SRT(μ <sub>m</sub> -b <sub>H</sub> )-1]
b <sub>H</sub>	b <sub>H</sub> = 0.1200	= b*1.04 <sup>(T-20)</sup> b at 20°C = 0.120
Y <sub>H</sub>	Y <sub>H</sub> = 0.4500 gVSS/g bCOD	
μ <sub>m,T</sub>	μ <sub>m,T</sub> = 6.0000 g/g*d	= μ <sub>max</sub> *1.04 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 6.000
Y <sub>n</sub>	Y <sub>n</sub> = 0.150 gVSS/g Nox	
NO <sub>x</sub>	NO <sub>x</sub> = 47.400 mg/l	
P <sub>x,bio,VSS</sub>	P <sub>x,bio,VSS</sub> = 2711.174 kg VSS/d	= Q*Y <sub>H</sub> (S <sub>0</sub> -S)/[1+b <sub>H</sub> (SRT)]+f <sub>d</sub> .b <sub>H</sub> .QY <sub>H</sub> (S <sub>0</sub> -S)SRT/[1+b <sub>H</sub> (SRT)]
	2434.427	= Q*Y <sub>n</sub> (Nox)[2+b <sub>AOB</sub> (SRT)]
	219.098	= Q*Y <sub>H</sub> (S <sub>0</sub> -S)/[1+b <sub>H</sub> (SRT)]
	57.649	= f <sub>d</sub> .b <sub>H</sub> .QY <sub>H</sub> (S <sub>0</sub> -S)SRT/[1+b <sub>H</sub> (SRT)]
		= QY <sub>n</sub> (Nox)[1+b <sub>AOB</sub> (SRT)]
NO <sub>x</sub>	NO <sub>x</sub> = 47.311 mg/l	= TKN-Ne-0.12P <sub>x,bio</sub> /Q
(4) Required Aeration Tank Volume		
V <sub>a</sub>	V <sub>a</sub> = 10,738 m <sup>3</sup>	
τ	τ = 17.18 hr ⇒ 18.00 hr	= V <sub>a</sub> /Q × 24
X <sub>VSS</sub> ·V <sub>a</sub>	X <sub>VSS</sub> ·V <sub>a</sub> = 23,453 kg VSS	= P <sub>x,VSS</sub> ·SRT
X <sub>TSS</sub> ·V <sub>a</sub>	X <sub>TSS</sub> ·V <sub>a</sub> = 32,214 kg TSS	= P <sub>x,TSS</sub> ·SRT
F/M	F/M= 0.224 kgBOD/kgMLVSS	
FractionVSS=	FractionVSS= 0.728	
MLVSS=	MLVSS= 2184 mg/L	
(5) BODloading	BODloading= 0.489 kg/m <sup>3</sup> ·d	
(6) Observed Yield		
Y <sub>obs,TSS</sub>	Y <sub>obs,TSS</sub> = 1.228 gTSS/gBOD	
Y <sub>obs,VSS</sub>	Y <sub>obs,VSS</sub> = 0.894 gVSS/gBOD	
bCODremoved=	bCODremov= 8,656 kg/d	
(7) effluent NO <sub>2</sub> -N	NO <sub>2</sub> -N= 0.2315 mg/l	= K <sub>s</sub> [1+b <sub>NOB</sub> (SRT)]/[SRT(μ <sub>NOB</sub> -b <sub>NOB</sub> )-1]
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700	= b*1.029 <sup>(T-20)</sup> b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 1.0000 g/g*d	= μ <sub>max</sub> *1.04 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 1.000
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.6897 g/g*d	= μ <sub>max,NOB</sub> [S <sub>0</sub> /(S <sub>0</sub> +K <sub>O2,NOB</sub> )]
	S <sub>0</sub> = 2.000 mg/l	
	K <sub>O2,NOB</sub> = 0.900 mg/l	
(8) effluent NH <sub>4</sub> -N	NH <sub>4</sub> -N= 0.5286 mg/l	= K <sub>s</sub> [1+b <sub>NOB</sub> (SRT)]/[SRT(μ <sub>NOB</sub> -b <sub>NOB</sub> )-1]
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700	= b*1.029 <sup>(T-20)</sup> b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 0.9000 g/g*d	= μ <sub>max</sub> *1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.7200 g/g*d	= μ <sub>max,NOB</sub> [S <sub>0</sub> /(S <sub>0</sub> +K <sub>O2,NOB</sub> )]
	S <sub>0</sub> = 2.000 mg/l	
	K <sub>O2,NOB</sub> = 0.500 mg/l	
(9) Ratio of Return Sludge	8,000*R <sub>r</sub> /(1+R <sub>r</sub> )= 3,000 mg/L 3,000/(8,000-3,000)= 0.60 R <sub>r</sub> = 0.60	



**STP Process Calculation\_Supporting Report 12.2.3**

<b>[3] Design for Nitrification and Denitrification Process</b>																					
(1) Active biomass concentration	$X_b = Q \cdot (SRT) / V \cdot Y_H(S_0 - S) [1 + b_H(SRT)]$ = 1,133.55 mg/l																				
(2) IR ratio	$IR = NO_x / Ne - 1.0 - R$ = 3.66																				
(3) The amount of NO3-N fed to the anoxic tank	$Nox\ feed = (IR + R) \cdot Q \cdot Ne$ = 574,659.15 kg/d																				
(4) The anoxic tank volume	$V_{nor} = 1,074\ m^3 = V_a \times 10\%$ $V_{nor} = 3,125\ m^3 \quad \tau_{DN} = 5.000\ h$																				
(5) F/M <sub>b</sub>	F/M <sub>b</sub> = 1.48 g/g·d																				
(6) Fraction of rbCOD	40.00% = rbCOD/bCOD																				
	<table border="1"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b<sub>0</sub></th> <th>b<sub>1</sub></th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>	Percent rdCOD(%)	SDNR equation coefficients		b <sub>0</sub>	b <sub>1</sub>	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162
Percent rdCOD(%)	SDNR equation coefficients																				
	b <sub>0</sub>	b <sub>1</sub>																			
10	0.186	0.078																			
20	0.213	0.118																			
30	0.235	0.141																			
40	0.242	0.152																			
50	0.270	0.162																			
(8) SDNR <sub>b</sub>	$SDNR_b = 0.302\ g/g \cdot d = b_0 + b_1 [\ln(F/M_b)]$ $b_0 = 0.242$ $b_1 = 0.152$																				
(8) SDNR	$SDNR = 0.113\ g/g \cdot d = SDNR_b (MLVSS_0 / MLVSS)$ $SDNR_{adj} = 0.217\ g/g \cdot d = SDNR_t - 0.029 \ln(F/M_b) - 0.012 \quad IR=3-4$ $= SDNR_t - 0.0166 \ln(F/M_b) - 0.078 \quad IR=2$ $SDNR_t = 0.302\ g/g \cdot d = SDNR_b \cdot \theta^{(t-20)} \quad \theta = 1.026$																				
(9) NO <sub>r</sub>	$NO_r = 769,650.62\ kg/d = N_{nox} \cdot SDNR \cdot X_b$ $> Nox\ feed = 574,659\ kg/d$																				
(10) Alkalinity to be added to maintain pH7	-108.33 mg/l  Influent Alk 380.00 mg/l Alk used 338.44 mg/l = 7.14 × Nox Alk produced 136.77 mg/l = 3.57 × (NOx - NO <sub>x</sub> e) Alk to maint: 70.00 mg/l																				
<b>[4] Design of Phosphorus Removal Process</b>																					
(1) Removal T-P	3.13 mg/l																				
P in waste sludge	px = 1.00%																				
Generated waste sludge	Px <sub>vss</sub> = 4690.557 kg/d																				
Removal Phosphorus	46.9055704 kg/d																				
(2) Effluent T-P without Al	3.87 mg/l																				
(3) Required Al to initial soluble phosphorus ratio	1.00 mol/mol																				
(4) Required Al dosing rate	3.48 mg/l as Al																				
	42.98 mg/l as crystal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> · 18H <sub>2</sub> O																				
(5) Required Aluminum Sulfate	644.66 kg/d																				
(6) Required Aluminum Sulfate solution 10%	6.14 m <sup>3</sup> /d																				
	255.82 L/H																				
(7) Additional sludge	261.35 kg/d																				

**STP Process Calculation\_Supporting Report 12.2.3**

<p><b>[5] Reactor</b></p> <p>(1) Total volume of Aeration Basins</p> <p>(2) Total volume of Anoxic Basins</p>	$V_A = Q \cdot \theta_a / 24$ $= 11,250 \text{ m}^3$ $V_{DN} = Q \cdot \theta_{DN} / 24$ $= 3,125 \text{ m}^3$ <table border="1" data-bbox="571 427 1061 627"> <thead> <tr> <th rowspan="2">Item</th> <th rowspan="2">Volume required</th> <th colspan="2">Retention Time required</th> <th rowspan="2">Ratio of Volume</th> </tr> <tr> <th>Summer</th> <th>Winter</th> </tr> <tr> <th>unit</th> <th>m<sup>3</sup></th> <th>hour</th> <th>hour</th> <th></th> </tr> </thead> <tbody> <tr> <td>Anaerobic</td> <td>V<sub>AN</sub></td> <td>940</td> <td>1.50</td> <td>1.50</td> <td>0.30</td> </tr> <tr> <td>Anoxic</td> <td>V<sub>DN</sub></td> <td>3,125</td> <td>5.00</td> <td>5.00</td> <td>1.00</td> </tr> <tr> <td>Aerobic</td> <td>V<sub>A</sub></td> <td>11,250</td> <td>18.00</td> <td>18.00</td> <td>3.60</td> </tr> <tr> <td>Total</td> <td>V</td> <td>15,315</td> <td>24.50</td> <td>24.50</td> <td></td> </tr> </tbody> </table>	Item	Volume required	Retention Time required		Ratio of Volume	Summer	Winter	unit	m <sup>3</sup>	hour	hour		Anaerobic	V <sub>AN</sub>	940	1.50	1.50	0.30	Anoxic	V <sub>DN</sub>	3,125	5.00	5.00	1.00	Aerobic	V <sub>A</sub>	11,250	18.00	18.00	3.60	Total	V	15,315	24.50	24.50																															
Item	Volume required			Retention Time required			Ratio of Volume																																																												
		Summer	Winter																																																																
unit	m <sup>3</sup>	hour	hour																																																																
Anaerobic	V <sub>AN</sub>	940	1.50	1.50	0.30																																																														
Anoxic	V <sub>DN</sub>	3,125	5.00	5.00	1.00																																																														
Aerobic	V <sub>A</sub>	11,250	18.00	18.00	3.60																																																														
Total	V	15,315	24.50	24.50																																																															
<p><b>[6] Geometry</b></p> <p>(1) Basin Dimensions</p> <p>Cross Section</p> <p>Hantzsch Subtraction</p> <p>after Subtraction</p> <p>Total Volume</p> <p>(2) Partition of Basin</p>	<p>Width      Length      Depth      Basins</p> <p>8.0                      180.0      5.5              2</p> <p>Cross Section      8.0*5.5      =      44.0 m<sup>2</sup>/Basin</p> <p>Hantzsch Subtraction      =      1.0 m<sup>2</sup>/Basin</p> <p>after Subtraction      44.0-1.0      =      43.0 m<sup>2</sup>/Basin</p> <p>Total Volume      43.0*180.0      =      7,740 m<sup>2</sup>/Basin      15,480 m<sup>3</sup>/Total</p> <table border="1" data-bbox="571 857 1129 1310"> <thead> <tr> <th>Item</th> <th>unit</th> <th>Anaerobic</th> <th>Anoxic</th> <th>Aerobic</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Cross Section</td> <td>m<sup>2</sup></td> <td colspan="3">43.0</td> <td></td> </tr> <tr> <td>Length required</td> <td>m</td> <td><b>10.9</b></td> <td><b>36.3</b></td> <td><b>130.8</b></td> <td><b>178.1</b></td> </tr> <tr> <td>Volume required per Basin</td> <td>m<sup>3</sup></td> <td>470</td> <td>1,563</td> <td>5,625</td> <td>7,658</td> </tr> <tr> <td>Total Volume required</td> <td>m<sup>3</sup></td> <td>940</td> <td>3,125</td> <td>11,250</td> <td>15,315</td> </tr> <tr> <td>Actual Cross Section</td> <td>m<sup>2</sup></td> <td>43.0</td> <td>43.0</td> <td>43.0</td> <td></td> </tr> <tr> <td>Actual Length</td> <td>m</td> <td>12.0</td> <td>37.0</td> <td>131.0</td> <td>180.0</td> </tr> <tr> <td>Actual Volume per Basin</td> <td>m<sup>3</sup></td> <td>516</td> <td>1,591</td> <td>5,633</td> <td>7,740</td> </tr> <tr> <td>Actual Total Volume</td> <td>m<sup>3</sup></td> <td>1,032</td> <td>3,182</td> <td>11,266</td> <td>15,480</td> </tr> <tr> <td>Actual Ratio of Volume</td> <td></td> <td>0.32</td> <td>1.00</td> <td>3.54</td> <td></td> </tr> <tr> <td>Actual Retention Time</td> <td>hour</td> <td>1.65</td> <td>5.09</td> <td>18.03</td> <td>24.77</td> </tr> </tbody> </table>	Item	unit	Anaerobic	Anoxic	Aerobic	Total	Cross Section	m <sup>2</sup>	43.0				Length required	m	<b>10.9</b>	<b>36.3</b>	<b>130.8</b>	<b>178.1</b>	Volume required per Basin	m <sup>3</sup>	470	1,563	5,625	7,658	Total Volume required	m <sup>3</sup>	940	3,125	11,250	15,315	Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0		Actual Length	m	12.0	37.0	131.0	180.0	Actual Volume per Basin	m <sup>3</sup>	516	1,591	5,633	7,740	Actual Total Volume	m <sup>3</sup>	1,032	3,182	11,266	15,480	Actual Ratio of Volume		0.32	1.00	3.54		Actual Retention Time	hour	1.65	5.09	18.03	24.77
Item	unit	Anaerobic	Anoxic	Aerobic	Total																																																														
Cross Section	m <sup>2</sup>	43.0																																																																	
Length required	m	<b>10.9</b>	<b>36.3</b>	<b>130.8</b>	<b>178.1</b>																																																														
Volume required per Basin	m <sup>3</sup>	470	1,563	5,625	7,658																																																														
Total Volume required	m <sup>3</sup>	940	3,125	11,250	15,315																																																														
Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0																																																															
Actual Length	m	12.0	37.0	131.0	180.0																																																														
Actual Volume per Basin	m <sup>3</sup>	516	1,591	5,633	7,740																																																														
Actual Total Volume	m <sup>3</sup>	1,032	3,182	11,266	15,480																																																														
Actual Ratio of Volume		0.32	1.00	3.54																																																															
Actual Retention Time	hour	1.65	5.09	18.03	24.77																																																														
<p><b>[7] Equipment</b></p> <p>(1) Ras Pumps</p> <p>Ras Ratio</p> <p>Required Capacity</p> <p>Number</p> <p>(2) Circulation Pumps</p> <p>Ras Ratio</p> <p>Required Capacity</p> <p>Number</p> <p>(3) SAS Pumps</p> <p>Excess Sludge</p> <p>Sludge withdraw</p> <p>Running Time</p> <p>Required Capacity</p> <p>Number</p>	<p>60%</p> <p>15,000 m<sup>3</sup>/day ×      60% / 24 /      2</p> <p>= 188 m<sup>3</sup>/Hr ⇒      190 m<sup>3</sup>/Hr</p> <p>2 Work</p> <p>2 Stanby</p> <p>366%</p> <p>15,000 m<sup>3</sup>/day ×      366% / 24 /      4</p> <p>= 571 m<sup>3</sup>/Hr ⇒      580 m<sup>3</sup>/Hr</p> <p>4 Work</p> <p>2 Stanby</p> <p>942 m<sup>3</sup>/day</p> <p>12 Times/day</p> <p>0.5 Hr/Time</p> <p>942 m<sup>3</sup>/day /      12 /      0.50 /      2</p> <p>= 78.52 m<sup>3</sup>/Hr ⇒      80 m<sup>3</sup>/Hr</p> <p>2 Work</p> <p>2 Stanby</p>																																																																		

B-1 Process Cal. EA&al 15MLD Varthur.Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

(4) Alum Solution Tank										
Number	2	W	+	0	S					
Alum concentration as crystal	10	%								
Gravity of dissolved dechlorine	1.05									
Required solution volume	644.66	kg / d	×	100	/	10	/	1.05	/	1000
=	6.14	m <sup>3</sup> /d								
Volume of Tank	3.5	m <sup>3</sup> /tank	(=	1.4	mW×	1.4	mL×	1.8	mH)	
Total Volume of Tanks	7.1	m <sup>3</sup>	(Duration=			1.15	day)			
(5) Mixer for Alum Solution Tank										
Number	2	W	+	0	S					
(6) Alum Dosing Pump										
Number	2	W	+	1	S					
Capacity	6.14	m <sup>3</sup> /d	/	24	×	1000	/	2	×	2
	255.82	l/h/unit	⇒	260	l/h/unit					

B-1 Process Cal. EA&al 15MLD Varthur Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>6. Air Requirement at Average Flow</b>	
[1] Design Condition	
(1) AOR	AOR = 6,490 kg/day = 270.4 kg/h
Q <sub>in</sub> : Design Average Flow m <sup>3</sup> /d	15,000
Inlet bCOD : S <sub>0</sub>	578 mg/l
S=	S= 0.451 mg/l
Nox=	Nox 47.400 mg/l
P <sub>X,bio</sub> =	P <sub>X,b</sub> 2,653.5 kg VSS/d does not include nitrifying bacteria
R <sub>0</sub> =	R <sub>0</sub> = Q(S <sub>0</sub> -S-k(NOx-NOxe))-1.42P <sub>X,bio</sub> +4.57Q•NOx
R <sub>0</sub> =	R <sub>0</sub> = 6,490 kg O <sub>2</sub> /d
	k= 2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{\text{AOR} \times C_s \cdot a \times 1.024^{20-T}}{\alpha \times F (\beta \cdot C_{sw}/C_s \cdot (P_b/P_a)a - C_A)}$
	C <sub>s</sub> : Saturated DO at sea level and 20 °C 9.09 mg/L
	C <sub>sw</sub> : Saturated DO at sea level and operating Temperature 9.09 mg/L at 20 °C
	20-T : 0.0 1.024 <sup>20-T</sup> : 1.0000
	C <sub>A</sub> : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1+0.40D <sub>j</sub> /P <sub>a</sub> 1.19357
	D <sub>j</sub> : Tank Liquid Depth 5.00 m
	P <sub>a</sub> : Standard absolute pressure at s 10.332 m
	P <sub>b</sub> : Absolute pressure at Plant Site Elevation m
	P <sub>b</sub> /P <sub>a</sub> : exp[-gM(z <sub>b</sub> -z <sub>a</sub> )/R*T] 0.900
	g : Acceleration due to Gravity 9.80665 m/s <sup>2</sup>
	M : Mole of Air 28.97 kg/kg-mole
	z <sub>b</sub> : Plant Site Elevation 900 m
	z <sub>a</sub> : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 293.15 Kelvin
	α : relative Transfer Rate to clean W <sub>a</sub> 0.65
	β : relative DO Saturation to clean W <sub>ε</sub> 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{70,410}{4.2591} = 16,531.48 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Standard O <sub>2</sub> required at Field Conditions per Bas =	8,266 kg/day
(5) SOTE for the above Effective Aeration Depth	28.0 %
(6) Fraction of O <sub>2</sub> in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	15%
(9) Air required at Field Conditions per Basins	= 121,567 m <sup>3</sup> /day = 5,065.3 m <sup>3</sup> /hr
[2] Equipment	

Air Requirement at Average Flow 12/23

B-1 Process Cal. EA&amp;al 15MLD Varthur Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

(1) Air Blower					
Number	4	W	+	2	S
Required Capacity	5065.3	m <sup>3</sup> /Hr·Basin	/	2	unit/Basin
	= 2532.6	m <sup>3</sup> /h	⇒	2600	m <sup>3</sup> /h /Unit
Pressure	65	kPa			
Safety Factor	10	%			
Heat capacity ratio	1.4				
Atmospheric pressure at site elevation	91.234	kPa			
Total inlet pressure	89.234	kPa			
Volume rate of flow at inlet point	49.193	m <sup>3</sup> /min			
Total discharge pressure	156.234	kPa			
Overall adiabatic efficiency	0.65				
Inlet air temperature (min.)	15	°C			
Shaft power	69.552	kW			
Rated Output of Motor	76.508	kW	⇒	90	kW

Air Requirement at Average Flow13/23

B-1 Process Cal. EA&al 15MLD Varthur Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>7. Final Clarifire</b></p>								
<p>[1] <b>Design Condition</b></p>								
<p>(1) Design Wastewater Flow</p>	$Q = 15,000 \text{ m}^3/\text{day}$							
<p>(2) Water Temperature</p>	$T = 20.0 \text{ }^\circ\text{C}$							
<p>(3) MLSS</p>	$X_{ef} = 3,000 \text{ mg/l}$							
<p>(4) SVI</p>	$SVI = 300$							
<p>(5) Sedimentation Velocity</p>	$v = 4.899 \cdot 10^6 \cdot T^{(0.954)} \cdot X_{ef}^{(-1.354)} \cdot SVI^{(-0.77)}$ $= 4.899 \cdot 10^6 \cdot 20.0^{0.954} \cdot 3,000^{-1.354} \cdot 150^{-0.770}$ $= 20.7 \text{ m/day}$							
<p>(6) Surface Overflow Rate required</p>	$S' = v / (1.5 \cdot 1) = \frac{20.7}{(1.5 \cdot 1.0)} = 13.8 \text{ m}^3/\text{m}^2 \cdot \text{day}$ $\rightarrow 12.0 \text{ m}^3/\text{m}^2 \cdot \text{day}$							
<p>[2] <b>Geometry</b></p>								
<p>(1) Surface Area required</p>	$A = 15,000 / 12.0 = 1,250 \text{ m}^2$							
<p>(2) Demensions</p>	<table border="0" style="width: 100%; text-align: center;"> <tr> <td>Diameter</td> <td>Depth</td> <td>Basin</td> </tr> <tr> <td><b>28.5</b></td> <td><b>3.5</b></td> <td><b>2</b></td> </tr> </table>		Diameter	Depth	Basin	<b>28.5</b>	<b>3.5</b>	<b>2</b>
Diameter	Depth	Basin						
<b>28.5</b>	<b>3.5</b>	<b>2</b>						
<p>(3) Actual Surface Area</p>	$S = 28.5^2 \cdot 3.14 / 4 \cdot 2.0 = 1,276 \text{ m}^2$							
<p>(4) Surface Overflow Rate</p>	$S = 15,000 / 1,276 = 11.8 \text{ m}^3/\text{m}^2 \cdot \text{day}$							

B-1 Process Cal. EA&aI 15MLD Varthur, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>8. Chlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 15,000 m <sup>3</sup> /day 625.00 m <sup>3</sup> /h Peak Flow 33,750 m <sup>3</sup> /day 1406.25 m <sup>3</sup> /h
(2) Contact Time	30 min
(3) Type of Chlorine	Cl <sub>2</sub> -GAS
(4) Design Chlorine Dosage Rate	10 mg/L
(5) Required Chlorine per day	Average Daily Flow / 1000 × Design Chlorine Dosage Rate = 150.0 kg/d = 6.25 kg/h
<b>[2] Chlorination Contact Tank</b>	
(1) Volume required	Average Daily Flow / 1440 × Contact Time = 312.5 m <sup>3</sup>
(2) Nos. of lanes	3 lanes
(3) Width of lane	2.00 m
(4) Length of lane	27.00 m
(5) Side Water Depth	2.00 m
(6) Nos. of Tanks	1 tank
(7) Total Width of Tank	6.80 m Approx..
(8) Average Velocity	Decant Flow / 3600 / Width / Depth = 625.00 / 3600 / 2.00 / 2.00 = 0.043 m/sec
(9) Total Volume	Width × Length × Depth × Nos. of lanes × Nos. of Tanks = 2.0 m × 27.0 m × 2.0 m × 3 × 1 = 324 m <sup>3</sup> > 312.5 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Chlorine Dosing Condition	
Operation Dosage Rate -1	DC1 10 mg/L
(2) Chlorine Cylinder	
Type	- Cylindrical Convexsd Container
Cylinder Capacity	Cc 928 kg/cylinder
Average Dosage Rate -1	q1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 150 kg/day
Maximum Dosage Rate -1	q3 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 338 kg/day
Storage day	T More than 15 days
Required Storage Capacity	EC1 D × T = 2,250 kg
Unit Number	EN1 EC1 / Cc = 2.4 cylinders
Maximum Operation Numbers	
Cl <sub>2</sub> -Gas Volatilize Rate	Vr1 ##### @ 20°C Standard temperature
Maximum Dosing Rate	DC1 10 mg/L, Q <sub>T-D</sub> × q3 × 10 <sup>-3</sup> / 24 = 14.06 kg/h
Operation Numbers	EN2 DC1 / Vr1 = 1.8sets
Number	2 W + 2 S
(3) Chlorinator	
Type	Solution Feed Vacuum Type
Number	1 W + 1 S
Operation Dosage Rate -1	Dq1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 337.5 kg/day
Required Dosage Rate	Chlorine -1 : Dq1 / (EN1 × 24) = Minimum 0.00 kg/hr Maximum 14.1 kg/hr
(4) Chlorine Booster Pump	

B-1 Process Cal. EA&al 15MLD Varthur Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

Type	Branchy on the water supply pipe
Water Demand	Water requiamet for mixed Chlori
Chlorinator Discharge	(kg/hr) 1.0 1.5 2.0 2.5 3.0 4.0
Water Demand	(L/min) 15 20 25 30 35 40
Chlorinator Discharge	(kg/hr) 5.0 6.0 10.0 50.0 100.0 200.0
Water Demand	(L/min) 45 50 60 300 600 1,200
Water requiamet	-
For Chlorin	Qp1 Maximum dosage rate 14.1 kg/hr therefore 90 L/min
Booster Pump Type	Single suction volute pump
Number	1 W + 1 S
<b>9. Dechlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 15,000 m <sup>3</sup> /day
(2) Contact Time	10 min
(3) Type of Dechlorine	Sodium Thiosulfate (Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 5H <sub>2</sub> O)
(4) Free Residual Chlorine	1.0 mg/L assumed value
(5) Consumption per day	Average Daily Flow / 1000 × Free Residual Chlorine × 1.75 × 1.5 (safety factor) = 39.4 kg/d = 1.64 kg/h
<b>[2] Dechlorination Contact Tank</b>	
(1) Volume required	Average Flow Rate / 60 × Contact Time = 104.2 m <sup>3</sup>
(2) Width of lane	6.80 m
(3) Length of lane	8.00 m
(4) Side Water Depth	2.00 m
(5) Nos. of Tanks	1 tank
(6) Total Volume	Width × Length × Depth = 6.8 m × 8.0 m × 2.0 m = 109 m <sup>3</sup> > 104.2 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Dechlorine Solution Tank	
Number	2 W + 0 S
Dechlorine concentration	10 %
Gravity of dissolved dechlorine	1.10
Required solution volume	39.38 kg/d × 100 / 10 / 1.10 / 1000 = 0.36 m <sup>3</sup> /d
Volume of Tank	0.200 m <sup>3</sup> /tank (= 0.5 mW × 0.5 mL × 0.8 mH)
Total Volume of Tanks	0.400 m <sup>3</sup> (Duration= 1.12 day)
(2) Mixer for Dechlorine Solution Tank	
Number	2 W + 0 S
(3) Dechlorine Dosing Pump	
Number	2 W + 1 S
Capacity	0.81 m <sup>3</sup> /d / 24 × 1000 / 2 16.78 l/h/unit ⇒ 17 l/h/unit





B-1 Process Cal. EA&aI 15MLD Varthur Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<b>11. Thickened Sludge Sump</b>	
<b>[1] Design Condition</b>	
(1) Inlet Solids	7,538 kg/day
(2) Inlet Sludge Volume	942 m <sup>3</sup> /d
<b>[2] Geometory</b>	
(1) Sludge withdrawl	12 Times/day
(2) Required Sump Volume	79 m <sup>3</sup> /d
(3) Number	2 Basins
(4) Width	3.5 m
(5) Length	4.0 m
(6) Side Water Depth	3.0 m
(7) Actual Sump Volume	$3.5 \times 4.0 \times 3.0 \times 2$ $= 84.0 \text{ m}^3$
<b>[3] Equipment</b>	
(1) Thickened Sludge Transfer Pumps	
Transfer Time	6.00 Hr
Number	2 W + 2 S
Required Capacity	$= \frac{942 \text{ m}^3}{78.5 \text{ m}^3/\text{Hr}} \Rightarrow \frac{6.0}{80} \times 2 \text{ m}^3/\text{Hr}/\text{Unit}$

B-1 Process Cal. EA&al 15MLD Varthur Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<p><b>12. Centrifuge</b>  <b>[1] Design Condition</b>                  (1) Type of Dewatering                  (2) Generated Sludge                  (3) Design Polyelectrolyte Dosage                  (4) Volume of Thickend Sludge                  (5) Consistency of Dewatered Sludge                  (6) Operation Time</p>	<p>Centrifuge                  6,784 kg/day                  Polyelectrolyte 5 kg/t-DS·day                  271.4 m<sup>3</sup>/day                  82 %                  12 hours/day (6 days per week)</p>
<p><b>[2] Volume of Centrifuges</b></p>	<p><math display="block">\frac{\text{Digested Solids}}{\text{Operation Time} \times \text{No.}} \times \text{Operation/week}</math> <math display="block">= \frac{271.4}{12 \times 2} \times \frac{7}{6} = 13.2</math> <p style="text-align: right;">→ 14 m<sup>3</sup>/hour</p> </p>
<p><b>[3] Dewatered Solids</b></p>	<p><math display="block">\text{Digested Sludge} \times (1 + \text{Injection Rate})</math> <math display="block">= 6,784 \times (1 + 0.0050)</math> <math display="block">= 6,818 \text{ kg/day}</math> </p>
<p><b>[4] Dewatered Cake Volume</b></p>	<p><math display="block">\text{Dewatered Solids} \times \frac{100}{100 - \frac{\text{Moisture Content}}{7}} \times \frac{7}{6 \text{ days per week}}</math> <math display="block">= 6,818 \times \frac{100}{100 - 82} \times \frac{7}{6}</math> <math display="block">= 44.19 \text{ t/day}</math> <p>apparent specific gravity 1.00  <math display="block">\frac{44.19}{1.0} = 44.2 \text{ m}^3/\text{day}</math></p> </p>
<p><b>[5] Polyelectrolyte</b>                  (1) Design Polyelectrolyte Dosage                  (2) Required Polyelectrolyte                  (3) Dissolving concentration                  (4) Volume of Polyelectrolyte solution</p>	<p>Polyelectrolyte 5 kg/t-DS·day                  33.92 kg/day                  0.20 %                  16.96 m<sup>3</sup>/day</p>

B-1 Process Cal. EA&aI 15MLD Varthur.Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

<b>[6] Equipment</b>	
(1) Centrifuge	
Capacity	14 m <sup>3</sup> /hr
Number	2 W + 1 S
(2) Centrifuge Feed Pumps	
Capacity	14 m <sup>3</sup> /hr
Number	2 W + 1 S
(3) Polyelectrolyte Dosing Pumps	
Volume of Polyelectrolyte solution	16.96 m <sup>3</sup> /day
Operation Time	12 hours/day (6 days per week)
Safety Factor	1.5
Number	2 W + 1 S
Required Capacity	16.96 m <sup>3</sup> /da × 7 / 6 / 12 / 2
	= 0.82 m <sup>3</sup> /Hr
Specification Capacity	0.82 m <sup>3</sup> /Hr × 1.5
	= 1.237 m <sup>3</sup> /Hr ⇒ 1.30 m <sup>3</sup> /Hr /Unit
(4) Polyelectrolyte dosing System	
Preparation time for solution	3 hr
Required dry polymer	33.92 kg/day × 7 / 6 / 12
	= 3.30 kg/hr
	= 9.89 kg per one batch
Feedong time per one batch	30 min
Capacity of Dry polymer Feeder	20 kg/h
Tanks Dimensions	Width 1.5 m × Length 2.0 m × Depth 2.0 m × 2
	= 12 m <sup>3</sup>
Retention Time of Tank	6.00 m <sup>3</sup> /tank / 0.82 m <sup>3</sup> /Hr / 2
	= 3.639 Hr > 3 Hr
Number	2 W + 0 S

B-1 Process Cal. EA&al 15MLD Varthur.Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

<b>11. Centrifuge Feed Sump</b>	
<b>[1] Design Condition</b>	
(1) Generated Thickend Sludge	6,784 kg/day
(2) Solids Consistency	2.50 %
(3) Volume of Thickened Sludge	$\begin{aligned} & \text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3} \\ = & 6,784 \times \frac{100}{2.50} \times 10^{-3} \\ = & 271 \text{ m}^3/\text{day} \\ = & 11.31 \text{ m}^3/\text{h} \end{aligned}$
(4) Sludge feed flow rate	14 m <sup>3</sup> /h × 2 = 28 m <sup>3</sup> /h
(5) Centrifuge Operation Time	12 hours/day ( 6 days per week)
<b>[2] Geometry</b>	
(1) Basin Dimensions	$\begin{aligned} & \text{Width } 6.0 \text{ m} \times \text{Length } 6.0 \text{ m} \\ & \times \text{Depth } 4.0 \text{ m} \times 2 \\ = & 288.0 \text{ m}^3 \end{aligned}$
<b>[3] Equipment</b>	
(1) Mixers for Centrifuge Feed Sumps	
Required Volume	288.0 m <sup>3</sup>
Number	1 W + 1 S

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Digestion Tank + Centrifugal Dewatering)

Table -1 Input Data

1. Calculation Manner	2	1:Premise that the quality of supernatants are same level removed with inlet sewage 2:Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency	2	1:Total Removal Ratio 2:Outlet Water Quality(input 1or2)
In case of 1 : input data		(%)
In case of 2 : input data	#REF!	(mg/l)
3. Selection of Excess Sludge Generation	2	1:Consideration of Solid Matter Only 2:Consideration of Converting of Solved BOD(input 1or2)
In case of 1 : input data (Sludge generation)		Sludge generation ratio per removal SS(%)
	a	0.4 T2=Q4·S4=(a·S <sub>BOD</sub> +b·S1-c·θ·XA)·Q3/10 <sup>6</sup> · (Excess sludge generation formula)
	b	0.9 a:Converting ratio of solved BOD(mgMLSS/mgBOD)
	c	0.05 b:Converting ratio of SS(mgMLSS/mgSS)
In case of 2 : input data	SBOD	234.50 c:Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)
	XA	3,000 S <sub>BOD</sub> :Solved BOD quality at inlet reactor
	θ	1 XA:MLSS concentration(mg/l)
		θ:Hydraulic retention time(day)


Table -2 Basic Conditions

Sewage Flow and Quality		Sludge Moisture and Recovery Ratio		Digestion Tank Conditions		Chemical Conditions for Dewatering	
·Inlet flow : Q <sub>0</sub> (m <sup>3</sup> /D)	15,000	·Primary sludge moisture ratio : W1(%)	0.0	·Removal ratio in primary tank : A2(%)	0.0	·Content of organics in thickened sludge : A6(%)	75.0
·Inlet quality : S <sub>0</sub> (mg/l)	450	·Excess sludge moisture ratio : W2(%)	99.2	·Recovery ratio in sludge thickener : A3(%)	90.0	·Digestion ratio : A7(%)	#REF!
·Total removal ratio : A1(%)	-	·Thickened sludge moisture ratio : W3(%)	97.5	·Recovery ratio in sludge digester : A4(%)	100.0	·Digestion gas generation : A8(Nm <sup>3</sup> /kgVS)	
·Effluent quality : S1(mg/l)	10.0	·Digested sludge moisture ratio : W4(%)	97.5	·Recovery ratio in dewatering : A5(%)	95.0		
·Sludge generation ratio per removal SS : S1(%)	-	·Dewatered sludge moisture ratio : W5(%)	82.0				

Table -3 Material Balance Calculation

	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	手入力(要取束)	16	17	
Q(m <sup>3</sup> /day)	15,000	15,923	0	15,923	942	14,981	271	671	0	271	0	17	288	36	252	923		14,981	0	
T(t·DS/day)	6,750	7,845	0.000	7,845	7,538	0.150	6,784	0,754	0.000	6,784	0.000	0,034	6,818	6,477	0,341	1,095	1,095		0,150	0,157
S(mg/l)	450	493	0	493	8,000	10	25,000	1,124	0	25,000	0	2,000	23,647	180,000	1,351	1,186			10	
X(T5/T0*100)	100	116.2	0.0	116.2	111.7	2.2	100.5	11.2	0.0	100.5	0.0	0.5	101.0	96.0	5.1	16.2			2.2	2.3

Figure -1 Material Balance Model




Calculation Formula						
·Q0=Input Data	·Q3=Q1-Q2	·Q6=T6*100/(100-W3)	·Q9=Q6	·Q12=Q9+Q11	·Q15=Q7+Q10+Q14	·Q5-1=Q5-Q11
·T0=Q0*S0*10 <sup>-6</sup>	·T3=T0*(100-A2)/100	·T6=(T2+T4)*A3/100	·T9=(T6-T8)*A4/100	·T12=T9+T11	·T15=T7+T10+T14	·T5-1=T5-T11
·S0=Input Data	·S3=T3*10 <sup>-6</sup> /Q3	·S6=10 <sup>-6</sup> *Q3/(100-W3)/100	·S9=T9*10 <sup>-6</sup> /Q9	·S12=T12*10 <sup>-6</sup> /Q12	·S15=T15*10 <sup>-6</sup> /Q15	·S5-1=S5
·Q1=Q0+Q15	·Q4=T4*100/(100-W2)	·Q7=(Q2+Q4)-Q6	·Q10=Q6-Q8-Q9	·Q13=T13*100/(100-W5)		
·T1=T0+T15	·T4=余剰汚泥発生式による	·T7=(T2+T4)-T6	·T10=T6-T8-T9	·T13=T12*A5/100		
·S1=T1*10 <sup>-6</sup> /Q1	·S4=10 <sup>-6</sup> *Q4/(100-W2)/100	·S7=T7*10 <sup>-6</sup> /Q7	·S10=T10*10 <sup>-6</sup> /Q10	·S13=10 <sup>-6</sup> *Q13/(100-W5)/100		
·Q2=T2*100/(100-W1)	·Q5=Q3-Q4*(T3-T5)/T4	·Q8=0	·Q11=T10*A9/A10	·Q14=Q12-Q13		
·T2=T1-T3	·T5=Q5*ST/10 <sup>-6</sup>	·T8=T6*A6*A7/10 <sup>-4</sup>	·T11=Q11*S11/10 <sup>-6</sup>	·T14=T12-T13		
·S2=10 <sup>-6</sup> *Q2/(100-W1)/100	·S5=St	#REF!	·S11=10 <sup>-4</sup> *A10	·S14=T14*10 <sup>-6</sup> /Q14		

Material Balance Sheet SD4

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Sheet  
[15MLD STP]



C-1 Process Cal. EA&al 4MLD Pillaganahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

**Design Condition**

Item	4MLD STP-TSPS				
(1) Design Flow for the year 2049	Flow Rate				
		m3/d	m3/h	m3/s	
	Average Daily	6,000	250	0.069	
	Max Dayly	6,000	250	0.069	
	Max Hourly Peak factor	2.5	15,000	625	0.174
(1) Design Flow for the year 2034	Flow Rate				
		m3/d	m3/h	m3/s	
	Average Daily	4,000	167	0.046	
	Max Dayly	4,000	167	0.046	
	Max Hourly Peak factor	2.5	10,000	417	0.116

**1. Inlet Chamber**

Item	4MLD STP-TSPS			
[1] Design Condition				
(1) Design Flow for the year 2049	Max Hourly	=	15,000	m3/d
		=	0.174	m3/sec
(2) Inlet Pipe				
Pipe Diameter	•	×		
Gradient			%	
Roughness Coefficient	n=	0.013	(Manning Formula)	
Full Pipe Flow Rate			m3/s	
(3) Influent Water Level	+		m	
[2] Geometory				
(1) Number of Basins	1	Basin		
(2) Depth of Basin	0.600	m	Approx.	
(3) Width of Basin	2.100	m	Approx.	
(4) Length of Basin	2.500	m	Approx.	
(5) Volume required of Basin	0.600	×	2.100	×
			2.500	=
				0.5
				m3
(6) Retention Time	0.600	×	2.100	×
			2.500	/
			0.174	×
				1
	=	18.10	sec	
(7) Basin Demensions	Width	2.100	m	×
				Length
				2.500
				m
	×	Depth	0.600	m



C-1 Process Cal. EA&al 4MLD Pillaganahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

**2. Coarse Screen Channel**

Item	4MLD STP-TSPS					
[1] Geometry						
(1) Inlet Gate						
Number	1	Main	+	1	Bypass	
Width	0.400	m				
Height	0.600	m				
Floor Level	+	5.000	m			
Bottom	+	0.000	m			
Influent Water Level	+	0.500	m			
Velocity	0.174	/	0.400	/	0.500	/ 1
where Design Flow for the year 2049	=	0.870	<	1.000	m/sec	OK
Velocity	0.116	/	0.400	/	0.500	/ 1
where Design Flow for the year 2034	=	0.580	<	1.000	m/sec	OK
(2) Screen Channel						
Number	1.0	Main	+	1.0	Bypass	
Width	0.800	m				
Side Water Depth	0.500	m				
Velocity	0.174	/	0.800	/	0.500	/ 1
where Design Flow for the year 2049	=	0.435	≐	0.450	m/sec	OK
Velocity	0.116	/	0.800	/	0.500	/ 1
where Design Flow for the year 2034	=	0.290	<	0.450	m/sec	OK
(3) Channel Dimensions	Width	0.8	m	×	Length	8.5 m
			×	SWD	0.5	m
[3] Equipment						
(1) Inlet Gate						
Number	2	Units				
Dimension	Width	0.4	m	×	Height	0.6 m
Design Water Level		m				
(2) Coarse Screens (Main Channel)						
Number	1	W	+	0	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	0.8	m				
Width of side plate	50	mm				
Side Water Depth	0.5	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.174	/	0.700	/	0.450	/ 1
	× ( 20	+	9 ) /	20		
	=	0.801	≐	0.800	m/sec	OK
Velocity through screen	0.116	/	0.700	/	0.450	/ 1
where Design Flow for the year 2034	× ( 20	+	9 ) /	20		
	=	0.534	<	0.800	m/sec	OK
(3) Coarse Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	50	mm				
Bar Thickness	9	mm				
Channel Width	0.8	m				
Side Water Depth	0.5	m				
Velocity through screen	0.174	/	0.800	/	0.500	/ 1
where Design Flow for the year 2049	× ( 50	+	9 ) /	50		
	=	0.513	<	0.800	m/sec	OK
Velocity through screen	0.116	/	0.800	/	0.500	/ 1
where Design Flow for the year 2034	× ( 50	+	9 ) /	50		
	=	0.342	<	0.800	m/sec	OK

C-1 Process Cal. EA&al 4MLD Pillaganahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

**3. Raw Sewage Sump**

Item	4MLD STP-TSPS	
[2] Geometory		
(1) Raw Sewage Sump		
Number	1	Basin
Dia	7.50	m
Pump Operating Depth	1.000	m
Retention Time whe Design Flow for the year 2049	$( \frac{7.50^2 \times \pi}{4} \times 1.000 ) / 0.174$	$/ 60$ = 4.23 > 3.75 min (=minimum time of one pump cycle) OK
Retention Time whe Design Flow for the year 2034	$( \frac{7.50^2 \times \pi}{4} \times 1.000 ) / 0.116$	$/ 60$ = 6.35 > 3.75 min (=minimum time of one pump cycle) OK
High Water Level	+ 0.000	m
Pump Off Level	+ -1.000	m
[3] Equipment		
(1) Sewage Pumps 1		
Number	1	W + 1 S
Bore Diameter	250	mm
Discharge Flow : Q whe Design Flow for the year 2034	$0.116 \times 3600$	$/ 1.0$ = 418 $\Rightarrow$ 418 m <sup>3</sup> /Hr
Total Head	15.0	m
(2) Sewage Pumps 2		
Number	W	+ S
Bore Diameter	mm	
Discharge Flow : 0.5 whe Design Flow for the year 2034		$\Rightarrow$ m <sup>3</sup> /Hr
Total Head	m	

C-1 Process Cal. EA&al 4MLD Pillaganahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

Item	4MLD STP																																																		
<b>1. STP Design Condition</b>																																																			
(1) Design Flow Rate	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th style="text-align: center;">m3/d</th> <th style="text-align: center;">m3/h</th> <th style="text-align: center;">m3/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td style="text-align: center;">4,000</td> <td style="text-align: center;">166.67</td> <td style="text-align: center;">0.046</td> </tr> <tr> <td>Max Daily</td> <td style="text-align: center;">4,000</td> <td style="text-align: center;">166.67</td> <td style="text-align: center;">0.046</td> </tr> <tr> <td>Max Hourly Peak factor 2.5</td> <td style="text-align: center;">10,000</td> <td style="text-align: center;">416.67</td> <td style="text-align: center;">0.116</td> </tr> </tbody> </table>											m3/d	m3/h	m3/s	Average Daily	4,000	166.67	0.046	Max Daily	4,000	166.67	0.046	Max Hourly Peak factor 2.5	10,000	416.67	0.116																									
	m3/d	m3/h	m3/s																																																
Average Daily	4,000	166.67	0.046																																																
Max Daily	4,000	166.67	0.046																																																
Max Hourly Peak factor 2.5	10,000	416.67	0.116																																																
(2) Design Water Quality	<p style="text-align: right;">Unit: mg/L</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th colspan="2">TP</th> </tr> <tr> <th>NH<sub>4</sub>-N</th> <th>Org-N</th> <th>NOx-N</th> <th>D-P</th> <th>P-P</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td style="text-align: center;">350</td> <td style="text-align: center;">800</td> <td style="text-align: center;">450</td> <td style="text-align: center;">45.5</td> <td style="text-align: center;">17.5</td> <td style="text-align: center;">7</td> <td style="text-align: center;">5</td> <td style="text-align: center;">2</td> </tr> <tr> <td>Outlet</td> <td style="text-align: center;">10</td> <td style="text-align: center;">50</td> <td style="text-align: center;">10</td> <td style="text-align: center;">1</td> <td style="text-align: center;">0</td> <td style="text-align: center;">9</td> <td style="text-align: center;">1</td> <td style="text-align: center;">1</td> </tr> <tr> <td>Removal rate</td> <td style="text-align: center;">97.1%</td> <td style="text-align: center;">93.7%</td> <td style="text-align: center;">97.8%</td> <td colspan="3" style="text-align: center;">85.7%</td> <td colspan="2" style="text-align: center;">71.4%</td> </tr> </tbody> </table>											BOD	COD	SS	T-N			TP		NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P	Inlet	350	800	450	45.5	17.5	7	5	2	Outlet	10	50	10	1	0	9	1	1	Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%	
	BOD	COD	SS	T-N			TP																																												
				NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P																																											
Inlet	350	800	450	45.5	17.5	7	5	2																																											
Outlet	10	50	10	1	0	9	1	1																																											
Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%																																												
<b>2. Inlet Chamber</b>																																																			
<b>[1] Design Condition</b>																																																			
(1) Design Flow Rate	Max Hourly	=	10,000	m3/day																																															
		=	0.116	m3/sec																																															
<b>[2] Geometry</b>																																																			
(1) Number of Basins	1	Basin																																																	
(2) Depth of Basin	1.000	m																																																	
(3) Width of Basin	1.800	m																																																	
(4) Length of Basin	1.500	m																																																	
(5) Volume required of Basin	1.000	×	1.800	×	1.500	=	1.2	m3																																											
(6) Retention Time	1.000	×	1.800	×	1.500	/	0.116	×	1																																										
	=	23.28	sec																																																
(7) Basin Dimensions	Width	1.800	m	×	Length	1.500	m																																												
	×	Depth	1.000	m																																															

C-1 Process Cal. EA&al 4MLD Pillaganahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Wastewater Flow	$\begin{aligned} \text{Max Hourly} &= 10,000 \text{ m}^3/\text{d} \\ &= 0.116 \text{ m}^3/\text{sec} \end{aligned}$
[2] Geometory	
(1) Inlet Gate	
Number	1 Main + 1 Bypass
Width	0.400 m
Height	0.600 m
Floor Level	+ 2.000 m
Bottom	+ 0.000 m
Influent Water Level	+ 0.500 m
Velocity	$\begin{aligned} &0.116 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 1 \\ = &0.580 \text{ } \div \quad 1.000 \text{ m/sec} \end{aligned}$
(2) Screen Channel	
Number	1 Main + 1 Bypass
Width	0.800 m
Side Water Depth	0.400 m
Velocity	$\begin{aligned} &0.116 \text{ } \swarrow \quad 0.800 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 1 \\ = &0.363 \text{ } \div \quad 0.450 \text{ m/sec} \end{aligned}$
(3) Channel Dimensions	$\begin{aligned} \text{Width} &0.8 \text{ m} \times \text{Length} \quad 6.0 \text{ m} \\ &\times \text{SWD} \quad 0.4 \text{ m} \quad (\text{Freeboard } 0.3\text{m}) \end{aligned}$
[3] Equipment	
(1) Inlet Gate	
Number	1 W + 1 S
Dimension	Width 0.4 m × Height 0.60 m
Design Water Level	2.00 m
(2) Fine Screens (Main Channel)	
Number	1 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	0.8 m
Width of side plate	50 mm
Side Water Depth	0.4 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	$\begin{aligned} &0.116 \text{ } \swarrow \quad 0.700 \text{ } \swarrow \quad 0.350 \text{ } \swarrow \quad 1 \\ &\times ( \quad 6 \quad + \quad 2 \quad ) / \quad 6 \\ = &0.631 < \quad 0.800 \text{ m/sec} \end{aligned}$
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	0.8 m
Side Water Depth	0.4 m
Velocity through screen	$\begin{aligned} &0.116 \text{ } \swarrow \quad 0.800 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 1 \\ &\times ( \quad 20 \quad + \quad 9 \quad ) / \quad 20 \\ = &0.526 < \quad 0.800 \text{ m/sec} \end{aligned}$

C-1 Process Cal. EA&al 4MLD Pillaganahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>4. Grit Chamber</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Max Hourly = 10,000 m <sup>3</sup> /day = 0.116 m <sup>3</sup> /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0111 m/sec = 960 m <sup>3</sup> /m <sup>2</sup> /day
(4) Average Velocity	0.3 m/sec
<b>[2] Grit Chamber</b>	
(1) Surface Area required	0.116 / 0.0111 = 10.45 m <sup>2</sup>
(2) Number of Basins	1 S + 1 W
(3) Surface Area required/Basin	10.45 / 1 = 10.45 m <sup>2</sup>
(4) Length of Basin	10.45 ^0.5 = 3.2 m → 3.5 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.116 × 60 sec / 1 = 7.0 m <sup>3</sup>
(7) Depth required	7.0 / 3.5 / 3.5 = 0.568 m
(8) Basin Dimensions	Width 3.5 m × Length 3.5 m × Depth 0.6 m (Freeboard 0.3m)
(9) Retention Time	3.5 × 3.5 × 0.6 / 0.116 × 1 = 60.00 sec
(10) Surface Overflow Rate at Peak Flow	10,000 / 3.5 / 3.5 / 1 = 816.326531 < 960 m <sup>3</sup> /m <sup>2</sup> /day
<b>[3] Parshall Flume</b>	
(1) Design Flow Rate	Q= 116.000 l/sec
(2) Throat width	W= 0.450 m
(3) Water depth Ha	Ha= ( Q / 2264 / W ) <sup>2/3</sup> Ha= 0.235 m
(4) Crest Level	+ 75.400 m ≐ Minimum water level at downstream channel
(5) Water level at the crest	+ 75.635 m
(6) Channel bottom level	+ m
(7) Upstream Channel width	1.500 m
(8) SWD of Upstream Channel	0.700 m
(9) Average velocity at upstream channel	0.110 m/sec
(10) Total Length of channel	10.000 m
<b>[4] Inlet Weir Gate</b>	
(1) Number	2 Units
(2) Weir Width	0.400 m
(3) Stroke	0.450 m
(4) Overflow Height	0.400 m
(5) Overflow Height (actual)	( 0.116 / 1.840 / 0.400 / 2 ) <sup>2/3</sup> = 0.184 < 0.400 m

**STP Process Calculation Supporting Report 12.2.3**

<b>5. Reactor</b>																																																								
<b>[1] Design Condition</b>																																																								
(1) Design Wastewater Flow	Q = 4,000 m <sup>3</sup> /day (summer) Q' = 4,000 m <sup>3</sup> /day (Winter)																																																							
(2) Design Sewage Quality																																																								
Inlet BOD	350 mg/l																																																							
Outlet BOD	10.0 mg/l																																																							
Inlet S-BOD	235 mg/l assumed as 67% of BOD																																																							
Inlet COD	800 mg/l																																																							
Inlet bCOD : S <sub>0</sub>	578 mg/l																																																							
Inlet nbCOD	223 mg/l																																																							
bCOD/BOD	1.65																																																							
Inlet S-COD : sCOD	271 mg/l																																																							
Inlet rbCOD	231 mg/l bCOD*40%																																																							
Inlet sbCOD	347 mg/l bCOD*60%																																																							
Outlet S-COD : nbsCODE	40 mg/l																																																							
Inlet nbpCOD : nbpCOD	183 mg/l = TCOD-bCOD-nbsCODE																																																							
Inlet SS	450 mg/l																																																							
Inlet VSS	383 mg/l assumed as 85% of TSS																																																							
: VSS <sub>COD</sub>	1.38 gCOD/gVSS = TCOD-sCOD/VSS																																																							
: nbVSS	131.96 gnbVSS/m <sup>3</sup> = nbpCOD/VSS <sub>COD</sub>																																																							
: iTSS	67.50 gnbVSS/m <sup>3</sup> = TSS-VSS																																																							
Inlet T-N	70 mg/l																																																							
Inlet TKN	70 mg/l																																																							
Inlet NH <sub>4</sub> -N	45 mg/l																																																							
Inlet T-P	7 mg/l																																																							
Inlet D-P	5 mg/l																																																							
Inlet Alkalinity as CaCO <sub>3</sub>	380 mg/l																																																							
Outlet Kjeldahl N	1.0 mg/l																																																							
Outlet NH <sub>4</sub> -N	1.0 mg/l																																																							
Outlet NO <sub>3</sub> -N	9.0 mg/l																																																							
Outlet T-P	2 mg/l																																																							
Outlet D-P	1 mg/l																																																							
(3) Water Temperature	T = 20.0 °C																																																							
(4) Safety Factor for Nitrogen	SF = 1.5																																																							
(5) Return Sludge Concentration	R <sub>s</sub> = 8,000 mg/l																																																							
(6) MLSS MLVSS	X <sub>TSS</sub> = 3,000 mg/l																																																							
(7) DO in the Reactor	2 mg/L																																																							
<b>[2] Design Value for perfect Nitrification of Nitrification Process</b>																																																								
(1) Activated sludge design kinwtic coefficients at 20°C																																																								
	<table border="1"> <thead> <tr> <th>Coefficient</th> <th>Unit</th> <th>COD oxidatio</th> <th>NH<sub>4</sub> oxidatio</th> <th>NO<sub>2</sub> oxidatio</th> </tr> </thead> <tbody> <tr> <td>μ<sub>max</sub></td> <td>gVSS/gVSS · d</td> <td>6.000</td> <td>0.900</td> <td>1.000</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>mg/L</td> <td>8.000</td> <td>0.500</td> <td>0.200</td> </tr> <tr> <td>Y</td> <td>gVSS/g substrate oxidized</td> <td>0.450</td> <td>0.150</td> <td>0.050</td> </tr> <tr> <td>b</td> <td>gVSS/gVSS · d</td> <td>0.120</td> <td>0.170</td> <td>0.170</td> </tr> <tr> <td>fd</td> <td>unitless</td> <td>0.150</td> <td>0.150</td> <td>0.150</td> </tr> <tr> <td>K<sub>O<sub>2</sub></sub></td> <td>mg/L</td> <td>0.200</td> <td>0.500</td> <td>0.900</td> </tr> <tr> <td>θ Value</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>μ<sub>max</sub></td> <td>unitless</td> <td>1.070</td> <td>1.072</td> <td>1.063</td> </tr> <tr> <td>b</td> <td>unitless</td> <td>1.040</td> <td>1.029</td> <td>1.029</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>unitless</td> <td>1.000</td> <td>1.000</td> <td>1.000</td> </tr> </tbody> </table> <p>Wastwater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF &amp; EDDY/AECOM)</p>	Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio	μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200	Y	gVSS/g substrate oxidized	0.450	0.150	0.050	b	gVSS/gVSS · d	0.120	0.170	0.170	fd	unitless	0.150	0.150	0.150	K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900	θ Value					μ <sub>max</sub>	unitless	1.070	1.072	1.063	b	unitless	1.040	1.029	1.029	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000
Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio																																																				
μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200																																																				
Y	gVSS/g substrate oxidized	0.450	0.150	0.050																																																				
b	gVSS/gVSS · d	0.120	0.170	0.170																																																				
fd	unitless	0.150	0.150	0.150																																																				
K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900																																																				
θ Value																																																								
μ <sub>max</sub>	unitless	1.070	1.072	1.063																																																				
b	unitless	1.040	1.029	1.029																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000																																																				
(2) μ <sub>AOB</sub>	μ <sub>AOB</sub> = 0.3100 g/g · d = μ <sub>max, AOB</sub> [S <sub>NH<sub>4</sub></sub> / (S <sub>NH<sub>4</sub></sub> + K <sub>NH<sub>4</sub></sub> )] [S <sub>O</sub> / (S <sub>O</sub> + K <sub>O, AOB</sub> )] - b <sub>AOB</sub>																																																							
μ <sub>max, AOB, T</sub>	μ <sub>max, AOB, T</sub> = 0.9000 g/g · d = μ <sub>max</sub> * 1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900																																																							
b <sub>AOB, T</sub>	b <sub>AOB, T</sub> = 0.1700 = b * 1.029 <sup>(T-20)</sup> b at 20°C = 0.170																																																							
S <sub>NH<sub>4</sub></sub>	S <sub>NH<sub>4</sub></sub> = 1.0000 mg/l																																																							
DO	DO = 2.0000 mg/l																																																							
K <sub>O, AOB</sub>	K <sub>O, AOB</sub> = 0.5000 mg/l																																																							

C-1 Process Cal. EA&al 4MLD Pillaganahalli Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

(2) Design SRT	SRT= 4.8387 day = $1/\mu_{AOB} \times SF$ ⇒ 5.0000 day
(3) Biomass production	
P <sub>X,VSS</sub>	1250.815 kg/d = P <sub>X,bio</sub> +Q(nbVSS)
P <sub>X,TSS</sub>	1648.400 kg/d = P <sub>X,bio</sub> /0.85+Q(nbVSS)+Q(TSS <sub>0</sub> -VSS <sub>0</sub> )+5*Q*Al
S	S= 0.4507 mg/l = $Ks[1+b_H(SRT)]/[SRT(\mu_m-b_H)-1]$
b <sub>H</sub>	b <sub>H</sub> = 0.1200 = $b*1.04^{(T-20)}$ b at 20°C = 0.120
Y <sub>H</sub>	Y <sub>H</sub> = 0.4500 gVSS/g bCOD
μ <sub>m,T</sub>	μ <sub>m,T</sub> = 6.0000 g/g·d = $\mu_{max} * 1.04^{(T-20)}$ μ max at 20°C = 6.000
Y <sub>n</sub>	Y <sub>n</sub> = 0.150 gVSS/g Nox
NO <sub>x</sub>	NO <sub>x</sub> = 47.400 mg/l
P <sub>X,bio,VSS</sub>	P <sub>X,bio,VSS</sub> = 722.980 kg VSS/d = $Q \cdot Y_H(S_0-S)/[1+b_H(SRT)] + f_d \cdot b_H \cdot QY_H(S_0-S)SRT/[1+b_H(SRT)]$ + QY <sub>n</sub> (Nox)[2+bAOB(SRT)] 649.180 = $Q \cdot Y_H(S_0-S)/[1+b_H(SRT)]$ 58.426 = $f_d \cdot b_H \cdot QY_H(S_0-S)SRT/[1+b_H(SRT)]$ 15.373 = $QY_n(Nox)[1+b_{AOB}(SRT)]$
NO <sub>x</sub>	NO <sub>x</sub> = 47.311 mg/l = $TKN-N_e - 0.12P_{X,bio}/Q$
(4) Required Aeration Tank Volume	
V <sub>a</sub>	V <sub>a</sub> = 2,747 m <sup>3</sup>
τ	τ = 16.48 hr = V <sub>a</sub> /Q × 24 ⇒ 18.00 hr
X <sub>VSS</sub> · V <sub>a</sub>	X <sub>VSS</sub> · V <sub>a</sub> = 6,254 kg VSS = P <sub>X,VSS</sub> · SRT
X <sub>TSS</sub> · V <sub>a</sub>	X <sub>TSS</sub> · V <sub>a</sub> = 8,242 kg TSS = P <sub>X,TSS</sub> · SRT
F/M	F/M= 0.224 kgBOD/kgMLVSS
FractionVSS	FractionVSS= 0.759
MLVSS	MLVSS= 2276 mg/L
(5) BODloading	BODloading= 0.510 kg/m <sup>3</sup> ·d
(6) Observed Yield	
Y <sub>obs,TSS</sub>	Y <sub>obs,TSS</sub> = 1.178 gTSS/gBOD
Y <sub>obs,VSS</sub>	Y <sub>obs,VSS</sub> = 0.894 gVSS/gBOD
bCODremoved	bCODremov= 2,308 kg/d
(7) effluent NO <sub>2</sub> -N	NO <sub>2</sub> -N= 0.2315 mg/l = $Ks[1+b_{NOB}(SRT)]/[SRT(\mu_{NOB}-b_{NOB})-1]$
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700 = $b*1.029^{(T-20)}$ b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 1.0000 g/g·d = $\mu_{max} * 1.04^{(T-20)}$ μ max at 20°C = 1.000
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.6897 g/g·d = $\mu_{max,NOB}[S_0/(S_0+K_{O2,NOB})]$
	S <sub>0</sub> = 2.000 mg/l
	K <sub>O2,NOB</sub> = 0.900 mg/l
(8) effluent NH <sub>4</sub> -N	NH <sub>4</sub> -N= 0.5286 mg/l = $Ks[1+b_{NOB}(SRT)]/[SRT(\mu_{NOB}-b_{NOB})-1]$
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700 = $b*1.029^{(T-20)}$ b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 0.9000 g/g·d = $\mu_{max} * 1.072^{(T-20)}$ μ max at 20°C = 0.900
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.7200 g/g·d = $\mu_{max,NOB}[S_0/(S_0+K_{O2,NOB})]$
	S <sub>0</sub> = 2.000 mg/l
	K <sub>O2,NOB</sub> = 0.500 mg/l
(9) Ratio of Return Sludge	8,000*Rr/(1+Rr)= 3,000 mg/L 3,000/(8,000-3,000)= 0.60 Rr = 0.60

**STP Process Calculation Supporting Report 12.2.3**

[3] Design for Nitrification and Denitrification Process																					
(1) Active biomass concentration	$X_b = \frac{Q \cdot (SRT) \cdot V \cdot Y_H \cdot (S_0 - S)}{1 + b_H(SRT)}$ $= 1,181.47 \text{ mg/l}$																				
(2) IR ratio	$IR = \frac{NO_x}{Ne} - 1.0 - R$ $= 3.66$																				
(3) The amount of NO <sub>3</sub> -N fed to the anoxic tank	$Nox \text{ feed} = (IR + R) \cdot Q \cdot Ne$ $= 153,242.44 \text{ kg/d}$																				
(4) The anoxic tank volume	$V_{nor} = 275 \text{ m}^3 = V_a \times 10\%$ $V_{nor} = 833 \text{ m}^3 \quad \tau_{DN} = 5.000 \text{ h}$																				
(5) F/M <sub>b</sub>	$F/M_b = 1.42 \text{ g/g} \cdot \text{d}$																				
(6) Fraction of rbCOD	$40.00\% = \frac{rbCOD}{bCOD}$																				
	<table border="1"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b<sub>0</sub></th> <th>b<sub>1</sub></th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>	Percent rdCOD(%)	SDNR equation coefficients		b <sub>0</sub>	b <sub>1</sub>	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162
Percent rdCOD(%)	SDNR equation coefficients																				
	b <sub>0</sub>	b <sub>1</sub>																			
10	0.186	0.078																			
20	0.213	0.118																			
30	0.235	0.141																			
40	0.242	0.152																			
50	0.270	0.162																			
(8) SDNR <sub>b</sub>	$SDNR_b = 0.296 \text{ g/g} \cdot \text{d} = b_0 + b_1 [\ln(F/M_b)]$ $b_0 = 0.242$ $b_1 = 0.152$																				
(8) SDNR	$SDNR = 0.110 \text{ g/g} \cdot \text{d} = SDNR_b (MLVSS_b / MLVSS)$ $SDNR_{adj} = 0.212 \text{ g/g} \cdot \text{d} = SDNR_i - 0.029 \ln(F/M_b) - 0.012 \quad IR=3-4$ $= SDNR_i - 0.0166 \ln(F/M_b) - 0.078 \quad IR=2$ $SDNR_t = 0.296 \text{ g/g} \cdot \text{d} = SDNR_b \cdot \theta^{(4-20)} \quad \theta = 1.026$																				
(9) NO <sub>r</sub>	$NO_r = 208,397.23 \text{ kg/d} = N_{nox} \cdot SDNR \cdot X_b$ $> Nox \text{ feed} = 153,242 \text{ kg/d}$																				
(10) Alkalinity to be added to maintain pH7	$-108.33 \text{ mg/l}$ $\text{Influent Alk} = 380.00 \text{ mg/l}$ $\text{Alk used} = 338.44 \text{ mg/l} = 7.14 \times Nox$ $\text{Alk produced} = 136.77 \text{ mg/l} = 3.57 \times (NO_x - NO_{xe})$ $\text{Alk to maint} = 70.00 \text{ mg/l}$																				
[4] Design of Phosphorous Removal Process																					
(1) Removal T-P	$3.13 \text{ mg/l}$																				
P in waste sludge	$px = 1.00\%$																				
Generated waste sludge	$Px_{VSS} = 1250.815 \text{ kg/d}$																				
Rwmoval Phosphorus	$12.50815211 \text{ kg/d}$																				
(2) Effluent T-P without Al	$3.87 \text{ mg/l}$																				
(3) Required Al to initial soluble phosphorous ratio	$1.00 \text{ mol/mol}$																				
(4) Required Al dosing rate	$3.48 \text{ mg/l} \text{ as Al}$																				
	$42.98 \text{ mg/l} \text{ as crystal, Al}_2(\text{SO}_4)_3 \cdot 18\text{H}_2\text{O}$																				
(5) Required Aluminium Sulphate	$171.91 \text{ kg/d}$																				
(6) Required Aluminium Sulphate sol 10%	$1.64 \text{ m}^3/\text{d}$																				
	$68.22 \text{ L/H}$																				
(7) Additional sludge	$69.69 \text{ kg/d}$																				



**STP Process Calculation Supporting Report 12.2.3**

<b>[5] Reactor</b>																																																																				
(1) Total volume of Aeration Basins	$V_A = Q \cdot \theta_a / 24$ = 3,000 m <sup>3</sup>																																																																			
(2) Total volume of Anoxic Basins	$V_{DN} = Q \cdot \theta_{DN} / 24$ = 833 m <sup>3</sup>																																																																			
	<table border="1"> <thead> <tr> <th rowspan="2">Item</th> <th rowspan="2">Volume required</th> <th colspan="2">Retention Time required</th> <th rowspan="2">Ratio of Volume</th> </tr> <tr> <th>Summer</th> <th>Winter</th> </tr> <tr> <th colspan="2">unit</th> <th>m<sup>3</sup></th> <th>hour</th> <th>hour</th> <th></th> </tr> </thead> <tbody> <tr> <td>Anaerobic</td> <td><math>V_{AN}</math></td> <td>250</td> <td>1.50</td> <td>1.50</td> <td>0.30</td> </tr> <tr> <td>Anoxic</td> <td><math>V_{DN}</math></td> <td>833</td> <td>5.00</td> <td>5.00</td> <td>1.00</td> </tr> <tr> <td>Aerobic</td> <td><math>V_A</math></td> <td>3,000</td> <td>18.00</td> <td>18.00</td> <td>3.60</td> </tr> <tr> <td>Total</td> <td>V</td> <td>4,083</td> <td>24.50</td> <td>24.50</td> <td></td> </tr> </tbody> </table>	Item	Volume required	Retention Time required		Ratio of Volume	Summer	Winter	unit		m <sup>3</sup>	hour	hour		Anaerobic	$V_{AN}$	250	1.50	1.50	0.30	Anoxic	$V_{DN}$	833	5.00	5.00	1.00	Aerobic	$V_A$	3,000	18.00	18.00	3.60	Total	V	4,083	24.50	24.50																															
Item	Volume required			Retention Time required			Ratio of Volume																																																													
		Summer	Winter																																																																	
unit		m <sup>3</sup>	hour	hour																																																																
Anaerobic	$V_{AN}$	250	1.50	1.50	0.30																																																															
Anoxic	$V_{DN}$	833	5.00	5.00	1.00																																																															
Aerobic	$V_A$	3,000	18.00	18.00	3.60																																																															
Total	V	4,083	24.50	24.50																																																																
<b>[6] Geometry</b>																																																																				
(1) Basin Dimensions	Width      Length      Depth      Basins 8.0            51.0            5.5            2																																																																			
Cross Section	8.0*5.5 = 44.0 m <sup>2</sup> /Basin																																																																			
Hantzsch Subtraction	= 1.0 m <sup>2</sup> /Basin																																																																			
after Subtraction	44.0-1.0 = 43.0 m <sup>2</sup> /Basin																																																																			
Total Volume	43.0*51.0 = 2,193 m <sup>2</sup> /Basin      4,386 m <sup>3</sup> /Total																																																																			
(2) Partition of Basin	<table border="1"> <thead> <tr> <th>Item</th> <th>unit</th> <th>Anaerobic</th> <th>Anoxic</th> <th>Aerobic</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Cross Section</td> <td>m<sup>2</sup></td> <td colspan="3">43.0</td> <td></td> </tr> <tr> <td>Length required</td> <td>m</td> <td>2.9</td> <td>9.7</td> <td>34.9</td> <td>47.5</td> </tr> <tr> <td>Volume required per Basin</td> <td>m<sup>3</sup></td> <td>125</td> <td>417</td> <td>1,500</td> <td>2,042</td> </tr> <tr> <td>Total Volume required</td> <td>m<sup>3</sup></td> <td>250</td> <td>833</td> <td>3,000</td> <td>4,083</td> </tr> <tr> <td>Actual Cross Section</td> <td>m<sup>2</sup></td> <td>43.0</td> <td>43.0</td> <td>43.0</td> <td></td> </tr> <tr> <td>Actual Length</td> <td>m</td> <td>4.0</td> <td>10.0</td> <td>37.0</td> <td>51.0</td> </tr> <tr> <td>Actual Volume per Basin</td> <td>m<sup>3</sup></td> <td>172</td> <td>430</td> <td>1,591</td> <td>2,193</td> </tr> <tr> <td>Actual Total Volume</td> <td>m<sup>3</sup></td> <td>344</td> <td>860</td> <td>3,182</td> <td>4,386</td> </tr> <tr> <td>Actual Ratio of Volume</td> <td></td> <td>0.40</td> <td>1.00</td> <td>3.70</td> <td></td> </tr> <tr> <td>Actual Retention Time</td> <td>hour</td> <td>2.06</td> <td>5.16</td> <td>19.09</td> <td>26.31</td> </tr> </tbody> </table>	Item	unit	Anaerobic	Anoxic	Aerobic	Total	Cross Section	m <sup>2</sup>	43.0				Length required	m	2.9	9.7	34.9	47.5	Volume required per Basin	m <sup>3</sup>	125	417	1,500	2,042	Total Volume required	m <sup>3</sup>	250	833	3,000	4,083	Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0		Actual Length	m	4.0	10.0	37.0	51.0	Actual Volume per Basin	m <sup>3</sup>	172	430	1,591	2,193	Actual Total Volume	m <sup>3</sup>	344	860	3,182	4,386	Actual Ratio of Volume		0.40	1.00	3.70		Actual Retention Time	hour	2.06	5.16	19.09	26.31	
Item	unit	Anaerobic	Anoxic	Aerobic	Total																																																															
Cross Section	m <sup>2</sup>	43.0																																																																		
Length required	m	2.9	9.7	34.9	47.5																																																															
Volume required per Basin	m <sup>3</sup>	125	417	1,500	2,042																																																															
Total Volume required	m <sup>3</sup>	250	833	3,000	4,083																																																															
Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0																																																																
Actual Length	m	4.0	10.0	37.0	51.0																																																															
Actual Volume per Basin	m <sup>3</sup>	172	430	1,591	2,193																																																															
Actual Total Volume	m <sup>3</sup>	344	860	3,182	4,386																																																															
Actual Ratio of Volume		0.40	1.00	3.70																																																																
Actual Retention Time	hour	2.06	5.16	19.09	26.31																																																															
<b>[7] Equipment</b>																																																																				
(1) Ras Pumps																																																																				
Ras Ratio	60%																																																																			
Required Capacity	4,000 m <sup>3</sup> /day × 60% / 24 / 2																																																																			
	= 50 m <sup>3</sup> /Hr ⇒ 50 m <sup>3</sup> /Hr																																																																			
Number	2 Work																																																																			
	2 Standby																																																																			
(2) Circulation Pumps																																																																				
Ras Ratio	366%																																																																			
Required Capacity	4,000 m <sup>3</sup> /day × 366% / 24 / 4																																																																			
	= 152 m <sup>3</sup> /Hr ⇒ 155 m <sup>3</sup> /Hr																																																																			
Number	4 Work																																																																			
	2 Standby																																																																			
(3) SAS Pumps																																																																				
Excess Sludge	217 m <sup>3</sup> /day																																																																			
Sludge withdraw	12 Times/day																																																																			
Running Time	0.5 Hr/Time																																																																			
Required Capacity	217 m <sup>3</sup> /day / 12 / 0.5 / 2																																																																			
	= 18.08 m <sup>3</sup> /Hr ⇒ 18 m <sup>3</sup> /Hr																																																																			
Number	2 Work																																																																			
	2 Standby																																																																			

C-1 Process Cal. EA&al 4MLD Pillaganahalli Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

(4) Alum Solution Tank										
Number	2	W	+	0	S					
Alum concentration as crystal	10	%								
Gravity of dissolved dechlorine	1.05									
Required solution volume	171.91	kg / d		×	100	/	10	/	1.05 / 1000	
	=	1.64							m3/d	
Volume of Tank	1.0								m3/tank	
Total Volume of Tanks	2.0						(Duration=	1.22	day)	
(5) Mixer for Alum Solution Tank										
Number	2	W	+	0	S					
(6) Alum Dosing Pump										
Number	2	W	+	1	S					
Capacity	1.64	m3/d /		24	×	1000	/	2	×	2
	68.22	l/h/unit	⇒		70	l/h/unit				

**STP Process Calculation Supporting Report 12.2.3**

<b>6. Air Requirement at Average Flow</b>	
[1] Design Condition	
(1) AOR	AOR = 1,731 kg/day = 72.1 kg/h
Q <sub>in</sub> : Design Average Flow m <sup>3</sup> /d	4,000
Inlet bCOD : S <sub>0</sub>	578 mg/l
S=	S= 0.451 mg/l
Nox=	Nox 47.400 mg/l
P <sub>X,bio</sub> =	P <sub>X,b</sub> 707.6 kg VSS/d does not include nitrifying bacteria
R <sub>0</sub> =	R <sub>0</sub> = Q(S <sub>0</sub> -S-k(NOx-NOx <sub>e</sub> ))-1.42P <sub>X,bio</sub> +4.57Q·NOx
R <sub>0</sub> =	R <sub>0</sub> = 1,731 kg O <sub>2</sub> /d
	k= 2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{\text{AOR} \times C_s \cdot a \times 1.024^{20-T}}{\alpha \times F (\beta \cdot C_{sW}/C_s \cdot (P_b/P_a)a - C_A)}$
	C <sub>s</sub> : Saturated DO at sea level and 20 °C 9.09 mg/L
	C <sub>sW</sub> : Saturated DO at sea level and operating Temperature 9.09 mg/L at 20 °C
	20-T : 0.0 1.024 <sup>20-T</sup> : 1.0000
	C <sub>A</sub> : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1+0.40D <sub>j</sub> /P <sub>a</sub> 1.19357
	D <sub>j</sub> : Tank Liquid Depth 5.00 m
	P <sub>a</sub> : Standard absolute pressure at s 10.332 m
	P <sub>b</sub> : Absolute pressure at Plant Site Elevation m
	P <sub>b</sub> /P <sub>a</sub> : exp[-gM(z <sub>b</sub> -z <sub>a</sub> )/R·T] 0.900
	g : Acceleration due to Gravity 9.80665 m/s <sup>2</sup>
	M : Mole of Air 28.97 kg/kg-mole
	z <sub>b</sub> : Plant Site Elevation 900 m
	z <sub>a</sub> : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 293.15 Kelvin
	α : relative Transfer Rate to clean Water 0.65
	β : relative DO Saturation to clean Water 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{18,776}{4.2591} = 4,408.40 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Standard O <sub>2</sub> required at Field Conditions per Basin =	2,204 kg/day
(5) SOTE for the above Effective Aeration Depth	28.0 %
(6) Fraction of O <sub>2</sub> in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	15%
(9) Air required at Field Conditions per Basins	= 32,418 m <sup>3</sup> /day = 1,350.7 m <sup>3</sup> /hr
[2] Equipment	

C-1 Process Cal EA&al 4MLD Pillaganahalli Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

(1) Air Blower					
Number	2	W	+	1	S
Required Capacity	1350.7	m <sup>3</sup> /Hr·Basin	/	1	unit/Basin
	= 1350.7	m <sup>3</sup> /h	⇒	1400	m <sup>3</sup> /h /Unit
Pressure	65	kPa			
Safety Factor	10	%			
Heat capacity ratio	1.4				
Atmospheric pressure at site elevation	91.234	kPa			
Total inlet pressure	89.234	kPa			
Volume rate of flow at inlet point	26.488	m <sup>3</sup> /min			
Total discharge pressure	156.234	kPa			
Overall adiabatic efficiency	0.65				
Inlet air temperature (min.)	15	°C			
Shaft power	37.451	kW			
Rated Output of Motor	41.196	kW	⇒	45	kW

Air Requirement at Average Flow13/21

C-1 Process Cal. EA&al 4MLD Pillaganahalli Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>7. Final Clarifire</b></p> <p><b>[1] Design Condition</b></p> <p>(1) Design Wastewater Flow</p> <p>(2) Water Temperature</p> <p>(3) MLSS</p> <p>(4) SVI</p> <p>(5) Sedimentation Velocity</p> <p>(6) Surface Overflow Rate required</p> <p><b>[2] Geometry</b></p> <p>(1) Surface Area required</p> <p>(2) Demensions</p> <p>(3) Actual Surface Area</p> <p>(4) Surface Overflow Rate</p>	<p><math>Q = 4,000 \text{ m}^3/\text{day}</math></p> <p><math>T = 20.0 \text{ }^\circ\text{C}</math></p> <p><math>X_{ef} = 3,000 \text{ mg/l}</math></p> <p><math>SVI = 300</math></p> <p><math>v = 4.899 \cdot 10^6 \cdot T^{(0.954)} \cdot X_{ef}^{(-1.354)} \cdot SVI^{(-0.77)}</math>  <math>= 4.899 \cdot 10^6 \cdot 20.0^{0.954} \cdot 3,000^{-1.354} \cdot 150^{-0.770}</math>  <math>= 20.7 \text{ m/day}</math></p> <p><math>S' = v / (1.5 \cdot 1) = 20.7 / (1.5 \cdot 1.0) = 13.8 \text{ m}^3/\text{m}^2 \cdot \text{day}</math>  <math>\rightarrow 12.0 \text{ m}^3/\text{m}^2 \cdot \text{day}</math></p> <p><math>A = 4,000 / 12.0 = 333 \text{ m}^2</math></p> <table style="margin-left: 40px;"> <tr> <td style="text-align: center;">Diameter</td> <td style="text-align: center;">Depth</td> <td style="text-align: center;">Basin</td> </tr> <tr> <td style="text-align: center;"><b>15.0</b></td> <td style="text-align: center;"><b>3.5</b></td> <td style="text-align: center;"><b>2</b></td> </tr> </table> <p><math>S = 15.0^2 \cdot 3.14 / 4 \cdot 2.0 = 353 \text{ m}^2</math></p> <p><math>S = 4,000 / 353 = 11.3 \text{ m}^3/\text{m}^2 \cdot \text{day}</math></p>	Diameter	Depth	Basin	<b>15.0</b>	<b>3.5</b>	<b>2</b>
Diameter	Depth	Basin					
<b>15.0</b>	<b>3.5</b>	<b>2</b>					

C-1 Process Cal. EA&al 4MLD Pillaganahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>8. Chlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Flow      4,000    m <sup>3</sup> /day      166.67    m <sup>3</sup> /h Peak Flow            10,000   m <sup>3</sup> /day      416.67    m <sup>3</sup> /h
(2) Contact Time	30    min
(3) Type of Chlorine	Cl <sub>2</sub> -GAS
(4) Design Chlorine Dosage Rate	10    mg/L
(5) Required Chlorine per day	Average Daily Flow    /    1000    ×            Design Chlorine Dosage Rate =    40.0    kg/d =    1.67    kg/h
<b>[2] Chlorination Contact Tank</b>	
(1) Volume required	Average Daily Flow    /    1440    ×    Contact Time =    83.3    m <sup>3</sup>
(2) Nos. of lanes	3    lanes
(3) Width of lane	1.50    m
(4) Length of lane	14.00    m
(5) Side Water Depth	1.50    m
(6) Nos. of Tanks	1    tank
(7) Total Width of Tank	5.30    m Approx..
(8) Average Velocity	Decant Flow            /            3600    /    Width            /    Depth =    166.67    /            3600    /    1.50            /    1.50 =    0.021    m/sec
(9) Total Volume	Width    ×    Length    ×    Depth    ×    Nos. of lanes    ×    Nos. of Tanks =    1.5    m    ×    14.0    m    ×    1.5    m =    95    m <sup>3</sup> >    83.3    m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Chlorine Dosing Condition	
Operation Dosage Rate -1	DC1      1 mg/L    10 mg/L
Average Dosage Rate -1	DC2      10 mg/L
(2) Chlorine Cylinder	
Type	-    Cylindrical Convexsd Container
Cylinder Capacity	Cc      928 kg/cylinder
Average Dosage Rate -1	q1      Chlorine -1 : Q <sub>T-D</sub> × DC2 × 10 <sup>-6</sup> × 10 <sup>3</sup> =    40 kg/day
Storage day	T      More than      15 days
Required Storage Capacity	EC1      D × T =      600 kg
Unit Number	EN1      EC1 / Cc =      0.6 cylinders
Maximum Operation Numbers	Vr1      ##### @ 20°C Standard temperature
Cl <sub>2</sub> -Gas Volatilize Rate	DC1      10 mg/L, Q <sub>T-D</sub> × q3 × 10 <sup>-3</sup> / 24 =    #####
Maximum Dosing Rate	EN2      DC1 / Vr1 =    0.5sets
(3) Chlorinator	
Type	Solution Feed Vacuum Type
Number	1    W    +    1    S
Operation Dosage Rate -1	Dq1      Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 4    kg/day to    100    kg/day
Required Dosage Rate	Chlorine -1 : Dq1 / (EN1 × 24) = Minimum                      Maximum 0.17    kg/hr                      4.2    kg/hr

C-1 Process Cal. EA&al 4MLD Pillaganahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p>(4) Chlorine Booster Pump</p> <p>Type</p> <p>Water Demand</p> <p>Chlorinator Discharge</p> <p>Water Demand</p> <p>Chlorinator Discharge</p> <p>Water Demand</p> <p>Water requiamet</p> <p>For Chlorin</p> <p>Booster Pump Type</p> <p>Number</p>	<p>Branchy on the water supply pipe</p> <p>Water requiamet for mixed Chlori</p> <table border="0"> <tr> <td>(kg/hr)</td> <td>1.0</td> <td>1.5</td> <td>2.0</td> <td>2.5</td> <td>3.0</td> <td>4.0</td> </tr> <tr> <td>(L/min)</td> <td>15</td> <td>20</td> <td>25</td> <td>30</td> <td>35</td> <td>40</td> </tr> <tr> <td>(kg/hr)</td> <td>5.0</td> <td>6.0</td> <td>10.0</td> <td>50.0</td> <td>100.0</td> <td>200.0</td> </tr> <tr> <td>(L/min)</td> <td>45</td> <td>50</td> <td>60</td> <td>300</td> <td>600</td> <td>1,200</td> </tr> </table> <p>Water requiamet -</p> <p>Qp1 Maximum dosage rate 4.2 kg/hr therefore 40 L/min</p> <p>Single suction volute pump</p> <p>1 W + 1 S</p>	(kg/hr)	1.0	1.5	2.0	2.5	3.0	4.0	(L/min)	15	20	25	30	35	40	(kg/hr)	5.0	6.0	10.0	50.0	100.0	200.0	(L/min)	45	50	60	300	600	1,200
(kg/hr)	1.0	1.5	2.0	2.5	3.0	4.0																							
(L/min)	15	20	25	30	35	40																							
(kg/hr)	5.0	6.0	10.0	50.0	100.0	200.0																							
(L/min)	45	50	60	300	600	1,200																							
<p><b>9. Dechlorination</b></p> <p><b>[1] Design Condition</b></p> <p>(1) Design Flow Rate</p> <p>(2) Contact Time</p> <p>(3) Type of Dechlorine</p> <p>(4) Free Residual Chlorine</p> <p>(5) Consumption per day</p> <p><b>[2] Dechlorination Contact Tank</b></p> <p>(1) Volume required</p> <p>(2) Width of lane</p> <p>(3) Length of lane</p> <p>(4) Side Water Depth</p> <p>(5) Nos. of Tanks</p> <p>(6) Total Volume</p> <p><b>[3] Equipment</b></p> <p>(1) Dechlorine Solution Tank</p> <p>Number</p> <p>Dechlorine concentration</p> <p>Gravity of dissolved dechlorine</p> <p>Required solution volume</p> <p>Volume of Tank</p> <p>Total Volume of Tanks</p> <p>(2) Mixer for Dechlorine Solution Tank</p> <p>Number</p> <p>(3) Dechlorine Dosing Pump</p> <p>Number</p> <p>Capacity</p>	<p>Average Daily Flow 4,000 m<sup>3</sup>/day</p> <p>10 min</p> <p>Sodium Thiosulfate (Na<sub>2</sub>S<sub>2</sub>O<sub>3</sub> 5H<sub>2</sub>O)</p> <p>1.0 mg/L assumed value</p> <p>Average Daily Flow / 1000 × Free Residual Chlorine × 1.75</p> <p>× 1.5 (safety factor)</p> <p>= 10.50 kg/d</p> <p>= 0.438 kg/h</p> <p>Average Flow Rate / 60 × Contact Time</p> <p>= 27.8 m<sup>3</sup></p> <p>5.30 m</p> <p>4.00 m</p> <p>1.50 m</p> <p>1 tank</p> <p>Width × Length × Depth</p> <p>= 5.3 m × 4.0 m × 1.5 m</p> <p>= 32 m<sup>3</sup> &gt; 27.8 m<sup>3</sup></p> <p>1 W + 0 S</p> <p>10 %</p> <p>1.10</p> <p>10.50 kg/d × 100 / 10 / 1.10 / 1000</p> <p>= 0.10 m<sup>3</sup>/d</p> <p>0.2 m<sup>3</sup>/tank</p> <p>0.2 m<sup>3</sup> (Duration= 2.10 day)</p> <p>1 W + 0 S</p> <p>1 W + 1 S</p> <p>0.24 m<sup>3</sup>/d / 24 × 1000 / 1</p> <p>9.94 l/h/unit ⇒ 10.0 l/h/unit</p>																												

C-1 Process Cal. EA&al 4MLD Pillaganahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

<p><b>10. Centrifuge</b>  <b>[1] Design Condition</b>                  (1) Type of Dewatering                  (2) Generated Sludge                  (3) Design Polyelectrolyte Dosage                  (4) Volume of Thickend Sludge                  (5) Consistency of Dewatered Sludge                  (6) Operation Time</p>	<p>Centrifuge                  1,735 kg/day                  Polyelectrolyte 5 kg/t-DS·day                  216.9 m<sup>3</sup>/day                  82 %                  12 hours/day (6 days per week)</p>
<p><b>[2] Volume of Centrifuges</b></p>	<p><math display="block">\frac{\text{Digested Solids}}{\text{Operation Time} \times \text{No.}} \times \text{Operation/week}</math> <math display="block">= \frac{216.9}{12 \times 1} \times \frac{7}{6} = 21.1</math> <p style="text-align: right;">→ 22 m<sup>3</sup>/hour</p> </p>
<p><b>[3] Dewatered Solids</b></p>	<p><math display="block">\text{Digested Sludge} \times (1 + \text{Injection Rate})</math> <math display="block">= 1,735 \times (1 + 0.0050)</math> <math display="block">= 1,744 \text{ kg/day}</math> </p>
<p><b>[4] Dewatered Cake Volume</b></p>	<p><math display="block">\text{Dewatered Solids} \times \frac{100}{100 - \frac{\text{Moisture Content}}{7}}</math> <math display="block">\times \frac{6 \text{ days per week}}{6}</math> <math display="block">= 1,744 \times \frac{100}{100 - 82} \times \frac{7}{6}</math> <math display="block">= 11.30 \text{ t/day}</math> <p>apparent specific gravity 1.00  <math display="block">\frac{11.30}{1.0} = 11.3 \text{ m}^3/\text{day}</math></p> </p>
<p><b>[5] Polyelectrolyte</b>                  (1) Design Polyelectrolyte Dosage                  (2) Required Polyelectrolyte                  (3) Dissolving concentration                  (4) Volume of Polyelectrolyte solution</p>	<p>Polyelectrolyte 5 kg/t-DS·day                  8.68 kg/day                  0.20 %                  4.34 m<sup>3</sup>/day</p>



C-1 Process Cal. EA&al 4MLD Pillaganahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

<b>[6] Equipment</b>						
(1) Centrifuge						
Capacity	22	m <sup>3</sup> /hr				
Number	1	W	+	1	S	
(2) Centrifuge Feed Pumps						
Capacity	22	m <sup>3</sup> /hr				
Number	1	W	+	1	S	
(3) Polyelectrolyte Dosing Pumps						
Volume of Polyelectrolyte solution	4.34	m <sup>3</sup> /day				
Operation Time	12	hours/day		(6 days per week)		
Safety Factor	1.5					
Number	1	W	+	1	S	
Required Capacity	4.34	m <sup>3</sup> /da;	×	7	/	6
					/	12
					/	1
	=	0.42	m <sup>3</sup> /Hr			
Specification Capacity	0.42	m <sup>3</sup> /Hr	×	1.5		
	=	0.633	m <sup>3</sup> /Hr	⇒	0.65	m <sup>3</sup> /Hr /Unit
(4) Polyelectrolyte dosing System						
Tanks Dimensions						
Width	1.5	m	×	Length	1.0	m
× Depth		1.8	m	×	2	
	=	5.4	m <sup>3</sup>			
Retention Time of Tanks	5.40	m <sup>3</sup>	/	0.42	m <sup>3</sup> /Hr	/
	=	12.802	Hr			
Number	2	W	+	0	S	

C-1 Process Cal. EA&al 4MLD Pillaganahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

<p><b>11. Centrifuge Feed Sump</b></p>	
<p><b>[1] Design Condition</b></p>	
<p>(1) Generated Thickend Sludge</p>	<p>1,735 kg/day</p>
<p>(2) Solids Consistency</p>	<p>0.80 %</p>
<p>(3) Volume of Excess Sludge</p>	$\begin{aligned} & \text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3} \\ = & 1,735 \times \frac{100}{0.80} \times 10^{-3} \\ = & 217 \text{ m}^3/\text{day} \\ = & 9.04 \text{ m}^3/\text{h} \end{aligned}$
<p>(4) Sludge feed flow rate</p>	<p>22 m<sup>3</sup>/h × 1 = 22 m<sup>3</sup>/h</p>
<p>(5) Centrifuge Operation Time</p>	<p>12 hours/day ( 6 days per week)</p>
<p><b>[2] Geometry</b></p>	
<p>(1) Basin Dimensions</p>	$\begin{aligned} & \text{Width } 4.5 \text{ m} \times \text{Length } 4.5 \text{ m} \\ & \times \text{Depth } 3.0 \text{ m} \times 2 \\ = & 121.5 \text{ m}^3 \end{aligned}$
<p><b>[3] Equipment</b></p>	
<p>(1) Mixers for Centrifuge Feed Sumps</p>	
<p>Required Volume</p>	<p>121.5 m<sup>3</sup></p>
<p>Number</p>	<p>1 W + 1 S</p>

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Digestion Tank + Centrifugal Dewatering)

Table -1 Input Data

1. Calculation Manner	2	1:Premise that the quality of supernatants are same level removed with inlet sewage 2:Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency	2	1:Total Removal Ratio 2:Outlet Water Quality(input 1or2)
In case of 1 : input data		(%)
In case of 2 : input data	#REF!	(mg/l)
3. Selection of Excess Sludge Generation	2	1:Consideration of Solid Matter Only 2:Consideration of Converting of Solved BOD(input 1or2)
In case of 1 : input data (Sludge generation)		Sludge generation ratio per removal SS(%) T2=Q4·S4-(a·S <sub>BOD</sub> +b·S1-c·θ·XA)·Q3/10 <sup>6</sup> ·(Excess sludge generation formula)
In case of 2 : input data	a	0.4 a:Converting ratio of solved BOD(mgMLSS/mgBOD)
	b	0.9 b:Converting ratio of SS(mgMLSS/mgSS)
	c	0.05 c:Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)
	SBOD	234.50 S <sub>BOD</sub> :Solved BOD quality at inlet reactor
	XA	3,000 XA:MLSS concentration(mg/l)
θ	1 θ:Hydraulic retention time(day)	


Table -2 Basic Conditions

Sewage Flow and Quality	Sludge Moisture and Recovery Ratio	Digestion Tank Conditions	Chemical Conditions for Dewatering
·Inlet flow : Q <sub>0</sub> (m <sup>3</sup> /D) 4,000	·Primary sludge moisture ratio : W1(%) 0.0	·Removal ratio in primary tank : A2(%) 0.0	·Content of organics in thickened sludge : A6(%) 75.0
·Inlet quality : S <sub>0</sub> (mg/l) 450	·Excess sludge moisture ratio : W2(%) 99.2	·Recovery ratio in sludge thickener : A3(%) 100.0	·Chemical dosage : A9(%) 0.5
·Total removal ratio : A1(%) -	·Thickened sludge moisture ratio : W3(%) 99.2	·Recovery ratio in sludge digester : A4(%) 100.0	·Chemical dissolve concentration : A10(%) 0.2
·Effluent quality : S1(mg/l) 10.0	·Digested sludge moisture ratio : W4(%) 99.2	·Recovery ratio in dewatering : A5(%) 95.0	·Digestion gas generation : A8(Nm <sup>3</sup> /kgVS)
·Sludge generation ratio per removal SS : S1(%) -	·Dewatered sludge moisture ratio : W5(%) 82.0		

Table -3 Material Balance Calculation

	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
Q(m <sup>3</sup> /day)	4,000	4,212	0	4,212	217	3,995	217	0	0	217	0	4	221	9	212	212	3,995	0
T(t·DS/day)	1,800	1,887	0.000	1,887	1,735	0.040	1,735	0.000	0.000	1,735	0.000	0.009	1,744	1,657	0.087	0.087	0.040	0.112
S(mg/l)	450	448	0	448	8,000	10	8,000	#DIV/0!	0	8,000	0	2,000	7,882	180,000	411	411	10	
X(T5/T0*100)	100	104.8	0.0	104.8	96.4	2.2	96.4	0.0	0.0	96.4	0.0	0.5	96.9	92.0	4.8	4.8	2.2	6.2

Figure -1 Material Balance Model




Calculation Formula						
·Q0=Input Data	·Q3=Q1-Q2	·Q6=T6*100/(100-W3)	·Q9=Q6	·Q12=Q9+Q11	·Q15=Q7+Q10+Q14	·Q5-1=Q5-Q11
·T0=Q0*S0*10 <sup>-6</sup>	·T3=T0*(100-A2)/100	·T6=(T2+T4)*A3/100	·T9=(T6-T8)*A4/100	·T12=T9+T11	·T15=T7+T10+T14	·T5-1=T5-T11
·S0=Input Data	·S3=T3*10 <sup>-6</sup> /Q3	·S6=10 <sup>-6</sup> *Q6*(100-W3)/100	·S9=T9*10 <sup>-6</sup> /Q9	·S12=T12*10 <sup>-6</sup> /Q12	·S15=T15*10 <sup>-6</sup> /Q15	·S5-1=S5
·Q1=Q0+Q15	·Q4=T4*100/(100-W2)	·Q7=(Q2+Q4)-Q6	·Q10=Q6-Q8-Q9	·Q13=T13*100/(100-W5)		
·T1=T0+T15	·T4=余剰汚泥発生式による	·T7=(T2+T4)-T6	·T10=T6-T8-T9	·T13=T12*A5/100		
·S1=T1*10 <sup>-6</sup> /Q1	·S4=10 <sup>-6</sup> *Q4*(100-W2)/100	·S7=T7*10 <sup>-6</sup> /Q7	·S10=T10*10 <sup>-6</sup> /Q10	·S13=10 <sup>-6</sup> *Q13*(100-W5)/100		
·Q2=T2*100/(100-W1)	·Q5=Q3-Q4*(T3-T5)/T4	·Q8=0	·Q11=T10*A9/A10	·Q14=Q12-Q13		
·T2=T1-T3	·T5=Q5*ST/10 <sup>-6</sup>	·T8=T6*A6*A7/10 <sup>-4</sup>	·T11=Q11*S11/10 <sup>-6</sup>	·T14=T12-T13		
·S2=10 <sup>-6</sup> *Q2*(100-W1)/100	·S5=St	#REF!	·S11=10 <sup>-4</sup> *A10	·S14=T14*10 <sup>-6</sup> /Q14		

Material Balance Sheet SD4

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Sheet  
[3MLD STP]



C-2 Process Cal, EA&al 5MLD Talaghattapura, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

**Design Condition**

Item	5MLD STP-TSPS				
(1) Design Flow for the year 2049	Flow Rate				
		m3/d	m3/h	m3/s	
	Average Daily	8,000	333	0.093	
	Max Dayly	8,000	333	0.093	
	Max Hourly Peak factor	2.25	18,000	750	0.208
(1) Design Flow for the year 2034	Flow Rate				
		m3/d	m3/h	m3/s	
	Average Daily	5,000	208	0.058	
	Max Dayly	5,000	208	0.058	
	Max Hourly Peak factor	2.5	12,500	521	0.145

**1. Inlet Chamber**

Item	5MLD STP-TSPS								
[1] Design Condition									
(1) Design Flow for the year 2049	Max Hourly	=	18,000	m3/d					
		=	0.208	m3/sec					
(2) Inlet Pipe									
Pipe Diameter	•	×							
Gradient			%						
Roughness Coefficient	n=	0.013	(Manning Formula)						
Full Pipe Flow Rate			m3/s						
(3) Influent Water Level	+		m						
[2] Geometory									
(1) Number of Basins	1	Basin							
(2) Depth of Basin	0.600	m	Approx.						
(3) Width of Basin	2.100	m	Approx.						
(4) Length of Basin	2.500	m	Approx.						
(5) Volume required of Basin	0.600	×	2.100	×	2.500	=	0.5	m3	
(6) Retention Time	0.600	×	2.100	×	2.500	/	0.208	×	1
	=	15.14	sec						
(7) Basin Demensions	Width	2.100	m	×	Length	2.500	m		
	×	Depth	0.600	m					

C-2 Process Cal. EA&amp;al 5MLD Talaghattapura Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3****2. Coarse Screen Channel**

Item	5MLD STP-TSPS					
[1] Geometry						
(1) Inlet Gate						
Number	1	Main	+	1	Bypass	
Width	0.400	m				
Height	0.600	m				
Floor Level	+	5.000	m			
Bottom	+	0.000	m			
Influent Water Level	+	0.500	m			
Velocity	0.208	/	0.400	/	0.500	/ 1
where Design Flow for the year 2049	=	1.040	<	1.000	m/sec	OK
Velocity	0.145	/	0.400	/	0.500	/ 1
where Design Flow for the year 2034	=	0.725	<	1.000	m/sec	OK
(2) Screen Channel						
Number	1.0	Main	+	1.0	Bypass	
Width	0.800	m				
Side Water Depth	0.600	m				
Velocity	0.208	/	0.800	/	0.600	/ 1
where Design Flow for the year 2049	=	0.433	≐	0.450	m/sec	OK
Velocity	0.145	/	0.800	/	0.600	/ 1
where Design Flow for the year 2034	=	0.302	<	0.450	m/sec	OK
(3) Channel Dimensions	Width	0.8	m	×	Length	8.5 m
			×	SWD	0.6	m
[3] Equipment						
(1) Inlet Gate						
Number	2	Units				
Dimension	Width	0.4	m	×	Height	0.6 m
Design Water Level		m				
(2) Coarse Screens (Main Channel)						
Number	1	W	+	0	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	0.8	m				
Width of side plate	50	mm				
Side Water Depth	0.6	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.208	/	0.700	/	0.550	/ 1
	× (	20	+	9	) /	20
	=	0.783	≐	0.800	m/sec	OK
Velocity through screen	0.145	/	0.700	/	0.550	/ 1
where Design Flow for the year 2034	× (	20	+	9	) /	20
	=	0.546	<	0.800	m/sec	OK
(3) Coarse Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	0.8	m				
Side Water Depth	0.6	m				
Velocity through screen	0.208	/	0.800	/	0.600	/ 1
where Design Flow for the year 2049	× (	20	+	9	) /	20
	=	0.628	<	0.800	m/sec	OK
Velocity through screen	0.145	/	0.800	/	0.600	/ 1
where Design Flow for the year 2034	× (	20	+	9	) /	20
	=	0.438	<	0.800	m/sec	OK

**STP Process Calculation\_Supporting Report 12.2.3**

**3. Raw Sewage Sump**

Item	5MLD STP-TSPS	
[2] Geometory		
(1) Raw Sewage Sump		
Number	1	Basin
Dia	8.00	m
Pump Operating Depth	1.000	m
Retention Time whe Design Flow for the year 2049	$( \frac{8.00^2 \times \pi}{4} \times 1.000 ) / 0.208$	$/ 60$ = 4.03 > 3.75 min (=minimum time of one pump cycle) OK
Retention Time whe Design Flow for the year 2034	$( \frac{8.00^2 \times \pi}{4} \times 1.000 ) / 0.145$	$/ 60$ = 5.78 > 3.75 min (=minimum time of one pump cycle) OK
High Water Level	+ 0.000	m
Pump Off Level	+ -1.000	m
[3] Equipment		
(1) Sewage Pumps 1		
Number	1	W + 1 S
Bore Diameter	250	mm
Discharge Flow : Q whe Design Flow for the year 2034	$0.145 \times 3600$	$/ 1.0$ = 522 $\Rightarrow$ 522 m <sup>3</sup> /Hr
Total Head	15.0	m
(2) Sewage Pumps 2		
Number		W + S
Bore Diameter		mm
Discharge Flow : Q whe Design Flow for the year 2034	$0.5$	$/$ = $\Rightarrow$ m <sup>3</sup> /Hr
Total Head		m

C-2 Process Cal. EA&al 5MLD Talaghattapura Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

Item	5MLD STP																																																		
<b>1. STP Design Condition</b>																																																			
(1) Design Flow Rate	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th style="text-align: center;">m3/d</th> <th style="text-align: center;">m3/h</th> <th style="text-align: center;">m3/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td style="text-align: center;">5,000</td> <td style="text-align: center;">208.33</td> <td style="text-align: center;">0.058</td> </tr> <tr> <td>Max Daily</td> <td style="text-align: center;">5,000</td> <td style="text-align: center;">208.33</td> <td style="text-align: center;">0.058</td> </tr> <tr> <td>Max Hourly Peak factor 2.5</td> <td style="text-align: center;">12,500</td> <td style="text-align: center;">520.83</td> <td style="text-align: center;">0.145</td> </tr> </tbody> </table>											m3/d	m3/h	m3/s	Average Daily	5,000	208.33	0.058	Max Daily	5,000	208.33	0.058	Max Hourly Peak factor 2.5	12,500	520.83	0.145																									
	m3/d	m3/h	m3/s																																																
Average Daily	5,000	208.33	0.058																																																
Max Daily	5,000	208.33	0.058																																																
Max Hourly Peak factor 2.5	12,500	520.83	0.145																																																
(2) Design Water Quality	<p style="text-align: right;">Unit: mg/L</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th colspan="2">TP</th> </tr> <tr> <th>NH<sub>4</sub>-N</th> <th>Org-N</th> <th>NOx-N</th> <th>D-P</th> <th>P-P</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td style="text-align: center;">350</td> <td style="text-align: center;">800</td> <td style="text-align: center;">450</td> <td style="text-align: center;">45.5</td> <td style="text-align: center;">17.5</td> <td style="text-align: center;">7</td> <td style="text-align: center;">5</td> <td style="text-align: center;">2</td> </tr> <tr> <td>Outlet</td> <td style="text-align: center;">10</td> <td style="text-align: center;">50</td> <td style="text-align: center;">10</td> <td style="text-align: center;">1</td> <td style="text-align: center;">0</td> <td style="text-align: center;">9</td> <td style="text-align: center;">1</td> <td style="text-align: center;">1</td> </tr> <tr> <td>Removal rate</td> <td style="text-align: center;">97.1%</td> <td style="text-align: center;">93.7%</td> <td style="text-align: center;">97.8%</td> <td colspan="3" style="text-align: center;">85.7%</td> <td colspan="2" style="text-align: center;">71.4%</td> </tr> </tbody> </table>											BOD	COD	SS	T-N			TP		NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P	Inlet	350	800	450	45.5	17.5	7	5	2	Outlet	10	50	10	1	0	9	1	1	Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%	
	BOD	COD	SS	T-N			TP																																												
				NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P																																											
Inlet	350	800	450	45.5	17.5	7	5	2																																											
Outlet	10	50	10	1	0	9	1	1																																											
Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%																																												
<b>2. Inlet Chamber</b>																																																			
<b>[1] Design Condition</b>																																																			
(1) Design Flow Rate	Max Hourly	=	12,500	m3/day																																															
		=	0.145	m3/sec																																															
<b>[2] Geometry</b>																																																			
(1) Number of Basins	1	Basin																																																	
(2) Depth of Basin	1.000	m																																																	
(3) Width of Basin	2.100	m																																																	
(4) Length of Basin	1.500	m																																																	
(5) Volume required of Basin	1.000	×	2.100	×	1.500	=	1.4	m3																																											
(6) Retention Time	1.000	×	2.100	×	1.500	/	0.145	×	1																																										
	=	21.72	sec																																																
(7) Basin Dimensions	Width	2.100	m	×	Length	1.500	m																																												
	×	Depth	1.000	m																																															



C-2 Process Cal. EA&al 5MLD Talaghattapura Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Wastewater Flow	$\begin{aligned} \text{Max Hourly} &= 12,500 \text{ m}^3/\text{d} \\ &= 0.145 \text{ m}^3/\text{sec} \end{aligned}$
[2] Geometory	
(1) Inlet Gate	
Number	1 Main + 1 Bypass
Width	0.400 m
Height	0.600 m
Floor Level	+ 2.000 m
Bottom	+ 0.000 m
Influent Water Level	+ 0.500 m
Velocity	$\begin{aligned} &0.145 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 1 \\ = &0.725 \text{ } \div \quad 1.000 \text{ m/sec} \end{aligned}$
(2) Screen Channel	
Number	1 Main + 1 Bypass
Width	0.800 m
Side Water Depth	0.400 m
Velocity	$\begin{aligned} &0.145 \text{ } \swarrow \quad 0.800 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 1 \\ = &0.453 \text{ } \div \quad 0.450 \text{ m/sec} \end{aligned}$
(3) Channel Dimensions	$\begin{aligned} \text{Width} &0.8 \text{ m} \times \text{Length} &6.0 \text{ m} \\ &\times \text{SWD} &0.4 \text{ m} \quad (\text{Freeboard } 0.3\text{m}) \end{aligned}$
[3] Equipment	
(1) Inlet Gate	
Number	1 W + 1 S
Dimension	Width 0.4 m × Height 0.60 m
Design Water Level	2.00 m
(2) Fine Screens (Main Channel)	
Number	1 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	0.8 m
Width of side plate	50 mm
Side Water Depth	0.4 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	$\begin{aligned} &0.145 \text{ } \swarrow \quad 0.700 \text{ } \swarrow \quad 0.350 \text{ } \swarrow \quad 1 \\ &\times \left( \frac{6}{6} + \frac{2}{6} \right) / 6 \\ = &0.789 < 0.800 \text{ m/sec} \end{aligned}$
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	0.8 m
Side Water Depth	0.4 m
Velocity through screen	$\begin{aligned} &0.145 \text{ } \swarrow \quad 0.800 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 1 \\ &\times \left( \frac{20}{20} + \frac{9}{20} \right) / 20 \\ = &0.657 < 0.800 \text{ m/sec} \end{aligned}$

C-2 Process Cal, EA&al 5MLD Talaghattapura, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>4. Grit Chamber</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Max Hourly = 12,500 m <sup>3</sup> /day = 0.145 m <sup>3</sup> /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0111 m/sec = 960 m <sup>3</sup> /m <sup>2</sup> /day
(4) Average Velocity	0.3 m/sec
<b>[2] Grit Chamber</b>	
(1) Surface Area required	0.145 / 0.0111 = 13.06 m <sup>2</sup>
(2) Number of Basins	1 S + 1 W
(3) Surface Area required/Basin	13.1 / 1 = 13.06 m <sup>2</sup>
(4) Length of Basin	13.06 ^0.5 = 3.6 m → 4.0 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.145 × 60 sec / 1 = 8.7 m <sup>3</sup>
(7) Depth required	8.7 / 4.0 / 4.0 = 0.544 m
(8) Basin Dimensions	Width 4.0 m × Length 4.0 m × Depth 0.5 m (Freeboard 0.3m)
(9) Retention Time	4 × 4.0 × 0.5 / 0.145 × 1 = 60.00 sec
(10) Surface Overflow Rate at Peak Flow	12,500 / 4.0 / 4.0 / 1 = 781.25 < 960 m <sup>3</sup> /m <sup>2</sup> /day
<b>[3] Parshall Flume</b>	
(1) Design Flow Rate	Q= 145.000 l/sec
(2) Throat width	W= 0.450 m
(3) Water depth Ha	Ha= ( Q / 2264 / W ) <sup>2/3</sup> Ha= 0.273 m
(4) Crest Level	+ 75.400 m ≐ Minimum water level at downstream channel
(5) Water level at the crest	+ 75.673 m
(6) Channel bottom level	+ m
(7) Upstream Channel width	1.500 m
(8) SWD of Upstream Channel	0.700 m
(9) Average velocity at upstream channel	0.138 m/sec
(10) Total Length of channel	10.000 m
<b>[4] Inlet Weir Gate</b>	
(1) Number	2 Units
(2) Weir Width	0.400 m
(3) Stroke	0.450 m
(4) Overflow Height	0.400 m
(5) Overflow Height (actual)	( 0.145 / 1.840 / 0.400 / 2 ) <sup>2/3</sup> = 0.213 < 0.400 m

C-2 Process Calculations 5MLD Talaghattapura Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<b>5. Reactor</b>																																																								
<b>[1] Design Condition</b>																																																								
(1) Design Wastewater Flow	Q = 5,000 m <sup>3</sup> /day (summer) Q' = 5,000 m <sup>3</sup> /day (Winter)																																																							
(2) Design Sewage Quality																																																								
Inlet BOD	350 mg/l																																																							
Outlet BOD	10.0 mg/l																																																							
Inlet S-BOD	235 mg/l assumed as 67% of BOD																																																							
Inlet COD	800 mg/l																																																							
Inlet bCOD : S <sub>0</sub>	578 mg/l																																																							
Inlet nbCOD	223 mg/l																																																							
bCOD/BOD	1.65																																																							
Inlet S-COD : sCOD	271 mg/l																																																							
Inlet rbCOD	231 mg/l bCOD*40%																																																							
Inlet sbCOD	347 mg/l bCOD*60%																																																							
Outlet S-COD : nbsCODe	40 mg/l																																																							
Inlet nbpCOD : nbpCOD	183 mg/l = TCOD-bCOD-nbsCODe																																																							
Inlet SS	450 mg/l																																																							
Inlet VSS	383 mg/l assumed as 85% of TSS																																																							
: VSS <sub>COD</sub>	1.38 gCOD/gVSS = TCOD-sCOD/VSS																																																							
: nbVSS	131.96 gnbVSS/m <sup>3</sup> = nbpCOD/VSS <sub>COD</sub>																																																							
: iTSS	67.50 gnbVSS/m <sup>3</sup> = TSS-VSS																																																							
Inlet T-N	70 mg/l																																																							
Inlet TKN	70 mg/l																																																							
Inlet NH <sub>4</sub> -N	45 mg/l																																																							
Inlet T-P	7 mg/l																																																							
Inlet D-P	5 mg/l																																																							
Inlet Alkalinity as CaCO <sub>3</sub>	380 mg/l																																																							
Outlet Kjeldahl N	1.0 mg/l																																																							
Outlet NH <sub>4</sub> -N	1.0 mg/l																																																							
Outlet NO <sub>3</sub> -N	9.0 mg/l																																																							
Outlet T-P	2 mg/l																																																							
Outlet D-P	1 mg/l																																																							
(3) Water Temperature	T = 20.0 °C																																																							
(4) Safety Factor for Nitrogen	SF = 1.5																																																							
(5) Return Sludge Concentration	R <sub>s</sub> = 8,000 mg/l																																																							
(6) MLSS MLVSS	X <sub>TSS</sub> = 3,000 mg/l																																																							
(7) DO in the Reactor	2 mg/L																																																							
<b>[2] Design Value for perfect Nitrification of Nitrification Process</b>																																																								
(1) Activated sludge design kinetic coefficients at 20°C																																																								
	<table border="1"> <thead> <tr> <th>Coefficient</th> <th>Unit</th> <th>COD oxidatio</th> <th>NH<sub>4</sub> oxidatio</th> <th>NO<sub>2</sub> oxidatio</th> </tr> </thead> <tbody> <tr> <td>μ<sub>max</sub></td> <td>gVSS/gVSS · d</td> <td>6.000</td> <td>0.900</td> <td>1.000</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>mg/L</td> <td>8.000</td> <td>0.500</td> <td>0.200</td> </tr> <tr> <td>Y</td> <td>gVSS/g substrate oxidized</td> <td>0.450</td> <td>0.150</td> <td>0.050</td> </tr> <tr> <td>b</td> <td>gVSS/gVSS · d</td> <td>0.120</td> <td>0.170</td> <td>0.170</td> </tr> <tr> <td>fd</td> <td>unitless</td> <td>0.150</td> <td>0.150</td> <td>0.150</td> </tr> <tr> <td>K<sub>O<sub>2</sub></sub></td> <td>mg/L</td> <td>0.200</td> <td>0.500</td> <td>0.900</td> </tr> <tr> <td>θ Value</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>μ<sub>max</sub></td> <td>unitless</td> <td>1.070</td> <td>1.072</td> <td>1.063</td> </tr> <tr> <td>b</td> <td>unitless</td> <td>1.040</td> <td>1.029</td> <td>1.029</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>unitless</td> <td>1.000</td> <td>1.000</td> <td>1.000</td> </tr> </tbody> </table> <p>Wastwater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF &amp; EDDY/AECOM)</p>	Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio	μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200	Y	gVSS/g substrate oxidized	0.450	0.150	0.050	b	gVSS/gVSS · d	0.120	0.170	0.170	fd	unitless	0.150	0.150	0.150	K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900	θ Value					μ <sub>max</sub>	unitless	1.070	1.072	1.063	b	unitless	1.040	1.029	1.029	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000
Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio																																																				
μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200																																																				
Y	gVSS/g substrate oxidized	0.450	0.150	0.050																																																				
b	gVSS/gVSS · d	0.120	0.170	0.170																																																				
fd	unitless	0.150	0.150	0.150																																																				
K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900																																																				
θ Value																																																								
μ <sub>max</sub>	unitless	1.070	1.072	1.063																																																				
b	unitless	1.040	1.029	1.029																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000																																																				
(2) μ <sub>AOB</sub>	μ <sub>AOB</sub> = 0.3100 g/g · d = μ <sub>max, AOB</sub> [S <sub>NH<sub>4</sub></sub> / (S <sub>NH<sub>4</sub></sub> + K <sub>NH<sub>4</sub></sub> )] [S <sub>O</sub> / (S <sub>O</sub> + K <sub>O, AOB</sub> )] - b <sub>AOB</sub>																																																							
μ <sub>max, AOB, T</sub>	μ <sub>max, AOB, T</sub> = 0.9000 g/g · d = μ <sub>max</sub> * 1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900																																																							
b <sub>AOB, T</sub>	b <sub>AOB, T</sub> = 0.1700 = b * 1.029 <sup>(T-20)</sup> b at 20°C = 0.170																																																							
S <sub>NH<sub>4</sub></sub>	S <sub>NH<sub>4</sub></sub> = 1.0000 mg/l																																																							
DO	DO = 2.0000 mg/l																																																							
K <sub>O, AOB</sub>	K <sub>O, AOB</sub> = 0.5000 mg/l																																																							

**STP Process Calculation Supporting Report 12.2.3**

(2) Design SRT	SRT= 4.8387 day = $1/\mu_{AOB} \times SF$ ⇒ 5.0000 day
(3) Biomass production	
P <sub>X,VSS</sub>	1563.519 kg/d = P <sub>X,bio</sub> +Q(nbVSS)
P <sub>X,TSS</sub>	2060.500 kg/d = P <sub>X,bio</sub> /0.85+Q(nbVSS)+Q(TSS <sub>0</sub> -VSS <sub>0</sub> )+5*Q*Al
S	S= 0.4507 mg/l = $K_s[1+b_H(SRT)]/[SRT(\mu_m-b_H)-1]$
b <sub>H</sub>	b <sub>H</sub> = 0.1200 = $b*1.04^{(T-20)}$ b at 20°C = 0.120
Y <sub>H</sub>	Y <sub>H</sub> = 0.4500 gVSS/g bCOD
μ <sub>m,T</sub>	μ <sub>m,T</sub> = 6.0000 g/g·d = $\mu_{max} * 1.04^{(T-20)}$ μ max at 20°C = 6.000
Y <sub>n</sub>	Y <sub>n</sub> = 0.150 gVSS/g Nox
NO <sub>x</sub>	NO <sub>x</sub> = 47.400 mg/l
P <sub>X,bio,VSS</sub>	P <sub>X,bio,VSS</sub> = 903.725 kg VSS/d = $Q \cdot Y_H(S_0-S)/[1+b_H(SRT)] + f_d \cdot b_H \cdot QY_H(S_0-S)SRT/[1+b_H(SRT)] + QY_n(Nox)[2+b_{AOB}(SRT)]$ 811.476 = $Q \cdot Y_H(S_0-S)/[1+b_H(SRT)]$ 73.033 = $f_d \cdot b_H \cdot QY_H(S_0-S)SRT/[1+b_H(SRT)]$ 19.216 = $QY_n(Nox)[1+b_{AOB}(SRT)]$
NO <sub>x</sub>	NO <sub>x</sub> = 47.311 mg/l = $TKN - Ne - 0.12P_{X,bio}/Q$
(4) Required Aeration Tank Volume	
V <sub>a</sub>	V <sub>a</sub> = 3,434 m <sup>3</sup>
τ	τ = 16.48 hr = V <sub>a</sub> /Q × 24 ⇒ 18.00 hr
X <sub>VSS</sub> · V <sub>a</sub>	X <sub>VSS</sub> · V <sub>a</sub> = 7,818 kg VSS = P <sub>X,VSS</sub> · SRT
X <sub>TSS</sub> · V <sub>a</sub>	X <sub>TSS</sub> · V <sub>a</sub> = 10,302 kg TSS = P <sub>X,TSS</sub> · SRT
F/M	F/M= 0.224 kgBOD/kgMLVSS
FractionVSS	FractionVSS= 0.759
MLVSS	MLVSS= 2276 mg/L
(5) BODloading	BODloading= 0.510 kg/m <sup>3</sup> ·d
(6) Observed Yield	
Y <sub>obs,TSS</sub>	Y <sub>obs,TSS</sub> = 1.178 gTSS/gBOD
Y <sub>obs,VSS</sub>	Y <sub>obs,VSS</sub> = 0.894 gVSS/gBOD
bCODremoved	bCODremov= 2,885 kg/d
(7) effluent NO <sub>2</sub> -N	NO <sub>2</sub> -N= 0.2315 mg/l = $K_s[1+b_{NOB}(SRT)]/[SRT(\mu_{NOB}-b_{NOB})-1]$
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700 = $b*1.029^{(T-20)}$ b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 1.0000 g/g·d = $\mu_{max} * 1.04^{(T-20)}$ μ max at 20°C = 1.000
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.6897 g/g·d = $\mu_{max,NOB}[S_0/(S_0+K_{O2,NOB})]$
	S <sub>0</sub> = 2.000 mg/l
	K <sub>O2,NOB</sub> = 0.900 mg/l
(8) effluent NH <sub>4</sub> -N	NH <sub>4</sub> -N= 0.5286 mg/l = $K_s[1+b_{NOB}(SRT)]/[SRT(\mu_{NOB}-b_{NOB})-1]$
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700 = $b*1.029^{(T-20)}$ b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 0.9000 g/g·d = $\mu_{max} * 1.072^{(T-20)}$ μ max at 20°C = 0.900
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.7200 g/g·d = $\mu_{max,NOB}[S_0/(S_0+K_{O2,NOB})]$
	S <sub>0</sub> = 2.000 mg/l
	K <sub>O2,NOB</sub> = 0.500 mg/l
(9) Ratio of Return Sludge	8,000*R <sub>r</sub> /(1+R <sub>r</sub> )= 3,000 mg/L 3,000/(8,000-3,000)= 0.60 R <sub>r</sub> = 0.60

C-2 Process Cal EA&al 5MLD Talaghattapura Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

[3] Design for Nitrification and Denitrification Process																					
(1) Active biomass concentration	$X_b = \frac{Q \cdot (SRT) \cdot V \cdot Y_H \cdot (S_0 - S)}{1 + b_H(SRT)}$ $= 1,181.47 \text{ mg/l}$																				
(2) IR ratio	$IR = \frac{NO_x}{Ne} - 1.0 - R$ $= 3.66$																				
(3) The amount of NO <sub>3</sub> -N fed to the anoxic tank	$Nox \text{ feed} = (IR + R) \cdot Q \cdot Ne$ $= 191,553.05 \text{ kg/d}$																				
(4) The anoxic tank volume	$V_{nor} = 343 \text{ m}^3 = V_a \times 10\%$ $V_{nor} = 1,042 \text{ m}^3 \quad \tau_{DN} = 5.000 \text{ h}$																				
(5) F/M <sub>b</sub>	$F/M_b = 1.42 \text{ g/g} \cdot \text{d}$																				
(6) Fraction of rbCOD	$40.00\% = \frac{rbCOD}{bCOD}$																				
	<table border="1"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b<sub>0</sub></th> <th>b<sub>1</sub></th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>	Percent rdCOD(%)	SDNR equation coefficients		b <sub>0</sub>	b <sub>1</sub>	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162
Percent rdCOD(%)	SDNR equation coefficients																				
	b <sub>0</sub>	b <sub>1</sub>																			
10	0.186	0.078																			
20	0.213	0.118																			
30	0.235	0.141																			
40	0.242	0.152																			
50	0.270	0.162																			
(8) SDNR <sub>b</sub>	$SDNR_b = 0.296 \text{ g/g} \cdot \text{d} = b_0 + b_1 [\ln(F/M_b)]$ $b_0 = 0.242$ $b_1 = 0.152$																				
(8) SDNR	$SDNR = 0.110 \text{ g/g} \cdot \text{d} = SDNR_b (MLVSS_b / MLVSS)$ $SDNR_{adj} = 0.212 \text{ g/g} \cdot \text{d} = SDNR_i - 0.029 \ln(F/M_b) - 0.012 \quad IR=3-4$ $= SDNR_i - 0.0166 \ln(F/M_b) - 0.078 \quad IR=2$ $SDNR_t = 0.296 \text{ g/g} \cdot \text{d} = SDNR_b \cdot \theta^{(4-20)} \quad \theta = 1.026$																				
(9) NO <sub>r</sub>	$NO_r = 260,496.54 \text{ kg/d} = N_{nox} \cdot SDNR \cdot X_b$ $> Nox \text{ feed} = 191,553 \text{ kg/d}$																				
(10) Alkalinity to be added to maintain pH7	$-108.33 \text{ mg/l}$ $\text{Influent Alk} = 380.00 \text{ mg/l}$ $\text{Alk used} = 338.44 \text{ mg/l} = 7.14 \times Nox$ $\text{Alk produced} = 136.77 \text{ mg/l} = 3.57 \times (NO_x - NO_{xe})$ $\text{Alk to maint} = 70.00 \text{ mg/l}$																				
[4] Design of Phosphorous Removal Process																					
(1) Removal T-P	$3.13 \text{ mg/l}$																				
P in waste sludge	$p_x = 1.00\%$																				
Generated waste sludge	$P_{x, VSS} = 1563.519 \text{ kg/d}$																				
Rwmoval Phosphorus	$15.63519013 \text{ kg/d}$																				
(2) Effluent T-P without Al	$3.87 \text{ mg/l}$																				
(3) Required Al to initial soluble phosphorous ratio	$1.00 \text{ mol/mol}$																				
(4) Required Al dosing rate	$3.48 \text{ mg/l} \text{ as Al}$ $42.98 \text{ mg/l} \text{ as crystal, Al}_2(\text{SO}_4)_3 \cdot 18\text{H}_2\text{O}$																				
(5) Required Aluminium Sulphate	$214.89 \text{ kg/d}$																				
(6) Required Aluminium Sulphate sol 10%	$2.05 \text{ m}^3/\text{d}$																				
	$85.27 \text{ L/H}$																				
(7) Additional sludge	$87.12 \text{ kg/d}$																				

C-2 Process Calculations at 5MLD Talaghattapura Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<b>[5] Reactor</b>																																																																				
(1) Total volume of Aeration Basins	$V_A = Q \cdot \theta_a / 24$ = 3,750 m <sup>3</sup>																																																																			
(2) Total volume of Anoxic Basins	$V_{DN} = Q \cdot \theta_{DN} / 24$ = 1,042 m <sup>3</sup>																																																																			
	<table border="1"> <thead> <tr> <th rowspan="2">Item</th> <th rowspan="2">Volume required</th> <th colspan="2">Retention Time required</th> <th rowspan="2">Ratio of Volume</th> </tr> <tr> <th>Summer</th> <th>Winter</th> </tr> <tr> <th colspan="2">unit</th> <th>m<sup>3</sup></th> <th>hour</th> <th>hour</th> <th></th> </tr> </thead> <tbody> <tr> <td>Anaerobic</td> <td><math>V_{AN}</math></td> <td>310</td> <td>1.50</td> <td>1.50</td> <td>0.30</td> </tr> <tr> <td>Anoxic</td> <td><math>V_{DN}</math></td> <td>1,042</td> <td>5.00</td> <td>5.00</td> <td>1.00</td> </tr> <tr> <td>Aerobic</td> <td><math>V_A</math></td> <td>3,750</td> <td>18.00</td> <td>18.00</td> <td>3.60</td> </tr> <tr> <td>Total</td> <td>V</td> <td>5,102</td> <td>24.50</td> <td>24.50</td> <td></td> </tr> </tbody> </table>	Item	Volume required	Retention Time required		Ratio of Volume	Summer	Winter	unit		m <sup>3</sup>	hour	hour		Anaerobic	$V_{AN}$	310	1.50	1.50	0.30	Anoxic	$V_{DN}$	1,042	5.00	5.00	1.00	Aerobic	$V_A$	3,750	18.00	18.00	3.60	Total	V	5,102	24.50	24.50																															
Item	Volume required			Retention Time required			Ratio of Volume																																																													
		Summer	Winter																																																																	
unit		m <sup>3</sup>	hour	hour																																																																
Anaerobic	$V_{AN}$	310	1.50	1.50	0.30																																																															
Anoxic	$V_{DN}$	1,042	5.00	5.00	1.00																																																															
Aerobic	$V_A$	3,750	18.00	18.00	3.60																																																															
Total	V	5,102	24.50	24.50																																																																
<b>[6] Geometry</b>																																																																				
(1) Basin Dimensions	Width 8.0 Length 63.0 Depth 5.5 Basins 2																																																																			
Cross Section	8.0*5.5 = 44.0 m <sup>2</sup> /Basin																																																																			
Hantzsch Subtraction	= 1.0 m <sup>2</sup> /Basin																																																																			
after Subtraction	44.0-1.0 = 43.0 m <sup>2</sup> /Basin																																																																			
Total Volume	43.0*63.0 = 2,709 m <sup>2</sup> /Basin 5,418 m <sup>3</sup> /Total																																																																			
(2) Partition of Basin	<table border="1"> <thead> <tr> <th>Item</th> <th>unit</th> <th>Anaerobic</th> <th>Anoxic</th> <th>Aerobic</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Cross Section</td> <td>m<sup>2</sup></td> <td colspan="3">43.0</td> <td></td> </tr> <tr> <td>Length required</td> <td>m</td> <td>3.6</td> <td>12.1</td> <td>43.6</td> <td>59.3</td> </tr> <tr> <td>Volume required per Basin</td> <td>m<sup>3</sup></td> <td>155</td> <td>521</td> <td>1,875</td> <td>2,551</td> </tr> <tr> <td>Total Volume required</td> <td>m<sup>3</sup></td> <td>310</td> <td>1,042</td> <td>3,750</td> <td>5,102</td> </tr> <tr> <td>Actual Cross Section</td> <td>m<sup>2</sup></td> <td>43.0</td> <td>43.0</td> <td>43.0</td> <td></td> </tr> <tr> <td>Actual Length</td> <td>m</td> <td>5.0</td> <td>13.0</td> <td>45.0</td> <td>63.0</td> </tr> <tr> <td>Actual Volume per Basin</td> <td>m<sup>3</sup></td> <td>215</td> <td>559</td> <td>1,935</td> <td>2,709</td> </tr> <tr> <td>Actual Total Volume</td> <td>m<sup>3</sup></td> <td>430</td> <td>1,118</td> <td>3,870</td> <td>5,418</td> </tr> <tr> <td>Actual Ratio of Volume</td> <td></td> <td>0.38</td> <td>1.00</td> <td>3.46</td> <td></td> </tr> <tr> <td>Actual Retention Time</td> <td>hour</td> <td>2.06</td> <td>5.37</td> <td>18.58</td> <td>26.01</td> </tr> </tbody> </table>	Item	unit	Anaerobic	Anoxic	Aerobic	Total	Cross Section	m <sup>2</sup>	43.0				Length required	m	3.6	12.1	43.6	59.3	Volume required per Basin	m <sup>3</sup>	155	521	1,875	2,551	Total Volume required	m <sup>3</sup>	310	1,042	3,750	5,102	Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0		Actual Length	m	5.0	13.0	45.0	63.0	Actual Volume per Basin	m <sup>3</sup>	215	559	1,935	2,709	Actual Total Volume	m <sup>3</sup>	430	1,118	3,870	5,418	Actual Ratio of Volume		0.38	1.00	3.46		Actual Retention Time	hour	2.06	5.37	18.58	26.01	
Item	unit	Anaerobic	Anoxic	Aerobic	Total																																																															
Cross Section	m <sup>2</sup>	43.0																																																																		
Length required	m	3.6	12.1	43.6	59.3																																																															
Volume required per Basin	m <sup>3</sup>	155	521	1,875	2,551																																																															
Total Volume required	m <sup>3</sup>	310	1,042	3,750	5,102																																																															
Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0																																																																
Actual Length	m	5.0	13.0	45.0	63.0																																																															
Actual Volume per Basin	m <sup>3</sup>	215	559	1,935	2,709																																																															
Actual Total Volume	m <sup>3</sup>	430	1,118	3,870	5,418																																																															
Actual Ratio of Volume		0.38	1.00	3.46																																																																
Actual Retention Time	hour	2.06	5.37	18.58	26.01																																																															
<b>[7] Equipment</b>																																																																				
(1) Ras Pumps																																																																				
Ras Ratio	60%																																																																			
Required Capacity	5,000 m <sup>3</sup> /day × 60% / 24 / 2 = 63 m <sup>3</sup> /Hr ⇒ 65 m <sup>3</sup> /Hr																																																																			
Number	2 Work 2 Standby																																																																			
(2) Circulation Pumps																																																																				
Ras Ratio	366%																																																																			
Required Capacity	5,000 m <sup>3</sup> /day × 366% / 24 / 4 = 190 m <sup>3</sup> /Hr ⇒ 190 m <sup>3</sup> /Hr																																																																			
Number	4 Work 2 Standby																																																																			
(3) SAS Pumps																																																																				
Excess Sludge	271 m <sup>3</sup> /day																																																																			
Sludge withdraw	12 Times/day																																																																			
Running Time	0.5 Hr/Time																																																																			
Required Capacity	271 m <sup>3</sup> /day / 12 / 0.5 / 2 = 22.60 m <sup>3</sup> /Hr ⇒ 23 m <sup>3</sup> /Hr																																																																			
Number	2 Work 2 Standby																																																																			

C-2 Process Cal EA&al 5MLD Talaghattapura Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

(4) Alum Solution Tank										
Number	2	W	+	0	S					
Alum concentration as crystal	10	%								
Gravity of dissolved dechlorine	1.05									
Required solution volume	214.89	kg / d		×	100	/	10	/	1.05 / 1000	
=	2.05				m3/d					
Volume of Tank	1.5				m3/tank					
Total Volume of Tanks	3.0				m3		(Duration=	1.47	day)	
(5) Mixer for Alum Solution Tank										
Number	2	W	+	0	S					
(6) Alum Dosing Pump										
Number	2	W	+	1	S					
Capacity	2.05	m3/d /		24	×	1000	/	2	×	2
	85.27	l/h/unit		⇒	90	l/h/unit				

**STP Process Calculation Supporting Report 12.2.3**

<b>6. Air Requirement at Average Flow</b>	
[1] Design Condition	
(1) AOR	AOR = 2,163 kg/day = 90.1 kg/h
Q <sub>in</sub> : Design Average Flow m <sup>3</sup> /d	5,000
Inlet bCOD : S <sub>0</sub>	578 mg/l
S=	S= 0.451 mg/l
Nox=	Nox 47.400 mg/l
P <sub>X,bio</sub> =	P <sub>X,b</sub> 884.5 kg VSS/d does not include nitrifying bacteria
R <sub>0</sub> =	R <sub>0</sub> = Q(S <sub>0</sub> -S-k(Nox-NOx))-1.42P <sub>X,bio</sub> +4.57Q·NOx
R <sub>0</sub> =	R <sub>0</sub> = 2,163 kg O <sub>2</sub> /d
	k= 2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{AOR \times C_s \cdot a \times 1.024^{20-T}}{\alpha \times F (\beta \cdot C_{sw}/C_s \cdot (P_b/P_a)a - C_A)}$
	C <sub>s</sub> : Saturated DO at sea level and 20 °C 9.09 mg/L
	C <sub>sw</sub> : Saturated DO at sea level and operating Temperature 9.09 mg/L at 20 °C
	20-T : 0.0 1.024 <sup>20-T</sup> : 1.0000
	C <sub>A</sub> : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1+0.40D <sub>j</sub> /P <sub>a</sub> 1.19357
	D <sub>j</sub> : Tank Liquid Depth 5.00 m
	P <sub>a</sub> : Standard absolute pressure at s 10.332 m
	P <sub>b</sub> : Absolute pressure at Plant Site Elevation m
	P <sub>b</sub> /P <sub>a</sub> : exp[-gM(z <sub>b</sub> -z <sub>a</sub> )/R*T] 0.900
	g : Acceleration due to Gravity 9.80665 m/s <sup>2</sup>
	M : Mole of Air 28.97 kg/kg-mole
	z <sub>b</sub> : Plant Site Elevation 900 m
	z <sub>a</sub> : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 293.15 Kelvin
	α : relative Transfer Rate to clean Water 0.65
	β : relative DO Saturation to clean Water 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{23,470}{4.2591} = 5,510.49 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Standard O <sub>2</sub> required at Field Conditions per Basin =	2,755 kg/day
(5) SOTE for the above Effective Aeration Depth	28.0 %
(6) Fraction of O <sub>2</sub> in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	15%
(9) Air required at Field Conditions per Basins	= 40,522 m <sup>3</sup> /day = 1,688.4 m <sup>3</sup> /hr
[2] Equipment	



C-2 Process Cal EA&al 5MLD Talaghattapura Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

(1) Air Blower					
Number	2	W	+	1	S
Required Capacity	1688.4	m <sup>3</sup> /Hr·Basin	/	1	unit/Basin
	= 1688.4	m <sup>3</sup> /h	⇒	1700	m <sup>3</sup> /h /Unit
Pressure	65	kPa			
Safety Factor	10	%			
Heat capacity ratio	1.4				
Atmospheric pressure at site elevation	91.234	kPa			
Total inlet pressure	89.234	kPa			
Volume rate of flow at inlet point	32.165	m <sup>3</sup> /min			
Total discharge pressure	156.234	kPa			
Overall adiabatic efficiency	0.65				
Inlet air temperature (min.)	15	°C			
Shaft power	45.477	kW			
Rated Output of Motor	50.024	kW	⇒	55	kW

C-2 Process Cal EA&al 5MLD Talaghattapura Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>7. Final Clarifire</b></p>			
<p>[1] <b>Design Condition</b></p>			
<p>(1) Design Wastewater Flow</p>	<p>Q= 5,000 m<sup>3</sup>/day</p>		
<p>(2) Water Temperature</p>	<p>T= 20.0 °C</p>		
<p>(3) MLSS</p>	<p>X<sub>ef</sub>= 3,000 mg/l</p>		
<p>(4) SVI</p>	<p>SVI= 300</p>		
<p>(5) Sedimentation Velocity</p>	$v = 4.899 \cdot 10^6 \cdot T^{(0.954)} \cdot X_{ef}^{(-1.354)} \cdot SVI^{(-0.77)}$ $= 4.899 \cdot 10^6 \cdot 20.0^{0.954} \cdot 3,000^{-1.354} \cdot 150^{-0.770}$ $= 20.7 \text{ m/day}$		
<p>(6) Surface Overflow Rate required</p>	$S' = v / (1.5 \cdot 1) = 20.7 / (1.5 \cdot 1.0) = 13.8 \text{ m}^3/\text{m}^2 \cdot \text{day}$	<p>→</p>	$12.0 \text{ m}^3/\text{m}^2 \cdot \text{day}$
<p>[2] <b>Geometry</b></p>			
<p>(1) Surface Area required</p>	$A = 5,000 / 12.0 = 417 \text{ m}^2$		
<p>(2) Demensions</p>	<p>Diameter                  Depth          Basin</p>		
	<p><b>16.5                          3.5                  2</b></p>		
<p>(3) Actual Surface Area</p>	$S = 16.5^2 \cdot 3.14 / 4 \cdot 2.0 = 428 \text{ m}^2$		
<p>(4) Surface Overflow Rate</p>	$S = 5,000 / 428 = 11.7 \text{ m}^3/\text{m}^2 \cdot \text{day}$		

**STP Process Calculation\_Supporting Report 12.2.3**

<b>8. Chlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Flow      5,000    m <sup>3</sup> /day      208.33    m <sup>3</sup> /h Peak Flow            12,500    m <sup>3</sup> /day      520.83    m <sup>3</sup> /h
(2) Contact Time	30    min
(3) Type of Chlorine	Cl <sub>2</sub> -GAS
(4) Design Chlorine Dosage Rate	10    mg/L
(5) Required Chlorine per day	Average Daily Flow    /    1000    ×            Design Chlorine Dosage Rate =    50.0    kg/d =    2.08    kg/h
<b>[2] Chlorination Contact Tank</b>	
(1) Volume required	Average Daily Flow    /    1440    ×    Contact Time =    104.2    m <sup>3</sup>
(2) Nos. of lanes	3    lanes
(3) Width of lane	1.50    m
(4) Length of lane	16.00    m
(5) Side Water Depth	1.50    m
(6) Nos. of Tanks	1    tank
(7) Total Width of Tank	5.30    m Approx..
(8) Average Velocity	Decant Flow    /    3600    /    Width    /    Depth =    208.33    /    3600    /    1.50    /    1.50 =    0.026    m/sec
(9) Total Volume	Width    ×    Length    ×    Depth    ×    Nos. of lanes    ×    Nos. of Tanks =    1.5    m    ×    16.0    m    ×    1.5    m =    108    m <sup>3</sup> >    104.2    m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Chlorine Dosing Condition	
Operation Dosage Rate -1	DC1      1 mg/L    10 mg/L
Average Dosage Rate -1	DC2      10 mg/L
(2) Chlorine Cylinder	
Type	-    Cylindrical Convexsd Container
Cylinder Capacity	Cc      928 kg/cylinder
Average Dosage Rate -1	q1      Chlorine -1 : Q <sub>T-D</sub> × DC2 × 10 <sup>-6</sup> × 10 <sup>3</sup> =    50 kg/day
Storage day	T      More than    15 days
Required Storage Capacity	EC1    D × T =    750 kg
Unit Number	EN1    EC1 / Cc =    0.8 cylinders
Maximum Operation Numbers	Vr1      ##### @ 20°C Standard temperature
Cl <sub>2</sub> -Gas Volatilize Rate	DC1      10 mg/L, Q <sub>T-D</sub> × q3 × 10 <sup>-3</sup> / 24 =    #####
Maximum Dosing Rate	EN2      DC1 / Vr1 =    0.7sets
(3) Chlorinator	
Type	Solution Feed Vacuum Type
Number	1    W    +    1    S
Operation Dosage Rate -1	Dq1    Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 5    kg/day to    125    kg/day
Required Dosage Rate	Chlorine -1 : Dq1 / (EN1 × 24) = Minimum                      Maximum 0.21    kg/hr                      5.2    kg/hr

**STP Process Calculation Supporting Report 12.2.3**

<p>(4) Chlorine Booster Pump</p> <p>Type</p> <p>Water Demand</p> <p>Chlorinator Discharge</p> <p>Water Demand</p> <p>Chlorinator Discharge</p> <p>Water Demand</p> <p>Water requiamet</p> <p>For Chlorin</p> <p>Booster Pump Type</p> <p>Number</p>	<p>Branchy on the water supply pipe</p> <p>Water requiamet for mixed Chlori</p> <table border="0"> <tr> <td>(kg/hr)</td> <td>1.0</td> <td>1.5</td> <td>2.0</td> <td>2.5</td> <td>3.0</td> <td>4.0</td> </tr> <tr> <td>(L/min)</td> <td>15</td> <td>20</td> <td>25</td> <td>30</td> <td>35</td> <td>40</td> </tr> <tr> <td>(kg/hr)</td> <td>5.0</td> <td>6.0</td> <td>10.0</td> <td>50.0</td> <td>100.0</td> <td>200.0</td> </tr> <tr> <td>(L/min)</td> <td>45</td> <td>50</td> <td>60</td> <td>300</td> <td>600</td> <td>1,200</td> </tr> </table> <p>Water requiamet -</p> <p>Qp1 Maximum dosage rate 5.2 kg/hr therefore 45 L/min</p> <p>Single suction volute pump</p> <p>1 W + 1 S</p>	(kg/hr)	1.0	1.5	2.0	2.5	3.0	4.0	(L/min)	15	20	25	30	35	40	(kg/hr)	5.0	6.0	10.0	50.0	100.0	200.0	(L/min)	45	50	60	300	600	1,200
(kg/hr)	1.0	1.5	2.0	2.5	3.0	4.0																							
(L/min)	15	20	25	30	35	40																							
(kg/hr)	5.0	6.0	10.0	50.0	100.0	200.0																							
(L/min)	45	50	60	300	600	1,200																							
<p><b>9. Dechlorination</b></p> <p><b>[1] Design Condition</b></p> <p>(1) Design Flow Rate</p> <p>(2) Contact Time</p> <p>(3) Type of Dechlorine</p> <p>(4) Free Residual Chlorine</p> <p>(5) Consumption per day</p> <p><b>[2] Dechlorination Contact Tank</b></p> <p>(1) Volume required</p> <p>(2) Width of lane</p> <p>(3) Length of lane</p> <p>(4) Side Water Depth</p> <p>(5) Nos. of Tanks</p> <p>(6) Total Volume</p> <p><b>[3] Equipment</b></p> <p>(1) Dechlorine Solution Tank</p> <p>Number</p> <p>Dechlorine concentration</p> <p>Gravity of dissolved dechlorine</p> <p>Required solution volume</p> <p>Volume of Tank</p> <p>Total Volume of Tanks</p> <p>(2) Mixer for Dechlorine Solution Tank</p> <p>Number</p> <p>(3) Dechlorine Dosing Pump</p> <p>Number</p> <p>Capacity</p>	<p>Average Daily Flow 5,000 m<sup>3</sup>/day</p> <p>10 min</p> <p>Sodium Thiosulfate (Na<sub>2</sub>S<sub>2</sub>O<sub>3</sub> · 5H<sub>2</sub>O)</p> <p>1.0 mg/L assumed value</p> <p>Average Daily Flow / 1000 × Free Residual Chlorine × 1.75</p> <p>× 1.5 (safety factor)</p> <p>= 13.13 kg/d</p> <p>= 0.547 kg/h</p> <p>Average Flow Rate / 60 × Contact Time</p> <p>= 34.7 m<sup>3</sup></p> <p>5.30 m</p> <p>5.00 m</p> <p>1.50 m</p> <p>1 tank</p> <p>Width × Length × Depth</p> <p>= 5.3 m × 5.0 m × 1.5 m</p> <p>= 40 m<sup>3</sup> &gt; 34.7 m<sup>3</sup></p> <p>1 W + 0 S</p> <p>10 %</p> <p>1.10</p> <p>13.13 kg/d × 100 / 10 / 1.10 / 1000</p> <p>= 0.12 m<sup>3</sup>/d</p> <p>0.2 m<sup>3</sup>/tank</p> <p>0.2 m<sup>3</sup> (Duration= 1.68 day)</p> <p>1 W + 0 S</p> <p>1 W + 1 S</p> <p>0.30 m<sup>3</sup>/d / 24 × 1000 / 1</p> <p>12.43 l/h/unit ⇒ 13.0 l/h/unit</p>																												

C-2 Process Cal. EA&al 5MLD Talaghattapura Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>10. Centrifuge</b>  <b>[1] Design Condition</b>                  (1) Type of Dewatering                  (2) Generated Sludge                  (3) Design Polyelectrolyte Dosage                  (4) Volume of Thickend Sludge                  (5) Consistency of Dewatered Sludge                  (6) Operation Time</p>	<p>Centrifuge                  2,169 kg/day                  Polyelectrolyte 5 kg/t-DS·day                  271.2 m<sup>3</sup>/day                  82 %                  12 hours/day (6 days per week)</p>
<p><b>[2] Volume of Centrifuges</b></p>	<p><u>Digested Solids</u>                  Operation Time × No. × Operation/week  <math display="block">= \frac{271.2}{12 \times 1} \times \frac{7}{6} = 26.4</math>                 → 27 m<sup>3</sup>/hour</p>
<p><b>[3] Dewatered Solids</b></p>	<p>Digested Sludge × ( 1 + Injection Rate)                  = 2,169 × ( 1 + 0.0050 )                  = 2,180 kg/day</p>
<p><b>[4] Dewatered Cake Volume</b></p>	<p>Dewatered Solids × <math>\frac{100}{100 - \frac{\text{Moisture Content}}{7}}</math>                  × 6 days per week  <math display="block">= 2,180 \times \frac{100}{100 - \frac{82}{6}} \times \frac{7}{6}</math>                 = 14.13 t/day                  apparent specific gravity 1.00  <math display="block">\frac{14.13}{1.00} = 14.1 \text{ m}^3/\text{day}</math></p>
<p><b>[5] Polyelectrolyte</b>                  (1) Design Polyelectrolyte Dosage                  (2) Required Polyelectrolyte                  (3) Dissolving concentration                  (4) Volume of Polyelectrolyte solution</p>	<p>Polyelectrolyte 5 kg/t-DS·day                  10.85 kg/day                  0.20 %                  5.42 m<sup>3</sup>/day</p>

C-2 Process Cal.EA&al 5MLD Talaghattapura Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

[6] <b>Equipment</b>								
(1) Centrifuge								
Capacity	27	m <sup>3</sup> /hr						
Number	1	W	+	1	S			
(2) Centrifuge Feed Pumps								
Capacity	27	m <sup>3</sup> /hr						
Number	1	W	+	1	S			
(3) Polyelectrolyte Dosing Pumps								
Volume of Polyelectrolyte solution	5.42	m <sup>3</sup> /day						
Operation Time	12	hours/day		(6 days per week)				
Safety Factor	1.5							
Number	1	W	+	1	S			
Required Capacity	5.42	m <sup>3</sup> /da; ×	7	/	6	/	12	/
	=	0.53	m <sup>3</sup> /Hr					
Specification Capacity	0.53	m <sup>3</sup> /Hr	×	1.5				
	=	0.791	m <sup>3</sup> /Hr	⇒	0.80	m <sup>3</sup> /Hr /Unit		
(4) Polyelectrolyte dosing System								
Tanks Dimensions								
	Width	1.5	m	×	Length	1.5	m	
	×	Depth	1.8	m	×	2		
	=	8.1	m <sup>3</sup>					
Retention Time of Tanks	8.10	m <sup>3</sup>	/	0.53	m <sup>3</sup> /Hr	/	1	
	=	15.361	Hr					
Number	2	W	+	0	S			

C-2 Process Cal, EA&al 5MLD Talaghattapura, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>11. Centrifuge Feed Sump</b>	
<b>[1] Design Condition</b>	
(1) Generated Thickend Sludge	2,169 kg/day
(2) Solids Consistency	0.80 %
(3) Volume of Excess Sludge	$\begin{aligned} & \text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3} \\ = & 2,169 \times \frac{100}{0.80} \times 10^{-3} \\ = & 271 \text{ m}^3/\text{day} \\ = & 11.30 \text{ m}^3/\text{h} \end{aligned}$
(4) Sludge feed flow rate	27 m <sup>3</sup> /h × 1 = 27 m <sup>3</sup> /h
(5) Centrifuge Operation Time	12 hours/day ( 6 days per week)
<b>[2] Geometry</b>	
(1) Basin Dimensions	$\begin{aligned} & \text{Width } 4.5 \text{ m} \times \text{Length } 5.0 \text{ m} \\ & \times \text{Depth } 3.5 \text{ m} \times 2 \\ = & 157.5 \text{ m}^3 \end{aligned}$
<b>[3] Equipment</b>	
(1) Mixers for Centrifuge Feed Sumps	Required Volume
Required Volume	157.5 m <sup>3</sup>
Number	1 W + 1 S

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Digestion Tank + Centrifugal Dewatering)

Table -1 Input Data

1. Calculation Manner	2	1:Premise that the quality of supernatants are same level removed with inlet sewage 2:Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency	2	1:Total Removal Ratio 2:Outlet Water Quality(input 1or2)
In case of 1 : input data		(%)
In case of 2 : input data	#REF!	(mg/l)
3. Selection of Excess Sludge Generation	2	1:Consideration of Solid Matter Only 2:Consideration of Converting of Solved BOD(input 1or2)
In case of 1 : input data (Sludge generation)		Sludge generation ratio per removal SS(%) T2=Q4·S4-(a·S <sub>BOD</sub> +b·S1-c·θ·XA)·Q3/10 <sup>6</sup> ·(Excess sludge generation formula)
In case of 2 : input data	a	0.4 a:Converting ratio of solved BOD(mgMLSS/mgBOD)
	b	0.9 b:Converting ratio of SS(mgMLSS/mgSS)
	c	0.05 c:Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)
	SBOD	234.50 S <sub>BOD</sub> :Solved BOD quality at inlet reactor
	XA	3,000 XA:MLSS concentration(mg/l)
θ	1 θ:Hydraulic retention time(day)	


Table -2 Basic Conditions

Sewage Flow and Quality	Sludge Moisture and Recovery Ratio	Digestion Tank Conditions	Chemical Conditions for Dewatering
·Inlet flow : Q <sub>0</sub> (m <sup>3</sup> /D)	5,000	·Primary sludge moisture ratio : W1(%)	0.0
·Inlet quality : S <sub>0</sub> (mg/l)	450	·Excess sludge moisture ratio : W2(%)	99.2
·Total removal ratio : A1(%)	-	·Thickened sludge moisture ratio : W3(%)	99.2
·Effluent quality : S1(mg/l)	10.0	·Digested sludge moisture ratio : W4(%)	99.2
·Sludge generation ratio per removal SS : S1(%)	-	·Dewatered sludge moisture ratio : W5(%)	82.0
		·Removal ratio in primary tank : A2(%)	0.0
		·Recovery ratio in sludge thickener : A3(%)	100.0
		·Recovery ratio in sludge digester : A4(%)	100.0
		·Recovery ratio in dewatering : A5(%)	95.0
		·Content of organics in thickened sludge : A6(%)	75.0
		·Digestion ratio : A7(%)	#REF!
		·Digestion gas generation : A8(Nm <sup>3</sup> /kgVS)	
		·Chemical dosage : A9(%)	0.5
		·Chemical dissolve concentration : A10(%)	0.2

Table -3 Material Balance Calculation

Q(m <sup>3</sup> /day)	5,000	5,265	0	5,265	271	4,994	271	0	271	0	5	277	12	265	265	265	4,994	0
T(t·DS/day)	2,250	2,359	0,000	2,359	2,169	0,050	2,169	0,000	2,169	0,000	0,011	2,180	2,071	0,109	0,109	0,109	0,050	0,140
S(mg/l)	450	448	0	448	8,000	10	8,000	#DIV/0!	8,000	0	2,000	7,882	180,000	411	411		10	
X(T5/T0*100)	100	104.8	0.0	104.8	96.4	2.2	96.4	0.0	96.4	0.0	0.5	96.9	92.1	4.8	4.8		2.2	6.2

Figure -1 Material Balance Model




Calculation Formula						
·Q0=Input Data	·Q3=Q1-Q2	·Q6=T6*100/(100-W3)	·Q9=Q6	·Q12=Q9+Q11	·Q15=Q7+Q10+Q14	·Q5-1=Q5-Q11
·T0=Q0*S0*10 <sup>-6</sup>	·T3=T0*(100-A2)/100	·T6=(T2+T4)*A3/100	·T9=(T6-T8)*A4/100	·T12=T9+T11	·T15=T7+T10+T14	·T5-1=T5-T11
·S0=Input Data	·S3=T3*10 <sup>-6</sup> /Q3	·S6=10 <sup>-6</sup> *Q3/(100-W3)/100	·S9=T9*10 <sup>-6</sup> /Q9	·S12=T12*10 <sup>-6</sup> /Q12	·S15=T15*10 <sup>-6</sup> /Q15	·S5-1=S5
·Q1=Q0+Q15	·Q4=T4*100/(100-W2)	·Q7=(Q2+Q4)-Q6	·Q10=Q6-Q8-Q9	·Q13=T13*100/(100-W5)		
·T1=T0+T15	·T4=余剰汚泥発生式による	·T7=(T2+T4)-T6	·T10=T6-T8-T9	·T13=T12*A5/100		
·S1=T1*10 <sup>-6</sup> /Q1	·S4=10 <sup>-6</sup> *Q4/(100-W2)/100	·S7=T7*10 <sup>-6</sup> /Q7	·S10=T10*10 <sup>-6</sup> /Q10	·S13=10 <sup>-6</sup> *Q13/(100-W5)/100		
·Q2=T2*100/(100-W1)	·Q5=Q3-Q4*(T3-T5)/T4	·Q8=0	·Q11=T10*A9/A10	·Q14=Q12-Q13		
·T2=T1-T3	·T5=Q5*ST/10 <sup>-6</sup>	·T8=T6*A6*A7/10 <sup>-4</sup>	·T11=Q11*S11/10 <sup>-6</sup>	·T14=T12-T13		
·S2=10 <sup>-6</sup> *Q2/(100-W1)/100	·S5=St	#REF!	·S11=10 <sup>-4</sup> *A10	·S14=T14*10 <sup>-6</sup> /Q14		



Material Balance Sheet SD4

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Sheet  
[3MLD STP]



D-1 Process Cal. EA&al 8MLD Somapura Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**Design Condition**

Item	8MLD STP-MPS			
(1) Design Flow for the year 2049	Flow Rate			
		m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s
	Average Daily	####	500	0.139
	Max Dayly	####	500	0.139
	Max Hourly Peak factor 2.25	####	1125	0.313
(1) Design Flow for the year 2034	Flow Rate			
		m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s
	Average Daily	8,000	333	0.093
	Max Dayly	8,000	333	0.093
	Max Hourly Peak factor 2.25	####	750	0.208

**1. Inlet Chamber**

Item	8MLD STP-MPS			
[1] Design Condition				
(1) Design Flow for the year 2049	Max Hourly	=	27,000	m <sup>3</sup> /d
		=	0.313	m <sup>3</sup> /sec
(2) Inlet Pipe				
Pipe Diameter	•	×		
Gradient			%	
Roughness Coefficient	n=	0.013	(Manning Formula)	
Full Pipe Flow Rate			m <sup>3</sup> /s	
(3) Influent Water Level	+		m	
[2] Geometory				
(1) Number of Basins	1	Basin		
(2) Depth of Basin	0.600	m	Approx.	
(3) Width of Basin	2.100	m	Approx.	
(4) Length of Basin	2.500	m	Approx.	
(5) Volume required of Basin	0.600	×	2.100	×
			2.500	=
				0.5
				m <sup>3</sup>
(6) Retention Time	0.600	×	2.100	×
			2.500	/
				0.313
				×
				1
	=	10.06	sec	
(7) Basin Demensions	Width	2.100	m	×
				Length
				2.500
				m
	×	Depth	0.600	m

D-1 Process Cal. EA&al 8MLD Somapura Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**2. Coarse Screen Channel**

Item	8MLD STP-MPS					
[1] Geometry						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Width	0.500	m				
Height	0.750	m				
Floor Level	+	5.000	m			
Bottom	+	0.000	m			
Influent Water Level	+	0.500	m			
Velocity	0.313	/		0.500	/	0.500 / 2
where Design Flow for the year 2049	=	0.626	<	1.000	m/sec	OK
Velocity	0.208	/		0.500	/	0.500 / 1
where Design Flow for the year 2034	=	0.832	<	1.000	m/sec	OK
(2) Screen Channel						
Number	2.0	Main	+	1.0	Bypass	
Width	0.800	m				
Side Water Depth	0.600	m				
Velocity	0.313	/		0.800	/	0.600 / 2
where Design Flow for the year 2049	=	0.326	≐	0.450	m/sec	OK
Velocity	0.208	/		0.800	/	0.600 / 1
where Design Flow for the year 2034	=	0.433	<	0.450	m/sec	OK
(3) Channel Dimensions	Width	0.8	m	×	Length	6.0 m
	×	SWD	0.6	m		
[3] Equipment						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Dimension	Width	0.5	m	×	Height	0.75 m
Design Water Level		m				
(2) Coarse Screens (Main Channel)						
Number	2	W	+	0	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	0.8	m				
Width of side plate	50	mm				
Side Water Depth	0.6	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.313	/		0.700	/	0.550 / 2
	×	( 20	+	9 ) /	20	
	=	0.589	<	0.800	m/sec	OK
Velocity through screen	0.208	/		0.700	/	0.550 / 1
where Design Flow for the year 2034	×	( 20	+	9 ) /	20	
	=	0.783	<	0.800	m/sec	OK
(3) Coarse Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	50	mm				
Bar Thickness	9	mm				
Channel Width	0.8	m				
Side Water Depth	0.6	m				
Velocity through screen	0.313	/		0.800	/	0.600 / 2
where Design Flow for the year 2049	×	( 50	+	9 ) /	50	
	=	0.385	<	0.800	m/sec	OK
Velocity through screen	0.208	/		0.800	/	0.600 / 1
where Design Flow for the year 2034	×	( 50	+	9 ) /	50	
	=	0.511	<	0.800	m/sec	OK

D-1 Process Cal. EA&al 8MLD Somapura Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**3. Raw Sewage Sump**

Item	8MLD STP-MPS	
[2] Geometory		
(1) Raw Sewage Sump		
Number	1	Basin
Dia	9.50	m
Pump Operating Depth	1.000	m
Retention Time whe Design Flow for the year 2049	$( \frac{9.50^2 \times \pi}{4} \times 1.000 ) / 0.313$	$/ 60 = 3.77 > 3.75$ min (=minimum time of one pump cycle) OK
Retention Time whe Design Flow for the year 2034	$( \frac{9.50^2 \times \pi}{4} \times 1.000 ) / 0.208$	$/ 60 = 5.68 > 3.75$ min (=minimum time of one pump cycle) OK
High Water Level	+ 0.000	m
Pump Off Level	+ -1.000	m
[3] Equipment		
(1) Sewage Pumps 1		
Number	2 W	+ 1 S
Bore Diameter	200	mm
Discharge Flow : 40% Q* 2 whe Design Flow for the year 2034	$0.208 \times 3600$	$\Rightarrow 300 \Rightarrow 300$ m <sup>3</sup> /Hr
Total Head	15.0	m
(2) Sewage Pumps 2		
Number	1 W	+ 1 S
Bore Diameter	150	mm
Discharge Flow : 20% Q* 1 whe Design Flow for the year 2034	$0.208 \times 3600$	$\Rightarrow 150 \Rightarrow 150$ m <sup>3</sup> /Hr
Total Head	15.0	m

D-1 Process Cal. EA&al 8MLD Somapura Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

Item	8MLD STP																																																		
<b>1. STP Design Condition</b>																																																			
(1) Design Flow Rate	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th style="text-align: center;">m3/d</th> <th style="text-align: center;">m3/h</th> <th style="text-align: center;">m3/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td style="text-align: center;">8,000</td> <td style="text-align: center;">333.33</td> <td style="text-align: center;">0.093</td> </tr> <tr> <td>Max Daily</td> <td style="text-align: center;">8,000</td> <td style="text-align: center;">333.33</td> <td style="text-align: center;">0.093</td> </tr> <tr> <td>Max Hourly Peak factor 2.25</td> <td style="text-align: center;">18,000</td> <td style="text-align: center;">750.00</td> <td style="text-align: center;">0.208</td> </tr> </tbody> </table>											m3/d	m3/h	m3/s	Average Daily	8,000	333.33	0.093	Max Daily	8,000	333.33	0.093	Max Hourly Peak factor 2.25	18,000	750.00	0.208																									
	m3/d	m3/h	m3/s																																																
Average Daily	8,000	333.33	0.093																																																
Max Daily	8,000	333.33	0.093																																																
Max Hourly Peak factor 2.25	18,000	750.00	0.208																																																
(2) Design Water Quality	<p style="text-align: right;">Unit: mg/L</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th colspan="2">TP</th> </tr> <tr> <th>NH<sub>4</sub>-N</th> <th>Org-N</th> <th>NOx-N</th> <th>D-P</th> <th>P-P</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td style="text-align: center;">350</td> <td style="text-align: center;">800</td> <td style="text-align: center;">450</td> <td style="text-align: center;">45.5</td> <td style="text-align: center;">17.5</td> <td style="text-align: center;">7</td> <td style="text-align: center;">5</td> <td style="text-align: center;">2</td> </tr> <tr> <td>Outlet</td> <td style="text-align: center;">10</td> <td style="text-align: center;">50</td> <td style="text-align: center;">10</td> <td style="text-align: center;">1</td> <td style="text-align: center;">0</td> <td style="text-align: center;">9</td> <td style="text-align: center;">1</td> <td style="text-align: center;">1</td> </tr> <tr> <td>Removal rate</td> <td style="text-align: center;">97.1%</td> <td style="text-align: center;">93.7%</td> <td style="text-align: center;">97.8%</td> <td colspan="3" style="text-align: center;">85.7%</td> <td colspan="2" style="text-align: center;">71.4%</td> </tr> </tbody> </table>											BOD	COD	SS	T-N			TP		NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P	Inlet	350	800	450	45.5	17.5	7	5	2	Outlet	10	50	10	1	0	9	1	1	Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%	
	BOD	COD	SS	T-N			TP																																												
				NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P																																											
Inlet	350	800	450	45.5	17.5	7	5	2																																											
Outlet	10	50	10	1	0	9	1	1																																											
Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%																																												
<b>2. Inlet Chamber</b>																																																			
<b>[1] Design Condition</b>																																																			
(1) Design Flow Rate	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 40%;"></td> <td style="width: 10%; text-align: center;">Max Hourly</td> <td style="width: 10%; text-align: center;">=</td> <td style="width: 10%; text-align: center;">18,000</td> <td style="width: 10%; text-align: center;">m3/day</td> <td colspan="6"></td> </tr> <tr> <td></td> <td></td> <td style="text-align: center;">=</td> <td style="text-align: center;">0.208</td> <td style="text-align: center;">m3/sec</td> <td colspan="6"></td> </tr> </table>											Max Hourly	=	18,000	m3/day									=	0.208	m3/sec																									
	Max Hourly	=	18,000	m3/day																																															
		=	0.208	m3/sec																																															
<b>[2] Geometry</b>																																																			
(1) Number of Basins	1 Basin																																																		
(2) Depth of Basin	1.500 m																																																		
(3) Width of Basin	2.100 m																																																		
(4) Length of Basin	2.000 m																																																		
(5) Volume required of Basin	1.500 × 2.100 × 2.000 = 1.6 m3																																																		
(6) Retention Time	1.500 × 2.100 × 2.000 / 0.208 = 30.29 sec																																																		
(7) Basin Dimensions	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 15%;">Width</td> <td style="width: 10%;">2.100</td> <td style="width: 10%;">m</td> <td style="width: 10%;">×</td> <td style="width: 10%;">Length</td> <td style="width: 10%;">2.000</td> <td style="width: 10%;">m</td> <td colspan="4"></td> </tr> <tr> <td></td> <td>×</td> <td>Depth</td> <td></td> <td>1.500</td> <td></td> <td>m</td> <td colspan="4"></td> </tr> </table>										Width	2.100	m	×	Length	2.000	m						×	Depth		1.500		m																							
Width	2.100	m	×	Length	2.000	m																																													
	×	Depth		1.500		m																																													

D-1 Process Cal. EA&al 8MLD Somapura Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Wastewater Flow	$\begin{aligned} \text{Max Hourly} &= 18,000 \text{ m}^3/\text{d} \\ &= 0.208 \text{ m}^3/\text{sec} \end{aligned}$
[2] Geometory	
(1) Inlet Gate	
Number	2 Main + 1 Bypass
Width	0.400 m
Height	0.600 m
Floor Level	+ 2.000 m
Bottom	+ 0.000 m
Influent Water Level	+ 0.300 m
Velocity	$\begin{aligned} &0.208 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 0.300 \text{ } \swarrow \quad 2 \\ = &0.867 \text{ } \div \quad 1.000 \text{ m/sec} \end{aligned}$
(2) Screen Channel	
Number	2 Main + 1 Bypass
Width	0.800 m
Side Water Depth	0.400 m
Velocity	$\begin{aligned} &0.208 \text{ } \swarrow \quad 0.800 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 2 \\ = &0.325 \text{ } \div \quad 0.450 \text{ m/sec} \end{aligned}$
(3) Channel Dimensions	$\begin{aligned} \text{Width} &0.8 \text{ m} \times \text{Length} &6.0 \text{ m} \\ &\times \text{SWD} &0.4 \text{ m} \end{aligned}$
[3] Equipment	
(1) Inlet Gate	
Number	2 W + 1 S
Dimension	Width 0.4 m × Height 0.60 m
Design Water Level	2.00 m
(2) Fine Screens (Main Channel)	
Number	2 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	0.8 m
Width of side plate	50 mm
Side Water Depth	0.4 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	$\begin{aligned} &0.208 \text{ } \swarrow \quad 0.700 \text{ } \swarrow \quad 0.350 \text{ } \swarrow \quad 2 \\ &\times ( \quad 6 \quad + \quad 2 \quad ) / \quad 6 \\ = &0.566 < \quad 0.800 \text{ m/sec} \end{aligned}$
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	0.8 m
Side Water Depth	0.4 m
Velocity through screen	$\begin{aligned} &0.208 \text{ } \swarrow \quad 0.800 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 2 \\ &\times ( \quad 20 \quad + \quad 9 \quad ) / \quad 20 \\ = &0.471 < \quad 0.800 \text{ m/sec} \end{aligned}$

D-1 Process Cal. EA&al 8MLD Somapura Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<b>4. Grit Chamber</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Peak flow = 18,000 m <sup>3</sup> /day = 0.208 m <sup>3</sup> /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0111 m/sec = 960 m <sup>3</sup> /m <sup>2</sup> /day
(4) Average Velocity	0.3 m/sec
<b>[2] Grit Chamber</b>	
(1) Surface Area required	0.208 / 0.0111 = 18.74 m <sup>2</sup>
(2) Number of Basins	1 S + 1 W
(3) Surface Area required/Basin	18.74 / 1 = 18.74 m <sup>2</sup>
(4) Length of Basin	18.74 ^0.5 = 4.3 m → 4.5 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.208 × 60 sec / 1 = 12.5 m <sup>3</sup>
(7) Depth required	12.5 / 4.5 / 4.5 = 0.616 m
(8) Basin Dimensions	Width 4.5 m × Length 4.5 m × Depth 0.6 m (Freeboard 0.3m)
(9) Retention Time	4.5 × 4.5 × 0.6 / 0.208 × 1 = 60.00 sec
(10) Surface Overflow Rate at Peak Flow	18,000 / 4.5 / 4.5 / 1 = 888.9 < 960 m <sup>3</sup> /m <sup>2</sup> /day
<b>[3] Parshall Flume</b>	
(1) Design Flow Rate	Q= 208.000 l/sec
(2) Throat width	W= 0.450 m
(3) Water depth Ha	Ha= ( Q / 2264 / W ) <sup>2/3</sup> Ha= 0.347 m
(4) Crest Level	+ m ≐ Minimum water level at downstream channel
(5) Water level at the crest	+ 0.347 m
(6) Channel bottom level	+ m
(7) Upstream Channel width	1.500 m
(8) SWD of Upstream Channel	0.700 m
(9) Average velocity at upstream channel	0.198 m/sec
(10) Total Length of channel	10.000 m
<b>[4] Inlet Weir Gate</b>	
(1) Number	2 Units
(2) Weir Width	0.600 m
(3) Stroke	0.450 m
(4) Overflow Height	0.400 m
(5) Overflow Height (actual)	( 0.208 / 1.840 / 0.600 / 2 ) <sup>2/3</sup> = 0.207 < 0.400 m

D-1 Process Cal. EA&al 8MLD Somapura\_Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>5. Reactor</b>																																																								
<b>[1] Design Condition</b>																																																								
(1) Design Wastewater Flow	Q = 8,000 m <sup>3</sup> /day (summer) Q' = 8,000 m <sup>3</sup> /day (Winter)																																																							
(2) Design Sewage Quality																																																								
Inlet BOD	350 mg/l																																																							
Outlet BOD	10.0 mg/l																																																							
Inlet S-BOD	235 mg/l assumed as 67% of BOD																																																							
Inlet COD	800 mg/l																																																							
Inlet bCOD : S <sub>0</sub>	578 mg/l																																																							
Inlet nbCOD	223 mg/l																																																							
bCOD/BOD	1.65																																																							
Inlet S-COD : sCOD	271 mg/l																																																							
Inlet rbCOD	231 mg/l bCOD*40%																																																							
Inlet sbCOD	347 mg/l bCOD*60%																																																							
Outlet S-COD : nbsCODE	40 mg/l																																																							
Inlet nbpCOD : nbpCOD	183 mg/l = TCOD-bCOD-nbsCODE																																																							
Inlet SS	450 mg/l																																																							
Inlet VSS	383 mg/l assumed as 85% of TSS																																																							
: VSS <sub>COD</sub>	1.38 gCOD/gVSS = TCOD-sCOD/VSS																																																							
: nbVSS	131.96 gnbVSS/m <sup>3</sup> = nbpCOD/VSS <sub>COD</sub>																																																							
: iTSS	67.50 gnbVSS/m <sup>3</sup> = TSS-VSS																																																							
Inlet T-N	70 mg/l																																																							
Inlet TKN	70 mg/l																																																							
Inlet NH <sub>4</sub> -N	45.0 mg/l																																																							
Inlet T-P	7 mg/l																																																							
Inlet D-P	5 mg/l																																																							
Inlet Alkalinity as CaCO <sub>3</sub>	380 mg/l																																																							
Outlet Kjeldahl N	1.0 mg/l																																																							
Outlet NH <sub>4</sub> -N	1.0 mg/l																																																							
Outlet NO <sub>3</sub> -N	9.0 mg/l																																																							
Outlet T-P	2 mg/l																																																							
Outlet D-P	1 mg/l																																																							
(3) Water Temperature	T = 20.0 °C																																																							
(4) Safety Factor for Nitrogen	SF = 1.5																																																							
(5) Return Sludge Concentration	R <sub>s</sub> = 8,000 mg/l																																																							
(6) MLSS MLVSS	X <sub>TSS</sub> = 3,000 mg/l																																																							
(7) DO in the Reactor	2 mg/L																																																							
<b>[2] Design Value for perfect Nitrification of Nitrification Process</b>																																																								
(1) Activated sludge design kinwtic coefficients at 20°C																																																								
	<table border="1"> <thead> <tr> <th>Coefficient</th> <th>Unit</th> <th>COD oxidatio</th> <th>NH<sub>4</sub> oxidatio</th> <th>NO<sub>2</sub> oxidatio</th> </tr> </thead> <tbody> <tr> <td>μ<sub>max</sub></td> <td>gVSS/gVSS · d</td> <td>6.000</td> <td>0.900</td> <td>1.000</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>mg/L</td> <td>8.000</td> <td>0.500</td> <td>0.200</td> </tr> <tr> <td>Y</td> <td>gVSS/g substrate oxidized</td> <td>0.450</td> <td>0.150</td> <td>0.050</td> </tr> <tr> <td>b</td> <td>gVSS/gVSS · d</td> <td>0.120</td> <td>0.170</td> <td>0.170</td> </tr> <tr> <td>fd</td> <td>unitless</td> <td>0.150</td> <td>0.150</td> <td>0.150</td> </tr> <tr> <td>K<sub>O<sub>2</sub></sub></td> <td>mg/L</td> <td>0.200</td> <td>0.500</td> <td>0.900</td> </tr> <tr> <td>θ Value</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>μ<sub>max</sub></td> <td>unitless</td> <td>1.070</td> <td>1.072</td> <td>1.063</td> </tr> <tr> <td>b</td> <td>unitless</td> <td>1.040</td> <td>1.029</td> <td>1.029</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>unitless</td> <td>1.000</td> <td>1.000</td> <td>1.000</td> </tr> </tbody> </table> <p>Wastwater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF &amp; EDDY/AECOM)</p>	Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio	μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200	Y	gVSS/g substrate oxidized	0.450	0.150	0.050	b	gVSS/gVSS · d	0.120	0.170	0.170	fd	unitless	0.150	0.150	0.150	K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900	θ Value					μ <sub>max</sub>	unitless	1.070	1.072	1.063	b	unitless	1.040	1.029	1.029	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000
Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio																																																				
μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200																																																				
Y	gVSS/g substrate oxidized	0.450	0.150	0.050																																																				
b	gVSS/gVSS · d	0.120	0.170	0.170																																																				
fd	unitless	0.150	0.150	0.150																																																				
K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900																																																				
θ Value																																																								
μ <sub>max</sub>	unitless	1.070	1.072	1.063																																																				
b	unitless	1.040	1.029	1.029																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000																																																				
(2) μ <sub>AOB</sub>	μ <sub>AOB</sub> = 0.3100 g/g · d = μ <sub>max, AOB</sub> [S <sub>NH<sub>4</sub></sub> / (S <sub>NH<sub>4</sub></sub> + K <sub>NH<sub>4</sub></sub> )] [S <sub>O</sub> / (S <sub>O</sub> + K <sub>O, AOB</sub> )] - b <sub>AOB</sub>																																																							
μ <sub>max, AOB, T</sub>	μ <sub>max, AOB, T</sub> = 0.9000 g/g · d = μ <sub>max</sub> * 1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900																																																							
b <sub>AOB, T</sub>	b <sub>AOB, T</sub> = 0.1700 = b * 1.029 <sup>(T-20)</sup> b at 20°C = 0.170																																																							
S <sub>NH<sub>4</sub></sub>	S <sub>NH<sub>4</sub></sub> = 1.0000 mg/l																																																							
DO	DO = 2.0000 mg/l																																																							
K <sub>O, AOB</sub>	K <sub>O, AOB</sub> = 0.5000 mg/l																																																							



D-1 Process Cal. EA&al 8MLD Somapura Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

(2) Design SRT	SRT= 4.8387 day = $1/\mu_{AOB} \times SF$ $\Rightarrow$ 5.0000 day
(3) Biomass production	
P <sub>X,VSS</sub>	P <sub>X,VSS</sub> = 2501.630 kg/d = P <sub>X,bio</sub> +Q(nbVSS)
P <sub>X,TSS</sub>	P <sub>X,TSS</sub> = 3296.800 kg/d = P <sub>X,bio</sub> /0.85+Q(nbVSS)+Q(TSS <sub>0</sub> -VSS <sub>0</sub> )+5*Q*Al
S	S= 0.4507 mg/l = $Ks[1+b_H(SRT)]/[SRT(\mu_m-b_H)-1]$
b <sub>H</sub>	b <sub>H</sub> = 0.1200 = $b*1.04^{(T-20)}$ b at 20°C = 0.120
Y <sub>H</sub>	Y <sub>H</sub> = 0.4500 gVSS/g bCOD
μ <sub>m,T</sub>	μ <sub>m,T</sub> = 6.0000 g/g·d = $\mu_{max}*1.04^{(T-20)}$ μ max at 20°C = 6.000
Y <sub>n</sub>	Y <sub>n</sub> = 0.150 gVSS/g Nox
NO <sub>x</sub>	NO <sub>x</sub> = 47.400 mg/l
P <sub>X,bio,VSS</sub>	P <sub>X,bio,VSS</sub> = 1445.959 kg VSS/d = $Q \cdot Y_H(S_0-S)/[1+b_H(SRT)] + f_d \cdot b_H \cdot QY_H(S_0-S)SRT/[1+b_H(SRT)]$ $+ QY_n(Nox)[2+b_{AOB}(SRT)]$ 1298.361 = $Q \cdot Y_H(S_0-S)/[1+b_H(SRT)]$ 116.852 = $f_d \cdot b_H \cdot QY_H(S_0-S)SRT/[1+b_H(SRT)]$ 30.746 = $QY_n(Nox)[1+b_{AOB}(SRT)]$
NO <sub>x</sub>	NO <sub>x</sub> = 47.311 mg/l = $TKN-Ne-0.12P_{X,bio}/Q$
(4) Required Aeration Tank Volume	
V <sub>a</sub>	V <sub>a</sub> = 5,495 m <sup>3</sup>
τ	τ = 16.48 hr = V <sub>a</sub> /Q × 24 $\Rightarrow$ 18.00 hr
X <sub>VSS</sub> · V <sub>a</sub>	X <sub>VSS</sub> · V <sub>a</sub> = 12,508 kg VSS = P <sub>X,VSS</sub> · SRT
X <sub>TSS</sub> · V <sub>a</sub>	X <sub>TSS</sub> · V <sub>a</sub> = 16,484 kg TSS = P <sub>X,TSS</sub> · SRT
F/M	F/M= 0.224 kgBOD/kgMLVSS
FractionVSS=	FractionVSS 0.759
MLVSS=	MLVSS= 2276 mg/L
(5) BODloading	BODloading 0.510 kg/m <sup>3</sup> ·d
(6) Observed Yield	
Y <sub>obs,TSS</sub>	Y <sub>obs,TSS</sub> = 1.178 gTSS/gBOD
Y <sub>obs,VSS</sub>	Y <sub>obs,VSS</sub> = 0.894 gVSS/gBOD
bCODremoved=	bCODremov= 4.616 kg/d
(7) effluent NO <sub>2</sub> -N	NO <sub>2</sub> -N= 0.2315 mg/l = $Ks[1+b_{NOB}(SRT)]/[SRT(\mu_{NOB}-b_{NOB})-1]$
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700 = $b*1.029^{(T-20)}$ b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 1.0000 g/g·d = $\mu_{max}*1.04^{(T-20)}$ μ max at 20°C = 1.000
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.6897 g/g·d = $\mu_{max,NOB}[S_0/(S_0+K_{O2,NOB})]$
	S <sub>0</sub> = 2.000 mg/l
	K <sub>O2,NOB</sub> = 0.900 mg/l
(8) effluent NH <sub>4</sub> -N	NH <sub>4</sub> -N= 0.5286 mg/l = $Ks[1+b_{NOB}(SRT)]/[SRT(\mu_{NOB}-b_{NOB})-1]$
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700 = $b*1.029^{(T-20)}$ b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 0.9000 g/g·d = $\mu_{max}*1.072^{(T-20)}$ μ max at 20°C = 0.900
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.7200 g/g·d = $\mu_{max,NOB}[S_0/(S_0+K_{O2,NOB})]$
	S <sub>0</sub> = 2.000 mg/l
	K <sub>O2,NOB</sub> = 0.500 mg/l
(9) Ratio of Return Sludge	8,000·Rr/(1+Rr)= 3,000 mg/L 3,000/(8,000-3,000)= 0.60 Rr = 0.60

D-1 Process Cal. EA&al 8MLD Somapura Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

<b>[3] Design for Nitrification and Denitrification Process</b>																					
(1) Active biomass concentration	$X_b = Q \cdot (SRT) / V \cdot Y_H (S_0 - S) [1 + b_H (SRT)]$ = 1,181.47 mg/l																				
(2) IR ratio	$IR = NO_x / Ne - 1.0 - R$ = 3.66																				
(3) The amount of NO <sub>3</sub> -N fed to the anoxic tank	$Nox\ feed = (IR + R) \cdot Q \cdot Ne$ = 306,484.88 kg/d																				
(4) The anoxic tank volume	$V_{nor} = 549\ m^3 = V_a \times 10\%$ $V_{nor} = 1,667\ m^3 \quad \tau_{DN} = 5.000\ h$																				
(5) F/M <sub>b</sub>	F/M <sub>b</sub> = 1.42 g/g·d																				
(6) Fraction of rbCOD	40.00% = rbCOD/bCOD																				
	<table border="1"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b<sub>0</sub></th> <th>b<sub>1</sub></th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>	Percent rdCOD(%)	SDNR equation coefficients		b <sub>0</sub>	b <sub>1</sub>	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162
Percent rdCOD(%)	SDNR equation coefficients																				
	b <sub>0</sub>	b <sub>1</sub>																			
10	0.186	0.078																			
20	0.213	0.118																			
30	0.235	0.141																			
40	0.242	0.152																			
50	0.270	0.162																			
(8) SDNR <sub>b</sub>	$SDNR_b = 0.296\ g/g \cdot d = b_0 + b_1 [\ln(F/M_b)]$ $b_0 = 0.242$ $b_1 = 0.152$																				
(8) SDNR	$SDNR = 0.110\ g/g \cdot d = SDNR_b (MLVSS_r / MLVSS)$ $SDNR_{adj} = 0.212\ g/g \cdot d = SDNR_r - 0.029 \ln(F/M_b) - 0.012 \quad IR=3-4$ $= SDNR_r - 0.0166 \ln(F/M_b) - 0.078 \quad IR=2$ $SDNR_t = 0.296\ g/g \cdot d = SDNR_b \cdot \theta^{(F/M_b - 20)} \quad \theta = 1.026$																				
(9) NO <sub>r</sub>	$NO_r = 416,794.46\ kg/d = N_{nox} \cdot SDNR \cdot X_b$ $> Nox\ feed = 306,485\ kg/d$																				
(10) Alkalinity to be added to maintain pH7	-108.33 mg/l Influent Alk 380.00 mg/l Alk used 338.44 mg/l = 7.14 × Nox Alk produced 136.77 mg/l = 3.57 × (NO <sub>x</sub> - NO <sub>xe</sub> ) Alk to maintain 70.00 mg/l																				
<b>[4] Design of Phosphorus Removal Process</b>																					
(1) Removal T-P	3.13 mg/l																				
P in waste sludge	px = 1.00%																				
Generated waste sludge	Px <sub>vss</sub> = 2501.630 kg/d																				
Rmval Phosphorus	25.01630421 kg/d																				
(2) Effluent T-P without Al	3.87 mg/l																				
(3) Required Al to initial soluble phosphorus ratio	1.00 mol/mol																				
(4) Required Al dosing rate	3.48 mg/l as Al																				
	42.98 mg/l as crystal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> · 18H <sub>2</sub> O																				
(5) Required Aluminum Sulfate	343.82 kg/d																				
(6) Required Aluminum Sulfate solutic 10%	3.27 m <sup>3</sup> /d																				
	136.44 L/H																				
(7) Additional sludge	139.39 kg/d																				

**STP Process Calculation\_Supporting Report 12.2.3**

**[5] Reactor**

(1) Total volume of Aeration Basins

$$V_A = Q \cdot \theta_a / 24$$

$$= 6,000 \text{ m}^3$$

(2) Total volume of Anoxic Basins

$$V_{DN} = Q \cdot \theta_{DN} / 24$$

$$= 1,667 \text{ m}^3$$

Item	Volume required	Retention Time required		Ratio of Volume	
		Summer	Winter		
unit	m <sup>3</sup>	hour	hour		
Anaerobic	V <sub>AN</sub>	500	1.50	1.50	0.30
Anoxic	V <sub>DN</sub>	1,667	5.00	5.00	1.00
Aerobic	V <sub>A</sub>	6,000	18.00	18.00	3.60
Total	V	8,167	24.50	24.50	

**[6] Geometry**

(1) Basin Dimensions

Width      Length      Depth      Basins  
8.0      96.0      5.5      2

Cross Section

$$8.0 \times 5.5 = 44.0 \text{ m}^2/\text{Basin}$$

Hantzschn Subtraction

$$= 1.0 \text{ m}^2/\text{Basin}$$

after Subtraction

$$44.0 - 1.0 = 43.0 \text{ m}^2/\text{Basin}$$

Total Volume

$$43.0 \times 96.0 = 4,128 \text{ m}^2/\text{Basin} \quad 8,256 \text{ m}^3/\text{Total}$$

(2) Partition of Basin

Item	unit	Anaerobic	Anoxic	Aerobic	Total
Cross Section	m <sup>2</sup>	43.0			
Length required	m	5.8	19.4	69.8	95.0
Volume required per Basin	m <sup>3</sup>	250	834	3,000	4,084
Total Volume required	m <sup>3</sup>	500	1,667	6,000	8,167
Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0	
Actual Length	m	6.0	20.0	70.0	96.0
Actual Volume per Basin	m <sup>3</sup>	258	860	3,010	4,128
Actual Total Volume	m <sup>3</sup>	516	1,720	6,020	8,256
Actual Ratio of Volume		0.30	1.00	3.50	
Actual Retention Time	hour	1.55	5.16	18.06	24.77

**[7] Equipment**

(1) Ras Pumps

Ras Ratio

60%

Required Capacity

$$8,000 \text{ m}^3/\text{day} \times \frac{60\%}{24} = 200 \text{ m}^3/\text{Hr}$$

Number

= 100 m<sup>3</sup>/Hr ⇒ 100 m<sup>3</sup>/Hr  
2 Work  
2 Standby

(2) Circulation Pumps

Ras Ratio

366%

Required Capacity

$$8,000 \text{ m}^3/\text{day} \times \frac{366\%}{24} = 1,220 \text{ m}^3/\text{Hr}$$

Number

= 305 m<sup>3</sup>/Hr ⇒ 305 m<sup>3</sup>/Hr  
4 Work  
2 Standby

(3) SAS Pumps

Excess Sludge

434 m<sup>3</sup>/day

Sludge withdraw

12 Times/day

Running Time

0.5 Hr/Time

Required Capacity

$$434 \text{ m}^3/\text{day} \times \frac{12}{24} \times 0.5 = 108.5 \text{ m}^3/\text{Hr}$$

Number

= 36.15 m<sup>3</sup>/Hr ⇒ 40 m<sup>3</sup>/Hr  
2 Work  
2 Standby

D-1 Process Cal. EA&al 8MLD Somapura Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

(4) Alum Solution Tank										
Number	2	W	+	0	S					
Alum concentration as crystal	10 %									
Gravity of dissolved dechlorine	1.05									
Required solution volume	343.82 kg / d		×	100	/	10	/	1.05	/	1000
	=	3.27		m3/d						
Volume of Tank	2.6			m3/tank						
Total Volume of Tanks	5.2			m3		(Duration=	1.59	day)		
(5) Mixer for Alum Solution Tank										
Number	2	W	+	0	S					
(6) Alum Dosing Pump										
Number	2	W	+	1	S					
Capacity	3.27 m3/d	/	24	×	1000	/	2	×	2	
	136.44 l/h/unit		⇒	140	l/h/unit					

D-1 Process Cal. EA&a1 8MLD Somapura Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>6. Air Requirement at Average Flow</b>	
[1] Design Condition	
(1) AOR	AOR = 3,461 kg/day = 144.2 kg/h
Q <sub>in</sub> : Design Average Flow m <sup>3</sup> /d	8,000
Inlet bCOD : S <sub>0</sub>	578 mg/l
S=	S= 0.451 mg/l
Nox=	Nox 47.400 mg/l
P <sub>X,bio</sub> =	P <sub>X,b</sub> 1,415.2 kg VSS/d does not include nitrifying bacteria
R <sub>0</sub> =	R <sub>0</sub> = Q(S <sub>0</sub> -S-k(Nox-NOx))-1.42P <sub>X,bio</sub> +4.57Q·NOx
R <sub>0</sub> =	R <sub>0</sub> = 3,461 kg O <sub>2</sub> /d
	k= 2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{AOR \times C_s \cdot a \times 1.024^{20-T}}{\alpha \times F (\beta \cdot C_{SW}/C_s \cdot (P_b/P_a)a - C_A)}$
	C <sub>S</sub> : Saturated DO at sea level and 20 °C 9.09 mg/L
	C <sub>SW</sub> : Saturated DO at sea level and operating Temperature 9.09 mg/L at 20 °C
	20-T : 0.0 1.024 <sup>20-T</sup> : 1.0000
	C <sub>A</sub> : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1+0.40D <sub>j</sub> /P <sub>a</sub> 1.19357
	D <sub>j</sub> : Tank Liquid Depth 5.00 m
	P <sub>a</sub> : Standard absolute pressure at s 10.332 m
	P <sub>b</sub> : Absolute pressure at Plant Site Elevation m
	P <sub>b</sub> /P <sub>a</sub> : exp[-gM(z <sub>b</sub> -z <sub>a</sub> )/R*T] 0.900
	g : Acceleration due to Gravity 9.80665 m/s <sup>2</sup>
	M : Mole of Air 28.97 kg/kg-mole
	z <sub>b</sub> : Plant Site Elevation 900 m
	z <sub>a</sub> : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 293.15 Kelvin
	α : relative Transfer Rate to clean Water 0.65
	β : relative DO Saturation to clean Water 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{37,552}{4.2591} = 8,816.79 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Standard O <sub>2</sub> required at Field Conditions per Basin =	4,408 kg/day
(5) SOTE for the above Effective Aeration Depth	28.0 %
(6) Fraction of O <sub>2</sub> in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	15%
(9) Air required at Field Conditions per Basins	= 64,836 m <sup>3</sup> /day = 2,701.5 m <sup>3</sup> /hr
[2] Equipment	

Air Requirement at Average Flow 12/21

D-1 Process Cal. EA&amp;al 8MLD Somapura\_Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

(1) Air Blower					
Number	4	W	+	2	S
Required Capacity	2701.5	m <sup>3</sup> /Hr·Basin	/	2	unit/Basin
	= 1350.7	m <sup>3</sup> /h	⇒	1400	m <sup>3</sup> /h /Unit
Pressure	65	kPa			
Safety Factor	10	%			
Heat capacity ratio	1.4				
Atmospheric pressure at site elevation	91.234	kPa			
Total inlet pressure	89.234	kPa			
Volume rate of flow at inlet point	26.488	m <sup>3</sup> /min			
Total discharge pressure	156.234	kPa			
Overall adiabatic efficiency	0.65				
Inlet air temperature (min.)	15	°C			
Shaft power	37.451	kW			
Rated Output of Motor	41.196	kW	⇒	45	kW

D-1 Process Cal. EA&al 8MLD Somapura Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>7. Final Clarifire</b></p>			
<p>[1] <b>Design Condition</b></p>			
<p>(1) Design Wastewater Flow</p>	<p>Q= 8,000 m<sup>3</sup>/day</p>		
<p>(2) Water Temperature</p>	<p>T= 20.0 °C</p>		
<p>(3) MLSS</p>	<p>X<sub>ef</sub>= 3,000 mg/l</p>		
<p>(4) SVI</p>	<p>SVI= 300</p>		
<p>(5) Sedimentation Velocity</p>	<p> <math>v = 4.899 \cdot 10^6 \cdot T^{(0.954)} \cdot X_{ef}^{(-1.354)} \cdot SVI^{(-0.77)}</math>  <math>= 4.899 \cdot 10^6 \cdot 20.0^{0.954} \cdot 3,000^{-1.354} \cdot 150^{-0.770}</math>  <math>= 20.7 \text{ m/day}</math> </p>		
<p>(6) Surface Overflow Rate required</p>	<p> <math>S' = v / (1.5 \cdot 1) = 20.7 / (1.5 \cdot 1.0) = 13.8 \text{ m}^3/\text{m}^2 \cdot \text{day}</math>  <math>\rightarrow 12.0 \text{ m}^3/\text{m}^2 \cdot \text{day}</math> </p>		
<p>[2] <b>Geometry</b></p>			
<p>(1) Surface Area required</p>	<p>A = 8,000 / 12.0 = 667 m<sup>2</sup></p>		
<p>(2) Demensions</p>	<p style="text-align: center;">                 Diameter                  Depth          Basin  <b>21.0                                  3.5                  2</b> </p>		
<p>(3) Actual Surface Area</p>	<p>S = 21.0<sup>2</sup> * 3.14 / 4 * 2.0 = 693 m<sup>2</sup></p>		
<p>(4) Surface Overflow Rate</p>	<p>S = 8,000 / 693 = 11.5 m<sup>3</sup>/m<sup>2</sup> · day</p>		

D-1 Process Cal. EA&al 8MLD Somapura Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<b>8. Chlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 8,000 m <sup>3</sup> /day 333.33 m <sup>3</sup> /h Peak Flow 18,000 m <sup>3</sup> /day 750.00 m <sup>3</sup> /h
(2) Contact Time	30 min
(3) Type of Chlorine	Cl <sub>2</sub> -GAS
(4) Design Chlorine Dosage Rate	10 mg/L
(5) Required Chlorine per day	Average Daily Flow / 1000 × Design Chlorine Dosage Rate = 80.0 kg/d = 3.33 kg/h
<b>[2] Chlorination Contact Tank</b>	
(1) Volume required	Average Daily Flow / 1440 × Contact Time = 166.7 m <sup>3</sup>
(2) Nos. of lanes	3 lanes
(3) Width of lane	2.00 m
(4) Length of lane	14.00 m
(5) Side Water Depth	2.00 m
(6) Nos. of Tanks	1 tank
(7) Total Width of Tank	6.80 m Approx..
(8) Average Velocity	Decant Flow / 3600 / Width / Depth = 333.33 / 3600 / 2.00 / 2.00 = 0.023 m/sec
(9) Total Volume	Width × Length × Depth × Nos. of lanes × Nos. of Tanks = 2.0 m × 14.0 m × 2.0 m × 3 × 1 = 168 m <sup>3</sup> > 166.7 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Chlorine Dosing Condition	
Operation Dosage Rate -1	DC1 10 mg/L
(2) Chlorine Cylinder	
Type	- Cylindrical Convexsd Container
Cylinder Capacity	Cc 928 kg/cylinder
Average Dosage Rate -1	q1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 80 kg/day
Maximum Dosage Rate -1	q3 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 180 kg/day
Storage day	T More than 15 days
Required Storage Capacity	EC1 D × T = 1,200 kg
Unit Number	EN1 EC1 / Cc = 1.3 cylinders
Maximum Operation Numbers	
Cl <sub>2</sub> -Gas Volatilize Rate	Vr1 ##### @ 20 <sup>o</sup> C Standard temperature
Maximum Dosing Rate	DC1 10 mg/L, Q <sub>T-D</sub> × q3 × 10 <sup>-3</sup> / 24 = 7.50 kg/h
Operation Numbers	EN2 DC1 / Vr1 = 0.9sets
Number	2 W + 2 S
(3) Chlorinator	
Type	Solution Feed Vacuum Type
Number	1 W + 1 S
Operation Dosage Rate -1	Dq1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 180 kg/day
Required Dosage Rate	Chlorine -1 : Dq1 / (EN1 × 24) = Minimum Maximum 0.00 kg/hr 7.5 kg/hr



D-1 Process Cal. EA&al 8MLD Somapura Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

(4) Chlorine Booster Pump	Branchy on the water supply pipe
Type	Water requiamet for mixsed Chlori
Water Demand	(kg/hr) 1.0 1.5 2.0 2.5 3.0 4.0
Chlorinator Discharge	(L/min) 15 20 25 30 35 40
Water Demand	(kg/hr) 5.0 6.0 10.0 50.0 100.0 200.0
Chlorinator Discharge	(L/min) 45 50 60 300 600 1,200
Water Demand	-
Water requiamet	
For Chlorin	Qp1 Maximum dosage rat 7.5 kg/hr therefore 60 L/min
Booster Pump Type	Single suction volute pump
Number	1 W + 1 S
<b>9. Dechlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 8,000 m <sup>3</sup> /day
(2) Contact Time	10 min
(3) Type of Dechlorine	Sodium Thiosulfate (Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 5H <sub>2</sub> O)
(4) Free Residual Chlorine	1.0 mg/L assumed value
(5) Consumption per day	Average Daily Flow / 1000 × Free Residual Chlorine × 1.75 × 1.5 (safety factor) = 21.0 kg/d = 0.88 kg/h
<b>[2] Dechlorination Contact Tank</b>	
(1) Volume required	Average Flow Rate / 60 × Contact Time = 55.6 m <sup>3</sup>
(2) Width of lane	6.80 m
(3) Length of lane	5.00 m
(4) Side Water Depth	2.00 m
(5) Nos. of Tanks	1 tank
(6) Total Volume	Width × Length × Depth = 6.8 m × 5.0 m × 2.0 m = 68 m <sup>3</sup> > 55.6 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Dechlorine Solution Tank	
Number	1 W + 0 S
Dechlorine concentration	10 %
Gravity of dissolved dechlorine	1.10
Required solution volume	21.00 kg / d × 100 / 10 / 1.10 / 1000 = 0.19 m <sup>3</sup> /d
Volume of Tank	0.200 m <sup>3</sup> /tank (= 0.5 mW × 0.5 mL × 0.8 mH)
Total Volume of Tanks	0.200 m <sup>3</sup> (Duration= 1.05 day)
(2) Mixer for Dechlorine Solution Tank	
Number	2 W + 0 S
(3) Dechlorine Dosing Pump	
Number	1 W + 1 S
Capacity	0.43 m <sup>3</sup> /d / 24 × 1000 / 1 17.90 l/h/unit ⇒ 18 l/h/unit

D-1 Process Cal. EA&al 8MLD Somapura Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<p><b>10. Centrifuge</b></p> <p><b>[1] Design Condition</b></p> <p>(1) Type of Dewatering</p> <p>(2) Generated Sludge</p> <p>(3) Design Polyelectrolyte Dosage</p> <p>(4) Volume of Thickend Sludge</p> <p>(5) Consistency of Dewatered Sludge</p> <p>(6) Operation Time</p> <p><b>[2] Volume of Centrifuges</b></p> <p><b>[3] Dewatered Solids</b></p> <p><b>[4] Dewatered Cake Volume</b></p> <p><b>[5] Polyelectrolyte</b></p> <p>(1) Design Polyelectrolyte Dosage</p> <p>(2) Required Polyelectrolyte</p> <p>(3) Dissolving concentration</p> <p>(4) Volume of Polyelectrolyte solution</p>	<p>Centrifuge 3,471 kg/day</p> <p>Polyelectrolyte 5 kg/t-DS·day</p> <p>433.8 m<sup>3</sup>/day</p> <p>82 %</p> <p>12 hours/day (6 days per week)</p> <p><u>Digested Solids</u>  <math display="block">\frac{\text{Operation Time} \times \text{No.}}{12 \times 2} \times \frac{433.8}{6} = 21.1</math> <math display="block">\rightarrow 22 \text{ m}^3/\text{hour}</math></p> <p>Digested Sludge × ( 1 + Injection Rate)          = 3,471 × ( 1 + 0.0050 )          = 3,488 kg/day</p> <p>Dewatered Solids × <math>\frac{100}{100 - \frac{\text{Moisture Content}}{7}}</math>  <math display="block">= 3,488 \times \frac{100}{100 - 82} \times \frac{7}{6}</math> <math display="block">= 22.61 \text{ t/day}</math>         apparent specific gravity 1.00  <math display="block">\frac{22.61}{1.00} = 22.6 \text{ m}^3/\text{day}</math></p> <p>Polyelectrolyte 5 kg/t-DS·day          17.35 kg/day          0.20 %          8.68 m<sup>3</sup>/day</p>
--	---

D-1 Process Cal. EA&al 8MLD Somapura Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

<b>[6] Equipment</b>	
(1) Centrifuge	
Capacity	22 m <sup>3</sup> /hr
Number	2 W + 1 S
(2) Centrifuge Feed Pumps	
Capacity	22 m <sup>3</sup> /hr
Number	2 W + 1 S
(3) Polyelectrolyte Dosing Pumps	
Volume of Polyelectrolyte solution	8.68 m <sup>3</sup> /day
Operation Time	12 hours/day (6 days per week)
Safety Factor	1.5
Number	2 W + 1 S
Required Capacity	8.68 m <sup>3</sup> /da × 7 / 6 / 12 / 2
	= 0.42 m <sup>3</sup> /Hr
Specification Capacity	0.42 m <sup>3</sup> /Hr × 1.5
	= 0.633 m <sup>3</sup> /Hr ⇒ 0.70 m <sup>3</sup> /Hr /Unit
(4) Polyelectrolyte dosing System	
Preparation time for solution	3 hr
Required dry polymer	17.35 kg/day × 7 / 6 / 12
	= 1.69 kg/hr
	= 5.06 kg per one batch
Feedong time per one batch	30 min
Capacity of Dry polymer Feeder	10 kg/h
Tanks Dimensions	Width 1.5 m × Length 1.5 m × Depth 1.5 m × 2
	= 6.8 m <sup>3</sup>
Retention Time of Tank	3.40 m <sup>3</sup> /tank / 0.42 m <sup>3</sup> /Hr / 2
	= 4.030 Hr > 3 Hr
Number	2 W + 0 S

D-1 Process Cal. EA&al 8MLD Somapura Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<b>11. Centrifuge Feed Sump</b>	
<b>[1] Design Condition</b>	
(1) Generated Thickend Sludge	3,471 kg/day
(2) Solids Consistency	0.80 %
(3) Volume of Thickened Sludge	$\begin{aligned} & \text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3} \\ = & 3,471 \times \frac{100}{0.80} \times 10^{-3} \\ = & 434 \text{ m}^3/\text{day} \\ = & 18.08 \text{ m}^3/\text{h} \end{aligned}$
(4) Sludge feed flow rate	22 m <sup>3</sup> /h × 2 = 44 m <sup>3</sup> /h
(5) Centrifuge Operation Time	12 hours/day ( 6 days per week)
<b>[2] Geometry</b>	
(1) Basin Dimensions	$\begin{aligned} & \text{Width } 6.0 \text{ m} \times \text{Length } 6.0 \text{ m} \\ & \times \text{Depth } 4.0 \text{ m} \times 2 \\ = & 288.0 \text{ m}^3 \end{aligned}$
<b>[3] Equipment</b>	
(1) Mixers for Centrifuge Feed Sumps	
Required Volume	288.0 m <sup>3</sup>
Number	1 W + 1 S

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Digestion Tank + Centrifugal Dewatering)

Table -1 Input Data

1. Calculation Manner	2	1:Premise that the quality of supernatants are same level removed with inlet sewage 2:Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency	2	1:Total Removal Ratio 2:Outlet Water Quality(input 1or2)
In case of 1 : input data		(%)
In case of 2 : input data	#REF!	(mg/l)
3. Selection of Excess Sludge Generation	2	1:Consideration of Solid Matter Only 2:Consideration of Converting of Solved BOD(input 1or2)
In case of 1 : input data (Sludge generation)		Sludge generation ratio per removal SS(%)
	a	0.4 T2=Q4·S4=(a·S <sub>BOD</sub> +b·S1-c·θ·XA)·Q3/10 <sup>6</sup> · (Excess sludge generation formula)
	b	0.9 a:Converting ratio of solved BOD(mgMLSS/mgBOD)
	c	0.05 b:Converting ratio of SS(mgMLSS/mgSS)
In case of 2 : input data	SBOD	234.50 c:Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)
	XA	3,000 S <sub>BOD</sub> :Solved BOD quality at inlet reactor
	θ	1 XA:MLSS concentration(mg/l)
		θ:Hydraulic retention time(day)


Table -2 Basic Conditions

Sewage Flow and Quality	Sludge Moisture and Recovery Ratio	Digestion Tank Conditions	Chemical Conditions for Dewatering
· Inlet flow : Q <sub>0</sub> (m <sup>3</sup> /D)	8,000	· Primary sludge moisture ratio : W1(%)	0.0
· Inlet quality : S <sub>0</sub> (mg/l)	450	· Excess sludge moisture ratio : W2(%)	99.2
· Total removal ratio : A1(%)	-	· Thickened sludge moisture ratio : W3(%)	99.2
· Effluent quality : S1(mg/l)	10.0	· Digested sludge moisture ratio : W4(%)	99.2
· Sludge generation ratio per removal SS : S1(%)	-	· Dewatered sludge moisture ratio : W5(%)	82.0
		· Removal ratio in primary tank : A2(%)	0.0
		· Recovery ratio in sludge thickener : A3(%)	100.0
		· Recovery ratio in sludge digester : A4(%)	100.0
		· Recovery ratio in dewatering : A5(%)	95.0
		· Content of organics in thickened sludge : A6(%)	75.0
		· Digestion ratio : A7(%)	#REF!
		· Digestion gas generation : A8(Nm <sup>3</sup> /kgVS)	
		· Chemical dosage : A9(%)	0.5
		· Chemical dissolve concentration : A10(%)	0.2

Table -3 Material Balance Calculation

	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	手入力(要取束)			16	17	
Q(m <sup>3</sup> /day)	8,000	8,424	0	8,424	434	7,990	434	0	0	434	0	9	443	18	424	424					7,990	0
T(t·DS/day)	3,600	3,774	0.000	3,774	3,471	0.080	3,471	0.000	0.000	3,471	0.000	0.017	3,488	3,314	0.174	0.174	0.174				0.080	0.223
S(mg/l)	450	448	0	448	8,000	10	8,000	#DIV/0!	0	8,000	0	2,000	7,882	180,000	411	411					10	
X(T5/T0*100)	100	104.8	0.0	104.8	96.4	2.2	96.4	0.0	0.0	96.4	0.0	0.5	96.9	92.0	4.8	4.8					2.2	6.2

Figure -1 Material Balance Model




Calculation Formula						
· Q0=Input Data	· Q3=Q1-Q2	· Q6=T6*100/(100-W3)	· Q9=Q6	· Q12=Q9+Q11	· Q15=Q7+Q10+Q14	· Q5-1=Q5-Q11
· T0=Q0*S0*10 <sup>-6</sup>	· T3=T0*(100-A2)/100	· T6=(T2+T4)*A3/100	· T9=(T6-T8)*A4/100	· T12=T9+T11	· T15=T7+T10+T14	· T5-1=T5-T11
· S0=Input Data	· S3=T3*10 <sup>-6</sup> /Q3	· S6=10 <sup>-6</sup> *Q3/(100-W3)/100	· S9=T9*10 <sup>-6</sup> /Q9	· S12=T12*10 <sup>-6</sup> /Q12	· S15=T15*10 <sup>-6</sup> /Q15	· S5-1=S5
· Q1=Q0+Q15	· Q4=T4*100/(100-W2)	· Q7=(Q2+Q4)-Q6	· Q10=Q6-Q8-Q9	· Q13=T13*100/(100-W5)		
· T1=T0+T15	· T4=余剰汚泥発生式による	· T7=(T2+T4)-T6	· T10=T6-T8-T9	· T13=T12*A5/100		
· S1=T1*10 <sup>-6</sup> /Q1	· S4=10 <sup>-6</sup> *Q4/(100-W2)/100	· S7=T7*10 <sup>-6</sup> /Q7	· S10=T10*10 <sup>-6</sup> /Q10	· S13=10 <sup>-6</sup> *Q13/(100-W5)/100		
· Q2=T2*100/(100-W1)	· Q5=Q3-Q4*(T3-T5)/T4	· Q8=0	· Q11=T10*A9/A10	· Q14=Q12-Q13		
· T2=T1-T3	· T5=Q5*ST/10 <sup>-6</sup>	· T8=T6*A6*A7/10 <sup>-4</sup>	· T11=Q11*S11/10 <sup>-6</sup>	· T14=T12-T13		
· S2=10 <sup>-6</sup> *Q2/(100-W1)/100	· S5=St	#REF!	· S11=10 <sup>-4</sup> *A10	· S14=T14*10 <sup>-6</sup> /Q14		

Material Balance Sheet SD4

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Sheet  
[8MLD STP]



D-2 Process Cal EA&al 13MLD Hemigepura Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

**Design Condition**

Item	13MLD STP-TSPS			
(1) Design Flow for the year 2049	Flow Rate			
		m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s
	Average Daily	####	833	0.231
	Max Dayly	####	833	0.231
	Max Hourly Peak factor 2.25	####	1875	0.521
(1) Design Flow for the year 2034	Flow Rate			
		m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s
	Average Daily	####	542	0.150
	Max Dayly	####	542	0.150
	Max Hourly Peak factor 2.25	####	1219	0.339

**1. Inlet Chamber**

Item	13MLD STP-TSPS			
[1] Design Condition				
(1) Design Flow for the year 2049	Max Hourly	=	45,000	m <sup>3</sup> /d
		=	0.521	m <sup>3</sup> /sec
(2) Inlet Pipe				
Pipe Diameter	•	×		
Gradient			%	
Roughness Coefficient	n=	0.013	(Manning Formula)	
Full Pipe Flow Rate			m <sup>3</sup> /s	
(3) Influent Water Level	+		m	
[2] Geometory				
(1) Number of Basins	1	Basin		
(2) Depth of Basin	0.600	m	Approx.	
(3) Width of Basin	2.500	m	Approx.	
(4) Length of Basin	2.500	m	Approx.	
(5) Volume required of Basin	0.600	×	2.500	×
			2.500	= 0.6 m <sup>3</sup>
(6) Retention Time	0.600	×	2.500	×
			2.500	/ 0.521 × 1
	=	7.20	sec	
(7) Basin Demensions	Width	2.500	m	×
				Length 2.500 m
	×	Depth	0.600	m

D-2 Process Cal EA&al 13MLD Hemigepura Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

**2. Coarse Screen Channel**

Item	13MLD STP-TSPS					
[1] Geometry						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Width	0.600	m				
Height	0.900	m				
Floor Level	+	5.000	m			
Bottom	+	0.000	m			
Influent Water Level	+	0.600	m			
Velocity	0.521	/		0.600	/	0.600 / 2
where Design Flow for the year 2049	=	0.724	<	1.000	m/sec	OK
Velocity	0.339	/		0.600	/	0.600 / 2
where Design Flow for the year 2034	=	0.471	<	1.000	m/sec	OK
(2) Screen Channel						
Number	2.0	Main	+	1.0	Bypass	
Width	1.000	m				
Side Water Depth	0.600	m				
Velocity	0.521	/		1.000	/	0.600 / 2
where Design Flow for the year 2049	=	0.434	≠	0.450	m/sec	OK
Velocity	0.339	/		1.000	/	0.600 / 2
where Design Flow for the year 2034	=	0.283	<	0.450	m/sec	OK
(3) Channel Dimensions	Width	1.0	m	×	Length	6.0 m
			×	SWD	0.6	m
[3] Equipment						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Dimension	Width	0.6	m	×	Height	0.9 m
Design Water Level	8.0	m				
(2) Coarse Screens (Main Channel)						
Number	2	W	+	0	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	1.0	m				
Width of side plate	50	mm				
Side Water Depth	0.6	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.521	/		0.900	/	0.550 / 2
	× (	20	+	9	) /	20
	=	0.763	<	0.800	m/sec	OK
Velocity through screen	0.339	/		0.900	/	0.550 / 2
where Design Flow for the year 2034	× (	20	+	9	) /	20
	=	0.497	<	0.800	m/sec	OK
(3) Coarse Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	50	mm				
Bar Thickness	9	mm				
Channel Width	1.0	m				
Side Water Depth	0.6	m				
Velocity through screen	0.521	/		1.000	/	0.600 / 2
where Design Flow for the year 2049	× (	50	+	9	) /	50
	=	0.512	<	0.800	m/sec	OK
Velocity through screen	0.339	/		1.000	/	0.600 / 2
where Design Flow for the year 2034	× (	50	+	9	) /	50
	=	0.333	<	0.800	m/sec	OK



D-2 Process Cal EA&aI 13MLD Hemigepura Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

**3. Raw Sewage Sump**

Item	13MLD STP-TSPS	
[2] Geometory		
(1) Raw Sewage Sump		
Number	1	Basin
Dia	11.00	m
Pump Operating Depth	1.300	m
Retention Time whe Design Flow for the year 2049	$( \frac{11.00^2 \times \pi}{4} \times 1.300 ) / 0.521 / 60$	$= 3.95 > 3.75$ min (=minimum time of one pump cycle) OK
Retention Time whe Design Flow for the year 2034	$( \frac{11.00^2 \times \pi}{4} \times 1.300 ) / 0.339 / 60$	$= 6.07 > 3.75$ min (=minimum time of one pump cycle) OK
High Water Level	+ 0.000	m
Pump Off Level	+ -1.300	m
[3] Equipment		
(1) Sewage Pumps 1		
Number	2 W	+ 1 S
Bore Diameter	300	mm
Discharge Flow : 40% Q* 2 whe Design Flow for the year 2034	$0.339 \times 3600 \times 40.0\%$	$Q \Rightarrow 488 \Rightarrow 490$ m3/Hr
Total Head	15.0	m
(2) Sewage Pumps 2		
Number	1 W	+ 1 S
Bore Diameter	200	mm
Discharge Flow : 20% Q* 1 whe Design Flow for the year 2034	$0.339 \times 3600 \times 20.0\%$	$Q \Rightarrow 244 \Rightarrow 245$ m3/Hr
Total Head	15.0	m

D-2 Process Cal EA&aI 13MLD Hemigepura Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

Item	13MLD STP																																													
<b>1. STP Design Condition</b>																																														
(1) Design Flow Rate	<table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th></th> <th>m3/d</th> <th>m3/h</th> <th colspan="2">m3/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td>13,000</td> <td>541.67</td> <td colspan="2">0.150</td> </tr> <tr> <td>Max Daily</td> <td>13,000</td> <td>541.67</td> <td colspan="2">0.150</td> </tr> <tr> <td>Max Hourly Peak factor 2.25</td> <td>29,250</td> <td>1218.75</td> <td colspan="2">0.339</td> </tr> </tbody> </table>						m3/d	m3/h	m3/s		Average Daily	13,000	541.67	0.150		Max Daily	13,000	541.67	0.150		Max Hourly Peak factor 2.25	29,250	1218.75	0.339																						
	m3/d	m3/h	m3/s																																											
Average Daily	13,000	541.67	0.150																																											
Max Daily	13,000	541.67	0.150																																											
Max Hourly Peak factor 2.25	29,250	1218.75	0.339																																											
(2) Design Water Quality	<p style="text-align: right;">Unit: mg/L</p> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th colspan="2">TP</th> </tr> <tr> <th>NH<sub>4</sub>-N</th> <th>Org-N</th> <th>NOx-N</th> <th>D-P</th> <th>P-P</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td>350</td> <td>800</td> <td>450</td> <td>45</td> <td>25</td> <td>0</td> <td>5</td> <td>2</td> </tr> <tr> <td>Outlet</td> <td>10</td> <td>50</td> <td>10</td> <td>1</td> <td>0</td> <td>9</td> <td>1</td> <td>1</td> </tr> <tr> <td>Removal rate</td> <td>97.1%</td> <td>93.7%</td> <td>97.8%</td> <td colspan="3">85.7%</td> <td colspan="2">71.4%</td> </tr> </tbody> </table>						BOD	COD	SS	T-N			TP		NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P	Inlet	350	800	450	45	25	0	5	2	Outlet	10	50	10	1	0	9	1	1	Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%	
	BOD	COD	SS	T-N						TP																																				
				NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P																																						
Inlet	350	800	450	45	25	0	5	2																																						
Outlet	10	50	10	1	0	9	1	1																																						
Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%																																							
<b>2. Inlet Chamber</b>																																														
<b>[1] Design Condition</b>																																														
(1) Design Flow Rate	Max Hourly	=	29,250	m3/day																																										
		=	0.339	m3/sec																																										
<b>[2] Geometry</b>																																														
(1) Number of Basins	1	Basin																																												
(2) Depth of Basin	2.000	m																																												
(3) Width of Basin	2.100	m																																												
(4) Length of Basin	2.500	m																																												
(5) Volume required of Basin	2.000	×	2.100	×	2.500 = 1.7 m3																																									
(6) Retention Time	2.000	×	2.100	×	2.500 / 0.339 × 1																																									
	=	30.97	sec																																											
(7) Basin Dimensions	Width	2.100	m	×	Length 2.500 m																																									
		×	Depth 2.000	m																																										

D-2 Process Cal EA&al 13MLD Hemigepura Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Wastewater Flow	$\begin{aligned} \text{Max Hourly} &= 29,250 \text{ m}^3/\text{d} \\ &= 0.339 \text{ m}^3/\text{sec} \end{aligned}$
[2] Geometory	
(1) Inlet Gate	
Number	2 Main + 1 Bypass
Width	0.500 m
Height	0.750 m
Floor Level	+ 2.000 m
Bottom	+ 0.000 m
Influent Water Level	+ 0.500 m
Velocity	$\begin{aligned} &0.339 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 2 \\ = &0.678 \text{ } \div \quad 1.000 \text{ m/sec} \end{aligned}$
(2) Screen Channel	
Number	2 Main + 1 Bypass
Width	0.800 m
Side Water Depth	0.500 m
Velocity	$\begin{aligned} &0.339 \text{ } \swarrow \quad 0.800 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 2 \\ = &0.424 \text{ } \div \quad 0.450 \text{ m/sec} \end{aligned}$
(3) Channel Dimensions	$\begin{aligned} \text{Width} &0.8 \text{ m} \times \text{Length} &6.0 \text{ m} \\ &\times \text{SWD} &0.5 \text{ m} \end{aligned}$
[3] Equipment	
(1) Inlet Gate	
Number	2 W + 1 S
Dimension	Width 0.5 m × Height 0.75 m
Design Water Level	2.00 m
(2) Fine Screens (Main Channel)	
Number	2 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	0.8 m
Width of side plate	50 mm
Side Water Depth	0.5 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	$\begin{aligned} &0.339 \text{ } \swarrow \quad 0.700 \text{ } \swarrow \quad 0.450 \text{ } \swarrow \quad 2 \\ &\times ( \quad 6 \quad + \quad 2 \quad ) / \quad 6 \\ = &0.717 < \quad 0.800 \text{ m/sec} \end{aligned}$
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	0.8 m
Side Water Depth	0.5 m
Velocity through screen	$\begin{aligned} &0.339 \text{ } \swarrow \quad 0.800 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 2 \\ &\times ( \quad 20 \quad + \quad 9 \quad ) / \quad 20 \\ = &0.614 < \quad 0.800 \text{ m/sec} \end{aligned}$

D-2 Process Cal EA&al 13MLD Hemigegepura Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>4. Grit Chamber</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Peak flow = 29,250 m <sup>3</sup> /day = 0.339 m <sup>3</sup> /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0111 m/sec = 960 m <sup>3</sup> /m <sup>2</sup> /day
(4) Average Velocity	0.3 m/sec
<b>[2] Grit Chamber</b>	
(1) Surface Area required	0.339 / 0.0111 = 30.54 m <sup>2</sup>
(2) Number of Basins	1 S + 1 W
(3) Surface Area required/Basin	30.54 / 1 = 30.54 m <sup>2</sup>
(4) Length of Basin	30.54 ^0.5 = 5.526 m → 6.0 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.339 × 60 sec / 1 = 20.3 m <sup>3</sup>
(7) Depth required	20.3 / 6.0 / 6.0 = 0.565 m
(8) Basin Dimensions	Width 6.0 m × Length 6.0 m × Depth 0.6 m (Freeboard 0.3m)
(9) Retention Time	6 × 6.0 × 0.6 / 0.339 × 1 = 60.00 sec
(10) Surface Overflow Rate at Peak Flow	29,250 / 6.0 / 6.0 / 1 = 812.5 < 960 m <sup>3</sup> /m <sup>2</sup> /day
<b>[3] Parshall Flume</b>	
(1) Design Flow Rate	Q= 339.000 l/sec
(2) Throat width	W= 0.450 m
(3) Water depth Ha	Ha= ( Q / 2264 / W ) <sup>2/3</sup>
(4) Crest Level	Ha= 0.480 m
(5) Water level at the crest	+ 0.480 m ≐ Minimum water level at downstream channel
(6) Channel bottom level	+ m
(7) Upstream Channel width	1.500 m
(8) SWD of Upstream Channel	0.700 m
(9) Average velocity at upstream channel	0.323 m/sec
(10) Total Length of channel	10.000 m
<b>[4] Inlet Weir Gate</b>	
(1) Number	2 Units
(2) Weir Width	0.800 m
(3) Stroke	0.550 m
(4) Overflow Height	0.500 m
(5) Overflow Height (actual)	( 0.339 / 1.840 / 0.800 / 2 ) <sup>2/3</sup> = 0.237 < 0.500 m

**STP Process Calculation Supporting Report 12.2.3**

<b>5. Reactor</b>																																																								
<b>[1] Design Condition</b>																																																								
(1) Design Wastewater Flow	Q = 13,000 m <sup>3</sup> /day (summer) Q' = 13,000 m <sup>3</sup> /day (Winter)																																																							
(2) Design Sewage Quality																																																								
Inlet BOD	350 mg/l																																																							
Outlet BOD	10.0 mg/l																																																							
Inlet S-BOD	235 mg/l assumed as 67% of BOD																																																							
Inlet COD	800 mg/l																																																							
Inlet bCOD : S <sub>0</sub>	578 mg/l																																																							
Inlet nbCOD	223 mg/l																																																							
bCOD/BOD	1.65																																																							
Inlet S-COD : sCOD	271 mg/l assumed as 33% of BOD																																																							
Inlet rbCOD	231 mg/l bCOD*40%																																																							
Inlet sbCOD	347 mg/l bCOD*60%																																																							
Outlet S-COD : nbsCODe	40 mg/l																																																							
Inlet nbpCOD : nbpCOD	183 mg/l = TCOD - bCOD - nbsCODe																																																							
Inlet SS	450 mg/l																																																							
Inlet VSS	383 mg/l assumed as 85% of TSS																																																							
:VSS <sub>COD</sub>	1.38 gCOD/gVSS = (TCOD - sCOD)/VSS																																																							
:nbVSS	131.96 gnbVSS/m <sup>3</sup> = nbpCOD/VSS <sub>COD</sub>																																																							
:iTSS	67.50 gnbVSS/m <sup>3</sup> = TSS - VSS																																																							
Inlet T-N	70 mg/l																																																							
Inlet TKN	70 mg/l																																																							
Inlet NH <sub>4</sub> -N	45.0 mg/l																																																							
Inlet T-P	7 mg/l																																																							
Inlet D-P	5 mg/l																																																							
Inlet Alkalinity as CaCO <sub>3</sub>	380 mg/l																																																							
Outlet Kjeldahl N	1.0 mg/l																																																							
Outlet NH <sub>4</sub> -N	1.0 mg/l																																																							
Outlet NO <sub>3</sub> -N	9.0 mg/l																																																							
Outlet T-P	2 mg/l																																																							
Outlet D-P	1 mg/l																																																							
(3) Water Temperature	T = 20.0 °C																																																							
(4) Safety Factor for Nitrogen	SF = 1.5																																																							
(5) Return Sludge Concentration	R <sub>s</sub> = 8,000 mg/l																																																							
(6) MLSS MLVSS	X <sub>TSS</sub> = 3,000 mg/l																																																							
(7) DO in the Reactor	2 mg/L																																																							
<b>[2] Design Value for perfect Nitrification of Nitrification Process</b>																																																								
(1) Activated sludge design kinwtic coefficients at 20°C																																																								
	<table border="1"> <thead> <tr> <th>Coefficient</th> <th>Unit</th> <th>COD oxidatio</th> <th>NH4 oxidatio</th> <th>NO2 oxidatio</th> </tr> </thead> <tbody> <tr> <td>μ<sub>max</sub></td> <td>gVSS/gVSS · d</td> <td>6.000</td> <td>0.900</td> <td>1.000</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH4</sub>, K<sub>NO2</sub></td> <td>mg/L</td> <td>8.000</td> <td>0.500</td> <td>0.200</td> </tr> <tr> <td>Y</td> <td>gVSS/g substrate oxidized</td> <td>0.450</td> <td>0.150</td> <td>0.050</td> </tr> <tr> <td>b</td> <td>gVSS/gVSS · d</td> <td>0.120</td> <td>0.170</td> <td>0.170</td> </tr> <tr> <td>fd</td> <td>unitless</td> <td>0.150</td> <td>0.150</td> <td>0.150</td> </tr> <tr> <td>K<sub>O2</sub></td> <td>mg/L</td> <td>0.200</td> <td>0.500</td> <td>0.900</td> </tr> <tr> <td>θ Value</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>μ<sub>max</sub></td> <td>unitless</td> <td>1.070</td> <td>1.072</td> <td>1.063</td> </tr> <tr> <td>b</td> <td>unitless</td> <td>1.040</td> <td>1.029</td> <td>1.029</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH4</sub>, K<sub>NO2</sub></td> <td>unitless</td> <td>1.000</td> <td>1.000</td> <td>1.000</td> </tr> </tbody> </table> <p>Wastwater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF &amp; EDDY/AECOM)</p>	Coefficient	Unit	COD oxidatio	NH4 oxidatio	NO2 oxidatio	μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000	K <sub>s</sub> , K <sub>NH4</sub> , K <sub>NO2</sub>	mg/L	8.000	0.500	0.200	Y	gVSS/g substrate oxidized	0.450	0.150	0.050	b	gVSS/gVSS · d	0.120	0.170	0.170	fd	unitless	0.150	0.150	0.150	K <sub>O2</sub>	mg/L	0.200	0.500	0.900	θ Value					μ <sub>max</sub>	unitless	1.070	1.072	1.063	b	unitless	1.040	1.029	1.029	K <sub>s</sub> , K <sub>NH4</sub> , K <sub>NO2</sub>	unitless	1.000	1.000	1.000
Coefficient	Unit	COD oxidatio	NH4 oxidatio	NO2 oxidatio																																																				
μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000																																																				
K <sub>s</sub> , K <sub>NH4</sub> , K <sub>NO2</sub>	mg/L	8.000	0.500	0.200																																																				
Y	gVSS/g substrate oxidized	0.450	0.150	0.050																																																				
b	gVSS/gVSS · d	0.120	0.170	0.170																																																				
fd	unitless	0.150	0.150	0.150																																																				
K <sub>O2</sub>	mg/L	0.200	0.500	0.900																																																				
θ Value																																																								
μ <sub>max</sub>	unitless	1.070	1.072	1.063																																																				
b	unitless	1.040	1.029	1.029																																																				
K <sub>s</sub> , K <sub>NH4</sub> , K <sub>NO2</sub>	unitless	1.000	1.000	1.000																																																				
(2) μ <sub>AOB</sub>	μ <sub>AOB</sub> = 0.3100 g/g · d = μ <sub>max, AOB</sub> [S <sub>NH4</sub> / (S <sub>NH4</sub> + K <sub>NH4</sub> )] [S <sub>O</sub> / (S <sub>O</sub> + K <sub>O, AOB</sub> )] - b <sub>AOB</sub>																																																							
μ <sub>max, AOB, T</sub>	μ <sub>max, AOB, T</sub> = 0.9000 g/g · d = μ <sub>max</sub> * 1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900																																																							
b <sub>AOB, T</sub>	b <sub>AOB, T</sub> = 0.1700 = b * 1.029 <sup>(T-20)</sup> b at 20°C = 0.170																																																							
S <sub>NH4</sub>	S <sub>NH4</sub> = 1.0000 mg/l																																																							
DO	DO = 2.0000 mg/l																																																							
K <sub>O, AOB</sub>	K <sub>O, AOB</sub> = 0.5000 mg/l																																																							

D-2 Process Calculations and 13MLD Hemigepura Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

(2) Design SRT	SRT= 4.8387 day ⇒ 5.0000 day	$= 1/\mu_{AOB} \times SF$
(3) Biomass production		
P <sub>X,VSS</sub>	P <sub>X,VSS</sub> = 4065.149 kg/d	= P <sub>X,bio</sub> + Q(nbVSS)
P <sub>X,TSS</sub>	P <sub>X,TSS</sub> = 5583.803 kg/d	= P <sub>X,bio</sub> × 0.85 + Q(nbVSS) + Q(TSS <sub>0</sub> - VSS <sub>0</sub> ) + 5*Q*Al
S	S= 0.4507 mg/l	= K <sub>s</sub> [1 + b <sub>H</sub> (SRT)]/[SRT(μ <sub>m</sub> - b <sub>H</sub> ) - 1]
b <sub>H</sub>	b <sub>H</sub> = 0.1200	= b * 1.04 <sup>(T-20)</sup> b at 20°C = 0.120
Y <sub>H</sub>	Y <sub>H</sub> = 0.4500 gVSS/g bCOD	
μ <sub>m,T</sub>	μ <sub>m,T</sub> = 6.0000 g/g·d	= μ <sub>max</sub> * 1.04 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 6.000
Y <sub>n</sub>	Y <sub>n</sub> = 0.150 gVSS/g Nox	
NO <sub>x</sub>	NO <sub>x</sub> = 47.400 mg/l	
P <sub>X,bio,VSS</sub>	P <sub>X,bio,VSS</sub> = 2349.684 kg VSS/d	= Q * Y <sub>H</sub> (S <sub>0</sub> - S) / [1 + b <sub>H</sub> (SRT)] + f <sub>d</sub> * b <sub>H</sub> * Q * Y <sub>H</sub> (S <sub>0</sub> - S) * SRT / [1 + b <sub>H</sub> (SRT)]
	2109.836	= Q * Y <sub>n</sub> (Nox) * [2 + b <sub>AOB</sub> (SRT)]
	189.885	= Q * Y <sub>H</sub> (S <sub>0</sub> - S) / [1 + b <sub>H</sub> (SRT)]
	49.962	= f <sub>d</sub> * b <sub>H</sub> * Q * Y <sub>H</sub> (S <sub>0</sub> - S) * SRT / [1 + b <sub>H</sub> (SRT)]
		= Q * Y <sub>n</sub> (Nox) * [1 + b <sub>AOB</sub> (SRT)]
NO <sub>x</sub>	NO <sub>x</sub> = 47.311 mg/l	= TKN - Ne - 0.12P <sub>X,bio</sub> /Q
(4) Required Aeration Tank Volume		
V <sub>a</sub>	V <sub>a</sub> = 9,306 m <sup>3</sup>	
τ	τ = 17.18 hr ⇒ 18.00 hr	= V <sub>a</sub> /Q × 24
X <sub>VSS</sub> · V <sub>a</sub>	X <sub>VSS</sub> · V <sub>a</sub> = 20,326 kg VSS	= P <sub>X,VSS</sub> · SRT
X <sub>TSS</sub> · V <sub>a</sub>	X <sub>TSS</sub> · V <sub>a</sub> = 27,919 kg TSS	= P <sub>X,TSS</sub> · SRT
F/M	F/M= 0.224 kgBOD/kgMLVSS	
FractionVSS=	FractionVSS= 0.728	
MLVSS=	MLVSS= 2184 mg/L	
(5) BODloading	BODloading= 0.489 kg/m <sup>3</sup> ·d	
(6) Observed Yield		
Y <sub>obs,TSS</sub>	Y <sub>obs,TSS</sub> = 1.228 gTSS/gBOD	
Y <sub>obs,VSS</sub>	Y <sub>obs,VSS</sub> = 0.894 gVSS/gBOD	
bCODremoved=	bCODremoved= 7,502 kg/d	
(7) effluent NO <sub>2</sub> -N	NO <sub>2</sub> -N= 0.2315 mg/l	= K <sub>s</sub> [1 + b <sub>NOB</sub> (SRT)]/[SRT(μ <sub>NOB</sub> - b <sub>NOB</sub> ) - 1]
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700	= b * 1.029 <sup>(T-20)</sup> b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 1.0000 g/g·d	= μ <sub>max</sub> * 1.04 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 1.000
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.6897 g/g·d	= μ <sub>max,NOB</sub> [S <sub>0</sub> / (S <sub>0</sub> + K <sub>O2,NOB</sub> )]
	S <sub>0</sub> = 2.000 mg/l	
	K <sub>O2,NOB</sub> = 0.900 mg/l	
(8) effluent NH <sub>4</sub> -N	NH <sub>4</sub> -N= 0.5286 mg/l	= K <sub>s</sub> [1 + b <sub>NOB</sub> (SRT)]/[SRT(μ <sub>NOB</sub> - b <sub>NOB</sub> ) - 1]
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700	= b * 1.029 <sup>(T-20)</sup> b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 0.9000 g/g·d	= μ <sub>max</sub> * 1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.7200 g/g·d	= μ <sub>max,NOB</sub> [S <sub>0</sub> / (S <sub>0</sub> + K <sub>O2,NOB</sub> )]
	S <sub>0</sub> = 2.000 mg/l	
	K <sub>O2,NOB</sub> = 0.500 mg/l	
(9) Ratio of Return Sludge	8,000 * R <sub>r</sub> / (1 + R <sub>r</sub> ) = 3,000 mg/L 3,000 / (8,000 - 3,000) = 0.60 R <sub>r</sub> = 0.60	

D-2 Process Calculations for 13MLD Hemigepura Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

<b>[3] Design for Nitrification and Denitrification Process</b>																						
(1) Active biomass concentration	$X_b = \frac{Q \cdot (SRT) \cdot V \cdot Y_H \cdot (S_0 - S)}{1 + b_H(SRT)}$	= 1,133.55 mg/l																				
(2) IR ratio	$IR = \frac{NO_x}{Ne - 1.0 - R}$	= 3.66																				
(3) The amount of NO <sub>3</sub> -N fed to the anoxic tank	$Nox\ feed = (IR + R) \cdot Q \cdot Ne$	= 498,037.93 kg/d																				
(4) The anoxic tank volume	$V_{nor} = \frac{Nox\ feed}{\tau_{DN} \cdot X_b}$	= 2,708 m <sup>3</sup> (10% of Va)																				
(5) F/M <sub>b</sub>	$F/M_b = \frac{Nox\ feed}{V_{nor} \cdot X_b}$	= 1.48 g/g·d																				
(6) Fraction of rbCOD	$\frac{rbCOD}{bCOD}$	= 40.00%																				
<table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b<sub>0</sub></th> <th>b<sub>1</sub></th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>			Percent rdCOD(%)	SDNR equation coefficients		b <sub>0</sub>	b <sub>1</sub>	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162
Percent rdCOD(%)	SDNR equation coefficients																					
	b <sub>0</sub>	b <sub>1</sub>																				
10	0.186	0.078																				
20	0.213	0.118																				
30	0.235	0.141																				
40	0.242	0.152																				
50	0.270	0.162																				
(8) SDNR <sub>b</sub>	$SDNR_b = b_0 + b_1 \ln(F/M_b)$	= 0.302 g/g·d																				
	$b_0 = 0.242$																					
	$b_1 = 0.152$																					
(8) SDNR	$SDNR = SDNR_b \cdot (MLVSS_r / MLVSS)$	= 0.113 g/g·d																				
	$SDNR_{adj} = SDNR_b - 0.029 \ln(F/M_b) - 0.012$	= 0.217 g/g·d (IR=3-4)																				
	$SDNR_{adj} = SDNR_b - 0.0166 \ln(F/M_b) - 0.078$	= 0.217 g/g·d (IR=2)																				
	$SDNR_t = SDNR_b \cdot \theta^{(F/M_b - 20)}$	$\theta = 1.026$																				
(9) NO <sub>r</sub>	$NO_r = N_{nox} \cdot SDNR \cdot X_b$	= 667,030.53 kg/d																				
	> Nox feed =	498,038 kg/d																				
(10) Alkalinity to be added to maintain pH7		-108.33 mg/l																				
	Influent Alk	380.00 mg/l																				
	Alk used	338.44 mg/l (= 7.14 × Nox)																				
	Alk produced	136.77 mg/l (= 3.57 × (NO <sub>x</sub> - NO <sub>xe</sub> ))																				
	Alk to maintain	70.00 mg/l																				
<b>[4] Design of Phosphorus Removal Process</b>																						
(1) Removal T-P		3.13 mg/l																				
P in waste sludge	$P_x = 1.00\%$																					
Generated waste sludge	$P_{x, VSS} = 4065.149 \text{ kg/d}$																					
Removal Phosphorus		40.65149435 kg/d																				
(2) Effluent T-P without Al		3.87 mg/l																				
(3) Required Al to initial soluble phosphorus ratio		1.00 mol/mol																				
(4) Required Al dosing rate		3.48 mg/l as Al																				
		42.98 mg/l as crystal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> · 18H <sub>2</sub> O																				
(5) Required Aluminum Sulfate		558.71 kg/d																				
(6) Required Aluminum Sulfate solution 10%		5.32 m <sup>3</sup> /d																				
		221.71 L/H																				
(7) Additional sludge		226.50 kg/d																				

D-2 Process CalEA&al 13MLD Hemigepura Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

<p><b>[5] Reactor</b></p> <p>(1) Total volume of Aeration Basins</p> <p>(2) Total volume of Anoxic Basins</p>	$V_A = Q \cdot \theta_a / 24$ $= 9,750 \text{ m}^3$ $V_{DN} = Q \cdot \theta_{DN} / 24$ $= 2,708 \text{ m}^3$ <table border="1"> <thead> <tr> <th rowspan="2">Item</th> <th rowspan="2">Volume required</th> <th colspan="2">Retention Time required</th> <th rowspan="2">Ratio of Volume</th> </tr> <tr> <th>Summer</th> <th>Winter</th> </tr> </thead> <tbody> <tr> <td>unit</td> <td>m<sup>3</sup></td> <td>hour</td> <td>hour</td> <td></td> </tr> <tr> <td>Anaerobic</td> <td>V<sub>AN</sub></td> <td>810</td> <td>1.50</td> <td>1.50</td> <td>0.30</td> </tr> <tr> <td>Anoxic</td> <td>V<sub>DN</sub></td> <td>2,708</td> <td>5.00</td> <td>5.00</td> <td>1.00</td> </tr> <tr> <td>Aerobic</td> <td>V<sub>A</sub></td> <td>9,750</td> <td>18.00</td> <td>18.00</td> <td>3.60</td> </tr> <tr> <td>Total</td> <td>V</td> <td>13,268</td> <td>24.50</td> <td>24.50</td> <td></td> </tr> </tbody> </table>	Item	Volume required	Retention Time required		Ratio of Volume	Summer	Winter	unit	m <sup>3</sup>	hour	hour		Anaerobic	V <sub>AN</sub>	810	1.50	1.50	0.30	Anoxic	V <sub>DN</sub>	2,708	5.00	5.00	1.00	Aerobic	V <sub>A</sub>	9,750	18.00	18.00	3.60	Total	V	13,268	24.50	24.50																															
Item	Volume required			Retention Time required			Ratio of Volume																																																												
		Summer	Winter																																																																
unit	m <sup>3</sup>	hour	hour																																																																
Anaerobic	V <sub>AN</sub>	810	1.50	1.50	0.30																																																														
Anoxic	V <sub>DN</sub>	2,708	5.00	5.00	1.00																																																														
Aerobic	V <sub>A</sub>	9,750	18.00	18.00	3.60																																																														
Total	V	13,268	24.50	24.50																																																															
<p><b>[6] Geometry</b></p> <p>(1) Basin Dimensions</p> <p>Cross Section</p> <p>Hantzschn Subtraction</p> <p>after Subtraction</p> <p>Total Volume</p> <p>(2) Partition of Basin</p>	<p>Width      Length      Depth      Basins</p> <p>8.0                      156.0      5.5      2</p> <p>Cross Section      =      44.0 m<sup>2</sup>/Basin</p> <p>Hantzschn Subtraction      =      1.0 m<sup>2</sup>/Basin</p> <p>after Subtraction      =      43.0 m<sup>2</sup>/Basin</p> <p>Total Volume      =      6,708 m<sup>2</sup>/Basin      13,416 m<sup>3</sup>/Total</p> <table border="1"> <thead> <tr> <th>Item</th> <th>unit</th> <th>Anaerobic</th> <th>Anoxic</th> <th>Aerobic</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Cross Section</td> <td>m<sup>2</sup></td> <td colspan="3">43.0</td> <td></td> </tr> <tr> <td>Length required</td> <td>m</td> <td><b>9.4</b></td> <td><b>31.5</b></td> <td><b>113.4</b></td> <td><b>154.3</b></td> </tr> <tr> <td>Volume required per Basin</td> <td>m<sup>3</sup></td> <td>405</td> <td>1,354</td> <td>4,875</td> <td>6,634</td> </tr> <tr> <td>Total Volume required</td> <td>m<sup>3</sup></td> <td>810</td> <td>2,708</td> <td>9,750</td> <td>13,268</td> </tr> <tr> <td>Actual Cross Section</td> <td>m<sup>2</sup></td> <td>43.0</td> <td>43.0</td> <td>43.0</td> <td></td> </tr> <tr> <td>Actual Length</td> <td>m</td> <td>10.0</td> <td>32.0</td> <td>114.0</td> <td>156.0</td> </tr> <tr> <td>Actual Volume per Basin</td> <td>m<sup>3</sup></td> <td>430</td> <td>1,376</td> <td>4,902</td> <td>6,708</td> </tr> <tr> <td>Actual Total Volume</td> <td>m<sup>3</sup></td> <td>860</td> <td>2,752</td> <td>9,804</td> <td>13,416</td> </tr> <tr> <td>Actual Ratio of Volume</td> <td></td> <td>0.31</td> <td>1.00</td> <td>3.56</td> <td></td> </tr> <tr> <td>Actual Retention Time</td> <td>hour</td> <td>1.59</td> <td>5.08</td> <td>18.10</td> <td>24.77</td> </tr> </tbody> </table>	Item	unit	Anaerobic	Anoxic	Aerobic	Total	Cross Section	m <sup>2</sup>	43.0				Length required	m	<b>9.4</b>	<b>31.5</b>	<b>113.4</b>	<b>154.3</b>	Volume required per Basin	m <sup>3</sup>	405	1,354	4,875	6,634	Total Volume required	m <sup>3</sup>	810	2,708	9,750	13,268	Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0		Actual Length	m	10.0	32.0	114.0	156.0	Actual Volume per Basin	m <sup>3</sup>	430	1,376	4,902	6,708	Actual Total Volume	m <sup>3</sup>	860	2,752	9,804	13,416	Actual Ratio of Volume		0.31	1.00	3.56		Actual Retention Time	hour	1.59	5.08	18.10	24.77
Item	unit	Anaerobic	Anoxic	Aerobic	Total																																																														
Cross Section	m <sup>2</sup>	43.0																																																																	
Length required	m	<b>9.4</b>	<b>31.5</b>	<b>113.4</b>	<b>154.3</b>																																																														
Volume required per Basin	m <sup>3</sup>	405	1,354	4,875	6,634																																																														
Total Volume required	m <sup>3</sup>	810	2,708	9,750	13,268																																																														
Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0																																																															
Actual Length	m	10.0	32.0	114.0	156.0																																																														
Actual Volume per Basin	m <sup>3</sup>	430	1,376	4,902	6,708																																																														
Actual Total Volume	m <sup>3</sup>	860	2,752	9,804	13,416																																																														
Actual Ratio of Volume		0.31	1.00	3.56																																																															
Actual Retention Time	hour	1.59	5.08	18.10	24.77																																																														
<p><b>[7] Equipment</b></p> <p>(1) Ras Pumps</p> <p>Ras Ratio</p> <p>Required Capacity</p> <p>Number</p> <p>(2) Circulation Pumps</p> <p>Ras Ratio</p> <p>Required Capacity</p> <p>Number</p> <p>(3) SAS Pumps</p> <p>Excess Sludge</p> <p>Sludge withdraw</p> <p>Running Time</p> <p>Required Capacity</p> <p>Number</p>	<p>60%</p> <p>13,000 m<sup>3</sup>/day ×      60% / 24 /      2</p> <p>= 163 m<sup>3</sup>/Hr ⇒      170 m<sup>3</sup>/Hr</p> <p>2 Work</p> <p>2 Stanby</p> <p>366%</p> <p>13,000 m<sup>3</sup>/day ×      366% / 24 /      4</p> <p>= 495 m<sup>3</sup>/Hr ⇒      500 m<sup>3</sup>/Hr</p> <p>4 Work</p> <p>2 Stanby</p> <p>817 m<sup>3</sup>/day</p> <p>12 Times/day</p> <p>0.5 Hr/Time</p> <p>817 m<sup>3</sup>/day /      12 /      0.5 /      2</p> <p>= 68.05 m<sup>3</sup>/Hr ⇒      70 m<sup>3</sup>/Hr</p> <p>2 Work</p> <p>2 Stanby</p>																																																																		



D-2 Process CalEA&al 13MLD Hemigepura Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

(4) Alum Solution Tank										
Number	2	W	+	0	S					
Alum concentration as crystal	10	%								
Gravity of dissolved dechlorine	1.05									
Required solution volume	558.71	kg / d	×	100	/	10	/	1.05	/	1000
	=	5.32				m <sup>3</sup> /d				
Volume of Tank	3.5	m <sup>3</sup> /tank	(=	1.4	mW×	1.4	mL×	1.8	mH)	
Total Volume of Tanks	7.1	m <sup>3</sup>	(Duration=			1.33	day)			
(5) Mixer for Alum Solution Tank										
Number	2	W	+	0	S					
(6) Alum Dosing Pump										
Number	2	W	+	1	S					
Capacity	5.32	m <sup>3</sup> /d	/	24	×	1000	/	2	×	2
	221.71	l/h/unit	⇒	230	l/h/unit					

D-2 Process Cal EA&al 13MLD Hemjigepura Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>6. Air Requirement at Average Flow</b>	
[1] Design Condition	
(1) AOR	AOR = 5,624 kg/day = 234.3 kg/h
Q <sub>in</sub> : Design Average Flow m <sup>3</sup> /d	13,000
Inlet bCOD : S <sub>0</sub>	578 mg/l
S=	S= 0.451 mg/l
Nox=	Nox 47.400 mg/l
P <sub>X,bio</sub> =	P <sub>X,b</sub> 2,299.7 kg VSS/d does not include nitrifying bacteria
R <sub>0</sub> =	R <sub>0</sub> = Q(S <sub>0</sub> -S-k(NOx-NOxe))-1.42P <sub>X,bio</sub> +4.57Q•NOx
R <sub>0</sub> =	R <sub>0</sub> = 5,624 kg O <sub>2</sub> /d
	k= 2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{\text{AOR} \times C_s \cdot a \times 1.024^{20-T}}{\alpha \times F (\beta \cdot C_{sw}/C_s \cdot (P_b/P_a)a - C_A)}$
	C <sub>s</sub> : Saturated DO at sea level and 20 °C 9.09 mg/L
	C <sub>sw</sub> : Saturated DO at sea level and operating Temperature 9.09 mg/L at 20 °C
	20-T : 0.0 1.024 <sup>20-T</sup> : 1.0000
	C <sub>A</sub> : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1+0.40D <sub>j</sub> /P <sub>a</sub> 1.19357
	D <sub>j</sub> : Tank Liquid Depth 5.00 m
	P <sub>a</sub> : Standard absolute pressure at s 10.332 m
	P <sub>b</sub> : Absolute pressure at Plant Site Elevation m
	P <sub>b</sub> /P <sub>a</sub> : exp[-gM(z <sub>b</sub> -z <sub>a</sub> )/R*T] 0.900
	g : Acceleration due to Gravity 9.80665 m/s <sup>2</sup>
	M : Mole of Air 28.97 kg/kg-mole
	z <sub>b</sub> : Plant Site Elevation 900 m
	z <sub>a</sub> : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 293.15 Kelvin
	α : relative Transfer Rate to clean W <sub>a</sub> 0.65
	β : relative DO Saturation to clean W <sub>ε</sub> 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{61,022}{4.2591} = 14,327.28 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Standard O <sub>2</sub> required at Field Conditions per Bas =	7,164 kg/day
(5) SOTE for the above Effective Aeration Depth	28.0 %
(6) Fraction of O <sub>2</sub> in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	15%
(9) Air required at Field Conditions per Basins	= 105,358 m <sup>3</sup> /day = 4,389.9 m <sup>3</sup> /hr
[2] Equipment	

Air Requirement at Average Flow 12/23

D-2 Process Cal EA&amp;al 13MLD Hemjigepura\_Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

(1) Air Blower					
Number	4	W	+	2	S
Required Capacity	4389.9	m <sup>3</sup> /Hr·Basin	/	2	unit/Basin
	= 2195.0	m <sup>3</sup> /h	⇒	2200	m <sup>3</sup> /h /Unit
Pressure	65	kPa			
Safety Factor	10	%			
Heat capacity ratio	1.4				
Atmospheric pressure at site elevation	91.234	kPa			
Total inlet pressure	89.234	kPa			
Volume rate of flow at inlet point	41.625	m <sup>3</sup> /min			
Total discharge pressure	156.234	kPa			
Overall adiabatic efficiency	0.65				
Inlet air temperature (min.)	15	°C			
Shaft power	58.852	kW			
Rated Output of Motor	64.737	kW	⇒	75	kW

Air Requirement at Average Flow13/23

D-2 Process Cal EA&al 13MLD Hemigepura Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>7. Final Clarifire</b></p> <p><b>[1] Design Condition</b></p> <p>(1) Design Wastewater Flow</p> <p>(2) Water Temperature</p> <p>(3) MLSS</p> <p>(4) SVI</p> <p>(5) Sedimentation Velocity</p> <p>(6) Surface Overflow Rate required</p> <p><b>[2] Geometry</b></p> <p>(1) Surface Area required</p> <p>(2) Demensions</p> <p>(3) Actual Surface Area</p> <p>(4) Surface Overflow Rate</p>	<p><math>Q = 13,000 \text{ m}^3/\text{day}</math></p> <p><math>T = 20.0 \text{ }^\circ\text{C}</math></p> <p><math>X_{ef} = 3,000 \text{ mg/l}</math></p> <p><math>SVI = 300</math></p> <p><math>v = 4.899 \cdot 10^6 \cdot T^{(0.954)} \cdot X_{ef}^{(-1.354)} \cdot SVI^{(-0.77)}</math>  <math>= 4.899 \cdot 10^6 \cdot 20.0^{0.954} \cdot 3,000^{-1.354} \cdot 150^{-0.770}</math>  <math>= 20.7 \text{ m/day}</math></p> <p><math>S' = v / (1.5 \cdot 1) = 20.7 / (1.5 \cdot 1.0) = 13.8 \text{ m}^3/\text{m}^2 \cdot \text{day}</math>  <math>\rightarrow 12.0 \text{ m}^3/\text{m}^2 \cdot \text{day}</math></p> <p><math>A = 13,000 / 12.0 = 1,083 \text{ m}^2</math></p> <table style="margin-left: 40px;"> <tr> <td style="text-align: center;">Diameter</td> <td style="text-align: center;">Depth</td> <td style="text-align: center;">Basin</td> </tr> <tr> <td style="text-align: center;"><b>26.5</b></td> <td style="text-align: center;"><b>3.5</b></td> <td style="text-align: center;"><b>2</b></td> </tr> </table> <p><math>S = 26.5^2 \cdot 3.14 / 4 \cdot 2.0 = 1,103 \text{ m}^2</math></p> <p><math>S = 13,000 / 1,103 = 11.8 \text{ m}^3/\text{m}^2 \cdot \text{day}</math></p>	Diameter	Depth	Basin	<b>26.5</b>	<b>3.5</b>	<b>2</b>
Diameter	Depth	Basin					
<b>26.5</b>	<b>3.5</b>	<b>2</b>					

D-2 Process Cal EA&al 13MLD Hemigepura Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>8. Chlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 13,000 m <sup>3</sup> /day 541.67 m <sup>3</sup> /h Peak Flow 29,250 m <sup>3</sup> /day 1218.75 m <sup>3</sup> /h
(2) Contact Time	30 min
(3) Type of Chlorine	Cl <sub>2</sub> -GAS
(4) Design Chlorine Dosage Rate	10 mg/L
(5) Required Chlorine per day	Average Daily Flow / 1000 × Design Chlorine Dosage Rate = 130.0 kg/d = 5.42 kg/h
<b>[2] Chlorination Contact Tank</b>	
(1) Volume required	Average Daily Flow / 1440 × Contact Time = 270.8 m <sup>3</sup>
(2) Nos. of lanes	3 lanes
(3) Width of lane	2.00 m
(4) Length of lane	24.00 m
(5) Side Water Depth	2.00 m
(6) Nos. of Tanks	1 tank
(7) Total Width of Tank	6.80 m Approx..
(8) Average Velocity	Decant Flow / 3600 / Width / Depth = 541.67 / 3600 / 2.00 / 2.00 = 0.038 m/sec
(9) Total Volume	Width × Length × Depth × Nos. of lanes × Nos. of Tanks = 2.0 m × 24.0 m × 2.0 m × 3 × 1 = 288 m <sup>3</sup> > 270.8 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Chlorine Dosing Condition	
Operation Dosage Rate -1	DC1 10 mg/L
(2) Chlorine Cylinder	
Type	- Cylindrical Convexsd Container
Cylinder Capacity	Cc 928 kg/cylinder
Average Dosage Rate -1	q1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 130 kg/day
Maximum Dosage Rate -1	q3 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 293 kg/day
Storage day	T More than 15 days
Required Storage Capacity	EC1 D × T = 1,950 kg
Unit Number	EN1 EC1 / Cc = 2.1 cylinders
Maximum Operation Numbers	
Cl <sub>2</sub> -Gas Volatilize Rate	Vr1 ##### @ 20 <sup>o</sup> C Standard temperature
Maximum Dosing Rate	DC1 10 mg/L, Q <sub>T-D</sub> × q3 × 10 <sup>-3</sup> / 24 = 12.19 kg/h
Operation Numbers	EN2 DC1 / Vr1 = 1.5sets
Number	2 W + 2 S
(3) Chlorinator	
Type	Solution Feed Vacuum Type
Number	1 W + 1 S
Operation Dosage Rate -1	Dq1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 292.5 kg/day
Required Dosage Rate	Chlorine -1 : Dq1 / (EN1 × 24) = Minimum 0.00 kg/hr Maximum 12.2 kg/hr
(4) Chlorine Booster Pump	

D-2 Process Cal EA&al 13MLD Hemigepura Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

Type	Branchy on the water supply pipe
Water Demand	Water requiamet for mixed Chlori
Chlorinator Discharge	(kg/hr) 1.0 1.5 2.0 2.5 3.0 4.0
Water Demand	(L/min) 15 20 25 30 35 40
Chlorinator Discharge	(kg/hr) 5.0 6.0 10.0 50.0 100.0 200.0
Water Demand	(L/min) 45 50 60 300 600 1,200
Water requiamet	-
For Chlorin	Qp1 Maximum dosage rate 12.2 kg/hr therefore 90 L/min
Booster Pump Type	Single suction volute pump
Number	1 W + 1 S
<b>9. Dechlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 13,000 m <sup>3</sup> /day
(2) Contact Time	10 min
(3) Type of Dechlorine	Sodium Thiosulfate (Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 5H <sub>2</sub> O)
(4) Free Residual Chlorine	1.0 mg/L assumed value
(5) Consumption per day	Average Daily Flow / 1000 × Free Residual Chlorine × 1.75 × 1.5 (safety factor) = 34.1 kg/d = 1.42 kg/h
<b>[2] Dechlorination Contact Tank</b>	
(1) Volume required	Average Flow Rate / 60 × Contact Time = 90.3 m <sup>3</sup>
(2) Width of lane	6.80 m
(3) Length of lane	7.00 m
(4) Side Water Depth	2.00 m
(5) Nos. of Tanks	1 tank
(6) Total Volume	Width × Length × Depth = 6.8 m × 7.0 m × 2.0 m = 95 m <sup>3</sup> > 90.3 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Dechlorine Solution Tank	
Number	2 W + 0 S
Dechlorine concentration	10 %
Gravity of dissolved dechlorine	1.10
Required solution volume	34.13 kg/d × 100 / 10 / 1.10 / 1000 = 0.31 m <sup>3</sup> /d
Volume of Tank	0.200 m <sup>3</sup> /tank (= 0.5 mW × 0.5 mL × 0.8 mH)
Total Volume of Tanks	0.400 m <sup>3</sup> (Duration= 1.29 day)
(2) Mixer for Dechlorine Solution Tank	
Number	2 W + 0 S
(3) Dechlorine Dosing Pump	
Number	2 W + 1 S
Capacity	0.70 m <sup>3</sup> /d / 24 × 1000 / 2 14.54 l/h/unit ⇒ 15 l/h/unit

D-2 Process Cal EA&amp;al 13MLD Hemigepura Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>10. Sludge Thikener</b>					
<b>[1] Design Condition</b>					
(1) Primary Sludge	0	kg/day	0	m <sup>3</sup> /day	
(2) Secondary Sludge	6,533	kg/day	817	m <sup>3</sup> /day	
(3) Total Solids	6,533	kg/day	817	m <sup>3</sup> /day	
(4) Operation Time	24	hours/day			
(5) Thikened Sludge Moisture Content	97.5	%			
<b>[2] Geometory</b>					
(1) Type					
(2) Number	2	W	+	0	S
(3) Design Solid Loadong	40	kg / m <sup>2</sup> /d			
(4) Required Surface Area	6533	×	$\frac{1}{40}$	=	163.30 m <sup>2</sup>
(5) Required diameter	$(\frac{4}{\pi} \times 163.30 \times \frac{1}{2})^{1/2}$			=	10.20 m
				→	10.50 m
(6) Side Water Depth	4	m			
(7) Actual Volume of Tank	$\frac{\pi}{4} \times 10.50^2 \times 4$		=	86.59	m <sup>3</sup>
(8) Retention Time	$\frac{86.59}{817} \times 4 \times 2 \times 24$		=	20.36	Hr
<b>[3] Volume of Thikened Sludge</b>					
	=	235	m <sup>3</sup> /d		
<b>[4] Quantity of Separation Liquid</b>					
	=	816.6	−	235.2	= 581.4 m <sup>3</sup> /day

D-2 Process Cal EA&aI 13MLD Hemigepura Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>11. Thickened Sludge Sump</b>	
<b>[1] Design Condition</b>	
(1) Inlet Solids	6,533 kg/day
(2) Inlet Sludge Volume	817 m <sup>3</sup> /d
<b>[2] Geometory</b>	
(1) Sludge withdrawl	12 Times/day
(2) Required Sump Volume	68 m <sup>3</sup> /d
(3) Number	2 Basins
(4) Width	3.5 m
(5) Length	4.0 m
(6) Side Water Depth	3.0 m
(7) Actual Sump Volume	$3.5 \times 4.0 \times 3.0 \times 2$ $= 84.0 \text{ m}^3$
<b>[3] Equipment</b>	
(1) Thickened Sludge Transfer Pumps	
Transfer Time	6.00 Hr
Number	2 W + 2 S
Required Capacity	$= \frac{817 \text{ m}^3}{6.0} \Rightarrow 70 \text{ m}^3/\text{Hr} / \text{Unit}$



D-2 Process Cal EA&al 13MLD Hemigeppura Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>12. Centrifuge</b></p> <p><b>[1] Design Condition</b></p> <p>(1) Type of Dewatering</p> <p>(2) Generated Sludge</p> <p>(3) Design Polyelectrolyte Dosage</p> <p>(4) Volume of Thickend Sludge</p> <p>(5) Consistency of Dewatered Sludge</p> <p>(6) Operation Time</p> <p><b>[2] Volume of Centrifuges</b></p> <p><b>[3] Dewatered Solids</b></p> <p><b>[4] Dewatered Cake Volume</b></p> <p><b>[5] Polyelectrolyte</b></p> <p>(1) Design Polyelectrolyte Dosage</p> <p>(2) Required Polyelectrolyte</p> <p>(3) Dissolving concentration</p> <p>(4) Volume of Polyelectrolyte solution</p>	<p>Centrifuge</p> <p>5,880 kg/day</p> <p>Polyelectrolyte 5 kg/t-DS·day</p> <p>235.2 m<sup>3</sup>/day</p> <p>82 %</p> <p>12 hours/day (6 days per week)</p> <p><u>Digested Solids</u>  <math display="block">\frac{\text{Operation Time} \times \text{No.}}{12 \times 2} \times \frac{235.2}{6} = 11.4</math> <math display="block">\rightarrow 12 \text{ m}^3/\text{hour}</math></p> <p>Digested Sludge × ( 1 + Injection Rate)          = 5,880 × ( 1 + 0.0050 )          = 5,909 kg/day</p> <p>Dewatered Solids × <math>\frac{100}{100 - \frac{\text{Moisture Content}}{7}}</math>  <math display="block">= 5,909 \times \frac{100}{100 - 82} \times \frac{7}{6}</math> <math display="block">= 38.30 \text{ t/day}</math>         apparent specific gravity 1.00  <math display="block">\frac{38.30}{1.0} = 38.3 \text{ m}^3/\text{day}</math></p> <p>Polyelectrolyte 5 kg/t-DS·day          29.40 kg/day          0.20 %          14.70 m<sup>3</sup>/day</p>
--	---

D-2 Process Cal EA&aI 13MLD Hemigepura Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

<b>[6] Equipment</b>	
(1) Centrifuge	
Capacity	12 m <sup>3</sup> /hr
Number	2 W + 1 S
(2) Centrifuge Feed Pumps	
Capacity	12 m <sup>3</sup> /hr
Number	2 W + 1 S
(3) Polyelectrolyte Dosing Pumps	
Volume of Polyelectrolyte solution	14.70 m <sup>3</sup> /day
Operation Time	12 hours/day (6 days per week)
Safety Factor	1.5
Number	2 W + 1 S
Required Capacity	14.70 m <sup>3</sup> /da × 7 / 6 / 12 / 2
	= 0.71 m <sup>3</sup> /Hr
Specification Capacity	0.71 m <sup>3</sup> /Hr × 1.5
	= 1.072 m <sup>3</sup> /Hr ⇒ 1.10 m <sup>3</sup> /Hr /Unit
(4) Polyelectrolyte dosing System	
Preparation time for solution	3 hr
Required dry polymer	29.40 kg/day × 7 / 6 / 12
	= 2.86 kg/hr
	= 8.57 kg per one batch
Feedong time per one batch	30 min
Capacity of Dry polymer Feeder	17 kg/h
Tanks Dimensions	Width 1.5 m × Length 1.5 m × Depth 2.0 m × 2
	= 9 m <sup>3</sup>
Retention Time of Tank	4.50 m <sup>3</sup> /tank / 0.71 m <sup>3</sup> /Hr / 2
	= 3.149 Hr > 3 Hr
Number	2 W + 0 S

D-2 Process Cal EA&al 13MLD Hemigepura Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>11. Centrifuge Feed Sump</b></p>	
<p><b>[1] Design Condition</b></p>	
<p>(1) Generated Thickend Sludge</p>	<p>5,880 kg/day</p>
<p>(2) Solids Consistency</p>	<p>2.50 %</p>
<p>(3) Volume of Thickened Sludge</p>	$\begin{aligned} & \text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3} \\ = & 5,880 \times \frac{100}{2.50} \times 10^{-3} \\ = & 235 \text{ m}^3/\text{day} \\ = & 9.80 \text{ m}^3/\text{h} \end{aligned}$
<p>(4) Sludge feed flow rate</p>	<p>12 m<sup>3</sup>/h × 2 = 24 m<sup>3</sup>/h</p>
<p>(5) Centrifuge Operation Time</p>	<p>12 hours/day ( 6 days per week)</p>
<p><b>[2] Geometry</b></p>	
<p>(1) Basin Dimensions</p>	$\begin{aligned} & \text{Width } 5.0 \text{ m} \times \text{Length } 6.0 \text{ m} \\ & \times \text{Depth } 4.0 \text{ m} \times 2 \\ = & 240.0 \text{ m}^3 \end{aligned}$
<p><b>[3] Equipment</b></p>	
<p>(1) Mixers for Centrifuge Feed Sumps</p>	
<p>Required Volume</p>	<p>240.0 m<sup>3</sup></p>
<p>Number</p>	<p>1 W + 1 S</p>

Material Balance SD4

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Digestion Tank + Centrifugal Dewatering)

Table -1 Input Data

1. Calculation Manner	2	1:Premise that the quality of supernatants are same level removed with inlet sewage 2:Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency	2	1:Total Removal Ratio 2:Outlet Water Quality(input 1or2)
In case of 1 : input data		(%)
In case of 2 : input data	#REF!	(mg/l)
3. Selection of Excess Sludge Generation	2	1:Consideration of Solid Matter Only 2:Consideration of Converting of Solved BOD(input 1or2)
In case of 1 : input data (Sludge generation)		Sludge generation ratio per removal SS(%) T2=Q4·S4=(a·S <sub>BOD</sub> +b·S1-c·θ·XA)·Q3/10 <sup>6</sup> ·(Excess sludge generation formula)
In case of 2 : input data	a	0.4 a:Converting ratio of solved BOD(mgMLSS/mgBOD)
	b	0.9 b:Converting ratio of SS(mgMLSS/mgSS)
	c	0.05 c:Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)
	SBOD	234.50 S <sub>BOD</sub> :Solved BOD quality at inlet reactor
	XA	3,000 XA:MLSS concentration(mg/l)
θ	1 θ:Hydraulic retention time(day)	


Table -2 Basic Conditions

Sewage Flow and Quality		Sludge Moisture and Recovery Ratio		Digestion Tank Conditions		Chemical Conditions for Dewatering	
·Inlet flow : Q <sub>0</sub> (m <sup>3</sup> /D)	13,000	·Primary sludge moisture ratio : W1(%)	0.0	·Removal ratio in primary tank : A2(%)	0.0	·Content of organics in thickened sludge : A6(%)	75.0
·Inlet quality : S <sub>0</sub> (mg/l)	450	·Excess sludge moisture ratio : W2(%)	99.2	·Recovery ratio in sludge thickener : A3(%)	90.0	·Digestion ratio : A7(%)	#REF!
·Total removal ratio : A1(%)	-	·Thickened sludge moisture ratio : W3(%)	97.5	·Recovery ratio in sludge digester : A4(%)	100.0	·Digestion gas generation : A8(Nm <sup>3</sup> /kgVS)	
·Effluent quality : S1(mg/l)	10.0	·Digested sludge moisture ratio : W4(%)	97.5	·Recovery ratio in dewatering : A5(%)	95.0		
·Sludge generation ratio per removal SS : S1(%)	-	·Dewatered sludge moisture ratio : W5(%)	82.0				

Table -3 Material Balance Calculation

	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	手入力(要取束)			16	17
Q(m <sup>3</sup> /day)	13,000	13,800	0	13,800	817	12,983	235	581	0	235	0	15	250	31	219	800	800			12,983	0
T(t·DS/day)	5,850	6,799	0.000	6,799	6,533	0.130	5,880	0.653	0.000	5,880	0.000	0.029	5,909	5,613	0.295	0.949	0.949			0.130	0.136
S(mg/l)	450	493	0	493	8,000	10	25,000	1,124	0	25,000	0	2,000	23,647	180,000	1,351	1,186				10	
X(T5/T0*100)	100	116.2	0.0	116.2	111.7	2.2	100.5	11.2	0.0	100.5	0.0	0.5	101.0	96.0	5.1	16.2				2.2	2.3

Figure -1 Material Balance Model




Calculation Formula						
·Q0=Input Data	·Q3=Q1-Q2	·Q6=T6*100/(100-W3)	·Q9=Q6	·Q12=Q9+Q11	·Q15=Q7+Q10+Q14	·Q5-1=Q5-Q11
·T0=Q0*S0*10 <sup>-6</sup>	·T3=T0*(100-A2)/100	·T6=(T2+T4)*A3/100	·T9=(T6-T8)*A4/100	·T12=T9+T11	·T15=T7+T10+T14	·T5-1=T5-T11
·S0=Input Data	·S3=T3*10 <sup>-6</sup> /Q3	·S6=10 <sup>-6</sup> *Q3/(100-W3)/100	·S9=T9*10 <sup>-6</sup> /Q9	·S12=T12*10 <sup>-6</sup> /Q12	·S15=T15*10 <sup>-6</sup> /Q15	·S5-1=S5
·Q1=Q0+Q15	·Q4=T4*100/(100-W2)	·Q7=(Q2+Q4)-Q6	·Q10=Q6-Q8-Q9	·Q13=T13*100/(100-W5)		
·T1=T0+T15	·T4=余剰汚泥発生式による	·T7=(T2+T4)-T6	·T10=T6-T8-T9	·T13=T12*A5/100		
·S1=T1*10 <sup>-6</sup> /Q1	·S4=10 <sup>-6</sup> *Q4/(100-W2)/100	·S7=T7*10 <sup>-6</sup> /Q7	·S10=T10*10 <sup>-6</sup> /Q10	·S13=10 <sup>-6</sup> *Q13/(100-W5)/100		
·Q2=T2*100/(100-W1)	·Q5=Q3-Q4*(T3-T5)/T4	·Q8=0	·Q11=T10*A9/A10	·Q14=Q12-Q13		
·T2=T1-T3	·T5=Q5*ST/10 <sup>-6</sup>	·T8=T6*A6*A7/10 <sup>-4</sup>	·T11=Q11*S11/10 <sup>-6</sup>	·T14=T12-T13		
·S2=10 <sup>-6</sup> *Q2/(100-W1)/100	·S5=St	#REF!	·S11=10 <sup>-4</sup> *A10	·S14=T14*10 <sup>-6</sup> /Q14		

Material Balance Sheet SD4

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Sheet  
[13MLD STP]



E-1 Process Cal. EA&al 9MLD Nagasandra Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

**Design Condition**

Item	9MLD STP-MPS			
(1) Design Flow for the year 2049	Flow Rate			
		m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s
	Daily Average	13,000	542	0.150
	Daily Maximum	13,000	542	0.150
Hourly Max. Peak factor 2.25	29,250	1219	0.339	
(1) Design Flow for the year 2034	Flow Rate			
		m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s
	Daily Average	9,000	375	0.104
	Daily Maximum	9,000	375	0.104
Hourly Max. Peak factor 2.25	20,250	844	0.234	

**1. Inlet Chamber**

Item	9MLD STP-MPS			
[1] Design Condition				
(1) Design Flow for the year 2049	Hourly Maximum	=	29,250	m <sup>3</sup> /d
		=	0.339	m <sup>3</sup> /sec
(2) Inlet Pipe				
Pipe Diameter	•	×		
Gradient		%		
Roughness Coefficient	n=	0.013	(Manning Formula)	
Full Pipe Flow Rate		m <sup>3</sup> /s		
(3) Influent Water Level	+	m		
[2] Geometory				
(1) Number of Basins	1	Basin		
(2) Depth of Basin	0.600	m	Approx.	
(3) Width of Basin	2.500	m	Approx.	
(4) Length of Basin	2.500	m	Approx.	
(5) Volume required of Basin	0.600	×	2.500	×
			2.500	= 0.6 m <sup>3</sup>
(6) Retention Time	0.600	×	2.500	×
			2.500	∕ 0.339 × 1
	=	11.06	sec	
(7) Basin Demensions	Width	2.500	m	×
				Length
				2.500
				m
	×	Depth	0.600	m

**STP Process Calculation\_Supporting Report 12.2.3**

**2. Coarse Screen Channel**

Item	9MLD STP-MPS					
[1] Geometry						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Width	0.600	m				
Height	0.900	m				
Floor Level	+	5.000	m			
Bottom	+	0.000	m			
Influent Water Level	+	0.500	m			
Velocity	0.339	/	0.600	/	0.500	/ 2
where Design Flow for the year 2049	=	0.565	<	1.000	m/sec	OK
Velocity	0.234	/	0.600	/	0.500	/ 1
where Design Flow for the year 2034	=	0.780	<	1.000	m/sec	OK
(2) Screen Channel						
Number	2.0	Main	+	1.0	Bypass	
Width	1.000	m				
Side Water Depth	0.600	m				
Velocity	0.339	/	1.000	/	0.600	/ 2
where Design Flow for the year 2049	=	0.283	≅	0.450	m/sec	OK
Velocity	0.234	/	1.000	/	0.600	/ 1
where Design Flow for the year 2034	=	0.390	<	0.450	m/sec	OK
(3) Channel Dimensions	Width	1.0	m	×	Length	6.0 m
	×	SWD	0.6	m		
[3] Equipment						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Dimension	Width	0.6	m	×	Height	0.9 m
Design Water Level		m				
(2) Coarse Screens (Main Channel)						
Number	2	W	+	0	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	1.0	m				
Width of side plate	50	mm				
Side Water Depth	0.6	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.339	/	0.900	/	0.550	/ 2
	×	( 20	+	9 )/	20	
	=	0.497	≅	0.800	m/sec	OK
Velocity through screen	0.234	/	0.900	/	0.550	/ 1
where Design Flow for the year 2034	×	( 20	+	9 )/	20	
	=	0.685	<	0.800	m/sec	OK
(3) Coarse Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	50	mm				
Bar Thickness	9	mm				
Channel Width	1.0	m				
Side Water Depth	0.6	m				
Velocity through screen	0.339	/	1.000	/	0.600	/ 2
where Design Flow for the year 2049	×	( 50	+	9 )/	50	
	=	0.333	<	0.800	m/sec	OK
Velocity through screen	0.234	/	1.000	/	0.600	/ 1
where Design Flow for the year 2034	×	( 50	+	9 )/	50	
	=	0.460	<	0.800	m/sec	OK

E-1 Process Cal. EA&al 9MLD Nagasandra Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**3. Raw Sewage Sump**

Item	9MLD STP-MPS	
[2] Geometory		
(1) Raw Sewage Sump		
Number	1	Basin
Dia	10.00	m
Pump Operating Depth	1.000	m
Retention Time whe Design Flow for the year 2049	$( 10.00^2 \times \pi / 4 \times 1.000 ) / 0.339 / 60$	$= 3.86 > 3.75$ min (=minimum time of one pump cycle) OK
Retention Time whe Design Flow for the year 2034	$( 10.00^2 \times \pi / 4 \times 1.000 ) / 0.234 / 60$	$= 5.59 > 3.75$ min (=minimum time of one pump cycle) OK
High Water Level	+ 0.000	m
Pump Off Level	+ -1.000	m
[3] Equipment		
(1) Sewage Pumps 1		
Number	2 W + 1 S	
Bore Diameter	200	mm
Discharge Flow : 40% Q* 2 whe Design Flow for the year 2034	$0.234 \times 3600 \times 40.0\%$	$Q \Rightarrow 337 \Rightarrow 340$ m3/Hr
Total Head	15.0	m
(2) Sewage Pumps 2		
Number	1 W + 1 S	
Bore Diameter	150	mm
Discharge Flow : 20% Q* 1 whe Design Flow for the year 2034	$0.234 \times 3600 \times 20.0\%$	$Q \Rightarrow 168 \Rightarrow 170$ m3/Hr
Total Head	15.0	m



E-1 Process Cal. EA&al 9MLD Nagasandra Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

Item	9MLD STP																																																		
<b>1. STP Design Condition</b>																																																			
(1) Design Flow Rate	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th style="text-align: center;">m3/d</th> <th style="text-align: center;">m3/h</th> <th style="text-align: center;">m3/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td style="text-align: center;">9,000</td> <td style="text-align: center;">375.00</td> <td style="text-align: center;">0.104</td> </tr> <tr> <td>Max Daily</td> <td style="text-align: center;">9,000</td> <td style="text-align: center;">375.00</td> <td style="text-align: center;">0.104</td> </tr> <tr> <td>Max Hourly Peak factor 2.25</td> <td style="text-align: center;">20,250</td> <td style="text-align: center;">843.75</td> <td style="text-align: center;">0.234</td> </tr> </tbody> </table>											m3/d	m3/h	m3/s	Average Daily	9,000	375.00	0.104	Max Daily	9,000	375.00	0.104	Max Hourly Peak factor 2.25	20,250	843.75	0.234																									
	m3/d	m3/h	m3/s																																																
Average Daily	9,000	375.00	0.104																																																
Max Daily	9,000	375.00	0.104																																																
Max Hourly Peak factor 2.25	20,250	843.75	0.234																																																
(2) Design Water Quality	<p style="text-align: right;">Unit: mg/L</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th colspan="2">TP</th> </tr> <tr> <th>NH<sub>4</sub>-N</th> <th>Org-N</th> <th>NOx-N</th> <th>D-P</th> <th>P-P</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td style="text-align: center;">350</td> <td style="text-align: center;">800</td> <td style="text-align: center;">450</td> <td style="text-align: center;">45.5</td> <td style="text-align: center;">17.5</td> <td style="text-align: center;">7</td> <td style="text-align: center;">5</td> <td style="text-align: center;">2</td> </tr> <tr> <td>Outlet</td> <td style="text-align: center;">10</td> <td style="text-align: center;">50</td> <td style="text-align: center;">10</td> <td style="text-align: center;">1</td> <td style="text-align: center;">0</td> <td style="text-align: center;">9</td> <td style="text-align: center;">1</td> <td style="text-align: center;">1</td> </tr> <tr> <td>Removal rate</td> <td style="text-align: center;">97.1%</td> <td style="text-align: center;">93.7%</td> <td style="text-align: center;">97.8%</td> <td colspan="3" style="text-align: center;">85.7%</td> <td colspan="2" style="text-align: center;">71.4%</td> </tr> </tbody> </table>											BOD	COD	SS	T-N			TP		NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P	Inlet	350	800	450	45.5	17.5	7	5	2	Outlet	10	50	10	1	0	9	1	1	Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%	
	BOD	COD	SS	T-N			TP																																												
				NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P																																											
Inlet	350	800	450	45.5	17.5	7	5	2																																											
Outlet	10	50	10	1	0	9	1	1																																											
Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%																																												
<b>2. Inlet Chamber</b>																																																			
<b>[1] Design Condition</b>																																																			
(1) Design Flow Rate	Max Hourly	=	20,250	m3/day																																															
		=	0.234	m3/sec																																															
<b>[2] Geometry</b>																																																			
(1) Number of Basins	1	Basin																																																	
(2) Depth of Basin	1.500	m																																																	
(3) Width of Basin	2.100	m																																																	
(4) Length of Basin	2.000	m																																																	
(5) Volume required of Basin	1.500	×	2.100	×	2.000	=	1.6	m3																																											
(6) Retention Time	1.500	×	2.100	×	2.000	/	0.234	×	1																																										
	=	26.92	sec																																																
(7) Basin Dimensions	Width	2.100	m	×	Length	2.000	m																																												
	×	Depth	1.500	m																																															

**STP Process Calculation Supporting Report 12.2.3**

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Wastewater Flow	$\begin{aligned} \text{Max Hourly} &= 20,250 \text{ m}^3/\text{d} \\ &= 0.234 \text{ m}^3/\text{sec} \end{aligned}$
[2] Geometory	
(1) Inlet Gate	
Number	2 Main + 1 Bypass
Width	0.400 m
Height	0.600 m
Floor Level	+ 2.000 m
Bottom	+ 0.000 m
Influent Water Level	+ 0.300 m
Velocity	$\begin{aligned} &0.234 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 0.300 \text{ } \swarrow \quad 2 \\ = &0.975 \text{ } \div \quad 1.000 \text{ m/sec} \end{aligned}$
(2) Screen Channel	
Number	2 Main + 1 Bypass
Width	0.800 m
Side Water Depth	0.400 m
Velocity	$\begin{aligned} &0.234 \text{ } \swarrow \quad 0.800 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 2 \\ = &0.366 \text{ } \div \quad 0.450 \text{ m/sec} \end{aligned}$
(3) Channel Dimensions	$\begin{aligned} \text{Width} &0.8 \text{ m} \times \text{Length} &6.0 \text{ m} \\ &\times \text{SWD} &0.4 \text{ m} \end{aligned}$
[3] Equipment	
(1) Inlet Gate	
Number	2 W + 1 S
Dimension	Width 0.4 m × Height 0.60 m
Design Water Level	2.00 m
(2) Fine Screens (Main Channel)	
Number	2 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	0.8 m
Width of side plate	50 mm
Side Water Depth	0.4 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	$\begin{aligned} &0.234 \text{ } \swarrow \quad 0.700 \text{ } \swarrow \quad 0.350 \text{ } \swarrow \quad 2 \\ &\times ( \quad 6 \quad + \quad 2 \quad ) / \quad 6 \\ = &0.637 < \quad 0.800 \text{ m/sec} \end{aligned}$
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	0.8 m
Side Water Depth	0.4 m
Velocity through screen	$\begin{aligned} &0.234 \text{ } \swarrow \quad 0.800 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 2 \\ &\times ( \quad 20 \quad + \quad 9 \quad ) / \quad 20 \\ = &0.530 < \quad 0.800 \text{ m/sec} \end{aligned}$

E-1 Process Cal. EA&al 9MLD Nagasandra Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>4. Grit Chamber</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Peak flow = 20,250 m <sup>3</sup> /day = 0.234 m <sup>3</sup> /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0111 m/sec = 960 m <sup>3</sup> /m <sup>2</sup> /day
(4) Average Velocity	0.3 m/sec
<b>[2] Grit Chamber</b>	
(1) Surface Area required	0.234 / 0.0111 = 21.08 m <sup>2</sup>
(2) Number of Basins	1 S + 1 W
(3) Surface Area required/Basin	21.1 / 1 = 21.08 m <sup>2</sup>
(4) Length of Basin	21.08 ^0.5 = 4.6 m → 5.0 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.234 × 60 sec / 1 = 14.0 m <sup>3</sup>
(7) Depth required	14.0 / 5.0 / 5.0 = 0.562 m
(8) Basin Dimensions	Width 5.0 m × Length 5.0 m × Depth 0.6 m (Freeboard 0.3m)
(9) Retention Time	5 × 5.0 × 0.6 / 0.234 × 1 = 60.00 sec
(10) Surface Overflow Rate at Peak Flow	20,250 / 5.0 / 5.0 / 1 = 810 < 960 m <sup>3</sup> /m <sup>2</sup> /day
<b>[3] Parshall Flume</b>	
(1) Design Flow Rate	Q= 234.000 l/sec
(2) Throat width	W= 0.450 m
(3) Water depth Ha	Ha= ( Q / 2264 / W ) <sup>2/3</sup> Ha= 0.375 m
(4) Crest Level	+ m ≐ Minimum water level at downstream channel
(5) Water level at the crest	+ 0.375 m
(6) Channel bottom level	+ m
(7) Upstream Channel width	1.500 m
(8) SWD of Upstream Channel	0.700 m
(9) Average velocity at upstream channel	0.223 m/sec
(10) Total Length of channel	10.000 m
<b>[4] Inlet Weir Gate</b>	
(1) Number	2 Units
(2) Weir Width	0.600 m
(3) Stroke	0.450 m
(4) Overflow Height	0.400 m
(5) Overflow Height (actual)	( 0.234 / 1.840 / 0.600 / 2 ) <sup>2/3</sup> = 0.224 < 0.400 m

**STP Process Calculation Supporting Report 12.2.3**

<b>5. Reactor</b>																																																								
<b>[1] Design Condition</b>																																																								
(1) Design Wastewater Flow	Q = 9,000 m <sup>3</sup> /day (summer) Q' = 9,000 m <sup>3</sup> /day (Winter)																																																							
(2) Design Sewage Quality																																																								
Inlet BOD	350 mg/l																																																							
Outlet BOD	10.0 mg/l																																																							
Inlet S-BOD	235 mg/l assumed as 67% of BOD																																																							
Inlet COD	800 mg/l																																																							
Inlet bCOD : S <sub>0</sub>	578 mg/l																																																							
Inlet nbCOD	223 mg/l																																																							
bCOD/BOD	1.65																																																							
Inlet S-COD : sCOD	271 mg/l																																																							
Inlet rbCOD	231 mg/l bCOD*40%																																																							
Inlet sbCOD	347 mg/l bCOD*60%																																																							
Outlet S-COD : nbsCODe	40 mg/l																																																							
Inlet nbpCOD : nbpCOD	183 mg/l = TCOD-bCOD-nbsCODe																																																							
Inlet SS	450 mg/l																																																							
Inlet VSS	383 mg/l assumed as 85% of TSS																																																							
: VSS <sub>COD</sub>	1.38 gCOD/gVSS = TCOD-sCOD/VSS																																																							
: nbVSS	131.96 gnbVSS/m <sup>3</sup> = nbpCOD/VSS <sub>COD</sub>																																																							
: iTSS	67.50 gnbVSS/m <sup>3</sup> = TSS-VSS																																																							
Inlet T-N	70 mg/l																																																							
Inlet TKN	70 mg/l																																																							
Inlet NH <sub>4</sub> -N	45.0 mg/l																																																							
Inlet T-P	7 mg/l																																																							
Inlet D-P	5 mg/l																																																							
Inlet Alkalinity as CaCO <sub>3</sub>	380 mg/l																																																							
Outlet Kjeldahl N	1.0 mg/l																																																							
Outlet NH <sub>4</sub> -N	1.0 mg/l																																																							
Outlet NO <sub>3</sub> -N	9.0 mg/l																																																							
Outlet T-P	2 mg/l																																																							
Outlet D-P	1 mg/l																																																							
(3) Water Temperature	T = 20.0 °C																																																							
(4) Safety Factor for Nitrogen	SF = 1.5																																																							
(5) Return Sludge Concentration	R <sub>s</sub> = 8,000 mg/l																																																							
(6) MLSS MLVSS	X <sub>TSS</sub> = 3,000 mg/l																																																							
(7) DO in the Reactor	2 mg/L																																																							
<b>[2] Design Value for perfect Nitrification of Nitrification Process</b>																																																								
(1) Activated sludge design kinwtic coefficients at 20°C																																																								
	<table border="1"> <thead> <tr> <th>Coefficient</th> <th>Unit</th> <th>COD oxidatio</th> <th>NH<sub>4</sub> oxidatio</th> <th>NO<sub>2</sub> oxidatio</th> </tr> </thead> <tbody> <tr> <td>μ<sub>max</sub></td> <td>gVSS/gVSS · d</td> <td>6.000</td> <td>0.900</td> <td>1.000</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>mg/L</td> <td>8.000</td> <td>0.500</td> <td>0.200</td> </tr> <tr> <td>Y</td> <td>gVSS/g substrate oxidized</td> <td>0.450</td> <td>0.150</td> <td>0.050</td> </tr> <tr> <td>b</td> <td>gVSS/gVSS · d</td> <td>0.120</td> <td>0.170</td> <td>0.170</td> </tr> <tr> <td>fd</td> <td>unitless</td> <td>0.150</td> <td>0.150</td> <td>0.150</td> </tr> <tr> <td>K<sub>O<sub>2</sub></sub></td> <td>mg/L</td> <td>0.200</td> <td>0.500</td> <td>0.900</td> </tr> <tr> <td>θ Value</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>μ<sub>max</sub></td> <td>unitless</td> <td>1.070</td> <td>1.072</td> <td>1.063</td> </tr> <tr> <td>b</td> <td>unitless</td> <td>1.040</td> <td>1.029</td> <td>1.029</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>unitless</td> <td>1.000</td> <td>1.000</td> <td>1.000</td> </tr> </tbody> </table> <p>Wastwater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF &amp; EDDY/AECOM)</p>	Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio	μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200	Y	gVSS/g substrate oxidized	0.450	0.150	0.050	b	gVSS/gVSS · d	0.120	0.170	0.170	fd	unitless	0.150	0.150	0.150	K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900	θ Value					μ <sub>max</sub>	unitless	1.070	1.072	1.063	b	unitless	1.040	1.029	1.029	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000
Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio																																																				
μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200																																																				
Y	gVSS/g substrate oxidized	0.450	0.150	0.050																																																				
b	gVSS/gVSS · d	0.120	0.170	0.170																																																				
fd	unitless	0.150	0.150	0.150																																																				
K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900																																																				
θ Value																																																								
μ <sub>max</sub>	unitless	1.070	1.072	1.063																																																				
b	unitless	1.040	1.029	1.029																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000																																																				
(2) μ <sub>AOB</sub>	μ <sub>AOB</sub> = 0.3100 g/g · d = μ <sub>max, AOB</sub> [S <sub>NH<sub>4</sub></sub> / (S <sub>NH<sub>4</sub></sub> + K <sub>NH<sub>4</sub></sub> )] [S <sub>O</sub> / (S <sub>O</sub> + K <sub>O, AOB</sub> )] - b <sub>AOB</sub>																																																							
μ <sub>max, AOB, T</sub>	μ <sub>max, AOB, T</sub> = 0.9000 g/g · d = μ <sub>max</sub> * 1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900																																																							
b <sub>AOB, T</sub>	b <sub>AOB, T</sub> = 0.1700 = b * 1.029 <sup>(T-20)</sup> b at 20°C = 0.170																																																							
S <sub>NH<sub>4</sub></sub>	S <sub>NH<sub>4</sub></sub> = 1.0000 mg/l																																																							
DO	DO = 2.0000 mg/l																																																							
K <sub>O, AOB</sub>	K <sub>O, AOB</sub> = 0.5000 mg/l																																																							

E-1 Process Cal. EA&al 9MLD Nagasandra Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

(2) Design SRT	SRT= 4.8387 day ⇒ 5.0000 day	=1/μ <sub>AOB</sub> × SF
(3) Biomass production	P <sub>X,VSS</sub> = 2814.334 kg/d P <sub>X,TSS</sub> = 3708.900 kg/d	=P <sub>X,bio</sub> +Q(nbVSS) =P <sub>X,bio</sub> ×0.85+Q(nbVSS)+Q(TSS <sub>0</sub> -VSS <sub>0</sub> )+5*Q*Al
S	S= 0.4507 mg/l	=K <sub>s</sub> [1+b <sub>H</sub> (SRT)]/[SRT(μ <sub>m</sub> -b <sub>H</sub> )-1]
b <sub>H</sub>	b <sub>H</sub> = 0.1200	=b*1.04 <sup>(T-20)</sup> b at 20°C = 0.120
Y <sub>H</sub>	Y <sub>H</sub> = 0.4500 gVSS/g bCOD	
μ <sub>m,T</sub>	μ <sub>m,T</sub> = 6.0000 g/g·d	=μ <sub>max</sub> *1.04 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 6.000
Y <sub>n</sub>	Y <sub>n</sub> = 0.150 gVSS/g Nox	
NO <sub>x</sub>	NO <sub>x</sub> = 47.400 mg/l	
P <sub>X,bio,VSS</sub>	P <sub>X,bio,VSS</sub> = 1626.704 kg VSS/d 1460.656 131.459 34.589	=Q·Y <sub>H</sub> (S <sub>0</sub> -S)/[1+b <sub>H</sub> (SRT)]+f <sub>d</sub> ·b <sub>H</sub> ·QY <sub>H</sub> (S <sub>0</sub> -S)SRT/[1+b <sub>H</sub> (SRT)] +QY <sub>n</sub> (Nox)[2+b <sub>AOB</sub> (SRT)] =Q·Y <sub>H</sub> (S <sub>0</sub> -S)/[1+b <sub>H</sub> (SRT)] =f <sub>d</sub> ·b <sub>H</sub> ·QY <sub>H</sub> (S <sub>0</sub> -S)SRT/[1+b <sub>H</sub> (SRT)] =QY <sub>n</sub> (Nox)[1+b <sub>AOB</sub> (SRT)]
NO <sub>x</sub>	NO <sub>x</sub> = 47.311 mg/l	=TKN-Ne-0.12P <sub>X,bio</sub> /Q
(4) Required Aeration Tank Volume	V <sub>a</sub> = 6,181 m <sup>3</sup> τ = 16.48 hr ⇒ 18.00 hr	=V <sub>a</sub> /Q × 24
X <sub>VSS</sub> ·V <sub>a</sub>	X <sub>VSS</sub> ·V <sub>a</sub> = 14,072 kg VSS	=P <sub>X,VSS</sub> ·SRT
X <sub>TSS</sub> ·V <sub>a</sub>	X <sub>TSS</sub> ·V <sub>a</sub> = 18,544 kg TSS	=P <sub>X,TSS</sub> ·SRT
F/M	F/M= 0.224 kgBOD/kgMLVSS	
FractionVSS=	FractionVSS= 0.759	
MLVSS=	MLVSS= 2276 mg/L	
(5) BODloading	BODloading= 0.510 kg/m <sup>3</sup> ·d	
(6) Observed Yield	Y <sub>obs,TSS</sub> = 1.178 gTSS/gBOD Y <sub>obs,VSS</sub> = 0.894 gVSS/gBOD	
bCODremoved=	bCODremov= 5,193 kg/d	
(7) effluent NO <sub>2</sub> -N	NO <sub>2</sub> -N= 0.2315 mg/l	=K <sub>s</sub> [1+b <sub>NOB</sub> (SRT)]/[SRT(μ <sub>NOB</sub> -b <sub>NOB</sub> )-1]
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700	=b*1.029 <sup>(T-20)</sup> b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 1.0000 g/g·d	=μ <sub>max</sub> *1.04 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 1.000
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.6897 g/g·d	=μ <sub>max,NOB</sub> [S <sub>0</sub> /(S <sub>0</sub> +K <sub>O2,NOB</sub> )]
	S <sub>0</sub> = 2.000 mg/l	
	K <sub>O2,NOB</sub> = 0.900 mg/l	
(8) effluent NH <sub>4</sub> -N	NH <sub>4</sub> -N= 0.5286 mg/l	=K <sub>s</sub> [1+b <sub>NOB</sub> (SRT)]/[SRT(μ <sub>NOB</sub> -b <sub>NOB</sub> )-1]
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700	=b*1.029 <sup>(T-20)</sup> b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 0.9000 g/g·d	=μ <sub>max</sub> *1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.7200 g/g·d	=μ <sub>max,NOB</sub> [S <sub>0</sub> /(S <sub>0</sub> +K <sub>O2,NOB</sub> )]
	S <sub>0</sub> = 2.000 mg/l	
	K <sub>O2,NOB</sub> = 0.500 mg/l	
(9) Ratio of Return Sludge	8,000*R <sub>r</sub> /(1+R <sub>r</sub> )= 3,000 mg/L 3,000/(8,000-3,000)= 0.60 R <sub>r</sub> = 0.60	

E-1 Process Cal. EA&a1 9MLD Nagasandra Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

<b>[3] Design for Nitrification and Denitrification Process</b>																					
(1) Active biomass concentration	$X_b = Q \cdot (SRT) / V \cdot Y_H (S_0 - S) [1 + b_H (SRT)]$ = 1,181.47 mg/l																				
(2) IR ratio	$IR = NO_x / Ne - 1.0 - R$ = 3.66																				
(3) The amount of NO <sub>3</sub> -N fed to the anoxic tank	$Nox\ feed = (IR + R) \cdot Q \cdot Ne$ = 344,795.49 kg/d																				
(4) The anoxic tank volume	$V_{nor} = 618\ m^3 = V_a \times 10\%$ $V_{nor} = 1,875\ m^3 \quad \tau_{DN} = 5.000\ h$																				
(5) F/M <sub>b</sub>	F/M <sub>b</sub> = 1.42 g/g·d																				
(6) Fraction of rbCOD	40.00% = rbCOD/bCOD																				
	<table border="1"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b<sub>0</sub></th> <th>b<sub>1</sub></th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>	Percent rdCOD(%)	SDNR equation coefficients		b <sub>0</sub>	b <sub>1</sub>	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162
Percent rdCOD(%)	SDNR equation coefficients																				
	b <sub>0</sub>	b <sub>1</sub>																			
10	0.186	0.078																			
20	0.213	0.118																			
30	0.235	0.141																			
40	0.242	0.152																			
50	0.270	0.162																			
(8) SDNR <sub>b</sub>	$SDNR_b = 0.296\ g/g \cdot d = b_0 + b_1 [\ln(F/M_b)]$ $b_0 = 0.242$ $b_1 = 0.152$																				
(8) SDNR	$SDNR = 0.110\ g/g \cdot d = SDNR_b (MLVSS_r / MLVSS)$ $SDNR_{adj} = 0.212\ g/g \cdot d = SDNR_b - 0.029 \ln(F/M_b) - 0.012 \quad IR=3-4$ $= SDNR_b - 0.0166 \ln(F/M_b) - 0.078 \quad IR=2$ $SDNR_t = 0.296\ g/g \cdot d = SDNR_b \cdot \theta^{(F-20)} \quad \theta = 1.026$																				
(9) NO <sub>r</sub>	$NO_r = 468,893.77\ kg/d = N_{nox} \cdot SDNR \cdot X_b$ $> Nox\ feed = 344,795\ kg/d$																				
(10) Alkalinity to be added to maintain pH7	-108.33 mg/l																				
	Influent Alk 380.00 mg/l Alk used 338.44 mg/l = 7.14 × Nox Alk produced 136.77 mg/l = 3.57 × (NO <sub>x</sub> - NO <sub>x,e</sub> ) Alk to maintain 70.00 mg/l																				
<b>[4] Design of Phosphorus Removal Process</b>																					
(1) Removal T-P	3.13 mg/l																				
P in waste sludge	px = 1.00%																				
Generated waste sludge	Px <sub>vss</sub> = 2814.334 kg/d																				
Rmval Phosphorus	28.14334224 kg/d																				
(2) Effluent T-P without Al	3.87 mg/l																				
(3) Required Al to initial soluble phosphorus ratio	1.00 mol/mol																				
(4) Required Al dosing rate	3.48 mg/l as Al																				
	42.98 mg/l as crystal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> · 18H <sub>2</sub> O																				
(5) Required Aluminum Sulfate	386.80 kg/d																				
(6) Required Aluminum Sulfate solutic 10%	3.68 m <sup>3</sup> /d																				
	153.49 L/H																				
(7) Additional sludge	156.81 kg/d																				

E-1 Process Cal. EA&al 9MLD Nagasandra Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**[5] Reactor**

- (1) Total volume of Aeration Basins
- (2) Total volume of Anoxic Basins

$$V_A = Q \cdot \theta_a / 24$$

$$= 6,750 \text{ m}^3$$

$$V_{DN} = Q \cdot \theta_{DN} / 24$$

$$= 1,875 \text{ m}^3$$

Item	Volume required	Retention Time required		Ratio of Volume	
		Summer	Winter		
unit	m <sup>3</sup>	hour	hour		
Anaerobic	V <sub>AN</sub>	560	1.50	1.50	0.30
Anoxic	V <sub>DN</sub>	1,875	5.00	5.00	1.00
Aerobic	V <sub>A</sub>	6,750	18.00	18.00	3.60
Total	V	9,185	24.50	24.50	

**[6] Geometry**

- (1) Basin Dimensions
  - Cross Section
  - Hantzschn Subtraction
  - after Subtraction
  - Total Volume
- (2) Partition of Basin

Width	Length	Depth	Basins
8.0	108.0	5.5	2
8.0*5.5	=		44.0 m <sup>2</sup> /Basin
	=		1.0 m <sup>2</sup> /Basin
44.0-1.0	=		43.0 m <sup>2</sup> /Basin
43.0*108.0	=		4,644 m <sup>2</sup> /Basin 9,288 m <sup>3</sup> /Total

Item	unit	Anaerobic	Anoxic	Aerobic	Total
Cross Section	m <sup>2</sup>	43.0			
Length required	m	<b>6.5</b>	<b>21.8</b>	<b>78.5</b>	<b>106.8</b>
Volume required per Basin	m <sup>3</sup>	280	938	3,375	4,593
Total Volume required	m <sup>3</sup>	560	1,875	6,750	9,185
Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0	
Actual Length	m	7.0	22.0	79.0	108.0
Actual Volume per Basin	m <sup>3</sup>	301	946	3,397	4,644
Actual Total Volume	m <sup>3</sup>	602	1,892	6,794	9,288
Actual Ratio of Volume		0.32	1.00	3.59	
Actual Retention Time	hour	1.61	5.05	18.12	24.78

**[7] Equipment**

- (1) Ras Pumps
  - Ras Ratio
  - Required Capacity
  - Number
- (2) Circulation Pumps
  - Ras Ratio
  - Required Capacity
  - Number
- (3) SAS Pumps
  - Excess Sludge
  - Sludge withdraw
  - Running Time
  - Required Capacity
  - Number

60%

9,000 m<sup>3</sup>/day × 60% / 24 / 2

= 113 m<sup>3</sup>/Hr ⇒ 115 m<sup>3</sup>/Hr

2 Work

2 Stanby

366%

9,000 m<sup>3</sup>/day × 366% / 24 / 4

= 343 m<sup>3</sup>/Hr ⇒ 345 m<sup>3</sup>/Hr

4 Work

2 Stanby

488 m<sup>3</sup>/day

12 Times/day

0.5 Hr/Time

488 m<sup>3</sup>/day / 12 / 0.5 / 2

= 40.68 m<sup>3</sup>/Hr ⇒ 45 m<sup>3</sup>/Hr

2 Work

2 Stanby

E-1 Process Cal. EA&al 9MLD Nagasandra Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

(4) Alum Solution Tank										
Number	2	W	+	0	S					
Alum concentration as crystal	10 %									
Gravity of dissolved dechlorine	1.05									
Required solution volume	386.80 kg / d		×	100	/	10	/	1.05	/	1000
	=	3.68		m3/d						
Volume of Tank	2.6			m3/tank						
Total Volume of Tanks	5.2			m3		(Duration=	1.41	day)		
(5) Mixer for Alum Solution Tank										
Number	2	W	+	0	S					
(6) Alum Dosing Pump										
Number	2	W	+	1	S					
Capacity	3.68 m3/d	/	24	×	1000	/	2	×	2	
	153.49 l/h/unit		⇒	160	l/h/unit					



E-1 Process Cal. EA&al 9MLD Nagasandra Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>6. Air Requirement at Average Flow</b>	
[1] Design Condition	
(1) AOR	AOR = 3,894 kg/day = 162.2 kg/h
Q <sub>in</sub> : Design Average Flow m <sup>3</sup> /d	9,000
Inlet bCOD : S <sub>0</sub>	578 mg/l
S=	0.451 mg/l
Nox=	47.400 mg/l
P <sub>X,bio</sub> =	1,592.1 kg VSS/d does not include nitrifying bacteria
R <sub>0</sub> =	R <sub>0</sub> = Q(S <sub>0</sub> - S - k(Nox - NOx)) - 1.42P <sub>X,bio</sub> + 4.57Q · NOx
R <sub>0</sub> =	3,894 kg O <sub>2</sub> /d
k=	2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{\text{AOR} \times C_s \cdot a \times 1.024^{20-T}}{\alpha \times F (\beta \cdot C_{sw} / C_s \cdot (P_b / P_a) a - C_A)}$
	C <sub>s</sub> : Saturated DO at sea level and 20 °C 9.09 mg/L
	C <sub>sw</sub> : Saturated DO at sea level and operating Temperature 9.09 mg/L at 20 °C
	20-T : 0.0 1.024 <sup>20-T</sup> : 1.0000
	C <sub>A</sub> : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1 + 0.40D <sub>j</sub> /P <sub>a</sub> 1.19357
	D <sub>j</sub> : Tank Liquid Depth 5.00 m
	P <sub>a</sub> : Standard absolute pressure at s 10.332 m
	P <sub>b</sub> : Absolute pressure at Plant Site Elevation m
	P <sub>b</sub> /P <sub>a</sub> : exp[-gM(z <sub>b</sub> -z <sub>a</sub> )/R*T] 0.900
	g : Acceleration due to Gravity 9.80665 m/s <sup>2</sup>
	M : Mole of Air 28.97 kg/kg-mole
	z <sub>b</sub> : Plant Site Elevation 900 m
	z <sub>a</sub> : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 293.15 Kelvin
	α : relative Transfer Rate to clean Water 0.65
	β : relative DO Saturation to clean Water 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{42,246}{4.2591} = 9,918.89 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Standard O <sub>2</sub> required at Field Conditions per Basin =	4,959 kg/day
(5) SOTE for the above Effective Aeration Depth	28.0 %
(6) Fraction of O <sub>2</sub> in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	15%
(9) Air required at Field Conditions per Basins	= 72,940 m <sup>3</sup> /day = 3,039.2 m <sup>3</sup> /hr
[2] Equipment	

Air Requirement at Average Flow 12/21

E-1 Process Cal. EA&al 9MLD Nagasandra\_Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

(1) Air Blower					
Number	4	W	+	2	S
Required Capacity	3039.2	m <sup>3</sup> /Hr·Basin	/	2	unit/Basin
	= 1519.6	m <sup>3</sup> /h	⇒	1600	m <sup>3</sup> /h/Unit
Pressure	65	kPa			
Safety Factor	10	%			
Heat capacity ratio	1.4				
Atmospheric pressure at site elevation	91.234	kPa			
Total inlet pressure	89.234	kPa			
Volume rate of flow at inlet point	30.273	m <sup>3</sup> /min			
Total discharge pressure	156.234	kPa			
Overall adiabatic efficiency	0.65				
Inlet air temperature (min.)	15	°C			
Shaft power	42.801	kW			
Rated Output of Motor	47.082	kW	⇒	55	kW

Air Requirement at Average Flow13/21

E-1 Process Cal. EA&al 9MLD Nagasandra Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>7. Final Clarifire</b></p>			
<p>[1] <b>Design Condition</b></p>			
<p>(1) Design Wastewater Flow</p>	<p>Q= 9,000 m<sup>3</sup>/day</p>		
<p>(2) Water Temperature</p>	<p>T= 20.0 °C</p>		
<p>(3) MLSS</p>	<p>X<sub>ef</sub>= 3,000 mg/l</p>		
<p>(4) SVI</p>	<p>SVI= 300</p>		
<p>(5) Sedimentation Velocity</p>	<p><math>v = 4.899 \cdot 10^6 \cdot T^{(0.954)} \cdot X_{ef}^{(-1.354)} \cdot SVI^{(-0.77)}</math>  <math>= 4.899 \cdot 10^6 \cdot 20.0^{0.954} \cdot 3,000^{-1.354} \cdot 150^{-0.770}</math>  <math>= 20.7 \text{ m/day}</math></p>		
<p>(6) Surface Overflow Rate required</p>	<p><math>S' = v / (1.5 \cdot 1) = 20.7 / (1.5 \cdot 1.0) = 13.8 \text{ m}^3/\text{m}^2 \cdot \text{day}</math></p>	<p>→</p>	<p><math>12.0 \text{ m}^3/\text{m}^2 \cdot \text{day}</math></p>
<p>[2] <b>Geometry</b></p>			
<p>(1) Surface Area required</p>	<p>A = 9,000/12.0 = 750 m<sup>2</sup></p>		
<p>(2) Demensions</p>	<p>Diameter                  Depth          Basin</p>		
	<p>22.0                          3.5                  2</p>		
<p>(3) Actual Surface Area</p>	<p>S = 22.0<sup>2</sup> * 3.14 /4 * 2.0 = 760 m<sup>2</sup></p>		
<p>(4) Surface Overflow Rate</p>	<p>S = 9,000/760 = 11.8 m<sup>3</sup>/m<sup>2</sup> · day</p>		

**STP Process Calculation Supporting Report 12.2.3**

<b>8. Chlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 9,000 m <sup>3</sup> /day 375.00 m <sup>3</sup> /h Peak Flow 20,250 m <sup>3</sup> /day 843.75 m <sup>3</sup> /h
(2) Contact Time	30 min
(3) Type of Chlorine	Cl <sub>2</sub> -GAS
(4) Design Chlorine Dosage Rate	10 mg/L
(5) Required Chlorine per day	Average Daily Flow / 1000 × Design Chlorine Dosage Rate = 90.0 kg/d = 3.75 kg/h
<b>[2] Chlorination Contact Tank</b>	
(1) Volume required	Average Daily Flow / 1440 × Contact Time = 187.5 m <sup>3</sup>
(2) Nos. of lanes	3 lanes
(3) Width of lane	2.00 m
(4) Length of lane	16.00 m
(5) Side Water Depth	2.00 m
(6) Nos. of Tanks	1 tank
(7) Total Width of Tank	6.80 m Approx..
(8) Average Velocity	Decant Flow / 3600 / Width / Depth = 375.00 / 3600 / 2.00 / 2.00 = 0.026 m/sec
(9) Total Volume	Width × Length × Depth × Nos. of lanes × Nos. of Tanks = 2.0 m × 16.0 m × 2.0 m × 3 × 1 = 192 m <sup>3</sup> > 187.5 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Chlorine Dosing Condition	
Operation Dosage Rate -1	DC1 10 mg/L
(2) Chlorine Cylinder	
Type	- Cylindrical Convexsd Container
Cylinder Capacity	Cc 928 kg/cylinder
Average Dosage Rate -1	q1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 90 kg/day
Maximum Dosage Rate -1	q3 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 203 kg/day
Storage day	T More than 15 days
Required Storage Capacity	EC1 D × T = 1,350 kg
Unit Number	EN1 EC1 / Cc = 1.5 cylinders
Maximum Operation Numbers	
Cl <sub>2</sub> -Gas Volatilize Rate	Vr1 ##### @ 20 <sup>o</sup> C Standard temperature
Maximum Dosing Rate	DC1 10 mg/L, Q <sub>T-D</sub> × q3 × 10 <sup>-3</sup> / 24 = 8.44 kg/h
Operation Numbers	EN2 DC1 / Vr1 = 1.1sets
Number	2 W + 2 S
(3) Chlorinator	
Type	Solution Feed Vacuum Type
Number	1 W + 1 S
Operation Dosage Rate -1	Dq1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 202.5 kg/day
Required Dosage Rate	Chlorine -1 : Dq1 / (EN1 × 24) = Minimum Maximum 0.00 kg/hr 8.5 kg/hr

**STP Process Calculation Supporting Report 12.2.3**

(4) Chlorine Booster Pump	
Type	Branchy on the water supply pipe
Water Demand	Water requiamet for mixsed Chlori
Chlorinator Discharge	(kg/hr) 1.0 1.5 2.0 2.5 3.0 4.0
Water Demand	(L/min) 15 20 25 30 35 40
Chlorinator Discharge	(kg/hr) 5.0 6.0 10.0 50.0 100.0 200.0
Water Demand	(L/min) 45 50 60 300 600 1,200
Water requiamet	-
For Chlorin	Qp1 Maximum dosage rate 8.5 kg/hr therefore 60 L/min
Booster Pump Type	Single suction volute pump
Number	1 W + 1 S
<b>9. Dechlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 9,000 m <sup>3</sup> /day
(2) Contact Time	10 min
(3) Type of Dechlorine	Sodium Thiosulfate (Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 5H <sub>2</sub> O)
(4) Free Residual Chlorine	1.0 mg/L assumed value
(5) Consumption per day	Average Daily Flow / 1000 × Free Residual Chlorine × 1.75 × 1.5 (safety factor) = 23.6 kg/d = 0.98 kg/h
<b>[2] Dechlorination Contact Tank</b>	
(1) Volume required	Average Flow Rate / 60 × Contact Time = 62.5 m <sup>3</sup>
(2) Width of lane	6.80 m
(3) Length of lane	5.00 m
(4) Side Water Depth	2.00 m
(5) Nos. of Tanks	1 tank
(6) Total Volume	Width × Length × Depth = 6.8 m × 5.0 m × 2.0 m = 68 m <sup>3</sup> > 62.5 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Dechlorine Solution Tank	
Number	1 W + 0 S
Dechlorine concentration	10 %
Gravity of dissolved dechlorine	1.10
Required solution volume	23.63 kg/d × 100 / 10 / 1.10 / 1000 = 0.21 m <sup>3</sup> /d
Volume of Tank	0.360 m <sup>3</sup> /tank (= 0.6 mW × 0.6 mL × 1.0 mH)
Total Volume of Tanks	0.360 m <sup>3</sup> (Duration= 1.68 day)
(2) Mixer for Dechlorine Solution Tank	
Number	2 W + 0 S
(3) Dechlorine Dosing Pump	
Number	1 W + 1 S
Capacity	0.48 m <sup>3</sup> /d / 24 × 1000 / 1 20.13 l/h/unit ⇒ 21 l/h/unit

**STP Process Calculation Supporting Report 12.2.3**

<p><b>10. Centrifuge</b>  <b>[1] Design Condition</b>                  (1) Type of Dewatering                  (2) Generated Sludge                  (3) Design Polyelectrolyte Dosage                  (4) Volume of Thickend Sludge                  (5) Consistency of Dewatered Sludge                  (6) Operation Time</p>	<p>Centrifuge                  3,905 kg/day                  Polyelectrolyte 5 kg/t-DS·day                  488.1 m<sup>3</sup>/day                  82 %                  12 hours/day (6 days per week)</p>
<p><b>[2] Volume of Centrifuges</b></p>	<p><u>Digested Solids</u>                  Operation Time × No. × Operation/week  <math display="block">= \frac{488.1}{12 \times 2} \times \frac{7}{6} = 23.7</math> <math display="block">\rightarrow 24 \text{ m}^3/\text{hour}</math></p>
<p><b>[3] Dewatered Solids</b></p>	<p>Digested Sludge × ( 1 + Injection Rate)                  = 3,905 × ( 1 + 0.0050 )                  = 3,924 kg/day</p>
<p><b>[4] Dewatered Cake Volume</b></p>	<p>Dewatered Solids × <math>\frac{100}{100 - \frac{\text{Moisture Content}}{7}}</math>  <math display="block">= 3,924 \times \frac{100}{100 - \frac{7}{82}} \times \frac{7}{6}</math> <math display="block">= 25.43 \text{ t/day}</math> <p>apparent specific gravity 1.00  <math display="block">\frac{25.43}{1.0} = 25.4 \text{ m}^3/\text{day}</math></p> </p>
<p><b>[5] Polyelectrolyte</b>                  (1) Design Polyelectrolyte Dosage                  (2) Required Polyelectrolyte                  (3) Dissolving concentration                  (4) Volume of Polyelectrolyte solution</p>	<p>Polyelectrolyte 5 kg/t-DS·day                  19.52 kg/day                  0.20 %                  9.76 m<sup>3</sup>/day</p>

E-1 Process Cal. EA&al 9MLD Nagasandra Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

<b>[6] Equipment</b>	
(1) Centrifuge	
Capacity	24 m <sup>3</sup> /hr
Number	2 W + 1 S
(2) Centrifuge Feed Pumps	
Capacity	24 m <sup>3</sup> /hr
Number	2 W + 1 S
(3) Polyelectrolyte Dosing Pumps	
Volume of Polyelectrolyte solution	9.76 m <sup>3</sup> /day
Operation Time	12 hours/day (6 days per week)
Safety Factor	1.5
Number	2 W + 1 S
Required Capacity	9.76 m <sup>3</sup> /da × 7 / 6 / 12 / 2
	= 0.47 m <sup>3</sup> /Hr
Specification Capacity	0.47 m <sup>3</sup> /Hr × 1.5
	= 0.712 m <sup>3</sup> /Hr ⇒ 0.80 m <sup>3</sup> /Hr /Unit
(4) Polyelectrolyte dosing System	
Preparation time for solution	3 hr
Required dry polymer	19.52 kg/day × 7 / 6 / 12
	= 1.90 kg/hr
	= 5.69 kg per one batch
Feedong time per one batch	30 min
Capacity of Dry polymer Feeder	11 kg/h
Tanks Dimensions	Width 1.5 m × Length 1.5 m
	× Depth 1.5 m × 2 (Freeboard 0.5m)
	= 6.8 m <sup>3</sup>
Retention Time of Tank	3.40 m <sup>3</sup> /tank / 0.47 m <sup>3</sup> /Hr / 2
	= 3.582 Hr > 3 Hr
Number	2 W + 0 S

E-1 Process Cal. EA&al 9MLD Nagasandra Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>11. Centrifuge Feed Sump</b>	
<b>[1] Design Condition</b>	
(1) Generated Thickend Sludge	3,905 kg/day
(2) Solids Consistency	0.80 %
(3) Volume of Thickened Sludge	$\begin{aligned} & \text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3} \\ = & 3,905 \times \frac{100}{0.80} \times 10^{-3} \\ = & 488 \text{ m}^3/\text{day} \\ = & 20.34 \text{ m}^3/\text{h} \end{aligned}$
(4) Sludge feed flow rate	24 m <sup>3</sup> /h × 2 = 48 m <sup>3</sup> /h
(5) Centrifuge Operation Time	12 hours/day ( 6 days per week)
<b>[2] Geometry</b>	
(1) Basin Dimensions	$\begin{aligned} & \text{Width } 6.0 \text{ m} \times \text{Length } 6.0 \text{ m} \\ & \times \text{Depth } 4.0 \text{ m} \times 2 \\ = & 288.0 \text{ m}^3 \end{aligned}$
<b>[3] Equipment</b>	
(1) Mixers for Centrifuge Feed Sumps	
Required Volume	288.0 m <sup>3</sup>
Number	1 W + 1 S



STP Process Calculation\_Supporting Report 12.2.3

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Digestion Tank + Centrifugal Dewatering)

Table -1 Input Data

1. Calculation Manner	2	1:Premise that the quality of supernatants are same level removed with inlet sewage 2:Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency	2	1:Total Removal Ratio 2:Outlet Water Quality(input 1or2)
In case of 1 : input data		(%)
In case of 2 : input data	#REF!	(mg/l)
3. Selection of Excess Sludge Generation	2	1:Consideration of Solid Matter Only 2:Consideration of Converting of Solved BOD(input 1or2)
In case of 1 : input data (Sludge generation)		Sludge generation ratio per removal SS(%) T2=Q4·S4-(a·S <sub>BOD</sub> +b·S1-c·θ·XA)·Q3/10 <sup>6</sup> ·(Excess sludge generation formula)
In case of 2 : input data	a	0.4 a:Converting ratio of solved BOD(mgMLSS/mgBOD)
	b	0.9 b:Converting ratio of SS(mgMLSS/mgSS)
	c	0.05 c:Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)
	SBOD	234.50 S <sub>BOD</sub> :Solved BOD quality at inlet reactor
	XA	3,000 XA:MLSS concentration(mg/l)
θ	1 θ:Hydraulic retention time(day)	


Table -2 Basic Conditions

Sewage Flow and Quality	Sludge Moisture and Recovery Ratio	Digestion Tank Conditions	Chemical Conditions for Dewatering
· Inlet flow : Q <sub>0</sub> (m <sup>3</sup> /D)	· Primary sludge moisture ratio : W1(%)	· Content of organics in thickened sludge : A6(%)	· Chemical dosage : A9(%)
· Inlet quality : S <sub>0</sub> (mg/l)	· Excess sludge moisture ratio : W2(%)	· Digestion ratio : A7(%)	· Chemical dissolve concentration : A10(%)
· Total removal ratio : A1(%)	· Thickened sludge moisture ratio : W3(%)	· Digestion gas generation : A8(Nm <sup>3</sup> /kgVS)	
· Effluent quality : S1(mg/l)	· Digested sludge moisture ratio : W4(%)		
· Sludge generation ratio per removal SS : S1(%)	· Dewatered sludge moisture ratio : W5(%)		

Table -3 Material Balance Calculation

	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	手入力(要取束)	16	17
Q(m <sup>3</sup> /day)	9,000	9,477	0	9,477	488	8,989	488	0	0	488	0	10	498	21	477	477		8,989	0
T(t·DS/day)	4,050	4,246	0,000	4,246	3,905	0,090	3,905	0,000	0,000	3,905	0,000	0,020	3,924	3,728	0,196	0,196	0,196	0,090	0,251
S(mg/l)	450	448	0	448	8,000	10	8,000	#DIV/0!	0	8,000	0	2,000	7,882	180,000	411	411		10	
X(T5/T0*100)	100	104.8	0.0	104.8	96.4	2.2	96.4	0.0	0.0	96.4	0.0	0.5	96.9	92.1	4.8	4.8		2.2	6.2

Figure -1 Material Balance Model




Calculation Formula						
· Q0=Input Data	· Q3=Q1-Q2	· Q6=T6*100/(100-W3)	· Q9=Q6	· Q12=Q9+Q11	· Q15=Q7+Q10+Q14	· Q5-1=Q5-Q11
· T0=Q0*S0*10 <sup>-6</sup>	· T3=T0*(100-A2)/100	· T6=(T2+T4)*A3/100	· T9=(T6-T8)*A4/100	· T12=T9+T11	· T15=T7+T10+T14	· T5-1=T5-T11
· S0=Input Data	· S3=T3*10 <sup>-6</sup> /Q3	· S6=10 <sup>-6</sup> *Q3/(100-W3)/100	· S9=T9*10 <sup>-6</sup> /Q9	· S12=T12*10 <sup>-6</sup> /Q12	· S15=T15*10 <sup>-6</sup> /Q15	· S5-1=S5
· Q1=Q0+Q15	· Q4=T4*100/(100-W2)	· Q7=(Q2+Q4)-Q6	· Q10=Q6-Q8-Q9	· Q13=T13*100/(100-W5)		
· T1=T0+T15	· T4=余剰汚泥発生式による	· T7=(T2+T4)-T6	· T10=T6-T8-T9	· T13=T12*A5/100		
· S1=T1*10 <sup>-6</sup> /Q1	· S4=10 <sup>-6</sup> *Q4/(100-W2)/100	· S7=T7*10 <sup>-6</sup> /Q7	· S10=T10*10 <sup>-6</sup> /Q10	· S13=10 <sup>-6</sup> *Q13/(100-W5)/100		
· Q2=T2*100/(100-W1)	· Q5=Q3-Q4*(T3-T5)/T4	· Q8=0	· Q11=T10*A9/A10	· Q14=Q12-Q13		
· T2=T1-T3	· T5=Q5*ST/10 <sup>-6</sup>	· T8=T6*A6*A7/10 <sup>-4</sup>	· T11=Q11*S11/10 <sup>-6</sup>	· T14=T12-T13		
· S2=10 <sup>-6</sup> *Q2/(100-W1)/100	· S5=St	#REF!	· S11=10 <sup>-4</sup> *A10	· S14=T14*10 <sup>-6</sup> /Q14		

Material Balance Sheet SD4

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Sheet  
[3MLD STP]



E-2 Process Cal. EA&al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

**Design Condition**

Item	10MLD STP-MPS			
(1) Design Flow for the year 2049	Flow Rate			
		m3/d	m3/h	m3/s
	Daily Average	16,000	667	0.185
	Daily Maximum	16,000	667	0.185
Hourly Max. Peak factor 2.25	36,000	1500	0.417	
(1) Design Flow for the year 2034	Flow Rate			
		m3/d	m3/h	m3/s
	Daily Average	####	417	0.116
	Daily Maximum	####	417	0.116
Hourly Max. Peak factor 2.25	####	938	0.260	

**1. Inlet Chamber**

Item	10MLD STP-MPS			
[1] Design Condition				
(1) Design Flow for the year 2049	Hourly Maximum	=	36,000	m3/d
		=	0.417	m3/sec
(2) Inlet Pipe				
Pipe Diameter	•	×		
Gradient		%		
Roughness Coefficient	n=	0.013	(Manning Formula)	
Full Pipe Flow Rate		m3/s		
(3) Influent Water Level	+	m		
[2] Geometory				
(1) Number of Basins	1	Basin		
(2) Depth of Basin	0.600	m	Approx.	
(3) Width of Basin	2.000	m	Approx.	
(4) Length of Basin	2.500	m	Approx.	
(5) Volume required of Basin	0.600	×	2.000	×
			2.500	=
				0.5
				m3
(6) Retention Time	0.600	×	2.000	×
			2.500	/
			0.417	×
				1
	=	7.19	sec	
(7) Basin Demensions	Width	2.000	m	×
				Length
				2.500
				m
	×	Depth	0.600	m

E-2 Process Cal. EA&al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

**2. Coarse Screen Channel**

Item	10MLD STP-MPS					
[1] Geometry						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Width	0.600	m				
Height	0.900	m				
Floor Level	+	5.000	m			
Bottom	+	0.000	m			
Influent Water Level	+	0.600	m			
Velocity	0.417	/		0.600	/	0.600 / 2
where Design Flow for the year 2049	=	0.579	<	1.000	m/sec	OK
Velocity	0.260	/		0.600	/	0.600 / 1
where Design Flow for the year 2034	=	0.722	<	1.000	m/sec	OK
(2) Screen Channel						
Number	2.0	Main	+	1.0	Bypass	
Width	1.000	m				
Side Water Depth	0.600	m				
Velocity	0.417	/		1.000	/	0.600 / 2
where Design Flow for the year 2049	=	0.348	≐	0.450	m/sec	OK
Velocity	0.260	/		1.000	/	0.600 / 1
where Design Flow for the year 2034	=	0.433	<	0.450	m/sec	OK
(3) Channel Dimensions	Width	1.0	m	×	Length	6.0 m
	×	SWD	0.6	m		
[3] Equipment						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Dimension	Width	0.6	m	×	Height	0.9 m
Design Water Level		m				
(2) Coarse Screens (Main Channel)						
Number	2	W	+	0	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	1.0	m				
Width of side plate	50	mm				
Side Water Depth	0.6	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.417	/		0.900	/	0.550 / 2
	×	( 20	+	9 )/	20	
	=	0.611	≐	0.800	m/sec	OK
Velocity through screen	0.260	/		0.900	/	0.550 / 1
where Design Flow for the year 2034	×	( 20	+	9 )/	20	
	=	0.762	<	0.800	m/sec	OK
(3) Coarse Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	50	mm				
Bar Thickness	9	mm				
Channel Width	1.0	m				
Side Water Depth	0.6	m				
Velocity through screen	0.417	/		1.000	/	0.600 / 2
where Design Flow for the year 2049	×	( 50	+	9 )/	50	
	=	0.410	<	0.800	m/sec	OK
Velocity through screen	0.260	/		1.000	/	0.600 / 1
where Design Flow for the year 2034	×	( 50	+	9 )/	50	
	=	0.511	<	0.800	m/sec	OK

E-2 Process Cal. EA&al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

**3. Raw Sewage Sump**

Item	10MLD STP-MPS	
[2] Geometory		
(1) Raw Sewage Sump		
Number	1	Basin
Dia	11.00	m
Pump Operating Depth	1.000	m
Retention Time whe Design Flow for the year 2049	$( \frac{11.00^2 \times \pi}{4} \times 1.000 ) / 0.417$	$/ 60$ = 3.80 > 3.75 min (=minimum time of one pump cycle) OK
Retention Time whe Design Flow for the year 2034	$( \frac{11.00^2 \times \pi}{4} \times 1.000 ) / 0.260$	$/ 60$ = 6.09 > 3.75 min (=minimum time of one pump cycle) OK
High Water Level	+ 0.000	m
Pump Off Level	+ -1.000	m
[3] Equipment		
(1) Sewage Pumps 1		
Number	2	W + 1 S
Bore Diameter	200	mm
Discharge Flow : 40% Q* 2 whe Design Flow for the year 2034	$0.260 \times 3600$	$\times 40.0\% Q$ = 374 $\Rightarrow$ 380 m <sup>3</sup> /Hr
Total Head	15.0	m
(2) Sewage Pumps 2		
Number	1	W + 1 S
Bore Diameter	150	mm
Discharge Flow : 20% Q* 1 whe Design Flow for the year 2034	$0.260 \times 3600$	$\times 20.0\% Q$ = 187 $\Rightarrow$ 190 m <sup>3</sup> /Hr
Total Head	15.0	m

E-2 Process Cal. EA&al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

Item	10MLD STP																																																		
<b>1. STP Design Condition</b>																																																			
(1) Design Flow Rate	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th style="text-align: center;">m3/d</th> <th style="text-align: center;">m3/h</th> <th style="text-align: center;">m3/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td style="text-align: center;">10,000</td> <td style="text-align: center;">416.67</td> <td style="text-align: center;">0.116</td> </tr> <tr> <td>Max Daily</td> <td style="text-align: center;">10,000</td> <td style="text-align: center;">416.67</td> <td style="text-align: center;">0.116</td> </tr> <tr> <td>Max Hourly Peak factor 2.25</td> <td style="text-align: center;">22,500</td> <td style="text-align: center;">937.50</td> <td style="text-align: center;">0.260</td> </tr> </tbody> </table>											m3/d	m3/h	m3/s	Average Daily	10,000	416.67	0.116	Max Daily	10,000	416.67	0.116	Max Hourly Peak factor 2.25	22,500	937.50	0.260																									
	m3/d	m3/h	m3/s																																																
Average Daily	10,000	416.67	0.116																																																
Max Daily	10,000	416.67	0.116																																																
Max Hourly Peak factor 2.25	22,500	937.50	0.260																																																
(2) Design Water Quality	<p style="text-align: right;">Unit: mg/L</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th colspan="2">TP</th> </tr> <tr> <th>NH<sub>4</sub>-N</th> <th>Org-N</th> <th>NOx-N</th> <th>D-P</th> <th>P-P</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td style="text-align: center;">350</td> <td style="text-align: center;">800</td> <td style="text-align: center;">450</td> <td style="text-align: center;">45.5</td> <td style="text-align: center;">17.5</td> <td style="text-align: center;">7</td> <td style="text-align: center;">5</td> <td style="text-align: center;">2</td> </tr> <tr> <td>Outlet</td> <td style="text-align: center;">10</td> <td style="text-align: center;">50</td> <td style="text-align: center;">10</td> <td style="text-align: center;">1</td> <td style="text-align: center;">0</td> <td style="text-align: center;">9</td> <td style="text-align: center;">1</td> <td style="text-align: center;">1</td> </tr> <tr> <td>Removal rate</td> <td style="text-align: center;">97.1%</td> <td style="text-align: center;">93.7%</td> <td style="text-align: center;">97.8%</td> <td colspan="3" style="text-align: center;">85.7%</td> <td colspan="2" style="text-align: center;">71.4%</td> </tr> </tbody> </table>											BOD	COD	SS	T-N			TP		NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P	Inlet	350	800	450	45.5	17.5	7	5	2	Outlet	10	50	10	1	0	9	1	1	Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%	
	BOD	COD	SS	T-N			TP																																												
				NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P																																											
Inlet	350	800	450	45.5	17.5	7	5	2																																											
Outlet	10	50	10	1	0	9	1	1																																											
Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%																																												
<b>2. Inlet Chamber</b>																																																			
<b>[1] Design Condition</b>																																																			
(1) Design Flow Rate	Max Hourly	=	22,500	m3/day																																															
		=	0.260	m3/sec																																															
<b>[2] Geometry</b>																																																			
(1) Number of Basins	1	Basin																																																	
(2) Depth of Basin	1.500	m																																																	
(3) Width of Basin	2.000	m																																																	
(4) Length of Basin	2.000	m																																																	
(5) Volume required of Basin	1.500	×	2.000	×	2.000	=	1.5	m3																																											
(6) Retention Time	1.500	×	2.000	×	2.000	/	0.260	×	1																																										
	=	23.08	sec																																																
(7) Basin Dimensions	Width	2.000	m	×	Length	2.000	m																																												
	×	Depth	1.500	m																																															

E-2 Process Cal. EA&al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Wastewater Flow	$\begin{aligned} \text{Max Hourly} &= 22,500 \text{ m}^3/\text{d} \\ &= 0.260 \text{ m}^3/\text{sec} \end{aligned}$
[2] Geometory	
(1) Inlet Gate	
Number	2 Main + 1 Bypass
Width	0.400 m
Height	0.600 m
Floor Level	+ 2.000 m
Bottom	+ 0.000 m
Influent Water Level	+ 0.300 m
Velocity	$\begin{aligned} &0.260 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 0.300 \text{ } \swarrow \quad 2 \\ = &1.083 \text{ } \div \quad 1.000 \text{ m/sec} \end{aligned}$
(2) Screen Channel	
Number	2 Main + 1 Bypass
Width	0.800 m
Side Water Depth	0.400 m
Velocity	$\begin{aligned} &0.260 \text{ } \swarrow \quad 0.800 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 2 \\ = &0.406 \text{ } \div \quad 0.450 \text{ m/sec} \end{aligned}$
(3) Channel Dimensions	$\begin{aligned} \text{Width} &0.8 \text{ m} \times \text{Length} &6.0 \text{ m} \\ &\times \text{SWD} &0.4 \text{ m} \end{aligned}$
[3] Equipment	
(1) Inlet Gate	
Number	2 W + 1 S
Dimension	Width 0.4 m × Height 0.60 m
Design Water Level	2.00 m
(2) Fine Screens (Main Channel)	
Number	2 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	0.8 m
Width of side plate	50 mm
Side Water Depth	0.4 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	$\begin{aligned} &0.260 \text{ } \swarrow \quad 0.700 \text{ } \swarrow \quad 0.350 \text{ } \swarrow \quad 2 \\ &\times ( \quad 6 \quad + \quad 2 \quad ) / \quad 6 \\ = &0.707 < \quad 0.800 \text{ m/sec} \end{aligned}$
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	0.8 m
Side Water Depth	0.4 m
Velocity through screen	$\begin{aligned} &0.260 \text{ } \swarrow \quad 0.800 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 2 \\ &\times ( \quad 20 \quad + \quad 9 \quad ) / \quad 20 \\ = &0.589 < \quad 0.800 \text{ m/sec} \end{aligned}$

E-2 Process Cal. EA&al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>4. Grit Chamber</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Peak flow = 22,500 m <sup>3</sup> /day = 0.260 m <sup>3</sup> /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0111 m/sec = 960 m <sup>3</sup> /m <sup>2</sup> /day
(4) Average Velocity	0.3 m/sec
<b>[2] Grit Chamber</b>	
(1) Surface Area required	0.260 / 0.0111 = 23.42 m <sup>2</sup>
(2) Number of Basins	1 S + 1 W
(3) Surface Area required/Basin	23.4 / 1 = 23.42 m <sup>2</sup>
(4) Length of Basin	23.42 ^0.5 = 4.8 m → 5.0 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.260 × 60 sec / 1 = 15.6 m <sup>3</sup>
(7) Depth required	15.6 / 5.0 / 5.0 = 0.624 m
(8) Basin Dimensions	Width 5.0 m × Length 5.0 m × Depth 0.6 m (Freeboard 0.3m)
(9) Retention Time	5 × 5.0 × 0.6 / 0.260 × 1 = 60.00 sec
(10) Surface Overflow Rate at Peak Flow	22,500 / 5.0 / 5.0 / 1 = 900 < 960 m <sup>3</sup> /m <sup>2</sup> /day
<b>[3] Parshall Flume</b>	
(1) Design Flow Rate	Q= 260.000 l/sec
(2) Throat width	W= 0.450 m
(3) Water depth Ha	Ha= ( Q / 2264 / W ) <sup>2/3</sup>
	Ha= 0.402 m
(4) Crest Level	+ m ≐ Minimum water level at downstream channel
(5) Water level at the crest	+ 0.402 m
(6) Channel bottom level	+ m
(7) Upstream Channel width	1.500 m
(8) SWD of Upstream Channel	0.700 m
(9) Average velocity at upstream channel	0.248 m/sec
(10) Total Length of channel	10.000 m
<b>[4] Inlet Weir Gate</b>	
(1) Number	2 Units
(2) Weir Width	0.800 m
(3) Stroke	0.450 m
(4) Overflow Height	0.400 m
(5) Overflow Height (actual)	( 0.260 / 1.840 / 0.800 / 2 ) <sup>2/3</sup> = 0.198 < 0.400 m



**STP Process Calculation Supporting Report 12.2.3**

<b>5. Reactor</b>																																																								
<b>[1] Design Condition</b>																																																								
(1) Design Wastewater Flow	Q = 10,000 m <sup>3</sup> /day (summer) Q' = 10,000 m <sup>3</sup> /day (Winter)																																																							
(2) Design Sewage Quality																																																								
Inlet BOD	350 mg/l																																																							
Outlet BOD	10.0 mg/l																																																							
Inlet S-BOD	235 mg/l assumed as 67% of BOD																																																							
Inlet COD	800 mg/l																																																							
Inlet bCOD : S <sub>0</sub>	578 mg/l																																																							
Inlet nbCOD	223 mg/l																																																							
bCOD/BOD	1.65																																																							
Inlet S-COD : sCOD	271 mg/l																																																							
Inlet rbCOD	231 mg/l bCOD*40%																																																							
Inlet sbCOD	347 mg/l bCOD*60%																																																							
Outlet S-COD : nbsCODe	40 mg/l																																																							
Inlet nbpCOD : nbpCOD	183 mg/l = TCOD-bCOD-nbsCODe																																																							
Inlet SS	450 mg/l																																																							
Inlet VSS	383 mg/l assumed as 85% of TSS																																																							
: VSS <sub>COD</sub>	1.38 gCOD/gVSS = TCOD-sCOD/VSS																																																							
: nbVSS	131.96 gnbVSS/m <sup>3</sup> = nbpCOD/VSS <sub>COD</sub>																																																							
: iTSS	67.50 gnbVSS/m <sup>3</sup> = TSS-VSS																																																							
Inlet T-N	70 mg/l																																																							
Inlet TKN	70 mg/l																																																							
Inlet NH <sub>4</sub> -N	45.0 mg/l																																																							
Inlet T-P	7 mg/l																																																							
Inlet D-P	5 mg/l																																																							
Inlet Alkalinity as CaCO <sub>3</sub>	380 mg/l																																																							
Outlet Kjeldahl N	1.0 mg/l																																																							
Outlet NH <sub>4</sub> -N	1.0 mg/l																																																							
Outlet NO <sub>3</sub> -N	9.0 mg/l																																																							
Outlet T-P	2 mg/l																																																							
Outlet D-P	1 mg/l																																																							
(3) Water Temperature	T = 20.0 °C																																																							
(4) Safety Factor for Nitrogen	SF = 1.5																																																							
(5) Return Sludge Concentration	R <sub>s</sub> = 8,000 mg/l																																																							
(6) MLSS MLVSS	X <sub>TSS</sub> = 3,000 mg/l																																																							
(7) DO in the Reactor	2 mg/L																																																							
<b>[2] Design Value for perfect Nitrification of Nitrification Process</b>																																																								
(1) Activated sludge design kinwtic coefficients at 20°C																																																								
	<table border="1"> <thead> <tr> <th>Coefficient</th> <th>Unit</th> <th>COD oxidatio</th> <th>NH<sub>4</sub> oxidatio</th> <th>NO<sub>2</sub> oxidatio</th> </tr> </thead> <tbody> <tr> <td>μ<sub>max</sub></td> <td>gVSS/gVSS · d</td> <td>6.000</td> <td>0.900</td> <td>1.000</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>mg/L</td> <td>8.000</td> <td>0.500</td> <td>0.200</td> </tr> <tr> <td>Y</td> <td>gVSS/g substrate oxidized</td> <td>0.450</td> <td>0.150</td> <td>0.050</td> </tr> <tr> <td>b</td> <td>gVSS/gVSS · d</td> <td>0.120</td> <td>0.170</td> <td>0.170</td> </tr> <tr> <td>fd</td> <td>unitless</td> <td>0.150</td> <td>0.150</td> <td>0.150</td> </tr> <tr> <td>K<sub>O<sub>2</sub></sub></td> <td>mg/L</td> <td>0.200</td> <td>0.500</td> <td>0.900</td> </tr> <tr> <td>θ Value</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>μ<sub>max</sub></td> <td>unitless</td> <td>1.070</td> <td>1.072</td> <td>1.063</td> </tr> <tr> <td>b</td> <td>unitless</td> <td>1.040</td> <td>1.029</td> <td>1.029</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>unitless</td> <td>1.000</td> <td>1.000</td> <td>1.000</td> </tr> </tbody> </table> <p>Wastwater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF &amp; EDDY/AECOM)</p>	Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio	μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200	Y	gVSS/g substrate oxidized	0.450	0.150	0.050	b	gVSS/gVSS · d	0.120	0.170	0.170	fd	unitless	0.150	0.150	0.150	K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900	θ Value					μ <sub>max</sub>	unitless	1.070	1.072	1.063	b	unitless	1.040	1.029	1.029	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000
Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio																																																				
μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200																																																				
Y	gVSS/g substrate oxidized	0.450	0.150	0.050																																																				
b	gVSS/gVSS · d	0.120	0.170	0.170																																																				
fd	unitless	0.150	0.150	0.150																																																				
K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900																																																				
θ Value																																																								
μ <sub>max</sub>	unitless	1.070	1.072	1.063																																																				
b	unitless	1.040	1.029	1.029																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000																																																				
(2) μ <sub>AOB</sub>	μ <sub>AOB</sub> = 0.3100 g/g · d = μ <sub>max, AOB</sub> [S <sub>NH<sub>4</sub></sub> / (S <sub>NH<sub>4</sub></sub> + K <sub>NH<sub>4</sub></sub> )] [S <sub>O</sub> / (S <sub>O</sub> + K <sub>O, AOB</sub> )] - b <sub>AOB</sub>																																																							
μ <sub>max, AOB, T</sub>	μ <sub>max, AOB, T</sub> = 0.9000 g/g · d = μ <sub>max</sub> * 1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900																																																							
b <sub>AOB, T</sub>	b <sub>AOB, T</sub> = 0.1700 = b * 1.029 <sup>(T-20)</sup> b at 20°C = 0.170																																																							
S <sub>NH<sub>4</sub></sub>	S <sub>NH<sub>4</sub></sub> = 1.0000 mg/l																																																							
DO	DO = 2.0000 mg/l																																																							
K <sub>O, AOB</sub>	K <sub>O, AOB</sub> = 0.5000 mg/l																																																							

E-2 Process Cal\_EA&al 10MLD Karivobanahalli Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

(2) Design SRT	SRT= 4.8387 day ⇒ 5.0000 day	=1/μ <sub>AOB</sub> × SF
(3) Biomass production	P <sub>X,VSS</sub> = 3127.038 kg/d P <sub>X,TSS</sub> = 4121.000 kg/d	=P <sub>X,bio</sub> +Q(nbVSS) =P <sub>X,bio</sub> /0.85+Q(nbVSS)+Q(TSS <sub>0</sub> -VSS <sub>0</sub> )+5*Q*Al
S	S= 0.4507 mg/l	=K <sub>s</sub> [1+b <sub>H</sub> (SRT)]/[SRT(μ <sub>m</sub> -b <sub>H</sub> )-1]
b <sub>H</sub>	b <sub>H</sub> = 0.1200	=b*1.04 <sup>(T-20)</sup> b at 20°C = 0.120
Y <sub>H</sub>	Y <sub>H</sub> = 0.4500 gVSS/g bCOD	
μ <sub>m,T</sub>	μ <sub>m,T</sub> = 6.0000 g/g·d	=μ <sub>max</sub> *1.04 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 6.000
Y <sub>n</sub>	Y <sub>n</sub> = 0.150 gVSS/g Nox	
NO <sub>x</sub>	NO <sub>x</sub> = 47.400 mg/l	
P <sub>X,bio,VSS</sub>	P <sub>X,bio,VSS</sub> = 1807.449 kg VSS/d 1622.951 146.066 38.432	=Q·Y <sub>H</sub> (S <sub>0</sub> -S)/[1+b <sub>H</sub> (SRT)]+f <sub>d</sub> ·b <sub>H</sub> ·QY <sub>H</sub> (S <sub>0</sub> -S)SRT/[1+b <sub>H</sub> (SRT)] +QY <sub>n</sub> (Nox)[2+b <sub>AOB</sub> (SRT)] =Q·Y <sub>H</sub> (S <sub>0</sub> -S)/[1+b <sub>H</sub> (SRT)] =f <sub>d</sub> ·b <sub>H</sub> ·QY <sub>H</sub> (S <sub>0</sub> -S)SRT/[1+b <sub>H</sub> (SRT)] =QY <sub>n</sub> (Nox)[1+b <sub>AOB</sub> (SRT)]
NO <sub>x</sub>	NO <sub>x</sub> = 47.311 mg/l	=TKN-Ne-0.12P <sub>X,bio</sub> /Q
(4) Required Aeration Tank Volume	V <sub>a</sub> = 6,868 m <sup>3</sup> τ = 16.48 hr ⇒ 18.00 hr	=V <sub>a</sub> /Q × 24
X <sub>VSS</sub> ·V <sub>a</sub>	X <sub>VSS</sub> ·V <sub>a</sub> = 15,635 kg VSS	=P <sub>X,VSS</sub> ·SRT
X <sub>TSS</sub> ·V <sub>a</sub>	X <sub>TSS</sub> ·V <sub>a</sub> = 20,605 kg TSS	=P <sub>X,TSS</sub> ·SRT
F/M	F/M= 0.224 kgBOD/kgMLVSS	
FractionVSS=	FractionVSS= 0.759	
MLVSS=	MLVSS= 2276 mg/L	
(5) BODloading	BODloading= 0.510 kg/m <sup>3</sup> ·d	
(6) Observed Yield	Y <sub>obs,TSS</sub> = 1.178 gTSS/gBOD Y <sub>obs,VSS</sub> = 0.894 gVSS/gBOD	
bCODremoved=	bCODremov= 5,770 kg/d	
(7) effluent NO <sub>2</sub> -N	NO <sub>2</sub> -N= 0.2315 mg/l	=K <sub>s</sub> [1+b <sub>NOB</sub> (SRT)]/[SRT(μ <sub>NOB</sub> -b <sub>NOB</sub> )-1]
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700	=b*1.029 <sup>(T-20)</sup> b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 1.0000 g/g·d	=μ <sub>max</sub> *1.04 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 1.000
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.6897 g/g·d	=μ <sub>max,NOB</sub> [S <sub>0</sub> /(S <sub>0</sub> +K <sub>O2,NOB</sub> )]
	S <sub>0</sub> = 2.000 mg/l	
	K <sub>O2,NOB</sub> = 0.900 mg/l	
(8) effluent NH <sub>4</sub> -N	NH <sub>4</sub> -N= 0.5286 mg/l	=K <sub>s</sub> [1+b <sub>NOB</sub> (SRT)]/[SRT(μ <sub>NOB</sub> -b <sub>NOB</sub> )-1]
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700	=b*1.029 <sup>(T-20)</sup> b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 0.9000 g/g·d	=μ <sub>max</sub> *1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.7200 g/g·d	=μ <sub>max,NOB</sub> [S <sub>0</sub> /(S <sub>0</sub> +K <sub>O2,NOB</sub> )]
	S <sub>0</sub> = 2.000 mg/l	
	K <sub>O2,NOB</sub> = 0.500 mg/l	
(9) Ratio of Return Sludge	8,000*R <sub>r</sub> /(1+R <sub>r</sub> )= 3,000 mg/L 3,000/(8,000-3,000)= 0.60 R <sub>r</sub> = 0.60	

E-2 Process Cal\_EA&al 10MLD Karivobanahalli Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

<b>[3] Design for Nitrification and Denitrification Process</b>																					
(1) Active biomass concentration	$X_b = Q \cdot (SRT) / V \cdot Y_H \cdot (S_0 - S) [1 + b_H(SRT)]$ = 1,181.47 mg/l																				
(2) IR ratio	$IR = NO_x / Ne - 1.0 - R$ = 3.66																				
(3) The amount of NO <sub>3</sub> -N fed to the anoxic tank	$Nox\ feed = (IR + R) \cdot Q \cdot Ne$ = 383,106.10 kg/d																				
(4) The anoxic tank volume	$V_{nor} = 687\ m^3 = V_a \times 10\%$ $V_{nor} = 2,083\ m^3 \quad \tau_{DN} = 5.000\ h$																				
(5) F/M <sub>b</sub>	F/M <sub>b</sub> = 1.42 g/g·d																				
(6) Fraction of rbCOD	40.00% = rbCOD/bCOD																				
	<table border="1"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b<sub>0</sub></th> <th>b<sub>1</sub></th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>	Percent rdCOD(%)	SDNR equation coefficients		b <sub>0</sub>	b <sub>1</sub>	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162
Percent rdCOD(%)	SDNR equation coefficients																				
	b <sub>0</sub>	b <sub>1</sub>																			
10	0.186	0.078																			
20	0.213	0.118																			
30	0.235	0.141																			
40	0.242	0.152																			
50	0.270	0.162																			
(8) SDNR <sub>b</sub>	$SDNR_b = 0.296\ g/g \cdot d = b_0 + b_1 [\ln(F/M_b)]$ $b_0 = 0.242$ $b_1 = 0.152$																				
(8) SDNR	$SDNR = 0.110\ g/g \cdot d = SDNR_b (MLVSS_r / MLVSS)$ $SDNR_{adj} = 0.212\ g/g \cdot d = SDNR_b - 0.029 \ln(F/M_b) - 0.012 \quad IR=3-4$ $= SDNR_b - 0.0166 \ln(F/M_b) - 0.078 \quad IR=2$ $SDNR_t = 0.296\ g/g \cdot d = SDNR_b \cdot \theta^{(F/M_b - 20)} \quad \theta = 1.026$																				
(9) NO <sub>r</sub>	$NO_r = 520,993.08\ kg/d = N_{nox} \cdot SDNR \cdot X_b$ $> Nox\ feed = 383,106\ kg/d$																				
(10) Alkalinity to be added to maintain pH7	-108.33 mg/l																				
	Influent Alk 380.00 mg/l Alk used 338.44 mg/l = 7.14 × Nox Alk produced 136.77 mg/l = 3.57 × (NO <sub>x</sub> - NO <sub>xe</sub> ) Alk to maintain 70.00 mg/l																				
<b>[4] Design of Phosphorus Removal Process</b>																					
(1) Removal T-P	3.13 mg/l																				
P in waste sludge	px = 1.00%																				
Generated waste sludge	Px <sub>vss</sub> = 3127.038 kg/d																				
Rmval Phosphorus	31.27038027 kg/d																				
(2) Effluent T-P without Al	3.87 mg/l																				
(3) Required Al to initial soluble phosphorus ratio	1.00 mol/mol																				
(4) Required Al dosing rate	3.48 mg/l as Al																				
	42.98 mg/l as crystal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> · 18H <sub>2</sub> O																				
(5) Required Aluminum Sulfate	429.78 kg/d																				
(6) Required Aluminum Sulfate solution 10%	4.09 m <sup>3</sup> /d																				
	170.55 L/H																				
(7) Additional sludge	174.23 kg/d																				

E-2 Process Cal. EA&al 10MLD Karivobanahalli Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

[5] **Reactor**

(1) Total volume of Aeration Basins

$$V_A = Q \cdot \theta_a / 24$$

$$= 7,500 \text{ m}^3$$

(2) Total volume of Anoxic Basins

$$V_{DN} = Q \cdot \theta_{DN} / 24$$

$$= 2,083 \text{ m}^3$$

Item	Volume required	Retention Time required		Ratio of Volume	
		Summer	Winter		
unit	m <sup>3</sup>	hour	hour		
Anaerobic	V <sub>AN</sub>	630	1.50	1.50	0.30
Anoxic	V <sub>DN</sub>	2,083	5.00	5.00	1.00
Aerobic	V <sub>A</sub>	7,500	18.00	18.00	3.60
Total	V	10,213	24.50	24.50	

[6] **Geometry**

(1) Basin Dimensions

Width      Length      Depth      Basins  
 8.0            123.0            5.5            2

Cross Section      8.0\*5.5      =      44.0 m<sup>2</sup>/Basin

Hantzsch Subtraction      =      1.0 m<sup>2</sup>/Basin

after Subtraction      44.0-1.0      =      43.0 m<sup>2</sup>/Basin

Total Volume      43.0\*123.0      =      5,289 m<sup>2</sup>/Basin      10,578 m<sup>3</sup>/Total

(2) Partition of Basin

Item	unit	Anaerobic	Anoxic	Aerobic	Total
Cross Section	m <sup>2</sup>	43.0			
Length required	m	7.3	24.2	87.2	118.8
Volume required per Basin	m <sup>3</sup>	315	1,042	3,750	5,107
Total Volume required	m <sup>3</sup>	630	2,083	7,500	10,213
Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0	
Actual Length	m	8.0	25.0	90.0	123.0
Actual Volume per Basin	m <sup>3</sup>	344	1,075	3,870	5,289
Actual Total Volume	m <sup>3</sup>	688	2,150	7,740	10,578
Actual Ratio of Volume		0.32	1.00	3.60	
Actual Retention Time	hour	1.65	5.16	18.58	25.39

[7] **Equipment**

(1) Ras Pumps

Ras Ratio      60%

Required Capacity      10,000 m<sup>3</sup>/day × 60% / 24 / 2

= 125 m<sup>3</sup>/Hr ⇒ 125 m<sup>3</sup>/Hr

Number      2 Work

                  2 Standby

(2) Circulation Pumps

Ras Ratio      366%

Required Capacity      10,000 m<sup>3</sup>/day × 366% / 24 / 4

= 381 m<sup>3</sup>/Hr ⇒ 385 m<sup>3</sup>/Hr

Number      4 Work

                  2 Standby

(3) SAS Pumps

Excess Sludge      542 m<sup>3</sup>/day

Sludge withdraw      12 Times/day

Running Time      0.5 Hr/Time

Required Capacity      542 m<sup>3</sup>/day / 12 / 0.5 / 2

= 45.20 m<sup>3</sup>/Hr ⇒ 50 m<sup>3</sup>/Hr

Number      2 Work

                  2 Standby

E-2 Process Cal. EA&al 10MLD Karivobanahalli Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

(4) Alum Solution Tank										
Number	2	W	+	0	S					
Alum concentration as crystal	10 %									
Gravity of dissolved dechlorine	1.05									
Required solution volume	429.78 kg / d		×	100	/	10	/	1.05	/	1000
	=	4.09				m3/d				
Volume of Tank	2.6					m3/tank				
Total Volume of Tanks	5.2					m3	(Duration=	1.27	day)	
(5) Mixer for Alum Solution Tank										
Number	2	W	+	0	S					
(6) Alum Dosing Pump										
Number	2	W	+	1	S					
Capacity	4.09 m3/d	/	24	×	1000	/	2	×	2	
	170.55 l/h/unit		⇒		180 l/h/unit					

**STP Process Calculation Supporting Report 12.2.3**

<b>6. Air Requirement at Average Flow</b>	
[1] Design Condition	
(1) AOR	AOR = 4,326 kg/day = 180.3 kg/h
Q <sub>in</sub> : Design Average Flow m <sup>3</sup> /d	10,000
Inlet bCOD : S <sub>0</sub>	578 mg/l
S=	0.451 mg/l
Nox=	47.400 mg/l
P <sub>X,bio</sub> =	1,769.0 kg VSS/d does not include nitrifying bacteria
R <sub>0</sub> =	R <sub>0</sub> = Q(S <sub>0</sub> - S - k(Nox - NOx)) - 1.42P <sub>X,bio</sub> + 4.57Q · NOx
R <sub>0</sub> =	4,326 kg O <sub>2</sub> /d
k=	2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{\text{AOR} \times C_s \cdot a \times 1.024^{20-T}}{\alpha \times F (\beta \cdot C_{sw} / C_s \cdot (P_b / P_a) a - C_A)}$
	C <sub>s</sub> : Saturated DO at sea level and 20 °C 9.09 mg/L
	C <sub>sw</sub> : Saturated DO at sea level and operating Temperature 9.09 mg/L at 20 °C
	20-T : 0.0 1.024 <sup>20-T</sup> : 1.0000
	C <sub>A</sub> : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1 + 0.40D <sub>j</sub> /P <sub>a</sub> 1.19357
	D <sub>j</sub> : Tank Liquid Depth 5.00 m
	P <sub>a</sub> : Standard absolute pressure at s 10.332 m
	P <sub>b</sub> : Absolute pressure at Plant Site Elevation m
	P <sub>b</sub> /P <sub>a</sub> : exp[-gM(z <sub>b</sub> -z <sub>a</sub> )/R*T] 0.900
	g : Acceleration due to Gravity 9.80665 m/s <sup>2</sup>
	M : Mole of Air 28.97 kg/kg-mole
	z <sub>b</sub> : Plant Site Elevation 900 m
	z <sub>a</sub> : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 293.15 Kelvin
	α : relative Transfer Rate to clean Water 0.65
	β : relative DO Saturation to clean Water 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{46,940}{4.2591} = 11,020.99 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Standard O <sub>2</sub> required at Field Conditions per Basin =	5,510 kg/day
(5) SOTE for the above Effective Aeration Depth	28.0 %
(6) Fraction of O <sub>2</sub> in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	15%
(9) Air required at Field Conditions per Basins	= 81,044 m <sup>3</sup> /day = 3,376.9 m <sup>3</sup> /hr
[2] Equipment	

E-2 Process Cal. EA&amp;al 10MLD Karivobanahalli Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

(1) Air Blower					
Number	4	W	+	2	S
Required Capacity	3376.9	m <sup>3</sup> /Hr·Basin	/	2	unit/Basin
	= 1688.4	m <sup>3</sup> /h	⇒	1700	m <sup>3</sup> /h /Unit
Pressure	65	kPa			
Safety Factor	10	%			
Heat capacity ratio	1.4				
Atmospheric pressure at site elevation	91.234	kPa			
Total inlet pressure	89.234	kPa			
Volume rate of flow at inlet point	32.165	m <sup>3</sup> /min			
Total discharge pressure	156.234	kPa			
Overall adiabatic efficiency	0.65				
Inlet air temperature (min.)	15	°C			
Shaft power	45.477	kW			
Rated Output of Motor	50.024	kW	⇒	55	kW

Air Requirement at Average Flow13/21

E-2 Process Cal. EA&al 10MLD Karivobanahalli Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>7. Final Clarifire</b></p>									
<p>[1] <b>Design Condition</b></p>									
<p>(1) Design Wastewater Flow</p>	<p>Q= 10,000 m<sup>3</sup>/day</p>								
<p>(2) Water Temperature</p>	<p>T= 20.0 °C</p>								
<p>(3) MLSS</p>	<p>Xef= 3,000 mg/l</p>								
<p>(4) SVI</p>	<p>SVI= 300</p>								
<p>(5) Sedimentation Velocity</p>	$v = 4.899 \cdot 10^6 \cdot T^{(0.954)} \cdot X_{ef}^{(-1.354)} \cdot SVI^{(-0.77)}$ $= 4.899 \cdot 10^6 \cdot 20.0^{0.954} \cdot 3,000^{-1.354} \cdot 150^{-0.770}$ $= 20.7 \text{ m/day}$								
<p>(6) Surface Overflow Rate required</p>	$S' = v / (1.5 \cdot 1) = \frac{20.7}{(1.5 \cdot 1.0)} = 13.8 \text{ m}^3/\text{m}^2 \cdot \text{day}$	<p>→</p>	<p>12.0 m<sup>3</sup>/m<sup>2</sup>·day</p>						
<p>[2] <b>Geometry</b></p>									
<p>(1) Surface Area required</p>	$A = 10,000 / 12.0 = 833 \text{ m}^2$								
<p>(2) Demensions</p>	<table border="0"> <tr> <td>Diameter</td> <td>Depth</td> <td>Basin</td> </tr> <tr> <td><b>23.0</b></td> <td><b>3.5</b></td> <td><b>2</b></td> </tr> </table>	Diameter	Depth	Basin	<b>23.0</b>	<b>3.5</b>	<b>2</b>		
Diameter	Depth	Basin							
<b>23.0</b>	<b>3.5</b>	<b>2</b>							
<p>(3) Actual Surface Area</p>	$S = 23.0^2 \cdot 3.14 / 4 \cdot 2.0 = 831 \text{ m}^2$								
<p>(4) Surface Overflow Rate</p>	$S = 10,000 / 831 = 12.0 \text{ m}^3/\text{m}^2 \cdot \text{day}$								



E-2 Process Cal. EA&amp;al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>8. Chlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 10,000 m <sup>3</sup> /day 416.67 m <sup>3</sup> /h Peak Flow 22,500 m <sup>3</sup> /day 937.50 m <sup>3</sup> /h
(2) Contact Time	30 min
(3) Type of Chlorine	Cl <sub>2</sub> -GAS
(4) Design Chlorine Dosage Rate	10 mg/L
(5) Required Chlorine per day	Average Daily Flow / 1000 × Design Chlorine Dosage Rate = 100.0 kg/d = 4.17 kg/h
<b>[2] Chlorination Contact Tank</b>	
(1) Volume required	Average Daily Flow / 1440 × Contact Time = 208.3 m <sup>3</sup>
(2) Nos. of lanes	3 lanes
(3) Width of lane	2.00 m
(4) Length of lane	18.00 m
(5) Side Water Depth	2.00 m
(6) Nos. of Tanks	1 tank
(7) Total Width of Tank	6.80 m Approx..
(8) Average Velocity	Decant Flow / 3600 / Width / Depth = 416.67 / 3600 / 2.00 / 2.00 = 0.029 m/sec
(9) Total Volume	Width × Length × Depth × Nos. of lanes × Nos. of Tanks = 2.0 m × 18.0 m × 2.0 m × 3 × 1 = 216 m <sup>3</sup> > 208.3 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Chlorine Dosing Condition	
Operation Dosage Rate -1	DC1 10 mg/L
(2) Chlorine Cylinder	
Type	- Cylindrical Convexsd Container
Cylinder Capacity	Cc 928 kg/cylinder
Average Dosage Rate -1	q1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 100 kg/day
Maximum Dosage Rate -1	q3 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 225 kg/day
Storage day	T More than 15 days
Required Storage Capacity	EC1 D × T = 1,500 kg
Unit Number	EN1 EC1 / Cc = 1.6 cylinders
Maximum Operation Numbers	
Cl <sub>2</sub> -Gas Volatilize Rate	Vr1 ##### @ 20 <sup>o</sup> C Standard temperature
Maximum Dosing Rate	DC1 10 mg/L, Q <sub>T-D</sub> × q3 × 10 <sup>-3</sup> / 24 = 9.38 kg/h
Operation Numbers	EN2 DC1 / Vr1 = 1.2sets
Number	2 W + 2 S
(3) Chlorinator	
Type	Solution Feed Vacuum Type
Number	1 W + 1 S
Operation Dosage Rate -1	Dq1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 225 kg/day
Required Dosage Rate	Chlorine -1 : Dq1 / (EN1 × 24) = Minimum Maximum 0.00 kg/hr 9.4 kg/hr
(4) Chlorine Booster Pump	

E-2 Process Cal. EA&al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

Type	Branchy on the water supply pipe
Water Demand	Water requiamet for mixed Chlori
Chlorinator Discharge	(kg/hr) 1.0 1.5 2.0 2.5 3.0 4.0
Water Demand	(L/min) 15 20 25 30 35 40
Chlorinator Discharge	(kg/hr) 5.0 6.0 10.0 50.0 100.0 200.0
Water Demand	(L/min) 45 50 60 300 600 1,200
Water requiamet	-
For Chlorin	Qp1 Maximum dosage rate 9.4 kg/hr therefore 60 L/min
Booster Pump Type	Single suction volute pump
Number	1 W + 1 S
<b>9. Dechlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 10,000 m <sup>3</sup> /day
(2) Contact Time	10 min
(3) Type of Dechlorine	Sodium Thiosulfate (Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 5H <sub>2</sub> O)
(4) Free Residual Chlorine	1.0 mg/L assumed value
(5) Consumption per day	Average Daily Flow / 1000 × Free Residual Chlorine × 1.75 × 1.5 (safety factor) = 26.3 kg/d = 1.09 kg/h
<b>[2] Dechlorination Contact Tank</b>	
(1) Volume required	Average Flow Rate / 60 × Contact Time = 69.4 m <sup>3</sup>
(2) Width of lane	6.80 m
(3) Length of lane	5.50 m
(4) Side Water Depth	2.00 m
(5) Nos. of Tanks	1 tank
(6) Total Volume	Width × Length × Depth = 6.8 m × 5.5 m × 2.0 m = 75 m <sup>3</sup> > 69.4 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Dechlorine Solution Tank	
Number	1 W + 0 S
Dechlorine concentration	10 %
Gravity of dissolved dechlorine	1.10
Required solution volume	26.25 kg/d × 100 / 10 / 1.10 / 1000 = 0.24 m <sup>3</sup> /d
Volume of Tank	0.360 m <sup>3</sup> /tank (= 0.6 mW × 0.6 mL × 1.0 mH)
Total Volume of Tanks	0.360 m <sup>3</sup> (Duration= 1.51 day)
(2) Mixer for Dechlorine Solution Tank	
Number	2 W + 0 S
(3) Dechlorine Dosing Pump	
Number	1 W + 1 S
Capacity	0.54 m <sup>3</sup> /d / 24 × 1000 / 1 22.37 l/h/unit ⇒ 23 l/h/unit

E-2 Process Cal. EA&al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>10. Centrifuge</b></p> <p><b>[1] Design Condition</b></p> <p>(1) Type of Dewatering</p> <p>(2) Generated Sludge</p> <p>(3) Design Polyelectrolyte Dosage</p> <p>(4) Volume of Thickend Sludge</p> <p>(5) Consistency of Dewatered Sludge</p> <p>(6) Operation Time</p> <p><b>[2] Volume of Centrifuges</b></p> <p><b>[3] Dewatered Solids</b></p> <p><b>[4] Dewatered Cake Volume</b></p> <p><b>[5] Polyelectrolyte</b></p> <p>(1) Design Polyelectrolyte Dosage</p> <p>(2) Required Polyelectrolyte</p> <p>(3) Dissolving concentration</p> <p>(4) Volume of Polyelectrolyte solution</p>	<p>Centrifuge 4,339 kg/day</p> <p>Polyelectrolyte 5 kg/t-DS·day</p> <p>542.4 m<sup>3</sup>/day</p> <p>82 %</p> <p>12 hours/day (6 days per week)</p> <p><u>Digested Solids</u> Operation Time × No. × Operation/week = <math>\frac{542.4}{12 \times 2} \times \frac{7}{6} = 26.4</math> → 27 m<sup>3</sup>/hour</p> <p>Digested Sludge × ( 1 + Injection Rate) = 4,339 × ( 1 + 0.0050 ) = 4,361 kg/day</p> <p>Dewatered Solids × <math>\frac{100}{100 - \frac{\text{Moisture Content}}{7}}</math> × 6 days per week = 4.361 × <math>\frac{100}{100 - \frac{82}{6}} \times \frac{7}{6}</math> = 28.27 t/day apparent specific gravity 1.00 <math>\frac{28.27}{1.00} = 28.3</math> m<sup>3</sup>/day</p> <p>Polyelectrolyte 5 kg/t-DS·day 21.69 kg/day 0.20 % 10.85 m<sup>3</sup>/day</p>
--	---

E-2 Process Cal. EA&al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

<b>[6] Equipment</b>	
(1) Centrifuge	
Capacity	27 m <sup>3</sup> /hr
Number	2 W + 1 S
(2) Centrifuge Feed Pumps	
Capacity	27 m <sup>3</sup> /hr
Number	2 W + 1 S
(3) Polyelectrolyte Dosing Pumps	
Volume of Polyelectrolyte solution	10.85 m <sup>3</sup> /day
Operation Time	12 hours/day (6 days per week)
Safety Factor	1.5
Number	2 W + 1 S
Required Capacity	10.85 m <sup>3</sup> /da × 7 / 6 / 12 / 2
	= 0.53 m <sup>3</sup> /Hr
Specification Capacity	0.53 m <sup>3</sup> /Hr × 1.5
	= 0.791 m <sup>3</sup> /Hr ⇒ 0.80 m <sup>3</sup> /Hr /Unit
(4) Polyelectrolyte dosing System	
Preparation time for solution	3 hr
Required dry polymer	21.69 kg/day × 7 / 6 / 12
	= 2.11 kg/hr
	= 6.33 kg per one batch
Feedong time per one batch	30 min
Capacity of Dry polymer Feeder	13 kg/h
Tanks Dimensions	Width 1.5 m × Length 1.5 m × Depth 2.0 m × 2 (Freeboard 0.5m)
	= 9 m <sup>3</sup>
Retention Time of Tank	4.50 m <sup>3</sup> /tank / 0.53 m <sup>3</sup> /Hr / 2
	= 4.267 Hr > 3 Hr
Number	2 W + 0 S

E-2 Process Cal. EA&al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>11. Centrifuge Feed Sump</b>	
<b>[1] Design Condition</b>	
(1) Generated Thickend Sludge	4,339 kg/day
(2) Solids Consistency	0.80 %
(3) Volume of Thickened Sludge	$\begin{aligned} & \text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3} \\ = & 4,339 \times \frac{100}{0.80} \times 10^{-3} \\ = & 542 \text{ m}^3/\text{day} \\ = & 22.60 \text{ m}^3/\text{h} \end{aligned}$
(4) Sludge feed flow rate	27 m <sup>3</sup> /h × 2 = 54 m <sup>3</sup> /h
(5) Centrifuge Operation Time	12 hours/day ( 6 days per week)
<b>[2] Geometry</b>	
(1) Basin Dimensions	$\begin{aligned} & \text{Width } 6.0 \text{ m} \times \text{Length } 7.0 \text{ m} \\ & \times \text{Depth } 4.0 \text{ m} \times 2 \\ = & 336.0 \text{ m}^3 \end{aligned}$
<b>[3] Equipment</b>	
(1) Mixers for Centrifuge Feed Sumps	
Required Volume	336.0 m <sup>3</sup>
Number	1 W + 1 S

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Digestion Tank + Centrifugal Dewatering)

Table -1 Input Data

1. Calculation Manner	2	1:Premise that the quality of supernatants are same level removed with inlet sewage 2:Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency	2	1:Total Removal Ratio 2:Outlet Water Quality(input 1or2)
In case of 1 : input data		(%)
In case of 2 : input data	#REF!	(mg/l)
3. Selection of Excess Sludge Generation	2	1:Consideration of Solid Matter Only 2:Consideration of Converting of Solved BOD(input 1or2)
In case of 1 : input data (Sludge generation)		Sludge generation ratio per removal SS(%) T2=Q4·S4=(a·S <sub>BOD</sub> +b·S1-c·θ·XA)·Q3/10 <sup>6</sup> ·(Excess sludge generation formula)
In case of 2 : input data	a	0.4 a:Converting ratio of solved BOD(mgMLSS/mgBOD)
	b	0.9 b:Converting ratio of SS(mgMLSS/mgSS)
	c	0.05 c:Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)
	SBOD	234.50 S <sub>BOD</sub> :Solved BOD quality at inlet reactor
	XA	3,000 XA:MLSS concentration(mg/l)
θ	1 θ:Hydraulic retention time(day)	


Table -2 Basic Conditions

Sewage Flow and Quality		Sludge Moisture and Recovery Ratio		Digestion Tank Conditions		Chemical Conditions for Dewatering	
·Inlet flow : Q <sub>0</sub> (m <sup>3</sup> /D)	10,000	·Primary sludge moisture ratio : W1(%)	0.0	·Removal ratio in primary tank : A2(%)	0.0	·Content of organics in thickened sludge : A6(%)	75.0
·Inlet quality : S <sub>0</sub> (mg/l)	450	·Excess sludge moisture ratio : W2(%)	99.2	·Recovery ratio in sludge thickener : A3(%)	100.0	·Digestion ratio : A7(%)	#REF!
·Total removal ratio : A1(%)	-	·Thickened sludge moisture ratio : W3(%)	99.2	·Recovery ratio in sludge digester : A4(%)	100.0	·Digestion gas generation : A8(Nm <sup>3</sup> /kgVS)	-
·Effluent quality : S1(mg/l)	10.0	·Digested sludge moisture ratio : W4(%)	99.2	·Recovery ratio in dewatering : A5(%)	95.0	·Chemical dosage : A9(%)	0.5
·Sludge generation ratio per removal SS : S1(%)	-	·Dewatered sludge moisture ratio : W5(%)	82.0			·Chemical dissolve concentration : A10(%)	0.2

Table -3 Material Balance Calculation

Q(m <sup>3</sup> /day)	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	手入力(要取束)	16	17	
T(t·DS/day)	4,500	4,718	0,000	4,718	4,339	0,100	4,339	0,000	0,000	4,339	0,000	0,022	4,361	4,143	0,218	0,218	0,218		0,100	0,279
S(mg/l)	450	448	0	448	8,000	10	8,000	#DIV/0!	0	8,000	0	2,000	7,882	180,000	411	411			10	
X(T5/T0*100)	100	104.8	0.0	104.8	96.4	2.2	96.4	0.0	0.0	96.4	0.0	0.5	96.9	92.1	4.8	4.8			2.2	6.2

Figure -1 Material Balance Model




Calculation Formula						
·Q0=Input Data	·Q3=Q1-Q2	·Q6=T6*100/(100-W3)	·Q9=Q6	·Q12=Q9+Q11	·Q15=Q7+Q10+Q14	·Q5-1=Q5-Q11
·T0=Q0*S0*10 <sup>-6</sup>	·T3=T0*(100-A2)/100	·T6=(T2+T4)*A3/100	·T9=(T6-T8)*A4/100	·T12=T9+T11	·T15=T7+T10+T14	·T5-1=T5-T11
·S0=Input Data	·S3=T3*10 <sup>-6</sup> /Q3	·S6=10 <sup>-6</sup> *Q3/(100-W3)/100	·S9=T9*10 <sup>-6</sup> /Q9	·S12=T12*10 <sup>-6</sup> /Q12	·S15=T15*10 <sup>-6</sup> /Q15	·S5-1=S5
·Q1=Q0+Q15	·Q4=T4*100/(100-W2)	·Q7=(Q2+Q4)-Q6	·Q10=Q6-Q8-Q9	·Q13=T13*100/(100-W5)		
·T1=T0+T15	·T4=余剰汚泥発生式による	·T7=(T2+T4)-T6	·T10=T6-T8-T9	·T13=T12*A5/100		
·S1=T1*10 <sup>-6</sup> /Q1	·S4=10 <sup>-6</sup> *Q4/(100-W2)/100	·S7=T7*10 <sup>-6</sup> /Q7	·S10=T10*10 <sup>-6</sup> /Q10	·S13=10 <sup>-6</sup> *Q13/(100-W5)/100		
·Q2=T2*100/(100-W1)	·Q5=Q3-Q4*(T3-T5)/T4	·Q8=0	·Q11=T10*A9/A10	·Q14=Q12-Q13		
·T2=T1-T3	·T5=Q5*ST/10 <sup>-6</sup>	·T8=T6*A6*A7/10 <sup>-4</sup>	·T11=Q11*S11/10 <sup>-6</sup>	·T14=T12-T13		
·S2=10 <sup>-6</sup> *Q2/(100-W1)/100	·S5=St	#REF!	·S11=10 <sup>-4</sup> *A10	·S14=T14*10 <sup>-6</sup> /Q14		

Material Balance Sheet SD4

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Sheet  
[3MLD STP]



E-2 Process Cal. EA&al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

**Design Condition**

Item	10MLD STP-MPS			
(1) Design Flow for the year 2049	Flow Rate			
		m3/d	m3/h	m3/s
	Daily Average	16,000	667	0.185
	Daily Maximum	16,000	667	0.185
	Hourly Max. Peak factor 2.25	36,000	1500	0.417
(1) Design Flow for the year 2034	Flow Rate			
		m3/d	m3/h	m3/s
	Daily Average	10,000	417	0.116
	Daily Maximum	10,000	417	0.116
	Hourly Max. Peak factor 2.25	22,500	938	0.260

**1. Inlet Chamber**

Item	10MLD STP-MPS			
[1] Design Condition				
(1) Design Flow for the year 2049	Hourly Maximum	=	36,000	m3/d
		=	0.417	m3/sec
(2) Inlet Pipe				
Pipe Diameter	•	×		
Gradient		%		
Roughness Coefficient	n=	0.013	(Manning Formula)	
Full Pipe Flow Rate		m3/s		
(3) Influent Water Level	+	m		
[2] Geometry				
(1) Number of Basins	1	Basin		
(2) Depth of Basin	0.600	m	Approx.	
(3) Width of Basin	2.000	m	Approx.	
(4) Length of Basin	2.500	m	Approx.	
(5) Volume required of Basin	0.600	×	2.000	×
			2.500	=
				0.5
				m3
(6) Retention Time	0.600	×	2.000	×
			2.500	/
			0.417	×
				1
	=	7.19	sec	
(7) Basin Demensions	Width	2.000	m	×
				Length
				2.500
				m
	×	Depth	0.600	m



E-2 Process Cal. EA&amp;al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3****2. Coarse Screen Channel**

Item	10MLD STP-MPS					
[1] Geometry						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Width	0.600	m				
Height	0.900	m				
Floor Level	+	5.000	m			
Bottom	+	0.000	m			
Influent Water Level	+	0.600	m			
Velocity	0.417	/		0.600	/	0.600 / 2
where Design Flow for the year 2049	=	0.579	<	1.000	m/sec	OK
Velocity	0.260	/		0.600	/	0.600 / 1
where Design Flow for the year 2034	=	0.722	<	1.000	m/sec	OK
(2) Screen Channel						
Number	2.0	Main	+	1.0	Bypass	
Width	1.000	m				
Side Water Depth	0.600	m				
Velocity	0.417	/		1.000	/	0.600 / 2
where Design Flow for the year 2049	=	0.348	≐	0.450	m/sec	OK
Velocity	0.260	/		1.000	/	0.600 / 1
where Design Flow for the year 2034	=	0.433	<	0.450	m/sec	OK
(3) Channel Dimensions	Width	1.0	m	×	Length	6.0 m
	×	SWD	0.6	m		
[3] Equipment						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Dimension	Width	0.6	m	×	Height	0.9 m
Design Water Level		m				
(2) Coarse Screens (Main Channel)						
Number	2	W	+	0	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	1.0	m				
Width of side plate	50	mm				
Side Water Depth	0.6	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.417	/		0.900	/	0.550 / 2
	×	( 20	+	9 ) /	20	
	=	0.611	≐	0.800	m/sec	OK
Velocity through screen	0.260	/		0.900	/	0.550 / 1
where Design Flow for the year 2034	×	( 20	+	9 ) /	20	
	=	0.762	<	0.800	m/sec	OK
(3) Coarse Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	50	mm				
Bar Thickness	9	mm				
Channel Width	1.0	m				
Side Water Depth	0.6	m				
Velocity through screen	0.417	/		1.000	/	0.600 / 2
where Design Flow for the year 2049	×	( 50	+	9 ) /	50	
	=	0.410	<	0.800	m/sec	OK
Velocity through screen	0.260	/		1.000	/	0.600 / 1
where Design Flow for the year 2034	×	( 50	+	9 ) /	50	
	=	0.511	<	0.800	m/sec	OK

E-2 Process Cal. EA&al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

**3. Raw Sewage Sump**

Item	10MLD STP-MPS	
[2] Geometory		
(1) Raw Sewage Sump		
Number	1	Basin
Dia	11.00	m
Pump Operating Depth	1.000	m
Retention Time whe Design Flow for the year 2049	$( \frac{11.00^2 \times \pi}{4} \times 1.000 ) / 0.417$	$/ 60 = 3.80 > 3.75$
		min (=minimum time of one pump cycle) OK
Retention Time whe Design Flow for the year 2034	$( \frac{11.00^2 \times \pi}{4} \times 1.000 ) / 0.260$	$/ 60 = 6.09 > 3.75$
		min (=minimum time of one pump cycle) OK
High Water Level	+ 0.000	m
Pump Off Level	+ -1.000	m
[3] Equipment		
(1) Sewage Pumps 1		
Number	2	W + 1 S
Bore Diameter	200	mm
Discharge Flow : 40% Q* 2 whe Design Flow for the year 2034	$0.260 \times 3600$	$\times 40.0\% Q = 374 \Rightarrow 380$
		m <sup>3</sup> /Hr
Total Head	15.0	m
(2) Sewage Pumps 2		
Number	1	W + 1 S
Bore Diameter	150	mm
Discharge Flow : 20% Q* 1 whe Design Flow for the year 2034	$0.260 \times 3600$	$\times 20.0\% Q = 187 \Rightarrow 190$
		m <sup>3</sup> /Hr
Total Head	15.0	m

E-2 Process Cal. EA&al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

Item	10MLD STP																																													
<b>1. STP Design Condition</b>																																														
(1) Design Flow Rate	<table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th></th> <th>m3/d</th> <th>m3/h</th> <th colspan="2">m3/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td>10,000</td> <td>416.67</td> <td colspan="2">0.116</td> </tr> <tr> <td>Max Daily</td> <td>10,000</td> <td>416.67</td> <td colspan="2">0.116</td> </tr> <tr> <td>Max Hourly Peak factor 2.25</td> <td>22,500</td> <td>937.50</td> <td colspan="2">0.260</td> </tr> </tbody> </table>						m3/d	m3/h	m3/s		Average Daily	10,000	416.67	0.116		Max Daily	10,000	416.67	0.116		Max Hourly Peak factor 2.25	22,500	937.50	0.260																						
	m3/d	m3/h	m3/s																																											
Average Daily	10,000	416.67	0.116																																											
Max Daily	10,000	416.67	0.116																																											
Max Hourly Peak factor 2.25	22,500	937.50	0.260																																											
(2) Design Water Quality	<p style="text-align: right;">Unit: mg/L</p> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th colspan="2">TP</th> </tr> <tr> <th>NH<sub>4</sub>-N</th> <th>Org-N</th> <th>NOx-N</th> <th>D-P</th> <th>P-P</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td>350</td> <td>800</td> <td>450</td> <td>45.5</td> <td>17.5</td> <td>7</td> <td>5</td> <td>2</td> </tr> <tr> <td>Outlet</td> <td>10</td> <td>50</td> <td>10</td> <td>1</td> <td>0</td> <td>9</td> <td>1</td> <td>1</td> </tr> <tr> <td>Removal rate</td> <td>97.1%</td> <td>93.7%</td> <td>97.8%</td> <td colspan="3">85.7%</td> <td colspan="2">71.4%</td> </tr> </tbody> </table>						BOD	COD	SS	T-N			TP		NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P	Inlet	350	800	450	45.5	17.5	7	5	2	Outlet	10	50	10	1	0	9	1	1	Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%	
	BOD	COD	SS	T-N						TP																																				
				NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P																																						
Inlet	350	800	450	45.5	17.5	7	5	2																																						
Outlet	10	50	10	1	0	9	1	1																																						
Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%																																							
<b>2. Inlet Chamber</b>																																														
<b>[1] Design Condition</b>																																														
(1) Design Flow Rate	Max Hourly	=	22,500	m3/day																																										
		=	0.260	m3/sec																																										
<b>[2] Geometry</b>																																														
(1) Number of Basins	1	Basin																																												
(2) Depth of Basin	1.500	m																																												
(3) Width of Basin	2.000	m																																												
(4) Length of Basin	2.000	m																																												
(5) Volume required of Basin	1.500	×	2.000	×	2.000 = 1.5 m3																																									
(6) Retention Time	1.500	×	2.000	×	2.000 / 0.260 × 1 = 23.08 sec																																									
(7) Basin Dimensions	Width	2.000	m	×	Length 2.000 m																																									
		×	Depth 1.500	m																																										

E-2 Process Cal. EA&al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Wastewater Flow	$\begin{aligned} \text{Max Hourly} &= 22,500 \text{ m}^3/\text{d} \\ &= 0.260 \text{ m}^3/\text{sec} \end{aligned}$
[2] Geometory	
(1) Inlet Gate	
Number	2 Main + 1 Bypass
Width	0.400 m
Height	0.600 m
Floor Level	+ 2.000 m
Bottom	+ 0.000 m
Influent Water Level	+ 0.300 m
Velocity	$\begin{aligned} &0.260 \text{ } \diagdown \quad 0.400 \text{ } \diagdown \quad 0.300 \text{ } \diagdown \quad 2 \\ = &1.083 \text{ } \div \quad 1.000 \text{ m/sec} \end{aligned}$
(2) Screen Channel	
Number	2 Main + 1 Bypass
Width	0.800 m
Side Water Depth	0.400 m
Velocity	$\begin{aligned} &0.260 \text{ } \diagdown \quad 0.800 \text{ } \diagdown \quad 0.400 \text{ } \diagdown \quad 2 \\ = &0.406 \text{ } \div \quad 0.450 \text{ m/sec} \end{aligned}$
(3) Channel Dimensions	$\begin{aligned} \text{Width} &0.8 \text{ m} \times \text{Length} &6.0 \text{ m} \\ &\times \text{SWD} &0.4 \text{ m} \end{aligned}$
[3] Equipment	
(1) Inlet Gate	
Number	2 W + 1 S
Dimension	Width 0.4 m × Height 0.60 m
Design Water Level	2.00 m
(2) Fine Screens (Main Channel)	
Number	2 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	0.8 m
Width of side plate	50 mm
Side Water Depth	0.4 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	$\begin{aligned} &0.260 \text{ } \diagdown \quad 0.700 \text{ } \diagdown \quad 0.350 \text{ } \diagdown \quad 2 \\ &\times ( \quad 6 \quad + \quad 2 \quad ) / \quad 6 \\ = &0.707 < \quad 0.800 \text{ m/sec} \end{aligned}$
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	0.8 m
Side Water Depth	0.4 m
Velocity through screen	$\begin{aligned} &0.260 \text{ } \diagdown \quad 0.800 \text{ } \diagdown \quad 0.400 \text{ } \diagdown \quad 2 \\ &\times ( \quad 20 \quad + \quad 9 \quad ) / \quad 20 \\ = &0.589 < \quad 0.800 \text{ m/sec} \end{aligned}$

E-2 Process Cal. EA&al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>4. Grit Chamber</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Peak flow = 22,500 m <sup>3</sup> /day = 0.260 m <sup>3</sup> /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0111 m/sec = 960 m <sup>3</sup> /m <sup>2</sup> /day
(4) Average Velocity	0.3 m/sec
<b>[2] Grit Chamber</b>	
(1) Surface Area required	0.260 / 0.0111 = 23.42 m <sup>2</sup>
(2) Number of Basins	1 S + 1 W
(3) Surface Area required/Basin	23.4 / 1 = 23.42 m <sup>2</sup>
(4) Length of Basin	23.42 ^0.5 = 4.8 m → 5.0 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.260 × 60 sec / 1 = 15.6 m <sup>3</sup>
(7) Depth required	15.6 / 5.0 / 5.0 = 0.624 m
(8) Basin Dimensions	Width 5.0 m × Length 5.0 m × Depth 0.6 m (Freeboard 0.3m)
(9) Retention Time	5 × 5.0 × 0.6 / 0.260 × 1 = 60.00 sec
(10) Surface Overflow Rate at Peak Flow	22,500 / 5.0 / 5.0 / 1 = 900 < 960 m <sup>3</sup> /m <sup>2</sup> /day
<b>[3] Parshall Flume</b>	
(1) Design Flow Rate	Q= 260.000 l/sec
(2) Throat width	W= 0.450 m
(3) Water depth Ha	Ha= ( Q / 2264 / W ) <sup>2/3</sup>
(4) Crest Level	Ha= 0.402 m
(5) Water level at the crest	+ 0.402 m
(6) Channel bottom level	+ m
(7) Upstream Channel width	1.500 m
(8) SWD of Upstream Channel	0.700 m
(9) Average velocity at upstream channel	0.248 m/sec
(10) Total Length of channel	10.000 m
<b>[4] Inlet Weir Gate</b>	
(1) Number	2 Units
(2) Weir Width	0.800 m
(3) Stroke	0.450 m
(4) Overflow Height	0.400 m
(5) Overflow Height (actual)	( 0.260 / 1.840 / 0.800 / 2 ) <sup>2/3</sup> = 0.198 < 0.400 m

**STP Process Calculation Supporting Report 12.2.3**

<b>5. Reactor</b>																																																								
<b>[1] Design Condition</b>																																																								
(1) Design Wastewater Flow	Q = 10,000 m <sup>3</sup> /day (summer) Q' = 10,000 m <sup>3</sup> /day (Winter)																																																							
(2) Design Sewage Quality																																																								
Inlet BOD	350 mg/l																																																							
Outlet BOD	10.0 mg/l																																																							
Inlet S-BOD	235 mg/l assumed as 67% of BOD																																																							
Inlet COD	800 mg/l																																																							
Inlet bCOD : S <sub>0</sub>	578 mg/l																																																							
Inlet nbCOD	223 mg/l																																																							
bCOD/BOD	1.65																																																							
Inlet S-COD : sCOD	271 mg/l																																																							
Inlet rbCOD	231 mg/l bCOD*40%																																																							
Inlet sbCOD	347 mg/l bCOD*60%																																																							
Outlet S-COD : nbsCODe	40 mg/l																																																							
Inlet nbpCOD : nbpCOD	183 mg/l = TCOD-bCOD-nbsCODe																																																							
Inlet SS	450 mg/l																																																							
Inlet VSS	383 mg/l assumed as 85% of TSS																																																							
: VSS <sub>COD</sub>	1.38 gCOD/gVSS = TCOD-sCOD/VSS																																																							
: nbVSS	131.96 gnbVSS/m <sup>3</sup> = nbpCOD/VSS <sub>COD</sub>																																																							
: iTSS	67.50 gnbVSS/m <sup>3</sup> = TSS-VSS																																																							
Inlet T-N	70 mg/l																																																							
Inlet TKN	70 mg/l																																																							
Inlet NH <sub>4</sub> -N	45.0 mg/l																																																							
Inlet T-P	7 mg/l																																																							
Inlet D-P	5 mg/l																																																							
Inlet Alkalinity as CaCO <sub>3</sub>	380 mg/l																																																							
Outlet Kjeldahl N	1.0 mg/l																																																							
Outlet NH <sub>4</sub> -N	1.0 mg/l																																																							
Outlet NO <sub>3</sub> -N	9.0 mg/l																																																							
Outlet T-P	2 mg/l																																																							
Outlet D-P	1 mg/l																																																							
(3) Water Temperature	T = 20.0 °C																																																							
(4) Safety Factor for Nitrogen	SF = 1.5																																																							
(5) Return Sludge Concentration	R <sub>s</sub> = 8,000 mg/l																																																							
(6) MLSS MLVSS	X <sub>TSS</sub> = 3,000 mg/l																																																							
(7) DO in the Reactor	2 mg/L																																																							
<b>[2] Design Value for perfect Nitrification of Nitrification Process</b>																																																								
(1) Activated sludge design kinwtic coefficients at 20°C																																																								
	<table border="1"> <thead> <tr> <th>Coefficient</th> <th>Unit</th> <th>COD oxidatio</th> <th>NH<sub>4</sub> oxidatio</th> <th>NO<sub>2</sub> oxidatio</th> </tr> </thead> <tbody> <tr> <td>μ<sub>max</sub></td> <td>gVSS/gVSS · d</td> <td>6.000</td> <td>0.900</td> <td>1.000</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>mg/L</td> <td>8.000</td> <td>0.500</td> <td>0.200</td> </tr> <tr> <td>Y</td> <td>gVSS/g substrate oxidized</td> <td>0.450</td> <td>0.150</td> <td>0.050</td> </tr> <tr> <td>b</td> <td>gVSS/gVSS · d</td> <td>0.120</td> <td>0.170</td> <td>0.170</td> </tr> <tr> <td>fd</td> <td>unitless</td> <td>0.150</td> <td>0.150</td> <td>0.150</td> </tr> <tr> <td>K<sub>O<sub>2</sub></sub></td> <td>mg/L</td> <td>0.200</td> <td>0.500</td> <td>0.900</td> </tr> <tr> <td>θ Value</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>μ<sub>max</sub></td> <td>unitless</td> <td>1.070</td> <td>1.072</td> <td>1.063</td> </tr> <tr> <td>b</td> <td>unitless</td> <td>1.040</td> <td>1.029</td> <td>1.029</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>unitless</td> <td>1.000</td> <td>1.000</td> <td>1.000</td> </tr> </tbody> </table> <p>Wastwater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF &amp; EDDY/AECOM)</p>	Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio	μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200	Y	gVSS/g substrate oxidized	0.450	0.150	0.050	b	gVSS/gVSS · d	0.120	0.170	0.170	fd	unitless	0.150	0.150	0.150	K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900	θ Value					μ <sub>max</sub>	unitless	1.070	1.072	1.063	b	unitless	1.040	1.029	1.029	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000
Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio																																																				
μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200																																																				
Y	gVSS/g substrate oxidized	0.450	0.150	0.050																																																				
b	gVSS/gVSS · d	0.120	0.170	0.170																																																				
fd	unitless	0.150	0.150	0.150																																																				
K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900																																																				
θ Value																																																								
μ <sub>max</sub>	unitless	1.070	1.072	1.063																																																				
b	unitless	1.040	1.029	1.029																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000																																																				
(2) μ <sub>AOB</sub>	μ <sub>AOB</sub> = 0.3100 g/g · d = μ <sub>max, AOB</sub> [S <sub>NH<sub>4</sub></sub> / (S <sub>NH<sub>4</sub></sub> + K <sub>NH<sub>4</sub></sub> )] [S <sub>O</sub> / (S <sub>O</sub> + K <sub>O, AOB</sub> )] - b <sub>AOB</sub>																																																							
μ <sub>max, AOB, T</sub>	μ <sub>max, AOB, T</sub> = 0.9000 g/g · d = μ <sub>max</sub> * 1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900																																																							
b <sub>AOB, T</sub>	b <sub>AOB, T</sub> = 0.1700 = b * 1.029 <sup>(T-20)</sup> b at 20°C = 0.170																																																							
S <sub>NH<sub>4</sub></sub>	S <sub>NH<sub>4</sub></sub> = 1.0000 mg/l																																																							
DO	DO = 2.0000 mg/l																																																							
K <sub>O, AOB</sub>	K <sub>O, AOB</sub> = 0.5000 mg/l																																																							

E-2 Process Cal\_EA&al 10MLD Karivobanahalli Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

(2) Design SRT	SRT= 4.8387 day = $1/\mu_{AOB} \times SF$ ⇒ 5.0000 day
(3) Biomass production	
P <sub>X,VSS</sub>	P <sub>X,VSS</sub> = 3127.038 kg/d = P <sub>X,bio</sub> +Q(nbVSS)
P <sub>X,TSS</sub>	P <sub>X,TSS</sub> = 4121.000 kg/d = P <sub>X,bio</sub> /0.85+Q(nbVSS)+Q(TSS <sub>0</sub> -VSS <sub>0</sub> )+5*Q*Al
S	S= 0.4507 mg/l = $Ks[1+b_H(SRT)]/[SRT(\mu_m-b_H)-1]$
b <sub>H</sub>	b <sub>H</sub> = 0.1200 = $b*1.04^{(T-20)}$ b at 20°C = 0.120
Y <sub>H</sub>	Y <sub>H</sub> = 0.4500 gVSS/g bCOD
μ <sub>m,T</sub>	μ <sub>m,T</sub> = 6.0000 g/g·d = $\mu_{max} * 1.04^{(T-20)}$ μ max at 20°C = 6.000
Y <sub>n</sub>	Y <sub>n</sub> = 0.150 gVSS/g Nox
NO <sub>x</sub>	NO <sub>x</sub> = 47.400 mg/l
P <sub>X,bio,VSS</sub>	P <sub>X,bio,VSS</sub> = 1807.449 kg VSS/d = $Q \cdot Y_H(S_0-S)/[1+b_H(SRT)] + f_d \cdot b_H \cdot QY_H(S_0-S)SRT/[1+b_H(SRT)] + QY_n(Nox)[2+b_{AOB}(SRT)]$ 1622.951 = $Q \cdot Y_H(S_0-S)/[1+b_H(SRT)]$ 146.066 = $f_d \cdot b_H \cdot QY_H(S_0-S)SRT/[1+b_H(SRT)]$ 38.432 = $QY_n(Nox)[1+b_{AOB}(SRT)]$
NO <sub>x</sub>	NO <sub>x</sub> = 47.311 mg/l = $TKN-Ne-0.12P_{X,bio}/Q$
(4) Required Aeration Tank Volume	
V <sub>a</sub>	V <sub>a</sub> = 6,868 m <sup>3</sup>
τ	τ = 16.48 hr = V <sub>a</sub> /Q × 24 ⇒ 18.00 hr
X <sub>VSS</sub> · V <sub>a</sub>	X <sub>VSS</sub> · V <sub>a</sub> = 15,635 kg VSS = P <sub>X,VSS</sub> · SRT
X <sub>TSS</sub> · V <sub>a</sub>	X <sub>TSS</sub> · V <sub>a</sub> = 20,605 kg TSS = P <sub>X,TSS</sub> · SRT
F/M	F/M= 0.224 kgBOD/kgMLVSS
FractionVSS=	FractionVSS 0.759
MLVSS=	MLVSS= 2276 mg/L
(5) BODloading	BODloading 0.510 kg/m <sup>3</sup> ·d
(6) Observed Yield	
Y <sub>obs,TSS</sub>	Y <sub>obs,TSS</sub> = 1.178 gTSS/gBOD
Y <sub>obs,VSS</sub>	Y <sub>obs,VSS</sub> = 0.894 gVSS/gBOD
bCODremoved=	bCODremov= 5,770 kg/d
(7) effluent NO <sub>2</sub> -N	NO <sub>2</sub> -N= 0.2315 mg/l = $Ks[1+b_{NOB}(SRT)]/[SRT(\mu_{NOB}-b_{NOB})-1]$
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700 = $b*1.029^{(T-20)}$ b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 1.0000 g/g·d = $\mu_{max} * 1.04^{(T-20)}$ μ max at 20°C = 1.000
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.6897 g/g·d = $\mu_{max,NOB}[S_0/(S_0+K_{O2,NOB})]$
	S <sub>0</sub> = 2.000 mg/l
	K <sub>O2,NOB</sub> = 0.900 mg/l
(8) effluent NH <sub>4</sub> -N	NH <sub>4</sub> -N= 0.5286 mg/l = $Ks[1+b_{NOB}(SRT)]/[SRT(\mu_{NOB}-b_{NOB})-1]$
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700 = $b*1.029^{(T-20)}$ b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 0.9000 g/g·d = $\mu_{max} * 1.072^{(T-20)}$ μ max at 20°C = 0.900
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.7200 g/g·d = $\mu_{max,NOB}[S_0/(S_0+K_{O2,NOB})]$
	S <sub>0</sub> = 2.000 mg/l
	K <sub>O2,NOB</sub> = 0.500 mg/l
(9) Ratio of Return Sludge	8,000*Rr/(1+Rr)= 3,000 mg/L 3,000/(8,000-3,000)= 0.60 Rr = 0.60

E-2 Process Cal\_EA&al 10MLD Karivobanahalli Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

<b>[3] Design for Nitrification and Denitrification Process</b>																					
(1) Active biomass concentration	$X_b = Q \cdot (SRT) / V \cdot Y_H \cdot (S_0 - S) [1 + b_H(SRT)]$ = 1,181.47 mg/l																				
(2) IR ratio	$IR = NO_x / Ne - 1.0 - R$ = 3.66																				
(3) The amount of NO <sub>3</sub> -N fed to the anoxic tank	$Nox\ feed = (IR + R) \cdot Q \cdot Ne$ = 383,106.10 kg/d																				
(4) The anoxic tank volume	$V_{nor} = 687\ m^3 = V_a \times 10\%$ $V_{nor} = 2,083\ m^3 \quad \tau_{DN} = 5.000\ h$																				
(5) F/M <sub>b</sub>	F/M <sub>b</sub> = 1.42 g/g·d																				
(6) Fraction of rbCOD	40.00% = rbCOD/bCOD																				
	<table border="1"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b<sub>0</sub></th> <th>b<sub>1</sub></th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>	Percent rdCOD(%)	SDNR equation coefficients		b <sub>0</sub>	b <sub>1</sub>	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162
Percent rdCOD(%)	SDNR equation coefficients																				
	b <sub>0</sub>	b <sub>1</sub>																			
10	0.186	0.078																			
20	0.213	0.118																			
30	0.235	0.141																			
40	0.242	0.152																			
50	0.270	0.162																			
(8) SDNR <sub>b</sub>	$SDNR_b = 0.296\ g/g \cdot d = b_0 + b_1 [\ln(F/M_b)]$ $b_0 = 0.242$ $b_1 = 0.152$																				
(8) SDNR	$SDNR = 0.110\ g/g \cdot d = SDNR_b (MLVSS_r / MLVSS)$ $SDNR_{adj} = 0.212\ g/g \cdot d = SDNR_b - 0.029 \ln(F/M_b) - 0.012 \quad IR=3-4$ $= SDNR_b - 0.0166 \ln(F/M_b) - 0.078 \quad IR=2$ $SDNR_t = 0.296\ g/g \cdot d = SDNR_b \cdot \theta^{(F-20)} \quad \theta = 1.026$																				
(9) NO <sub>r</sub>	$NO_r = 520,993.08\ kg/d = N_{nox} \cdot SDNR \cdot X_b$ $> Nox\ feed = 383,106\ kg/d$																				
(10) Alkalinity to be added to maintain pH7	-108.33 mg/l																				
	Influent Alk 380.00 mg/l Alk used 338.44 mg/l = 7.14 × Nox Alk produced 136.77 mg/l = 3.57 × (NO <sub>x</sub> - NO <sub>xe</sub> ) Alk to maintain 70.00 mg/l																				
<b>[4] Design of Phosphorus Removal Process</b>																					
(1) Removal T-P	3.13 mg/l																				
P in waste sludge	px = 1.00%																				
Generated waste sludge	Px <sub>vss</sub> = 3127.038 kg/d																				
Rmval Phosphorus	31.27038027 kg/d																				
(2) Effluent T-P without Al	3.87 mg/l																				
(3) Required Al to initial soluble phosphorus ratio	1.00 mol/mol																				
(4) Required Al dosing rate	3.48 mg/l as Al																				
	42.98 mg/l as crystal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> · 18H <sub>2</sub> O																				
(5) Required Aluminum Sulfate	429.78 kg/d																				
(6) Required Aluminum Sulfate solution 10%	4.09 m <sup>3</sup> /d																				
	170.55 L/H																				
(7) Additional sludge	174.23 kg/d																				



E-2 Process Cal. EA&al 10MLD Karivobanahalli Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**[5] Reactor**

(1) Total volume of Aeration Basins

$$V_A = Q \cdot \theta_a / 24$$

$$= 7,500 \text{ m}^3$$

(2) Total volume of Anoxic Basins

$$V_{DN} = Q \cdot \theta_{DN} / 24$$

$$= 2,083 \text{ m}^3$$

Item	Volume required	Retention Time required		Ratio of Volume	
		Summer	Winter		
unit	m <sup>3</sup>	hour	hour		
Anaerobic	V <sub>AN</sub>	630	1.50	1.50	0.30
Anoxic	V <sub>DN</sub>	2,083	5.00	5.00	1.00
Aerobic	V <sub>A</sub>	7,500	18.00	18.00	3.60
Total	V	10,213	24.50	24.50	

**[6] Geometry**

(1) Basin Dimensions

Width      Length      Depth      Basins

8.0            123.0      5.5            2

Cross Section      8.0\*5.5      =      44.0 m<sup>2</sup>/Basin

Hantzschn Subtraction      =      1.0 m<sup>2</sup>/Basin

after Subtraction      44.0-1.0      =      43.0 m<sup>2</sup>/Basin

Total Volume      43.0\*123.0      =      5,289 m<sup>2</sup>/Basin      10,578 m<sup>3</sup>/Total

(2) Partition of Basin

Item	unit	Anaerobic	Anoxic	Aerobic	Total
Cross Section	m <sup>2</sup>	43.0			
Length required	m	7.3	24.2	87.2	118.8
Volume required per Basin	m <sup>3</sup>	315	1,042	3,750	5,107
Total Volume required	m <sup>3</sup>	630	2,083	7,500	10,213
Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0	
Actual Length	m	8.0	25.0	90.0	123.0
Actual Volume per Basin	m <sup>3</sup>	344	1,075	3,870	5,289
Actual Total Volume	m <sup>3</sup>	688	2,150	7,740	10,578
Actual Ratio of Volume		0.32	1.00	3.60	
Actual Retention Time	hour	1.65	5.16	18.58	25.39

**[7] Equipment**

(1) Ras Pumps

Ras Ratio

60%

Required Capacity

10,000 m<sup>3</sup>/day × 60% / 24 / 2

= 125 m<sup>3</sup>/Hr ⇒ 125 m<sup>3</sup>/Hr

Number

2 Work

2 Stanby

(2) Circulation Pumps

Ras Ratio

366%

Required Capacity

10,000 m<sup>3</sup>/day × 366% / 24 / 4

= 381 m<sup>3</sup>/Hr ⇒ 385 m<sup>3</sup>/Hr

Number

4 Work

2 Stanby

(3) SAS Pumps

Excess Sludge

542 m<sup>3</sup>/day

Sludge withdraw

12 Times/day

Running Time

0.5 Hr/Time

Required Capacity

542 m<sup>3</sup>/day / 12 / 0.5 / 2

= 45.20 m<sup>3</sup>/Hr ⇒ 50 m<sup>3</sup>/Hr

Number

2 Work

2 Stanby

E-2 Process Cal. EA&al 10MLD Karivobanahalli Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

(4) Alum Solution Tank										
Number	2	W	+	0	S					
Alum concentration as crystal	10 %									
Gravity of dissolved dechlorine	1.05									
Required solution volume	429.78 kg / d		×	100	/	10	/	1.05	/	1000
	=	4.09				m3/d				
Volume of Tank	2.6					m3/tank				
Total Volume of Tanks	5.2					m3	(Duration=	1.27	day)	
(5) Mixer for Alum Solution Tank										
Number	2	W	+	0	S					
(6) Alum Dosing Pump										
Number	2	W	+	1	S					
Capacity	4.09 m3/d	/	24	×	1000	/	2	×	2	
	170.55 l/h/unit		⇒		180 l/h/unit					

**STP Process Calculation Supporting Report 12.2.3**

<b>6. Air Requirement at Average Flow</b>	
[1] Design Condition	
(1) AOR	AOR = 4,326 kg/day = 180.3 kg/h
Q <sub>in</sub> : Design Average Flow m <sup>3</sup> /d	10,000
Inlet bCOD : S <sub>0</sub>	578 mg/l
S=	0.451 mg/l
Nox=	47.400 mg/l
P <sub>X,bio</sub> =	1,769.0 kg VSS/d does not include nitrifying bacteria
R <sub>0</sub> =	R <sub>0</sub> = Q(S <sub>0</sub> - S - k(Nox - NOx)) - 1.42P <sub>X,bio</sub> + 4.57Q · NOx
R <sub>0</sub> =	4,326 kg O <sub>2</sub> /d
k=	2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{AOR \times C_s \cdot a \times 1.024^{20-T}}{\alpha \times F (\beta \cdot C_{SW} / C_s \cdot (P_b / P_a) a - C_A)}$
	C <sub>S</sub> : Saturated DO at sea level and 20 °C 9.09 mg/L
	C <sub>SW</sub> : Saturated DO at sea level and operating Temperature 9.09 mg/L at 20 °C
	20-T : 0.0 1.024 <sup>20-T</sup> : 1.0000
	C <sub>A</sub> : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1 + 0.40D <sub>j</sub> /P <sub>a</sub> 1.19357
	D <sub>j</sub> : Tank Liquid Depth 5.00 m
	P <sub>a</sub> : Standard absolute pressure at s 10.332 m
	P <sub>b</sub> : Absolute pressure at Plant Site Elevation m
	P <sub>b</sub> /P <sub>a</sub> : exp[-gM(z <sub>b</sub> -z <sub>a</sub> )/R*T] 0.900
	g : Acceleration due to Gravity 9.80665 m/s <sup>2</sup>
	M : Mole of Air 28.97 kg/kg-mole
	z <sub>b</sub> : Plant Site Elevation 900 m
	z <sub>a</sub> : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 293.15 Kelvin
	α : relative Transfer Rate to clean Water 0.65
	β : relative DO Saturation to clean Water 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{46,940}{4.2591} = 11,020.99 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Standard O <sub>2</sub> required at Field Conditions per Basin =	5,510 kg/day
(5) SOTE for the above Effective Aeration Depth	28.0 %
(6) Fraction of O <sub>2</sub> in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	15%
(9) Air required at Field Conditions per Basins	= 81,044 m <sup>3</sup> /day = 3,376.9 m <sup>3</sup> /hr

E-2 Process Cal. EA&al 10MLD Karivobanahalli Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

[2] Equipment				
(1) Air Blower				
Number	4	W	+	2 S
Required Capacity	3376.9	m <sup>3</sup> /Hr·Basin	/	2 unit/Basin
	= 1688.4	m <sup>3</sup> /h	⇒	1700 m <sup>3</sup> /h /Unit
Pressure	65	kPa		
Safety Factor	10	%		
Heat capacity ratio	1.4			
Atmospheric pressure at site elevation	91.234	kPa		
Total inlet pressure	89.234	kPa		
Volume rate of flow at inlet point	32.165	m <sup>3</sup> /min		
Total discharge pressure	156.234	kPa		
Overall adiabatic efficiency	0.65			
Inlet air temperature (min.)	15	°C		
Shaft power	45.477	kW		
Rated Output of Motor	50.024	kW	⇒	55 kW

E-2 Process Cal. EA&al 10MLD Karivobanahalli Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>7. Final Clarifire</b></p> <p><b>[1] Design Condition</b></p> <p>(1) Design Wastewater Flow</p> <p>(2) Water Temperature</p> <p>(3) MLSS</p> <p>(4) SVI</p> <p>(5) Sedimentation Velocity</p> <p>(6) Surface Overflow Rate required</p> <p><b>[2] Geometry</b></p> <p>(1) Surface Area required</p> <p>(2) Demensions</p> <p>(3) Actual Surface Area</p> <p>(4) Surface Overflow Rate</p>	<p><math>Q = 10,000 \text{ m}^3/\text{day}</math></p> <p><math>T = 20.0 \text{ }^\circ\text{C}</math></p> <p><math>X_{ef} = 3,000 \text{ mg/l}</math></p> <p><math>SVI = 300</math></p> <p><math>v = 4.899 \cdot 10^6 \cdot T^{(0.954)} \cdot X_{ef}^{(-1.354)} \cdot SVI^{(-0.77)}</math>  <math>= 4.899 \cdot 10^6 \cdot 20.0^{0.954} \cdot 3,000^{-1.354} \cdot 150^{-0.770}</math>  <math>= 20.7 \text{ m/day}</math></p> <p><math>S' = v / (1.5 \cdot 1) = 20.7 / (1.5 \cdot 1.0) = 13.8 \text{ m}^3/\text{m}^2 \cdot \text{day}</math>  <math>\rightarrow 12.0 \text{ m}^3/\text{m}^2 \cdot \text{day}</math></p> <p><math>A = 10,000 / 12.0 = 833 \text{ m}^2</math></p> <table style="margin-left: 40px;"> <tr> <td style="text-align: center;">Diameter</td> <td style="text-align: center;">Depth</td> <td style="text-align: center;">Basin</td> </tr> <tr> <td style="text-align: center;"><b>23.0</b></td> <td style="text-align: center;"><b>3.5</b></td> <td style="text-align: center;"><b>2</b></td> </tr> </table> <p><math>S = 23.0^2 \cdot 3.14 / 4 \cdot 2.0 = 831 \text{ m}^2</math></p> <p><math>S = 10,000 / 831 = 12.0 \text{ m}^3/\text{m}^2 \cdot \text{day}</math></p>	Diameter	Depth	Basin	<b>23.0</b>	<b>3.5</b>	<b>2</b>
Diameter	Depth	Basin					
<b>23.0</b>	<b>3.5</b>	<b>2</b>					

E-2 Process Cal. EA&amp;al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>8. Chlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 10,000 m <sup>3</sup> /day 416.67 m <sup>3</sup> /h Peak Flow 22,500 m <sup>3</sup> /day 937.50 m <sup>3</sup> /h
(2) Contact Time	30 min
(3) Type of Chlorine	Cl <sub>2</sub> -GAS
(4) Design Chlorine Dosage Rate	10 mg/L
(5) Required Chlorine per day	Average Daily Flow / 1000 × Design Chlorine Dosage Rate = 100.0 kg/d = 4.17 kg/h
<b>[2] Chlorination Contact Tank</b>	
(1) Volume required	Average Daily Flow / 1440 × Contact Time = 208.3 m <sup>3</sup>
(2) Nos. of lanes	3 lanes
(3) Width of lane	2.00 m
(4) Length of lane	18.00 m
(5) Side Water Depth	2.00 m
(6) Nos. of Tanks	1 tank
(7) Total Width of Tank	6.80 m Approx..
(8) Average Velocity	Decant Flow / 3600 / Width / Depth = 416.67 / 3600 / 2.00 / 2.00 = 0.029 m/sec
(9) Total Volume	Width × Length × Depth × Nos. of lanes × Nos. of Tanks = 2.0 m × 18.0 m × 2.0 m × 3 × 1 = 216 m <sup>3</sup> > 208.3 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Chlorine Dosing Condition	
Operation Dosage Rate -1	DC1 10 mg/L
(2) Chlorine Cylinder	
Type	- Cylindrical Convexsd Container
Cylinder Capacity	Cc 928 kg/cylinder
Average Dosage Rate -1	q1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 100 kg/day
Maximum Dosage Rate -1	q3 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 225 kg/day
Storage day	T More than 15 days
Required Storage Capacity	EC1 D × T = 1,500 kg
Unit Number	EN1 EC1 / Cc = 1.6 cylinders
Maximum Operation Numbers	
Cl <sub>2</sub> -Gas Volatilize Rate	Vr1 ##### @ 20°C Standard temperature
Maximum Dosing Rate	DC1 10 mg/L, Q <sub>T-D</sub> × q3 × 10 <sup>-3</sup> / 24 = 9.38 kg/h
Operation Numbers	EN2 DC1 / Vr1 = 1.2sets
Number	2 W + 2 S
(3) Chlorinator	
Type	Solution Feed Vacuum Type
Number	1 W + 1 S
Operation Dosage Rate -1	Dq1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 225 kg/day
Required Dosage Rate	Chlorine -1 : Dq1 / (EN1 × 24) = Minimum Maximum 0.00 kg/hr 9.4 kg/hr

E-2 Process Cal. EA&amp;al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

(4) Chlorine Booster Pump	Branchy on the water supply pipe
Type	Water requiamet for mixed Chlori
Water Demand	(kg/hr) 1.0 1.5 2.0 2.5 3.0 4.0
Chlorinator Discharge	(L/min) 15 20 25 30 35 40
Water Demand	(kg/hr) 5.0 6.0 10.0 50.0 100.0 200.0
Chlorinator Discharge	(L/min) 45 50 60 300 600 1,200
Water Demand	-
Water requiamet	Qp1 Maximum dosage rate 9.4 kg/hr
For Chlorin	therefore 60 L/min
Booster Pump Type	Single suction volute pump
Number	1 W + 1 S
<b>9. Dechlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 10,000 m <sup>3</sup> /day
(2) Contact Time	10 min
(3) Type of Dechlorine	Sodium Thiosulfate (Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 5H <sub>2</sub> O)
(4) Free Residual Chlorine	1.0 mg/L assumed value
(5) Consumption per day	Average Daily Flow / 1000 × Free Residual Chlorine × 1.75
	× 1.5 (safety factor)
	= 26.3 kg/d
	= 1.09 kg/h
<b>[2] Dechlorination Contact Tank</b>	
(1) Volume required	Average Flow Rate / 60 × Contact Time
	= 69.4 m <sup>3</sup>
(2) Width of lane	6.80 m
(3) Length of lane	5.50 m
(4) Side Water Depth	2.00 m
(5) Nos. of Tanks	1 tank
(6) Total Volume	Width × Length × Depth
	= 6.8 m × 5.5 m × 2.0 m
	= 75 m <sup>3</sup> > 69.4 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Dechlorine Solution Tank	
Number	1 W + 0 S
Dechlorine concentration	10 %
Gravity of dissolved dechlorine	1.10
Required solution volume	26.25 kg/d × 100 / 10 / 1.10 / 1000
	= 0.24 m <sup>3</sup> /d
Volume of Tank	0.360 m <sup>3</sup> /tank (= 0.6 mW × 0.6 mL × 1.0 mH)
Total Volume of Tanks	0.360 m <sup>3</sup> (Duration= 1.51 day)
(2) Mixer for Dechlorine Solution Tank	
Number	2 W + 0 S
(3) Dechlorine Dosing Pump	
Number	1 W + 1 S
Capacity	0.54 m <sup>3</sup> /d / 24 × 1000 / 1
	22.37 l/h/unit ⇒ 23 l/h/unit

E-2 Process Cal. EA&al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

<p><b>10. Centrifuge</b>  <b>[1] Design Condition</b>                  (1) Type of Dewatering                  (2) Generated Sludge                  (3) Design Polyelectrolyte Dosage                  (4) Volume of Thickend Sludge                  (5) Consistency of Dewatered Sludge                  (6) Operation Time</p>	<p>Centrifuge                  4,339 kg/day                  Polyelectrolyte 5 kg/t-DS·day                  542.4 m<sup>3</sup>/day                  82 %                  12 hours/day (6 days per week)</p>
<p><b>[2] Volume of Centrifuges</b></p>	<p><math display="block">\frac{\text{Digested Solids}}{\text{Operation Time} \times \text{No.}} \times \text{Operation/week}</math> <math display="block">= \frac{542.4}{12 \times 2} \times \frac{7}{6} = 26.4</math> <p style="text-align: right;">→ 27 m<sup>3</sup>/hour</p> </p>
<p><b>[3] Dewatered Solids</b></p>	<p><math display="block">\text{Digested Sludge} \times (1 + \text{Injection Rate})</math> <math display="block">= 4,339 \times (1 + 0.0050)</math> <math display="block">= 4,361 \text{ kg/day}</math> </p>
<p><b>[4] Dewatered Cake Volume</b></p>	<p><math display="block">\text{Dewatered Solids} \times \frac{100}{100 - \frac{\text{Moisture Content}}{7}} \times \frac{7}{6}</math> <math display="block">= 4,361 \times \frac{100}{100 - 82} \times \frac{7}{6}</math> <math display="block">= 28.27 \text{ t/day}</math> <p>apparent specific gravity 1.00  <math display="block">\frac{28.27}{1.0} = 28.3 \text{ m}^3/\text{day}</math></p> </p>
<p><b>[5] Polyelectrolyte</b>                  (1) Design Polyelectrolyte Dosage                  (2) Required Polyelectrolyte                  (3) Dissolving concentration                  (4) Volume of Polyelectrolyte solution</p>	<p>Polyelectrolyte 5 kg/t-DS·day                  21.69 kg/day                  0.20 %                  10.85 m<sup>3</sup>/day</p>



E-2 Process Cal. EA&al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

<b>[6] Equipment</b>	
(1) Centrifuge	
Capacity	27 m <sup>3</sup> /hr
Number	2 W + 1 S
(2) Centrifuge Feed Pumps	
Capacity	27 m <sup>3</sup> /hr
Number	2 W + 1 S
(3) Polyelectrolyte Dosing Pumps	
Volume of Polyelectrolyte solution	10.85 m <sup>3</sup> /day
Operation Time	12 hours/day (6 days per week)
Safety Factor	1.5
Number	2 W + 1 S
Required Capacity	10.85 m <sup>3</sup> /da × 7 / 6 / 12 / 2
	= 0.53 m <sup>3</sup> /Hr
Specification Capacity	0.53 m <sup>3</sup> /Hr × 1.5
	= 0.791 m <sup>3</sup> /Hr ⇒ 0.80 m <sup>3</sup> /Hr /Unit
(4) Polyelectrolyte dosing System	
Preparation time for solution	3 hr
Required dry polymer	21.69 kg/day × 7 / 6 / 12
	= 2.11 kg/hr
	= 6.33 kg per one batch
Feeding time per one batch	30 min
Capacity of Dry polymer Feeder	13 kg/h
Tanks Dimensions	Width 1.5 m × Length 1.5 m × Depth 2.0 m × 2 (Freeboard 0.5m)
	= 9 m <sup>3</sup>
Retention Time of Tank	4.50 m <sup>3</sup> /tank / 0.53 m <sup>3</sup> /Hr / 2
	= 4.267 Hr > 3 Hr
Number	2 W + 0 S

E-2 Process Cal. EA&al 10MLD Karivobanahalli, Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>11. Centrifuge Feed Sump</b>	
<b>[1] Design Condition</b>	
(1) Generated Thickend Sludge	4,339 kg/day
(2) Solids Consistency	0.80 %
(3) Volume of Thickened Sludge	$\text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3}$ $= 4,339 \times \frac{100}{0.80} \times 10^{-3}$ $= 542 \text{ m}^3/\text{day}$ $= 22.60 \text{ m}^3/\text{h}$
(4) Sludge feed flow rate	27 m <sup>3</sup> /h × 2 = 54 m <sup>3</sup> /h
(5) Centrifuge Operation Time	12 hours/day ( 6 days per week)
<b>[2] Geometry</b>	
(1) Basin Dimensions	$\text{Width } 6.0 \text{ m} \times \text{Length } 7.0 \text{ m}$ $\times \text{Depth } 4.0 \text{ m} \times 2$ $= 336.0 \text{ m}^3$
<b>[3] Equipment</b>	
(1) Mixers for Centrifuge Feed Sumps	
Required Volume	336.0 m <sup>3</sup>
Number	1 W + 1 S

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Digestion Tank + Centrifugal Dewatering)

Table -1 Input Data

1. Calculation Manner	2	1:Premise that the quality of supernatants are same level removed with inlet sewage 2:Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency	2	1:Total Removal Ratio 2:Outlet Water Quality(input 1or2)
In case of 1 : input data		(%)
In case of 2 : input data	#REF!	(mg/l)
3. Selection of Excess Sludge Generation	2	1:Consideration of Solid Matter Only 2:Consideration of Converting of Solved BOD(input 1or2)
In case of 1 : input data (Sludge generation)		Sludge generation ratio per removal SS(%)
	a	0.4 T2=Q4·S4=(a·S <sub>BOD</sub> +b·S1-c·θ·XA)·Q3/10 <sup>6</sup> · (Excess sludge generation formula)
	b	0.9 a:Converting ratio of solved BOD(mgMLSS/mgBOD)
	c	0.05 b:Converting ratio of SS(mgMLSS/mgSS)
In case of 2 : input data	SBOD	234.50 c:Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)
	XA	3,000 S <sub>BOD</sub> :Solved BOD quality at inlet reactor
	θ	1 XA:MLSS concentration(mg/l)
		θ:Hydraulic retention time(day)


Table -2 Basic Conditions

Sewage Flow and Quality	Sludge Moisture and Recovery Ratio	Digestion Tank Conditions	Chemical Conditions for Dewatering
·Inlet flow : Q <sub>0</sub> (m <sup>3</sup> /D)	10,000	·Primary sludge moisture ratio : W1(%)	0.0
·Inlet quality : S <sub>0</sub> (mg/l)	450	·Excess sludge moisture ratio : W2(%)	99.2
·Total removal ratio : A1(%)	-	·Thickened sludge moisture ratio : W3(%)	99.2
·Effluent quality : S1(mg/l)	10.0	·Digested sludge moisture ratio : W4(%)	99.2
·Sludge generation ratio per removal SS : S1(%)	-	·Dewatered sludge moisture ratio : W5(%)	82.0
		·Removal ratio in primary tank : A2(%)	0.0
		·Recovery ratio in sludge thickener : A3(%)	100.0
		·Recovery ratio in sludge digester : A4(%)	100.0
		·Recovery ratio in dewatering : A5(%)	95.0
		·Content of organics in thickened sludge : A6(%)	75.0
		·Digestion ratio : A7(%)	#REF!
		·Digestion gas generation : A8(Nm <sup>3</sup> /kgVS)	
		·Chemical dosage : A9(%)	0.5
		·Chemical dissolve concentration : A10(%)	0.2

Table -3 Material Balance Calculation

Q(m <sup>3</sup> /day)	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	手入力(要取束)	16	17	
T(t·DS/day)	4,500	4,718	0,000	4,718	4,339	0,100	4,339	0,000	0,000	4,339	0,000	0,022	4,361	4,143	0,218	0,218	0,218		0,100	0,279
S(mg/l)	450	448	0	448	8,000	10	8,000	#DIV/0!	0	8,000	0	2,000	7,882	180,000	411	411			10	
X(T5/T0*100)	100	104.8	0.0	104.8	96.4	2.2	96.4	0.0	0.0	96.4	0.0	0.5	96.9	92.1	4.8	4.8			2.2	6.2

Figure -1 Material Balance Model




Calculation Formula						
·Q0=Input Data	·Q3=Q1-Q2	·Q6=T6*100/(100-W3)	·Q9=Q6	·Q12=Q9+Q11	·Q15=Q7+Q10+Q14	·Q5-1=Q5-Q11
·T0=Q0*S0*10 <sup>-6</sup>	·T3=T0*(100-A2)/100	·T6=(T2+T4)*A3/100	·T9=(T6-T8)*A4/100	·T12=T9+T11	·T15=T7+T10+T14	·T5-1=T5-T11
·S0=Input Data	·S3=T3*10 <sup>-6</sup> /Q3	·S6=10 <sup>-6</sup> *Q3/(100-W3)/100	·S9=T9*10 <sup>-6</sup> /Q9	·S12=T12*10 <sup>-6</sup> /Q12	·S15=T15*10 <sup>-6</sup> /Q15	·S5-1=S5
·Q1=Q0+Q15	·Q4=T4*100/(100-W2)	·Q7=(Q2+Q4)-Q6	·Q10=Q6-Q8-Q9	·Q13=T13*100/(100-W5)		
·T1=T0+T15	·T4=余剰汚泥発生式による	·T7=(T2+T4)-T6	·T10=T6-T8-T9	·T13=T12*A5/100		
·S1=T1*10 <sup>-6</sup> /Q1	·S4=10 <sup>-6</sup> *Q4/(100-W2)/100	·S7=T7*10 <sup>-6</sup> /Q7	·S10=T10*10 <sup>-6</sup> /Q10	·S13=10 <sup>-6</sup> *Q13/(100-W5)/100		
·Q2=T2*100/(100-W1)	·Q5=Q3-Q4*(T3-T5)/T4	·Q8=0	·Q11=T10*A9/A10	·Q14=Q12-Q13		
·T2=T1-T3	·T5=Q5*ST/10 <sup>-6</sup>	·T8=T6*A6*A7/10 <sup>-4</sup>	·T11=Q11*S11/10 <sup>-6</sup>	·T14=T12-T13		
·S2=10 <sup>-6</sup> *Q2/(100-W1)/100	·S5=St	#REF!	·S11=10 <sup>-4</sup> *A10	·S14=T14*10 <sup>-6</sup> /Q14		

Material Balance Sheet SD4

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Sheet  
[3MLD STP]



E-3 Process Cal EA&al 3MLD Herohalli, Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**Design Condition**

Item	3MLD STP-TSPS			
(1) Design Flow for the year 2049	Flow Rate			
		m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s
	Daily Average	5,000	208	0.058
	Daily Maximum	5,000	208	0.058
Hourly Max. Peak factor 2.5	#####	521	0.145	
(1) Design Flow for the year 2034	Flow Rate			
		m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s
	Daily Average	3,000	125	0.035
	Daily Maximum	3,000	125	0.035
Hourly Max. Peak factor 2.5	7,500	313	0.087	

**1. Inlet Chamber**

Item	3MLD STP-TSPS			
[1] Design Condition				
(1) Design Flow for the year 2049	Max Hourly	=	12,500	m <sup>3</sup> /d
		=	0.145	m <sup>3</sup> /sec
(2) Inlet Pipe				
Pipe Diameter	·	×		
Gradient		%		
Roughness Coefficient	n=	0.013	(Manning Formula)	
Full Pipe Flow Rate		m <sup>3</sup> /s		
(3) Influent Water Level	+	m		
[2] Geometory				
(1) Number of Basins	1	Basin		
(2) Depth of Basin	0.600	m	Approx.	
(3) Width of Basin	1.800	m	Approx.	
(4) Length of Basin	2.500	m	Approx.	
(5) Volume required of Basin	0.600	×	1.800	×
			2.500	=
				0.4
				m <sup>3</sup>
(6) Retention Time	0.600	×	1.800	×
			2.500	/
				0.145
				×
				1
	=	18.62	sec	
(7) Basin Demensions	Width	1.800	m	×
				Length
				2.500
				m
	×	Depth	0.600	m

E-3 Process Cal. EA&al 3MLD Herohalli, Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**2. Coarse Screen Channel**

Item	3MLD STP-TSPS					
[1] Geometry						
(1) Inlet Gate						
Number	1	Main	+	1	Bypass	
Width	0.400	m				
Height	0.600	m				
Floor Level	+	5.000	m			
Bottom	+	0.000	m			
Influent Water Level	+	0.500	m			
Velocity	0.145	/		0.400	/	0.500 / 1
where Design Flow for the year 2049	=	0.725	<	1.000	m/sec	OK
Velocity	0.087	/		0.400	/	0.500 / 1
where Design Flow for the year 2034	=	0.435	<	1.000	m/sec	OK
(2) Screen Channel						
Number	1.0	Main	+	1.0	Bypass	
Width	0.800	m				
Side Water Depth	0.500	m				
Velocity	0.145	/		0.800	/	0.500 / 1
where Design Flow for the year 2049	=	0.363	≐	0.450	m/sec	OK
Velocity	0.087	/		0.800	/	0.500 / 1
where Design Flow for the year 2034	=	0.218	<	0.450	m/sec	OK
(3) Channel Dimensions	Width	0.8	m	×	Length	8.5 m
	×	SWD	0.5	m	(Freeboard 0.3m)	
[3] Equipment						
(1) Inlet Gate						
Number	2	Units				
Dimension	Width	0.4	m	×	Height	0.6 m
Design Water Level		m				
(2) Coarse Screens (Main Channel)						
Number	1	W	+	0	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	0.8	m				
Width of side plate	50	mm				
Side Water Depth	0.5	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.145	/		0.700	/	0.450 / 1
	×	( 20	+	9 )/	20	
	=	0.667	≐	0.800	m/sec	OK
Velocity through screen	0.087	/		0.700	/	0.450 / 1
where Design Flow for the year 2034	×	( 20	+	9 )/	20	
	=	0.400	<	0.800	m/sec	OK
(3) Coarse Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	50	mm				
Bar Thickness	9	mm				
Channel Width	0.8	m				
Side Water Depth	0.5	m				
Velocity through screen	0.145	/		0.800	/	0.500 / 1
where Design Flow for the year 2049	×	( 50	+	9 )/	50	
	=	0.428	<	0.800	m/sec	OK
Velocity through screen	0.087	/		0.800	/	0.500 / 1
where Design Flow for the year 2034	×	( 50	+	9 )/	50	
	=	0.257	<	0.800	m/sec	OK

E-3 Process Cal. EA&al 3MLD Herohalli, Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**3. Raw Sewage Sump**

Item	3MLD STP-TSPS	
[2] Geometyry		
(1) Raw Sewage Sump		
Number	1	Basin
Dia	6.50	m
Pump Operating Depth	1.000	m
Retention Time whe Design Flow for the year 2049	$( \frac{6.50^2 \times \pi}{4} \times 1.000 ) / 0.145$	$/ 60$ = 3.81 > 3.75 min (=minimum time of one pump cycle) OK
Retention Time whe Design Flow for the year 2034	$( \frac{6.50^2 \times \pi}{4} \times 1.000 ) / 0.087$	$/ 60$ = 6.36 > 3.75 min (=minimum time of one pump cycle) OK
High Water Level	+ 0.000	m
Pump Off Level	+ -1.000	m
[3] Equipment		
(1) Sewage Pumps 1		
Number	1	W + 1 S
Bore Diameter	200	mm
Discharge Flow : Q whe Design Flow for the year 2034	$0.087 \times 3600$	$/ 1.0$ = 313 $\Rightarrow$ 315 m <sup>3</sup> /Hr
Total Head	15.0	m
(2) Sewage Pumps 2		
Number	W	+ S
Bore Diameter	mm	
Discharge Flow : 0.5 whe Design Flow for the year 2034		$/$ = $\Rightarrow$ m <sup>3</sup> /Hr
Total Head	m	

E-3 Process Cal. EA&al 3MLD Herohalli, Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

Item	3MLD STP																																													
<b>1. STP Design Condition</b>																																														
(1) Design Flow Rate	<table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th></th> <th>m<sup>3</sup>/d</th> <th>m<sup>3</sup>/h</th> <th colspan="2">m<sup>3</sup>/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td>3,000</td> <td>125.00</td> <td colspan="2">0.035</td> </tr> <tr> <td>Max Daily</td> <td>3,000</td> <td>125.00</td> <td colspan="2">0.035</td> </tr> <tr> <td>Max Hourly Peak factor 2.5</td> <td>7,500</td> <td>312.50</td> <td colspan="2">0.087</td> </tr> </tbody> </table>						m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s		Average Daily	3,000	125.00	0.035		Max Daily	3,000	125.00	0.035		Max Hourly Peak factor 2.5	7,500	312.50	0.087																						
	m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s																																											
Average Daily	3,000	125.00	0.035																																											
Max Daily	3,000	125.00	0.035																																											
Max Hourly Peak factor 2.5	7,500	312.50	0.087																																											
(2) Design Water Quality	<p style="text-align: right;">Unit: mg/L</p> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th colspan="2">TP</th> </tr> <tr> <th>NH<sub>4</sub>-N</th> <th>Org-N</th> <th>NOx-N</th> <th>D-P</th> <th>P-P</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td>350</td> <td>800</td> <td>450</td> <td>45.5</td> <td>17.5</td> <td>7</td> <td>5</td> <td>2</td> </tr> <tr> <td>Outlet</td> <td>10</td> <td>50</td> <td>10</td> <td>1</td> <td>0</td> <td>9</td> <td>1</td> <td>1</td> </tr> <tr> <td>Removal rate</td> <td>97.1%</td> <td>93.7%</td> <td>97.8%</td> <td colspan="3">85.7%</td> <td colspan="2">71.4%</td> </tr> </tbody> </table>						BOD	COD	SS	T-N			TP		NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P	Inlet	350	800	450	45.5	17.5	7	5	2	Outlet	10	50	10	1	0	9	1	1	Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%	
	BOD	COD	SS	T-N						TP																																				
				NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P																																						
Inlet	350	800	450	45.5	17.5	7	5	2																																						
Outlet	10	50	10	1	0	9	1	1																																						
Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%																																							
<b>2. Inlet Chamber</b>																																														
<b>[1] Design Condition</b>																																														
(1) Design Flow Rate	Max Hourly	=	7,500	m <sup>3</sup> /day																																										
		=	0.087	m <sup>3</sup> /sec																																										
<b>[2] Geometry</b>																																														
(1) Number of Basins	1	Basin																																												
(2) Depth of Basin	1.000	m																																												
(3) Width of Basin	1.800	m																																												
(4) Length of Basin	1.500	m																																												
(5) Volume required of Basin	1.000	×	1.800	×	1.500 = 1.2 m <sup>3</sup>																																									
(6) Retention Time	1.000	×	1.800	×	1.500 / 0.087 × 1																																									
	=	31.03	sec																																											
(7) Basin Dimensions	Width	1.800	m	×	Length 1.500 m																																									
	×	Depth	1.000	m																																										



E-3 Process Cal. EA&al 3MLD Herohalli, Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Wastewater Flow	$\begin{aligned} \text{Max Hourly} &= 7,500 \text{ m}^3/\text{d} \\ &= 0.087 \text{ m}^3/\text{sec} \end{aligned}$
[2] Geometory	
(1) Inlet Gate	
Number	1 Main + 1 Bypass
Width	0.400 m
Height	0.600 m
Floor Level	+ 2.000 m
Bottom	+ 0.000 m
Influent Water Level	+ 0.500 m
Velocity	$\begin{aligned} &0.087 \text{ } \diagdown \quad 0.400 \text{ } \diagdown \quad 0.500 \text{ } \diagdown \quad 1 \\ = &0.435 \text{ } \div \quad 1.000 \text{ m/sec} \end{aligned}$
(2) Screen Channel	
Number	1 Main + 1 Bypass
Width	0.600 m
Side Water Depth	0.400 m
Velocity	$\begin{aligned} &0.087 \text{ } \diagdown \quad 0.600 \text{ } \diagdown \quad 0.400 \text{ } \diagdown \quad 1 \\ = &0.363 \text{ } \div \quad 0.450 \text{ m/sec} \end{aligned}$
(3) Channel Dimensions	$\begin{aligned} \text{Width} &0.6 \text{ m} \times \text{Length} &6.0 \text{ m} \\ &\times \text{SWD} &0.4 \text{ m} \quad (\text{Freeboard } 0.3\text{m}) \end{aligned}$
[3] Equipment	
(1) Inlet Gate	
Number	1 W + 1 S
Dimension	Width 0.4 m × Height 0.60 m
Design Water Level	2.00 m
(2) Fine Screens (Main Channel)	
Number	1 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	0.6 m
Width of side plate	50 mm
Side Water Depth	0.4 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	$\begin{aligned} &0.087 \text{ } \diagdown \quad 0.500 \text{ } \diagdown \quad 0.350 \text{ } \diagdown \quad 1 \\ &\times ( \frac{6}{6} + \frac{2}{6} ) \\ = &0.663 < 0.800 \text{ m/sec} \end{aligned}$
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	0.6 m
Side Water Depth	0.4 m
Velocity through screen	$\begin{aligned} &0.087 \text{ } \diagdown \quad 0.600 \text{ } \diagdown \quad 0.400 \text{ } \diagdown \quad 1 \\ &\times ( \frac{20}{20} + \frac{9}{20} ) \\ = &0.526 < 0.800 \text{ m/sec} \end{aligned}$

E-3 Process Cal. EA&al 3MLD Herohalli, Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<b>4. Grit Chamber</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Max Hourly = 7,500 m <sup>3</sup> /day = 0.087 m <sup>3</sup> /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0111 m/sec = 960 m <sup>3</sup> /m <sup>2</sup> /day
(4) Average Velocity	0.3 m/sec
<b>[2] Grit Chamber</b>	
(1) Surface Area required	0.087 / 0.0111 = 7.84 m <sup>2</sup>
(2) Number of Basins	1 S + 1 W
(3) Surface Area required/Basin	7.8 / 1 = 7.84 m <sup>2</sup>
(4) Length of Basin	7.84 ^0.5 = 2.8 m → 3.0 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.087 × 60 sec / 1 = 5.2 m <sup>3</sup>
(7) Depth required	5.2 / 3.0 / 3.0 = 0.580 m
(8) Basin Dimensions	Width 3.0 m × Length 3.0 m × Depth 0.6 m (Freeboard 0.3m)
(9) Retention Time	3 × 3.0 × 0.6 / 0.087 × 1 = 60.00 sec
(10) Surface Overflow Rate at Peak Flow	7,500 / 3.0 / 3.0 / 1 = 833.333333 < 960 m <sup>3</sup> /m <sup>2</sup> /day
<b>[3] Parshall Flume</b>	
(1) Design Flow Rate	Q= 87.000 l/sec
(2) Throat width	W= 0.450 m
(3) Water depth Ha	Ha= ( Q / 2264 / W ) <sup>2/3</sup> Ha= 0.194 m
(4) Crest Level	+ 75.400 m ≐ Minimum water level at downstream channel
(5) Water level at the crest	+ 75.594 m
(6) Channel bottom level	+ m
(7) Upstream Channel width	1.500 m
(8) SWD of Upstream Channel	0.700 m
(9) Average velocity at upstream channel	0.083 m/sec
(10) Total Length of channel	10.000 m
<b>[4] Inlet Weir Gate</b>	
(1) Number	2 Units
(2) Weir Width	0.300 m
(3) Stroke	0.350 m
(4) Overflow Height	0.300 m
(5) Overflow Height (actual)	( 0.087 / 1.840 / 0.300 / 2 ) <sup>2/3</sup> = 0.184 < 0.300 m

**STP Process Calculation Supporting Report 12.2.3**

<b>5. Reactor</b>																																																								
<b>[1] Design Condition</b>																																																								
(1) Design Wastewater Flow	Q = 3,000 m <sup>3</sup> /day (summer) Q' = 3,000 m <sup>3</sup> /day (Winter)																																																							
(2) Design Sewage Quality																																																								
Inlet BOD	350 mg/l																																																							
Outlet BOD	10.0 mg/l																																																							
Inlet S-BOD	235 mg/l assumed as 67% of BOD																																																							
Inlet COD	800 mg/l																																																							
Inlet bCOD : S <sub>0</sub>	578 mg/l																																																							
Inlet nbCOD	223 mg/l																																																							
bCOD/BOD	1.65																																																							
Inlet S-COD : sCOD	271 mg/l																																																							
Inlet rbCOD	231 mg/l bCOD*40%																																																							
Inlet sbCOD	347 mg/l bCOD*60%																																																							
Outlet S-COD : nbsCODE	40 mg/l																																																							
Inlet nbpCOD : nbpCOD	183 mg/l = TCOD-bCOD-nbsCODE																																																							
Inlet SS	450 mg/l																																																							
Inlet VSS	383 mg/l assumed as 85% of TSS																																																							
: VSS <sub>COD</sub>	1.38 gCOD/gVSS = TCOD-sCOD/VSS																																																							
: nbVSS	131.96 gnbVSS/m <sup>3</sup> = nbpCOD/VSS <sub>COD</sub>																																																							
: iTSS	67.50 gnbVSS/m <sup>3</sup> = TSS-VSS																																																							
Inlet T-N	70 mg/l																																																							
Inlet TKN	70 mg/l																																																							
Inlet NH <sub>4</sub> -N	45 mg/l																																																							
Inlet T-P	7 mg/l																																																							
Inlet D-P	5 mg/l																																																							
Inlet Alkalinity as CaCO <sub>3</sub>	380 mg/l																																																							
Outlet Kjeldahl N	1.0 mg/l																																																							
Outlet NH <sub>4</sub> -N	1.0 mg/l																																																							
Outlet NO <sub>3</sub> -N	9.0 mg/l																																																							
Outlet T-P	2 mg/l																																																							
Outlet D-P	1 mg/l																																																							
(3) Water Temperature	T = 20.0 °C																																																							
(4) Safety Factor for Nitrogen	SF = 1.5																																																							
(5) Return Sludge Concentration	R <sub>s</sub> = 8,000 mg/l																																																							
(6) MLSS MLVSS	X <sub>TSS</sub> = 3,000 mg/l																																																							
(7) DO in the Reactor	2 mg/L																																																							
<b>[2] Design Value for perfect Nitrification of Nitrification Process</b>																																																								
(1) Activated sludge design kinwtic coefficients at 20°C																																																								
	<table border="1"> <thead> <tr> <th>Coefficient</th> <th>Unit</th> <th>COD oxidatio</th> <th>NH<sub>4</sub> oxidatio</th> <th>NO<sub>2</sub> oxidatio</th> </tr> </thead> <tbody> <tr> <td>μ<sub>max</sub></td> <td>gVSS/gVSS · d</td> <td>6.000</td> <td>0.900</td> <td>1.000</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>mg/L</td> <td>8.000</td> <td>0.500</td> <td>0.200</td> </tr> <tr> <td>Y</td> <td>gVSS/g substrate oxidized</td> <td>0.450</td> <td>0.150</td> <td>0.050</td> </tr> <tr> <td>b</td> <td>gVSS/gVSS · d</td> <td>0.120</td> <td>0.170</td> <td>0.170</td> </tr> <tr> <td>fd</td> <td>unitless</td> <td>0.150</td> <td>0.150</td> <td>0.150</td> </tr> <tr> <td>K<sub>O<sub>2</sub></sub></td> <td>mg/L</td> <td>0.200</td> <td>0.500</td> <td>0.900</td> </tr> <tr> <td>θ Value</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>μ<sub>max</sub></td> <td>unitless</td> <td>1.070</td> <td>1.072</td> <td>1.063</td> </tr> <tr> <td>b</td> <td>unitless</td> <td>1.040</td> <td>1.029</td> <td>1.029</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>unitless</td> <td>1.000</td> <td>1.000</td> <td>1.000</td> </tr> </tbody> </table> <p>Wastwater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF &amp; EDDY/AECOM)</p>	Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio	μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200	Y	gVSS/g substrate oxidized	0.450	0.150	0.050	b	gVSS/gVSS · d	0.120	0.170	0.170	fd	unitless	0.150	0.150	0.150	K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900	θ Value					μ <sub>max</sub>	unitless	1.070	1.072	1.063	b	unitless	1.040	1.029	1.029	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000
Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio																																																				
μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200																																																				
Y	gVSS/g substrate oxidized	0.450	0.150	0.050																																																				
b	gVSS/gVSS · d	0.120	0.170	0.170																																																				
fd	unitless	0.150	0.150	0.150																																																				
K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900																																																				
θ Value																																																								
μ <sub>max</sub>	unitless	1.070	1.072	1.063																																																				
b	unitless	1.040	1.029	1.029																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000																																																				
(2) μ <sub>AOB</sub>	μ <sub>AOB</sub> = 0.3100 g/g · d = μ <sub>max, AOB</sub> [S <sub>NH<sub>4</sub></sub> / (S <sub>NH<sub>4</sub></sub> + K <sub>NH<sub>4</sub></sub> )] [S <sub>O</sub> / (S <sub>O</sub> + K <sub>O, AOB</sub> )] - b <sub>AOB</sub>																																																							
μ <sub>max, AOB, T</sub>	μ <sub>max, AOB, T</sub> = 0.9000 g/g · d = μ <sub>max</sub> * 1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900																																																							
b <sub>AOB, T</sub>	b <sub>AOB, T</sub> = 0.1700 = b * 1.029 <sup>(T-20)</sup> b at 20°C = 0.170																																																							
S <sub>NH<sub>4</sub></sub>	S <sub>NH<sub>4</sub></sub> = 1.0000 mg/l																																																							
DO	DO = 2.0000 mg/l																																																							
K <sub>O, AOB</sub>	K <sub>O, AOB</sub> = 0.5000 mg/l																																																							

**STP Process Calculation Supporting Report 12.2.3**

(2) Design SRT	SRT= 4.8387 day = $1/\mu_{AOB} \times SF$ ⇒ 5.0000 day
(3) Biomass production	
P <sub>X,VSS</sub>	938.111 kg/d = P <sub>X,bio</sub> +Q(nbVSS)
P <sub>X,TSS</sub>	1236.300 kg/d = P <sub>X,bio</sub> /0.85+Q(nbVSS)+Q(TSS <sub>0</sub> -VSS <sub>0</sub> )+5*Q*Al
S	S= 0.4507 mg/l = $K_s[1+b_H(SRT)]/[SRT(\mu_m-b_H)-1]$
b <sub>H</sub>	b <sub>H</sub> = 0.1200 = $b*1.04^{(T-20)}$ b at 20°C = 0.120
Y <sub>H</sub>	Y <sub>H</sub> = 0.4500 gVSS/g bCOD
μ <sub>m,T</sub>	μ <sub>m,T</sub> = 6.0000 g/g·d = $\mu_{max} * 1.04^{(T-20)}$ μ max at 20°C = 6.000
Y <sub>n</sub>	Y <sub>n</sub> = 0.150 gVSS/g Nox
NO <sub>x</sub>	NO <sub>x</sub> = 47.400 mg/l
P <sub>X,bio,VSS</sub>	P <sub>X,bio,VSS</sub> = 542.235 kg VSS/d = $Q \cdot Y_H(S_0-S)/[1+b_H(SRT)] + f_d \cdot b_H \cdot QY_H(S_0-S)SRT/[1+b_H(SRT)]$ + QY <sub>n</sub> (Nox)[2+bAOB(SRT)] 486.885 = $Q \cdot Y_H(S_0-S)/[1+b_H(SRT)]$ 43.820 = $f_d \cdot b_H \cdot QY_H(S_0-S)SRT/[1+b_H(SRT)]$ 11.530 = $QY_n(Nox)[1+b_{AOB}(SRT)]$
NO <sub>x</sub>	NO <sub>x</sub> = 47.311 mg/l = $TKN - Ne - 0.12P_{X,bio}/Q$
(4) Required Aeration Tank Volume	
V <sub>a</sub>	V <sub>a</sub> = 2,060 m <sup>3</sup>
τ	τ = 16.48 hr = V <sub>a</sub> /Q × 24 ⇒ 18.00 hr
X <sub>VSS</sub> · V <sub>a</sub>	X <sub>VSS</sub> · V <sub>a</sub> = 4,691 kg VSS = P <sub>X,VSS</sub> · SRT
X <sub>TSS</sub> · V <sub>a</sub>	X <sub>TSS</sub> · V <sub>a</sub> = 6,181 kg TSS = P <sub>X,TSS</sub> · SRT
F/M	F/M= 0.224 kgBOD/kgMLVSS
FractionVSS	FractionVSS= 0.759
MLVSS	MLVSS= 2276 mg/L
(5) BODloading	BODloading= 0.510 kg/m <sup>3</sup> ·d
(6) Observed Yield	
Y <sub>obs,TSS</sub>	Y <sub>obs,TSS</sub> = 1.178 gTSS/gBOD
Y <sub>obs,VSS</sub>	Y <sub>obs,VSS</sub> = 0.894 gVSS/gBOD
bCODremoved	bCODremov= 1,731 kg/d
(7) effluent NO <sub>2</sub> -N	NO <sub>2</sub> -N= 0.2315 mg/l = $K_s[1+b_{NOB}(SRT)]/[SRT(\mu_{NOB}-b_{NOB})-1]$
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700 = $b*1.029^{(T-20)}$ b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 1.0000 g/g·d = $\mu_{max} * 1.04^{(T-20)}$ μ max at 20°C = 1.000
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.6897 g/g·d = $\mu_{max,NOB}[S_0/(S_0+K_{O2,NOB})]$
	S <sub>0</sub> = 2.000 mg/l
	K <sub>O2,NOB</sub> = 0.900 mg/l
(8) effluent NH <sub>4</sub> -N	NH <sub>4</sub> -N= 0.5286 mg/l = $K_s[1+b_{NOB}(SRT)]/[SRT(\mu_{NOB}-b_{NOB})-1]$
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700 = $b*1.029^{(T-20)}$ b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 0.9000 g/g·d = $\mu_{max} * 1.072^{(T-20)}$ μ max at 20°C = 0.900
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.7200 g/g·d = $\mu_{max,NOB}[S_0/(S_0+K_{O2,NOB})]$
	S <sub>0</sub> = 2.000 mg/l
	K <sub>O2,NOB</sub> = 0.500 mg/l
(9) Ratio of Return Sludge	8,000·Rr/(1+Rr)= 3,000 mg/L 3,000/(8,000-3,000)= 0.60 Rr = 0.60

**STP Process Calculation Supporting Report 12.2.3**

[3] Design for Nitrification and Denitrification Process																					
(1) Active biomass concentration	$X_b = \frac{Q \cdot (SRT) \cdot V \cdot Y_H \cdot (S_0 - S)}{1 + b_H(SRT)}$ = 1,181.47 mg/l																				
(2) IR ratio	$IR = \frac{NOx}{Ne} - 1.0 - R$ = 3.66																				
(3) The amount of NO3-N fed to the anoxic tank	$Nox\ feed = (IR + R) \cdot Q \cdot Ne$ = 114,931.83 kg/d																				
(4) The anoxic tank volume	$V_{nor} = 206\ m^3 = V_a \times 10\%$ $V_{nor} = 625\ m^3 \quad \tau_{DN} = 5.000\ h$																				
(5) F/M <sub>b</sub>	F/M <sub>b</sub> = 1.42 g/g · d																				
(6) Fraction of rbCOD	40.00% = rbCOD/bCOD																				
<table border="1"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b0</th> <th>b1</th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>		Percent rdCOD(%)	SDNR equation coefficients		b0	b1	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162
Percent rdCOD(%)	SDNR equation coefficients																				
	b0	b1																			
10	0.186	0.078																			
20	0.213	0.118																			
30	0.235	0.141																			
40	0.242	0.152																			
50	0.270	0.162																			
(8) SDNR <sub>b</sub>	$SDNR_b = 0.296\ g/g \cdot d = b_0 + b_1[\ln(F/M_b)]$ $b_0 = 0.242$ $b_1 = 0.152$																				
(8) SDNR	$SDNR = 0.110\ g/g \cdot d = SDNR_b(MLVSS_b/MLVSS)$ $SDNR_{adj} = 0.212\ g/g \cdot d = SDNR_i - 0.029 \ln(F/M_b) - 0.012 \quad IR=3-4$ $= SDNR_i - 0.0166 \ln(F/M_b) - 0.078 \quad IR=2$ $SDNR_t = 0.296\ g/g \cdot d = SDNR_b \cdot \theta^{(4-20)} \quad \theta = 1.026$																				
(9) NO <sub>r</sub>	$NO_r = 156,297.92\ kg/d = N_{nox} \cdot SDNR \cdot X_b$ $> Nox\ feed = 114,932\ kg/d$																				
(10) Alkalinity to be added to maintain pH7	-108.33 mg/l Influent Alk 380.00 mg/l Alk used 338.44 mg/l = 7.14 × Nox Alk produced 136.77 mg/l = 3.57 × (NOx - NO <sub>x,e</sub> ) Alk to maint 70.00 mg/l																				
[4] Design of Phosphorous Removal Process																					
(1) Removal T-P	3.13 mg/l																				
P in waste sludge	px = 1.00%																				
Generated waste sludge	Px <sub>vss</sub> = 938.111 kg/d																				
Rwmoval Phosphorus	9.38111408 kg/d																				
(2) Effluent T-P without Al	3.87 mg/l																				
(3) Required Al to initial soluble phosphorous ratio	1.00 mol/mol																				
(4) Required Al dosing rate	3.48 mg/l as Al																				
	42.98 mg/l as crystal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> · 18H <sub>2</sub> O																				
(5) Required Aluminium Sulphate	128.93 kg/d																				
(6) Required Aluminium Sulphate sol 10%	1.23 m <sup>3</sup> /d																				
	51.16 L/H																				
(7) Additional sludge	52.27 kg/d																				

**STP Process Calculation Supporting Report 12.2.3**

<b>[5] Reactor</b>																																																																				
(1) Total volume of Aeration Basins	$V_A = Q \cdot \theta_a / 24$ = 2,250 m <sup>3</sup>																																																																			
(2) Total volume of Anoxic Basins	$V_{DN} = Q \cdot \theta_{DN} / 24$ = 625 m <sup>3</sup>																																																																			
	<table border="1"> <thead> <tr> <th rowspan="2">Item</th> <th rowspan="2">Volume required</th> <th colspan="2">Retention Time required</th> <th rowspan="2">Ratio of Volume</th> </tr> <tr> <th>Summer</th> <th>Winter</th> </tr> </thead> <tbody> <tr> <td>unit</td> <td>m<sup>3</sup></td> <td>hour</td> <td>hour</td> <td></td> </tr> <tr> <td>Anaerobic</td> <td><math>V_{AN}</math></td> <td>190</td> <td>1.50</td> <td>1.50</td> <td>0.30</td> </tr> <tr> <td>Anoxic</td> <td><math>V_{DN}</math></td> <td>625</td> <td>5.00</td> <td>5.00</td> <td>1.00</td> </tr> <tr> <td>Aerobic</td> <td><math>V_A</math></td> <td>2,250</td> <td>18.00</td> <td>18.00</td> <td>3.60</td> </tr> <tr> <td>Total</td> <td>V</td> <td>3,065</td> <td>24.50</td> <td>24.50</td> <td></td> </tr> </tbody> </table>	Item	Volume required	Retention Time required		Ratio of Volume	Summer	Winter	unit	m <sup>3</sup>	hour	hour		Anaerobic	$V_{AN}$	190	1.50	1.50	0.30	Anoxic	$V_{DN}$	625	5.00	5.00	1.00	Aerobic	$V_A$	2,250	18.00	18.00	3.60	Total	V	3,065	24.50	24.50																																
Item	Volume required			Retention Time required			Ratio of Volume																																																													
		Summer	Winter																																																																	
unit	m <sup>3</sup>	hour	hour																																																																	
Anaerobic	$V_{AN}$	190	1.50	1.50	0.30																																																															
Anoxic	$V_{DN}$	625	5.00	5.00	1.00																																																															
Aerobic	$V_A$	2,250	18.00	18.00	3.60																																																															
Total	V	3,065	24.50	24.50																																																																
<b>[6] Geometry</b>																																																																				
(1) Basin Dimensions	Width      Length      Depth      Basins 8.0            39.0            5.5            2																																																																			
Cross Section	8.0*5.5 = 44.0 m <sup>2</sup> /Basin																																																																			
Hantzsch Subtraction	= 1.0 m <sup>2</sup> /Basin																																																																			
after Subtraction	44.0-1.0 = 43.0 m <sup>2</sup> /Basin																																																																			
Total Volume	43.0*39.0 = 1,677 m <sup>2</sup> /Basin    3,354 m <sup>3</sup> /Total																																																																			
(2) Partition of Basin	<table border="1"> <thead> <tr> <th>Item</th> <th>unit</th> <th>Anaerobic</th> <th>Anoxic</th> <th>Aerobic</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Cross Section</td> <td>m<sup>2</sup></td> <td colspan="3">43.0</td> <td></td> </tr> <tr> <td>Length required</td> <td>m</td> <td>2.2</td> <td>7.3</td> <td>26.2</td> <td>35.6</td> </tr> <tr> <td>Volume required per Basin</td> <td>m<sup>3</sup></td> <td>95</td> <td>313</td> <td>1,125</td> <td>1,533</td> </tr> <tr> <td>Total Volume required</td> <td>m<sup>3</sup></td> <td>190</td> <td>625</td> <td>2,250</td> <td>3,065</td> </tr> <tr> <td>Actual Cross Section</td> <td>m<sup>2</sup></td> <td>43.0</td> <td>43.0</td> <td>43.0</td> <td></td> </tr> <tr> <td>Actual Length</td> <td>m</td> <td>3.0</td> <td>8.0</td> <td>28.0</td> <td>39.0</td> </tr> <tr> <td>Actual Volume per Basin</td> <td>m<sup>3</sup></td> <td>129</td> <td>344</td> <td>1,204</td> <td>1,677</td> </tr> <tr> <td>Actual Total Volume</td> <td>m<sup>3</sup></td> <td>258</td> <td>688</td> <td>2,408</td> <td>3,354</td> </tr> <tr> <td>Actual Ratio of Volume</td> <td></td> <td>0.38</td> <td>1.00</td> <td>3.50</td> <td></td> </tr> <tr> <td>Actual Retention Time</td> <td>hour</td> <td>2.06</td> <td>5.50</td> <td>19.26</td> <td>26.82</td> </tr> </tbody> </table>	Item	unit	Anaerobic	Anoxic	Aerobic	Total	Cross Section	m <sup>2</sup>	43.0				Length required	m	2.2	7.3	26.2	35.6	Volume required per Basin	m <sup>3</sup>	95	313	1,125	1,533	Total Volume required	m <sup>3</sup>	190	625	2,250	3,065	Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0		Actual Length	m	3.0	8.0	28.0	39.0	Actual Volume per Basin	m <sup>3</sup>	129	344	1,204	1,677	Actual Total Volume	m <sup>3</sup>	258	688	2,408	3,354	Actual Ratio of Volume		0.38	1.00	3.50		Actual Retention Time	hour	2.06	5.50	19.26	26.82	
Item	unit	Anaerobic	Anoxic	Aerobic	Total																																																															
Cross Section	m <sup>2</sup>	43.0																																																																		
Length required	m	2.2	7.3	26.2	35.6																																																															
Volume required per Basin	m <sup>3</sup>	95	313	1,125	1,533																																																															
Total Volume required	m <sup>3</sup>	190	625	2,250	3,065																																																															
Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0																																																																
Actual Length	m	3.0	8.0	28.0	39.0																																																															
Actual Volume per Basin	m <sup>3</sup>	129	344	1,204	1,677																																																															
Actual Total Volume	m <sup>3</sup>	258	688	2,408	3,354																																																															
Actual Ratio of Volume		0.38	1.00	3.50																																																																
Actual Retention Time	hour	2.06	5.50	19.26	26.82																																																															
<b>[7] Equipment</b>																																																																				
(1) Ras Pumps																																																																				
Ras Ratio	60%																																																																			
Required Capacity	3,000 m <sup>3</sup> /day × 60% / 24 / 2																																																																			
	= 38 m <sup>3</sup> /Hr ⇒ 40 m <sup>3</sup> /Hr																																																																			
Number	2 Work																																																																			
	2 Standby																																																																			
(2) Circulation Pumps																																																																				
Ras Ratio	366%																																																																			
Required Capacity	3,000 m <sup>3</sup> /day × 366% / 24 / 4																																																																			
	= 114 m <sup>3</sup> /Hr ⇒ 120 m <sup>3</sup> /Hr																																																																			
Number	4 Work																																																																			
	2 Standby																																																																			
(3) SAS Pumps																																																																				
Excess Sludge	163 m <sup>3</sup> /day																																																																			
Sludge withdraw	12 Times/day																																																																			
Running Time	0.5 Hr/Time																																																																			
Required Capacity	163 m <sup>3</sup> /day / 12 / 0.5 / 2																																																																			
	= 13.56 m <sup>3</sup> /Hr ⇒ 14 m <sup>3</sup> /Hr																																																																			
Number	2 Work																																																																			
	2 Standby																																																																			

E-3 Process Cal. EA&al 3MLD Herohalli Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

(4) Alum Solution Tank										
Number	2	W	+	0	S					
Alum concentration as crystal	10	%								
Gravity of dissolved dechlorine	1.05									
Required solution volume	128.93	kg / d		×	100	/	10	/	1.05 / 1000	
	=	1.23			m3/d					
Volume of Tank	1.0				m3/tank					
Total Volume of Tanks	2.0				m3		(Duration=	1.63	day)	
(5) Mixer for Alum Solution Tank										
Number	2	W	+	0	S					
(6) Alum Dosing Pump										
Number	2	W	+	1	S					
Capacity	1.23	m3/d /		24	×	1000	/	2	×	2
	51.16	l/h/unit		⇒	60	l/h/unit				

**STP Process Calculation Supporting Report 12.2.3**

<b>6. Air Requirement at Average Flow</b>	
[1] Design Condition	
(1) AOR	AOR = 1,298 kg/day = 54.1 kg/h
Q <sub>in</sub> : Design Average Flow m <sup>3</sup> /d	3,000
Inlet bCOD : S <sub>0</sub>	578 mg/l
S=	0.451 mg/l
Nox=	47.400 mg/l
P <sub>X,bio</sub> =	530.7 kg VSS/d does not include nitrifying bacteria
R <sub>0</sub> =	R <sub>0</sub> = Q(S <sub>0</sub> -S-k(Nox-NOx))-1.42P <sub>X,bio</sub> +4.57Q·NOx
R <sub>0</sub> =	1,298 kg O <sub>2</sub> /d
k=	2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{\text{AOR} \times C_s \cdot a \times 1.024^{20-T}}{\alpha \times F (\beta \cdot C_{sW}/C_s \cdot (P_b/P_a)a - C_A)}$
	C <sub>s</sub> : Saturated DO at sea level and 20 °C 9.09 mg/L
	C <sub>sW</sub> : Saturated DO at sea level and operating Temperature 9.09 mg/L at 20 °C
	20-T : 0.0 1.024 <sup>20-T</sup> : 1.0000
	C <sub>A</sub> : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1+0.40D <sub>j</sub> /P <sub>a</sub> 1.19357
	D <sub>j</sub> : Tank Liquid Depth 5.00 m
	P <sub>a</sub> : Standard absolute pressure at s 10.332 m
	P <sub>b</sub> : Absolute pressure at Plant Site Elevation m
	P <sub>b</sub> /P <sub>a</sub> : exp[-gM(z <sub>b</sub> -z <sub>a</sub> )/R*T] 0.900
	g : Acceleration due to Gravity 9.80665 m/s <sup>2</sup>
	M : Mole of Air 28.97 kg/kg-mole
	z <sub>b</sub> : Plant Site Elevation 900 m
	z <sub>a</sub> : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 293.15 Kelvin
	α : relative Transfer Rate to clean Water 0.65
	β : relative DO Saturation to clean Water 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{14,082}{4.2591} = 3,306.30 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Standard O <sub>2</sub> required at Field Conditions per Basin =	1,653 kg/day
(5) SOTE for the above Effective Aeration Depth	28.0 %
(6) Fraction of O <sub>2</sub> in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	15%
(9) Air required at Field Conditions per Basins	= 24,313 m <sup>3</sup> /day = 1,013.1 m <sup>3</sup> /hr



E-3 Process Cal. EA&al 3MLD Herohalli Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

[2] Equipment				
(1) Air Blower				
Number	2	W	+	1 S
Required Capacity	1013.1	m <sup>3</sup> /Hr·Basin	/	1 unit/Basin
	= 1013.1	m <sup>3</sup> /h	⇒	1000 m <sup>3</sup> /h /Unit
Pressure	65	kPa		
Safety Factor	10	%		
Heat capacity ratio	1.4			
Atmospheric pressure at site elevation	91.234	kPa		
Total inlet pressure	89.234	kPa		
Volume rate of flow at inlet point	18.920	m <sup>3</sup> /min		
Total discharge pressure	156.234	kPa		
Overall adiabatic efficiency	0.65			
Inlet air temperature (min.)	15	°C		
Shaft power	26.751	kW		
Rated Output of Motor	29.426	kW	⇒	30 kW

E-3 Process Cal. EA&al 3MLD Herohalli Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>7. Final Clarifire</b></p>									
<p>[1] <b>Design Condition</b></p>									
<p>(1) Design Wastewater Flow</p>	<p>Q= 3,000 m<sup>3</sup>/day</p>								
<p>(2) Water Temperature</p>	<p>T= 20.0 °C</p>								
<p>(3) MLSS</p>	<p>X<sub>ef</sub>= 3,000 mg/l</p>								
<p>(4) SVI</p>	<p>SVI= 300</p>								
<p>(5) Sedimentation Velocity</p>	$v = 4.899 \times 10^6 \cdot T^{(0.954)} \cdot X_{ef}^{(-1.354)} \cdot SVI^{(-0.77)}$ $= 4.899 \times 10^6 \cdot 20.0^{0.954} \cdot 3,000^{-1.354} \cdot 150^{-0.770}$ $= 20.7 \text{ m/day}$								
<p>(6) Surface Overflow Rate required</p>	$S' = v / (1.5 \cdot 1) = \frac{20.7}{(1.5 \cdot 1.0)} = 13.8 \text{ m}^3/\text{m}^2 \cdot \text{day}$ $\rightarrow 12.0 \text{ m}^3/\text{m}^2 \cdot \text{day}$								
<p>[2] <b>Geometry</b></p>									
<p>(1) Surface Area required</p>	$A = 3,000 / 12.0 = 250 \text{ m}^2$								
<p>(2) Demensions</p>	<table style="margin-left: auto; margin-right: auto;"> <tr> <td style="text-align: center;">Diameter</td> <td style="text-align: center;">Depth</td> <td style="text-align: center;">Basin</td> </tr> <tr> <td style="text-align: center;"><b>13.0</b></td> <td style="text-align: center;"><b>3.5</b></td> <td style="text-align: center;"><b>2</b></td> </tr> </table>			Diameter	Depth	Basin	<b>13.0</b>	<b>3.5</b>	<b>2</b>
Diameter	Depth	Basin							
<b>13.0</b>	<b>3.5</b>	<b>2</b>							
<p>(3) Actual Surface Area</p>	$S = 13.0^2 \cdot \frac{3.14}{4} \cdot 2.0 = 265 \text{ m}^2$								
<p>(4) Surface Overflow Rate</p>	$S = 3,000 / 265 = 11.3 \text{ m}^3/\text{m}^2 \cdot \text{day}$								

E-3 Process Cal. EA&al 3MLD Herohalli, Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<b>8. Chlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Flow      3,000    m <sup>3</sup> /day      125.00    m <sup>3</sup> /h Peak Flow            7,500    m <sup>3</sup> /day      312.50    m <sup>3</sup> /h
(2) Contact Time	30    min
(3) Type of Chlorine	Cl <sub>2</sub> -GAS
(4) Design Chlorine Dosage Rate	10    mg/L
(5) Required Chlorine per day	Average Daily Flow    /    1000    ×      Design Chlorine Dosage Rate =    30.0    kg/d =    1.25    kg/h
<b>[2] Chlorination Contact Tank</b>	
(1) Volume required	Average Daily Flow    /    1440    ×      Contact Time =    62.5    m <sup>3</sup>
(2) Nos. of lanes	3    lanes
(3) Width of lane	1.50    m
(4) Length of lane	10.00    m
(5) Side Water Depth	1.50    m
(6) Nos. of Tanks	1    tank
(7) Total Width of Tank	5.30    m Approx..
(8) Average Velocity	Decant Flow            /    3600    /      Width    /      Depth =    125.00    /    3600    /    1.50    /    1.50 =    0.015    m/sec
(9) Total Volume	Width    ×      Length    ×      Depth    ×      Nos. of lanes    ×      Nos. of Tanks =    1.5    m    ×    10.0    m    ×    1.5    m =    68    m <sup>3</sup> >    62.5    m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Chlorine Dosing Condition	
Operation Dosage Rate -1	DC1      1 mg/L    10 mg/L
Average Dosage Rate -1	DC2      10 mg/L
(2) Chlorine Cylinder	
Type	-      Cylindrical Convexsd Container
Cylinder Capacity	Cc      928 kg/cylinder
Average Dosage Rate -1	q1      Chlorine -1 : Q <sub>T-D</sub> × DC2 × 10 <sup>-6</sup> × 10 <sup>3</sup> =    30 kg/day
Storage day	T      More than      15 days
Required Storage Capacity	EC1      D × T =      450 kg
Unit Number	EN1      EC1 / Cc =      0.5 cylinders
Maximum Operation Numbers	Vr1      ##### @ 20 <sup>o</sup> C Standard temperature
Cl <sub>2</sub> -Gas Volatilize Rate	DC1      10 mg/L, Q <sub>T-D</sub> × q3 × 10 <sup>-3</sup> / 24 =      #####
Maximum Dosing Rate	EN2      DC1 / Vr1 =      0.4sets
Operation Numbers	
(3) Chlorinator	
Type	Solution Feed Vacuum Type
Number	1    W    +    1    S
Operation Dosage Rate -1	Dq1    Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 3    kg/day to    75    kg/day
Required Dosage Rate	Chlorine -1 : Dq1 / (EN1 × 24) = Minimum                      Maximum 0.13    kg/hr                      3.1    kg/hr

E-3 Process Cal. EA&al 3MLD Herohalli, Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

(4) Chlorine Booster Pump	
Type	Branchy on the water supply pipe
Water Demand	Water requiamet for mixsed Chlori
Chlorinator Discharge	(kg/hr) 1.0 1.5 2.0 2.5 3.0 4.0
Water Demand	(L/min) 15 20 25 30 35 40
Chlorinator Discharge	(kg/hr) 5.0 6.0 10.0 50.0 100.0 200.0
Water Demand	(L/min) 45 50 60 300 600 1,200
Water requiamet	-
For Chlorin	Qp1 Maximum dosage rate 3.1 kg/hr therefore 35 L/min
Booster Pump Type	Single suction volute pump
Number	1 W + 1 S
<b>9. Dechlorination</b>	
[1] Design Condition	
(1) Design Flow Rate	Average Daily Flow 3,000 m <sup>3</sup> /day
(2) Contact Time	10 min
(3) Type of Dechlorine	Sodium Thiosulfate ( Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 5H <sub>2</sub> O )
(4) Free Residual Chlorine	1.0 mg/L assumed value
(5) Consumption per day	Average Daily Flow / 1000 × Free Residual Chlorine × 1.19 × 2 (safety factor) = 7.1 kg/d = 0.30 kg/h
<b>9. Dechlorination</b>	
[1] Design Condition	
(1) Design Flow Rate	Average Daily Flow 3,000 m <sup>3</sup> /day
(2) Contact Time	10 min
(3) Type of Dechlorine	Sodium Thiosulfate ( Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 5H <sub>2</sub> O )
(4) Free Residual Chlorine	1.0 mg/L assumed value
(5) Consumption per day	Average Daily Flow / 1000 × Free Residual Chlorine × 1.75 × 1.5 (safety factor) = 7.88 kg/d = 0.328 kg/h
[2] Dechlorination Contact Tank	
(1) Volume required	Average Flow Rate / 60 × Contact Time = 20.8 m <sup>3</sup>
(2) Width of lane	5.30 m
(3) Length of lane	3.00 m
(4) Side Water Depth	1.50 m
(5) Nos. of Tanks	1 tank
(6) Total Volume	Width × Length × Depth = 5.3 m × 3.0 m × 1.5 m = 24 m <sup>3</sup> > 20.8 m <sup>3</sup>

E-3 Process Cal. EA&al 3MLD Herohalli, Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

<b>[3] Equipment</b>	
(1) Dechlorine Solution Tank	
Number	1 W + 0 S
Dechlorine concentration	10 %
Gravity of dissolved dechlorine	1.10
Required solution volume	$7.88 \text{ kg/d} \times 100 / 10 / 1.10 / 1000$
	= 0.07 m <sup>3</sup> /d
Volume of Tank	0.2 m <sup>3</sup> /tank
Total Volume of Tanks	0.2 m <sup>3</sup> (Duration= 2.79 day)
(2) Mixer for Dechlorine Solution Tank	
Number	1 W + 0 S
(3) Dechlorine Dosing Pump	
Number	1 W + 1 S
Capacity	$0.18 \text{ m}^3/\text{d} / 24 \times 1000 / 1$
	7.46 l/h/unit $\Rightarrow$ 7.5 l/h/unit

E-3 Process Cal. EA&al 3MLD Herohalli, Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<p><b>10. Centrifuge</b></p> <p><b>[1] Design Condition</b></p> <p>(1) Type of Dewatering</p> <p>(2) Generated Sludge</p> <p>(3) Design Polyelectrolyte Dosage</p> <p>(4) Volume of Thickend Sludge</p> <p>(5) Consistency of Dewatered Sludge</p> <p>(6) Operation Time</p> <p><b>[2] Volume of Centrifuges</b></p> <p><b>[3] Dewatered Solids</b></p> <p><b>[4] Dewatered Cake Volume</b></p> <p><b>[5] Polyelectrolyte</b></p> <p>(1) Design Polyelectrolyte Dosage</p> <p>(2) Required Polyelectrolyte</p> <p>(3) Dissolving concentration</p> <p>(4) Volume of Polyelectrolyte solution</p>	<p>Centrifuge                      1,301 kg/day</p> <p>Polyelectrolyte 5 kg/t-DS·day</p> <p>162.7 m<sup>3</sup>/day</p> <p>82 %</p> <p>12 hours/day (6 days per week)</p> <p><u>Digested Solids</u>                      Operation Time × No. × Operation/week  <math display="block">= \frac{162.7}{12 \times 1} \times \frac{7}{6} = 15.8</math>                     → 16 m<sup>3</sup>/hour</p> <p>Digested Sludge × ( 1 + Injection Rate)                      = 1,301 × ( 1 + 0.0050 )                      = 1,308 kg/day</p> <p>Dewatered Solids × <math>\frac{100}{100 - \frac{Moisture\ Content}{7}}</math>                      × <math>\frac{6\ days\ per\ week}{6}</math>  <math display="block">= 1,308 \times \frac{100}{100 - 82} \times \frac{7}{6}</math>                     = 8.48 t/day                      apparent specific gravity 1.00  <math display="block">\frac{8.48}{1.0} = 8.5\ m^3/day</math></p> <p>Polyelectrolyte 5 kg/t-DS·day                      6.51 kg/day                      0.20 %                      3.25 m<sup>3</sup>/day</p>
<p><b>[6] Equipment</b></p> <p>(1) Centrifuge</p> <p>Capacity</p> <p>Number</p> <p>(2) Centrifuge Feed Pumps</p> <p>Capacity</p> <p>Number</p> <p>(3) Polyelectrolyte Dosing Pumps</p> <p>Volume of Polyelectrolyte solution</p> <p>Operation Time</p> <p>Safety Factor</p> <p>Number</p> <p>Required Capacity</p> <p>Specification Capacity</p> <p>(4) Polyelectrolyte dosing System</p> <p>Tanks Dimensions</p> <p>Retention Time of Tanks</p> <p>Number</p>	<p>16 m<sup>3</sup>/hr</p> <p>1 W + 1 S</p> <p>16 m<sup>3</sup>/hr</p> <p>1 W + 1 S</p> <p>3.25 m<sup>3</sup>/day</p> <p>12 hours/day (6 days per week)</p> <p>1.5</p> <p>1 W + 1 S</p> <p><math>3.25\ m^3/day \times \frac{7}{6} \div 12 \div 1</math>                      = 0.32 m<sup>3</sup>/Hr</p> <p>0.32 m<sup>3</sup>/Hr × 1.5                      = 0.474 m<sup>3</sup>/Hr ⇒ 0.50 m<sup>3</sup>/Hr /Unit</p> <p>Width 1.5 m × Length 1.0 m                      × Depth 1.8 m × 2 (Freeboard 0.5m)                      = 5.4 m<sup>3</sup></p> <p><math>\frac{5.40\ m^3}{0.32\ m^3/Hr} \div 1</math>                      = 17.073 Hr</p> <p>2 W + 0 S</p>

E-3 Process Cal. EA&al 3MLD Herohalli, Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<b>11. Centrifuge Feed Sump</b>	
<b>[1] Design Condition</b>	
(1) Generated Thickend Sludge	1,301 kg/day
(2) Solids Consistency	0.80 %
(3) Volume of Thickened Sludge	$\begin{aligned} & \text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3} \\ = & 1,301 \times \frac{100}{0.80} \times 10^{-3} \\ = & 163 \text{ m}^3/\text{day} \\ = & 6.78 \text{ m}^3/\text{h} \end{aligned}$
(4) Sludge feed flow rate	16 m <sup>3</sup> /h × 1 = 16 m <sup>3</sup> /h
(5) Centrifuge Operation Time	12 hours/day ( 6 days per week)
<b>[2] Geometry</b>	
(1) Basin Dimensions	$\begin{aligned} & \text{Width } 4.0 \text{ m} \times \text{Length } 4.5 \text{ m} \\ & \times \text{Depth } 3.0 \text{ m} \times 2 \\ = & 108.0 \text{ m}^3 \end{aligned}$
<b>[3] Equipment</b>	
(1) Mixers for Centrifuge Feed Sumps	
Required Volume	108.0 m <sup>3</sup>
Number	1 W + 1 S

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Digestion Tank + Centrifugal Dewatering)

Table -1 Input Data

1. Calculation Manner	2	1:Premise that the quality of supernatants are same level removed with inlet sewage 2:Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency	2	1:Total Removal Ratio 2:Outlet Water Quality(input 1or2)
In case of 1 : input data		(%)
In case of 2 : input data	#REF!	(mg/l)
3. Selection of Excess Sludge Generation	2	1:Consideration of Solid Matter Only 2:Consideration of Converting of Solved BOD(input 1or2)
In case of 1 : input data (Sludge generation)		Sludge generation ratio per removal SS(%)
	a	0.4 T2=Q4·S4=(a·S <sub>BOD</sub> +b·S1-c·θ·XA)·Q3/10 <sup>6</sup> · (Excess sludge generation formula)
	b	0.9 a:Converting ratio of solved BOD(mgMLSS/mgBOD)
	c	0.05 b:Converting ratio of SS(mgMLSS/mgSS)
In case of 2 : input data	SBOD	234.50 c:Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)
	XA	3,000 S <sub>BOD</sub> :Solved BOD quality at inlet reactor
	θ	1 XA:MLSS concentration(mg/l)
		θ:Hydraulic retention time(day)


Table -2 Basic Conditions

Sewage Flow and Quality		Sludge Moisture and Recovery Ratio		Digestion Tank Conditions		Chemical Conditions for Dewatering	
· Inlet flow : Q <sub>0</sub> (m <sup>3</sup> /D)	3,000	· Primary sludge moisture ratio : W1(%)	0.0	· Removal ratio in primary tank : A2(%)	0.0	· Content of organics in thickened sludge : A6(%)	75.0
· Inlet quality : S <sub>0</sub> (mg/l)	450	· Excess sludge moisture ratio : W2(%)	99.2	· Recovery ratio in sludge thickener : A3(%)	100.0	· Digestion ratio : A7(%)	#REF!
· Total removal ratio : A1(%)	-	· Thickened sludge moisture ratio : W3(%)	99.2	· Recovery ratio in sludge digester : A4(%)	100.0	· Digestion gas generation : A8(Nm <sup>3</sup> /kgVS)	
· Effluent quality : S1(mg/l)	10.0	· Digested sludge moisture ratio : W4(%)	99.2	· Recovery ratio in dewatering : A5(%)	95.0		
· Sludge generation ratio per removal SS : S1(%)	-	· Dewatered sludge moisture ratio : W5(%)	82.0				

Table -3 Material Balance Calculation

	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	手入力(要取束)	16	17
Q(m <sup>3</sup> /day)	3,000	3,159	0	3,159	163	2,996	163	0	0	163	0	3	166	7	159	159		2,996	0
T(t·DS/day)	1,350	1,415	0.000	1,415	1,301	0.030	1,301	0.000	0.000	1,301	0.000	0.007	1,308	1,242	0.065	0.065	0.065	0.030	0.084
S(mg/l)	450	448	0	448	8,000	10	8,000	#DIV/0!	0	8,000	0	2,000	7,882	180,000	411	411		10	
X(T5/T0*100)	100	104.8	0.0	104.8	96.4	2.2	96.4	0.0	0.0	96.4	0.0	0.5	96.9	92.0	4.8	4.8		2.2	6.2

Figure -1 Material Balance Model




Calculation Formula						
· Q <sub>0</sub> =Input Data	· Q <sub>3</sub> =Q <sub>1</sub> -Q <sub>2</sub>	· Q <sub>6</sub> =T <sub>6</sub> *100/(100-W3)	· Q <sub>9</sub> =Q <sub>6</sub>	· Q <sub>12</sub> =Q <sub>9</sub> +Q <sub>11</sub>	· Q <sub>15</sub> =Q <sub>7</sub> +Q <sub>10</sub> +Q <sub>14</sub>	· Q <sub>5</sub> -1=Q <sub>5</sub> -Q <sub>11</sub>
· T <sub>0</sub> =Q <sub>0</sub> *S <sub>0</sub> *10 <sup>-6</sup>	· T <sub>3</sub> =T <sub>0</sub> *(100-A2)/100	· T <sub>6</sub> =(T <sub>2</sub> +T <sub>4</sub> )*A3/100	· T <sub>9</sub> =(T <sub>6</sub> -T <sub>8</sub> )*A4/100	· T <sub>12</sub> =T <sub>9</sub> +T <sub>11</sub>	· T <sub>15</sub> =T <sub>7</sub> +T <sub>10</sub> +T <sub>14</sub>	· T <sub>5</sub> -1=T <sub>5</sub> -T <sub>11</sub>
· S <sub>0</sub> =Input Data	· S <sub>3</sub> =T <sub>3</sub> *10 <sup>6</sup> /Q <sub>3</sub>	· S <sub>6</sub> =T <sub>6</sub> *10 <sup>6</sup> *(100-W3)/100	· S <sub>9</sub> =T <sub>9</sub> *10 <sup>6</sup> /Q <sub>9</sub>	· S <sub>12</sub> =T <sub>12</sub> *10 <sup>6</sup> /Q <sub>12</sub>	· S <sub>15</sub> =T <sub>15</sub> *10 <sup>6</sup> /Q <sub>15</sub>	· S <sub>5</sub> -1=S <sub>5</sub>
· Q <sub>1</sub> =Q <sub>0</sub> +Q <sub>15</sub>	· Q <sub>4</sub> =T <sub>4</sub> *100/(100-W2)	· Q <sub>7</sub> =(Q <sub>2</sub> +Q <sub>4</sub> )-Q <sub>6</sub>	· Q <sub>10</sub> =Q <sub>6</sub> -Q <sub>8</sub> -Q <sub>9</sub>	· Q <sub>13</sub> =T <sub>13</sub> *100/(100-W5)		
· T <sub>1</sub> =T <sub>0</sub> +T <sub>15</sub>	· T <sub>4</sub> =余剰汚泥発生式による	· T <sub>7</sub> =(T <sub>2</sub> +T <sub>4</sub> )-T <sub>6</sub>	· T <sub>10</sub> =T <sub>6</sub> -T <sub>8</sub> -T <sub>9</sub>	· T <sub>13</sub> =T <sub>12</sub> *A5/100		
· S <sub>1</sub> =T <sub>1</sub> *10 <sup>6</sup> /Q <sub>1</sub>	· S <sub>4</sub> =10 <sup>6</sup> *((100-W2)/100)	· S <sub>7</sub> =T <sub>7</sub> *10 <sup>6</sup> /Q <sub>7</sub>	· S <sub>10</sub> =T <sub>10</sub> *10 <sup>6</sup> /Q <sub>10</sub>	· S <sub>13</sub> =10 <sup>6</sup> *((100-W5)/100)		
· Q <sub>2</sub> =T <sub>2</sub> *100/(100-W1)	· Q <sub>5</sub> =Q <sub>3</sub> -Q <sub>4</sub> *(T <sub>3</sub> -T <sub>5</sub> )/T <sub>4</sub>	· Q <sub>8</sub> =0	· Q <sub>11</sub> =T <sub>10</sub> *A9/A10	· Q <sub>14</sub> =Q <sub>12</sub> -Q <sub>13</sub>		
· T <sub>2</sub> =T <sub>1</sub> -T <sub>3</sub>	· T <sub>5</sub> =Q <sub>5</sub> *S <sub>1</sub> /10 <sup>6</sup>	· T <sub>8</sub> =T <sub>6</sub> *A6*A7/10 <sup>4</sup>	· T <sub>11</sub> =Q <sub>11</sub> *S <sub>11</sub> /10 <sup>6</sup>	· T <sub>14</sub> =T <sub>12</sub> -T <sub>13</sub>		
· S <sub>2</sub> =10 <sup>6</sup> *((100-W1)/100)	· S <sub>5</sub> =S <sub>1</sub>	#REF!	· S <sub>11</sub> =10 <sup>4</sup> *A10	· S <sub>14</sub> =T <sub>14</sub> *10 <sup>6</sup> /Q <sub>14</sub>		



Material Balance Sheet SD4

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Sheet  
[3MLD STP]



E-4 Process Cal. EA&al 6MLD Hosahalli, Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**Design Condition**

Item	6MLD STP-TSPS			
(1) Design Flow for the year 2049	Flow Rate			
		m3/d	m3/h	m3/s
	Daily Average	10,000	417	0.116
	Daily Maximum	10,000	417	0.116
	Hourly Max. Peak factor 2.25	22,500	938	0.260
(1) Design Flow for the year 2034	Flow Rate			
		m3/d	m3/h	m3/s
	Daily Average	6,000	250	0.069
	Daily Maximum	6,000	250	0.069
	Hourly Max. Peak factor 2.5	15,000	625	0.174

**1. Inlet Chamber**

Item	6MLD STP-TSPS			
[1] Design Condition				
(1) Design Flow for the year 2049	Max Hourly	=	22,500	m3/d
		=	0.260	m3/sec
(2) Inlet Pipe				
Pipe Diameter	•	×		
Gradient			%	
Roughness Coefficient	n=	0.013	(Manning Formula)	
Full Pipe Flow Rate			m3/s	
(3) Influent Water Level	+		m	
[2] Geometory				
(1) Number of Basins	1	Basin		
(2) Depth of Basin	0.600	m	Approx.	
(3) Width of Basin	2.100	m	Approx.	
(4) Length of Basin	2.500	m	Approx.	
(5) Volume required of Basin	0.600	×	2.100	×
			2.500	=
				0.5
				m3
(6) Retention Time	0.600	×	2.100	×
			2.500	/
				0.260
				×
				1
	=	12.12	sec	
(7) Basin Demensions	Width	2.100	m	×
				Length
				2.500
				m
	×	Depth	0.600	m

E-4 Process Cal. EA&al 6MLD Hosahalli, Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**2. Coarse Screen Channel**

Item	6MLD STP-TSPS					
[1] Geometry						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Width	0.400	m				
Height	0.600	m				
Floor Level	+	5.000	m			
Bottom	+	0.000	m			
Influent Water Level	+	0.400	m			
Velocity	0.260	/		0.400	/	0.400 / 2
where Design Flow for the year 2049	=	0.813	<	1.000	m/sec	OK
Velocity	0.174	/		0.400	/	0.400 / 1
where Design Flow for the year 2034	=	1.088	<	1.000	m/sec	OK
(2) Screen Channel						
Number	2.0	Main	+	1.0	Bypass	
Width	0.800	m				
Side Water Depth	0.500	m				
Velocity	0.260	/		0.800	/	0.500 / 2
where Design Flow for the year 2049	=	0.325	≅	0.450	m/sec	OK
Velocity	0.174	/		0.800	/	0.500 / 1
where Design Flow for the year 2034	=	0.435	<	0.450	m/sec	OK
(3) Channel Dimensions	Width	0.8	m	×	Length	8.5 m
				×	SWD	0.5 m
[3] Equipment						
(1) Inlet Gate						
Number	3	Units				
Dimension	Width	0.4	m	×	Height	0.6 m
Design Water Level		m				
(2) Coarse Screens (Main Channel)						
Number	2	W	+	0	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	0.8	m				
Width of side plate	50	mm				
Side Water Depth	0.5	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.260	/		0.700	/	0.450 / 2
	× (	20	+	9	)/	20
	=	0.598	≅	0.800	m/sec	OK
Velocity through screen	0.174	/		0.700	/	0.450 / 1
where Design Flow for the year 2034	× (	20	+	9	)/	20
	=	0.801	<	0.800	m/sec	OK
(3) Coarse Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	0.8	m				
Side Water Depth	0.5	m				
Velocity through screen	0.260	/		0.800	/	0.500 / 2
where Design Flow for the year 2049	× (	20	+	9	)/	20
	=	0.471	<	0.800	m/sec	OK
Velocity through screen	0.174	/		0.800	/	0.500 / 1
where Design Flow for the year 2034	× (	20	+	9	)/	20
	=	0.631	<	0.800	m/sec	OK

E-4 Process Cal. EA&al 6MLD Hosahalli, Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**3. Raw Sewage Sump**

Item	6MLD STP-TSPS	
[2] Geometory		
(1) Raw Sewage Sump		
Number	1	Basin
Dia	9.00	m
Pump Operating Depth	1.000	m
Retention Time whe Design Flow for the year 2049	$( \frac{9.00^2 \times \pi}{4} \times 1.000 ) / 0.260$	$/ 60$ = 4.08 > 3.75 min (=minimum time of one pump cycle) OK
Retention Time whe Design Flow for the year 2034	$( \frac{9.00^2 \times \pi}{4} \times 1.000 ) / 0.174$	$/ 60$ = 6.09 > 3.75 min (=minimum time of one pump cycle) OK
High Water Level	+ 0.000	m
Pump Off Level	+ -1.000	m
[3] Equipment		
(1) Sewage Pumps 1		
Number	2 W	+ 1 S
Bore Diameter	250	mm
Discharge Flow : Q whe Design Flow for the year 2034	$0.174 \times 3600$	$/ 2.0$ = 313 $\Rightarrow$ 315 m <sup>3</sup> /Hr
Total Head	15.0	m
(2) Sewage Pumps 2		
Number	W	+ S
Bore Diameter	mm	
Discharge Flow : 0.5 whe Design Flow for the year 2034		$\Rightarrow$ m <sup>3</sup> /Hr
Total Head	m	

E-4 Process Cal. EA&al 6MLD Hosahalli, Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

Item	6MLD STP																																														
<b>1. STP Design Condition</b>																																															
(1) Design Flow Rate	<table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th></th> <th>m<sup>3</sup>/d</th> <th>m<sup>3</sup>/h</th> <th colspan="3">m<sup>3</sup>/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td>6,000</td> <td>250.00</td> <td colspan="3">0.069</td> </tr> <tr> <td>Max Daily</td> <td>6,000</td> <td>250.00</td> <td colspan="3">0.069</td> </tr> <tr> <td>Max Hourly Peak factor 2.5</td> <td>15,000</td> <td>625.00</td> <td colspan="3">0.174</td> </tr> </tbody> </table>							m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s			Average Daily	6,000	250.00	0.069			Max Daily	6,000	250.00	0.069			Max Hourly Peak factor 2.5	15,000	625.00	0.174																			
	m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s																																												
Average Daily	6,000	250.00	0.069																																												
Max Daily	6,000	250.00	0.069																																												
Max Hourly Peak factor 2.5	15,000	625.00	0.174																																												
(2) Design Water Quality	<p style="text-align: right;">Unit: mg/L</p> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th colspan="2">TP</th> </tr> <tr> <th>NH<sub>4</sub>-N</th> <th>Org-N</th> <th>NOx-N</th> <th>D-P</th> <th>P-P</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td>350</td> <td>800</td> <td>450</td> <td>45.5</td> <td>17.5</td> <td>7</td> <td>5</td> <td>2</td> </tr> <tr> <td>Outlet</td> <td>10</td> <td>50</td> <td>10</td> <td>1</td> <td>0</td> <td>9</td> <td>1</td> <td>1</td> </tr> <tr> <td>Removal rate</td> <td>97.1%</td> <td>93.7%</td> <td>97.8%</td> <td colspan="3">85.7%</td> <td colspan="2">71.4%</td> </tr> </tbody> </table>							BOD	COD	SS	T-N			TP		NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P	Inlet	350	800	450	45.5	17.5	7	5	2	Outlet	10	50	10	1	0	9	1	1	Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%	
	BOD	COD	SS	T-N							TP																																				
				NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P																																							
Inlet	350	800	450	45.5	17.5	7	5	2																																							
Outlet	10	50	10	1	0	9	1	1																																							
Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%																																								
<b>2. Inlet Chamber</b>																																															
<b>[1] Design Condition</b>																																															
(1) Design Flow Rate	Max Hourly	=	15,000	m <sup>3</sup> /day																																											
		=	0.174	m <sup>3</sup> /sec																																											
<b>[2] Geometry</b>																																															
(1) Number of Basins	1	Basin																																													
(2) Depth of Basin	1.000	m																																													
(3) Width of Basin	2.100	m																																													
(4) Length of Basin	1.500	m																																													
(5) Volume required of Basin	1.000	×	2.100	×	1.500	=	1.4	m <sup>3</sup>																																							
(6) Retention Time	1.000	×	2.100	×	1.500	∕	0.174	×	1																																						
	=	18.10	sec																																												
(7) Basin Dimensions	Width	2.100	m	×	Length	1.500	m																																								
	×	Depth	1.000	m																																											

E-4 Process Cal. EA&al 6MLD Hosahalli, Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Wastewater Flow	$\begin{aligned} \text{Max Hourly} &= 15,000 \text{ m}^3/\text{d} \\ &= 0.174 \text{ m}^3/\text{sec} \end{aligned}$
[2] Geometory	
(1) Inlet Gate	
Number	1 Main + 1 Bypass
Width	0.400 m
Height	0.600 m
Floor Level	+ 2.000 m
Bottom	+ 0.000 m
Influent Water Level	+ 0.500 m
Velocity	$\begin{aligned} &0.174 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 1 \\ = &0.870 \text{ } \div \quad 1.000 \text{ m/sec} \end{aligned}$
(2) Screen Channel	
Number	1 Main + 1 Bypass
Width	0.800 m
Side Water Depth	0.500 m
Velocity	$\begin{aligned} &0.174 \text{ } \swarrow \quad 0.800 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 1 \\ = &0.435 \text{ } \div \quad 0.450 \text{ m/sec} \end{aligned}$
(3) Channel Dimensions	$\begin{aligned} \text{Width} &0.8 \text{ m} \times \text{Length} \quad 6.0 \text{ m} \\ &\times \text{SWD} \quad 0.5 \text{ m} \quad (\text{Freeboard } 0.3\text{m}) \end{aligned}$
[3] Equipment	
(1) Inlet Gate	
Number	1 W + 1 S
Dimension	Width 0.4 m × Height 0.60 m
Design Water Level	2.00 m
(2) Fine Screens (Main Channel)	
Number	1 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	0.8 m
Width of side plate	50 mm
Side Water Depth	0.5 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	$\begin{aligned} &0.174 \text{ } \swarrow \quad 0.700 \text{ } \swarrow \quad 0.450 \text{ } \swarrow \quad 1 \\ &\times \left( \frac{6}{6} + \frac{2}{6} \right) \\ = &0.737 < 0.800 \text{ m/sec} \end{aligned}$
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	0.8 m
Side Water Depth	0.5 m
Velocity through screen	$\begin{aligned} &0.174 \text{ } \swarrow \quad 0.800 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 1 \\ &\times \left( \frac{20}{20} + \frac{9}{20} \right) \\ = &0.631 < 0.800 \text{ m/sec} \end{aligned}$

E-4 Process Cal. EA&aI 6MLD Hosahalli, Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<b>4. Grit Chamber</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Max Hourly = 15,000 m <sup>3</sup> /day = 0.174 m <sup>3</sup> /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0111 m/sec = 960 m <sup>3</sup> /m <sup>2</sup> /day
(4) Average Velocity	0.3 m/sec
<b>[2] Grit Chamber</b>	
(1) Surface Area required	0.174 / 0.0111 = 15.68 m <sup>2</sup>
(2) Number of Basins	1 S + 1 W
(3) Surface Area required/Basin	15.68 / 1 = 15.68 m <sup>2</sup>
(4) Length of Basin	15.68 ^0.5 = 4.0 m → 4.0 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.174 × 60 sec / 1 = 10.4 m <sup>3</sup>
(7) Depth required	10.4 / 4.0 / 4.0 = 0.653 m
(8) Basin Dimensions	Width 4.0 m × Length 4.0 m × Depth 0.7 m (Freeboard 0.3m)
(9) Retention Time	4 × 4.0 × 0.7 / 0.174 × 1 = 60.00 sec
(10) Surface Overflow Rate at Peak Flow	15,000 / 4.0 / 4.0 / 1 = 937.5 < 960 m <sup>3</sup> /m <sup>2</sup> /day
<b>[3] Parshall Flume</b>	
(1) Design Flow Rate	Q= 174,000 l/sec
(2) Throat width	W= 0.450 m
(3) Water depth Ha	Ha= ( Q / 2264 / W ) <sup>2/3</sup> Ha= 0.308 m
(4) Crest Level	+ 75.400 m ≐ Minimum water level at downstream channel
(5) Water level at the crest	+ 75.708 m
(6) Channel bottom level	+ m
(7) Upstream Channel width	1.500 m
(8) SWD of Upstream Channel	0.700 m
(9) Average velocity at upstream channel	0.166 m/sec
(10) Total Length of channel	10.000 m
<b>[4] Inlet Weir Gate</b>	
(1) Number	2 Units
(2) Weir Width	0.400 m
(3) Stroke	0.450 m
(4) Overflow Height	0.400 m
(5) Overflow Height (actual)	( 0.174 / 1.840 / 0.400 / 2 ) <sup>2/3</sup> = 0.241 < 0.400 m

**STP Process Calculation Supporting Report 12.2.3**

<b>5. Reactor</b>																																																								
<b>[1] Design Condition</b>																																																								
(1) Design Wastewater Flow	Q = 6,000 m <sup>3</sup> /day (summer) Q' = 6,000 m <sup>3</sup> /day (Winter)																																																							
(2) Design Sewage Quality																																																								
Inlet BOD	350 mg/l																																																							
Outlet BOD	10.0 mg/l																																																							
Inlet S-BOD	235 mg/l assumed as 67% of BOD																																																							
Inlet COD	800 mg/l																																																							
Inlet bCOD : S <sub>0</sub>	578 mg/l																																																							
Inlet nbCOD	223 mg/l																																																							
bCOD/BOD	1.65																																																							
Inlet S-COD : sCOD	271 mg/l																																																							
Inlet rbCOD	231 mg/l bCOD*40%																																																							
Inlet sbCOD	347 mg/l bCOD*60%																																																							
Outlet S-COD : nbsCODe	40 mg/l																																																							
Inlet nbpCOD : nbpCOD	183 mg/l = TCOD-bCOD-nbsCODe																																																							
Inlet SS	450 mg/l																																																							
Inlet VSS	383 mg/l assumed as 85% of TSS																																																							
: VSS <sub>COD</sub>	1.38 gCOD/gVSS = TCOD-sCOD/VSS																																																							
: nbVSS	131.96 gnbVSS/m <sup>3</sup> = nbpCOD/VSS <sub>COD</sub>																																																							
: iTSS	67.50 gnbVSS/m <sup>3</sup> = TSS-VSS																																																							
Inlet T-N	70 mg/l																																																							
Inlet TKN	70 mg/l																																																							
Inlet NH <sub>4</sub> -N	45 mg/l																																																							
Inlet T-P	7 mg/l																																																							
Inlet D-P	5 mg/l																																																							
Inlet Alkalinity as CaCO <sub>3</sub>	380 mg/l																																																							
Outlet Kjeldahl N	1.0 mg/l																																																							
Outlet NH <sub>4</sub> -N	1.0 mg/l																																																							
Outlet NO <sub>3</sub> -N	9.0 mg/l																																																							
Outlet T-P	2 mg/l																																																							
Outlet D-P	1 mg/l																																																							
(3) Water Temperature	T = 20.0 °C																																																							
(4) Safety Factor for Nitrogen	SF = 1.5																																																							
(5) Return Sludge Concentration	R <sub>s</sub> = 8,000 mg/l																																																							
(6) MLSS MLVSS	X <sub>TSS</sub> = 3,000 mg/l																																																							
(7) DO in the Reactor	2 mg/L																																																							
<b>[2] Design Value for perfect Nitrification of Nitrification Process</b>																																																								
(1) Activated sludge design kinwtic coefficients at 20°C																																																								
	<table border="1"> <thead> <tr> <th>Coefficient</th> <th>Unit</th> <th>COD oxidatio</th> <th>NH<sub>4</sub> oxidatio</th> <th>NO<sub>2</sub> oxidatio</th> </tr> </thead> <tbody> <tr> <td>μ<sub>max</sub></td> <td>gVSS/gVSS · d</td> <td>6.000</td> <td>0.900</td> <td>1.000</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>mg/L</td> <td>8.000</td> <td>0.500</td> <td>0.200</td> </tr> <tr> <td>Y</td> <td>gVSS/g substrate oxidized</td> <td>0.450</td> <td>0.150</td> <td>0.050</td> </tr> <tr> <td>b</td> <td>gVSS/gVSS · d</td> <td>0.120</td> <td>0.170</td> <td>0.170</td> </tr> <tr> <td>fd</td> <td>unitless</td> <td>0.150</td> <td>0.150</td> <td>0.150</td> </tr> <tr> <td>K<sub>O<sub>2</sub></sub></td> <td>mg/L</td> <td>0.200</td> <td>0.500</td> <td>0.900</td> </tr> <tr> <td>θ Value</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>μ<sub>max</sub></td> <td>unitless</td> <td>1.070</td> <td>1.072</td> <td>1.063</td> </tr> <tr> <td>b</td> <td>unitless</td> <td>1.040</td> <td>1.029</td> <td>1.029</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>unitless</td> <td>1.000</td> <td>1.000</td> <td>1.000</td> </tr> </tbody> </table> <p>Wastwater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF &amp; EDDY/AECOM)</p>	Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio	μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200	Y	gVSS/g substrate oxidized	0.450	0.150	0.050	b	gVSS/gVSS · d	0.120	0.170	0.170	fd	unitless	0.150	0.150	0.150	K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900	θ Value					μ <sub>max</sub>	unitless	1.070	1.072	1.063	b	unitless	1.040	1.029	1.029	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000
Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio																																																				
μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200																																																				
Y	gVSS/g substrate oxidized	0.450	0.150	0.050																																																				
b	gVSS/gVSS · d	0.120	0.170	0.170																																																				
fd	unitless	0.150	0.150	0.150																																																				
K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900																																																				
θ Value																																																								
μ <sub>max</sub>	unitless	1.070	1.072	1.063																																																				
b	unitless	1.040	1.029	1.029																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000																																																				
(2) μ <sub>AOB</sub>	μ <sub>AOB</sub> = 0.3100 g/g · d = μ <sub>max, AOB</sub> [S <sub>NH<sub>4</sub></sub> / (S <sub>NH<sub>4</sub></sub> + K <sub>NH<sub>4</sub></sub> )] [S <sub>O</sub> / (S <sub>O</sub> + K <sub>O, AOB</sub> )] - b <sub>AOB</sub>																																																							
μ <sub>max, AOB, T</sub>	μ <sub>max, AOB, T</sub> = 0.9000 g/g · d = μ <sub>max</sub> * 1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900																																																							
b <sub>AOB, T</sub>	b <sub>AOB, T</sub> = 0.1700 = b * 1.029 <sup>(T-20)</sup> b at 20°C = 0.170																																																							
S <sub>NH<sub>4</sub></sub>	S <sub>NH<sub>4</sub></sub> = 1.0000 mg/l																																																							
DO	DO = 2.0000 mg/l																																																							
K <sub>O, AOB</sub>	K <sub>O, AOB</sub> = 0.5000 mg/l																																																							



**STP Process Calculation Supporting Report 12.2.3**

(2) Design SRT	SRT= 4.8387 day = $1/\mu_{AOB} \times SF$ ⇒ 5.0000 day
(3) Biomass production	
P <sub>X,VSS</sub>	1876.223 kg/d = P <sub>X,bio</sub> +Q(nbVSS)
P <sub>X,TSS</sub>	2472.600 kg/d = P <sub>X,bio</sub> /0.85+Q(nbVSS)+Q(TSS <sub>0</sub> -VSS <sub>0</sub> )+5*Q*Al
S	S= 0.4507 mg/l = $Ks[1+b_H(SRT)]/[SRT(\mu_m-b_H)-1]$
b <sub>H</sub>	b <sub>H</sub> = 0.1200 = $b*1.04^{(T-20)}$ b at 20°C = 0.120
Y <sub>H</sub>	Y <sub>H</sub> = 0.4500 gVSS/g bCOD
μ <sub>m,T</sub>	μ <sub>m,T</sub> = 6.0000 g/g·d = $\mu_{max} * 1.04^{(T-20)}$ μ max at 20°C = 6.000
Y <sub>n</sub>	Y <sub>n</sub> = 0.150 gVSS/g Nox
NO <sub>x</sub>	NO <sub>x</sub> = 47.400 mg/l
P <sub>X,bio,VSS</sub>	P <sub>X,bio,VSS</sub> = 1084.470 kg VSS/d = $Q \cdot Y_H(S_0-S)/[1+b_H(SRT)] + f_d \cdot b_H \cdot QY_H(S_0-S)SRT/[1+b_H(SRT)] + QY_n(Nox)[2+b_{AOB}(SRT)]$ 973.771 = $Q \cdot Y_H(S_0-S)/[1+b_H(SRT)]$ 87.639 = $f_d \cdot b_H \cdot QY_H(S_0-S)SRT/[1+b_H(SRT)]$ 23.059 = $QY_n(Nox)[1+b_{AOB}(SRT)]$
NO <sub>x</sub>	NO <sub>x</sub> = 47.311 mg/l = $TKN - Ne - 0.12P_{X,bio}/Q$
(4) Required Aeration Tank Volume	
V <sub>a</sub>	V <sub>a</sub> = 4,121 m <sup>3</sup>
τ	τ = 16.48 hr = $V_a/Q \times 24$ ⇒ 18.00 hr
X <sub>VSS</sub> ·V <sub>a</sub>	X <sub>VSS</sub> ·V <sub>a</sub> = 9,381 kg VSS = P <sub>X,VSS</sub> ·SRT
X <sub>TSS</sub> ·V <sub>a</sub>	X <sub>TSS</sub> ·V <sub>a</sub> = 12,363 kg TSS = P <sub>X,TSS</sub> ·SRT
F/M	F/M= 0.224 kgBOD/kgMLVSS
FractionVSS	FractionVSS= 0.759
MLVSS	MLVSS= 2276 mg/L
(5) BODloading	BODloading= 0.510 kg/m <sup>3</sup> ·d
(6) Observed Yield	
Y <sub>obs,TSS</sub>	Y <sub>obs,TSS</sub> = 1.178 gTSS/gBOD
Y <sub>obs,VSS</sub>	Y <sub>obs,VSS</sub> = 0.894 gVSS/gBOD
bCODremoved	bCODremov= 3,462 kg/d
(7) effluent NO <sub>2</sub> -N	NO <sub>2</sub> -N= 0.2315 mg/l = $Ks[1+b_{NOB}(SRT)]/[SRT(\mu_{NOB}-b_{NOB})-1]$
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700 = $b*1.029^{(T-20)}$ b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 1.0000 g/g·d = $\mu_{max} * 1.04^{(T-20)}$ μ max at 20°C = 1.000
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.6897 g/g·d = $\mu_{max,NOB}[S_0/(S_0+K_{O2,NOB})]$
	S <sub>0</sub> = 2.000 mg/l
	K <sub>O2,NOB</sub> = 0.900 mg/l
(8) effluent NH <sub>4</sub> -N	NH <sub>4</sub> -N= 0.5286 mg/l = $Ks[1+b_{NOB}(SRT)]/[SRT(\mu_{NOB}-b_{NOB})-1]$
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700 = $b*1.029^{(T-20)}$ b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 0.9000 g/g·d = $\mu_{max} * 1.072^{(T-20)}$ μ max at 20°C = 0.900
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.7200 g/g·d = $\mu_{max,NOB}[S_0/(S_0+K_{O2,NOB})]$
	S <sub>0</sub> = 2.000 mg/l
	K <sub>O2,NOB</sub> = 0.500 mg/l
(9) Ratio of Return Sludge	8,000·Rr/(1+Rr)= 3,000 mg/L 3,000/(8,000-3,000)= 0.60 Rr = 0.60

**STP Process Calculation Supporting Report 12.2.3**

[3] Design for Nitrification and Denitrification Process																					
(1) Active biomass concentration	$X_b = \frac{Q \cdot (SRT) \cdot V \cdot Y_H \cdot (S_0 - S)}{1 + b_H(SRT)}$ = 1,181.47 mg/l																				
(2) IR ratio	$IR = \frac{NOx}{Ne} - 1.0 - R$ = 3.66																				
(3) The amount of NO3-N fed to the anoxic tank	$Nox\ feed = (IR + R) \cdot Q \cdot Ne$ = 229,863.66 kg/d																				
(4) The anoxic tank volume	$V_{nor} = 412\ m^3 = V_a \times 10\%$ $V_{nor} = 1,250\ m^3 \quad \tau_{DN} = 5.000\ h$																				
(5) F/M <sub>b</sub>	F/M <sub>b</sub> = 1.42 g/g · d																				
(6) Fraction of rbCOD	40.00% = rbCOD/bCOD																				
	<table border="1"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b0</th> <th>b1</th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>	Percent rdCOD(%)	SDNR equation coefficients		b0	b1	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162
Percent rdCOD(%)	SDNR equation coefficients																				
	b0	b1																			
10	0.186	0.078																			
20	0.213	0.118																			
30	0.235	0.141																			
40	0.242	0.152																			
50	0.270	0.162																			
(8) SDNR <sub>b</sub>	$SDNR_b = 0.296\ g/g \cdot d = b_0 + b_1[\ln(F/M_b)]$ $b_0 = 0.242$ $b_1 = 0.152$																				
(8) SDNR	$SDNR = 0.110\ g/g \cdot d = SDNR_b(MLVSS_b/MLVSS)$ $SDNR_{adj} = 0.212\ g/g \cdot d = SDNR_i - 0.029 \ln(F/M_b) - 0.012 \quad IR=3-4$ $= SDNR_i - 0.0166 \ln(F/M_b) - 0.078 \quad IR=2$ $SDNR_t = 0.296\ g/g \cdot d = SDNR_b \cdot \theta^{(4-20)} \quad \theta = 1.026$																				
(9) NO <sub>r</sub>	$NO_r = 312,595.85\ kg/d = N_{nox} \cdot SDNR \cdot X_b$ $> Nox\ feed = 229,864\ kg/d$																				
(10) Alkalinity to be added to maintain pH7	-108.33 mg/l Influent Alk = 380.00 mg/l Alk used = 338.44 mg/l = 7.14 × Nox Alk produced = 136.77 mg/l = 3.57 × (NOx - NO <sub>x,e</sub> ) Alk to maintain = 70.00 mg/l																				
[4] Design of Phosphorous Removal Process																					
(1) Removal T-P	3.13 mg/l																				
P in waste sludge	px = 1.00%																				
Generated waste sludge	Px <sub>vss</sub> = 1876.223 kg/d																				
Rwmoval Phosphorus	18.76222816 kg/d																				
(2) Effluent T-P without Al	3.87 mg/l																				
(3) Required Al to initial soluble phosphorous ratio	1.00 mol/mol																				
(4) Required Al dosing rate	3.48 mg/l as Al																				
	42.98 mg/l as crystal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> · 18H <sub>2</sub> O																				
(5) Required Aluminium Sulphate	257.87 kg/d																				
(6) Required Aluminium Sulphate sol 10%	2.46 m <sup>3</sup> /d																				
	102.33 L/H																				
(7) Additional sludge	104.54 kg/d																				

**STP Process Calculation Supporting Report 12.2.3**

<p><b>[5] Reactor</b></p> <p>(1) Total volume of Aeration Basins</p> <p>(2) Total volume of Anoxic Basins</p>	$V_A = Q \cdot \theta_a / 24$ $= 4,500 \text{ m}^3$ $V_{DN} = Q \cdot \theta_{DN} / 24$ $= 1,250 \text{ m}^3$ <table border="1" data-bbox="571 398 1061 600"> <thead> <tr> <th rowspan="2">Item</th> <th rowspan="2">Volume required</th> <th colspan="2">Retention Time required</th> <th rowspan="2">Ratio of Volume</th> </tr> <tr> <th>Summer</th> <th>Winter</th> </tr> <tr> <th>unit</th> <th>m<sup>3</sup></th> <th>hour</th> <th>hour</th> <th></th> </tr> </thead> <tbody> <tr> <td>Anaerobic</td> <td>V<sub>AN</sub></td> <td>380</td> <td>1.50</td> <td>1.50</td> <td>0.30</td> </tr> <tr> <td>Anoxic</td> <td>V<sub>DN</sub></td> <td>1,250</td> <td>5.00</td> <td>5.00</td> <td>1.00</td> </tr> <tr> <td>Aerobic</td> <td>V<sub>A</sub></td> <td>4,500</td> <td>18.00</td> <td>18.00</td> <td>3.60</td> </tr> <tr> <td>Total</td> <td>V</td> <td>6,130</td> <td>24.50</td> <td>24.50</td> <td></td> </tr> </tbody> </table>	Item	Volume required	Retention Time required		Ratio of Volume	Summer	Winter	unit	m <sup>3</sup>	hour	hour		Anaerobic	V <sub>AN</sub>	380	1.50	1.50	0.30	Anoxic	V <sub>DN</sub>	1,250	5.00	5.00	1.00	Aerobic	V <sub>A</sub>	4,500	18.00	18.00	3.60	Total	V	6,130	24.50	24.50																															
Item	Volume required			Retention Time required			Ratio of Volume																																																												
		Summer	Winter																																																																
unit	m <sup>3</sup>	hour	hour																																																																
Anaerobic	V <sub>AN</sub>	380	1.50	1.50	0.30																																																														
Anoxic	V <sub>DN</sub>	1,250	5.00	5.00	1.00																																																														
Aerobic	V <sub>A</sub>	4,500	18.00	18.00	3.60																																																														
Total	V	6,130	24.50	24.50																																																															
<p><b>[6] Geometry</b></p> <p>(1) Basin Dimensions</p> <p>Cross Section</p> <p>Hantzsch Subtraction</p> <p>after Subtraction</p> <p>Total Volume</p> <p>(2) Partition of Basin</p>	<p>Width      Length      Depth      Basins</p> <p>8.0            75.0            5.5            2</p> <p>Cross Section      =      44.0 m<sup>2</sup>/Basin</p> <p>Hantzsch Subtraction      =      1.0 m<sup>2</sup>/Basin</p> <p>after Subtraction      =      43.0 m<sup>2</sup>/Basin</p> <p>Total Volume      =      3,225 m<sup>2</sup>/Basin      6,450 m<sup>3</sup>/Total</p> <table border="1" data-bbox="571 824 1129 1281"> <thead> <tr> <th>Item</th> <th>unit</th> <th>Anaerobic</th> <th>Anoxic</th> <th>Aerobic</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Cross Section</td> <td>m<sup>2</sup></td> <td colspan="3">43.0</td> <td></td> </tr> <tr> <td>Length required</td> <td>m</td> <td>4.4</td> <td>14.5</td> <td>52.3</td> <td>71.3</td> </tr> <tr> <td>Volume required per Basin</td> <td>m<sup>3</sup></td> <td>190</td> <td>625</td> <td>2,250</td> <td>3,065</td> </tr> <tr> <td>Total Volume required</td> <td>m<sup>3</sup></td> <td>380</td> <td>1,250</td> <td>4,500</td> <td>6,130</td> </tr> <tr> <td>Actual Cross Section</td> <td>m<sup>2</sup></td> <td>43.0</td> <td>43.0</td> <td>43.0</td> <td></td> </tr> <tr> <td>Actual Length</td> <td>m</td> <td>6.0</td> <td>15.0</td> <td>54.0</td> <td>75.0</td> </tr> <tr> <td>Actual Volume per Basin</td> <td>m<sup>3</sup></td> <td>258</td> <td>645</td> <td>2,322</td> <td>3,225</td> </tr> <tr> <td>Actual Total Volume</td> <td>m<sup>3</sup></td> <td>516</td> <td>1,290</td> <td>4,644</td> <td>6,450</td> </tr> <tr> <td>Actual Ratio of Volume</td> <td></td> <td>0.40</td> <td>1.00</td> <td>3.60</td> <td></td> </tr> <tr> <td>Actual Retention Time</td> <td>hour</td> <td>2.06</td> <td>5.16</td> <td>18.58</td> <td>25.80</td> </tr> </tbody> </table>	Item	unit	Anaerobic	Anoxic	Aerobic	Total	Cross Section	m <sup>2</sup>	43.0				Length required	m	4.4	14.5	52.3	71.3	Volume required per Basin	m <sup>3</sup>	190	625	2,250	3,065	Total Volume required	m <sup>3</sup>	380	1,250	4,500	6,130	Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0		Actual Length	m	6.0	15.0	54.0	75.0	Actual Volume per Basin	m <sup>3</sup>	258	645	2,322	3,225	Actual Total Volume	m <sup>3</sup>	516	1,290	4,644	6,450	Actual Ratio of Volume		0.40	1.00	3.60		Actual Retention Time	hour	2.06	5.16	18.58	25.80
Item	unit	Anaerobic	Anoxic	Aerobic	Total																																																														
Cross Section	m <sup>2</sup>	43.0																																																																	
Length required	m	4.4	14.5	52.3	71.3																																																														
Volume required per Basin	m <sup>3</sup>	190	625	2,250	3,065																																																														
Total Volume required	m <sup>3</sup>	380	1,250	4,500	6,130																																																														
Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0																																																															
Actual Length	m	6.0	15.0	54.0	75.0																																																														
Actual Volume per Basin	m <sup>3</sup>	258	645	2,322	3,225																																																														
Actual Total Volume	m <sup>3</sup>	516	1,290	4,644	6,450																																																														
Actual Ratio of Volume		0.40	1.00	3.60																																																															
Actual Retention Time	hour	2.06	5.16	18.58	25.80																																																														
<p><b>[7] Equipment</b></p> <p>(1) Ras Pumps</p> <p>Ras Ratio</p> <p>Required Capacity</p> <p>Number</p> <p>(2) Circulation Pumps</p> <p>Ras Ratio</p> <p>Required Capacity</p> <p>Number</p> <p>(3) SAS Pumps</p> <p>Excess Sludge</p> <p>Sludge withdraw</p> <p>Running Time</p> <p>Required Capacity</p> <p>Number</p>	<p>60%</p> <p>6,000 m<sup>3</sup>/day ×      60% / 24 /      2</p> <p>= 75 m<sup>3</sup>/Hr ⇒      75 m<sup>3</sup>/Hr</p> <p>2 Work</p> <p>2 Standby</p> <p>366%</p> <p>6,000 m<sup>3</sup>/day ×      366% / 24 /      4</p> <p>= 229 m<sup>3</sup>/Hr ⇒      230 m<sup>3</sup>/Hr</p> <p>4 Work</p> <p>2 Standby</p> <p>325 m<sup>3</sup>/day</p> <p>12 Times/day</p> <p>0.5 Hr/Time</p> <p>325 m<sup>3</sup>/day /      12 /      0.50 /      2</p> <p>= 27.12 m<sup>3</sup>/Hr ⇒      28 m<sup>3</sup>/Hr</p> <p>2 Work</p> <p>2 Standby</p>																																																																		

E-4 Process Cal. EA&al 6MLD Hosahalli Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

(4) Alum Solution Tank										
Number	2	W	+	0	S					
Alum concentration as crystal	10	%								
Gravity of dissolved dechlorine	1.05									
Required solution volume	257.87	kg / d		×	100	/	10	/	1.05 / 1000	
	=	2.46			m3/d					
Volume of Tank	1.5				m3/tank					
Total Volume of Tanks	3.0				m3		(Duration=	1.22	day)	
(5) Mixer for Alum Solution Tank										
Number	2	W	+	0	S					
(6) Alum Dosing Pump										
Number	2	W	+	1	S					
Capacity	2.46	m3/d /		24	×	1000	/	2	×	2
	102.33	l/h/unit		⇒	110	l/h/unit				

**STP Process Calculation Supporting Report 12.2.3**

<b>6. Air Requirement at Average Flow</b>	
[1] Design Condition	
(1) AOR	AOR = 2,596 kg/day = 108.2 kg/h
Q <sub>in</sub> : Design Average Flow m <sup>3</sup> /d	6,000
Inlet bCOD : S <sub>0</sub>	578 mg/l
S=	0.451 mg/l
Nox=	47.400 mg/l
P <sub>X,bio</sub> =	1,061.4 kg VSS/d does not include nitrifying bacteria
R <sub>0</sub> =	R <sub>0</sub> = Q(S <sub>0</sub> - S - k(Nox - NOx)) - 1.42P <sub>X,bio</sub> + 4.57Q · NOx
R <sub>0</sub> =	2,596 kg O <sub>2</sub> /d
k=	2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{\text{AOR} \times C_s \cdot a \times 1.024^{20-T}}{\alpha \times F (\beta \cdot C_{sW} / C_s \cdot (P_b / P_a) a - C_A)}$
	C <sub>s</sub> : Saturated DO at sea level and 20 °C 9.09 mg/L
	C <sub>sW</sub> : Saturated DO at sea level and operating Temperature 9.09 mg/L at 20 °C
	20-T : 0.0 1.024 <sup>20-T</sup> : 1.0000
	C <sub>A</sub> : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1 + 0.40D <sub>j</sub> /P <sub>a</sub> 1.19357
	D <sub>j</sub> : Tank Liquid Depth 5.00 m
	P <sub>a</sub> : Standard absolute pressure at s 10.332 m
	P <sub>b</sub> : Absolute pressure at Plant Site Elevation m
	P <sub>b</sub> /P <sub>a</sub> : exp[-gM(z <sub>b</sub> -z <sub>a</sub> )/R*T] 0.900
	g : Acceleration due to Gravity 9.80665 m/s <sup>2</sup>
	M : Mole of Air 28.97 kg/kg-mole
	z <sub>b</sub> : Plant Site Elevation 900 m
	z <sub>a</sub> : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 293.15 Kelvin
	α : relative Transfer Rate to clean Water 0.65
	β : relative DO Saturation to clean Water 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{28,164}{4.2591} = 6,612.59 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Standard O <sub>2</sub> required at Field Conditions per Basin =	3,306 kg/day
(5) SOTE for the above Effective Aeration Depth	28.0 %
(6) Fraction of O <sub>2</sub> in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	15%
(9) Air required at Field Conditions per Basins	= 48,627 m <sup>3</sup> /day = 2,026.1 m <sup>3</sup> /hr

E-4 Process Cal. EA&amp;al 6MLD Hosahalli Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

[2] Equipment					
(1) Air Blower					
Number	2	W	+	1	S
Required Capacity	2026.1	m <sup>3</sup> /Hr·Basin	/	1	unit/Basin
	= 2026.1	m <sup>3</sup> /h	⇒	2100	m <sup>3</sup> /h /Unit
Pressure	65	kPa			
Safety Factor	10	%			
Heat capacity ratio	1.4				
Atmospheric pressure at site elevation	91.234	kPa			
Total inlet pressure	89.234	kPa			
Volume rate of flow at inlet point	39.733	m <sup>3</sup> /min			
Total discharge pressure	156.234	kPa			
Overall adiabatic efficiency	0.65				
Inlet air temperature (min.)	15	°C			
Shaft power	56.177	kW			
Rated Output of Motor	61.795	kW	⇒	75	kW

E-4 Process Cal. EA&al 6MLD Hosahalli Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<p><b>7. Final Clarifire</b></p> <p><b>[1] Design Condition</b></p> <p>(1) Design Wastewater Flow</p> <p>(2) Water Temperature</p> <p>(3) MLSS</p> <p>(4) SVI</p> <p>(5) Sedimentation Velocity</p> <p>(6) Surface Overflow Rate required</p> <p><b>[2] Geometry</b></p> <p>(1) Surface Area required</p> <p>(2) Demensions</p> <p>(3) Actual Surface Area</p> <p>(4) Surface Overflow Rate</p>	<p><math>Q = 6,000 \text{ m}^3/\text{day}</math></p> <p><math>T = 20.0 \text{ }^\circ\text{C}</math></p> <p><math>X_{ef} = 3,000 \text{ mg/l}</math></p> <p><math>SVI = 300</math></p> <p><math>v = 4.899 \cdot 10^6 \cdot T^{(0.954)} \cdot X_{ef}^{(-1.354)} \cdot SVI^{(-0.77)}</math>  <math>= 4.899 \cdot 10^6 \cdot 20.0^{0.954} \cdot 3,000^{-1.354} \cdot 150^{-0.770}</math>  <math>= 20.7 \text{ m/day}</math></p> <p><math>S' = v / (1.5 \cdot 1) = 20.7 / (1.5 \cdot 1.0) = 13.8 \text{ m}^3/\text{m}^2 \cdot \text{day}</math>  <math>\rightarrow 12.0 \text{ m}^3/\text{m}^2 \cdot \text{day}</math></p> <p><math>A = 6,000 / 12.0 = 500 \text{ m}^2</math></p> <table style="margin-left: 40px;"> <tr> <td style="text-align: center;">Diameter</td> <td style="text-align: center;">Depth</td> <td style="text-align: center;">Basin</td> </tr> <tr> <td style="text-align: center;"><b>18.0</b></td> <td style="text-align: center;"><b>3.5</b></td> <td style="text-align: center;"><b>2</b></td> </tr> </table> <p><math>S = 18.0^2 \cdot 3.14 / 4 \cdot 2.0 = 509 \text{ m}^2</math></p> <p><math>S = 6,000 / 509 = 11.8 \text{ m}^3/\text{m}^2 \cdot \text{day}</math></p>	Diameter	Depth	Basin	<b>18.0</b>	<b>3.5</b>	<b>2</b>
Diameter	Depth	Basin					
<b>18.0</b>	<b>3.5</b>	<b>2</b>					

E-4 Process Cal. EA&al 6MLD Hosahalli, Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<b>8. Chlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Flow      6,000    m <sup>3</sup> /day      250.00    m <sup>3</sup> /h Peak Flow          15,000    m <sup>3</sup> /day      625.00    m <sup>3</sup> /h
(2) Contact Time	30    min
(3) Type of Chlorine	Cl <sub>2</sub> -GAS
(4) Design Chlorine Dosage Rate	10    mg/L
(5) Required Chlorine per day	Average Daily Flow    /    1000    ×      Design Chlorine Dosage Rate =      60.0    kg/d =      2.50    kg/h
<b>[2] Chlorination Contact Tank</b>	
(1) Volume required	Average Daily Flow    /    1440    ×      Contact Time =      125.0    m <sup>3</sup>
(2) Nos. of lanes	3      lanes
(3) Width of lane	1.50    m
(4) Length of lane	19.00    m
(5) Side Water Depth	1.50    m
(6) Nos. of Tanks	1      tank
(7) Total Width of Tank	5.30    m Approx..
(8) Average Velocity	Decant Flow      /      3600    /      Width      /      Depth =      250.00    /      3600    /      1.50      /      1.50 =      0.031    m/sec
(9) Total Volume	Width    ×      Length    ×      Depth    ×      Nos. of lanes    ×      Nos. of Tanks =      1.5      m      ×      19.0      m      ×      1.5      m ×      3      ×      1 =      128    m <sup>3</sup> >      125.0    m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Chlorine Dosing Condition	
Operation Dosage Rate -1	DC1      1 mg/L    10 mg/L
Average Dosage Rate -1	DC2      10 mg/L
(2) Chlorine Cylinder	
Type	-      Cylindrical Convexsd Container
Cylinder Capacity	Cc      928 kg/cylinder
Average Dosage Rate -1	q1      Chlorine -1 : Q <sub>T-D</sub> × DC2 × 10 <sup>-6</sup> × 10 <sup>3</sup> =    60 kg/day
Storage day	T      More than      15 days
Required Storage Capacity	EC1      D × T =      900 kg
Unit Number	EN1      EC1 / Cc =      1.0 cylinders
Maximum Operation Numbers	Vr1      ##### @ 20°C Standard temperature
Cl <sub>2</sub> -Gas Volatilize Rate	DC1      10 mg/L, Q <sub>T-D</sub> × q3 × 10 <sup>-3</sup> / 24 =      #####
Maximum Dosing Rate	EN2      DC1 / Vr1 =      0.8sets
(3) Chlorinator	
Type	Solution Feed Vacuum Type
Number	1      W      +      1      S
Operation Dosage Rate -1	Dq1      Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 6    kg/day to    150    kg/day
Required Dosage Rate	Chlorine -1 : Dq1 / (EN1 × 24) = Minimum                      Maximum 0.25    kg/hr                      6.3    kg/hr



E-4 Process Cal. EA&al 6MLD Hosahalli, Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<p>(4) Chlorine Booster Pump</p> <p>Type</p> <p>Water Demand</p> <p>Chlorinator Discharge</p> <p>Water Demand</p> <p>Chlorinator Discharge</p> <p>Water Demand</p> <p>Water requiamet</p> <p>For Chlorin</p> <p>Booster Pump Type</p> <p>Number</p>	<p>Branchy on the water supply pipe</p> <p>Water requiamet for mixed Chlori</p> <table border="0"> <tr> <td>(kg/hr)</td> <td>1.0</td> <td>1.5</td> <td>2.0</td> <td>2.5</td> <td>3.0</td> <td>4.0</td> </tr> <tr> <td>(L/min)</td> <td>15</td> <td>20</td> <td>25</td> <td>30</td> <td>35</td> <td>40</td> </tr> <tr> <td>(kg/hr)</td> <td>5.0</td> <td>6.0</td> <td>10.0</td> <td>50.0</td> <td>100.0</td> <td>200.0</td> </tr> <tr> <td>(L/min)</td> <td>45</td> <td>50</td> <td>60</td> <td>300</td> <td>600</td> <td>1,200</td> </tr> </table> <p>Water requiamet -</p> <p>Qp1 Maximum dosage rate 6.3 kg/hr          therefore 50 L/min</p> <p>Single suction volute pump</p> <table border="0"> <tr> <td>1</td> <td>W</td> <td>+</td> <td>1</td> <td>S</td> </tr> </table>	(kg/hr)	1.0	1.5	2.0	2.5	3.0	4.0	(L/min)	15	20	25	30	35	40	(kg/hr)	5.0	6.0	10.0	50.0	100.0	200.0	(L/min)	45	50	60	300	600	1,200	1	W	+	1	S
(kg/hr)	1.0	1.5	2.0	2.5	3.0	4.0																												
(L/min)	15	20	25	30	35	40																												
(kg/hr)	5.0	6.0	10.0	50.0	100.0	200.0																												
(L/min)	45	50	60	300	600	1,200																												
1	W	+	1	S																														
<p><b>9. Dechlorination</b></p> <p><b>[1] Design Condition</b></p> <p>(1) Design Flow Rate</p> <p>(2) Contact Time</p> <p>(3) Type of Dechlorine</p> <p>(4) Free Residual Chlorine</p> <p>(5) Consumption per day</p> <p><b>[2] Dechlorination Contact Tank</b></p> <p>(1) Volume required</p> <p>(2) Width of lane</p> <p>(3) Length of lane</p> <p>(4) Side Water Depth</p> <p>(5) Nos. of Tanks</p> <p>(6) Total Volume</p> <p><b>[3] Equipment</b></p> <p>(1) Dechlorine Solution Tank</p> <p>Number</p> <p>Dechlorine concentration</p> <p>Gravity of dissolved dechlorine</p> <p>Required solution volume</p> <p>Volume of Tank</p> <p>Total Volume of Tanks</p> <p>(2) Mixer for Dechlorine Solution Tank</p> <p>Number</p> <p>(3) Dechlorine Dosing Pump</p> <p>Number</p> <p>Capacity</p>	<p>Average Daily Flow 6,000 m<sup>3</sup>/day</p> <p>10 min</p> <p>Sodium Thiosulfate (Na<sub>2</sub>S<sub>2</sub>O<sub>3</sub> 5H<sub>2</sub>O)</p> <p>1.0 mg/L assumed value</p> <p>Average Daily Flow / 1000 × Free Residual Chlorine × 1.75</p> <p>× 1.5 (safety factor)</p> <p>= 15.75 kg/d</p> <p>= 0.656 kg/h</p> <p>Average Flow Rate / 60 × Contact Time</p> <p>= 41.7 m<sup>3</sup></p> <p>5.30 m</p> <p>6.00 m</p> <p>1.50 m</p> <p>1 tank</p> <p>Width × Length × Depth</p> <p>= 5.3 m × 6.0 m × 1.5 m</p> <p>= 48 m<sup>3</sup> &gt; 41.7 m<sup>3</sup></p> <p>1 W + 0 S</p> <p>10 %</p> <p>1.10</p> <p>15.75 kg/d × 100 / 10 / 1.10 / 1000</p> <p>= 0.14 m<sup>3</sup>/d</p> <p>0.2 m<sup>3</sup>/tank</p> <p>0.2 m<sup>3</sup> (Duration= 1.40 day)</p> <p>1 W + 0 S</p> <p>1 W + 1 S</p> <p>0.36 m<sup>3</sup>/d / 24 × 1000 / 1</p> <p>14.91 l/h/unit ⇒ 15.0 l/h/unit</p>																																	

E-4 Process Cal. EA&al 6MLD Hosahalli, Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<p><b>10. Centrifuge</b>  <b>[1] Design Condition</b>                  (1) Type of Dewatering                  (2) Generated Sludge                  (3) Design Polyelectrolyte Dosage                  (4) Volume of Thickend Sludge                  (5) Consistency of Dewatered Sludge                  (6) Operation Time</p>	<p>Centrifuge                  2,604 kg/day                  Polyelectrolyte 5 kg/t-DS·day                  325.4 m<sup>3</sup>/day                  82 %                  12 hours/day (6 days per week)</p>
<p><b>[2] Volume of Centrifuges</b></p>	<p><math display="block">\frac{\text{Digested Solids}}{\text{Operation Time} \times \text{No.}} \times \text{Operation/week}</math> <math display="block">= \frac{325.4}{12 \times 1} \times \frac{7}{6} = 31.6</math> <p style="text-align: right;">→ 32 m<sup>3</sup>/hour</p> </p>
<p><b>[3] Dewatered Solids</b></p>	<p><math display="block">\text{Digested Sludge} \times \left( \frac{1}{1} + \frac{\text{Injection Rate}}{0.0050} \right)</math> <math display="block">= 2,604 \times \left( \frac{1}{1} + \frac{0.0050}{0.0050} \right)</math> <math display="block">= 2,617 \text{ kg/day}</math> </p>
<p><b>[4] Dewatered Cake Volume</b></p>	<p><math display="block">\text{Dewatered Solids} \times \frac{100}{100 - \frac{\text{Moisture Content}}{7}}</math> <math display="block">\times \frac{6 \text{ days per week}}{6}</math> <math display="block">= 2,617 \times \frac{100}{100 - \frac{82}{6}} \times \frac{7}{6}</math> <math display="block">= 16.96 \text{ t/day}</math> <p>apparent specific gravity 1.00  <math display="block">\frac{16.96}{1.0} = 17.0 \text{ m}^3/\text{day}</math></p> </p>
<p><b>[5] Polyelectrolyte</b>                  (1) Design Polyelectrolyte Dosage                  (2) Required Polyelectrolyte                  (3) Dissolving concentration                  (4) Volume of Polyelectrolyte solution</p>	<p>Polyelectrolyte 5 kg/t-DS·day                  13.02 kg/day                  0.20 %                  6.51 m<sup>3</sup>/day</p>

E-4 Process Cal. EA&al 6MLD Hosahalli, Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

[6] <b>Equipment</b>						
(1) Centrifuge						
Capacity	32	m <sup>3</sup> /hr				
Number	1	W	+	1	S	
(2) Centrifuge Feed Pumps						
Capacity	32	m <sup>3</sup> /hr				
Number	1	W	+	1	S	
(3) Polyelectrolyte Dosing Pumps						
Volume of Polyelectrolyte solution	6.51	m <sup>3</sup> /day				
Operation Time	12	hours/day		(6 days per week)		
Safety Factor	1.5					
Number	1	W	+	1	S	
Required Capacity	6.51	m <sup>3</sup> /da;	×	7	/	6
					/	12
					/	1
	=	0.63				m <sup>3</sup> /Hr
Specification Capacity	0.63	m <sup>3</sup> /Hr	×	1.5		
	=	0.949			⇒	1.00 m <sup>3</sup> /Hr /Unit
(4) Polyelectrolyte dosing System						
Tanks Dimensions						
Width	1.5	m	×	Length	1.5	m
× Depth				1.8	m	×
						2
	=	8.1				m <sup>3</sup>
Retention Time of Tanks	8.10	m <sup>3</sup>	/	0.63	m <sup>3</sup> /Hr	/
	=	12.800				Hr
Number	2	W	+	0	S	

E-4 Process Cal. EA&al 6MLD Hosahalli, Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<b>11. Centrifuge Feed Sump</b>	
<b>[1] Design Condition</b>	
(1) Generated Thickend Sludge	2,604 kg/day
(2) Solids Consistency	0.80 %
(3) Volume of Excess Sludge	$\begin{aligned} & \text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3} \\ = & 2,604 \times \frac{100}{0.80} \times 10^{-3} \\ = & 325 \text{ m}^3/\text{day} \\ = & 13.56 \text{ m}^3/\text{h} \end{aligned}$
(4) Sludge feed flow rate	32 m <sup>3</sup> /h × 1 = 32 m <sup>3</sup> /h
(5) Centrifuge Operation Time	12 hours/day ( 6 days per week)
<b>[2] Geometry</b>	
(1) Basin Dimensions	$\begin{aligned} & \text{Width } 5.0 \text{ m} \times \text{Length } 5.0 \text{ m} \\ & \times \text{Depth } 4.0 \text{ m} \times 2 \\ = & 200.0 \text{ m}^3 \end{aligned}$
<b>[3] Equipment</b>	
(1) Mixers for Centrifuge Feed Sumps	
Required Volume	200.0 m <sup>3</sup>
Number	1 W + 1 S

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Digestion Tank + Centrifugal Dewatering)

Table -1 Input Data

1. Calculation Manner	2	1:Premise that the quality of supernatants are same level removed with inlet sewage 2:Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency	2	1:Total Removal Ratio 2:Outlet Water Quality(input 1or2)
In case of 1 : input data		(%)
In case of 2 : input data	#REF!	(mg/l)
3. Selection of Excess Sludge Generation	2	1:Consideration of Solid Matter Only 2:Consideration of Converting of Solved BOD(input 1or2)
In case of 1 : input data (Sludge generation)		Sludge generation ratio per removal SS(%)
	a	0.4 T2=Q4·S4=(a·S <sub>BOD</sub> +b·S1-c·θ·XA)·Q3/10 <sup>6</sup> · (Excess sludge generation formula)
	b	0.9 a:Converting ratio of solved BOD(mgMLSS/mgBOD)
	c	0.05 b:Converting ratio of SS(mgMLSS/mgSS)
In case of 2 : input data	SBOD	234.50 c:Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)
	XA	3,000 S <sub>BOD</sub> :Solved BOD quality at inlet reactor
	θ	1 XA:MLSS concentration(mg/l)
		θ:Hydraulic retention time(day)


Table -2 Basic Conditions

Sewage Flow and Quality		Sludge Moisture and Recovery Ratio		Digestion Tank Conditions		Chemical Conditions for Dewatering	
· Inlet flow : Q <sub>0</sub> (m <sup>3</sup> /D)	6,000	· Primary sludge moisture ratio : W1(%)	0.0	· Removal ratio in primary tank : A2(%)	0.0	· Content of organics in thickened sludge : A6(%)	75.0
· Inlet quality : S <sub>0</sub> (mg/l)	450	· Excess sludge moisture ratio : W2(%)	99.2	· Recovery ratio in sludge thickener : A3(%)	100.0	· Digestion ratio : A7(%)	#REF!
· Total removal ratio : A1(%)	-	· Thickened sludge moisture ratio : W3(%)	99.2	· Recovery ratio in sludge digester : A4(%)	100.0	· Digestion gas generation : A8(Nm <sup>3</sup> /kgVS)	
· Effluent quality : S1(mg/l)	10.0	· Digested sludge moisture ratio : W4(%)	99.2	· Recovery ratio in dewatering : A5(%)	95.0	· Chemical dosage : A9(%)	0.5
· Sludge generation ratio per removal SS : S1(%)	-	· Dewatered sludge moisture ratio : W5(%)	82.0			· Chemical dissolve concentration : A10(%)	0.2

Table -3 Material Balance Calculation

	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	手入力(要取束)	16	17	
Q(m <sup>3</sup> /day)	6,000	6,318	0	6,318	325	5,993	325	0	0	325	0	7	332	14	318	318		5,993	0	
T(t·DS/day)	2,700	2,831	0.000	2,831	2,604	0.060	2,604	0.000	0.000	2,604	0.000	0.013	2,617	2,486	0.131	0.131	0.131		0.060	0.167
S(mg/l)	450	448	0	448	8,000	10	8,000	#DIV/0!	0	8,000	0	2,000	7,882	180,000	411	411			10	
X(T5/T0*100)	100	104.9	0.0	104.9	96.4	2.2	96.4	0.0	0.0	96.4	0.0	0.5	96.9	92.1	4.8	4.8			2.2	6.2

Figure -1 Material Balance Model




Calculation Formula						
· Q0=Input Data	· Q3=Q1-Q2	· Q6=T6*100/(100-W3)	· Q9=Q6	· Q12=Q9+Q11	· Q15=Q7+Q10+Q14	· Q5-1=Q5-Q11
· T0=Q0*S0*10 <sup>-6</sup>	· T3=T0*(100-A2)/100	· T6=(T2+T4)*A3/100	· T9=(T6-T8)*A4/100	· T12=T9+T11	· T15=T7+T10+T14	· T5-1=T5-T11
· S0=Input Data	· S3=T3*10 <sup>-6</sup> /Q3	· S6=10 <sup>-6</sup> *Q6*(100-W3)/100	· S9=T9*10 <sup>-6</sup> /Q9	· S12=T12*10 <sup>-6</sup> /Q12	· S15=T15*10 <sup>-6</sup> /Q15	· S5-1=S5
· Q1=Q0+Q15	· Q4=T4*100/(100-W2)	· Q7=(Q2+Q4)-Q6	· Q10=Q6-Q8-Q9	· Q13=T13*100/(100-W5)		
· T1=T0+T15	· T4=余剰汚泥発生式による	· T7=(T2+T4)-T6	· T10=T6-T8-T9	· T13=T12*A5/100		
· S1=T1*10 <sup>-6</sup> /Q1	· S4=10 <sup>-6</sup> *Q4*(100-W2)/100	· S7=T7*10 <sup>-6</sup> /Q7	· S10=T10*10 <sup>-6</sup> /Q10	· S13=10 <sup>-6</sup> *Q13*(100-W5)/100		
· Q2=T2*100/(100-W1)	· Q5=Q3-Q4*(T3-T5)/T4	· Q8=0	· Q11=T10*A9/A10	· Q14=Q12-Q13		
· T2=T1-T3	· T5=Q5*ST/10 <sup>-6</sup>	· T8=T6*A6*A7/10 <sup>-4</sup>	· T11=Q11*S11/10 <sup>-6</sup>	· T14=T12-T13		
· S2=10 <sup>-6</sup> *Q2*(100-W1)/100	· S5=St	#REF!	· S11=10 <sup>-4</sup> *A10	· S14=T14*10 <sup>-6</sup> /Q14		

Material Balance Sheet SD4

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Sheet  
[3MLD STP]



**STP Process Calculation\_Supporting Report 12.2.3**

**Design Condition**

Item	4MLD STP-TSPS			
(1) Design Flow for the year 2049	Flow Rate			
		m3/d	m3/h	m3/s
	Daily Average	####	417	0.116
	Daily Maximum	####	417	0.116
Hourly Max. Peak factor	2.25	####	938	0.260
(1) Design Flow for the year 2034	Flow Rate			
		m3/d	m3/h	m3/s
	Daily Average	4,000	167	0.046
	Daily Maximum	4,000	167	0.046
Hourly Max. Peak factor	2.5	####	417	0.116

**1. Inlet Chamber**

Item	4MLD STP-TSPS			
[1] Design Condition				
(1) Design Flow for the year 2049	Max Hourly	=	22,500	m3/d
		=	0.260	m3/sec
(2) Inlet Pipe				
Pipe Diameter	·	×		
Gradient		%		
Roughness Coefficient	n=	0.013	(Manning Formula)	
Full Pipe Flow Rate		m3/s		
(3) Influent Water Level	+	m		
[2] Geometory				
(1) Number of Basins	1	Basin		
(2) Depth of Basin	0.600	m	Approx.	
(3) Width of Basin	2.100	m	Approx.	
(4) Length of Basin	2.500	m	Approx.	
(5) Volume required of Basin	0.600	×	2.100	×
			2.500	=
				0.5
				m3
(6) Retention Time	0.600	×	2.100	×
			2.500	/
				0.260
				×
				1
	=	12.12	sec	
(7) Basin Demensions	Width	2.100	m	×
				Length
				2.500
				m
	×	Depth	0.600	m

**STP Process Calculation\_Supporting Report 12.2.3**

**2. Coarse Screen Channel**

Item	4MLD STP-TSPS					
[1] Geometry						
(1) Inlet Gate						
Number	2	Main	+	1	Bypass	
Width	0.400	m				
Height	0.600	m				
Floor Level	+	5.000	m			
Bottom	+	0.000	m			
Influent Water Level	+	0.500	m			
Velocity	0.260	/	0.400	/	0.500	/ 2
where Design Flow for the year 2049	=	0.650	<	1.000	m/sec	OK
Velocity	0.116	/	0.400	/	0.500	/ 1
where Design Flow for the year 2034	=	0.580	<	1.000	m/sec	OK
(2) Screen Channel						
Number	2.0	Main	+	1.0	Bypass	
Width	0.800	m				
Side Water Depth	0.500	m				
Velocity	0.260	/	0.800	/	0.500	/ 2
where Design Flow for the year 2049	=	0.325	≅	0.450	m/sec	OK
Velocity	0.116	/	0.800	/	0.500	/ 1
where Design Flow for the year 2034	=	0.290	<	0.450	m/sec	OK
(3) Channel Dimensions	Width	0.8	m	×	Length	8.5 m
			×	SWD	0.5	m
[3] Equipment						
(1) Inlet Gate						
Number	2	Units				
Dimension	Width	0.4	m	×	Height	0.6 m
Design Water Level		m				
(2) Coarse Screens (Main Channel)						
Number	2	W	+	0	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	0.8	m				
Width of side plate	50	mm				
Side Water Depth	0.5	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.260	/	0.700	/	0.450	/ 2
	× (	20	+	9	) /	20
	=	0.598	≅	0.800	m/sec	OK
Velocity through screen	0.116	/	0.700	/	0.450	/ 1
where Design Flow for the year 2034	× (	20	+	9	) /	20
	=	0.534	<	0.800	m/sec	OK
(3) Coarse Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	50	mm				
Bar Thickness	9	mm				
Channel Width	0.8	m				
Side Water Depth	0.5	m				
Velocity through screen	0.260	/	0.800	/	0.500	/ 2
where Design Flow for the year 2049	× (	50	+	9	) /	50
	=	0.384	<	0.800	m/sec	OK
Velocity through screen	0.116	/	0.800	/	0.500	/ 1
where Design Flow for the year 2034	× (	50	+	9	) /	50
	=	0.342	<	0.800	m/sec	OK



E-5 Process Cal. EA&al 4MLD Chikkabanavara Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

**3. Raw Sewage Sump**

Item	4MLD STP-TSPS	
[2] Geometory		
(1) Raw Sewage Sump		
Number	1	Basin
Dia	9.00	m
Pump Operating Depth	1.000	m
Retention Time whe Design Flow for the year 2049	$( \frac{9.00^2 \times \pi}{4} \times 1.000 ) / 0.260$	$/ 60 = 4.08 > 3.75$ min (=minimum time of one pump cycle) OK
Retention Time whe Design Flow for the year 2034	$( \frac{9.00^2 \times \pi}{4} \times 1.000 ) / 0.116$	$/ 60 = 9.14 > 3.75$ min (=minimum time of one pump cycle) OK
High Water Level	+ 0.000	m
Pump Off Level	+ -1.000	m
[3] Equipment		
(1) Sewage Pumps 1		
Number	1	W + 1 S
Bore Diameter	250	mm
Discharge Flow : Q whe Design Flow for the year 2034	$0.116 \times 3600$	$/ 1.0 = 418 \Rightarrow 418$ m <sup>3</sup> /Hr
Total Head	15.0	m
(2) Sewage Pumps 2		
Number	W	+ S
Bore Diameter	mm	
Discharge Flow : 0.5 whe Design Flow for the year 2034		$\Rightarrow$ m <sup>3</sup> /Hr
Total Head	m	

E-5 Process Cal. EA&al 4MLD Chikkabanavara Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

Item	4MLD STP																																												
<b>1. STP Design Condition</b>																																													
(1) Design Flow Rate	<table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th></th> <th>m<sup>3</sup>/d</th> <th>m<sup>3</sup>/h</th> <th>m<sup>3</sup>/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td>4,000</td> <td>166.67</td> <td>0.046</td> </tr> <tr> <td>Max Daily</td> <td>4,000</td> <td>166.67</td> <td>0.046</td> </tr> <tr> <td>Max Hourly Peak factor 2.5</td> <td>10,000</td> <td>416.67</td> <td>0.116</td> </tr> </tbody> </table>					m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s	Average Daily	4,000	166.67	0.046	Max Daily	4,000	166.67	0.046	Max Hourly Peak factor 2.5	10,000	416.67	0.116																									
	m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s																																										
Average Daily	4,000	166.67	0.046																																										
Max Daily	4,000	166.67	0.046																																										
Max Hourly Peak factor 2.5	10,000	416.67	0.116																																										
(2) Design Water Quality	<p style="text-align: right;">Unit: mg/L</p> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th colspan="2">TP</th> </tr> <tr> <th>NH<sub>4</sub>-N</th> <th>Org-N</th> <th>NOx-N</th> <th>D-P</th> <th>P-P</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td>350</td> <td>800</td> <td>450</td> <td>45.5</td> <td>17.5</td> <td>7</td> <td>5</td> <td>2</td> </tr> <tr> <td>Outlet</td> <td>10</td> <td>50</td> <td>10</td> <td>1</td> <td>0</td> <td>9</td> <td>1</td> <td>1</td> </tr> <tr> <td>Removal rate</td> <td>97.1%</td> <td>93.7%</td> <td>97.8%</td> <td colspan="3">85.7%</td> <td colspan="2">71.4%</td> </tr> </tbody> </table>					BOD	COD	SS	T-N			TP		NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P	Inlet	350	800	450	45.5	17.5	7	5	2	Outlet	10	50	10	1	0	9	1	1	Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%	
	BOD	COD	SS	T-N					TP																																				
				NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P																																					
Inlet	350	800	450	45.5	17.5	7	5	2																																					
Outlet	10	50	10	1	0	9	1	1																																					
Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%																																						
<b>2. Inlet Chamber</b>																																													
<b>[1] Design Condition</b>																																													
(1) Design Flow Rate	Max Hourly	=	10,000	m <sup>3</sup> /day																																									
		=	0.116	m <sup>3</sup> /sec																																									
<b>[2] Geometry</b>																																													
(1) Number of Basins	1	Basin																																											
(2) Depth of Basin	1.000	m																																											
(3) Width of Basin	1.800	m																																											
(4) Length of Basin	1.500	m																																											
(5) Volume required of Basin	1.000	×	1.800	×	1.500	=	1.2	m <sup>3</sup>																																					
(6) Retention Time	1.000	×	1.800	×	1.500	/	0.116	×	1																																				
	=	23.28	sec																																										
(7) Basin Dimensions	Width	1.800	m	×	Length	1.500	m																																						
	×	Depth	1.000	m																																									

E-5 Process Cal. EA&al 4MLD Chikkabanavara Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Wastewater Flow	$\begin{aligned} \text{Max Hourly} &= 10,000 \text{ m}^3/\text{d} \\ &= 0.116 \text{ m}^3/\text{sec} \end{aligned}$
[2] Geometory	
(1) Inlet Gate	
Number	1 Main + 1 Bypass
Width	0.400 m
Height	0.600 m
Floor Level	+ 2.000 m
Bottom	+ 0.000 m
Influent Water Level	+ 0.500 m
Velocity	$\begin{aligned} &0.116 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 0.500 \text{ } \swarrow \quad 1 \\ = &0.580 \text{ } \div \quad 1.000 \text{ m/sec} \end{aligned}$
(2) Screen Channel	
Number	1 Main + 1 Bypass
Width	0.800 m
Side Water Depth	0.400 m
Velocity	$\begin{aligned} &0.116 \text{ } \swarrow \quad 0.800 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 1 \\ = &0.363 \text{ } \div \quad 0.450 \text{ m/sec} \end{aligned}$
(3) Channel Dimensions	$\begin{aligned} \text{Width} &0.8 \text{ m} \times \text{Length} &6.0 \text{ m} \\ &\times \text{SWD} &0.4 \text{ m} \quad (\text{Freeboard } 0.3\text{m}) \end{aligned}$
[3] Equipment	
(1) Inlet Gate	
Number	1 W + 1 S
Dimension	Width 0.4 m × Height 0.60 m
Design Water Level	2.00 m
(2) Fine Screens (Main Channel)	
Number	1 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	0.8 m
Width of side plate	50 mm
Side Water Depth	0.4 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	$\begin{aligned} &0.116 \text{ } \swarrow \quad 0.700 \text{ } \swarrow \quad 0.350 \text{ } \swarrow \quad 1 \\ &\times ( \quad 6 \quad + \quad 2 \quad ) / \quad 6 \\ = &0.631 < \quad 0.800 \text{ m/sec} \end{aligned}$
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	0.8 m
Side Water Depth	0.4 m
Velocity through screen	$\begin{aligned} &0.116 \text{ } \swarrow \quad 0.800 \text{ } \swarrow \quad 0.400 \text{ } \swarrow \quad 1 \\ &\times ( \quad 20 \quad + \quad 9 \quad ) / \quad 20 \\ = &0.526 < \quad 0.800 \text{ m/sec} \end{aligned}$

E-5 Process Cal. EA&al 4MLD Chikkabanavara Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>4. Grit Chamber</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Max Hourly = 10,000 m <sup>3</sup> /day = 0.116 m <sup>3</sup> /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0111 m/sec = 960 m <sup>3</sup> /m <sup>2</sup> /day
(4) Average Velocity	0.3 m/sec
<b>[2] Grit Chamber</b>	
(1) Surface Area required	0.116 / 0.0111 = 10.45 m <sup>2</sup>
(2) Number of Basins	1 S + 1 W
(3) Surface Area required/Basin	10.5 / 1 = 10.45 m <sup>2</sup>
(4) Length of Basin	10.45 ^0.5 = 3.2 m → 3.5 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.116 × 60 sec / 1 = 7.0 m <sup>3</sup>
(7) Depth required	7.0 / 3.5 / 3.5 = 0.568 m
(8) Basin Dimensions	Width 3.5 m × Length 3.5 m × Depth 0.6 m (Freeboard 0.3m)
(9) Retention Time	3.5 × 3.5 × 0.6 / 0.116 × 1 = 60.00 sec
(10) Surface Overflow Rate at Peak Flow	10,000 / 3.5 / 3.5 / 1 = 816.326531 < 960 m <sup>3</sup> /m <sup>2</sup> /day
<b>[3] Parshall Flume</b>	
(1) Design Flow Rate	Q= 116.000 l/sec
(2) Throat width	W= 0.450 m
(3) Water depth Ha	Ha= ( Q / 2264 / W ) <sup>2/3</sup> Ha= 0.235 m
(4) Crest Level	+ 75.400 m ≐ Minimum water level at downstream channel
(5) Water level at the crest	+ 75.635 m
(6) Channel bottom level	+ m
(7) Upstream Channel width	1.500 m
(8) SWD of Upstream Channel	0.700 m
(9) Average velocity at upstream channel	0.110 m/sec
(10) Total Length of channel	10.000 m
<b>[4] Inlet Weir Gate</b>	
(1) Number	2 Units
(2) Weir Width	0.400 m
(3) Stroke	0.450 m
(4) Overflow Height	0.400 m
(5) Overflow Height (actual)	( 0.116 / 1.840 / 0.400 / 2 ) <sup>2/3</sup> = 0.184 < 0.400 m

E-5 Process Cal, EA&al 4MLD Chikkabanavara Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<b>5. Reactor</b>																																																								
<b>[1] Design Condition</b>																																																								
(1) Design Wastewater Flow	Q = 4,000 m <sup>3</sup> /day (summer) Q' = 4,000 m <sup>3</sup> /day (Winter)																																																							
(2) Design Sewage Quality																																																								
Inlet BOD	350 mg/l																																																							
Outlet BOD	10.0 mg/l																																																							
Inlet S-BOD	235 mg/l assumed as 67% of BOD																																																							
Inlet COD	800 mg/l																																																							
Inlet bCOD : S <sub>0</sub>	578 mg/l																																																							
Inlet nbCOD	223 mg/l																																																							
bCOD/BOD	1.65																																																							
Inlet S-COD : sCOD	271 mg/l																																																							
Inlet rbCOD	231 mg/l bCOD*40%																																																							
Inlet sbCOD	347 mg/l bCOD*60%																																																							
Outlet S-COD : nbsCODe	40 mg/l																																																							
Inlet nbpCOD : nbpCOD	183 mg/l = TCOD-bCOD-nbsCODe																																																							
Inlet SS	450 mg/l																																																							
Inlet VSS	383 mg/l assumed as 85% of TSS																																																							
: VSS <sub>COD</sub>	1.38 gCOD/gVSS = TCOD-sCOD/VSS																																																							
: nbVSS	131.96 gnbVSS/m <sup>3</sup> = nbpCOD/VSS <sub>COD</sub>																																																							
: iTSS	67.50 gnbVSS/m <sup>3</sup> = TSS-VSS																																																							
Inlet T-N	70 mg/l																																																							
Inlet TKN	70 mg/l																																																							
Inlet NH <sub>4</sub> -N	45 mg/l																																																							
Inlet T-P	7 mg/l																																																							
Inlet D-P	5 mg/l																																																							
Inlet Alkalinity as CaCO <sub>3</sub>	380 mg/l																																																							
Outlet Kjeldahl N	1.0 mg/l																																																							
Outlet NH <sub>4</sub> -N	1.0 mg/l																																																							
Outlet NO <sub>3</sub> -N	9.0 mg/l																																																							
Outlet T-P	2 mg/l																																																							
Outlet D-P	1 mg/l																																																							
(3) Water Temperature	T = 20.0 °C																																																							
(4) Safety Factor for Nitrogen	SF = 1.5																																																							
(5) Return Sludge Concentration	R <sub>s</sub> = 8,000 mg/l																																																							
(6) MLSS MLVSS	X <sub>TSS</sub> = 3,000 mg/l																																																							
(7) DO in the Reactor	2 mg/L																																																							
<b>[2] Design Value for perfect Nitrification of Nitrification Process</b>																																																								
(1) Activated sludge design kinwtic coefficients at 20°C																																																								
	<table border="1"> <thead> <tr> <th>Coefficient</th> <th>Unit</th> <th>COD oxidatio</th> <th>NH<sub>4</sub> oxidatio</th> <th>NO<sub>2</sub> oxidatio</th> </tr> </thead> <tbody> <tr> <td>μ<sub>max</sub></td> <td>gVSS/gVSS · d</td> <td>6.000</td> <td>0.900</td> <td>1.000</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>mg/L</td> <td>8.000</td> <td>0.500</td> <td>0.200</td> </tr> <tr> <td>Y</td> <td>gVSS/g substrate oxidized</td> <td>0.450</td> <td>0.150</td> <td>0.050</td> </tr> <tr> <td>b</td> <td>gVSS/gVSS · d</td> <td>0.120</td> <td>0.170</td> <td>0.170</td> </tr> <tr> <td>fd</td> <td>unitless</td> <td>0.150</td> <td>0.150</td> <td>0.150</td> </tr> <tr> <td>K<sub>O<sub>2</sub></sub></td> <td>mg/L</td> <td>0.200</td> <td>0.500</td> <td>0.900</td> </tr> <tr> <td>θ Value</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>μ<sub>max</sub></td> <td>unitless</td> <td>1.070</td> <td>1.072</td> <td>1.063</td> </tr> <tr> <td>b</td> <td>unitless</td> <td>1.040</td> <td>1.029</td> <td>1.029</td> </tr> <tr> <td>K<sub>s</sub>, K<sub>NH<sub>4</sub></sub>, K<sub>NO<sub>2</sub></sub></td> <td>unitless</td> <td>1.000</td> <td>1.000</td> <td>1.000</td> </tr> </tbody> </table> <p>Wastwater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF &amp; EDDY/AECOM)</p>	Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio	μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200	Y	gVSS/g substrate oxidized	0.450	0.150	0.050	b	gVSS/gVSS · d	0.120	0.170	0.170	fd	unitless	0.150	0.150	0.150	K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900	θ Value					μ <sub>max</sub>	unitless	1.070	1.072	1.063	b	unitless	1.040	1.029	1.029	K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000
Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio																																																				
μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200																																																				
Y	gVSS/g substrate oxidized	0.450	0.150	0.050																																																				
b	gVSS/gVSS · d	0.120	0.170	0.170																																																				
fd	unitless	0.150	0.150	0.150																																																				
K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900																																																				
θ Value																																																								
μ <sub>max</sub>	unitless	1.070	1.072	1.063																																																				
b	unitless	1.040	1.029	1.029																																																				
K <sub>s</sub> , K <sub>NH<sub>4</sub></sub> , K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000																																																				
(2) μ <sub>AOB</sub>	μ <sub>AOB</sub> = 0.3100 g/g · d = μ <sub>max, AOB</sub> [S <sub>NH<sub>4</sub></sub> / (S <sub>NH<sub>4</sub></sub> + K <sub>NH<sub>4</sub></sub> )] [S <sub>O</sub> / (S <sub>O</sub> + K <sub>O, AOB</sub> )] - b <sub>AOB</sub>																																																							
μ <sub>max, AOB, T</sub>	μ <sub>max, AOB, T</sub> = 0.9000 g/g · d = μ <sub>max</sub> * 1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900																																																							
b <sub>AOB, T</sub>	b <sub>AOB, T</sub> = 0.1700 = b * 1.029 <sup>(T-20)</sup> b at 20°C = 0.170																																																							
S <sub>NH<sub>4</sub></sub>	S <sub>NH<sub>4</sub></sub> = 1.0000 mg/l																																																							
DO	DO = 2.0000 mg/l																																																							
K <sub>O, AOB</sub>	K <sub>O, AOB</sub> = 0.5000 mg/l																																																							

E-5 Process Cal. EA&al 4MLD Chikkabanavara Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

(2) Design SRT	SRT= 4.8387 day = $1/\mu_{AOB} \times SF$ ⇒ 5.0000 day
(3) Biomass production	
P <sub>X,VSS</sub>	1250.815 kg/d = P <sub>X,bio</sub> +Q(nbVSS)
P <sub>X,TSS</sub>	1648.400 kg/d = P <sub>X,bio</sub> /0.85+Q(nbVSS)+Q(TSS <sub>0</sub> -VSS <sub>0</sub> )+5*Q*Al
S	S= 0.4507 mg/l = $Ks[1+b_H(SRT)]/[SRT(\mu_m-b_H)-1]$
b <sub>H</sub>	b <sub>H</sub> = 0.1200 = $b*1.04^{(T-20)}$ b at 20°C = 0.120
Y <sub>H</sub>	Y <sub>H</sub> = 0.4500 gVSS/g bCOD
μ <sub>m,T</sub>	μ <sub>m,T</sub> = 6.0000 g/g·d = $\mu_{max} * 1.04^{(T-20)}$ μ max at 20°C = 6.000
Y <sub>n</sub>	Y <sub>n</sub> = 0.150 gVSS/g Nox
NO <sub>x</sub>	NO <sub>x</sub> = 47.400 mg/l
P <sub>X,bio,VSS</sub>	P <sub>X,bio,VSS</sub> = 722.980 kg VSS/d = $Q \cdot Y_H(S_0-S)/[1+b_H(SRT)] + f_d \cdot b_H \cdot QY_H(S_0-S)SRT/[1+b_H(SRT)]$ + QY <sub>n</sub> (Nox)[2+bAOB(SRT)] 649.180 = $Q \cdot Y_H(S_0-S)/[1+b_H(SRT)]$ 58.426 = $f_d \cdot b_H \cdot QY_H(S_0-S)SRT/[1+b_H(SRT)]$ 15.373 = $QY_n(Nox)[1+b_{AOB}(SRT)]$
NO <sub>x</sub>	NO <sub>x</sub> = 47.311 mg/l = $TKN-N_e - 0.12P_{X,bio}/Q$
(4) Required Aeration Tank Volume	
V <sub>a</sub>	V <sub>a</sub> = 2,747 m <sup>3</sup>
τ	τ = 16.48 hr = V <sub>a</sub> /Q × 24 ⇒ 18.00 hr
X <sub>VSS</sub> · V <sub>a</sub>	X <sub>VSS</sub> · V <sub>a</sub> = 6,254 kg VSS = P <sub>X,VSS</sub> · SRT
X <sub>TSS</sub> · V <sub>a</sub>	X <sub>TSS</sub> · V <sub>a</sub> = 8,242 kg TSS = P <sub>X,TSS</sub> · SRT
F/M	F/M= 0.224 kgBOD/kgMLVSS
FractionVSS	FractionVSS= 0.759
MLVSS	MLVSS= 2276 mg/L
(5) BODloading	BODloading= 0.510 kg/m <sup>3</sup> ·d
(6) Observed Yield	
Y <sub>obs,TSS</sub>	Y <sub>obs,TSS</sub> = 1.178 gTSS/gBOD
Y <sub>obs,VSS</sub>	Y <sub>obs,VSS</sub> = 0.894 gVSS/gBOD
bCODremoved	bCODremov= 2,308 kg/d
(7) effluent NO <sub>2</sub> -N	NO <sub>2</sub> -N= 0.2315 mg/l = $Ks[1+b_{NOB}(SRT)]/[SRT(\mu_{NOB}-b_{NOB})-1]$
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700 = $b*1.029^{(T-20)}$ b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 1.0000 g/g·d = $\mu_{max} * 1.04^{(T-20)}$ μ max at 20°C = 1.000
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.6897 g/g·d = $\mu_{max,NOB}[S_0/(S_0+K_{O2,NOB})]$
	S <sub>0</sub> = 2.000 mg/l
	K <sub>O2,NOB</sub> = 0.900 mg/l
(8) effluent NH <sub>4</sub> -N	NH <sub>4</sub> -N= 0.5286 mg/l = $Ks[1+b_{NOB}(SRT)]/[SRT(\mu_{NOB}-b_{NOB})-1]$
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700 = $b*1.029^{(T-20)}$ b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 0.9000 g/g·d = $\mu_{max} * 1.072^{(T-20)}$ μ max at 20°C = 0.900
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.7200 g/g·d = $\mu_{max,NOB}[S_0/(S_0+K_{O2,NOB})]$
	S <sub>0</sub> = 2.000 mg/l
	K <sub>O2,NOB</sub> = 0.500 mg/l
(9) Ratio of Return Sludge	8,000·Rr/(1+Rr)= 3,000 mg/L 3,000/(8,000-3,000)= 0.60 Rr = 0.60

**STP Process Calculation Supporting Report 12.2.3**

[3] Design for Nitrification and Denitrification Process																					
(1) Active biomass concentration	$X_b = \frac{Q \cdot (SRT) \cdot V \cdot Y_H \cdot (S_0 - S)}{1 + b_H(SRT)}$ $= 1,181.47 \text{ mg/l}$																				
(2) IR ratio	$IR = \frac{NO_x}{Ne} - 1.0 - R$ $= 3.66$																				
(3) The amount of NO <sub>3</sub> -N fed to the anoxic tank	$Nox \text{ feed} = (IR + R) \cdot Q \cdot Ne$ $= 153,242.44 \text{ kg/d}$																				
(4) The anoxic tank volume	$V_{nor} = 275 \text{ m}^3 = V_a \times 10\%$ $V_{nor} = 833 \text{ m}^3 \quad \tau_{DN} = 5.000 \text{ h}$																				
(5) F/M <sub>b</sub>	$F/M_b = 1.42 \text{ g/g} \cdot \text{d}$																				
(6) Fraction of rbCOD	$40.00\% = \frac{rbCOD}{bCOD}$																				
	<table border="1"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b<sub>0</sub></th> <th>b<sub>1</sub></th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>	Percent rdCOD(%)	SDNR equation coefficients		b <sub>0</sub>	b <sub>1</sub>	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162
Percent rdCOD(%)	SDNR equation coefficients																				
	b <sub>0</sub>	b <sub>1</sub>																			
10	0.186	0.078																			
20	0.213	0.118																			
30	0.235	0.141																			
40	0.242	0.152																			
50	0.270	0.162																			
(8) SDNR <sub>b</sub>	$SDNR_b = 0.296 \text{ g/g} \cdot \text{d} = b_0 + b_1 [\ln(F/M_b)]$ $b_0 = 0.242$ $b_1 = 0.152$																				
(8) SDNR	$SDNR = 0.110 \text{ g/g} \cdot \text{d} = SDNR_b (MLVSS_b / MLVSS)$ $SDNR_{adj} = 0.212 \text{ g/g} \cdot \text{d} = SDNR_i - 0.029 \ln(F/M_b) - 0.012 \quad IR=3-4$ $= SDNR_i - 0.0166 \ln(F/M_b) - 0.078 \quad IR=2$ $SDNR_t = 0.296 \text{ g/g} \cdot \text{d} = SDNR_b \cdot \theta^{(4-20)} \quad \theta = 1.026$																				
(9) NO <sub>r</sub>	$NO_r = 208,397.23 \text{ kg/d} = N_{nox} \cdot SDNR \cdot X_b$ $> Nox \text{ feed} = 153,242 \text{ kg/d}$																				
(10) Alkalinity to be added to maintain pH7	$-108.33 \text{ mg/l}$ $\text{Influent Alk} = 380.00 \text{ mg/l}$ $\text{Alk used} = 338.44 \text{ mg/l} = 7.14 \times Nox$ $\text{Alk produced} = 136.77 \text{ mg/l} = 3.57 \times (NO_x - NO_{xe})$ $\text{Alk to maint} = 70.00 \text{ mg/l}$																				
[4] Design of Phosphorous Removal Process																					
(1) Removal T-P	$3.13 \text{ mg/l}$																				
P in waste sludge	$px = 1.00\%$																				
Generated waste sludge	$Px_{VSS} = 1250.815 \text{ kg/d}$																				
Rwmoval Phosphorus	$12.50815211 \text{ kg/d}$																				
(2) Effluent T-P without Al	$3.87 \text{ mg/l}$																				
(3) Required Al to initial soluble phosphorous ratio	$1.00 \text{ mol/mol}$																				
(4) Required Al dosing rate	$3.48 \text{ mg/l} \text{ as Al}$ $42.98 \text{ mg/l} \text{ as crystal, Al}_2(\text{SO}_4)_3 \cdot 18\text{H}_2\text{O}$																				
(5) Required Aluminium Sulphate	$171.91 \text{ kg/d}$																				
(6) Required Aluminium Sulphate sol 10%	$1.64 \text{ m}^3/\text{d}$ $68.22 \text{ L/H}$																				
(7) Additional sludge	$69.69 \text{ kg/d}$																				

**STP Process Calculation Supporting Report 12.2.3**

<b>[5] Reactor</b>																																																																							
(1) Total volume of Aeration Basins	$V_A = Q \cdot \theta_a / 24$ = 3,000 m <sup>3</sup>																																																																						
(2) Total volume of Anoxic Basins	$V_{DN} = Q \cdot \theta_{DN} / 24$ = 833 m <sup>3</sup>																																																																						
		<table border="1"> <thead> <tr> <th rowspan="2">Item</th> <th rowspan="2">Volume required</th> <th colspan="2">Retention Time required</th> <th rowspan="2">Ratio of Volume</th> </tr> <tr> <th>Summer</th> <th>Winter</th> </tr> </thead> <tbody> <tr> <td>unit</td> <td>m<sup>3</sup></td> <td>hour</td> <td>hour</td> <td></td> </tr> <tr> <td>Anaerobic</td> <td><math>V_{AN}</math></td> <td>250</td> <td>1.50</td> <td>1.50</td> <td>0.30</td> </tr> <tr> <td>Anoxic</td> <td><math>V_{DN}</math></td> <td>833</td> <td>5.00</td> <td>5.00</td> <td>1.00</td> </tr> <tr> <td>Aerobic</td> <td><math>V_A</math></td> <td>3,000</td> <td>18.00</td> <td>18.00</td> <td>3.60</td> </tr> <tr> <td>Total</td> <td>V</td> <td>4,083</td> <td>24.50</td> <td>24.50</td> <td></td> </tr> </tbody> </table>	Item	Volume required	Retention Time required		Ratio of Volume	Summer	Winter	unit	m <sup>3</sup>	hour	hour		Anaerobic	$V_{AN}$	250	1.50	1.50	0.30	Anoxic	$V_{DN}$	833	5.00	5.00	1.00	Aerobic	$V_A$	3,000	18.00	18.00	3.60	Total	V	4,083	24.50	24.50																																		
Item	Volume required	Retention Time required			Ratio of Volume																																																																		
		Summer	Winter																																																																				
unit	m <sup>3</sup>	hour	hour																																																																				
Anaerobic	$V_{AN}$	250	1.50	1.50	0.30																																																																		
Anoxic	$V_{DN}$	833	5.00	5.00	1.00																																																																		
Aerobic	$V_A$	3,000	18.00	18.00	3.60																																																																		
Total	V	4,083	24.50	24.50																																																																			
<b>[6] Geometry</b>																																																																							
(1) Basin Dimensions	Width 8.0	Length 51.0	Depth 5.5	Basins 2																																																																			
Cross Section	8.0*5.5	=	44.0	m <sup>2</sup> /Basin																																																																			
Hantzsch Subtraction		=	1.0	m <sup>2</sup> /Basin																																																																			
after Subtraction	44.0-1.0	=	43.0	m <sup>2</sup> /Basin																																																																			
Total Volume	43.0*51.0	=	2,193	m <sup>2</sup> /Basin 4,386 m <sup>3</sup> /Total																																																																			
(2) Partition of Basin																																																																							
		<table border="1"> <thead> <tr> <th>Item</th> <th>unit</th> <th>Anaerobic</th> <th>Anoxic</th> <th>Aerobic</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Cross Section</td> <td>m<sup>2</sup></td> <td colspan="3">43.0</td> <td></td> </tr> <tr> <td>Length required</td> <td>m</td> <td>2.9</td> <td>9.7</td> <td>34.9</td> <td>47.5</td> </tr> <tr> <td>Volume required per Basin</td> <td>m<sup>3</sup></td> <td>125</td> <td>417</td> <td>1,500</td> <td>2,042</td> </tr> <tr> <td>Total Volume required</td> <td>m<sup>3</sup></td> <td>250</td> <td>833</td> <td>3,000</td> <td>4,083</td> </tr> <tr> <td>Actual Cross Section</td> <td>m<sup>2</sup></td> <td>43.0</td> <td>43.0</td> <td>43.0</td> <td></td> </tr> <tr> <td>Actual Length</td> <td>m</td> <td>4.0</td> <td>10.0</td> <td>37.0</td> <td>51.0</td> </tr> <tr> <td>Actual Volume per Basin</td> <td>m<sup>3</sup></td> <td>172</td> <td>430</td> <td>1,591</td> <td>2,193</td> </tr> <tr> <td>Actual Total Volume</td> <td>m<sup>3</sup></td> <td>344</td> <td>860</td> <td>3,182</td> <td>4,386</td> </tr> <tr> <td>Actual Ratio of Volume</td> <td></td> <td>0.40</td> <td>1.00</td> <td>3.70</td> <td></td> </tr> <tr> <td>Actual Retention Time</td> <td>hour</td> <td>2.06</td> <td>5.16</td> <td>19.09</td> <td>26.31</td> </tr> </tbody> </table>	Item	unit	Anaerobic	Anoxic	Aerobic	Total	Cross Section	m <sup>2</sup>	43.0				Length required	m	2.9	9.7	34.9	47.5	Volume required per Basin	m <sup>3</sup>	125	417	1,500	2,042	Total Volume required	m <sup>3</sup>	250	833	3,000	4,083	Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0		Actual Length	m	4.0	10.0	37.0	51.0	Actual Volume per Basin	m <sup>3</sup>	172	430	1,591	2,193	Actual Total Volume	m <sup>3</sup>	344	860	3,182	4,386	Actual Ratio of Volume		0.40	1.00	3.70		Actual Retention Time	hour	2.06	5.16	19.09	26.31			
Item	unit	Anaerobic	Anoxic	Aerobic	Total																																																																		
Cross Section	m <sup>2</sup>	43.0																																																																					
Length required	m	2.9	9.7	34.9	47.5																																																																		
Volume required per Basin	m <sup>3</sup>	125	417	1,500	2,042																																																																		
Total Volume required	m <sup>3</sup>	250	833	3,000	4,083																																																																		
Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0																																																																			
Actual Length	m	4.0	10.0	37.0	51.0																																																																		
Actual Volume per Basin	m <sup>3</sup>	172	430	1,591	2,193																																																																		
Actual Total Volume	m <sup>3</sup>	344	860	3,182	4,386																																																																		
Actual Ratio of Volume		0.40	1.00	3.70																																																																			
Actual Retention Time	hour	2.06	5.16	19.09	26.31																																																																		
<b>[7] Equipment</b>																																																																							
(1) Ras Pumps																																																																							
Ras Ratio	60%																																																																						
Required Capacity	4,000 m <sup>3</sup> /day ×	60% / 24	/	2																																																																			
	= 50 m <sup>3</sup> /Hr	⇒	50	m <sup>3</sup> /Hr																																																																			
Number	2	Work																																																																					
	2	Standby																																																																					
(2) Circulation Pumps																																																																							
Ras Ratio	366%																																																																						
Required Capacity	4,000 m <sup>3</sup> /day ×	366% / 24	/	4																																																																			
	= 152 m <sup>3</sup> /Hr	⇒	155	m <sup>3</sup> /Hr																																																																			
Number	4	Work																																																																					
	2	Standby																																																																					
(3) SAS Pumps																																																																							
Excess Sludge	217 m <sup>3</sup> /day																																																																						
Sludge withdraw	12 Times/day																																																																						
Running Time	0.5 Hr/Time																																																																						
Required Capacity	217 m <sup>3</sup> /day /	12 /	0.50 /	2																																																																			
	= 18.08 m <sup>3</sup> /Hr	⇒	18	m <sup>3</sup> /Hr																																																																			
Number	2	Work																																																																					
	2	Standby																																																																					



E-5 Process Cal, EA&al 4MLD Chikkabanavara Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

(4) Alum Solution Tank										
Number	2	W	+	0	S					
Alum concentration as crystal	10	%								
Gravity of dissolved dechlorine	1.05									
Required solution volume	171.91	kg / d		×	100	/	10	/	1.05 / 1000	
	=	1.64			m3/d					
Volume of Tank	1.0				m3/tank					
Total Volume of Tanks	2.0				m3		(Duration=	1.22	day)	
(5) Mixer for Alum Solution Tank										
Number	2	W	+	0	S					
(6) Alum Dosing Pump										
Number	2	W	+	1	S					
Capacity	1.64	m3/d	/	24	×	1000	/	2	×	2
	68.22	l/h/unit	⇒	70	l/h/unit					

**STP Process Calculation Supporting Report 12.2.3**

<b>6. Air Requirement at Average Flow</b>	
[1] Design Condition	
(1) AOR	AOR = 1,731 kg/day = 72.1 kg/h
Q <sub>in</sub> : Design Average Flow m <sup>3</sup> /d	4,000
Inlet bCOD : S <sub>0</sub>	578 mg/l
S=	0.451 mg/l
Nox=	47.400 mg/l
P <sub>X,bio</sub> =	707.6 kg VSS/d does not include nitrifying bacteria
R <sub>0</sub> =	R <sub>0</sub> = Q(S <sub>0</sub> - S - k(Nox - NOx)) - 1.42P <sub>X,bio</sub> + 4.57Q · NOx
R <sub>0</sub> =	1,731 kg O <sub>2</sub> /d
k=	2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{\text{AOR} \times C_s \cdot a \times 1.024^{20-T}}{\alpha \times F (\beta \cdot C_{sw} / C_s \cdot (P_b / P_a) a - C_A)}$
C <sub>S</sub>	: Saturated DO at sea level and 20 °C 9.09 mg/L
C <sub>SW</sub>	: Saturated DO at sea level and operating Temperature 9.09 mg/L at 20 °C
20-T	: 0.0 1.024 <sup>20-T</sup> : 1.0000
C <sub>A</sub>	: operating DO in Basin 2.0 mg/L
a	: Correction Factor by the Water Depth 1 + 0.40D <sub>j</sub> /P <sub>a</sub> 1.19357
D <sub>j</sub>	: Tank Liquid Depth 5.00 m
P <sub>a</sub>	: Standard absolute pressure at s 10.332 m
P <sub>b</sub>	: Absolute pressure at Plant Site Elevation m
P <sub>b</sub> /P <sub>a</sub>	: exp[-gM(z <sub>b</sub> -z <sub>a</sub> )/R*T] 0.900
g	: Acceleration due to Gravity 9.80665 m/s <sup>2</sup>
M	: Mole of Air 28.97 kg/kg-mole
z <sub>b</sub>	: Plant Site Elevation 900 m
z <sub>a</sub>	: Sea Elevation 0 m
R	: Universal Gas Constant 8314 Nm/kg-mole.K
T	: Temperature 273.15+t = 293.15 Kelvin
α	: relative Transfer Rate to clean Water 0.65
β	: relative DO Saturation to clean Water 0.95
F	: Diffuser Fouling Factor 0.90
	$= \frac{18,776}{4.2591} = 4,408.40 \text{ kg/day}$
(3) No. of Basins	2 Basin
(4) Standard O <sub>2</sub> required at Field Conditions per Basin =	2,204 kg/day
(5) SOTE for the above Effective Aeration Depth	28.0 %
(6) Fraction of O <sub>2</sub> in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	15%
(9) Air required at Field Conditions per Basins	= 32,418 m <sup>3</sup> /day = 1,350.7 m <sup>3</sup> /hr

E-5 Process Cal. EA&al 4MLD Chikkabanavara\_Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

[2] Equipment				
(1) Air Blower				
Number	2	W	+	1 S
Required Capacity	1350.7	m <sup>3</sup> /Hr·Basin	/	1 unit/Basin
	= 1350.7	m <sup>3</sup> /h	⇒	1400 m <sup>3</sup> /h /Unit
Pressure	65	kPa		
Safety Factor	10	%		
Heat capacity ratio	1.4			
Atmospheric pressure at site elevation	91.234	kPa		
Total inlet pressure	89.234	kPa		
Volume rate of flow at inlet point	26.488	m <sup>3</sup> /min		
Total discharge pressure	156.234	kPa		
Overall adiabatic efficiency	0.65			
Inlet air temperature (min.)	15	°C		
Shaft power	37.451	kW		
Rated Output of Motor	41.196	kW	⇒	45 kW

E-5 Process Cal. EA&al 4MLD Chikkabanavara Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>7. Final Clarifire</b></p>			
<p>[1] <b>Design Condition</b></p>			
<p>(1) Design Wastewater Flow</p>	<p>Q= 4,000 m<sup>3</sup>/day</p>		
<p>(2) Water Temperature</p>	<p>T= 20.0 °C</p>		
<p>(3) MLSS</p>	<p>X<sub>ef</sub>= 3,000 mg/l</p>		
<p>(4) SVI</p>	<p>SVI= 300</p>		
<p>(5) Sedimentation Velocity</p>	$v = 4.899 \cdot 10^6 \cdot T^{(0.954)} \cdot X_{ef}^{(-1.354)} \cdot SVI^{(-0.77)}$ $= 4.899 \cdot 10^6 \cdot 20.0^{0.954} \cdot 3,000^{-1.354} \cdot 150^{-0.770}$ $= 20.7 \text{ m/day}$		
<p>(6) Surface Overflow Rate required</p>	$S' = v / (1.5 \cdot 1) = 20.7 / (1.5 \cdot 1.0) = 13.8 \text{ m}^3/\text{m}^2 \cdot \text{day}$	<p>→</p>	$12.0 \text{ m}^3/\text{m}^2 \cdot \text{day}$
<p>[2] <b>Geometry</b></p>			
<p>(1) Surface Area required</p>	$A = 4,000 / 12.0 = 333 \text{ m}^2$		
<p>(2) Demensions</p>	<p>Diameter                  Depth          Basin</p>		
	<p>   <b>15.0</b>                  <b>3.5</b>                  <b>2</b></p>		
<p>(3) Actual Surface Area</p>	$S = 15.0^2 \cdot 3.14 / 4 \cdot 2.0 = 353 \text{ m}^2$		
<p>(4) Surface Overflow Rate</p>	$S = 4,000 / 353 = 11.3 \text{ m}^3/\text{m}^2 \cdot \text{day}$		

E-5 Process Cal. EA&al 4MLD Chikkabanavara Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>8. Chlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Flow      4,000    m <sup>3</sup> /day      166.67    m <sup>3</sup> /h Peak Flow          10,000   m <sup>3</sup> /day      416.67    m <sup>3</sup> /h
(2) Contact Time	30    min
(3) Type of Chlorine	Cl <sub>2</sub> -GAS
(4) Design Chlorine Dosage Rate	10    mg/L
(5) Required Chlorine per day	Average Daily Flow    /    1000    ×      Design Chlorine Dosage Rate =      40.0    kg/d =      1.67    kg/h
<b>[2] Chlorination Contact Tank</b>	
(1) Volume required	Average Daily Flow    /    1440    ×      Contact Time =      83.3    m <sup>3</sup>
(2) Nos. of lanes	3      lanes
(3) Width of lane	1.50    m
(4) Length of lane	14.00   m
(5) Side Water Depth	1.50    m
(6) Nos. of Tanks	1      tank
(7) Total Width of Tank	5.30    m Approx..
(8) Average Velocity	Decant Flow          /      3600    /      Width      /      Depth =      166.67    /      3600    /      1.50      /      1.50 =      0.021    m/sec
(9) Total Volume	Width      ×      Length      ×      Depth      ×      Nos. of lanes      ×      Nos. of Tanks =      1.5      m      ×      14.0      m      ×      1.5      m ×      3      ×      1 =      95      m <sup>3</sup> >      83.3    m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Chlorine Dosing Condition	
Operation Dosage Rate -1	DC1      1 mg/L      10 mg/L
Average Dosage Rate -1	DC2      10 mg/L
(2) Chlorine Cylinder	
Type	-      Cylindrical Convexsd Container
Cylinder Capacity	Cc      928 kg/cylinder
Average Dosage Rate -1	q1      Chlorine -1 : Q <sub>T-D</sub> × DC2 × 10 <sup>-6</sup> × 10 <sup>3</sup> =      40 kg/day
Storage day	T      More than      15 days
Required Storage Capacity	EC1      D × T =      600 kg
Unit Number	EN1      EC1 / Cc =      0.6 cylinders
Maximum Operation Numbers	Vr1      ##### @ 20°C Standard temperature
Cl <sub>2</sub> -Gas Volatilize Rate	DC1      10 mg/L, Q <sub>T-D</sub> × q3 × 10 <sup>-3</sup> / 24 =      #####
Maximum Dosing Rate	EN2      DC1 / Vr1 =      0.5sets
Operation Numbers	
(3) Chlorinator	
Type	Solution Feed Vacuum Type
Number	1      W      +      1      S
Operation Dosage Rate -1	Dq1      Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 4      kg/day to      100      kg/day
Required Dosage Rate	Chlorine -1 : Dq1 / (EN1 × 24) = Minimum                      Maximum 0.17      kg/hr                      4.2      kg/hr

E-5 Process Cal. EA&al 4MLD Chikkabanavara Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p>(4) Chlorine Booster Pump</p> <p>Type</p> <p>Water Demand</p> <p>Chlorinator Discharge</p> <p>Water Demand</p> <p>Chlorinator Discharge</p> <p>Water Demand</p> <p>Water requiamet</p> <p>For Chlorin</p> <p>Booster Pump Type</p> <p>Number</p>	<p>Branchy on the water supply pipe</p> <p>Water requiamet for mixed Chlori</p> <table border="0"> <tr> <td>(kg/hr)</td> <td>1.0</td> <td>1.5</td> <td>2.0</td> <td>2.5</td> <td>3.0</td> <td>4.0</td> </tr> <tr> <td>(L/min)</td> <td>15</td> <td>20</td> <td>25</td> <td>30</td> <td>35</td> <td>40</td> </tr> <tr> <td>(kg/hr)</td> <td>5.0</td> <td>6.0</td> <td>10.0</td> <td>50.0</td> <td>100.0</td> <td>200.0</td> </tr> <tr> <td>(L/min)</td> <td>45</td> <td>50</td> <td>60</td> <td>300</td> <td>600</td> <td>1,200</td> </tr> </table> <p>Water requiamet -</p> <p>Qp1 Maximum dosage rate 4.2 kg/hr therefore 40 L/min</p> <p>Single suction volute pump</p> <p>1 W + 1 S</p>	(kg/hr)	1.0	1.5	2.0	2.5	3.0	4.0	(L/min)	15	20	25	30	35	40	(kg/hr)	5.0	6.0	10.0	50.0	100.0	200.0	(L/min)	45	50	60	300	600	1,200
(kg/hr)	1.0	1.5	2.0	2.5	3.0	4.0																							
(L/min)	15	20	25	30	35	40																							
(kg/hr)	5.0	6.0	10.0	50.0	100.0	200.0																							
(L/min)	45	50	60	300	600	1,200																							
<p><b>9. Dechlorination</b></p> <p>[1] Design Condition</p> <p>(1) Design Flow Rate</p> <p>(2) Contact Time</p> <p>(3) Type of Dechlorine</p> <p>(4) Free Residual Chlorine</p> <p>(5) Consumption per day</p> <p>[2] Dechlorination Contact Tank</p> <p>(1) Volume required</p> <p>(2) Width of lane</p> <p>(3) Length of lane</p> <p>(4) Side Water Depth</p> <p>(5) Nos. of Tanks</p> <p>(6) Total Volume</p> <p>[3] Equipment</p> <p>(1) Dechlorine Solution Tank</p> <p>Number</p> <p>Dechlorine concentration</p> <p>Gravity of dissolved dechlorine</p> <p>Required solution volume</p> <p>Volume of Tank</p> <p>Total Volume of Tanks</p> <p>(2) Mixer for Dechlorine Solution Tank</p> <p>Number</p> <p>(3) Dechlorine Dosing Pump</p> <p>Number</p> <p>Capacity</p>	<p>Average Daily Flow 4,000 m<sup>3</sup>/day</p> <p>10 min</p> <p>Sodium Thiosulfate (Na<sub>2</sub>S<sub>2</sub>O<sub>3</sub> 5H<sub>2</sub>O)</p> <p>1.0 mg/L assumed value</p> <p>Average Daily Flow / 1000 × Free Residual Chlorine × 1.75</p> <p>× 1.5 (safety factor)</p> <p>= 10.50 kg/d</p> <p>= 0.438 kg/h</p> <p>Average Flow Rate / 60 × Contact Time</p> <p>= 27.8 m<sup>3</sup></p> <p>5.30 m</p> <p>4.00 m</p> <p>1.50 m</p> <p>1 tank</p> <p>Width × Length × Depth</p> <p>= 5.3 m × 4.0 m × 1.5 m</p> <p>= 32 m<sup>3</sup> &gt; 27.8 m<sup>3</sup></p> <p>1 W + 0 S</p> <p>10 %</p> <p>1.10</p> <p>10.50 kg/d × 100 / 10 / 1.10 / 1000</p> <p>= 0.10 m<sup>3</sup>/d</p> <p>0.2 m<sup>3</sup>/tank</p> <p>0.2 m<sup>3</sup> (Duration= 2.10 day)</p> <p>1 W + 0 S</p> <p>1 W + 1 S</p> <p>0.24 m<sup>3</sup>/d / 24 × 1000 / 1</p> <p>9.94 l/h/unit ⇒ 10.0 l/h/unit</p>																												

E-5 Process Cal. EA&al 4MLD Chikkabanavara Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>10. Centrifuge</b>  <b>[1] Design Condition</b>                  (1) Type of Dewatering                  (2) Generated Sludge                  (3) Design Polyelectrolyte Dosage                  (4) Volume of Thickend Sludge                  (5) Consistency of Dewatered Sludge                  (6) Operation Time</p>	<p>Centrifuge                  1,735 kg/day                  Polyelectrolyte 5 kg/t-DS·day                  216.9 m<sup>3</sup>/day                  82 %                  12 hours/day (6 days per week)</p>
<p><b>[2] Volume of Centrifuges</b></p>	<p><u>Digested Solids</u>                  Operation Time × No. × Operation/week  <math display="block">= \frac{216.9}{12 \times 1} \times \frac{7}{6} = 21.1</math>                 → 22 m<sup>3</sup>/hour</p>
<p><b>[3] Dewatered Solids</b></p>	<p>Digested Sludge × ( 1 + Injection Rate)                  = 1,735 × ( 1 + 0.0050 )                  = 1,744 kg/day</p>
<p><b>[4] Dewatered Cake Volume</b></p>	<p>Dewatered Solids × <math>\frac{100}{100 - \frac{\text{Moisture Content}}{7}}</math>                  × 6 days per week  <math display="block">= 1.744 \times \frac{100}{100 - \frac{82}{6}} \times \frac{7}{6}</math>                 = 11.30 t/day                  apparent specific gravity 1.00  <math display="block">\frac{11.30}{1.00} = 11.3 \text{ m}^3/\text{day}</math></p>
<p><b>[5] Polyelectrolyte</b>                  (1) Design Polyelectrolyte Dosage                  (2) Required Polyelectrolyte                  (3) Dissolving concentration                  (4) Volume of Polyelectrolyte solution</p>	<p>Polyelectrolyte 5 kg/t-DS·day                  8.68 kg/day                  0.20 %                  4.34 m<sup>3</sup>/day</p>

E-5 Process Cal. EA&al 4MLD Chikkabanavara Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

[6] <b>Equipment</b>							
(1) Centrifuge							
Capacity	22	m <sup>3</sup> /hr					
Number	1	W	+	1	S		
(2) Centrifuge Feed Pumps							
Capacity	22	m <sup>3</sup> /hr					
Number	1	W	+	1	S		
(3) Polyelectrolyte Dosing Pumps							
Volume of Polyelectrolyte solution	4.34	m <sup>3</sup> /day					
Operation Time	12	hours/day		(6 days per week)			
Safety Factor	1.5						
Number	1	W	+	1	S		
Required Capacity	4.34	m <sup>3</sup> /da;	×	7	/	6	/
						12	/
	=	0.42	m <sup>3</sup> /Hr				
Specification Capacity	0.42	m <sup>3</sup> /Hr	×	1.5			
	=	0.633	m <sup>3</sup> /Hr	⇒	0.65	m <sup>3</sup> /Hr /Unit	
(4) Polyelectrolyte dosing System							
Tanks Dimensions							
Width	1.5	m	×	Length	1.0	m	
× Depth		1.8	m	×	2		
	=	5.4	m <sup>3</sup>				
Retention Time of Tanks	5.40	m <sup>3</sup>	/	0.42	m <sup>3</sup> /Hr	/	1
	=	12.802	Hr				
Number	2	W	+	0	S		



E-5 Process Cal. EA&al 4MLD Chikkabanavara Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>11. Centrifuge Feed Sump</b>	
<b>[1] Design Condition</b>	
(1) Generated Thickend Sludge	1,735 kg/day
(2) Solids Consistency	0.80 %
(3) Volume of Excess Sludge	$\begin{aligned} & \text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3} \\ = & 1,735 \times \frac{100}{0.80} \times 10^{-3} \\ = & 217 \text{ m}^3/\text{day} \\ = & 9.04 \text{ m}^3/\text{h} \end{aligned}$
(4) Sludge feed flow rate	22 m <sup>3</sup> /h × 1 = 22 m <sup>3</sup> /h
(5) Centrifuge Operation Time	12 hours/day ( 6 days per week)
<b>[2] Geometry</b>	
(1) Basin Dimensions	$\begin{aligned} & \text{Width } 4.5 \text{ m} \times \text{Length } 4.5 \text{ m} \\ & \times \text{Depth } 3.0 \text{ m} \times 2 \\ = & 121.5 \text{ m}^3 \end{aligned}$
<b>[3] Equipment</b>	
(1) Mixers for Centrifuge Feed Sumps	121.5 m <sup>3</sup>
Required Volume	121.5 m <sup>3</sup>
Number	1 W + 1 S

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Digestion Tank + Centrifugal Dewatering)

Table -1 Input Data

1. Calculation Manner	2	1:Premise that the quality of supernatants are same level removed with inlet sewage 2:Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency	2	1:Total Removal Ratio 2:Outlet Water Quality(input 1or2)
In case of 1 : input data		(%)
In case of 2 : input data	#REF!	(mg/l)
3. Selection of Excess Sludge Generation	2	1:Consideration of Solid Matter Only 2:Consideration of Converting of Solved BOD(input 1or2)
In case of 1 : input data (Sludge generation)		Sludge generation ratio per removal SS(%)
	a	0.4 T2=Q4·S4=(a·S <sub>BOD</sub> +b·S1-c·θ·XA)·Q3/10 <sup>6</sup> · (Excess sludge generation formula)
	b	0.9 a:Converting ratio of solved BOD(mgMLSS/mgBOD)
	c	0.05 b:Converting ratio of SS(mgMLSS/mgSS)
In case of 2 : input data	SBOD	234.50 c:Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)
	XA	3,000 S <sub>BOD</sub> :Solved BOD quality at inlet reactor
	θ	1 XA:MLSS concentration(mg/l)
		θ:Hydraulic retention time(day)


Table -2 Basic Conditions

Sewage Flow and Quality	Sludge Moisture and Recovery Ratio	Digestion Tank Conditions	Chemical Conditions for Dewatering
· Inlet flow : Q <sub>0</sub> (m <sup>3</sup> /D)	4,000	· Primary sludge moisture ratio : W1(%)	0.0
· Inlet quality : S <sub>0</sub> (mg/l)	450	· Excess sludge moisture ratio : W2(%)	99.2
· Total removal ratio : A1(%)	-	· Thickened sludge moisture ratio : W3(%)	99.2
· Effluent quality : S1(mg/l)	10.0	· Digested sludge moisture ratio : W4(%)	99.2
· Sludge generation ratio per removal SS : S1(%)	-	· Dewatered sludge moisture ratio : W5(%)	82.0
		· Removal ratio in primary tank : A2(%)	0.0
		· Recovery ratio in sludge thickener : A3(%)	100.0
		· Recovery ratio in sludge digester : A4(%)	100.0
		· Recovery ratio in dewatering : A5(%)	95.0
		· Content of organics in thickened sludge : A6(%)	75.0
		· Digestion ratio : A7(%)	#REF!
		· Digestion gas generation : A8(Nm <sup>3</sup> /kgVS)	
		· Chemical dosage : A9(%)	0.5
		· Chemical dissolve concentration : A10(%)	0.2

Table -3 Material Balance Calculation

	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
Q(m <sup>3</sup> /day)	4,000	4,212	0	4,212	217	3,995	217	0	0	217	0	4	221	9	212	212	3,995	0
T(t·DS/day)	1,800	1,887	0.000	1,887	1,735	0.040	1,735	0.000	0.000	1,735	0.000	0.009	1,744	1,657	0.087	0.087	0.040	0.112
S(mg/l)	450	448	0	448	8,000	10	8,000	#DIV/0!	0	8,000	0	2,000	7,882	180,000	411	411	10	
X(T5/T0*100)	100	104.8	0.0	104.8	96.4	2.2	96.4	0.0	0.0	96.4	0.0	0.5	96.9	92.0	4.8	4.8	2.2	6.2

Figure -1 Material Balance Model




Calculation Formula						
· Q0=Input Data	· Q3=Q1-Q2	· Q6=T6*100/(100-W3)	· Q9=Q6	· Q12=Q9+Q11	· Q15=Q7+Q10+Q14	· Q5-1=Q5-Q11
· T0=Q0*S0*10 <sup>-6</sup>	· T3=T0*(100-A2)/100	· T6=(T2+T4)*A3/100	· T9=(T6-T8)*A4/100	· T12=T9+T11	· T15=T7+T10+T14	· T5-1=T5-T11
· S0=Input Data	· S3=T3*10 <sup>-6</sup> /Q3	· S6=10 <sup>-6</sup> *Q6*(100-W3)/100	· S9=T9*10 <sup>-6</sup> /Q9	· S12=T12*10 <sup>-6</sup> /Q12	· S15=T15*10 <sup>-6</sup> /Q15	· S5-1=S5
· Q1=Q0+Q15	· Q4=T4*100/(100-W2)	· Q7=(Q2+Q4)-Q6	· Q10=Q6-Q8-Q9	· Q13=T13*100/(100-W5)		
· T1=T0+T15	· T4=余剰汚泥発生式による	· T7=(T2+T4)-T6	· T10=T6-T8-T9	· T13=T12*A5/100		
· S1=T1*10 <sup>-6</sup> /Q1	· S4=10 <sup>-6</sup> *Q4*(100-W2)/100	· S7=T7*10 <sup>-6</sup> /Q7	· S10=T10*10 <sup>-6</sup> /Q10	· S13=10 <sup>-6</sup> *Q13*(100-W5)/100		
· Q2=T2*100/(100-W1)	· Q5=Q3-Q4*(T3-T5)/T4	· Q8=0	· Q11=T10*A9/A10	· Q14=Q12-Q13		
· T2=T1-T3	· T5=Q5*ST/10 <sup>-6</sup>	· T8=T6*A6*A7/10 <sup>-4</sup>	· T11=Q11*S11/10 <sup>-6</sup>	· T14=T12-T13		
· S2=10 <sup>-6</sup> *Q2*(100-W1)/100	· S5=St	#REF!	· S11=10 <sup>-4</sup> *A10	· S14=T14*10 <sup>-6</sup> /Q14		

Material Balance Sheet SD4

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Sheet  
[3MLD STP]



Reference, Process Cal. EA&al 24MLD Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**Design Condition**

Item	24MLD STP-MPS		
(1) Design Flow for the year 2049	Flow Rate		
		m3/d	m3/h
	Daily Average	####	1458
	Daily Maximum	####	1458
	Hourly Max. Peak factor 2.25	####	3281
		m3/s	0.405
		m3/h	1458
		m3/s	0.405
(1) Design Flow for the year 2034	Flow Rate		
		m3/d	m3/h
	Daily Average	####	1000
	Daily Maximum	####	1000
	Hourly Max. Peak factor 2.25	####	2250
		m3/s	0.278
		m3/h	1000
		m3/s	0.278
		m3/s	0.625

**1. Inlet Chamber**

Item	24MLD STP-MPS		
[1] Design Condition			
(1) Design Flow for the year 2049	Max Hourly	=	78,750 m3/d
		=	0.911 m3/sec
(2) Inlet Pipe			
Pipe Diameter	.	×	
Gradient		%	
Roughness Coefficient	n=	0.013	(Manning Formula)
Full Pipe Flow Rate		m3/s	
(3) Influent Water Level	+		m
[2] Geometry			
(1) Number of Basins	1	Basin	
(2) Depth of Basin	0.600	m	Approx.
(3) Width of Basin	4.400	m	Approx.
(4) Length of Basin	2.800	m	Approx.
(5) Volume required of Basin	0.600	×	4.400
		×	2.800
		=	0.9 m3
(6) Retention Time	0.600	×	4.400
		×	2.800
	=	8.11	sec
(7) Basin Demensions	Width	4.400	m
	×	Length	2.800
		×	Depth
		0.600	m

Reference Process Cal. EA&al 24MLD Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**2. Coarse Screen Channel**

Item	24MLD STP-MPS					
[1] Geometry						
(1) Inlet Gate						
Number	3	Main	+	1	Bypass	
Width	0.600	m				
Height	0.900	m				
Floor Level	+	5.000	m			
Bottom	+	0.000	m			
Influent Water Level	+	0.600	m			
Velocity	0.911	/		0.600	/	0.600 / 3
where Design Flow for the year 2049	=	0.844	<	1.000	m/sec	OK
Velocity	0.625	/		0.600	/	0.600 / 2
where Design Flow for the year 2034	=	0.868	<	1.000	m/sec	OK
(2) Screen Channel						
Number	3.0	Main	+	1.0	Bypass	
Width	1.200	m				
Side Water Depth	0.600	m				
Velocity	0.911	/		1.200	/	0.600 / 3
where Design Flow for the year 2049	=	0.422	≅	0.450	m/sec	OK
Velocity	0.625	/		1.200	/	0.600 / 2
where Design Flow for the year 2034	=	0.434	<	0.450	m/sec	OK
(3) Channel Dimensions	Width	1.2	m	×	Length	6.0 m
			×	SWD	0.6	m
[3] Equipment						
(1) Inlet Gate						
Number	3	Main	+	1	Bypass	
Dimension	Width	0.6	m	×	Height	0.9 m
Design Water Level	8.0	m				
(2) Coarse Screens (Main Channel)						
Number	3	W	+	0	S	
Open Space	20	mm				
Bar Thickness	9	mm				
Channel Width	1.2	m				
Width of side plate	50	mm				
Side Water Depth	0.6	m				
Height of Blind Plate at the bottom	50	mm				
Velocity through screen	0.911	/		1.100	/	0.550 / 3
	× ( 20	+	9 ) /	20		
	=	0.728	≅	0.800	m/sec	OK
Velocity through screen	0.625	/		1.100	/	0.550 / 2
where Design Flow for the year 2034	× ( 20	+	9 ) /	20		
	=	0.749	<	0.800	m/sec	OK
(3) Coarse Screens (Bypass Channel)						
Number	0	W	+	1	S	
Open Space	50	mm				
Bar Thickness	9	mm				
Channel Width	1.2	m				
Side Water Depth	0.6	m				
Velocity through screen	0.911	/		1.200	/	0.600 / 3
where Design Flow for the year 2049	× ( 50	+	9 ) /	50		
	=	0.498	<	0.800	m/sec	OK
Velocity through screen	0.625	/		1.200	/	0.600 / 2
where Design Flow for the year 2034	× ( 50	+	9 ) /	50		
	=	0.512	<	0.800	m/sec	OK

Reference Process Cal. EA&al 24MLD Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**3. Raw Sewage Sump**

Item	24MLD STP-MPS	
[2] Geometory		
(1) Raw Sewage Sump		
Number	1	Basin
Dia	14.00	m
Pump Operating Depth	1.500	m
Retention Time whe Design Flow for the year 2049	$( \frac{14.00^2 \times \pi}{4} \times 1.500 ) / 0.911 / 60$	$= 4.22 > 3.75$ min (=minimum time of one pump cycle) OK
Retention Time whe Design Flow for the year 2034	$( \frac{14.00^2 \times \pi}{4} \times 1.500 ) / 0.625 / 60$	$= 6.16 > 3.75$ min (=minimum time of one pump cycle) OK
High Water Level	+ 0.000	m
Pump Off Level	+ -1.500	m
[3] Equipment		
(1) Sewage Pumps 1		
Number	2 W	+ 1 S
Bore Diameter	350	mm
Discharge Flow : 40% Q* 2 whe Design Flow for the year 2034	$0.625 \times 3600 \times 40.0\%$	$900 \Rightarrow 900$ m <sup>3</sup> /Hr
Total Head	15.0	m
(2) Sewage Pumps 2		
Number	1 W	+ 1 S
Bore Diameter	250	mm
Discharge Flow : 20% Q* 1 whe Design Flow for the year 2034	$0.625 \times 3600 \times 20.0\%$	$450 \Rightarrow 450$ m <sup>3</sup> /Hr
Total Head	15.0	m

Reference Process Cal. EA&al 24MLD Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

Item	24MLD STP																																										
<b>1. STP Design Condition</b>																																											
(1) Design Flow Rate	<table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th></th> <th>m<sup>3</sup>/d</th> <th>m<sup>3</sup>/h</th> <th>m<sup>3</sup>/s</th> </tr> </thead> <tbody> <tr> <td>Average Daily</td> <td>24,000</td> <td>1000.00</td> <td>0.278</td> </tr> <tr> <td>Max Daily</td> <td>24,000</td> <td>1000.00</td> <td>0.278</td> </tr> <tr> <td>Max Hourly Peak factor 2.25</td> <td>54,000</td> <td>2250.00</td> <td>0.625</td> </tr> </tbody> </table>			m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s	Average Daily	24,000	1000.00	0.278	Max Daily	24,000	1000.00	0.278	Max Hourly Peak factor 2.25	54,000	2250.00	0.625																									
	m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s																																								
Average Daily	24,000	1000.00	0.278																																								
Max Daily	24,000	1000.00	0.278																																								
Max Hourly Peak factor 2.25	54,000	2250.00	0.625																																								
(2) Design Water Quality	<p style="text-align: right;">Unit: mg/L</p> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="2"></th> <th rowspan="2">BOD</th> <th rowspan="2">COD</th> <th rowspan="2">SS</th> <th colspan="3">T-N</th> <th colspan="2">TP</th> </tr> <tr> <th>NH<sub>4</sub>-N</th> <th>Org-N</th> <th>NOx-N</th> <th>D-P</th> <th>P-P</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td>350</td> <td>800</td> <td>450</td> <td>45.5</td> <td>17.5</td> <td>7</td> <td>5</td> <td>2</td> </tr> <tr> <td>Outlet</td> <td>10</td> <td>50</td> <td>10</td> <td>1</td> <td>0</td> <td>9</td> <td>1</td> <td>1</td> </tr> <tr> <td>Removal rate</td> <td>97.1%</td> <td>93.7%</td> <td>97.8%</td> <td colspan="3">85.7%</td> <td colspan="2">71.4%</td> </tr> </tbody> </table>			BOD	COD	SS	T-N			TP		NH <sub>4</sub> -N	Org-N	NOx-N	D-P	P-P	Inlet	350	800	450	45.5	17.5	7	5	2	Outlet	10	50	10	1	0	9	1	1	Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%	
	BOD	COD					SS	T-N			TP																																
			NH <sub>4</sub> -N	Org-N	NOx-N	D-P		P-P																																			
Inlet	350	800	450	45.5	17.5	7	5	2																																			
Outlet	10	50	10	1	0	9	1	1																																			
Removal rate	97.1%	93.7%	97.8%	85.7%			71.4%																																				
<b>2. Inlet Chamber</b>																																											
<b>[1] Design Condition</b>																																											
(1) Design Flow Rate	Max Hourly	= 54,000 m <sup>3</sup> /day = 0.625 m <sup>3</sup> /sec																																									
<b>[2] Geometry</b>																																											
(1) Number of Basins	1	Basin																																									
(2) Depth of Basin	1.500	m																																									
(3) Width of Basin	2.800	m																																									
(4) Length of Basin	2.800	m																																									
(5) Volume required of Basin	1.500 × 2.800 × 2.800	= 1.5 m <sup>3</sup>																																									
(6) Retention Time	1.500 × 2.800 × 2.800	÷ 0.625 × 1																																									
	= 18.82	sec																																									
(7) Basin Dimensions	Width 2.800 m	× Length 2.800 m																																									
	× Depth 1.500 m																																										

Reference Process Cal. EA&al 24MLD Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

3. Fine Screen Channel	
[1] Design Condition	
(1) Design Wastewater Flow	$\begin{aligned} \text{Max Hourly} &= 54,000 \text{ m}^3/\text{d} \\ &= 0.625 \text{ m}^3/\text{sec} \end{aligned}$
[2] Geometory	
(1) Inlet Gate	
Number	2 Main + 1 Bypass
Width	0.600 m
Height	0.900 m
Floor Level	+ 2.000 m
Bottom	+ 0.000 m
Influent Water Level	+ 0.600 m
Velocity	$\begin{aligned} &0.625 \text{ } \diagdown \quad 0.600 \text{ } \diagdown \quad 0.600 \text{ } \diagdown \quad 2 \\ = &0.868 \text{ } \div \quad 1.000 \text{ m/sec} \end{aligned}$
(2) Screen Channel	
Number	2 Main + 1 Bypass
Width	1.200 m
Side Water Depth	0.600 m
Velocity	$\begin{aligned} &0.625 \text{ } \diagdown \quad 1.200 \text{ } \diagdown \quad 0.600 \text{ } \diagdown \quad 2 \\ = &0.434 \text{ } \div \quad 0.450 \text{ m/sec} \end{aligned}$
(3) Channel Dimensions	$\begin{aligned} \text{Width} &1.2 \text{ m} \times \text{Length} &6.0 \text{ m} \\ &\times \text{SWD} &0.6 \text{ m} \end{aligned}$
[3] Equipment	
(1) Inlet Gate	
Number	2 W + 1 S
Dimension	Width 0.6 m × Height 0.90 m
Design Water Level	2.00 m
(2) Fine Screens (Main Channel)	
Number	2 W + 0 S
Open Space	6 mm
Bar Thickness	2 mm
Channel Width	1.2 m
Width of side plate	50 mm
Side Water Depth	0.6 m
Height of Blind Plate at the bottom	50 mm
Velocity through screen	$\begin{aligned} &0.625 \text{ } \diagdown \quad 1.100 \text{ } \diagdown \quad 0.550 \text{ } \diagdown \quad 2 \\ &\times ( \frac{6}{6} + \frac{2}{6} ) / 6 \\ = &0.689 < 0.800 \text{ m/sec} \end{aligned}$
(3) Fine Screens (Bypass Channel)	
Number	0 W + 1 S
Open Space	20 mm
Bar Thickness	9 mm
Channel Width	1.2 m
Side Water Depth	0.6 m
Velocity through screen	$\begin{aligned} &0.625 \text{ } \diagdown \quad 1.200 \text{ } \diagdown \quad 0.600 \text{ } \diagdown \quad 2 \\ &\times ( \frac{20}{20} + \frac{9}{20} ) / 20 \\ = &0.629 < 0.800 \text{ m/sec} \end{aligned}$



Reference Process Cal. EA&al 24MLD Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<b>4. Grit Chamber</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Peak flow = 54,000 m <sup>3</sup> /day = 0.625 m <sup>3</sup> /sec
(2) Specific gravity of Sand	2.65
(3) Sedimentation Velocity	0.0111 m/sec = 960 m <sup>3</sup> /m <sup>2</sup> /day
(4) Average Velocity	0.3 m/sec
<b>[2] Grit Chamber</b>	
(1) Surface Area required	0.625 / 0.0111 = 56.31 m <sup>2</sup>
(2) Number of Basins	1 S + 1 W
(3) Surface Area required/Basin	56.3 / 1 = 56.31 m <sup>2</sup>
(4) Length of Basin	56.31 ^0.5 = 7.504 m → 7.5 m
(5) HRT in Grit Chamber	60 sec
(6) Volume required of Basin	0.625 × 60 sec / 1 = 37.5 m <sup>3</sup>
(7) Depth required	37.5 / 7.5 / 7.5 = 0.667 m
(8) Basin Dimensions	Width 7.5 m × Length 7.5 m × Depth 0.7 m (Freeboard 0.3m)
(9) Retention Time	7.5 × 7.5 × 0.7 / 0.625 × 1 = 60.00 sec
(10) Surface Overflow Rate at Peak Flow	54,000 / 7.5 / 7.5 / 1 = 960 < 960 m <sup>3</sup> /m <sup>2</sup> /day
<b>[3] Parshall Flume</b>	
(1) Design Flow Rate	Q= 625.000 l/sec
(2) Throat width	W= 0.600 m
(3) Water depth Ha	Ha= ( Q / 2264 / W ) <sup>2/3</sup> Ha= 0.596 m
(4) Crest Level	+ m ≐ Minimum water level at downstream channel
(5) Water level at the crest	+ 0.596 m
(6) Channel bottom level	+ m
(7) Upstream Channel width	1.500 m
(8) SWD of Upstream Channel	0.700 m
(9) Average velocity at upstream channel	0.595 m/sec
(10) Total Length of channel	12.000 m
<b>[4] Inlet Weir Gate</b>	
(1) Number	4 Units
(2) Weir Width	0.800 m
(3) Stroke	0.450 m
(4) Overflow Height	0.400 m
(5) Overflow Height (actual)	( 0.625 / 1.840 / 0.800 / 4 ) <sup>2/3</sup> = 0.224 < 0.400 m

**STP Process Calculation\_Supporting Report 12.2.3**

<b>5. Reactor</b>																																																								
<b>[1] Design Condition</b>																																																								
(1) Design Wastewater Flow	Q= 24,000 m <sup>3</sup> /day (summer) Q' = 24,000 m <sup>3</sup> /day(Winter)																																																							
(2) Design Sewage Quality																																																								
Inlet BOD	350 mg/l																																																							
Outlet BOD	10.0 mg/l																																																							
Inlet S-BOD	235 mg/l assumed as 67% of BOD																																																							
Inlet COD	800 mg/l																																																							
Inlet bCOD :S <sub>0</sub>	578 mg/l																																																							
Inlet nbCOD	223 mg/l																																																							
bCOD/BOD	1.65																																																							
Inlet S-COD :sCOD	271 mg/l																																																							
Inlet rbCOD	231 mg/l bCOD*40%																																																							
Inlet sbCOD	347 mg/l bCOD*60%																																																							
Outlet S-COD :nbsCODe	40 mg/l																																																							
:nbpCOD	183 mg/l =TCOD-bCOD-nbsCODe																																																							
Inlet SS	450 mg/l																																																							
Inlet VSS	383 mg/l assumed as 85% of TSS																																																							
:VSS <sub>COD</sub>	1.38 gCOD/gVSS =(TCOD-sCOD)/VSS																																																							
:nbVSS	131.96 gnbVSS/m <sup>3</sup> =nbpCOD/VSS <sub>COD</sub>																																																							
:iTSS	67.50 gnbVSS/m <sup>3</sup> =TSS-VSS																																																							
Inlet T-N	70 mg/l																																																							
Inlet TKN	70 mg/l																																																							
Inlet NH <sub>4</sub> -N	45.0 mg/l																																																							
Inlet T-P	7 mg/l																																																							
Inlet D-P	5 mg/l																																																							
Inlet Alkalinity as CaCO <sub>3</sub>	380 mg/l																																																							
Outlet Kjeldahl N	1.0 mg/l																																																							
Outlet NH <sub>4</sub> -N	1.0 mg/l																																																							
Outlet NO <sub>3</sub> -N	9.0 mg/l																																																							
Outlet T-P	2 mg/l																																																							
Outlet D-P	1 mg/l																																																							
(3) Water Temperature	T= 20.0 °C																																																							
(4) Safety Factor for Nitrogen	SF= 1.5																																																							
(5) Return Sludge Concentration	R <sub>s</sub> = 8,000 mg/l																																																							
(6) MLSS MLVSS	X <sub>TSS</sub> = 3,000 mg/l																																																							
(7) DO in the Reactor	2 mg/L																																																							
<b>[2] Design Value for perfect Nitrification of Nitrification Process</b>																																																								
(1) Activated sludge design kinwtic coefficients at 20°C																																																								
	<table border="1"> <thead> <tr> <th>Coefficient</th> <th>Unit</th> <th>COD oxidatio</th> <th>NH<sub>4</sub> oxidatio</th> <th>NO<sub>2</sub> oxidatio</th> </tr> </thead> <tbody> <tr> <td>μ<sub>max</sub></td> <td>gVSS/gVSS · d</td> <td>6.000</td> <td>0.900</td> <td>1.000</td> </tr> <tr> <td>K<sub>s</sub>,K<sub>NH<sub>4</sub></sub>,K<sub>NO<sub>2</sub></sub></td> <td>mg/L</td> <td>8.000</td> <td>0.500</td> <td>0.200</td> </tr> <tr> <td>Y</td> <td>gVSS/g substrate oxidized</td> <td>0.450</td> <td>0.150</td> <td>0.050</td> </tr> <tr> <td>b</td> <td>gVSS/gVSS · d</td> <td>0.120</td> <td>0.170</td> <td>0.170</td> </tr> <tr> <td>fd</td> <td>unitless</td> <td>0.150</td> <td>0.150</td> <td>0.150</td> </tr> <tr> <td>K<sub>O<sub>2</sub></sub></td> <td>mg/L</td> <td>0.200</td> <td>0.500</td> <td>0.900</td> </tr> <tr> <td>θ Value</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>μ<sub>max</sub></td> <td>unitless</td> <td>1.070</td> <td>1.072</td> <td>1.063</td> </tr> <tr> <td>b</td> <td>unitless</td> <td>1.040</td> <td>1.029</td> <td>1.029</td> </tr> <tr> <td>K<sub>s</sub>,K<sub>NH<sub>4</sub></sub>,K<sub>NO<sub>2</sub></sub></td> <td>unitless</td> <td>1.000</td> <td>1.000</td> <td>1.000</td> </tr> </tbody> </table> <p>Wastwater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF &amp; EDDY/AECOM)</p>	Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio	μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000	K <sub>s</sub> ,K <sub>NH<sub>4</sub></sub> ,K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200	Y	gVSS/g substrate oxidized	0.450	0.150	0.050	b	gVSS/gVSS · d	0.120	0.170	0.170	fd	unitless	0.150	0.150	0.150	K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900	θ Value					μ <sub>max</sub>	unitless	1.070	1.072	1.063	b	unitless	1.040	1.029	1.029	K <sub>s</sub> ,K <sub>NH<sub>4</sub></sub> ,K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000
Coefficient	Unit	COD oxidatio	NH <sub>4</sub> oxidatio	NO <sub>2</sub> oxidatio																																																				
μ <sub>max</sub>	gVSS/gVSS · d	6.000	0.900	1.000																																																				
K <sub>s</sub> ,K <sub>NH<sub>4</sub></sub> ,K <sub>NO<sub>2</sub></sub>	mg/L	8.000	0.500	0.200																																																				
Y	gVSS/g substrate oxidized	0.450	0.150	0.050																																																				
b	gVSS/gVSS · d	0.120	0.170	0.170																																																				
fd	unitless	0.150	0.150	0.150																																																				
K <sub>O<sub>2</sub></sub>	mg/L	0.200	0.500	0.900																																																				
θ Value																																																								
μ <sub>max</sub>	unitless	1.070	1.072	1.063																																																				
b	unitless	1.040	1.029	1.029																																																				
K <sub>s</sub> ,K <sub>NH<sub>4</sub></sub> ,K <sub>NO<sub>2</sub></sub>	unitless	1.000	1.000	1.000																																																				
(2) μ <sub>AOB</sub>	μ <sub>AOB</sub> = 0.3100 g/g · d = μ <sub>max,AOB</sub> [S <sub>NH<sub>4</sub></sub> /(S <sub>NH<sub>4</sub></sub> +K <sub>NH<sub>4</sub></sub> )] [S <sub>0</sub> /(S <sub>0</sub> +K <sub>O,AOB</sub> )] - b <sub>AOB</sub>																																																							
μ <sub>max,AOB,T</sub>	μ <sub>max,AOB,T</sub> = 0.9000 g/g · d = μ <sub>max</sub> * 1.072 <sup>(T-20)</sup> μ <sub>max</sub> at 20°C = 0.900																																																							
b <sub>AOB,T</sub>	b <sub>AOB,T</sub> = 0.1700 = b * 1.029 <sup>(T-20)</sup> b at 20°C = 0.170																																																							
S <sub>NH<sub>4</sub></sub>	S <sub>NH<sub>4</sub></sub> = 1.0000 mg/l																																																							
DO	DO = 2.0000 mg/l																																																							
K <sub>O,AOB</sub>	K <sub>O,AOB</sub> = 0.5000 mg/l																																																							

Reference\_Process Cal. EA&al 24MLD.Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

(2) Design SRT	SRT= 4.8387 day = $1/\mu_{AOB} \times SF$ ⇒ 5.0000 day
(3) Biomass production	
P <sub>X,VSS</sub>	7504.891 kg/d = P <sub>X,bio</sub> +Q(nbVSS)
P <sub>X,TSS</sub>	9890.399 kg/d = P <sub>X,bio</sub> /0.85+Q(nbVSS)+Q(TSS <sub>0</sub> -VSS <sub>0</sub> )+5*Q*Al
S	S= 0.4507 mg/l = $K_s[1+b_H(SRT)]/[SRT(\mu_{m,b_H}-1)]$
b <sub>H</sub>	b <sub>H</sub> = 0.1200 = $b * 1.04^{(T-20)}$ b at 20°C = 0.120
Y <sub>H</sub>	Y <sub>H</sub> = 0.4500 gVSS/g bCOD
μ <sub>m,T</sub>	μ <sub>m,T</sub> = 6.0000 g/g·d = $\mu_{max} * 1.04^{(T-20)}$ μ max at 20°C = 6.000
Y <sub>n</sub>	Y <sub>n</sub> = 0.150 gVSS/g Nox
NOx	NOx= 47.400 mg/l
P <sub>X,bio,VSS</sub>	P <sub>X,bio,VSS</sub> = 4337.878 kg VSS/d = $Q \cdot Y_H(S_0-S)/[1+b_H(SRT)] + f_d \cdot b_H \cdot QY_H(S_0-S)SRT/[1+b_H(SRT)]$ + QY <sub>n</sub> (Nox)[2+bAOB(SRT)] 3895.083 = $Q \cdot Y_H(S_0-S)/[1+b_H(SRT)]$ 350.557 = $f_d \cdot b_H \cdot QY_H(S_0-S)SRT/[1+b_H(SRT)]$ 92.238 = $QY_n(Nox)[1+b_{AOB}(SRT)]$
NOx	NOx= 47.311 mg/l = $TKN - Ne - 0.12P_{X,bio}/Q$
(4) Required Aeration Tank Volume	
V <sub>a</sub>	V <sub>a</sub> = 16,484 m <sup>3</sup>
τ	τ = 16.48 hr = V <sub>a</sub> /Q × 24 ⇒ 18.00 hr
X <sub>VSS</sub> · V <sub>a</sub>	X <sub>VSS</sub> · V <sub>a</sub> = 37,524 kg VSS = P <sub>X,VSS</sub> · SRT
X <sub>TSS</sub> · V <sub>a</sub>	X <sub>TSS</sub> · V <sub>a</sub> = 49,452 kg TSS = P <sub>X,TSS</sub> · SRT
F/M	F/M= 0.224 kgBOD/kgMLVSS
FractionVSS	FractionVSS= 0.759
MLVSS	MLVSS= 2276 mg/L
(5) BODloading	BODloading= 0.510 kg/m <sup>3</sup> ·d
(6) Observed Yield	
Y <sub>obs,TSS</sub>	Y <sub>obs,TSS</sub> = 1.178 gTSS/gBOD
Y <sub>obs,VSS</sub>	Y <sub>obs,VSS</sub> = 0.894 gVSS/gBOD
bCODremoved	bCODremov= 13,849 kg/d
(7) effluent NO <sub>2</sub> -N	NO <sub>2</sub> -N= 0.2315 mg/l = $K_s[1+b_{NOB}(SRT)]/[SRT(\mu_{NOB}-b_{NOB})-1]$
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700 = $b * 1.029^{(T-20)}$ b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 1.0000 g/g·d = $\mu_{max} * 1.04^{(T-20)}$ μ max at 20°C = 1.000
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.6897 g/g·d = $\mu_{max,NOB}[S_0/(S_0+K_{O2,NOB})]$
	S <sub>0</sub> = 2.000 mg/l
	K <sub>O2,NOB</sub> = 0.900 mg/l
(8) effluent NH <sub>4</sub> -N	NH <sub>4</sub> -N= 0.5286 mg/l = $K_s[1+b_{NOB}(SRT)]/[SRT(\mu_{NOB}-b_{NOB})-1]$
b <sub>NOB</sub>	b <sub>NOB</sub> = 0.1700 = $b * 1.029^{(T-20)}$ b at 20°C = 0.170
μ <sub>m,T</sub>	μ <sub>max,NOB,T</sub> = 0.9000 g/g·d = $\mu_{max} * 1.072^{(T-20)}$ μ max at 20°C = 0.900
μ <sub>AOB</sub>	μ <sub>NOB,T</sub> = 0.7200 g/g·d = $\mu_{max,NOB}[S_0/(S_0+K_{O2,NOB})]$
	S <sub>0</sub> = 2.000 mg/l
	K <sub>O2,NOB</sub> = 0.500 mg/l
(9) Ratio of Return Sludge	8,000*R <sub>r</sub> /(1+R <sub>r</sub> )= 3,000 mg/L 3,000/(8,000-3,000)= 0.60 R <sub>r</sub> = 0.60

**STP Process Calculation\_Supporting Report 12.2.3**

[3] Design for Nitrification and Denitrification Process																					
(1) Active biomass concentration	$X_b = \frac{Q \cdot (SRT) \cdot V \cdot Y_H \cdot (S_0 - S)}{1 + b_H(SRT)}$ $= 1,181.47 \text{ mg/l}$																				
(2) IR ratio	$IR = \frac{NOx}{Ne} - 1.0 - R$ $= 3.66$																				
(3) The amount of NO3-N fed to the anoxic tank	$Nox \text{ feed} = (IR + R) \cdot Q \cdot Ne$ $= 919,454.64 \text{ kg/d}$																				
(4) The anoxic tank volume	$V_{nor} = 1,648 \text{ m}^3 = V_a \times 10\%$ $V_{nor} = 5,000 \text{ m}^3 \quad \tau_{DN} = 5,000 \text{ h}$																				
(5) F/M <sub>b</sub>	$F/M_b = 1.42 \text{ g/g} \cdot \text{d}$																				
(6) Fraction of rbCOD	$40.00\% = \frac{rbCOD}{bCOD}$																				
	<table border="1"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b<sub>0</sub></th> <th>b<sub>1</sub></th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>	Percent rdCOD(%)	SDNR equation coefficients		b <sub>0</sub>	b <sub>1</sub>	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162
Percent rdCOD(%)	SDNR equation coefficients																				
	b <sub>0</sub>	b <sub>1</sub>																			
10	0.186	0.078																			
20	0.213	0.118																			
30	0.235	0.141																			
40	0.242	0.152																			
50	0.270	0.162																			
(8) SDNR <sub>b</sub>	$SDNR_b = 0.296 \text{ g/g} \cdot \text{d} = b_0 + b_1 [\ln(F/M_b)]$ $b_0 = 0.242$ $b_1 = 0.152$																				
(8) SDNR	$SDNR = 0.110 \text{ g/g} \cdot \text{d} = SDNR_b (MLVSS_b / MLVSS)$ $SDNR_{adj} = 0.212 \text{ g/g} \cdot \text{d} = SDNR_i - 0.029 \ln(F/M_b) - 0.012 \quad IR=3-4$ $= SDNR_i - 0.0166 \ln(F/M_b) - 0.078 \quad IR=2$ $SDNR_t = 0.296 \text{ g/g} \cdot \text{d} = SDNR_b \cdot \theta^{(4-20)} \quad \theta = 1.026$																				
(9) NO <sub>r</sub>	$NO_r = 1,250,383.39 \text{ kg/d} = N_{nox} \cdot SDNR \cdot X_b$ $> Nox \text{ feed} = 919,455 \text{ kg/d}$																				
(10) Alkalinity to be added to maintain pH7	$-108.33 \text{ mg/l}$ <p>Influent Alk 380.00 mg/l                      Alk used 338.44 mg/l = 7.14 × Nox                      Alk produced 136.77 mg/l = 3.57 × (NOx - NO<sub>x</sub>e)                      Alk to maint 70.00 mg/l</p>																				
[4] Design of Phosphorous Removal Process																					
(1) Removal T-P	3.13 mg/l																				
P in waste sludge	px = 1.00%																				
Generated waste sludge	Px <sub>vss</sub> = 7504.891 kg/d																				
Rwmoval Phosphorus	75.04891264 kg/d																				
(2) Effluent T-P without Al	3.87 mg/l																				
(3) Required Al to initial soluble phosphorous ratio	1.00 mol/mol																				
(4) Required Al dosing rate	3.48 mg/l as Al																				
	42.98 mg/l as crystal, Al <sub>2</sub> (SO <sub>4</sub> ) <sub>3</sub> · 18H <sub>2</sub> O																				
(5) Required Aluminum Sulfate	1,031.46 kg/d																				
(6) Required Aluminum Sulfate solutic 10%	9.82 m <sup>3</sup> /d																				
	409.31 L/H																				
(7) Additional sludge	418.16 kg/d																				

**STP Process Calculation\_Supporting Report 12.2.3**

<b>[5] Reactor</b>																																																																							
(1) Total volume of Aeration Basins	$V_A = Q \cdot \theta_a / 24$ = 18,000 m <sup>3</sup>																																																																						
(2) Total volume of Anoxic Basins	$V_{DN} = Q \cdot \theta_{DN} / 24$ = 5,000 m <sup>3</sup>																																																																						
		<table border="1"> <thead> <tr> <th rowspan="2">Item</th> <th rowspan="2">Volume required</th> <th colspan="2">Retention Time required</th> <th rowspan="2">Ratio of Volume</th> </tr> <tr> <th>Summer</th> <th>Winter</th> </tr> <tr> <th colspan="2">unit</th> <th>m<sup>3</sup></th> <th>hour</th> <th>hour</th> </tr> </thead> <tbody> <tr> <td>Anaerobic</td> <td>V<sub>AN</sub></td> <td>1,500</td> <td>1.50</td> <td>1.50</td> <td>0.30</td> </tr> <tr> <td>Anoxic</td> <td>V<sub>DN</sub></td> <td>5,000</td> <td>5.00</td> <td>5.00</td> <td>1.00</td> </tr> <tr> <td>Aerobic</td> <td>V<sub>A</sub></td> <td>18,000</td> <td>18.00</td> <td>18.00</td> <td>3.60</td> </tr> <tr> <td>Total</td> <td>V</td> <td>24,500</td> <td>24.50</td> <td>24.50</td> <td></td> </tr> </tbody> </table>	Item	Volume required	Retention Time required		Ratio of Volume	Summer	Winter	unit		m <sup>3</sup>	hour	hour	Anaerobic	V <sub>AN</sub>	1,500	1.50	1.50	0.30	Anoxic	V <sub>DN</sub>	5,000	5.00	5.00	1.00	Aerobic	V <sub>A</sub>	18,000	18.00	18.00	3.60	Total	V	24,500	24.50	24.50																																		
Item	Volume required	Retention Time required			Ratio of Volume																																																																		
		Summer	Winter																																																																				
unit		m <sup>3</sup>	hour	hour																																																																			
Anaerobic	V <sub>AN</sub>	1,500	1.50	1.50	0.30																																																																		
Anoxic	V <sub>DN</sub>	5,000	5.00	5.00	1.00																																																																		
Aerobic	V <sub>A</sub>	18,000	18.00	18.00	3.60																																																																		
Total	V	24,500	24.50	24.50																																																																			
<b>[6] Geometry</b>																																																																							
(1) Basin Dimensions	Width 8.0	Length 147.0	Depth 5.5	Basins 4																																																																			
Cross Section	8.0*5.5 =		44.0 m <sup>2</sup> /Basin																																																																				
Hantzsich Subtraction	=		1.0 m <sup>2</sup> /Basin																																																																				
after Subtraction	44.0-1.0 =		43.0 m <sup>2</sup> /Basin																																																																				
Total Volume	43.0*147.0 =		6,321 m <sup>2</sup> /Basin 25,284 m <sup>3</sup> /Total																																																																				
(2) Partition of Basin	<table border="1"> <thead> <tr> <th>Item</th> <th>unit</th> <th>Anaerobic</th> <th>Anoxic</th> <th>Aerobic</th> <th>Total</th> </tr> </thead> <tbody> <tr> <td>Cross Section</td> <td>m<sup>2</sup></td> <td colspan="3">43.0</td> <td></td> </tr> <tr> <td>Length required</td> <td>m</td> <td>8.7</td> <td>29.1</td> <td>104.7</td> <td>142.4</td> </tr> <tr> <td>Volume required per Basin</td> <td>m<sup>3</sup></td> <td>375</td> <td>1,250</td> <td>4,500</td> <td>6,125</td> </tr> <tr> <td>Total Volume required</td> <td>m<sup>3</sup></td> <td>1,500</td> <td>5,000</td> <td>18,000</td> <td>24,500</td> </tr> <tr> <td>Actual Cross Section</td> <td>m<sup>2</sup></td> <td>43.0</td> <td>43.0</td> <td>43.0</td> <td></td> </tr> <tr> <td>Actual Length</td> <td>m</td> <td>10.0</td> <td>30.0</td> <td>107.0</td> <td>147.0</td> </tr> <tr> <td>Actual Volume per Basin</td> <td>m<sup>3</sup></td> <td>430</td> <td>1,290</td> <td>4,601</td> <td>6,321</td> </tr> <tr> <td>Actual Total Volume</td> <td>m<sup>3</sup></td> <td>1,720</td> <td>5,160</td> <td>18,404</td> <td>25,284</td> </tr> <tr> <td>Actual Ratio of Volume</td> <td></td> <td>0.33</td> <td>1.00</td> <td>3.57</td> <td></td> </tr> <tr> <td>Actual Retention Time</td> <td>hour</td> <td>1.72</td> <td>5.16</td> <td>18.40</td> <td>25.28</td> </tr> </tbody> </table>					Item	unit	Anaerobic	Anoxic	Aerobic	Total	Cross Section	m <sup>2</sup>	43.0				Length required	m	8.7	29.1	104.7	142.4	Volume required per Basin	m <sup>3</sup>	375	1,250	4,500	6,125	Total Volume required	m <sup>3</sup>	1,500	5,000	18,000	24,500	Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0		Actual Length	m	10.0	30.0	107.0	147.0	Actual Volume per Basin	m <sup>3</sup>	430	1,290	4,601	6,321	Actual Total Volume	m <sup>3</sup>	1,720	5,160	18,404	25,284	Actual Ratio of Volume		0.33	1.00	3.57		Actual Retention Time	hour	1.72	5.16	18.40	25.28
Item	unit	Anaerobic	Anoxic	Aerobic	Total																																																																		
Cross Section	m <sup>2</sup>	43.0																																																																					
Length required	m	8.7	29.1	104.7	142.4																																																																		
Volume required per Basin	m <sup>3</sup>	375	1,250	4,500	6,125																																																																		
Total Volume required	m <sup>3</sup>	1,500	5,000	18,000	24,500																																																																		
Actual Cross Section	m <sup>2</sup>	43.0	43.0	43.0																																																																			
Actual Length	m	10.0	30.0	107.0	147.0																																																																		
Actual Volume per Basin	m <sup>3</sup>	430	1,290	4,601	6,321																																																																		
Actual Total Volume	m <sup>3</sup>	1,720	5,160	18,404	25,284																																																																		
Actual Ratio of Volume		0.33	1.00	3.57																																																																			
Actual Retention Time	hour	1.72	5.16	18.40	25.28																																																																		
<b>[7] Equipment</b>																																																																							
(1) Ras Pumps																																																																							
Ras Ratio	60%																																																																						
Required Capacity	24,000 m <sup>3</sup> /day ×	60% / 24 /			4																																																																		
	= 150 m <sup>3</sup> /Hr ⇒	150 m <sup>3</sup> /Hr																																																																					
Number	4 Work																																																																						
	4 Stanby																																																																						
(2) Circulation Pumps																																																																							
Ras Ratio	366%																																																																						
Required Capacity	24,000 m <sup>3</sup> /day ×	366% / 24 /			8																																																																		
	= 457 m <sup>3</sup> /Hr ⇒	460 m <sup>3</sup> /Hr																																																																					
Number	8 Work																																																																						
	4 Stanby																																																																						
(3) SAS Pumps																																																																							
Excess Sludge	1,446 m <sup>3</sup> /day																																																																						
Sludge withdraw	12 Times/day																																																																						
Running Time	0.5 Hr/Time																																																																						
Required Capacity	1,446 m <sup>3</sup> /day /	12 /		0.50 / 4																																																																			
	= 60.26 m <sup>3</sup> /Hr ⇒	65 m <sup>3</sup> /Hr																																																																					
Number	4 Work																																																																						
	4 Stanby																																																																						

Reference\_Process Cal, EA&al 24MLD,Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

(4) Alum Solution Tank										
Number	2	W	+	0	S					
Alum concentration as crystal	10	%								
Gravity of dissolved dechlorine	1.05									
Required solution volume	1031.46	kg / d	×	100	/	10	/	1.05	/	1000
	=	9.82		m3/d						
Volume of Tank	5.1	m3/tank	(=	1.6	mW×	1.6	mL×	2.0	mH)	
Total Volume of Tanks	10.2	m3	(Duration=			1.04	day)			
(5) Mixer for Alum Solution Tank										
Number	2	W	+	0	S					
(6) Alum Dosing Pump										
Number	2	W	+	1	S					
Capacity	9.82	m3/d	/	24	×	1000	/	2	×	2
	409.31	l/h/unit	⇒	410	l/h/unit					

Reference: Process Cal. EA&al 24MLD Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>6. Air Requirement at Average Flow</b>	
[1] Design Condition	
(1) AOR	AOR = 10,383 kg/day = 432.6 kg/h
Q <sub>in</sub> : Design Average Flow m <sup>3</sup> /d	24,000
Inlet bCOD : S <sub>0</sub>	578 mg/l
S=	0.451 mg/l
Nox=	47.400 mg/l
P <sub>X,bio</sub> =	4,245.6 kg VSS/d does not include nitrifying bacteria
R <sub>0</sub> =	R <sub>0</sub> = Q(S <sub>0</sub> -S-k(Nox-NOx))-1.42P <sub>X,bio</sub> +4.57Q·NOx
R <sub>0</sub> =	10,383 kg O <sub>2</sub> /d
k=	2.86
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{\text{AOR} \times C_s \cdot a \times 1.024^{20-T}}{\alpha \times F (\beta \cdot C_{sW} / C_s \cdot (P_b/P_a)a - C_A)}$
	C <sub>s</sub> : Saturated DO at sea level and 20 °C 9.09 mg/L
	C <sub>sW</sub> : Saturated DO at sea level and operating Temperature 9.09 mg/L at 20 °C
	20-T : 0.0 1.024 <sup>20-T</sup> : 1.0000
	C <sub>A</sub> : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1+0.40D <sub>j</sub> /P <sub>a</sub> 1.19357
	D <sub>j</sub> : Tank Liquid Depth 5.00 m
	P <sub>a</sub> : Standard absolute pressure at s 10.332 m
	P <sub>b</sub> : Absolute pressure at Plant Site Elevation m
	P <sub>b</sub> /P <sub>a</sub> : exp[-gM(z <sub>b</sub> -z <sub>a</sub> )/R*T] 0.900
	g : Acceleration due to Gravity 9.80665 m/s <sup>2</sup>
	M : Mole of Air 28.97 kg/kg-mole
	z <sub>b</sub> : Plant Site Elevation 900 m
	z <sub>a</sub> : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 293.15 Kelvin
	α : relative Transfer Rate to clean Water 0.65
	β : relative DO Saturation to clean Water 0.95
	F : Diffuser Fouling Factor 0.90
	$= \frac{112,656}{4.2591} = 26,450.37 \text{ kg/day}$
(3) No. of Basins	4 Basin
(4) Standard O <sub>2</sub> required at Field Conditions per Basin =	6,613 kg/day
(5) SOTE for the above Effective Aeration Depth	28.0 %
(6) Fraction of O <sub>2</sub> in Air	23.18 %
(7) Specific Gravity of Air at Standard Condition	1.293
(8) Safety Factor	15%
(9) Air required at Field Conditions per Basins	= 97,253 m <sup>3</sup> /day = 4,052.2 m <sup>3</sup> /hr

Air Requirement at Average Flow 12/23

Reference: Process Cal. EA&al 24MLD Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

[2] Equipment				
(1) Air Blower				
Number	4	W	+	2 S
Required Capacity	4052.2	m <sup>3</sup> /Hr·Basin	/	1 unit/Basin
	= 4052.2	m <sup>3</sup> /h	⇒	4100 m <sup>3</sup> /h /Unit
Pressure	65	kPa		
Safety Factor	10	%		
Heat capacity ratio	1.4			
Atmospheric pressure at site elevation	91.234	kPa		
Total inlet pressure	89.234	kPa		
Volume rate of flow at inlet point	77.573	m <sup>3</sup> /min		
Total discharge pressure	156.234	kPa		
Overall adiabatic efficiency	0.65			
Inlet air temperature (min.)	15	°C		
Shaft power	109.679	kW		
Rated Output of Motor	120.647	kW	⇒	130 kW



Reference Process Cal. EA&al 24MLD Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p><b>7. Final Clarifire</b></p> <p><b>[1] Design Condition</b></p> <p>(1) Design Wastewater Flow</p> <p>(2) Water Temperature</p> <p>(3) MLSS</p> <p>(4) SVI</p> <p>(5) Sedimentation Velocity</p> <p>(6) Surface Overflow Rate required</p> <p><b>[2] Geometry</b></p> <p>(1) Surface Area required</p> <p>(2) Demensions</p> <p>(3) Actual Surface Area</p> <p>(4) Surface Overflow Rate</p>	<p><math>Q = 24,000 \text{ m}^3/\text{day}</math></p> <p><math>T = 20.0 \text{ }^\circ\text{C}</math></p> <p><math>X_{ef} = 3,000 \text{ mg/l}</math></p> <p><math>SVI = 300</math></p> <p><math>v = 4.899 \cdot 10^6 \cdot T^{(0.954)} \cdot X_{ef}^{(-1.354)} \cdot SVI^{(-0.77)}</math>  <math>= 4.899 \cdot 10^6 \cdot 20.0^{0.954} \cdot 3,000^{-1.354} \cdot 150^{-0.770}</math>  <math>= 20.7 \text{ m/day}</math></p> <p><math>S' = v / (1.5 \cdot 1) = 20.7 / (1.5 \cdot 1.0) = 13.8 \text{ m}^3/\text{m}^2 \cdot \text{day}</math>  <math>\rightarrow 12.0 \text{ m}^3/\text{m}^2 \cdot \text{day}</math></p> <p><math>A = 24,000 / 12.0 = 2,000 \text{ m}^2</math></p> <table style="margin-left: 40px;"> <tr> <td style="text-align: center;">Diameter</td> <td style="text-align: center;">Depth</td> <td style="text-align: center;">Basin</td> </tr> <tr> <td style="text-align: center;"><b>26.0</b></td> <td style="text-align: center;"><b>3.5</b></td> <td style="text-align: center;"><b>4</b></td> </tr> </table> <p><math>S = 26.0^2 \cdot 3.14 / 4 \cdot 4.0 = 2,124 \text{ m}^2</math></p> <p><math>S = 24,000 / 2,124 = 11.3 \text{ m}^3/\text{m}^2 \cdot \text{day}</math></p>	Diameter	Depth	Basin	<b>26.0</b>	<b>3.5</b>	<b>4</b>
Diameter	Depth	Basin					
<b>26.0</b>	<b>3.5</b>	<b>4</b>					

Reference Process Cal. EA&al 24MLD Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

8. Chlorination	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 24,000 m <sup>3</sup> /day 1000.00 m <sup>3</sup> /h Peak Flow 54,000 m <sup>3</sup> /day 2250.00 m <sup>3</sup> /h
(2) Contact Time	30 min
(3) Type of Chlorine	Cl <sub>2</sub> -GAS
(4) Design Chlorine Dosage Rate	10 mg/L
(5) Required Chlorine per day	Average Daily Flow / 1000 × Design Chlorine Dosage Rate = 240.0 kg/d = 10.00 kg/h
<b>[2] Chlorination Contact Tank</b>	
(1) Volume required	Average Daily Flow / 1440 × Contact Time = 500.0 m <sup>3</sup>
(2) Nos. of lanes	5 lanes
(3) Width of lane	2.00 m
(4) Length of lane	26.00 m
(5) Side Water Depth	2.00 m
(6) Nos. of Tanks	1 tank
(7) Total Width of Tank	11.60 m Approx..
(8) Average Velocity	Decant Flow / 3600 / Width / Depth = 1000.00 / 3600 / 2.00 / 2.00 = 0.069 m/sec
(9) Total Volume	Width × Length × Depth × Nos. of lanes × Nos. of Tanks = 2.0 m × 26.0 m × 2.0 m × 5 × 1 = 520 m <sup>3</sup> > 500.0 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Chlorine Dosing Condition	
Operation Dosage Rate -1	DC1 10 mg/L
(2) Chlorine Cylinder	
Type	- Cylindrical Convexsd Container
Cylinder Capacity	Cc 928 kg/cylinder
Average Dosage Rate -1	q1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 240 kg/day
Maximum Dosage Rate -1	q3 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 540 kg/day
Storage day	T More than 15 days
Required Storage Capacity	EC1 D × T = 3,600 kg
Unit Number	EN1 EC1 / Cc = 3.9 cylinders
Maximum Operation Numbers	
Cl <sub>2</sub> -Gas Volatilize Rate	Vr1 ##### @ 20°C Standard temperature
Maximum Dosing Rate	DC1 10 mg/L, Q <sub>T-D</sub> × q3 × 10 <sup>-3</sup> / 24 = 22.50 kg/h
Operation Numbers	EN2 DC1 / Vr1 = 2.8sets
Number	3 W + 2 S
(3) Chlorinator	
Type	Solution Feed Vacuum Type
Number	1 W + 1 S
Operation Dosage Rate -1	Dq1 Chlorine -1 : Q <sub>T-D</sub> × DC1 × 10 <sup>-6</sup> × 10 <sup>3</sup> = 540 kg/day
Required Dosage Rate	Chlorine -1 : Dq1 / (EN1 × 24) = Minimum Maximum 0.00 kg/hr 22.5 kg/hr

Reference Process Cal. EA&amp;al 24MLD Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

(4) Chlorine Booster Pump	Branchy on the water supply pipe
Type	Water requiamet for mixsed Chlora
Water Demand	(kg/hr) 1.0 1.5 2.0 2.5 3.0 4.0
Chlorinator Discharge	(L/min) 15 20 25 30 35 40
Water Demand	(kg/hr) 5.0 6.0 10.0 50.0 100.0 200.0
Chlorinator Discharge	(L/min) 45 50 60 300 600 1,200
Water Demand	-
Water requiamet	Qp1 Maximum dosage rate 22.5 kg/hr
For Chlorin	therefore 135 L/min
Booster Pump Type	Single suction volute pump
Number	1 W + 1 S
<b>9. Dechlorination</b>	
<b>[1] Design Condition</b>	
(1) Design Flow Rate	Average Daily Flow 24,000 m <sup>3</sup> /day
(2) Contact Time	10 min
(3) Type of Dechlorine	Sodium Thiosulfate (Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 5H <sub>2</sub> O)
(4) Free Residual Chlorine	1.0 mg/L assumed value
(5) Consumption per day	Average Daily Flow / 1000 × Free Residual Chlorine × 1.75
	× 1.5 (safety factor)
	= 63.0 kg/d
	= 2.63 kg/h
<b>[2] Dechlorination Contact Tank</b>	
(1) Volume required	Average Flow Rate / 60 × Contact Time
	= 166.7 m <sup>3</sup>
(2) Width of lane	11.60 m
(3) Length of lane	8.00 m
(4) Side Water Depth	2.00 m
(5) Nos. of Tanks	1 tank
(6) Total Volume	Width × Length × Depth
	= 11.6 m × 8.0 m × 2.0 m
	= 186 m <sup>3</sup> > 166.7 m <sup>3</sup>
<b>[3] Equipment</b>	
(1) Dechlorine Solution Tank	
Number	2 W + 0 S
Dechlorine concentration	10 %
Gravity of dissolved dechlorine	1.10
Required solution volume	63.00 kg/d × 100 / 10 / 1.10 / 1000
	= 0.57 m <sup>3</sup> /d
Volume of Tank	0.360 m <sup>3</sup> /tank (= 0.6 mW × 0.6 mL × 1.0 mH)
Total Volume of Tanks	0.720 m <sup>3</sup> (Duration= 1.26 day)
(2) Mixer for Dechlorine Solution Tank	
Number	2 W + 0 S
(3) Dechlorine Dosing Pump	
Number	2 W + 1 S
Capacity	1.29 m <sup>3</sup> /d / 24 × 1000 / 2
	26.85 l/h/unit ⇒ 27 l/h/unit



Reference Process Cal. EA&al 24MLD Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>11. Thickened Sludge Sump</b>	
<b>[1] Design Condition</b>	
(1) Inlet Solids	11,570 kg/day
(2) Inlet Sludge Volume	1,446 m <sup>3</sup> /d
<b>[2] Geometory</b>	
(1) Sludge withdrawl	15 Times/day
(2) Required Sump Volume	96 m <sup>3</sup> /d
(3) Number	2 Basins
(4) Width	3.5 m
(5) Length	4.0 m
(6) Side Water Depth	3.0 m
(7) Actual Sump Volume	$3.5 \times 4.0 \times 3.5 \times 2$ $= 98.0 \text{ m}^3$
<b>[3] Equipment</b>	
(1) Thickened Sludge Transfer Pumps	
Transfer Time	6.00 Hr
Number	2 W + 2 S
Required Capacity	$= \frac{1446 \text{ m}^3}{6.0} \Rightarrow 241 \text{ m}^3/\text{Hr}$

Reference Process Cal. EA&al 24MLD Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<p><b>12. Centrifuge</b>  <b>[1] Design Condition</b>                  (1) Type of Dewatering                  (2) Generated Sludge                  (3) Design Polyelectrolyte Dosage                  (4) Volume of Thickend Sludge                  (5) Consistency of Dewatered Sludge                  (6) Operation Time</p>	<p>Centrifuge                  10,413 kg/day                  Polyelectrolyte 5 kg/t-DS·day                  416.5 m<sup>3</sup>/day                  82 %                  12 hours/day (6 days per week)</p>
<p><b>[2] Volume of Centrifuges</b></p>	<p><math display="block">\frac{\text{Digested Solids}}{\text{Operation Time} \times \text{No.}} \times \text{Operation/week}</math> <math display="block">= \frac{416.5}{12 \times 2} \times \frac{7}{6} = 20.2</math> <math display="block">\rightarrow 21 \text{ m}^3/\text{hour}</math></p>
<p><b>[3] Dewatered Solids</b></p>	<p><math display="block">\text{Digested Sludge} \times (1 + \text{Injection Rate})</math> <math display="block">= 10,413 \times (1 + 0.0050)</math> <math display="block">= 10,465 \text{ kg/day}</math></p>
<p><b>[4] Dewatered Cake Volume</b></p>	<p><math display="block">\text{Dewatered Solids} \times \frac{100}{100 - \frac{\text{Moisture Content}}{7}}</math> <math display="block">\times \frac{6 \text{ days per week}}{6}</math> <math display="block">= 10,465 \times \frac{100}{100 - 82} \times \frac{7}{6}</math> <math display="block">= 67.83 \text{ t/day}</math> <p>apparent specific gravity 1.00  <math display="block">\frac{67.83}{1.0} = 67.8 \text{ m}^3/\text{day}</math></p> </p>
<p><b>[5] Polyelectrolyte</b>                  (1) Design Polyelectrolyte Dosage                  (2) Required Polyelectrolyte                  (3) Dissolving concentration                  (4) Volume of Polyelectrolyte solution</p>	<p>Polyelectrolyte 5 kg/t-DS·day                  52.07 kg/day                  0.20 %                  26.03 m<sup>3</sup>/day</p>

Reference Process Cal. EA&al 24MLD Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>[6] Equipment</b>	
(1) Centrifuge	
Capacity	21 m <sup>3</sup> /hr
Number	2 W + 1 S
(2) Centrifuge Feed Pumps	
Capacity	21 m <sup>3</sup> /hr
Number	2 W + 1 S
(3) Polyelectrolyte Dosing Pumps	
Volume of Polyelectrolyte solution	26.03 m <sup>3</sup> /day
Operation Time	12 hours/day (6 days per week)
Safety Factor	1.5
Number	2 W + 1 S
Required Capacity	26.03 m <sup>3</sup> /da × 7 / 6 / 12 / 2
	= 1.27 m <sup>3</sup> /Hr
Specification Capacity	1.27 m <sup>3</sup> /Hr × 1.5
	= 1.898 m <sup>3</sup> /Hr ⇒ 1.90 m <sup>3</sup> /Hr /Unit
(4) Polyelectrolyte dosing System	
Preparation time for solution	3 hr
Required dry polymer	52.07 kg/day × 7 / 6 / 12
	= 5.06 kg/hr
	= 15.19 kg per one batch
Feeding time per one batch	30 min
Capacity of Dry polymer Feeder	30 kg/h
Tanks Dimensions	Width 2.0 m × Length 2.0 m × Depth 2.5 m × 2 (Freeboard 0.5m)
	= 20 m <sup>3</sup>
Retention Time of Tank	10.00 m <sup>3</sup> /tank / 1.27 m <sup>3</sup> /Hr
	= 3.951 Hr > 3 Hr
Number	2 W + 0 S

Reference Process Cal. EA&al 24MLD Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<b>11. Centrifuge Feed Sump</b>	
<b>[1] Design Condition</b>	
(1) Generated Thickend Sludge	10,413 kg/day
(2) Solids Consistency	2.50 %
(3) Volume of Thickened Sludge	$\begin{aligned} & \text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3} \\ = & 10,413 \times \frac{100}{2.50} \times 10^{-3} \\ = & 417 \text{ m}^3/\text{day} \\ = & 17.36 \text{ m}^3/\text{h} \end{aligned}$
(4) Sludge feed flow rate	21 m <sup>3</sup> /h × 2 = 42 m <sup>3</sup> /h
(5) Centrifuge Operation Time	12 hours/day ( 6 days per week)
<b>[2] Geometry</b>	
(1) Basin Dimensions	$\begin{aligned} & \text{Width } 6.0 \text{ m} \times \text{Length } 7.0 \text{ m} \\ & \times \text{Depth } 4.0 \text{ m} \times 2 \\ = & 336.0 \text{ m}^3 \end{aligned}$
<b>[3] Equipment</b>	
(1) Mixers for Centrifuge Feed Sumps	Required Volume
Required Volume	336.0 m <sup>3</sup>
Number	1 W + 1 S



STP Process Calculation\_Supporting Report 12.2.3

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Digestion Tank + Centrifugal Dewatering)

Table -1 Input Data

1. Calculation Manner	2	1:Premise that the quality of supernatants are same level removed with inlet sewage 2:Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency	2	1:Total Removal Ratio 2:Outlet Water Quality(input 1or2)
In case of 1 : input data		(%)
In case of 2 : input data	#REF!	(mg/l)
3. Selection of Excess Sludge Generation	2	1:Consideration of Solid Matter Only 2:Consideration of Converting of Solved BOD(input 1or2)
In case of 1 : input data (Sludge generation)		Sludge generation ratio per removal SS(%) T2=Q4·S4-(a·S <sub>BOD</sub> +b·S1-c·θ·XA)·Q3/10 <sup>6</sup> ·(Excess sludge generation formula)
In case of 2 : input data	a	0.4 a:Converting ratio of solved BOD(mgMLSS/mgBOD)
	b	0.9 b:Converting ratio of SS(mgMLSS/mgSS)
	c	0.05 c:Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)
	SBOD	234.50 S <sub>BOD</sub> :Solved BOD quality at inlet reactor
	XA	3,000 XA:MLSS concentration(mg/l)
θ	1 θ:Hydraulic retention time(day)	


Table -2 Basic Conditions

Sewage Flow and Quality		Sludge Moisture and Recovery Ratio		Digestion Tank Conditions		Chemical Conditions for Dewatering	
·Inlet flow : Q <sub>0</sub> (m <sup>3</sup> /D)	24,000	·Primary sludge moisture ratio : W1(%)	0.0	·Removal ratio in primary tank : A2(%)	0.0	·Content of organics in thickened sludge : A6(%)	75.0
·Inlet quality : S <sub>0</sub> (mg/l)	450	·Excess sludge moisture ratio : W2(%)	99.2	·Recovery ratio in sludge thickener : A3(%)	90.0	·Digestion ratio : A7(%)	#REF!
·Total removal ratio : A1(%)	-	·Thickened sludge moisture ratio : W3(%)	97.5	·Recovery ratio in sludge digester : A4(%)	100.0	·Digestion gas generation : A8(Nm <sup>3</sup> /kgVS)	
·Effluent quality : S1(mg/l)	10.0	·Digested sludge moisture ratio : W4(%)	97.5	·Recovery ratio in dewatering : A5(%)	95.0		
·Sludge generation ratio per removal SS : S1(%)	-	·Dewatered sludge moisture ratio : W5(%)	82.0				

Table -3 Material Balance Calculation

	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	手入力(要取束)	16	17	
Q(m <sup>3</sup> /day)	24,000	25,417	0	25,417	1,446	23,971	417	1,030	0	417	0	26	443	55	387	1,417	1,417		23,971	0
T(t·DS/day)	10,800	12,480	0.000	12,480	11,570	0,240	10,413	1,157	0.000	10,413	0.000	0,052	10,465	9,942	0,523	1,680	1,680		0,240	0,670
S(mg/l)	450	491	0	491	8,000	10	25,000	1,124	0	25,000	0	2,000	23,647	180,000	1,351	1,186			10	
X(T5/T0*100)	100	115.6	0.0	115.6	107.1	2.2	96.4	10.7	0.0	96.4	0.0	0.5	96.9	92.1	4.8	15.6			2.2	6.2

Figure -1 Material Balance Model




Calculation Formula						
·Q0=Input Data	·Q3=Q1-Q2	·Q6=T6*100/(100-W3)	·Q9=Q6	·Q12=Q9+Q11	·Q15=Q7+Q10+Q14	·Q5-1=Q5-Q11
·T0=Q0*S0*10 <sup>-6</sup>	·T3=T0*(100-A2)/100	·T6=(T2+T4)*A3/100	·T9=(T6-T8)*A4/100	·T12=T9+T11	·T15=T7+T10+T14	·T5-1=T5-T11
·S0=Input Data	·S3=T3*10 <sup>-6</sup> /Q3	·S6=10 <sup>-6</sup> *Q3/(100-W3)/100	·S9=T9*10 <sup>-6</sup> /Q9	·S12=T12*10 <sup>-6</sup> /Q12	·S15=T15*10 <sup>-6</sup> /Q15	·S5-1=S5
·Q1=Q0+Q15	·Q4=T4*100/(100-W2)	·Q7=(Q2+Q4)-Q6	·Q10=Q6-Q8-Q9	·Q13=T13*100/(100-W5)		
·T1=T0+T15	·T4=余剰汚泥発生式による	·T7=(T2+T4)-T6	·T10=T6-T8-T9	·T13=T12*A5/100		
·S1=T1*10 <sup>-6</sup> /Q1	·S4=10 <sup>-6</sup> *Q4/(100-W2)/100	·S7=T7*10 <sup>-6</sup> /Q7	·S10=T10*10 <sup>-6</sup> /Q10	·S13=10 <sup>-6</sup> *Q13/(100-W5)/100		
·Q2=T2*100/(100-W1)	·Q5=Q3-Q4*(T3-T5)/T4	·Q8=0	·Q11=T10*A9/A10	·Q14=Q12-Q13		
·T2=T1-T3	·T5=Q5*ST/10 <sup>-6</sup>	·T8=T6*A6*A7/10 <sup>-4</sup>	·T11=Q11*S11/10 <sup>-6</sup>	·T14=T12-T13		
·S2=10 <sup>-6</sup> *Q2/(100-W1)/100	·S5=S1	#REF!	·S11=10 <sup>-4</sup> *A10	·S14=T14*10 <sup>-6</sup> /Q14		

Material Balance Sheet SD4

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Sheet  
[24MLD STP]



Reference Process Cal. SBR&al 10MLD Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**Design Condition**

Item	Gazipur-MPS			
(1) Design Flow for the year 2045	Flow Rate			
		m3/d	m3/h	m3/sec
	Daily Average	####	1015	0.282
	Daily Maximum	####	1015	0.282
	Hourly Max. Peak factor 2.25	####	2283	0.634
(1) Design Flow for the year 2030	Flow Rate			
		m3/d	m3/h	m3/sec
	Daily Average	####	817	0.227
	Daily Maximum	####	817	0.227
	Hourly Max. Peak factor 2.25	####	1838	0.510

**1. Inlet Chamber**

Item	Gazipur-MPS			
[1] Design Condition				
(1) Design Flow for the year 2045	Max Hourly	=	54,797	m3/d
		=	0.634	m3/sec
(2) Inlet Pipe				
Pipe Diameter	·	×		mm
Gradient			%	
Roughness Coefficient	n=	0.013	(Manning Formula)	
Full Pipe Flow Rate			m <sup>3</sup> /sec	
(3) Influent Water Level	+		m	
[2] Geometory				
(1) Number of Basins	1	Basin		
(2) Depth of Basin	2.000	m		
(3) Width of Basin	2.500	m		
(4) Length of Basin	3.700	m		
(5) Volume required of Basin	2.000	×	2.500	×
			3.700	= 1.4 m3
(6) Retention Time	2.000	×	2.500	×
			3.700	/ 0.634 × 1
	=	29.18	sec	
(7) Basin Demensions	Width	2.500	m	×
				Length 3.700 m
	×	Depth	2.000	m

Reference Process Cal. SBR&al 10MLD Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<b>2. Coarse Screen Channel</b>							
<b>[1] Design Flow Rate</b>							
(1) Design Flow for the year 2045		Max Hourly	=	54,797	m <sup>3</sup> /day		
			=	0.634	m <sup>3</sup> /sec		
(2) Design Flow for the year 2030		Max Hourly	=	44,105	m <sup>3</sup> /day		
			=	0.510	m <sup>3</sup> /sec		
<b>[2] Geometry</b>							
<b>(1) Inlet Gate</b>							
Number	2	Main	+	1	Bypass		
Width	0.600	m					
Height	0.900	m					
Floor Level	+	0.000	m				
Bottom	+	0.000	m				
Influent Water Level	+	0.600	m				
Velocity	0.634	/	0.600	/	0.600	/	2
wher Design Flow for the year 2045	=	0.881	<	1.000	m/sec		OK
Velocity	0.510	/	0.600	/	0.600	/	2
wher Design Flow for the year 2030	=	0.708	<	1.000	m/sec		OK
<b>(2) Screen Channel</b>							
Number	2.0	Main	+	1.0	Bypass		
Width	1.000	m					
Side Water Depth	0.700	m					
Velocity	0.634	/	1.000	/	0.700	/	2
wher Design Flow for the year 2045	=	0.453	≅	0.450	m/sec		OK
Velocity	0.510	/	1.000	/	0.700	/	2
wher Design Flow for the year 2030	=	0.364	<	0.450	m/sec		OK
<b>(3) Channel Dimensions</b>							
Width	1.0	m	×	Length	7.5	m	
	×	SWD	0.7	m	(Freeboard 0.3m)		
<b>[3] Equipment</b>							
<b>(1) Inlet Gate</b>							
Number	2	Units					
Dimension	Width	0.6	m	×	Height	0.9	m
Design Water Level		m					
<b>(2) Coarse Screens (Main Channel)</b>							
Number	2	W	+	0	S		
Open Space	20	mm					
Bar Thickness	9	mm					
Channel Width	1.0	m					
Width of side plate	50	mm					
Side Water Depth	0.7	m					
Height of Blind Plate at the bottom	50	mm					
Velocity through screen	0.634	/	0.900	/	0.650	/	2
	×	( 20	+	9 )/	20		
	=	0.786	≅	0.800	m/sec		OK
Velocity through screen	0.510	/	0.900	/	0.650	/	2
wher Design Flow for the year 2030	×	( 20	+	9 )/	20		
	=	0.632	<	0.800	m/sec		OK
<b>(3) Coarse Screens (Bypass Channel)</b>							
Number	0	W	+	1	S		
Open Space	50	mm					
Bar Thickness	9	mm					
Channel Width	1.0	m					
Side Water Depth	0.7	m					
Velocity through screen	0.634	/	1.000	/	0.700	/	2
wher Design Flow for the year 2045	×	( 50	+	9 )/	50		
	=	0.534	<	0.800	m/sec		OK
Velocity through screen	0.510	/	1.000	/	0.700	/	2
wher Design Flow for the year 2030	×	( 50	+	9 )/	50		
	=	0.430	<	0.800	m/sec		OK

Reference Process Cal. SBR&al 10MLD Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<b>3. Raw Sewage Sump</b>	
<b>[1] Geometry</b>	
(1) Raw Sewage Sump	
Number	1 Basin
Dia	12.00 m
Pump Operating Depth	1.700 m
Retention Time whe Design Flow for the year 2045	$( \frac{12.00^2 \times \pi}{4} \times 1.700 ) / 0.634 / 60$ = 5.05 > 3.75 min (=minimum time of one pump cycle) OK
Retention Time whe Design Flow for the year 2030	$( \frac{12.00^2 \times \pi}{4} \times 1.700 ) / 0.510 / 60$ = 6.28 > 3.75 min (=minimum time of one pump cycle) OK
High Water Level	+ m
Pump Off Level	+ m
<b>[2] Equipment</b>	
(1) Sewage Pumps	
Number	4 W + 2 S
Bore Diameter	150 mm
Discharge Flow whe Design Flow for the year 2030	$0.510 \times 3600 / 4$ = 459 $\Rightarrow$ 460 m <sup>3</sup> /Hr
Total Head	22.0 m

Reference Process Cal. SBR&al 10MLD Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**1. STP Design Condition**

Item	Gazipur-STP 18MLD						
(1) Design Average Daily Wastewater Flow	Flow Rate						
		m <sup>3</sup> /d	m <sup>3</sup> /h	m <sup>3</sup> /s			
	Average Daily	####	750	0.208			
	Max Dayly	####	750	0.208			
Max Hourly Peak factor	2.25	####	1688	0.469			
(2) Design Sewage Quality and Effluent Quality	Unit:mg/L						
		Water Quality Item					
		BOD	COD	SS	T-N		TP
					NH <sub>4</sub> -N	Org-N	NOx-N
	Inlet	250	450	250	25	10	5
	Outlet	10	50	20	2	0	8
Removal rate	####	####	####	####		####	

**4. Stilling Chamber**

Item	Gazipur-STP 18MLD						
[1] Design Condition							
(1) Design Wastewater Flow	Max Hourly	=	40,500	m <sup>3</sup> /day			
		=	0.469	m <sup>3</sup> /sec			
[2] Geometry							
(1) Number of Basins	1	Basin					
(2) Depth of Basin	2.000	m					
(3) Width of Basin	3.200	m					
(4) Length of Basin	4.500	m					
(5) Volume required of Basin	2.000	×	3.200	×	4.500	=	1.4 m <sup>3</sup>
(6) Retention Time	2.000	×	3.200	×	4.500	/	0.469 × 1
	=	61.4072495	sec				
(7) Basin Demensions	Width	3.200	m	×	Length	4.500	m
	×	Depth	2.000	m			

Reference Process Cal. SBR&al 10MLD Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**5. Fine Screen Channel**

Item	Gazipur-STP 18MLD			
[1] Design Condition				
(1) Design Wastewater Flow	Max Hourly	=	40,500	m <sup>3</sup> /day
		=	0.469	m <sup>3</sup> /sec
[2] Geometory				
(1) Inlet Gate				
Number	2	Main	+	1 Bypass
Width	0.600	m		
Height	0.900	m		
Floor Level	+	107.100	m	
Bottom	+	104.600	m	
Influent Water Level	+	105.200	m	
Velocity	0.469	/	0.600	/ 0.600 / 2
	=	0.651	<	1.000 m/sec
(2) Screen Channel				
Number	2	Main	+	1 Bypass
Width	0.800	m		
Side Water Depth	0.700	m		
Velocity	0.469	/	0.800	/ 0.700 / 2
	=	0.419	≅	0.450 m/sec
(3) Channel Dimensions	Width	0.8	m	× Length 8.5 m
	×	SWD	0.7	m (Freeboard 0.3m)
[3] Equipment				
(1) Inlet Gate				
Number	2	Units		
Dimension	Width	0.6	m	× Height 0.9 m
Design Water Level	2.50	m		
(2) Fine Screens (Main Channel)				
Number	2	W	+	0 S
Open Space	6	mm		
Bar Thickness	2	mm		
Channel Width	0.8	m		
Width of side plate	50	mm		
Side Water Depth	0.7	m		
Height of Blind Plate at the bottom	50	mm		
Velocity through screen	0.469	/	0.700	/ 0.650 / 2
	× (	6	+ 2	) / 6
	=	0.687	<	0.800 m/sec
(3) Fine Screens (Bypass Channel)				
Number	0	W	+	1 S
Open Space	20	mm		
Bar Thickness	9	mm		
Channel Width	0.8	m		
Side Water Depth	0.7	m		
Velocity through screen	0.469	/	0.800	/ 0.700 / 2
	× (	20	+ 9	) / 20
	=	0.607	<	0.800 m/sec

Reference Process Cal. SBR&al 10MLD Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**6. Grit Chamber**

Item	Gazipur-STP 18MLD	
[1] Design Condition		
(1) Design Wastewater Flow	Max Hourly	= 40,500 m <sup>3</sup> /day
		= 0.469 m <sup>3</sup> /sec
(2) Specific gravity of Sand	2.65	
(3) Sedimentation Velocity	0.0111 m/sec	= 960 m <sup>3</sup> /m <sup>2</sup> /day
(4) Average Velocity	0.3 m/sec	
[2] Grit Chamber	Square Grit Chamber	
(1) Surface Area required	0.469 / 0.0111	= 42.25 m <sup>2</sup>
(2) Number of Basins	2 S + 0 W	
(3) Surface Area required/Basin	42.3 / 2	= 21.13 m <sup>2</sup>
(4) Length of Basin	21.1261261 ^0.5	= 4.6 m → 5.0 m
(5) HRT in Grit Chamber	60 sec	
(6) Volume required of Basin	0.469 × 60 sec / 2	= 14.1 m <sup>3</sup>
(7) Depth required	14.1 / 5.0 / 5.0	= 0.563 m
(8) Basin Dimensions	Width 5.0 m × Length 5.0 m	
	× Depth 0.6 m (Freeboard 0.3m)	
(9) Retention Time	5 × 5.0 × 0.6 / 0.469 × 2	
	= 60.00 sec	
(10) Surface Overflow Rate at Peak Flow	40,500 / 5.0 / 5.0 / 2	
	= 810 < 960	m <sup>3</sup> /m <sup>2</sup> /day



**STP Process Calculation\_Supporting Report 12.2.3**

**8. Air Requirement at Average Flow**

Item	STP 10MLD
[1] Design Condition	
(1) O <sub>2</sub> demand	
R <sub>o</sub> =	$Q(S_o - S - 2.86(\text{Nox} - \text{NOx}_e)) - 1.42P_{X,bb} + 4.57Q \cdot \text{NOx}$
R <sub>o</sub> =	6,214 kg O <sub>2</sub> /d
Q <sub>in</sub> : Design Average Flow	10,000 m <sup>3</sup> /d
Inlet bCOD	S <sub>0</sub> = 578 mg/l
S=	S = 0.291 mg/l
Nox=	NOX = 52.471 mg/l
P <sub>X,bb</sub> =	P <sub>X,bb</sub> = 1,377.5 kg VSS/d *does not include nitrifying bacteria
(2) SOR(Standard Oxygen Transfer Rate at site)	$= \frac{R_o}{\alpha} \times \frac{C_s \cdot a}{F (\beta \cdot C_{sw/CS} \cdot (P_b/P_a)^a - C_A)} \times 1.024^{20-T}$
	C <sub>s</sub> : Saturated DO at sea level and 20 °C degrees Celsius 9.09 mg/L
	C <sub>sw</sub> : Saturated DO at sea level and operating Temperature 6.93 mg/L at 35 degrees Celsius
	20-T : -15.0 1.024 <sup>20-T</sup> : 0.7006
	C <sub>A</sub> : operating DO in Basin 2.0 mg/L
	a : Correction Factor by the Water Depth 1+0.40D <sub>j</sub> /Pa 1.19357
	D <sub>j</sub> : Tank Liquid Depth 5.00 m
	P <sub>a</sub> : Standard absolute pressure at sea level 10.332 m
	P <sub>b</sub> : Absolute pressure at Plant Site Elevation m
	P <sub>b</sub> /P <sub>a</sub> : exp[-gM(z <sub>b</sub> -z <sub>a</sub> )/R*T] 0.905
	g : Acceleration due to Gravity 9.80665 m/s <sup>2</sup>
	M : Mole of Air 28.97 kg/kg-mole
	z <sub>b</sub> : Plant Site Elevation 900 m
	z <sub>a</sub> : Sea Elevation 0 m
	R : Universal Gas Constant 8314 Nm/kg-mole.K
	T : Temperature 273.15+t = 308.15 Kelvin
	α : relative Transfer Rate to clean Water 0.65
	β : relative DO Saturation to clean Water 0.95
	F : Diffuser Fouling Factor 0.90
	= $\frac{47,237}{2.9902} = 15,797.15$ kg/day
(3) No. of Basins	3 Basin
(4) Number of cycles	5.0 cycles/basin · day × 3
	total 15 cycles/day
(5) Standard O <sub>2</sub> required at Field Conditions per cycle	= 1,053.1 kg/cycle/basin/day
(6) SOTE for the above Effective Aeration Depth	28.0 %
(7) Fraction of O <sub>2</sub> in Air	23.18 %
(8) Specific Gravity of Air at Standard Condition	1.293
(9) Safety Factor	10%
(10) Air required at Field Conditions per cycle	= 14,815 m <sup>3</sup> /cycle/basin/day
(11) Aeration time per cycle t <sub>A</sub>	= 1.80 h
	= 8,230.8 m <sup>3</sup> /hr/basin

Reference\_Process Cal. SBR&al 10MLD.Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

[2] Equipment					
(1) Air Blower					
Operating No. per basin		2	unit/Basin		
Operating No. per set of blowers		1	basin/set		
Required Capacity		8230.8	m <sup>3</sup> /Hr·Basin	/	2 unit/Basin
	=	4115.4	m <sup>3</sup> /Hr	⇒	4200 m <sup>3</sup> /Hr/Unit
Number		6	W	+	3 S
Pressure		65	kPa		
Safety Factor		10	%		
Heat capacity ratio		1.4			
Atmospheric pressure at site elevation		91.701	kPa		
Total inlet pressure		89.701	kPa		
Volume rate of flow at inlet point		79.052	m <sup>3</sup> /min		
Total discharge pressure		156.701	kPa		
Overall adiabatic efficiency		0.65			
Inlet air temperature (min.)		15	°C		
Shaft power		111.869	kW		
Rated Output of Motor		123.056	kW	⇒	130 kW

Reference Process Cal\_SBR&al 10MLD Appendix 12.2.3  
**STP Process Calculation\_Supporting Report 12.2.3**

**13. Centrifuge**

Item	STP 10MLD
[1] Design Condition	
(1) Type of Dewatering	Centrifuge
(2) Quantity of Thickend Sludge generated	3,823 kg/day
(3) Design Polyelectrolyte Dosage	Polyelectrolyte 5 kg/t-DS·day
(4) Volume of Thickend Sludge	477.9 m <sup>3</sup> /day
(5) Consistency of Dewatered Sludge	82 %
(6) Operation Time	12 hours/day (6 days per week)
[2] Volume of Centrifuges	$\frac{\text{Digested Solids}}{\text{Operation Time} \times \text{No.}} \times \text{Operation/week}$ $= \frac{477.9}{12 \times 2} \times \frac{7}{6} = 23.2$ $\rightarrow 30 \text{ m}^3/\text{hour}$
[3] Dewatered Solids	$\text{Digested Sludge} \times \left( \frac{1}{1} + \frac{\text{Injection Rate}}{0.0050} \right)$ $= 3,823 \times \left( \frac{1}{1} + \frac{0.0050}{0.0050} \right)$ $= 3,842 \text{ kg/day}$
[4] Dewatered Cake Volume	$\text{Dewatered Solids} \times \frac{100 - \text{Moisture Content}}{100} \times \frac{7}{6 \text{ days per week}}$ $= 3,842 \times \frac{100 - 7}{100} \times \frac{7}{6}$ $= 24.90 \text{ t/day}$ $\text{apparent specific gravity} = \frac{24.90}{1.0} = 24.9 \text{ m}^3/\text{day}$
[5] Polyelectrolyte	
(1) Design Polyelectrolyte Dosage	Polyelectrolyte 5 kg/t-DS·day
(2) Required Polyelectrolyte	19.11 kg/day
(3) Dissolving concentration	0.20 %
(4) Volume of Polyelectrolyte solution	9.56 m <sup>3</sup> /day
[6] Equipment	
(1) Centrifuge	
Capacity	30 m <sup>3</sup> /hr
Number	2 W + 1 S
(2) Centrifuge Feed Pumps	
Capacity	30 m <sup>3</sup> /hr
Number	2 W + 1 S
(3) Polyelectrolyte Dosing Pumps	
Volume of Polyelectrolyte solution	9.56 m <sup>3</sup> /day
Operation Time	8 hours/day (6 days per week)
Safety Factor	1.5
Number	2 W + 1 S
Required Capacity	$9.56 \text{ m}^3/\text{Hr} \times \frac{7}{6} \times \frac{8}{6} \times 2$ $= 0.70 \text{ m}^3/\text{Hr}$
Specification Capacity	$0.70 \text{ m}^3/\text{Hr} \times 1.5$ $= 1.045 \text{ m}^3/\text{Hr} \Rightarrow 0.26 \text{ m}^3/\text{Hr /Unit}$
(4) Polyelectrolyte dosing System	
Tanks Dimensions	$\text{Width} \times \text{Depth} \times \text{Length}$ $1.5 \text{ m} \times 2.0 \text{ m} \times 2 \text{ (Freeboard 0.5m)}$ $= 9 \text{ m}^3$
Retention Time of Tanks	$9.00 \text{ m}^3 \div 0.70 \text{ m}^3/\text{Hr} \div 2$ $= 6.457 \text{ Hr}$
Number	2 W + 0 S

Reference Process Cal. SBR&al 10MLD Appendix 12.2.3  
**STP Process Calculation Supporting Report 12.2.3**

<p><b>14. Centrifuge Feed Sump</b></p>	
<p><b>[1] Design Condition</b></p>	
<p>(1) Generated Thickend Sludge</p>	<p>3,823 kg/day</p>
<p>(2) Solids Consistency</p>	<p>2.50 %</p>
<p>(3) Volume of Thickened Sludge</p>	$\begin{aligned} & \text{Total Solids} \times \frac{100}{\text{Solids Consistency}} \times 10^{-3} \\ = & 3,823 \times \frac{100}{2.50} \times 10^{-3} \\ = & 153 \text{ m}^3/\text{day} \\ = & 6.37 \text{ m}^3/\text{h} \end{aligned}$
<p>(4) Sludge feed flow rate</p>	<p>30 m<sup>3</sup>/h × 2 = 60 m<sup>3</sup>/h</p>
<p>(5) Centrifuge Operation Time</p>	<p>12 hours/day ( 6 days per week)</p>
<p><b>[2] Geometry</b></p>	
<p>(1) Required sludge volume for continuation</p>	$\begin{aligned} & ( 60 - 6.37 ) \times 12 \\ = & 643.54 \text{ m}^3 \end{aligned}$
<p>(2) Basin Dimensions</p>	$\begin{aligned} & \text{Width } 4.0 \text{ m} \times \text{Length } 5.0 \text{ m} \\ & \times \text{Depth } 3.0 \text{ m} \times 2 \\ = & 120.0 \text{ m}^3 \end{aligned}$
<p><b>[3] Equipment</b></p>	
<p>(1) Mixers for Centrifuge Feed Sumps</p>	
<p>Required Volume</p>	<p>120.0 m<sup>3</sup></p>
<p>Number</p>	<p>1 W + 1 S</p>

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Digestion Tank + Centrifugal Dewatering)

Table -1 Input Data

1. Calculation Manner	2	1:Premise that the quality of supernatants are same level removed with inlet sewage 2:Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency	2	1:Total Removal Ratio 2:Outlet Water Quality(input 1or2)
In case of 1 : input data		(%)
In case of 2 : input data	10	(mg/l)
3. Selection of Excess Sludge Generation	2	1:Consideration of Solid Matter Only 2:Consideration of Converting of Solved BOD(input 1or2)
In case of 1 : input data (Sludge generation)		Sludge generation ratio per removal SS(%) T2=Q4·S4-(a·S <sub>BOD</sub> +b·S1-c·θ·XA)·Q3/10 <sup>6</sup> ·(Excess sludge generation formula)
In case of 2 : input data	a	0.4 a:Converting ratio of solved BOD(mgMLSS/mgBOD)
	b	0.9 b:Converting ratio of SS(mgMLSS/mgSS)
	c	0.05 c:Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)
	SBOD	167.00 S <sub>BOD</sub> :Solved BOD quality at inlet reactor
	XA	3,000 XA:MLSS concentration(mg/l)
θ	0.667 θ:Hydraulic retention time(day)	


Table -2 Basic Conditions

Sewage Flow and Quality	Sludge Moisture and Recovery Ratio	Digestion Tank Conditions	Chemical Conditions for Dewatering
·Inlet flow : Q <sub>0</sub> (m <sup>3</sup> /D)	10,000	·Primary sludge moisture ratio : W1(%)	0.0
·Inlet quality : S <sub>0</sub> (mg/l)	450	·Excess sludge moisture ratio : W2(%)	99.2
·Total removal ratio : A1(%)	-	·Thickened sludge moisture ratio : W3(%)	99.2
·Effluent quality : S1(mg/l)	10.0	·Digested sludge moisture ratio : W4(%)	99.2
·Sludge generation ratio per removal SS : S1(%)	-	·Dewatered sludge moisture ratio : W5(%)	82.0
		·Removal ratio in primary tank : A2(%)	0.0
		·Recovery ratio in sludge thickener : A3(%)	100.0
		·Recovery ratio in sludge digester : A4(%)	100.0
		·Recovery ratio in dewatering : A5(%)	95.0
		·Content of organics in thickened sludge : A6(%)	75.0
		·Digestion ratio : A7(%)	#REF!
		·Digestion gas generation : A8(Nm <sup>3</sup> /kgVS)	
		·Chemical dosage : A9(%)	0.5
		·Chemical dissolve concentration : A10(%)	0.2

Table -3 Material Balance Calculation

	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	手入力(要取束)	16	17
Q(m <sup>3</sup> /day)	10,000	10,467	0	10,467	478	9,989	478	0	0	478	0	10	487	20	467	467		9,989	0
T(t·DS/day)	4,500	4,692	0.000	4,692	3,823	0.100	3,823	0.000	0.000	3,823	0.000	0.019	3,842	3,650	0.192	0.192	0.192	0.100	0.769
S(mg/l)	450	448	0	448	8,000	10	8,000	#DIV/0!	0	8,000	0	2,000	7,882	180,000	411	411		10	
X(T5/T0*100)	100	104.3	0.0	104.3	85.0	2.2	85.0	0.0	0.0	85.0	0.0	0.4	85.4	81.1	4.3	4.3		2.2	17.1

Figure -1 Material Balance Model




Calculation Formula						
·Q0=Input Data	·Q3=Q1-Q2	·Q6=T6*100/(100-W3)	·Q9=Q6	·Q12=Q9+Q11	·Q15=Q7+Q10+Q14	·Q5-1=Q5-Q11
·T0=Q0*S0*10 <sup>-6</sup>	·T3=T0*(100-A2)/100	·T6=(T2+T4)*A3/100	·T9=(T6-T8)*A4/100	·T12=T9+T11	·T15=T7+T10+T14	·T5-1=T5-T11
·S0=Input Data	·S3=T3*10 <sup>-6</sup> /Q3	·S6=10 <sup>-6</sup> *Q3/(100-W3)/100	·S9=T9*10 <sup>-6</sup> /Q9	·S12=T12*10 <sup>-6</sup> /Q12	·S15=T15*10 <sup>-6</sup> /Q15	·S5-1=S5
·Q1=Q0+Q15	·Q4=T4*100/(100-W2)	·Q7=(Q2+Q4)-Q6	·Q10=Q6-Q8-Q9	·Q13=T13*100/(100-W5)		
·T1=T0+T15	·T4=余剰汚泥発生式による	·T7=(T2+T4)-T6	·T10=T6-T8-T9	·T13=T12*A5/100		
·S1=T1*10 <sup>-6</sup> /Q1	·S4=10 <sup>-6</sup> *Q4/(100-W2)/100	·S7=T7*10 <sup>-6</sup> /Q7	·S10=T10*10 <sup>-6</sup> /Q10	·S13=10 <sup>-6</sup> *Q13/(100-W5)/100		
·Q2=T2*100/(100-W1)	·Q5=Q3-Q4*(T3-T5)/T4	·Q8=0	·Q11=T10*A9/A10	·Q14=Q12-Q13		
·T2=T1-T3	·T5=Q5*ST/10 <sup>-6</sup>	·T8=T6*A6*A7/10 <sup>-4</sup>	·T11=Q11*S11/10 <sup>-6</sup>	·T14=T12-T13		
·S2=10 <sup>-6</sup> *Q2/(100-W1)/100	·S5=St	#REF!	·S11=10 <sup>-4</sup> *A10	·S14=T14*10 <sup>-6</sup> /Q14		

Material Balance Sheet SD4

STP Process Calculation\_Supporting Report 12.2.3

Material Balance Sheet  
[10 STP]



Reference\_Process Cal. SBR&amp;al 10MLD.Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3****7. SBR 10MLD**

Item	STP 10MLD		
<b>[1] Design Condition</b>			
(1) Design Wastewater Flow	Q =	10,000 m <sup>3</sup> /day (summer)	
	Q' =	10,000 m <sup>3</sup> /day (Winter)	
(2) Design Sewage Quality			
Inlet BOD		350 mg/l	
Inlet COD		800 mg/l	
Inlet TSS		450 mg/l	
Inlet T-N		70.0 mg/l	
Inlet TKN		70.0 mg/l	
Inlet NH <sub>4</sub> -N		45.0 mg/l	
Inlet T-P		7 mg/l	
Inlet Alkalinity as CaCO <sub>3</sub>		380 mg/l	
Outlet BOD		10.0 mg/l	
Outlet COD		50 mg/l	
Outlet TSS		10 mg/l	
Outlet T-N		10.0 mg/l	
Outlet TKN		5.0 mg/l	
Outlet T-P		2 mg/l	
Inlet S-BOD		235 mg/l	
Inlet S-COD :sCOD		271 mg/l	
Outlet S-COD :nbsCODe		40 mg/l	=sCOD-1.6sBOD
Inlet rbCOD		231 mg/l	
bCOD/BOD		1.65	
Inlet bCOD :S <sub>0</sub>		578 mg/l	=1.6BOD
Inlet nbCOD		223 mg/l	
:nbpCOD		183 mg/l	=TCOD-bCOD-nbsCODe
Inlet VSS		383 mg/l	
:VSS <sub>COD</sub>		1.38 gCOD/gVSS	=TCOD-sCOD/VSS
:nbVSS		131.96 gnbVSS/m <sup>3</sup>	=nbpCOD/VSS <sub>COD</sub>
:ITSS		67.50 gnbTSS/m <sup>3</sup>	=TSS-VSS
Inlet D-P		5 mg/l	
Outlet Kjeldahl N		1.0 mg/l	
Outlet NH <sub>4</sub> -N		1.0 mg/l	
Outlet NO <sub>3</sub> -N		9.0 mg/l	
Outlet D-P		1 mg/l	
(3) Water Temperature	T =	20.0 °C	
(4) Safety Factor for Nitrogen	SF =	1.5	
(5) Excess Sludge Concentration	Rs =	8,000 mg/l	
(6) MLSS	At tank full X <sub>TSS</sub> =	3,000 mg/l	
(7) DO in the Reactor		2 mg/L	
(8) Operating Cycle			
T <sub>c</sub> Total time		4.80 h	
t <sub>f</sub> Fill time		1.60 h	
t <sub>d</sub> Anoxic(denitrification) time		1.25 h	
t <sub>A</sub> Aeration time		1.80 h	
t <sub>S</sub> Settlement time		1.00 h	
t <sub>D</sub> Decanting time		0.75 h	
(9) Number of cycles		5.0 cycles/basin·day × 3 tanks	
	total	15 cycles/day	
(10) Full volume per cycle		666.667 m <sup>3</sup> /fill	
(11) Full liquid depth		5.00 m	
(12) Decant depth		0.75 m	15.0% of full tank depth
(13) Required aeration tank volume		4444.44 m <sup>3</sup> /tank	τ <sub>a</sub> = 1.3333 day 32 h
(14) Decant flow rate	666.667 m <sup>3</sup> /fill /	0.75 h =	888.89 m <sup>3</sup> /h
(15) No. of basins receiving flow simultaneously	1	nos.	
(16) No. of basins Aerating simultaneously	1	nos.	
(17) No. of basins Decanting simultaneously	1	nos.	
(18) Flow rate	416.666667	m <sup>3</sup> /h	
(19) Flow rate to each basin	416.666667	m <sup>3</sup> /h	

SBR7/16

Reference\_Process Cal. SBR&al 10MLD.Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

<p>[2] Design for Nitrification Process</p>																																																										
<p>(1) Activated sludge design kinwtic coefficients at 20°C</p>																																																										
	<table border="1"> <thead> <tr> <th>Coefficient</th> <th>Unit</th> <th>COD oxidatio</th> <th>NH4 oxidatio</th> <th>NO2 oxidatio</th> </tr> </thead> <tbody> <tr> <td><math>\mu_{max}</math></td> <td>gVSS/gVSS · d</td> <td>6.000</td> <td>0.900</td> <td>1.000</td> </tr> <tr> <td><math>K_s, K_{NH4}, K_{NO2}</math></td> <td>mg/L</td> <td>8.000</td> <td>0.500</td> <td>0.200</td> </tr> <tr> <td>Y</td> <td>gVSS/g substrate oxidized</td> <td>0.450</td> <td>0.150</td> <td>0.050</td> </tr> <tr> <td>b</td> <td>gVSS/gVSS · d</td> <td>0.120</td> <td>0.170</td> <td>0.170</td> </tr> <tr> <td>fd</td> <td>unitless</td> <td>0.150</td> <td>0.150</td> <td>0.150</td> </tr> <tr> <td><math>K_{CO2}</math></td> <td>mg/L</td> <td>0.200</td> <td>0.500</td> <td>0.900</td> </tr> <tr> <td><math>\theta</math>Value</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td><math>\mu_{max}</math></td> <td>unitless</td> <td>1.070</td> <td>1.072</td> <td>1.063</td> </tr> <tr> <td>b</td> <td>unitless</td> <td>1.040</td> <td>1.029</td> <td>1.029</td> </tr> <tr> <td><math>K_s, K_{NH4}, K_{NO2}</math></td> <td>unitless</td> <td>1.000</td> <td>1.000</td> <td>1.000</td> </tr> </tbody> </table> <p>Wastwater Engineering Treatment and Resouce Recovery Fifth Edition (METCALF &amp; EDDY/AECOM)</p>	Coefficient	Unit	COD oxidatio	NH4 oxidatio	NO2 oxidatio	$\mu_{max}$	gVSS/gVSS · d	6.000	0.900	1.000	$K_s, K_{NH4}, K_{NO2}$	mg/L	8.000	0.500	0.200	Y	gVSS/g substrate oxidized	0.450	0.150	0.050	b	gVSS/gVSS · d	0.120	0.170	0.170	fd	unitless	0.150	0.150	0.150	$K_{CO2}$	mg/L	0.200	0.500	0.900	$\theta$ Value					$\mu_{max}$	unitless	1.070	1.072	1.063	b	unitless	1.040	1.029	1.029	$K_s, K_{NH4}, K_{NO2}$	unitless	1.000	1.000	1.000		
Coefficient	Unit	COD oxidatio	NH4 oxidatio	NO2 oxidatio																																																						
$\mu_{max}$	gVSS/gVSS · d	6.000	0.900	1.000																																																						
$K_s, K_{NH4}, K_{NO2}$	mg/L	8.000	0.500	0.200																																																						
Y	gVSS/g substrate oxidized	0.450	0.150	0.050																																																						
b	gVSS/gVSS · d	0.120	0.170	0.170																																																						
fd	unitless	0.150	0.150	0.150																																																						
$K_{CO2}$	mg/L	0.200	0.500	0.900																																																						
$\theta$ Value																																																										
$\mu_{max}$	unitless	1.070	1.072	1.063																																																						
b	unitless	1.040	1.029	1.029																																																						
$K_s, K_{NH4}, K_{NO2}$	unitless	1.000	1.000	1.000																																																						
<p>(3) SRT calculated with the assumed operating condition</p>	<p>SRT= 11.0000 day</p>																																																									
	<p>a: <math>(P_{X,TSS})SRT = 40,000.000 \text{ kg} = V \cdot X_{MLSS}</math></p> <p>b: <math>(P_{X,TSS})SRT = 39,940.636 \text{ kg} = \text{SUM}(\textcircled{1} : \textcircled{6})</math></p> <p><math>\textcircled{1} = 14,488.754 \text{ kg} = Q(SRT) \cdot Y_H(S_0 - S)[1 + b_H(SRT)]/0.85</math></p> <p><math>\textcircled{2} = 14,515.477 \text{ kg} = Q(SRT)nbVSS</math></p> <p><math>\textcircled{3} = 466.950 \text{ kg} = Q(SRT)Y_n(NOx)[1 + b_H(SRT)]/0.85</math></p> <p><math>\textcircled{4} = 2,870.222 \text{ kg} = f_d \cdot b_H \cdot QY_H(S_0 - S)SRT^2/[1 + b_H(SRT)]/0.85</math></p> <p><math>\textcircled{5} = 7,425.000 \text{ kg} = Q(SRT)(TSS_0 - VSS_0)</math></p> <p><math>\textcircled{6} = 174.23 \text{ kg} = 5 \cdot Q \cdot A_I</math></p>																																																									
<p>(4) Sludge production <math>P_{X,TSS} =</math></p>	<p><math>P_{X,TSS} = 3,630.967 \text{ kg/day}</math></p>																																																									
<p>(5) Determine MLVSS concentration</p>																																																										
<p><math>P_{X,VSS}</math> <math>(P_{X,VSS})SRT =</math></p>	<p><math>P_{X,VSS} = 2697.047 \text{ kg/d}</math> <math>(P_{X,VSS})SRT = 29,667.514 \text{ kg} = \text{SUM}(\textcircled{1} : \textcircled{4})</math></p> <p><math>\textcircled{1} = 12,315.441 \text{ kg} = Q(SRT) \cdot Y_H(S_0 - S)[1 + b_H(SRT)]</math></p> <p><math>\textcircled{2} = 14,515.477 \text{ kg} = Q(SRT)nbVSS</math></p> <p><math>\textcircled{3} = 396.907 \text{ kg} = Q(SRT)Y_n(NOx)[1 + b_H(SRT)]</math></p> <p><math>\textcircled{4} = 2,439.689 \text{ kg} = f_d \cdot b_H \cdot QY_H(S_0 - S)SRT^2/[1 + b_H(SRT)]</math></p>																																																									
<p><math>X_{MLVSS} =</math></p>	<p><math>X_{MLVSS} = 2,225 \text{ mg/l}</math></p>																																																									
<p>NOx</p>	<p>NOx= 52.500 mg/l</p>																																																									
<p>S</p>	<p>S= 0.2915 mg/l = <math>K_s[1 + b_H(SRT)]/[SRT(\mu_m - b_H) - 1]</math></p>																																																									
<p><math>b_H</math></p>	<p><math>b_H = 0.1200 = b \cdot 1.04^{(T-20)}</math> b at 20°C = 0.120</p>																																																									
<p><math>Y_H</math></p>	<p><math>Y_H = 0.4500 \text{ gVSS/g bCOD}</math></p>																																																									
<p><math>\mu_{m,T}</math></p>	<p><math>\mu_{m,T} = 6.0000 \text{ g/g} \cdot \text{d} = \mu_{max} \cdot 1.04^{(T-20)}</math> <math>\mu_{max}</math> at 20°C = 6.000</p>																																																									
<p>Yn</p>	<p>Yn= 0.150 gVSS/g Nox</p>																																																									
<p><math>b_n</math> average</p>	<p><math>b_n = 0.1075 = b_{NOB1} \cdot (t_a/T_c) + b_{NOB2} \cdot (1 - t_a/T_c)</math></p>																																																									
<p><math>b_{NOB1}</math> at aerobic</p>	<p><math>b_{NOB} = 0.1700 = b \cdot 1.029^{(T-20)}</math> b at 20°C = 0.170</p>																																																									
<p><math>b_{NOB2}</math> at anoxic</p>	<p><math>b_{NOB} = 0.0700 = b \cdot 1.029^{(T-20)}</math> b at 20°C = 0.070</p>																																																									
<p>FractionVSS=</p>	<p>FractionVSS 0.742 = MLVSS/MLSS</p>																																																									
<p>(6) Determine amount of NH4-N oxidized</p>																																																										
<p>Biomass production <math>P_{X,bio} =</math></p>	<p><math>P_{X,bio} = 1,377.458 \text{ kg} = \text{SUM}(\textcircled{1} : \textcircled{3})</math></p> <p><math>\textcircled{1} = 1,119.586 \text{ kg} = Q \cdot Y_H(S_0 - S)[1 + b_H(SRT)]</math></p> <p><math>\textcircled{2} = 36.082 \text{ kg} = QY_n(NOx)[1 + b_{AOB}(SRT)]</math></p> <p><math>\textcircled{3} = 221.790 = f_d \cdot b_H \cdot QY_H(S_0 - S)SRT/[1 + b_H(SRT)]</math></p>																																																									
	<p>NOx= 52.471 mg/l = <math>TN_0 - N_c - 0.12P_{X,bio}/Q</math></p> <p>&lt; 52.500 mg/l (assumed Nox) <b>OK</b></p>																																																									



Reference\_Process Cal. SBR&al 10MLD\_Appendix 12.2.3

**STP Process Calculation Supporting Report 12.2.3**

<p>(7) NO3-N Produced per cycles</p>	<p>At tank full NO3-N = 34,980 gNOx/fill 7.871 g/m3 concentration &lt; 9.0 g/m3 <b>OK</b></p> <p>After decant NO3-N = 29,733 gNOx/decant 7.871 g/m3 concentration</p> <p>At tank full Xb= 923.658 g/m3 =Px, bio*SRT/V<sub>T</sub> Biomass= 4,105 kg</p> <p>Q<sub>F</sub>= 10,000 m3/d =V<sub>F</sub>/t<sub>F</sub> Q<sub>F</sub>*S<sub>O</sub>= 3,500 kg/day</p>																				
<p>(8) Initial NH4-N</p> <p>V<sub>F</sub>(NOx)= V<sub>s</sub>(Ne)=</p>	<p>N<sub>O</sub>= 8.721 mg/l = [V<sub>F</sub>(NOx)+V<sub>s</sub>(Ne)]/V<sub>T</sub></p> <p>V<sub>F</sub>(NOx)= 34.980 kg V<sub>s</sub>(Ne)= 3.778 kg</p>																				
<p>(9) Nitrifier concentration</p> <p>b<sub>NOB</sub></p>	<p>X<sub>n</sub>= 29.8 mg/l = Q*Y<sub>n</sub>*NOx*SRT/[1+b<sub>NOB</sub>(SRT)]/V</p> <p>b<sub>NOB</sub>= 0.1075</p>																				
<p>(10) Review of Aeration time for nitrification</p>	<p>t= <math>\frac{8.80341845}{142.8063241} = \frac{K_{NH4} \ln(N_o/N_i) + (N_o - N_i)}{X_n(\mu_{max, AOB}/Y_n)[S_o/(K_{s, AOB} + S_o)]}</math></p> <p>t= 0.062 day 1.480 h &lt; 1.80 h (Aeration time) <b>OK</b></p> <p><math>\mu_{max, NOB, T} = 0.9000 \text{ g/g}\cdot\text{d} = \mu_{max} * 1.072^{(T-20)}</math> <math>\mu_{max}</math> at 20°C = 0.900 <math>\mu_{NOB, T} = 0.7200 \text{ g/g}\cdot\text{d} = \mu_{max, NOB} [S_o / (S_o + K_{O2, NOB})]</math> S<sub>o</sub>= 2.000 mg/l K<sub>O2, NOB</sub>= 0.500 mg/l K<sub>NH4</sub>= 0.500 mg/l</p>																				
<p>[3] Design for Denitrification Process</p>																					
<p>(1) F/M<sub>b</sub></p>	<p>F/M<sub>b</sub>= 0.853 g/g·d</p>																				
<p>(2) Fraction of rbCOD</p>	<p>40.00% =rbCOD/bCOD</p> <table border="1" data-bbox="686 1355 1077 1556"> <thead> <tr> <th rowspan="2">Percent rdCOD(%)</th> <th colspan="2">SDNR equation coefficients</th> </tr> <tr> <th>b0</th> <th>b1</th> </tr> </thead> <tbody> <tr> <td>10</td> <td>0.186</td> <td>0.078</td> </tr> <tr> <td>20</td> <td>0.213</td> <td>0.118</td> </tr> <tr> <td>30</td> <td>0.235</td> <td>0.141</td> </tr> <tr> <td>40</td> <td>0.242</td> <td>0.152</td> </tr> <tr> <td>50</td> <td>0.270</td> <td>0.162</td> </tr> </tbody> </table>	Percent rdCOD(%)	SDNR equation coefficients		b0	b1	10	0.186	0.078	20	0.213	0.118	30	0.235	0.141	40	0.242	0.152	50	0.270	0.162
Percent rdCOD(%)	SDNR equation coefficients																				
	b0	b1																			
10	0.186	0.078																			
20	0.213	0.118																			
30	0.235	0.141																			
40	0.242	0.152																			
50	0.270	0.162																			
<p>(3) SDNRb</p>	<p>SDNR= 0.194 g/g·d =SDNR<sub>0</sub> * θ<sup>(t-20)</sup> θ= 1.026</p> <p>SDNRb= 0.194 g/g·d = b<sub>0</sub>+b<sub>1</sub>[ln(F/M<sub>b</sub>)] b<sub>0</sub>= 0.213 b<sub>1</sub>= 0.118</p>																				
<p>(4) NO3-N removal capacity during the fill period (per tank)</p>	<p>NOx= 797,144 g/g·d =SDNR<sub>0</sub>(X<sub>b</sub>)(V<sub>T</sub>)</p>																				
<p>(5) NO3-N removal capacity :NO<sub>r</sub></p>	<p>NO<sub>r</sub>= 41,518 g =NO<sub>x</sub> * td/24 &gt;Nox feed= 29,733 g <b>OK</b> td= 1.250 hr</p>																				

Reference\_Process Cal. SBR&al 10MLD.Appendix 12.2.3

**STP Process Calculation\_Supporting Report 12.2.3**

<p><b>[4] Design of Phosphorous Removal Process</b></p> <p>(1) Removal T-P                      P in waste sludge                      Generated waste sludge                      Rwmoval Phosphorus</p> <p>(2) Effluent T-P without Al</p> <p>(3) Required Al toinitial soluble phosphourus ratio</p> <p>(4) Required Al dosing rate</p> <p>(5) Required Alumnum Sulfate</p> <p>(6) Required Alumnum Sulfate solutiic 10%</p> <p>(7) Additional sludge</p>	<p style="text-align: right;">2.70 mg/l</p> <p>px= 1.00%</p> <p>Px,vss= 2697.047 kg /d</p> <p style="text-align: right;">26.970 kg /d</p> <p style="text-align: right;">4.30 mg/l</p> <p style="text-align: right;">1.00 mol/mol</p> <p style="text-align: right;">3.48 mg/l as Al</p> <p style="text-align: right;">42.98 mg/l as crystal, Al2(SO4)3·18H2O</p> <p style="text-align: right;">429.78 kg/d</p> <p style="text-align: right;">4.09 m3/d</p> <p style="text-align: right;">170.55 L/H</p> <p style="text-align: right;">174.23 kg/d</p>																																																																				
<p><b>[5] Geometry</b></p> <p>(1) Basin Dimensions</p> <p>Cross Section</p> <p>Total Volume</p> <p><b>[6] Equipment</b></p> <p>(1) RAS Pumps</p> <p>RAS Ratio</p> <p>Required Capacity</p> <p>Number</p> <p>(2) SAS Pumps</p> <p>Excess Sludge</p> <p>Sludge withdraw</p> <p>Running Time</p> <p>Required Capacity</p> <p>Number</p>	<table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Width</th> <th style="text-align: left;">Length</th> <th style="text-align: left;">Depth</th> <th style="text-align: left;">Basins</th> </tr> </thead> <tbody> <tr> <td>16.0</td> <td>56.0</td> <td>5.0</td> <td>3</td> </tr> <tr> <td colspan="2">16.0*5.0</td> <td>=</td> <td>80.0 m<sup>2</sup>/Basin</td> </tr> <tr> <td colspan="2">80.0*56.0</td> <td>=</td> <td>4,480 m<sup>3</sup>/Basin &gt; 4,444 m<sup>3</sup></td> </tr> <tr> <td colspan="2"></td> <td></td> <td>13,440 m<sup>3</sup>/Total</td> </tr> </tbody> </table> <table style="width: 100%; border-collapse: collapse;"> <tbody> <tr> <td style="width: 30%;">10</td> <td style="width: 30%;">%</td> <td style="width: 30%;"></td> <td style="width: 10%;"></td> </tr> <tr> <td>417</td> <td>m3/h×</td> <td>10%</td> <td></td> </tr> <tr> <td>= 42</td> <td>m3/Hr ⇒</td> <td>45</td> <td>m3/Hr</td> </tr> <tr> <td>3</td> <td>Work</td> <td></td> <td></td> </tr> <tr> <td>3</td> <td>Stanby (Spare)</td> <td></td> <td></td> </tr> </tbody> </table> <table style="width: 100%; border-collapse: collapse;"> <tbody> <tr> <td style="width: 30%;">478</td> <td style="width: 30%;">m3/day</td> <td style="width: 30%;"></td> <td style="width: 10%;"></td> </tr> <tr> <td>5</td> <td>cycles/day</td> <td></td> <td></td> </tr> <tr> <td>1.0</td> <td>Hr/Time</td> <td></td> <td></td> </tr> <tr> <td>478</td> <td>m3/day /</td> <td>5 /</td> <td>1.00 / 3</td> </tr> <tr> <td>= 31.86</td> <td>m3/Hr ⇒</td> <td>40</td> <td>m3/Hr</td> </tr> <tr> <td>3</td> <td>Work</td> <td></td> <td></td> </tr> <tr> <td>3</td> <td>Stanby (Spare)</td> <td></td> <td></td> </tr> </tbody> </table>	Width	Length	Depth	Basins	16.0	56.0	5.0	3	16.0*5.0		=	80.0 m <sup>2</sup> /Basin	80.0*56.0		=	4,480 m <sup>3</sup> /Basin > 4,444 m <sup>3</sup>				13,440 m <sup>3</sup> /Total	10	%			417	m3/h×	10%		= 42	m3/Hr ⇒	45	m3/Hr	3	Work			3	Stanby (Spare)			478	m3/day			5	cycles/day			1.0	Hr/Time			478	m3/day /	5 /	1.00 / 3	= 31.86	m3/Hr ⇒	40	m3/Hr	3	Work			3	Stanby (Spare)		
Width	Length	Depth	Basins																																																																		
16.0	56.0	5.0	3																																																																		
16.0*5.0		=	80.0 m <sup>2</sup> /Basin																																																																		
80.0*56.0		=	4,480 m <sup>3</sup> /Basin > 4,444 m <sup>3</sup>																																																																		
			13,440 m <sup>3</sup> /Total																																																																		
10	%																																																																				
417	m3/h×	10%																																																																			
= 42	m3/Hr ⇒	45	m3/Hr																																																																		
3	Work																																																																				
3	Stanby (Spare)																																																																				
478	m3/day																																																																				
5	cycles/day																																																																				
1.0	Hr/Time																																																																				
478	m3/day /	5 /	1.00 / 3																																																																		
= 31.86	m3/Hr ⇒	40	m3/Hr																																																																		
3	Work																																																																				
3	Stanby (Spare)																																																																				
<p>(4) Alum Solution Tank</p> <p>Number</p> <p>Alum concentration as crystal</p> <p>Gravity of dissolved dechlorine</p> <p>Required solution volume</p> <p>Volume of Tank</p> <p>Total Volume of Tanks</p> <p>(5) Mixer for Alum Solution Tank</p> <p>Number</p> <p>(6) Alum Dosing Pump</p> <p>Number</p> <p>Capacity</p>	<table style="width: 100%; border-collapse: collapse;"> <tbody> <tr> <td style="width: 30%;">2</td> <td style="width: 30%;">W</td> <td style="width: 30%;">+</td> <td style="width: 10%;">0</td> <td style="width: 10%;">S</td> </tr> <tr> <td>10</td> <td>%</td> <td></td> <td></td> <td></td> </tr> <tr> <td>1.05</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>429.78</td> <td>kg / d</td> <td>×</td> <td>100 /</td> <td>10 /</td> </tr> <tr> <td>=</td> <td>4.09</td> <td>m3/d</td> <td>1.05 /</td> <td>1000</td> </tr> <tr> <td>2.6</td> <td>m3/tank</td> <td></td> <td></td> <td></td> </tr> <tr> <td>5.2</td> <td>m3</td> <td>(Duration=</td> <td>1.27</td> <td>day)</td> </tr> </tbody> </table> <table style="width: 100%; border-collapse: collapse;"> <tbody> <tr> <td style="width: 30%;">2</td> <td style="width: 30%;">W</td> <td style="width: 30%;">+</td> <td style="width: 10%;">0</td> <td style="width: 10%;">S</td> </tr> </tbody> </table> <table style="width: 100%; border-collapse: collapse;"> <tbody> <tr> <td style="width: 30%;">3</td> <td style="width: 30%;">W</td> <td style="width: 30%;">+</td> <td style="width: 10%;">1</td> <td style="width: 10%;">S</td> </tr> <tr> <td>4.09</td> <td>m3/d /</td> <td>24</td> <td>×</td> <td>1000 /</td> </tr> <tr> <td>113.70</td> <td>l/h/unit</td> <td>⇒</td> <td>120</td> <td>l/h/unit</td> </tr> </tbody> </table>	2	W	+	0	S	10	%				1.05					429.78	kg / d	×	100 /	10 /	=	4.09	m3/d	1.05 /	1000	2.6	m3/tank				5.2	m3	(Duration=	1.27	day)	2	W	+	0	S	3	W	+	1	S	4.09	m3/d /	24	×	1000 /	113.70	l/h/unit	⇒	120	l/h/unit													
2	W	+	0	S																																																																	
10	%																																																																				
1.05																																																																					
429.78	kg / d	×	100 /	10 /																																																																	
=	4.09	m3/d	1.05 /	1000																																																																	
2.6	m3/tank																																																																				
5.2	m3	(Duration=	1.27	day)																																																																	
2	W	+	0	S																																																																	
3	W	+	1	S																																																																	
4.09	m3/d /	24	×	1000 /																																																																	
113.70	l/h/unit	⇒	120	l/h/unit																																																																	