

APPENDIX FOR CHAPTER 2 CURRENT SITUATIONS AND EFFORT IN ACTIVITIES

AF2.1 PRESENT SERVICE CONDITIONS IN WASA-F SERVICE AREA

1. Current Production and Water Demand

The present (2016) water source is composed of three groundwater systems and four surface water (WTP) systems. Out of three groundwater system, the largest one is Chenab well field system followed by Jhang Branch Canal (JBC) Well Field system. The Rahk Branch Canal (RBC) well field system is the oldest system, but its capacity is the smallest one. Out of four WTP system, one is newly constructed New Jhal Khanuana WTP and three slow sand filtration plants including Original Jhal Khanuana, Millat Town and Ghulfishan Colony WTPs. The Ghulfishan Colony WTP is presently under rehabilitation. The Production capacity (Design Capacity) and the present production are summarized in the following table.

Table 1 Production Capacity and Current (2016) Distribution Flow of Water Source Facilities

Production Facilities	Production Capacity		Day Average Distribution		Day Maximum Distribution	
	m ³ /day	MGD	m ³ /day	MGD	m ³ /day	MGD
Chenab Well Field	254,600	56	144,540	32	174,840	38
JBC Well Field	90,900	20	56,780	12	90,900	20
RBC Well Field	81,800	18	7,370	2	7,370	2
New Jhal Khanuana WTP	45,500	10	20,440	4	35,000	8
Original Jhal Khanuana WTP	15,900	3.5	6,800	1	6,800	1
Millat Town WTP	4,500	1.0	4,000	1	4,000	1
Ghulfishan Colony WTP	6,800	1.5	-	-	-	-
Total	500,000	110	239,530	52	318,510	70

The present water supply area is divided into 15 areas (Distribution Zones) which are supplied from Chenab Well Field system, JBC Well Field system, New and Original Jhal Khanuana WTP system and one slow sand filtration plant system (Millat Town WTP), where well water is transmitted to Terminal reservoir from where water is distributed through Arterial Main network. Jhal Khanuana WTPs distribute finished water through also Arterial Main network. Millat Town WTP distribute finished water locally around the WTP. The service areas fed directly from RBC Tube Well Pumps which supply capacity is too small comparing with potential demand of the service areas, thus the service conditions of these service areas shall be poor. The present number of service connections (Domestic Use) is estimated about 140,000 units, thus average demand per connection is calculated at about 1.714 m³/day/connection (239,930/140,000).

2. Distribution Pumps

The dimension of distribution pump of each system above is summarized in the following table.

Table 2 Dimensions of Distribution Pumps

Production System	Pump A			Pump B			Total Pump Capacity	
	Discharge	Head	Number	Discharge	Head	Number	m ³ /day	m ³ /hr
	m ³ /min	m	unit	m ³ /min	m	unit		
Old Terminal Reservoir ^{*1}	37.5	45.12	^W 5+ ^S 2	27.4	45.12	^W 2+ ^S 1	348,900	14,500
New Terminal Reservoir ^{*2}	63.2	45.12	^W 2+ ^S 1	31.6	45.12	^W 1+ ^S 1	227,500	9,480
New Jhal Khanuana WTP	15.8	35	^W 2+ ^S 1	-	-	-	45,500	1,890
Original Jhal Khanuana WTP	3.4	38	^W 1+ ^S 1	5.1	36.6	^W 1+ ^S 1	12,200	510
Millat Town WTP	5.1	36.6	^W 1+ ^S 1	3.4	30.5	^W 2+ ^S 1	14,700	610
RBC Well Field ^{*3}	1.7	39.6	^W 12+ ^S 2	-	-	-	7,370	612

Note: ^{*1} Supply from Chenab Well Field ^{*2} Supply from JBC Well Field

^{*3} Daily production is estimated based on 6 hours operation of well pumps per day

3. Arterial Main Network

Arterial mains are installed surrounding core area of the City as shown on Fig. 1. The size of arterial main is ranging from 500mm to 1,600mm in diameter. The total length of arterial mains is about 53.9 km including those from Terminal Reservoir system and Original & New Jhal Khanuana WTP systems.




Fig.1 Arterial Network and Distribution Zones

4. Assessment of Supply Conditions

4.1 Water Demand Distribution

Water demand of each distribution zone (DZ) is estimated based on the ratio of area covered by the tertiary mains (ND 80~100mm). GIS map is used for measuring these areas. The following table presents the demand distribution of DZs.

Table 3 Demand Distribution to Distribution Zone (DZ)

DZ	Area	Water Demand			DZ	Area	Water Demand		
		Day Average		Peak Flow			Day Average		Peak Flow
	km ²	m ³ /day	l/s	l/s		km ²	m ³ /day	l/s	l/s
1	2.118	8,990	104.1	208.1	9	3.371	14,300	166.5	331.0
2	3.672	15,580	180.3	360.6	10	3.729	15,820	183.1	366.2
3	6.420	27,240	315.3	630.6	11	5.326	22,600	261.6	523.1
4	5.071	21,510	249.0	497.9	12	6.900	29,270	338.8	677.5
5	3.328	14,120	163.4	326.9	13	1.695	7,190	83.2	166.4
6	3.938	16,710	193.4	386.8	14	0.954	4,050	46.9	93.8
7	3.169	13,440	155.6	311.1	15	2.524	10,710	124.0	247.9
8	2.610	11,070	128.1	256.3	Total	54.825	232,600	2,692.1	5,384.3

Note: peak factor of 2.0 is applied

4.2 Overview of the Present Distribution System

Distribution Network System (Arterial Main System) is considered as combined one system fed from Terminal Reservoir and Jhal Khanuana WTP. On the other hand, RBC system is considered separate from the mentioned arterial main network system. Therefore RBC distribution system is considered as independent system.

In service area, there are 40 overhead reservoirs exist. However, the capacity and height of overhead reservoir (OHR) are small, thus the covered area by OHR will be small except a few areas served by large capacity and high height of OHRs. On the other hand, many service areas are considered supplied from the arterial main network directly. These mixed supply conditions from water sources results complex distribution system as a whole.

The arterial main network system is composed of seven grids. The large supply area surrounding this arterial network has been developed. Therefore, supply conditions of surrounding area of the arterial network will be depending on the capacity of the distribution pipelines fed by the arterials network although pressure conditions of arterials network is considered as good.

Considering the present complicated distribution system, limited information of distribution system and time constraint, this assessment will not be accurate enough. However, the assessment will show tendency of deteriorating supply conditions toward remote areas from arterial network.

4.3 Methodology of Hydraulic Analysis

The assessment of service conditions of 15 DZs is carried out as followed:

- Grasping water demand of distribution block in each distribution zone,
- Hydraulic analysis of existing distribution mains (dia. 150mm and above) from the arterials network in each DZ giving assumed tapping pressures,
- Carrying out network analysis of arterial mains using discharge for each distribution zone using the results of network analysis made above, and
- Repeat the above trial analysis to fined similar results of pressure at tapping points for distribution zones on the arterial network.

4.4 Assumption of Hydraulic Analysis

The following assumptions are set-up for hydraulic analysis that

1. Arterial Network from the Terminal Reservoirs (Chenab and JBC Well Field) and New Jhal Khanuana WTP System are connected and they work as one network.
2. In this analysis, all service areas are if they are supplied directly from the arterial network system, although the present distribution system is mixed with direct supply from the arterial network and system through overhead reservoirs partly.
3. Water demand of respective distribution zones is distributed in proportion to the area where tertiary mains are installed.
4. Service area of DZ is further divided into distribution blocks which boundaries are determined in accordance with layout of the existing secondary mains, where water demand is distributed similarly as mentioned above.
5. Hydraulic analysis is made using Hazen & Williams Formula, where loss co-efficient of C as 110 is applied.
6. Effective pressure of 14m at tertiary network (12m tapping pressure to service connection + 2m head loss of tertiary network) is considered as appropriate.
7. Day Average Demand is taken for hydraulic analysis, where peak hourly factor of 2.0 is applied which obtained from SCADA data on fluctuation of distribution flow (Main Report Fig. B3.4.4)
8. Distribution system is assumed to be composed of three groups due to its size, namely primary, secondary and tertiary mains. The size and function of each kind of distribution main is defined as follows:

Kind of Mains	Primary Main	Secondary Main	Tertiary Main
Size of Mains	ND 300mm or Larger	ND 150 ~ 250mm	ND 80 and 100mm
Function	Distribute water in respective area of DZ.	Branch from primary main to distribute water to respective blocks of DZ	Generally service connection is tapped from tertiary mains

It is assumed that, in general, branch will not be provided from primary main to tertiary mains.

5. Result of Assessment

The result of supply conditions of 15 distribution zones are illustrated in Fig. 2, where pressure conditions of blocks of DZ are shown.

Evaluation criteria of supply conditions are based on the pressure condition of secondary main of service area, and it is set-up as follows:

- “Good” is that pressure condition of 5m or above is observed at 80% or more in DZ.
- “Fair” is that pressure condition with 5m or above is observed at more than 60% in DZ.
- “Poor” is that pressure condition of more than 5m is observed at less than 60% in DZ.

Based on the above evaluation criteria, the service conditions of respective distribution zones are summarized and presented in table below.

Table 3 Evaluated Service Condition in Distribution Zones

Distribution Zone (DZ)	Estimated Demand ^{*1}	Estimated Connection	Pressure Condition		Evaluation	Capacity of Distribution		Distance from Arterial Main ^{*1}
			P > 14m	P > 5m		Primary	Secondary	
	m ³ /day	units	%	%		m ³ /conn.	m ³ /conn.	km
DZ - 1	8,990	5,250	57	0	Poor	-	0.020	1.9
DZ - 2	15,580	9,090	81	0	Good	0.025	0.028	1.6
DZ - 3	27,240	15,890	30	11	Poor	0.028	0.034	2.7
DZ - 4	21,510	12,550	74	12	Good	0.006	0.039	0.7
DZ - 5	14,120	8,340	25	40	Fair	0.040	0.047	3.2
DZ - 6	16,710	9,230	49	7	Poor	0.035	0.069	2.8
DZ - 7	13,440	7,840	100	0	Good	0.053	0.033	2.3
DZ - 8	11,070	6,450	100	0	Good	0.154	0.045	2.7
DZ - 9	14,300	8,340	100	0	Good	0.131	0.045	2.3
DZ -10	15,820	9,230	32	36	Fair	0.015	0.049	2.0
DZ -11	22,600	13,190	66	0	Fair	0.014	0.035	1.1
DZ -12	29,270	17,080	28	5	Poor	0.009	0.039	3.1
DZ -13	7,190	4,200	100	0	Good	0.019	0.042	1.6
DZ -14	4,050	2,360	56	44	Good	0.037	0.020	1.4
DZ -15	10,710	6,250	32	7	Poor	0.012	0.028	5.0

Note ^{*} the distance shown is from arterial main to remote end of distribution zones




Fig. 2 Service Conditions of Distribution Zones

ATTACHMENT

ATTACHMENT 1

Distribution Block of DZ




Fig. A.1.1 Distribution Zone 01




Fig. A.1.2 Distribution Zone 02




Fig. A.1.3 Distribution Zone 03




Fig. A.1.4 Distribution Zone 04




Fig. A.1.5 Distribution Zone 05




Fig. A.1.6 Distribution Zone 06




Fig. A.1.7 Distribution Zone 07




Fig. A.1.8 Distribution Zone 08




Fig. A.1.9 Distribution Zone 09




Fig. A.1.10 Distribution Zone 10




Fig. A.1.11 Distribution Zone 11




Fig. A.1.12 Distribution Zone 12




Fig. A.1.13 Distribution Zone 13



Fig. A.1.14 Distribution Zone 14




Fig. A.1.15 Distribution Zone 15

ATTACHMENT 2
Arterial MAIN Network




Fig. A.2 Layout of Arterial Main Network

ATTACHMENT 2.1

NETWORK ANALYSIS OF ARTERIAL MAIN -1

Node Data

Node No.	Discharge		WL m	GL m	Eff. Head m
	CMD	l/s			
TREx ^{*1}	-329,290	-3,811.2	233.00	188	45.00
TRNw ^{*2}	-78,483	-908.4	233.00	188	45.00
NJK WTP ^{*3}	-52,168	-603.8	214.20	187	27.20
z01a/z02a	23,401	270.8	223.29	183	40.29
z01b	4,965	57.5	224.56	184	40.56
z02b	3,210	37.2	222.19	185	37.19
z02c	12,115	140.2	221.61	185	36.61
z02d	5,434	62.9	220.55	185	35.55
z03a	24,279	281.0	219.96	183	36.96
z03b	3,741	43.3	218.10	186	32.10
z03c	12,854	148.8	217.94	186	31.94
z03d	13,609	157.5	217.81	186	31.81
z04a	4,948	57.3	218.73	183	35.73
z04b/z05a	14,767	170.9	217.64	186	31.64
z04c/z05b	12,483	144.5	217.64	185	32.64
z04d	6,063	70.2	217.89	186	31.89
z04e	3,246	37.6	218.42	186	32.42
z04f	4,337	50.2	217.42	189	28.42
z04g	0	0.0	219.09	186	33.09
z04h	7,849	90.8	217.41	190	27.41
z04i	11,167	129.2	217.50	187	30.50
z04j	2,722	31.5	222.81	185	37.81
z05c	4,192	48.5	217.10	185	32.10
z06a	3,231	37.4	214.44	188	26.44
z06b	7,448	86.2	213.80	186	27.80
z06c	7,388	85.5	213.68	188	25.68
z06d	15,353	177.7	213.65	186	27.65
z07/08/09a	64,949	751.7	222.25	185	37.25
z07b	5,359	62.0	223.08	185	38.08
z07c	2,486	28.8	219.30	187	32.30
z07d	2,722	31.5	214.73	186	28.73
z07e	2,062	23.9	214.54	187	27.54
z10a	12,897	149.3	214.20	187	27.20
z10b	916	10.6	213.19	185	28.19
z10c	7,424	85.9	212.70	186	26.70
z10d	10,394	120.3	212.00	186	26.00
z11a	7,176	83.1	213.85	188	25.85
z11b	14,161	163.9	213.95	190	23.95
z11c	3,855	44.6	211.85	183	28.85
z11d	4,275	49.5	211.08	186	25.08
z11e	6,623	76.7	211.03	185	26.03
z11f	9,123	105.6	211.10	186	25.10
z12a	11,706	135.5	213.66	182	31.66
z12b	13,174	152.5	212.20	184	28.20
z12c	13,517	156.4	211.21	184	27.21
z12d	3,983	46.1	211.56	186	25.56
z12e	8,027	92.9	211.99	185	26.99

Node No.	Discharge		WL m	GL m	Eff. Head m
	CMD	l/s			
z12f	8,354	96.7	211.21	185	26.21
z13a	14,386	166.5	225.67	185	40.67
z14a	8,104	93.8	229.97	182	47.97
z15a	15,466	179.0	225.86	185	40.86
J101	0	0.0	232.70	185	47.70
J107	0	0.0	222.97	185	37.97
J108	0	0.0	223.71	182	41.71
J111	0	0.0	227.54	182	45.54
J128	0	0.0	218.45	190	28.45
J129	0	0.0	222.08	187	35.08
J131	0	0.0	226.26	183	43.26
J140	0	0.0	218.10	187	31.10
J142	0	0.0	218.76	185	33.76
J143	0	0.0	219.40	187	32.40
J144	0	0.0	219.71	187	32.71
J145	0	0.0	218.13	189	29.13
J146	0	0.0	217.09	193	24.09
J147	0	0.0	214.94	186	28.94
J149	0	0.0	215.65	190	25.65
J150	0	0.0	214.27	190	24.27
J151	0	0.0	217.28	189	28.28
J152	0	0.0	217.15	185	32.15
J153	0	0.0	217.02	186	31.02
J154	0	0.0	215.54	189	26.54
J155	0	0.0	214.64	187	27.64
J156	0	0.0	214.59	186	28.59
J157	0	0.0	213.75	183	30.75
J180	0	0.0	212.19	184	28.19
J199	0	0.0	232.81	185	47.81
J401	0	0.0	211.84	186	25.84
J402	0	0.0	211.80	186	25.80
J405	0	0.0	212.35	185	27.35
J406	0	0.0	211.62	186	25.62
J408	0	0.0	211.41	187	24.41
J409	0	0.0	211.39	187	24.39
J606	0	0.0	211.78	183	28.78
J701	0	0.0	214.15	190	24.15
J702	0	0.0	214.13	190	24.13
J703	0	0.0	214.07	190	24.07
J705	0	0.0	213.89	185	28.89
J706	0	0.0	213.88	188	25.88
J708	0	0.0	213.25	184	29.25
J709	0	0.0	213.22	184	29.22
J710	0	0.0	213.20	184	29.20
J711	0	0.0	214.18	187	27.18
J713	0	0.0	212.22	184	28.22
J716	0	0.0	211.87	184	27.87

ATTACHMENT 2.2.1

NETWORK ANALYSIS OF ARTERIAL MAIN - 2.1

Pipeline Data -1

Node Number		Dia	Length	Friction L.	Head Loss	Flow		Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	m ³ /d	l/s	m/s	%o
TREx	J101	1,600	140.4	110	0.30	329,290	3,811.2	1.90	2.13
TRNw	J199	1,000	125.7	110	0.19	78,483	908.4	1.16	1.48
NJK WTP*3	J711	800	10.0	110	0.02	52,168	603.8	1.20	2.06
z03b	z04a	800	399.1	110	-0.62	-44,974	-520.5	-1.04	1.56
J101	z14a	1600	1,278.4	110	2.72	329,290	3,811.2	1.90	2.13
z04a	z03a	800	650.0	110	-1.24	-49,922	-577.8	-1.15	1.90
z04f	z05c	800	698.6	110	0.32	23,214	268.7	0.53	0.46
J146	J147	800	958.7	110	2.16	54,668	632.7	1.26	2.25
z11a	z10b	800	699.9	110	0.66	34,451	398.7	0.79	0.95
z12d	J408	500	323.5	110	0.15	6,732	77.9	0.40	0.46
J711	J702	800	990.8	110	-0.05	6,935	80.3	0.16	0.05
z13a	z01a/z02a	1,200	1,927.3	110	2.51	118,361	1,369.9	1.21	1.30
z02b	z01a/z02a	900	313.1	110	-1.10	-94,960	-1,099.1	-1.73	3.52
z03a	z02d	1,000	439.8	110	-0.58	-74,201	-858.8	-1.09	1.33
z-4b/z05/a	z03d	800	834.9	110	-0.17	-14,770	-171.0	-0.34	0.20
z04e	L140	900	353.8	110	0.33	46,093	533.5	0.84	0.92
J142	z04e	900	325.7	110	0.34	49,339	571.1	0.90	1.05
J129	J144	900	671.0	110	2.38	95,317	1,103.2	1.74	3.54
J108	z07b	1,200	627.6	110	0.63	103,059	1,192.8	1.06	1.01
z151	z01b	1,400	1,044.0	110	1.29	172,973	2,002.0	1.30	1.24
J111	z15a	1,400	1,156.0	110	1.68	188,439	2,181.0	1.42	1.45
J129	z07c	900	1,136.6	110	2.78	78,144	904.4	1.42	2.45
z04h	J151	600	383.7	110	0.13	9,184	106.3	0.38	0.34
z04c/z05b	z041	800	359.6	110	0.23	27,551	318.9	0.63	0.63
J154	J153	600	550.1	110	-1.47	-28,206	-326.5	-1.16	2.68
J155	J154	600	337.6	110	-0.90	-28,206	-326.5	-1.16	2.68
z06b	z06a	700	639.3	110	-0.65	-24,975	-289.1	-0.75	1.01
z06c	J157	800	276.8	110	-0.07	-17,527	-202.9	-0.40	0.27
z06d	z06c	800	299.7	110	-0.03	-10,139	-117.4	-0.23	0.10
J713	z12a	600	534.9	110	-1.44	-28,313	-327.7	-1.16	2.70
z12f	z12c	600	454.0	110	-0.00	-1,622	-18.8	-0.07	0.01
J409	z12f	500	401.6	110	0.18	6,732	77.9	0.40	0.46
J401	J406	500	199.8	110	0.22	10,715	124.0	0.63	1.08
z11d	J402	500	1,140.8	110	-0.74	-8,159	-94.4	-0.48	0.65
z11e	z11d	500	299.7	110	-0.05	-3,884	-45.0	-0.23	0.17
J606	z11f	500	521.2	110	0.68	11,862	137.3	0.70	1.31
z10a	z11a	800	317.8	110	0.35	36,987	428.1	0.85	1.09
z07d	z07e	800	92.0	110	0.19	51,946	601.2	1.20	2.04
J107	z07/08/09a	1,000	694.4	110	0.72	64,949	751.7	0.96	1.04
z10c	z10d	700	633.8	110	0.70	26,111	302.2	0.79	1.10
J706	J705	700	355.4	110	0.01	-4,640	-53.7	-0.14	0.04
J408	J409	500	36.6	110	0.02	6,732	77.9	0.40	0.46
J140	z04d	1,000	376.5	110	0.21	46,093	533.5	0.68	0.55
z04d	z04c/z05b	900	344.9	110	0.24	40,030	463.3	0.73	0.71
J131	J111	1,200	795.0	110	-1.28	-132,747	-1,536.4	-1.36	1.61
z13a	J131	1,200	363.7	110	-0.59	-132,747	-1,536.4	-1.36	1.61
J152	J151	600	404.5	110	-0.14	-9,184	-106.3	-0.38	0.34
z05c	J153	800	255.4	110	0.08	19,022	220.2	0.44	0.32
J145	J128	1,000	230.1	110	0.32	-75,658	-875.7	-1.12	1.38
J145	J146	800	465.5	110	1.05	54,668	632.7	1.26	2.25

ATTACHMENT 2.2.2

NETWORK ANALYSIS OF ARTERIAL MAIN - 2.2


Pipeline Data -2

Node Number		Dia	Length	Friction L.	Head Loss	Flow		Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	m ³ /d	l/s	m/s	%
z11b	J705	700	1,245.4	110	-0.05	4,640	53.7	0.14	0.04
J702	J703	800	206.2	110	0.06	18,801	217.6	0.43	0.31
J406	z12d	500	57.8	110	0.06	10,715	124.0	0.63	1.08
z01b	J108	1,200	343.3	110	0.85	168,008	1,944.5	1.72	2.49
J716	J180	600	378.9	110	-0.32	-15,139	-175.2	-0.62	0.85
J199	z04j	1,000	6,760.3	110	10.01	78,483	908.4	1.16	1.48
z04j	J129	1,200	275.5	110	0.73	173,461	2,007.6	1.78	2.64
J405	J710	700	732.7	110	-0.85	-26,901	-311.4	-0.81	1.16
z04i	J149	800	1,557.5	110	1.85	38,767	448.7	0.89	1.19
J150	J149	700	605.3	110	-1.38	-38,767	-448.7	-1.17	2.28
J701	J702	700	76.2	110	0.02	11,866	137.3	0.36	0.25
J143	z04g	900	297.4	110	0.31	49,339	571.1	0.90	1.05
z12a	J171	800	326.2	110	-0.52	-45,233	-523.5	-1.04	1.58
J716	z12c	600	773.2	110	0.66	15,139	175.2	0.62	0.85
J701	J708	700	780.3	110	0.91	26,901	311.4	0.81	1.16
z14a	J111	1,600	1,193.0	110	2.43	321,186	3,717.4	1.85	2.04
J152	J153	600	397.6	110	0.14	9,184	106.3	0.38	0.34
J143	J144	900	294.4	110	-0.31	-49,339	-571.1	-0.90	1.05
z12e	J401	700	253.0	110	0.15	18,874	218.5	0.57	0.60
J405	z12e	700	314.7	110	0.37	26,901	311.4	0.81	1.16
J708	J709	700	20.3	110	0.02	26,901	311.4	0.81	1.16
J713	z12b	700	20.3	110	0.03	28,313	327.7	0.85	1.27
J108	J107	1,000	707.1	110	0.74	64,949	751.7	0.96	1.04
J706	z11a	700	525.3	110	-0.02	4,640	53.7	0.14	0.04
z11c	J606	500	51.9	110	0.07	11,862	137.3	0.70	1.31
J710	J709	700	20.8	110	-0.02	-26,901	-311.4	-0.81	1.16
J401	J402	500	13.3	110	0.01	8,159	94.4	0.48	0.65
z12b	J180	700	20.4	110	0.01	15,139	175.2	0.46	0.40
J703	z11b	800	379.0	110	0.12	18,801	217.6	0.43	0.31
J155	J156	600	20.1	110	0.05	28,206	326.5	1.16	2.68
J144	z04i	800	1,355.5	110	2.21	45,977	532.1	1.06	1.63
J145	z04i	600	408.9	110	0.63	20,990	242.9	0.86	1.55
z06d	z12a	600	124.0	110	0.01	-5,214	-60.3	-0.21	0.12
J147	z07d	800	90.8	110	0.20	54,668	632.7	1.26	2.25
J150	J701	700	53.2	110	0.12	38,767	448.7	1.17	2.28
z02b	z02c	1,000	293.5	110	0.58	91,750	1,061.9	1.35	1.98
z02c	z02d	1,000	700.6	110	1.06	79,635	921.7	1.17	1.52
z03b	z03c	800	121.6	110	0.16	41,233	477.2	0.95	1.33
z03c	z03d	800	196.2	110	0.13	28,379	328.5	0.65	0.67
z04b/z05a	z04c/z05b	800	669.0	110	0.00	3	0.0	0.00	0.00
z04g	J142	900	310.5	110	0.33	49,339	571.1	0.90	1.05
z04i	z04h	900	596.4	110	0.09	17,033	197.1	0.31	0.15
J156	z06a	700	112.9	110	0.14	28,206	326.5	0.85	1.26
z06b	J157	700	83.4	110	0.04	17,527	202.9	0.53	0.52
z07b	z04j	1,200	286.5	110	0.26	97,700	1,130.8	1.00	0.91
z07c	J128	900	367.0	110	0.85	75,658	875.7	1.38	2.31
z07e	z10a	800	181.2	110	0.34	49,884	577.4	1.15	1.90
z10b	z10c	700	281.2	110	0.49	33,535	388.1	1.01	1.74
z10d	z11c	700	355.5	110	0.15	15,717	181.9	0.47	0.43
z11f	z11e	500	802.2	110	0.07	2,739	31.7	0.16	0.09

ATTACHMENT 3
Distribution Network of DZ

ATTACHMENT 3.1


Layout of Distribution Network




Distribution Zone - 01

Legend


- Arterial Main
- Distribution Main
- 110 Discharge Node of Arterial Main
- 10 Discharge Node of Distribution Main
- $Pe > 14m$
- $Pe : 5 \sim 14m$
- $Pe : < 5m$ (Positive)
- $Pe < 0$ (Nrgative)




Distribution Zone - 02




Distribution Zone - 03




Distribution Zone - 04




Distribution Zone - 05




Distribution Zone – 06.1




Distribution Zone – 06.2




Distribution Zone – 07




Distribution Zone – 08




Distribution Zone – 09





Distribution Zone – 10




Distribution Zone – 11




Distribution Zone – 12



Distribution Zone – 13



Distribution Zone – 14



Distribution Zone – 15

ATTACHMENT 3.2
DISTRIBUTION NETWORK ANALYSIS

Distribution Network Analysis for Zone 01

Node Data

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
z01a	-150.66	223.29	188	35.29
z01b	-57.64	224.56	188	36.56
1	13.8	209.60	188	21.60
2	9.9	207.94	188	19.94
3	4.5	209.24	188	21.24
4	3.3	209.08	188	21.08
5	8.3	219.55	188	31.55
6	11.2	218.23	188	30.23
7	5.3	217.27	188	29.27
8	1.4	217.26	188	29.26
9	2.7	217.19	188	29.19
10	4.1	217.15	188	29.15
11	10.4	216.00	188	28.00
12	27.8	210.34	188	22.34

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
13	17.80	199.58	188	11.56
14	9.00	192.63	188	4.61
15	14.40	178.70	188	-9.32
16	11.70	186.13	188	-1.88
17	6.80	186.69	188	-1.33
18	4.00	186.61	188	-1.41
19	9.50	193.17	188	5.16
20	4.10	198.87	188	10.86
21	3.60	210.32	188	22.31
22	3.60	223.02	188	35.01
23	3.70	224.50	188	36.49
24	3.60	224.53	188	36.52
25	7.10	178.18	188	-9.83
26	6.70	219.09	188	31.08

Pipeline Data

Node Number		Dia	Length	Friction L.	Head Loss	Flow	Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	l/s	m/s	%o
z01a	5	300	200	110	3.74	150.66	2.13	18.70
z01b	24	300	10	110	0.03	57.64	0.82	3.16
5	6	300	160	110	1.31	96.65	1.37	8.22
6	9	300	330	110	1.04	57.65	0.82	3.16
9	11	300	370	110	1.19	58.36	0.83	3.23
5	1	150	330	110	9.95	31.50	1.78	30.15
1	2	150	470	110	1.66	9.90	0.56	3.53
1	3	150	160	110	0.36	7.80	0.44	2.27
3	4	150	350	110	0.16	3.30	0.19	0.46
5	7	150	330	110	2.28	14.21	0.80	6.90
7	8	150	160	110	0.02	1.40	0.08	0.09
7	9	150	160	110	0.08	3.41	0.19	0.49
7	10	150	180	110	0.12	4.10	0.23	0.69
6	12	150	330	110	7.89	27.80	1.57	23.92
11	13	150	250	110	16.42	47.96	2.72	65.67
13	14	150	250	110	6.96	30.16	1.71	27.82
14	16	150	450	110	6.50	21.16	1.20	14.43
16	15	150	500	110	7.43	21.50	1.22	14.86
15	25	150	270	110	0.52	7.10	0.40	1.91
16	17	150	110	110	-0.56	-12.04	-0.68	-5.08
17	18	150	120	110	0.08	4.00	0.23	0.66
17	19	150	390	110	-6.48	-22.84	-1.29	-16.63
19	20	150	180	110	-5.70	-32.34	-1.83	-31.66
20	21	150	290	110	-11.45	-36.44	-2.06	-39.49
21	22	150	270	110	-12.69	-40.04	-2.27	-47.01
22	24	250	330	110	-1.51	-43.64	-0.89	-4.58
24	23	200	180	110	0.03	3.70	0.12	0.14
24	26	100	440	110	5.44	6.70	0.85	12.36

Distribution Network Analysis for Zone 02

Node Data

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
z02a	-120.19	223.29	184	39.29
z02b	-37.51	222.19	185	37.69
z02c	-140.22	221.61	185	36.61
z02d	-62.89	220.55	185	35.55
1	3.50	223.22	184	39.22
2	18.30	222.18	185	37.68
3	16.00	221.52	185	36.52
4	8.40	220.19	185	35.19
5	11.00	219.02	185	34.02
6	10.90	203.12	185	18.12
7	7.10	204.99	185	19.99
8	15.00	209.10	185	24.10
9	7.10	220.71	184	37.21
10	14.20	220.20	183	37.20
11	21.50	202.26	185	17.26
12	25.00	177.26	185	-7.74

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
13	10.70	174.61	185.000	-10.39
14	20.70	219.14	185.000	34.14
15	12.80	219.35	185.000	34.35
16	25.30	218.05	185.000	33.05
17	16.30	214.22	185.000	29.22
18	17.00	212.27	185.000	27.27
19	5.60	222.95	185.000	37.95
20	11.40	221.70	185.000	36.70
21	2.00	220.87	185.000	35.87
22	11.70	220.02	185.000	35.02
23	4.30	219.62	185.000	34.62
24	9.50	219.37	185.000	34.37
25	13.60	206.91	185.000	21.91
26	15.40	209.01	185.000	24.01
27	22.80	206.52	185.000	21.52
28	3.70	219.76	185.000	34.76

Pipeline Data

Node Number		Dia	Length	Friction L.	Head Loss	Flow	Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	l/s	m/s	%
z02a	1	300	10	110	0.07	91.62	1.30	7.45
z02b	2	250	10	110	0.01	16.20	0.33	0.73
z02c	3	300	10	110	0.09	99.59	1.41	8.69
z02d	15	250	180	110	1.20	53.39	1.09	6.66
z02d	15	250	180	110	1.20	53.39	1.09	6.66
z02d	24	150	360	110	1.18	9.50	0.54	3.28
z02a	19	300	400	110	0.34	28.57	0.40	0.86
z02b	20	250	400	110	0.49	21.31	0.43	1.22
z02c	21	300	450	110	0.74	40.62	0.57	1.65
1	2	150	300	110	1.03	9.76	0.55	3.44
2	3	150	300	110	0.66	7.66	0.43	2.20
3	4	300	180	110	1.33	91.25	1.29	7.39
4	5	250	200	110	1.17	49.90	1.02	5.87
5	6	150	480	110	15.90	33.14	1.88	33.13
6	7	150	300	110	-1.87	-13.46	-0.76	-6.25
7	8	150	300	110	-4.11	-20.56	-1.16	-13.68
8	9	200	520	110	-11.61	-57.06	-1.82	-22.33
9	1	300	450	110	-2.51	-78.36	-1.11	-5.58
9	10	200	300	110	0.51	14.20	0.45	1.70
8	11	150	460	110	6.84	21.50	1.22	14.87
6	12	150	680	110	25.85	35.70	2.02	38.02
12	13	150	650	110	2.65	10.70	0.61	4.08
14	15	250	180	110	-0.21	-20.70	-0.42	-1.15
15	14	250	180	110	0.21	20.70	0.42	1.15
15	4	300	750	110	-0.84	-32.95	-0.47	-1.12
15	16	250	200	110	1.31	52.84	1.08	6.53
16	5	150	750	110	-0.97	-5.76	-0.33	-1.30
16	17	150	430	110	3.83	16.30	0.92	8.90
16	18	150	600	110	5.77	17.00	0.96	9.62
19	20	200	300	110	1.24	22.97	0.73	4.14
20	21	300	750	110	0.84	32.88	0.47	1.12
21	22	300	180	110	0.85	71.50	1.01	4.70
22	23	150	530	110	0.40	4.30	0.24	0.75
22	28	150	450	110	0.26	3.70	0.21	0.57
22	26	200	590	110	11.01	51.80	1.65	18.66
26	25	150	330	110	2.10	13.60	0.77	6.37
26	27	150	150	110	2.49	22.80	1.29	16.57

Distribution Network Analysis for Zone 03

Node Data

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
z03a	-281.02	219.96	183	36.96
z03b	-43.30	218.10	186	32.10
z03c	-148.77	217.94	186	31.94
z03d	-157.51	217.81	186	31.81
1	0.00	219.90	183	36.90
2	13.60	217.95	183	34.95
3	10.50	213.16	183	30.16
4	8.20	212.09	183	29.09
5	0.00	212.39	183	29.39
6	8.40	216.96	183	33.96
7	1.90	213.13	183	30.13
8	29.00	210.80	183	27.80
9	7.10	197.91	183	14.91
10	0.00	193.52	186	7.52
11	8.20	191.65	186	5.65
12	14.40	167.44	186	-18.56
13	9.70	166.32	186	-19.68
14	17.80	163.98	186	-22.02
15	4.80	165.02	186	-20.98
16	17.70	161.59	186	-24.41
17	17.60	184.88	186	-1.12
18	13.20	182.77	186	-3.23
19	14.20	182.19	186	-3.81
20	9.60	180.38	186	-5.62
21	12.30	193.86	186	7.86
22	9.20	192.50	186	6.50
23	4.30	190.60	186	4.60
24	8.70	175.08	186	-10.92
25	1.60	170.36	186	-15.64
26	0.80	169.79	186	-16.21
27	3.70	169.29	186	-16.71
28	5.30	169.37	186	-16.63
29	3.90	169.15	186	-16.85
30	4.40	169.10	186	-16.90
31	3.10	168.47	186	-17.53
32	11.70	168.35	186	-17.65
33	3.50	170.28	186	-15.72
34	7.20	169.95	186	-16.05
35	2.40	168.41	186	-17.59
36	2.40	168.37	186	-17.63
371	5.60	218.10	186	32.10

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
37	10.30	217.26	186	31.26
38	5.70	216.82	186	30.82
39	2.00	215.00	186	29.00
40	2.10	214.96	186	28.96
41	2.00	213.97	186	27.97
42	2.10	213.93	186	27.93
43	12.10	213.03	186	27.03
44	1.40	213.01	186	27.01
451	8.80	217.92	186	31.92
45	11.50	202.26	186	16.26
46	9.70	200.47	186	14.47
471	15.50	217.79	186	31.79
47	30.60	200.19	186	14.19
48	4.90	176.65	186	-9.35
49	5.00	176.32	186	-9.68
50	11.60	169.33	186	-16.67
51	5.00	166.13	186	-19.87
52	3.80	165.94	186	-20.06
53	1.90	166.10	186	-19.90
54	9.60	165.63	186	-20.37
55	2.40	165.16	186	-20.84
56	1.40	165.14	186	-20.86
57	3.70	163.63	186	-22.37
58	7.50	163.44	186	-22.56
59	16.40	161.91	186	-24.09
60	6.00	160.59	186	-25.41
61	11.00	160.21	186	-25.79
62	9.00	150.74	186	-35.26
63	2.10	148.80	186	-37.20
64	1.70	147.65	186	-38.35
65	9.10	145.46	186	-40.54
66	10.00	145.42	186	-40.58
67	19.90	146.13	186	-39.87
68	13.80	150.46	186	-35.54
69	13.80	161.99	186	-24.01
70	6.60	148.21	186	-37.79
71	6.70	157.76	186	-28.24
72	4.80	154.76	186	-31.24
73	9.10	152.89	186	-33.11
74	11.70	152.90	186	-33.10
75	12.30	157.63	186	-28.37

Pipeline Data -DZ-3.1

Node Number		Dia	Length	Friction L.	Head Loss	Flow	Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	l/s	m/s	‰
z03a	1	300	1	110	0.06	281.02	3.98	59.35
1	2	250	60	110	1.95	125.79	2.56	32.55
2	3	250	210	110	4.79	103.79	2.12	22.80
3	4	150	350	110	1.07	9.17	0.52	3.07
4	5	250	150	110	-0.30	-28.03	-0.57	-2.02
5	1	300	380	110	-7.51	-155.23	-2.20	-19.77
2	6	150	380	110	0.99	8.40	0.48	2.61
3	7	150	200	110	0.03	1.90	0.11	0.17
9	3	250	1030	110	-15.25	-82.22	-1.68	-14.81
4	8	250	600	110	1.29	29.00	0.59	2.15
5	10	300	1380	110	18.87	127.20	1.80	13.67
10	11	150	750	110	1.87	8.20	0.46	2.49
10	12	150	230	110	26.08	64.40	3.65	113.37
12	13	150	330	110	1.12	9.70	0.55	3.40
12	14	150	330	110	3.46	17.80	1.01	10.48
12	15	150	150	110	2.43	22.50	1.27	16.17
15	16	150	330	110	3.42	17.70	1.00	10.37
10	17	200	420	110	8.64	54.60	1.74	20.57
17	18	150	350	110	2.11	13.20	0.75	6.02
17	19	150	150	110	2.69	23.80	1.35	17.94
19	20	150	540	110	1.80	9.60	0.54	3.34
9	21	250	260	110	4.05	84.50	1.72	15.58
21	22	150	440	110	1.36	9.20	0.52	3.09
21	23	250	360	110	3.26	63.00	1.28	9.04
23	24	200	660	110	15.52	58.70	1.87	23.52
24	25	150	270	110	4.72	23.46	1.33	17.47
25	26	150	130	110	0.57	11.16	0.63	4.41
26	27	150	130	110	0.50	10.36	0.59	3.84
27	28	150	130	110	-0.08	-3.80	-0.22	-0.60
28	24	150	260	110	-5.71	-26.54	-1.50	-21.96
28	29	250	260	110	0.22	17.44	0.36	0.84
29	30	250	660	110	0.04	4.40	0.09	0.07
27	31	150	210	110	0.82	10.46	0.59	3.91
31	32	150	390	110	0.11	2.56	0.14	0.29
32	29	150	260	110	-0.79	-9.14	-0.52	-3.05
25	33	150	150	110	0.08	3.50	0.20	0.52
25	34	150	210	110	0.41	7.20	0.41	1.96
31	36	150	390	110	0.10	2.40	0.14	0.26
31	35	150	200	110	0.05	2.40	0.14	0.26
z03b	371	300	1	110	0.00	43.30	0.61	1.86
371	37	300	580	110	0.83	37.70	0.53	1.44
37	38	150	350	110	0.45	5.70	0.32	1.27
37	39	150	150	110	2.27	21.70	1.23	15.12
39	40	150	200	110	0.04	2.10	0.12	0.20
39	41	150	100	110	1.03	17.60	1.00	10.26

Pipeline Data -DZ-3.2

Node Number		Dia	Length	Friction L.	Head Loss	Flow	Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	l/s	m/s	%o
41	42	150	200	110	0.04	2.10	0.12	0.20
41	43	150	150	110	0.94	13.50	0.76	6.28
43	44	150	200	110	0.02	1.40	0.08	0.09
z03c	451	300	1	110	0.02	148.77	2.11	18.28
451	45	300	960	110	15.67	139.97	1.98	16.32
45	46	150	150	110	1.79	19.08	1.08	11.91
46	9	150	800	110	2.56	9.38	0.53	3.20
z03d	471	300	1	110	0.02	157.51	2.23	20.32
471	47	300	1050	110	17.60	142.01	2.01	16.76
47	45	300	200	110	-2.07	-109.39	-1.55	-10.34
47	48	300	620	110	23.54	220.80	3.13	37.96
48	49	150	330	110	0.33	5.00	0.28	1.00
48	50	300	210	110	7.32	210.90	2.99	34.87
50	51	150	170	110	3.20	24.43	1.38	18.83
51	52	150	320	110	0.19	3.80	0.22	0.60
51	53	150	170	110	0.03	1.90	0.11	0.17
50	54	300	150	110	3.70	174.87	2.48	24.65
54	55	150	170	110	0.48	8.72	0.49	2.79
55	51	150	150	110	-0.97	-13.73	-0.78	-6.48
55	58	150	150	110	1.71	18.65	1.06	11.42
55	56	150	170	110	0.02	1.40	0.08	0.09
54	57	200	150	110	2.00	43.22	1.38	13.35
57	58	150	170	110	0.19	5.25	0.30	1.09
58	59	150	170	110	1.53	16.40	0.93	9.00
57	60	200	350	110	3.04	34.27	1.09	8.68
60	61	150	330	110	0.38	5.42	0.31	1.16
61	62	150	270	110	9.47	34.18	1.94	35.09
62	63	150	130	110	1.94	21.53	1.22	14.91
63	64	150	200	110	1.14	12.83	0.73	5.72
64	65	150	500	110	2.20	11.13	0.63	4.40
65	66	150	180	110	0.03	2.03	0.12	0.19
66	67	150	300	110	-0.71	-7.97	-0.45	-2.36
67	68	150	180	110	-4.33	-27.87	-1.58	-24.03
68	62	150	500	110	-0.28	-3.65	-0.21	-0.56
68	69	150	270	110	-11.53	-38.02	-2.15	-42.71
69	61	300	500	110	1.78	61.52	0.87	3.56
69	54	300	330	110	-3.64	-113.33	-1.60	-11.04
63	70	150	350	110	0.58	6.60	0.37	1.67
60	71	150	170	110	2.83	22.85	1.29	16.64
71	72	150	510	110	3.00	13.04	0.74	5.89
72	73	150	740	110	1.86	8.24	0.47	2.52
73	74	150	240	110	-0.01	-0.86	-0.05	-0.04
74	75	150	860	110	-4.72	-12.56	-0.71	-5.49
75	71	150	330	110	-0.14	-3.11	-0.18	-0.41
75	61	150	170	110	-2.58	-21.75	-1.23	-15.19

Distribution Network Analysis for Zone 04

Node Data

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
z04a	-57.28	218.73	183	35.73
z04b	-11.80	217.64	186	31.64
z04c	-19.30	217.64	186	31.64
z04d	-70.16	217.89	186	31.89
z04e	-37.56	218.42	186	32.42
z04f	-50.20	217.42	186	31.42
z04g	0.00	219.09	186	33.09
z04h	-90.84	217.41	190	27.41
z04i	-129.26	217.50	187	30.50
z04j	-31.50	222.81	185	37.81
1	10.00	218.36	186	32.36
2	6.70	217.22	186	31.22
3	5.80	218.24	186	32.24
4	5.80	218.14	186	32.14
5	5.80	216.58	186	30.58
6	5.80	215.07	186	29.07
7	14.10	214.94	186	28.94
8	12.60	214.86	186	28.86
9	8.30	215.37	186	29.37
10	18.20	215.54	186	29.54
11	19.60	216.66	186	30.66
12	17.80	217.17	186	31.17
13	3.90	216.44	188	28.44
14	6.60	217.18	186	31.18
15	6.40	217.23	186	31.23
151	6.30	217.64	186	31.64
111	25.50	217.88	186	31.88
16	5.10	217.86	186	31.86
461	5.90	217.64	186	31.64
46	5.90	217.61	186	31.61
171	8.90	217.41	186	31.41

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
17	5.90	216.01	186	30.01
18	8.80	215.04	186	29.04
19	16.40	215.35	186	29.35
20	5.10	215.00	186	29.00
21	5.10	215.00	186	29.00
22	5.40	214.29	186	28.29
23	11.60	211.73	186	25.73
24	12.50	214.55	186	28.55
25	16.70	209.32	186	23.32
26	5.40	217.47	186	31.47
27	29.20	215.96	186	29.96
28	35.10	208.87	186	22.87
29	14.50	213.91	186	27.91
30	0.00	212.13	190	22.13
31	8.70	209.77	190	19.77
32	7.00	205.58	190	15.58
33	9.50	204.66	190	14.66
34	6.50	211.26	190	21.26
35	5.20	210.00	190	20.00
36	3.60	209.44	190	19.44
37	6.40	209.21	190	19.21
38	2.90	209.34	190	19.34
39	8.10	208.34	190	18.34
40	8.00	209.02	190	19.02
41	4.00	209.03	190	19.03
42	2.70	209.32	190	19.32
43	12.20	206.99	190	16.99
44	4.90	208.77	190	18.77
451	6.30	222.59	185	37.59
45	25.20	142.11	185	-42.89

Pipeline Data -DZ-4

Node Number		Dia	Length	Friction L.	Head Loss	Flow	Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	l/s	m/s	%o
z04a	1	300	120	110	0.37	57.28	0.81	3.12
1	2	150	660	110	1.13	6.70	0.38	1.72
1	3	200	10	110	0.12	40.58	1.29	11.88
3	4	200	300	110	0.10	5.80	0.18	0.32
3	5	200	260	110	1.66	28.98	0.92	6.37
5	6	200	360	110	1.52	23.18	0.74	4.21
6	7	300	370	110	0.13	17.38	0.25	0.34
7	8	200	700	110	0.08	3.28	0.10	0.11
8	9	150	160	110	-0.51	-9.32	-0.53	-3.16
9	10	150	540	110	-0.18	-2.73	-0.15	-0.33
10	11	200	320	110	-1.12	-20.93	-0.67	-3.49
11	12	150	540	110	-0.51	-4.87	-0.28	-0.95
12	9	150	240	110	1.81	14.88	0.84	7.52
12	z04c	250	360	110	-1.25	-37.56	-0.77	-3.47
11	111	250	320	110	-1.22	-39.56	-0.81	-3.82
111	z04d	250	1	110	-0.01	-70.16	-1.43	-11.04
11	13	150	340	110	0.21	3.90	0.22	0.63
z04b	461	300	1	110	0.00	11.80	0.17	0.17
461	46	300	640	110	0.03	5.90	0.08	0.05
z04c	151	200	1	110	0.00	19.30	0.61	3.00
151	14	200	1100	110	0.45	6.60	0.21	0.41
151	15	150	260	110	0.41	6.40	0.36	1.58
111	16	250	200	110	0.02	5.10	0.10	0.09
z04f	171	250	1	110	0.01	50.20	1.02	5.94
171	17	250	340	110	1.41	41.30	0.84	4.14
17	18	150	340	110	0.97	8.80	0.50	2.84
17	19	250	360	110	0.66	26.60	0.54	1.83
19	20	150	340	110	0.35	5.10	0.29	1.04
19	21	150	340	110	0.35	5.10	0.29	1.04
22	24	250	320	110	-0.26	-17.00	-0.35	-0.80
22	23	150	540	110	2.56	11.60	0.66	4.74
24	26	250	600	110	-2.92	-45.06	-0.92	-4.86
26	27	250	340	110	1.50	42.83	0.87	4.43
27	28	150	1110	110	7.09	13.63	0.77	6.39
28	29	150	340	110	-5.04	-21.47	-1.22	-14.83
29	26	250	1110	110	-3.56	-35.97	-0.73	-3.20
26	180	250	1	110	-0.03	-129.26	-2.63	-34.24
z04h	30	200	100	110	5.28	90.84	2.89	52.81
30	31	200	480	110	2.36	25.20	0.80	4.91
31	32	150	460	110	4.19	16.50	0.93	9.11
32	33	150	280	110	0.92	9.50	0.54	3.28
30	34	200	30	110	0.87	65.64	2.09	28.93
34	38	200	420	110	1.92	24.23	0.77	4.57
38	42	200	150	110	0.02	3.84	0.12	0.15
42	25	200	150	110	0.00	1.14	0.04	0.02
25	24	150	640	110	-5.23	-15.56	-0.88	-8.17
34	35	150	170	110	1.26	14.75	0.84	7.40
35	36	150	170	110	0.56	9.55	0.54	3.31
36	37	150	170	110	0.23	5.95	0.34	1.38
37	38	150	170	110	-0.14	-4.45	-0.25	-0.80
38	39	150	170	110	1.00	13.04	0.74	5.89
39	40	150	340	110	-0.68	-7.26	-0.41	-1.99
40	34	150	170	110	-2.24	-20.16	-1.14	-13.19
40	44	150	260	110	0.25	4.90	0.28	0.96
39	43	150	260	110	1.35	12.20	0.69	5.21
37	41	150	260	110	0.17	4.00	0.23	0.66
z04j	451	100	1	110	0.22	31.50	4.01	217.34
451	45	100	560	110	80.49	25.20	3.21	143.72

Distribution Network Analysis for Zone 05

Node Data

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
z05a	-159.11	217.64	186	31.64
z05b	-125.17	217.64	186	31.64
z05c	-48.52	217.10	188	29.10
101	5.90	203.98	186	17.98
1	32.00	203.96	188	15.96
2	26.50	193.08	188	5.08
3	6.80	192.50	188	4.50
4	5.30	192.76	188	4.76
5	5.50	190.93	188	2.93
6	1.30	190.91	188	2.91
7	0.70	189.20	188	1.20
8	4.10	188.22	188	0.22
9	9.00	183.65	188	-4.35
10	13.60	181.02	186	-4.98
11	3.80	180.93	186	-5.07
12	7.20	180.96	186	-5.04
13	8.50	175.55	186	-10.45
14	7.70	174.52	186	-11.48
15	8.10	174.52	186	-11.48
16	4.80	174.43	186	-11.57
17	0.00	213.66	186	27.66
18	6.80	206.63	186	20.63
19	0.00	205.51	186	19.51
20	3.40	200.60	186	14.60
21	1.60	199.31	186	13.31
22	3.10	198.78	186	12.78
23	3.40	198.61	186	12.61
24	5.80	199.01	186	13.01
25	5.80	201.75	186	15.75

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
26	5.50	198.65	186	12.65
27	1.00	198.77	186	12.77
28	2.40	198.23	186	12.23
29	3.20	198.15	186	12.15
30	1.40	198.19	186	12.19
31	6.40	194.73	186	8.73
32	6.40	194.20	186	8.20
33	0.00	191.83	186	5.83
34	5.30	190.08	188	2.08
35	7.80	189.45	188	1.45
36	0.00	205.39	188	17.39
37	17.60	193.10	188	5.10
38	13.80	190.28	188	2.28
39	0.00	205.38	188	17.38
40	2.60	205.37	188	17.37
41	2.50	205.26	188	17.26
42	3.50	204.95	188	16.95
43	4.10	205.96	188	17.96
44	18.30	206.46	188	18.46
45	15.70	211.21	188	23.21
46	4.90	216.64	188	28.64
47	4.00	186.22	188	-1.78
48	2.60	186.15	188	-1.85
49	12.20	185.44	188	-2.56
50	3.30	187.46	188	-0.54
51	3.80	187.46	188	-0.54
52	3.80	187.19	188	-0.81
81	0.00	187.73	188	-0.27

Pipeline Data -DZ-5

Node Number		Dia	Length	Friction L.	Head Loss	Flow	Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	l/s	m/s	%o
z05a	101	300	660	110	13.66	159.11	2.25	20.70
101	1	300	1	110	0.02	153.21	2.17	19.30
1	2	300	870	110	10.88	121.21	1.72	12.50
2	3	150	330	110	0.58	6.80	0.38	1.76
2	4	150	290	110	0.32	5.30	0.30	1.11
2	5	300	350	110	2.15	82.61	1.17	6.15
5	6	150	210	110	0.02	1.30	0.07	0.08
5	7	300	330	110	1.73	75.81	1.07	5.24
7	8	300	120	110	0.98	96.50	1.37	8.20
8	9	250	510	110	4.57	62.70	1.28	8.96
9	10	250	390	110	2.62	53.70	1.09	6.73
10	11	150	150	110	0.09	3.80	0.22	0.60
10	12	250	390	110	0.06	7.20	0.15	0.16
10	13	150	210	110	5.47	29.10	1.65	26.04
13	14	150	390	110	1.03	8.46	0.48	2.64
14	15	250	660	110	0.00	0.76	0.02	0.00
15	13	150	200	110	-1.03	-12.14	-0.69	-5.16
15	16	200	390	110	0.09	4.80	0.15	0.23
z05b	17	300	300	110	3.98	125.17	1.77	13.27
17	18	300	530	110	7.03	125.17	1.77	13.27
18	19	300	170	110	1.11	85.55	1.21	6.56
19	20	200	270	110	4.91	51.07	1.63	18.18
20	21	200	60	110	1.30	56.06	1.79	21.60
21	22	150	270	110	0.53	7.17	0.41	1.95
22	23	150	430	110	0.17	3.07	0.17	0.41
23	24	150	200	110	-0.40	-7.33	-0.41	-2.02
24	25	150	240	110	-2.74	-18.63	-1.05	-11.40
25	18	150	150	110	-4.88	-32.81	-1.86	-32.53
25	20	150	440	110	1.14	8.39	0.47	2.60
24	26	150	300	110	0.36	5.50	0.31	1.19
22	27	150	130	110	0.01	1.00	0.06	0.05
23	28	150	200	110	0.37	7.00	0.40	1.86
28	29	150	200	110	0.09	3.20	0.18	0.44
28	30	150	500	110	0.05	1.40	0.08	0.09
21	31	200	290	110	4.57	47.29	1.51	15.76
31	32	150	340	110	0.54	6.40	0.36	1.58
31	33	200	330	110	2.90	34.49	1.10	8.79
33	34	200	200	110	1.76	34.49	1.10	8.79
34	35	250	290	110	0.63	29.19	0.59	2.18
35	7	250	200	110	0.24	21.39	0.44	1.22
19	36	300	100	110	0.12	34.48	0.49	1.22
36	37	150	410	110	12.29	31.40	1.78	29.98
37	38	150	430	110	2.81	13.80	0.78	6.54
36	39	300	600	110	0.01	3.08	0.04	0.01
39	40	150	30	110	0.01	3.08	0.17	0.41
40	41	150	80	110	0.11	6.00	0.34	1.40
41	42	150	590	110	0.30	3.50	0.20	0.52
40	43	150	490	110	-0.59	-5.52	-0.31	-1.20
43	44	150	150	110	-0.50	-9.62	-0.54	-3.35
44	45	200	800	110	-4.75	-27.92	-0.89	-5.94
45	46	200	400	110	-5.43	-43.62	-1.39	-13.57
46	z05c	300	200	110	-0.46	-48.52	-0.69	-2.30
8	81	300	530	110	0.49	29.70	0.42	0.92
81	47	150	130	110	1.51	18.80	1.06	11.60
47	48	150	230	110	0.07	2.60	0.15	0.30
47	49	150	150	110	0.78	12.20	0.69	5.21
81	50	250	760	110	0.27	10.90	0.22	0.35
50	51	250	30	110	0.01	7.60	0.15	0.18
51	52	150	450	110	0.27	3.80	0.22	0.60

Distribution Network Analysis for Zone 06

Node Data

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
z06a	-37.40	214.44	188	26.44
z06b	-86.20	213.80	187	26.80
z06c	-84.38	213.68	187	26.68
z06d	-178.82	213.65	186	27.65
1	10.80	213.75	187	26.75
2	15.40	210.45	188	22.95
3	10.00	209.03	188	21.03
4	17.70	208.32	188	20.32
5	26.40	208.31	188	20.31
6	5.90	213.00	188	25.00
7	2.70	213.21	188	25.21
8	7.00	210.28	188	22.28
9	5.00	210.15	188	22.15
10	3.60	210.25	188	22.25
11	6.90	209.84	188	21.84
12	0.90	209.84	188	21.84
13	1.00	209.84	188	21.84
14	4.20	209.65	188	21.65
15	6.10	209.22	188	21.22
16	0.00	209.65	188	21.65
121	2.10	213.67	187	26.67
17	4.40	207.45	186	21.45
18	8.60	211.85	186	25.85
19	6.10	207.63	186	21.63
20	4.60	207.30	186	21.30
21	9.10	206.43	186	20.43
22	6.10	205.96	186	19.96
23	10.30	201.98	186	15.98
24	2.20	196.71	186	10.71
25	6.80	196.56	186	10.56
26	0.00	194.99	186	8.99
27	5.20	193.11	186	7.11
28	0.90	193.08	186	7.08
29	2.60	193.01	186	7.01
30	4.60	193.18	186	7.18
31	4.60	196.18	186	10.18

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
32	8.80	196.21	186	10.21
33	15.70	191.47	186	5.47
34	10.20	188.78	186	2.78
35	1.70	194.95	186	8.95
36	9.30	187.63	186	1.63
37	6.60	187.55	186	1.55
38	4.10	187.70	186	1.70
39	8.30	188.04	186	2.04
40	4.20	187.43	186	1.43
41	0.00	187.44	186	1.44
42	10.90	187.47	186	1.47
43	6.60	188.44	186	2.44
44	4.80	187.70	186	1.70
45	2.10	187.06	186	1.06
46	3.30	186.91	186	0.91
47	1.80	188.42	186	2.42
48	4.30	189.30	186	3.30
49	1.80	188.37	186	2.37
50	1.10	186.89	186	0.89
51	6.50	187.14	186	1.14
52	8.80	186.02	186	0.02
53	4.00	186.08	186	0.08
54	7.90	186.00	186	-0.00
55	3.30	186.74	186	0.74
56	6.30	185.91	186	-0.09
57	3.30	186.06	186	0.06
58	5.70	185.25	186	-0.75
59	6.10	184.88	186	-1.12
60	4.90	184.84	186	-1.16
61	6.80	185.15	186	-0.85
62	2.50	185.04	186	-0.96
63	4.60	184.77	186	-1.23
64	4.10	184.75	186	-1.25
65	4.60	186.11	186	0.11
66	0.00	193.35	186	7.35
131	0.00	213.62	186	27.62

Pipeline Data -DZ6.1

Node Number		Dia	Length	Friction L.	Head Loss	Flow	Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	l/s	m/s	%
z06b	1	200	1	110	0.05	86.20	2.75	47.93
1	2	200	240	110	3.30	43.93	1.40	13.75
2	3	200	770	110	1.42	14.86	0.47	1.85
3	4	150	750	110	0.71	4.86	0.28	0.95
4	2	200	1350	110	-2.14	-13.66	-0.44	-1.58
4	5	150	300	110	0.01	0.83	0.05	0.04
5	6	200	930	110	-4.70	-25.57	-0.81	-5.05
6	1	250	300	110	-0.75	-31.47	-0.64	-2.50
z06a	7	200	120	110	1.23	37.40	1.19	10.21
7	8	200	330	110	2.93	34.70	1.11	8.89
8	9	200	530	110	0.13	5.00	0.16	0.25
8	10	200	210	110	0.03	3.60	0.11	0.13
8	11	200	150	110	0.44	19.10	0.61	2.94
11	12	200	330	110	0.00	0.90	0.03	0.01
11	13	200	330	110	0.00	1.00	0.03	0.01
11	14	200	200	110	0.19	10.30	0.33	0.94
14	15	150	300	110	0.43	6.10	0.35	1.44
14	16	150	210	110	0.00	0.00	0.00	0.00
z06c	121	300	1	110	0.01	84.38	1.19	6.39
121	17	300	1020	110	6.22	82.28	1.16	6.10
z06d	131	300	1	110	0.03	178.82	2.53	25.70
131	18	300	200	110	1.78	100.80	1.43	8.89
18	19	300	560	110	4.22	92.20	1.31	7.53
19	20	150	380	110	0.32	4.60	0.26	0.86
19	21	300	200	110	1.20	81.50	1.15	6.00
21	22	300	200	110	0.47	49.05	0.69	2.34
22	17	300	270	110	-1.49	-77.88	-1.10	-5.51
22	23	300	320	110	3.98	120.84	1.71	12.43
23	24	300	500	110	5.27	110.54	1.56	10.54
131	25	250	1270	110	17.06	78.02	1.59	13.44
25	26	250	110	110	1.57	80.50	1.64	14.24
26	27	150	390	110	1.88	11.71	0.66	4.82
27	28	200	90	110	0.04	6.51	0.21	0.40
28	29	200	210	110	0.06	5.61	0.18	0.30
29	30	200	100	110	-0.17	-14.10	-0.45	-1.68
30	31	200	270	110	-3.00	-39.12	-1.25	-11.10
30	39	150	380	110	5.14	20.42	1.16	13.52
31	24	200	50	110	-0.54	-38.46	-1.22	-10.75
31	32	250	330	110	-0.03	-5.26	-0.11	-0.09
32	25	250	630	110	-0.35	-14.06	-0.29	-0.56
25	21	150	570	110	-9.87	-23.35	-1.32	-17.32
24	33	150	250	110	5.25	25.90	1.47	20.99

Pipeline Data -DZ6.2

Node Number		Dia	Length	Friction L.	Head Loss	Flow	Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	l/s	m/s	%o
33	34	150	720	110	2.69	10.20	0.58	3.74
24	35	250	380	110	1.77	43.98	0.90	4.65
35	66	250	370	110	1.60	42.28	0.86	4.32
66	36	150	110	110	5.72	42.28	2.39	52.00
36	37	250	170	110	0.08	12.67	0.26	0.46
37	38	150	480	110	-0.15	-2.64	-0.15	-0.31
38	39	150	200	110	-0.35	-6.74	-0.38	-1.73
39	40	150	530	110	0.61	5.39	0.30	1.15
40	41	250	170	110	-0.00	-1.82	-0.04	-0.01
41	37	150	40	110	-0.11	-8.71	-0.49	-2.79
40	42	250	180	110	-0.04	-8.41	-0.17	-0.22
42	43	150	530	110	-0.96	-6.91	-0.39	-1.82
43	29	150	470	110	-4.58	-17.11	-0.97	-9.74
43	47	200	130	110	0.02	3.60	0.11	0.13
42	44	250	500	110	-0.22	-12.40	-0.25	-0.45
44	45	150	390	110	0.63	6.50	0.37	1.62
45	46	150	200	110	0.16	4.40	0.25	0.79
47	49	150	320	110	0.05	1.80	0.10	0.15
46	50	150	320	110	0.02	1.10	0.06	0.06
44	48	150	90	110	-1.60	-23.70	-1.34	-17.81
48	26	300	1300	110	-5.69	-68.79	-0.97	-4.38
36	51	150	90	110	0.48	12.40	0.70	5.37
36	54	150	700	110	1.63	7.90	0.45	2.33
51	52	150	830	110	1.13	5.90	0.33	1.36
41	53	150	750	110	1.36	6.90	0.39	1.81
53	52	150	170	110	0.06	2.90	0.16	0.36
40	55	150	150	110	0.69	11.41	0.65	4.60
55	65	150	260	110	0.64	8.11	0.46	2.45
65	56	150	390	110	0.20	3.51	0.20	0.52
56	57	200	80	110	-0.16	-15.33	-0.49	-1.96
57	48	200	270	110	-3.24	-40.79	-1.30	-11.99
57	58	200	210	110	0.81	22.15	0.71	3.87
58	59	200	330	110	0.38	11.44	0.36	1.14
59	60	150	180	110	0.03	2.06	0.12	0.19
60	61	150	240	110	-0.31	-5.75	-0.33	-1.29
61	56	200	560	110	-0.76	-12.55	-0.40	-1.35
58	62	150	210	110	0.21	5.02	0.28	1.00
62	63	150	980	110	0.27	2.52	0.14	0.28
63	64	150	180	110	0.01	1.20	0.07	0.07
64	60	150	240	110	-0.09	-2.90	-0.16	-0.37
63	59	150	240	110	-0.11	-3.28	-0.19	-0.46

Distribution Network Analysis for Zone 07

Node Data

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
z07a	-164.76	222.25	185	37.25
z07b	-62.07	223.08	185	38.08
z07c	-28.73	219.30	186	33.30
z07d	-31.50	214.73	187	27.73
z07e	-23.84	214.54	187	27.54
1	0.00	222.24	185	37.24
2	11.40	221.16	185	36.16
3	15.00	213.86	185	28.86
4	10.80	213.12	185	28.12
5	4.30	220.07	185	35.07
6	4.40	218.20	185	33.20
7	11.90	217.51	185	32.51
8	4.20	219.34	185	34.34
9	11.40	213.68	186	27.68
10	12.30	210.53	186	24.53
11	7.50	210.22	186	24.22
12	1.60	210.29	186	24.29
13	0.00	210.56	186	24.56
14	5.60	210.92	186	24.92
15	3.60	211.35	186	25.35
16	11.60	211.76	186	25.76
17	9.90	210.56	186	24.56
18	1.80	218.50	186	32.50
19	5.90	205.84	186	19.84
20	4.80	205.48	186	19.48
21	20.80	201.64	186	15.64

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
22	6.00	211.02	186	25.02
23	3.20	211.30	186	25.30
24	12.90	211.33	186	25.33
25	2.50	213.27	187	26.27
26	4.50	213.48	187	26.48
27	0.00	213.57	187	26.57
28	19.10	214.43	187	27.43
29	4.20	210.04	185	25.04
30	5.80	209.98	185	24.98
31	5.20	222.97	185	37.97
32	6.00	221.68	185	36.68
33	1.30	221.66	185	36.66
34	1.50	218.60	185	33.60
35	26.70	216.59	185	31.59
36	8.70	216.52	185	31.52
37	3.00	216.53	185	31.53
38	7.70	218.60	185	33.60
39	3.60	218.47	185	33.47
40	5.20	218.60	185	33.60
41	1.40	218.53	185	33.53
42	4.30	218.44	185	33.44
43	2.20	218.44	185	33.44
44	11.90	217.15	185	32.15
45	2.10	218.78	185	33.78
46	3.10	210.63	186	24.63

Pipeline Data -DZ07

Node Number		Dia	Length	Friction L	Head Loss	Flow	Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	l/s	m/s	%o
z07a	1	400	1	110	0.01	164.76	1.31	5.44
1	2	400	200	110	1.09	164.76	1.31	5.44
2	3	150	350	110	7.29	25.80	1.46	20.84
3	4	150	180	110	0.75	10.80	0.61	4.15
2	5	400	320	110	1.08	127.56	1.02	3.39
5	6	150	210	110	1.87	16.30	0.92	8.90
6	7	150	140	110	0.70	11.90	0.67	4.97
5	8	400	300	110	0.73	106.96	0.85	2.44
8	9	150	220	110	5.66	28.90	1.64	25.72
9	10	150	310	110	3.15	17.50	0.99	10.16
10	11	150	290	110	0.31	5.20	0.29	1.07
11	12	150	300	110	-0.07	-2.30	-0.13	-0.24
12	29	200	290	110	0.26	10.00	0.32	0.89
29	30	200	170	110	0.06	5.80	0.18	0.32
8	18	400	680	110	0.84	73.86	0.59	1.23
18	16	150	140	110	6.74	40.56	2.30	48.17
17	16	150	340	110	-1.20	-9.90	-0.56	-3.54
16	15	150	70	110	0.41	13.06	0.74	5.91
15	14	150	170	110	0.43	8.23	0.47	2.51
14	46	150	180	110	0.29	6.43	0.36	1.59
46	13	150	160	110	0.08	3.33	0.19	0.47
13	12	150	40	110	0.27	13.90	0.79	6.63
18	19	150	420	110	12.67	31.50	1.78	30.16
19	20	150	390	110	0.36	4.80	0.27	0.93
19	21	150	300	110	4.20	20.80	1.18	13.98
22	16	150	530	110	-0.74	-6.00	-0.34	-1.40
23	15	150	680	110	-0.05	-1.23	-0.07	-0.07
23	24	150	170	110	-0.03	-1.97	-0.11	-0.18
24	14	150	680	110	0.41	3.80	0.21	0.60
24	25	150	170	110	-1.95	-18.67	-1.06	-11.45
25	13	150	680	110	2.71	10.57	0.60	3.99
25	26	300	200	110	-0.21	-31.74	-0.45	-1.05
26	27	300	140	110	-0.09	-23.84	-0.34	-0.62
27	z07e	250	650	110	-0.97	-23.84	-0.49	-1.50
26	28	200	720	110	-0.95	-12.40	-0.39	-1.32
28	z07d	200	40	110	-0.30	-31.50	-1.00	-7.43
z07b	31	300	30	110	0.11	62.07	0.88	3.62
31	32	300	420	110	1.29	56.87	0.80	3.08
32	33	150	230	110	0.02	1.30	0.07	0.08
32	34	150	70	110	3.08	38.61	2.19	43.96
34	35	150	80	110	2.01	28.54	1.62	25.13
35	36	150	440	110	0.07	1.84	0.10	0.16
36	37	300	160	110	-0.01	-6.86	-0.10	-0.06
37	34	150	590	110	-2.07	-9.86	-0.56	-3.51
34	38	300	160	110	-0.00	-1.29	-0.02	-0.00
38	32	150	720	110	-3.08	-10.97	-0.62	-4.27
38	39	150	240	110	0.13	3.60	0.20	0.54
38	40	300	390	110	-0.00	-1.63	-0.02	-0.00
40	41	300	420	110	0.07	12.06	0.17	0.17
41	42	250	260	110	0.09	10.66	0.22	0.34
42	43	300	240	110	0.00	2.20	0.03	0.01
42	44	150	260	110	1.29	11.90	0.67	4.97
42	45	150	150	110	-0.34	-7.74	-0.44	-2.24
45	z07c	300	600	110	-0.52	-28.73	-0.41	-0.87
45	40	300	440	110	0.18	18.88	0.27	0.40

Distribution Network Analysis for Zone 08

Node Data

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
z08a	-587.00	222.25	185	37.25
1	0.00	218.04	185	33.04
2	3.70	215.61	185	30.61
3	9.90	213.92	185	28.92
4	10.70	212.79	185	27.79
5	4.50	212.50	185	27.50
6	3.00	212.32	185	27.32
7	1.40	212.31	185	27.31
8	3.50	212.36	185	27.36
9	5.30	212.77	185	27.77
10	3.60	212.87	185	27.87
11	1.40	212.35	185	27.35
12	10.40	211.28	185	26.28
13	1.70	211.10	185	26.10
14	4.10	211.12	185	26.12
15	10.00	211.58	185	26.58
16	8.90	211.40	185	26.40
17	3.40	211.37	185	26.37
18	6.50	211.64	185	26.64
19	5.80	212.08	185	27.08
20	0.00	217.17	185	32.17
21	6.00	212.20	185	27.20
22	4.80	211.94	185	26.94
23	5.40	210.64	185	25.64
24	7.50	209.08	185	24.08
25	5.70	208.33	185	23.33

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
26	4.70	210.88	185	25.88
27	3.00	211.01	185	26.01
28	9.40	207.78	185	22.78
29	5.80	211.06	185	26.06
30	12.00	210.69	185	25.69
31	2.20	211.31	185	26.31
32	2.70	213.05	185	28.05
33	5.00	212.84	185	27.84
34	11.60	215.56	185	30.56
35	12.30	214.45	185	29.45
36	0.00	216.69	185	31.69
37	2.10	216.65	185	31.65
38	4.50	216.65	185	31.65
39	0.00	216.65	185	31.65
40	7.80	214.94	185	29.94
41	4.60	216.37	185	31.37
42	1.90	216.37	185	31.37
43	2.00	216.32	185	31.32
44	4.90	217.42	185	32.42
45	1.40	215.97	185	30.97
46	1.40	214.95	185	29.95
47	8.30	213.97	185	28.97
48	3.50	213.88	185	28.88
49	17.80	210.72	185	25.72
50	0.00	213.41	185	28.41
901	330.90	216.86	185	31.86

Pipeline Data -DZ08

Node Number		Dia	Length	Friction L.	Head Loss	Flow	Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	l/s	m/s	%o
z08a	1	600	530	110	4.21	587.00	2.08	7.94
1	2	250	210	110	2.43	72.02	1.47	11.58
2	3	300	390	110	1.69	68.32	0.97	4.32
3	4	300	350	110	1.13	58.42	0.83	3.24
4	5	300	170	110	0.29	41.72	0.59	1.73
5	6	300	160	110	0.17	32.42	0.46	1.09
6	7	300	90	110	0.01	10.82	0.15	0.14
7	8	200	60	110	-0.05	-9.35	-0.30	-0.78
8	9	200	210	110	-0.41	-15.37	-0.49	-1.97
9	10	300	210	110	-0.10	-20.67	-0.29	-0.47
10	11	300	190	110	0.52	53.17	0.75	2.72
11	8	250	180	110	-0.00	-2.52	-0.05	-0.02
7	12	200	360	110	1.03	18.78	0.60	2.85
12	13	150	330	110	0.19	3.68	0.21	0.56
13	14	150	390	110	-0.02	-1.02	-0.06	-0.05
14	15	200	260	110	-0.46	-14.52	-0.46	-1.77
11	15	300	470	110	0.77	40.57	0.57	1.65
15	16	300	590	110	0.17	16.05	0.23	0.30
16	17	150	380	110	0.03	1.35	0.08	0.09
17	18	150	360	110	-0.27	-4.25	-0.24	-0.74
18	19	200	440	110	-0.45	-10.75	-0.34	-1.01
19	11	250	500	110	-0.27	-13.72	-0.28	-0.54
19	30	150	330	110	1.39	10.88	0.62	4.21
30	49	150	360	110	-0.02	-1.12	-0.06	-0.06
49	50	150	230	110	-2.70	-18.92	-1.07	-11.73
50	10	300	100	110	0.55	77.44	1.10	5.45
50	20	300	460	110	-3.76	-96.36	-1.36	-8.17
20	1	600	150	110	-0.87	-495.48	-1.75	-5.80
4	21	150	420	110	0.59	6.00	0.34	1.40
5	22	150	600	110	0.56	4.80	0.27	0.93
6	23	200	600	110	1.68	18.60	0.59	2.80
23	24	150	260	110	1.57	13.20	0.75	6.02
24	25	150	590	110	0.75	5.70	0.32	1.27
12	26	150	450	110	0.40	4.70	0.27	0.89
13	27	150	230	110	0.09	3.00	0.17	0.39
14	28	150	1040	110	3.34	9.40	0.53	3.21
16	29	150	260	110	0.34	5.80	0.33	1.31
17	31	150	300	110	0.07	2.20	0.12	0.22
19	32	150	150	110	-0.97	-13.72	-0.78	-6.47
32	33	150	210	110	0.21	5.00	0.28	1.00
32	34	150	170	110	-2.51	-21.42	-1.21	-14.75
34	35	150	210	110	1.11	12.30	0.70	5.28
34	36	250	230	110	-1.13	-45.32	-0.92	-4.91
36	901	600	1160	110	-0.17	-68.22	-0.24	-0.15
36	37	500	890	110	0.04	22.90	0.12	0.05
37	38	500	120	110	0.00	13.00	0.07	0.02
38	39	500	150	110	0.00	3.90	0.02	0.00
37	40	150	750	110	1.70	7.80	0.44	2.27
38	41	150	320	110	0.27	4.60	0.26	0.85
39	42	150	440	110	0.28	3.90	0.22	0.63
42	43	150	250	110	0.05	2.00	0.11	0.18
1	44	150	50	110	0.62	19.50	1.10	12.40
44	45	150	200	110	1.45	14.60	0.83	7.26
45	46	150	170	110	1.02	13.20	0.75	6.02
46	47	150	200	110	0.98	11.80	0.67	4.89
47	48	150	170	110	0.09	3.50	0.20	0.52
20	901	600	80	110	0.31	399.12	1.41	3.88

Distribution Network Analysis for Zone 09

Node Data

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
109	-330.90	216.86	185	31.86
2	0.00	216.86	185	31.86
3	0.00	215.48	185	30.48
4	0.00	215.19	185	30.19
5	5.30	214.88	185	29.88
6	3.70	210.77	185	25.77
7	10.10	209.28	185	24.28
8	8.40	209.28	185	24.28
9	7.60	204.61	185	19.61
10	20.00	204.61	185	19.61
11	12.60	212.42	185	27.42
12	7.40	215.13	185	30.13
13	2.40	214.79	185	29.79
14	3.70	214.07	185	29.07
15	4.80	214.07	185	29.07
16	4.60	214.04	185	29.04
17	5.00	214.21	185	29.21
18	2.60	214.91	185	29.91
19	2.40	215.27	185	30.27
20	2.10	204.07	185	19.07
21	4.80	203.85	185	18.85
22	3.90	203.74	185	18.74
23	6.80	203.69	185	18.69
24	11.70	203.57	185	18.57
25	8.60	203.85	185	18.85
26	3.80	209.08	185	24.08
27	7.80	209.29	185	24.29
28	0.00	209.78	185	24.78
29	0.50	210.77	185	25.77
30	3.90	209.19	185	24.19
31	5.00	214.77	185	29.77

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
32	6.10	211.40	185	26.40
33	6.70	210.54	185	25.54
34	2.60	210.89	185	25.89
35	6.10	210.25	185	25.25
36	10.20	211.91	185	26.91
37	2.60	214.19	185	29.19
38	2.20	204.02	185	19.02
39	3.10	203.78	185	18.78
40	6.70	203.02	185	18.02
41	8.50	208.01	185	23.01
42	16.00	214.65	185	29.65
43	0.00	214.55	185	29.55
44	0.00	214.53	185	29.53
45	5.60	214.31	185	29.31
46	15.80	213.90	185	28.90
47	11.60	213.60	185	28.60
48	17.80	210.67	185	25.67
49	6.20	214.54	185	29.54
50	10.60	211.00	185	26.00
51	8.40	210.68	185	25.68
52	0.00	214.54	185	29.54
53	0.00	214.54	185	29.54
54	0.00	214.54	185	29.54
55	3.90	214.23	185	29.23
56	2.60	214.17	185	29.17
57	1.40	214.17	185	29.17
58	1.40	214.18	185	29.18
59	2.90	215.08	185	30.08
60	2.40	214.85	185	29.85
61	10.00	214.47	185	29.47

Pipeline Data -DZ09.1

Node Number		Dia	Length	Friction L.	Head Loss	Flow	Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	l/s	m/s	%o
109	2	600	1	110	0.00	330.90	1.17	2.75
2	3	600	780	110	1.38	260.58	0.92	1.76
3	4	600	240	110	0.29	213.18	0.75	1.22
4	59	600	120	110	0.11	185.98	0.66	0.94
59	5	600	380	110	0.20	135.23	0.48	0.52
5	6	150	360	110	4.10	18.63	1.05	11.40
6	7	150	210	110	1.49	14.43	0.82	7.10
7	8	150	170	110	0.00	0.43	0.02	0.01
8	9	150	100	110	4.67	39.88	2.26	46.65
8	59	200	360	110	-5.80	-47.84	-1.52	-16.10
9	10	230	240	110	0.00	0.16	0.00	0.00
10	11	150	610	110	-7.81	-19.84	-1.12	-12.80
11	2	250	400	110	-4.43	-70.32	-1.43	-11.08
4	12	250	30	110	0.06	27.20	0.55	1.91
12	13	250	210	110	0.34	25.02	0.51	1.64
13	14	200	150	110	0.72	24.86	0.79	4.79
14	15	150	450	110	-0.00	-0.34	-0.02	-0.01
15	16	150	80	110	0.04	3.37	0.19	0.48
16	17	200	150	110	-0.17	-11.43	-0.36	-1.14
17	18	200	240	110	-0.70	-19.03	-0.61	-2.92
18	60	250	120	110	0.06	13.14	0.27	0.50
60	13	150	260	110	0.06	2.24	0.13	0.22
60	15	150	290	110	0.77	8.51	0.48	2.67
18	19	250	120	110	-0.36	-34.78	-0.71	-3.01
19	3	250	40	110	-0.21	-47.40	-0.97	-5.34
19	12	225	260	110	0.14	10.23	0.26	0.52
9	20	250	210	110	0.55	32.11	0.65	2.60
20	21	250	110	110	0.22	27.81	0.57	1.99
21	22	250	100	110	0.11	19.91	0.41	1.07
22	23	250	200	110	0.05	9.31	0.19	0.26
23	24	150	440	110	0.12	2.51	0.14	0.28
24	25	150	90	110	-0.28	-9.19	-0.52	-3.08
25	26	150	500	110	-5.23	-17.79	-1.01	-10.46
26	27	250	170	110	-0.21	-21.59	-0.44	-1.24
27	28	250	140	110	-0.49	-37.89	-0.77	-3.53

Pipeline Data -DZ09.2

Node Number		Dia	Length	Friction L.	Head Loss	Flow	Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	l/s	m/s	%o
28	11	250	750	110	-2.64	-37.89	-0.77	-3.53
6	29	150	190	110	0.00	0.50	0.03	0.01
7	30	150	150	110	0.09	3.90	0.22	0.63
12	31	150	360	110	0.36	5.00	0.28	1.00
14	32	150	180	110	2.68	21.50	1.22	14.86
32	33	150	500	110	0.86	6.70	0.38	1.72
32	34	150	180	110	0.50	8.70	0.49	2.78
34	35	150	450	110	0.65	6.10	0.35	1.44
16	36	150	570	110	2.13	10.20	0.58	3.74
17	37	200	180	110	0.01	2.60	0.08	0.07
20	38	150	230	110	0.05	2.20	0.12	0.22
21	39	150	170	110	0.07	3.10	0.18	0.41
22	40	150	420	110	0.72	6.70	0.38	1.72
27	41	150	480	110	1.28	8.50	0.48	2.67
5	42	600	630	110	0.23	111.30	0.39	0.36
42	43	600	750	110	0.10	65.03	0.23	0.13
43	44	400	150	110	0.01	18.42	0.15	0.09
44	61	400	250	110	0.06	30.53	0.24	0.24
61	45	300	340	110	0.16	20.53	0.29	0.47
45	42	200	250	110	-0.33	-12.47	-0.40	-1.34
45	46	200	200	110	0.41	15.80	0.50	2.07
45	47	150	150	110	0.71	11.60	0.66	4.74
42	48	150	380	110	3.98	17.80	1.01	10.48
43	49	600	70	110	0.01	46.61	0.16	0.07
49	50	150	300	110	3.55	19.00	1.08	11.82
50	51	150	120	110	0.31	8.40	0.48	2.61
49	52	600	250	110	0.00	21.41	0.08	0.02
52	53	600	70	110	0.00	21.41	0.08	0.02
53	44	500	240	110	0.00	12.11	0.06	0.01
53	54	600	140	110	0.00	9.30	0.03	0.00
54	55	200	390	110	0.30	9.30	0.30	0.78
55	56	150	170	110	0.06	2.87	0.16	0.36
56	57	150	180	110	0.00	0.27	0.02	0.00
57	58	150	170	110	-0.01	-1.13	-0.06	-0.06
58	55	150	180	110	-0.05	-2.53	-0.14	-0.28

Distribution Network Analysis for Zone 10

Node Data

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
z10a	-149.27	214.20	186	28.20
z10b	-10.60	213.19	186	27.19
z10c	-85.93	212.70	186	26.70
z10d	-120.30	212.00	186	26.00
1	9.00	213.75	186	27.75
2	9.00	213.49	186	27.49
3	7.30	213.14	186	27.14
4	9.00	213.57	186	27.57
5	9.00	213.28	186	27.28
6	7.40	213.00	186	27.00
7	10.60	213.19	186	27.19
8	20.20	202.77	186	16.77
9	16.60	194.24	186	8.24
10	15.90	191.10	186	5.10
11	17.80	191.07	186	5.07
12	6.90	193.95	186	7.95
13	5.20	193.24	186	7.24
14	3.70	193.10	186	7.10
15	2.00	202.25	186	16.25
16	3.60	195.33	186	9.33
17	4.20	193.19	186	7.19
18	6.60	192.49	186	6.49
19	5.60	192.94	186	6.94
20	12.50	189.63	186	3.63
21	5.10	189.14	186	3.14
22	0.00	190.22	186	4.22
23	26.10	188.94	186	2.94

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
24	6.40	188.80	186	2.80
25	2.70	188.90	186	2.90
26	4.10	188.72	186	2.72
27	4.10	188.86	186	2.86
28	4.00	188.42	186	2.42
29	11.20	189.28	186	3.28
30	0.00	211.88	186	25.88
31	10.00	207.66	186	21.66
32	16.70	204.59	186	18.59
33	0.00	208.86	186	22.86
34	17.40	174.57	186	-11.43
35	11.60	166.99	186	-19.01
36	7.00	165.21	186	-20.79
37	6.60	164.86	186	-21.14
38	2.00	208.03	186	22.03
39	12.10	205.62	186	19.62
40	5.00	205.26	186	19.26
41	4.50	205.09	186	19.09
42	4.10	207.91	186	21.91
43	4.20	207.47	186	21.47
44	4.20	207.81	186	21.81
45	5.90	204.96	186	18.96
46	7.20	204.21	186	18.21
47	0.00	207.81	186	21.81
48	1.80	207.77	186	21.77
50	0.00	192.71	186	6.71

Pipeline Data -DZ10

Node Number		Dia	Length	Friction L.	Head Loss	Flow	Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	l/s	m/s	%o
z10a	1	250	10	110	0.45	149.27	3.04	44.69
1	2	250	360	110	0.27	16.30	0.33	0.74
2	3	150	170	110	0.34	7.30	0.41	2.01
1	4	250	110	110	0.19	25.40	0.52	1.68
4	5	250	380	110	0.28	16.40	0.33	0.75
5	6	150	140	110	0.29	7.40	0.42	2.06
z10b	7	250	1	110	0.00	10.60	0.22	0.33
1	8	250	530	110	10.98	98.57	2.01	20.72
8	9	250	630	110	8.54	78.37	1.60	13.55
9	10	250	360	110	3.14	61.77	1.26	8.72
10	11	300	20	110	0.02	34.67	0.49	1.23
11	12	200	410	110	-2.87	-30.53	-0.97	-7.01
12	13	200	990	110	0.71	8.90	0.28	0.72
13	14	150	240	110	0.14	3.70	0.21	0.57
z10c	15	250	650	110	10.45	85.93	1.75	16.07
15	16	250	450	110	6.92	83.93	1.71	15.38
16	12	250	270	110	1.38	46.33	0.94	5.12
16	17	200	250	110	2.14	34.00	1.08	8.56
17	18	150	420	110	0.70	6.60	0.37	1.67
17	19	200	60	110	0.25	23.20	0.74	4.22
19	50	200	90	110	0.23	17.60	0.56	2.53
50	20	150	300	110	3.08	17.60	1.00	10.26
20	21	150	480	110	0.50	5.10	0.29	1.04
10	11	300	20	110	0.02	34.67	0.49	1.23
11	22	300	390	110	0.86	47.40	0.67	2.20
22	23	250	240	110	1.28	47.40	0.97	5.34
23	24	200	360	110	0.14	6.40	0.20	0.39
23	25	200	450	110	0.04	2.70	0.09	0.08
23	26	200	360	110	0.22	8.10	0.26	0.60
23	27	200	450	110	0.08	4.10	0.13	0.17
26	28	150	450	110	0.30	4.00	0.23	0.66
10	29	150	410	110	1.82	11.20	0.63	4.44
z10d	30	300	10	110	0.12	120.30	1.70	12.33
30	31	150	190	110	4.22	26.70	1.51	22.20
31	32	150	330	110	3.07	16.70	0.95	9.31
30	33	300	390	110	3.02	93.60	1.32	7.75
33	34	150	650	110	34.28	42.60	2.41	52.74
34	35	150	380	110	7.58	25.20	1.43	19.95
35	36	150	280	110	1.78	13.60	0.77	6.37
36	37	150	210	110	0.35	6.60	0.37	1.67
33	38	300	330	110	0.83	51.00	0.72	2.52
38	39	200	650	110	2.40	21.60	0.69	3.69
39	40	200	450	110	0.36	9.50	0.30	0.81
40	41	150	210	110	0.17	4.50	0.25	0.82
38	42	300	150	110	0.12	27.40	0.39	0.80
42	43	150	600	110	0.43	4.20	0.24	0.72
42	44	300	240	110	0.10	19.10	0.27	0.41
44	45	150	480	110	2.85	13.10	0.74	5.94
45	46	150	380	110	0.75	7.20	0.41	1.96
44	47	300	420	110	0.00	1.80	0.03	0.01
47	48	150	230	110	0.03	1.80	0.10	0.15

Distribution Network Analysis for Zone 11

Node Data

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
z11a	-83.06	213.85	186	27.85
z11b	-163.90	213.95	186	27.95
z11c	-44.62	211.85	186	25.85
z11d	-49.48	211.08	186	25.08
z11e	-76.65	211.03	186	25.03
z11f	-105.59	211.10	186	25.10
1	0.00	209.81	186	23.81
2	12.80	206.46	186	20.46
3	25.00	205.79	186	19.79
4	14.70	205.89	186	19.89
5	36.80	209.35	186	23.35
6	32.90	205.91	186	19.91
7	22.80	203.56	186	17.56
8	17.00	205.10	186	19.10
9	25.20	195.22	186	9.22
10	14.70	202.00	186	16.00
11	15.70	210.56	186	24.56
12	0.00	202.14	186	16.14
13	3.00	193.00	186	7.00
14	3.00	181.17	186	-4.83
15	6.20	152.93	186	-33.07
16	12.10	151.86	186	-34.14
17	9.50	149.89	186	-36.11
18	16.70	149.16	186	-36.84
19	0.00	190.18	186	4.18
20	9.20	80.70	186	-105.30
21	5.90	74.69	186	-111.31
22	12.90	72.38	186	-113.62

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
23	0.00	71.71	186	-114.29
24	6.50	66.79	186	-119.21
25	11.90	65.17	186	-120.83
26	14.10	61.70	186	-124.30
27	6.80	64.59	186	-121.41
28	8.30	64.20	186	-121.80
29	3.50	64.09	186	-121.91
30	15.50	71.75	186	-114.25
31	6.60	80.35	186	-105.65
32	12.20	69.67	186	-116.33
33	5.30	211.85	186	25.85
34	9.30	210.41	186	24.41
35	14.80	209.82	186	23.82
36	24.80	207.91	186	21.91
37	10.50	210.31	186	24.31
38	9.30	210.69	186	24.69
39	6.90	211.02	186	25.02
40	8.70	191.72	186	5.72
41	10.10	190.51	186	4.51
42	8.90	188.19	186	2.19
43	9.10	186.74	186	0.74
44	3.10	210.15	186	24.15
45	3.10	210.00	186	24.00
46	8.00	210.01	186	24.01
47	4.10	209.89	186	23.89
48	5.80	209.14	186	23.14
49	0.00	210.31	186	24.31
50	0.00	210.03	186	24.03

Pipeline Data -DZ11

Node Number		Dia	Length	Friction L.	Head Loss	Flow	Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	l/s	m/s	%
z14a	1	300	650	110	4.04	83.06	1.18	6.21
1	2	300	540	110	3.35	83.06	1.18	6.21
2	3	225	90	110	0.67	43.15	1.09	7.50
3	4	225	410	110	-0.11	-7.05	-0.18	-0.26
4	5	225	630	110	-3.45	-36.45	-0.92	-5.48
5	6	150	700	110	3.44	11.82	0.67	4.91
6	7	150	420	110	2.35	12.70	0.72	5.60
7	8	150	420	110	-1.54	-10.10	-0.57	-3.67
8	2	225	430	110	-1.36	-27.10	-0.68	-3.17
3	9	150	530	110	10.57	25.20	1.43	19.94
4	10	150	530	110	3.90	14.70	0.83	7.35
5	z11f	300	270	110	-1.75	-85.07	-1.20	-6.49
z11d	11	300	220	110	0.52	49.48	0.70	2.38
11	50	300	450	110	0.53	33.78	0.48	1.17
50	6	150	120	110	4.12	33.78	1.91	34.31
z11b	12	300	540	110	11.81	163.90	2.32	21.87
12	13	150	150	110	9.14	46.06	2.61	60.94
13	14	150	220	110	11.83	43.06	2.44	53.79
14	15	150	600	110	28.24	40.06	2.27	47.06
15	16	150	210	110	1.08	12.10	0.69	5.13
15	17	150	200	110	3.04	21.76	1.23	15.20
17	18	150	140	110	0.74	12.26	0.69	5.26
18	19	200	480	110	-41.02	-117.84	-3.75	-85.46
19	12	200	140	110	-11.96	-117.84	-3.75	-85.46
18	20	200	860	110	68.45	113.40	3.61	79.60
20	21	200	300	110	6.01	53.84	1.71	20.04
21	22	150	400	110	2.31	12.90	0.73	5.77
21	23	200	330	110	2.98	35.04	1.12	9.04
23	24	200	270	110	4.91	51.10	1.63	18.19
24	25	225	360	110	1.62	32.80	0.83	4.51
25	26	150	510	110	3.47	14.10	0.80	6.80
25	27	150	330	110	0.58	6.80	0.38	1.76
24	28	150	530	110	2.59	11.80	0.67	4.89
28	29	150	220	110	0.11	3.50	0.20	0.52
23	30	200	20	110	-0.04	-16.06	-0.51	-2.13
30	31	200	630	110	-8.60	-43.76	-1.39	-13.65
31	20	200	20	110	-0.35	-50.36	-1.60	-17.71
30	32	150	400	110	2.08	12.20	0.69	5.20
z11c	33	250	1	110	0.00	44.62	0.91	4.78
33	34	250	380	110	1.44	39.32	0.80	3.78
34	35	150	430	110	0.59	5.92	0.34	1.36
35	36	150	400	110	1.91	11.65	0.66	4.78
35	z11f	200	380	110	-1.28	-20.53	-0.65	-3.36
36	37	150	400	110	-2.39	-13.15	-0.74	-5.99
37	38	250	260	110	-0.38	-23.65	-0.48	-1.47
38	39	250	120	110	-0.33	-32.95	-0.67	-2.72
39	z11e	250	1	110	-0.01	-76.65	-1.56	-13.01
39	40	150	480	110	19.30	36.80	2.08	40.21
40	41	150	330	110	1.21	10.10	0.57	3.67
40	42	150	330	110	3.53	18.00	1.02	10.69
42	43	150	480	110	1.45	9.10	0.52	3.02
34	44	250	170	110	0.26	24.10	0.49	1.53
44	45	150	360	110	0.15	3.10	0.18	0.41
44	46	250	160	110	0.14	17.90	0.36	0.88
46	47	150	180	110	0.12	4.10	0.23	0.69
46	48	150	660	110	0.87	5.80	0.33	1.31
37	49	250	330	110	0.00	0.00	0.00	0.00

Distribution Network Analysis for Zone 12

Node Data

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
z12a	-135.49	213.66	186	27.66
z12b	-152.48	212.20	186	26.20
z12c	-156.45	211.21	186	25.21
z12d	-46.10	211.56	186	25.56
z12e	-92.90	211.99	186	25.99
z12f	-96.68	211.21	186	25.21
1	0.00	186.77	186	0.77
2	4.80	174.64	186	-11.36
3	20.50	164.70	186	-21.30
4	28.00	165.95	186	-20.05
5	14.40	184.65	186	-1.35
6	15.90	202.90	186	16.90
7	2.50	166.60	186	-19.40
8	4.90	176.24	186	-9.76
9	7.80	185.69	186	-0.31
10	9.90	188.49	186	2.49
11	9.40	165.57	186	-20.43
12	16.20	165.49	186	-20.51
13	11.40	161.81	186	-24.19
14	13.30	161.76	186	-24.24
15	15.30	159.23	186	-26.77
16	5.40	161.23	186	-24.77
17	6.70	113.70	186	-72.30
18	14.50	109.23	186	-76.77
19	5.80	105.58	186	-80.42
20	24.40	103.03	186	-82.97
21	7.60	100.02	186	-85.98
22	18.80	98.95	186	-87.05
23	8.60	99.93	186	-86.07
24	2.00	102.60	186	-83.40
25	2.00	104.53	186	-81.47
26	6.80	107.87	186	-78.13
27	5.10	95.88	186	-90.12
28	11.60	95.26	186	-90.74
29	5.90	99.28	186	-86.72
30	23.90	159.13	186	-26.87

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
31	13.60	142.21	186	-43.79
32	8.60	111.77	186	-74.23
33	14.00	101.90	186	-84.10
34	12.90	100.71	186	-85.29
35	3.40	100.66	186	-85.34
36	5.10	100.69	186	-85.31
37	24.00	101.51	186	-84.49
38	26.10	100.35	186	-85.65
39	3.30	158.83	186	-27.17
40	25.40	189.44	186	3.44
41	16.70	183.38	186	-2.62
42	0.00	210.04	186	24.04
43	14.40	208.47	186	22.47
44	9.70	207.20	186	21.20
45	7.80	207.38	186	21.38
46	10.70	208.72	186	22.72
47	1.70	207.09	186	21.09
48	1.80	207.05	186	21.05
49	3.00	211.92	186	25.92
50	15.00	210.94	186	24.94
51	3.40	210.82	186	24.82
52	13.60	208.34	186	22.34
53	7.90	205.59	186	19.59
54	10.70	195.45	186	9.45
55	4.40	203.30	186	17.30
56	3.10	202.98	186	16.98
57	3.10	202.29	186	16.29
58	1.60	202.23	186	16.23
59	1.60	202.21	186	16.21
60	24.60	211.19	186	25.19
61	20.60	207.36	186	21.36
62	8.90	205.97	186	19.97
63	15.00	198.15	186	12.15
121	10.50	211.18	186	25.18
141	10.50	211.98	186	25.98

Pipeline Data -DZ12.1

Node Number		Dia	Length	Friction L.	Head Loss	Flow	Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	l/s	m/s	%o
z12a	1	250	720	110	26.89	135.49	2.76	37.35
1	2	250	600	110	12.13	97.26	1.98	20.21
2	3	250	540	110	9.94	92.46	1.88	18.40
3	4	150	610	110	-1.25	-7.38	-0.42	-2.05
4	5	150	500	110	-18.70	-35.38	-2.00	-37.40
5	6	200	340	110	-18.25	-91.64	-2.92	-53.67
6	121	250	340	110	-8.28	-107.54	-2.19	-24.35
z12c	121	250	1	110	0.03	118.04	2.41	28.94
3	7	300	240	110	-1.90	-94.61	-1.34	-7.90
7	8	250	330	110	-9.64	-118.68	-2.42	-29.22
8	9	250	300	110	-9.45	-123.58	-2.52	-31.50
9	10	250	150	110	-2.80	-93.16	-1.90	-18.66
9	1	250	300	110	-1.08	-38.23	-0.78	-3.59
10	z12b	250	510	110	-23.71	-152.48	-3.11	-46.49
10	11	150	330	110	22.92	49.43	2.80	69.46
11	12	200	150	110	0.08	7.40	0.24	0.51
12	7	200	300	110	-1.11	-21.57	-0.69	-3.69
12	13	150	650	110	3.68	12.77	0.72	5.67
13	14	150	490	110	0.04	1.37	0.08	0.09
14	11	200	480	110	-3.81	-32.63	-1.04	-7.93
14	15	150	320	110	2.53	15.30	0.87	7.92
14	16	150	460	110	0.53	5.40	0.31	1.15
3	17	200	290	110	51.01	173.95	5.54	175.88
17	18	300	270	110	4.47	140.96	2.00	16.54
18	19	300	270	110	3.65	126.46	1.79	13.53
19	20	300	270	110	2.55	104.07	1.47	9.43
20	21	200	600	110	3.02	25.52	0.81	5.03
21	22	150	210	110	1.06	12.02	0.68	5.06
22	23	150	540	110	-0.97	-6.89	-0.39	-1.81
23	24	150	330	110	-2.67	-15.49	-0.88	-8.10
24	25	150	190	110	-1.93	-17.49	-0.99	-10.14
25	26	150	270	110	-3.35	-19.49	-1.10	-12.39
26	17	150	270	110	-5.82	-26.29	-1.49	-21.57
22	19	150	720	110	-6.63	-16.60	-0.94	-9.20
22	27	150	330	110	3.07	16.70	0.95	9.31
27	28	150	130	110	0.62	11.60	0.66	4.74
21	29	150	540	110	0.73	5.90	0.33	1.36
30	31	150	210	110	16.92	53.55	3.03	80.57
31	32	150	650	110	30.44	39.95	2.26	46.83

Pipeline Data -DZ12.2

Node Number		Dia	Length	Friction L.	Head Loss	Flow	Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	l/s	m/s	%
32	33	150	330	110	9.87	31.35	1.77	29.89
33	34	150	450	110	1.20	8.49	0.48	2.66
34	35	150	330	110	0.05	1.81	0.10	0.15
35	36	150	330	110	-0.04	-1.59	-0.09	-0.12
36	37	150	480	110	-0.82	-6.69	-0.38	-1.71
37	38	200	480	110	1.17	17.24	0.55	2.43
37	34	150	540	110	0.81	6.23	0.35	1.50
37	20	300	540	110	-1.52	-54.15	-0.77	-2.81
33	38	150	540	110	1.56	8.86	0.50	2.88
5	30	150	500	110	25.53	41.85	2.37	51.05
30	39	150	650	110	0.30	3.30	0.19	0.46
z12c	40	150	500	110	21.77	38.41	2.17	43.55
40	30	150	680	110	30.31	38.90	2.20	44.57
40	41	150	650	110	6.05	16.70	0.95	9.31
z12d	42	250	300	110	1.52	46.10	0.94	5.07
42	43	200	330	110	1.57	24.76	0.79	4.76
43	44	150	330	110	1.27	10.36	0.59	3.84
44	45	150	520	110	-0.18	-2.84	-0.16	-0.35
45	46	150	330	110	-1.33	-10.64	-0.60	-4.04
46	42	150	90	110	-1.32	-21.34	-1.21	-14.67
44	47	150	210	110	0.11	3.50	0.20	0.52
47	48	150	300	110	0.05	1.80	0.10	0.15
z12e	141	300	1	110	0.01	92.90	1.31	7.64
141	49	300	180	110	0.07	18.00	0.25	0.37
49	50	200	520	110	0.98	15.00	0.48	1.88
141	51	300	300	110	1.16	64.40	0.91	3.88
51	52	150	390	110	2.48	13.60	0.77	6.37
51	53	200	330	110	5.23	47.40	1.51	15.83
53	63	150	360	110	7.45	25.70	1.46	20.69
63	54	150	660	110	2.70	10.70	0.61	4.08
53	55	150	350	110	2.29	13.80	0.78	6.54
55	56	150	100	110	0.32	9.40	0.53	3.21
56	57	150	450	110	0.69	6.30	0.36	1.53
57	58	150	150	110	0.07	3.20	0.18	0.44
58	59	150	190	110	0.02	1.60	0.09	0.12
z12f	60	250	1	110	0.02	96.68	1.97	20.00
60	61	250	330	110	3.83	72.08	1.47	11.61
61	62	150	480	110	1.39	8.90	0.50	2.90
61	40	150	340	110	17.92	42.58	2.41	52.72

Distribution Network Analysis for Zone 13

Node Data

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
z13a	-166.50	225.67	184	40.10
101	10.90	225.65	184	40.08
1	0.00	224.28	184	38.71
2	19.10	223.26	184	37.69
3	10.20	220.83	184	35.26
4	10.20	220.46	184	34.89
5	13.10	218.92	184	33.35
6	8.80	216.90	184	31.33
7	3.30	216.90	184	31.33
8	6.70	213.17	188	23.60
9	2.00	213.09	184	27.52
10	4.30	213.02	184	27.45
11	2.10	212.99	184	27.42

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
12	1.40	213.06	184	27.49
13	6.40	213.06	184	27.49
14	1.90	215.14	184	29.57
15	3.90	216.26	184	30.69
16	7.00	217.32	184	31.75
17	4.00	218.16	184	32.59
18	2.20	216.86	184	31.29
19	13.10	209.51	184	23.94
20	10.70	208.33	184	22.76
21	5.60	208.35	184	22.78
22	2.60	208.65	184	23.08
23	6.10	207.91	184	22.34
24	10.90	211.34	184	25.77

Pipeline Data

Node Number		Dia	Length	Friction L.	Head Loss	Flow	Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	l/s	m/s	%
z13a	101	300	1	110	0.02	166.50	2.36	22.52
101	1	250	360	110	1.37	39.50	0.81	3.81
1	2	200	90	110	1.02	39.50	1.26	11.29
2	3	150	180	110	2.43	20.40	1.15	13.48
3	4	200	400	110	0.37	10.20	0.32	0.92
101	5	300	700	110	6.73	105.20	1.49	9.61
5	6	150	420	110	2.02	11.69	0.66	4.81
6	7	150	130	110	0.00	0.69	0.04	0.03
6	18	150	180	110	0.04	2.20	0.12	0.22
7	8	150	400	110	3.73	16.71	0.95	9.32
8	9	150	140	110	0.08	3.74	0.21	0.58
9	10	150	460	110	0.07	1.74	0.10	0.14
10	11	150	140	110	0.03	2.12	0.12	0.20
11	12	250	20	110	-0.07	-38.08	-0.78	-3.56
12	13	250	100	110	0.01	4.82	0.10	0.08
13	10	200	160	110	0.03	4.68	0.15	0.22
13	8	200	300	110	-0.11	-6.27	-0.20	-0.37
12	14	250	440	110	-2.07	-44.29	-0.90	-4.71
14	15	250	220	110	-1.12	-46.19	-0.94	-5.09
15	16	250	180	110	-1.06	-50.09	-1.02	-5.91
16	17	300	270	110	-0.84	-57.09	-0.81	-3.10
17	7	200	420	110	1.26	19.32	0.62	3.00
17	5	300	130	110	-0.76	-80.41	-1.14	-5.85
11	19	200	330	110	3.49	38.10	1.21	10.56
19	20	150	140	110	1.18	15.81	0.90	8.41
20	21	150	350	110	-0.02	-0.99	-0.06	-0.05
21	22	150	180	110	-0.30	-6.59	-0.37	-1.66
22	19	150	280	110	-0.86	-9.19	-0.52	-3.08
20	23	150	290	110	0.42	6.10	0.35	1.44
101	24	100	470	110	14.30	10.90	1.39	30.43

Distribution Network Analysis for Zone 14

Node Data

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
z14a	-93.80	229.97	185	44.97
1	5.50	227.64	185	42.64
2	14.70	223.74	185	38.74
3	20.50	221.91	185	36.91
4	6.90	203.82	185	18.82
5	5.00	203.00	185	18.00

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
6	2.20	202.92	185	17.92
7	7.00	198.33	185	13.33
8	7.40	191.60	185	6.60
9	2.50	191.48	185	6.48
10	14.80	189.97	185	4.97
11	7.30	221.02	185	36.02

Pipeline Data

Node Number		Dia	Length	Friction L.	Head Loss	Flow	Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	l/s	m/s	‰
z14a	1	300	300	110	2.33	93.80	1.33	7.78
1	2	300	560	110	3.89	88.30	1.25	6.95
2	3	300	370	110	1.84	73.60	1.04	4.96
3	4	150	300	110	18.09	45.80	2.59	60.29
4	5	150	420	110	0.82	7.20	0.41	1.96
5	6	150	330	110	0.07	2.20	0.12	0.22
4	7	150	180	110	5.49	31.70	1.79	30.50
7	8	150	350	110	6.73	24.70	1.40	19.22
8	9	150	450	110	0.12	2.50	0.14	0.28
8	10	150	220	110	1.64	14.80	0.84	7.44
3	11	150	440	110	0.88	7.30	0.41	2.01

Distribution Network Analysis for Zone 15-1 (Arterial System)

Node Data

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
z15a	-179.00	225.86	185	40.86
1	8.20	225.80	185	40.80
2	0.00	224.77	185	39.77
3	13.10	220.60	185	35.60
4	5.70	220.22	185	35.22
5	8.30	198.08	185	13.08
6	0.00	188.51	185	3.51
7	5.30	166.91	185	-18.09
8	9.50	155.51	185	-29.49
9	12.10	152.85	185	-32.15
10	0.00	156.75	185	-28.25
11	6.10	117.05	185	-67.95

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
12	8.80	108.83	185	-76.17
13	9.70	104.20	185	-80.80
14	7.40	83.04	185	-101.96
15	4.10	66.31	185	-118.69
16	7.80	59.14	185	-125.86
17	10.00	56.71	185	-128.29
18	16.50	56.92	185	-128.08
19	7.70	58.31	185	-126.69
20	4.10	59.23	185	-125.77
21	0.00	56.00	185	-129.00
22	21.60	53.30	185	-131.70
23	13.00	54.07	185	-130.93

Pipeline Data

Node Number		Dia	Length	Friction L.	Head Loss	Flow	Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	l/s	m/s	%o
z15a	1	250	1	110	0.06	179.00	3.65	62.57
1	2	200	360	110	1.03	18.80	0.60	2.86
2	3	150	360	110	4.17	18.80	1.06	11.59
3	4	150	300	110	0.38	5.70	0.32	1.27
1	5	250	600	110	27.71	152.00	3.10	46.19
5	6	250	230	110	9.57	143.70	2.93	41.63
6	7	150	960	110	21.60	26.90	1.52	22.50
7	8	150	760	110	11.39	21.60	1.22	14.99
8	9	150	520	110	2.67	12.10	0.69	5.13
6	10	250	1120	110	31.76	116.80	2.38	28.36
10	11	250	1400	110	39.70	116.80	2.38	28.36
11	12	250	320	110	8.22	110.70	2.26	25.68
12	13	250	210	110	4.63	101.90	2.08	22.03
13	14	200	390	110	21.16	92.20	2.94	54.26
14	15	200	360	110	16.73	84.80	2.70	46.47
15	16	200	660	110	7.17	38.69	1.23	10.87
16	17	200	340	110	2.44	30.89	0.98	7.16
17	18	250	400	110	-0.21	-13.71	-0.28	-0.54
18	19	250	600	110	-1.39	-30.21	-0.62	-2.32
19	20	250	260	110	-0.92	-37.91	-0.77	-3.53
20	15	200	560	110	-7.09	-42.01	-1.34	-12.65
17	21	200	80	110	0.71	34.60	1.10	8.84
21	22	150	180	110	2.70	21.60	1.22	14.99
21	23	150	330	110	1.93	13.00	0.74	5.85

Distribution Network Analysis for Zone 15-2 (Millat Town WTP System)

Node Data

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
z15b	-69.10	220.60	185.00	35.60
24	12.70	220.07	185.00	35.07
25	21.90	219.73	185.00	34.73
26	9.60	219.60	185.00	34.60

Node No.	Discharge l/s	WL m	GL m	Eff. Head m
27	12.70	216.26	185.00	31.26
18	6.10	219.53	185.00	34.53
20	6.10	219.53	185.00	34.53
19	0.00	219.53	185.00	34.53

Pipeline Data

Node Number		Dia	Length	Friction L.	Head Loss	Flow	Velocity	H Gradient
Up-stream	Dn-stream	mm	m	Co-efficient	m	l/s	m/s	%o
z15b	24	300	120	110	0.53	69.10	0.98	4.42
24	25	300	180	110	0.34	43.70	0.62	1.89
24	27	150	680	110	3.81	12.70	0.72	5.61
25	26	250	180	110	0.13	15.94	0.32	0.71
26	18	250	540	110	0.07	6.34	0.13	0.13
25	20	200	600	110	0.20	5.86	0.19	0.33
18	19	250	340	110	0.00	0.24	0.00	0.00
19	20	250	260	110	0.00	0.24	0.00	0.00

Service Pipe Connection and Customer Water Meter Installation Manual in WASA-F


1. General

(1) Scope and Applicability

This manual describes procedures for service pipe connection and water meter installation. It is possible to grasp the amount of water consumption of customer use. And sustainability is guaranteed by proper construction. This manual is applicable for the water supply area of WASA-F.

(2) Overall figure of coverage

The following figure is a conceptual diagram from the branch distribution pipe to the customer's water property. The first letter of the name will be explained in the next section.



The definition in the above figure is described below. A to F are collectively referred to as a water supply Equipment.

1. Branch is point of branch from distribution pipe to services pipe.

2. Services pipe is water supply pipes from branch to customer tap or storage tank
3. Water meter is installed in services pipe for measure the amount of water used by customers
4. Sucking Pump is water sucking from distribution pipe and pressurizing water for supply water to house or storage tank.
5. Storage tank is installed in rooftop of customer for water storage and supply to house.
6. Earth work is excavating and buck filling for installed water supply equipment.

(3) Principle

- A. The construction method is based on WASA-F standards.
- B. The construction material is based on WASA-F standards
- C. The constructor must submit a water supply construction (as-built) drawing and completion report to WASA-F later.
- D. The constructor should coordinate with WASA-F when it is necessary to cut off water supply by construction.
- E. WASA-F needs to supervise as necessary
- F. When the constructor finds an unknown pipe or inappropriate remaining pipe at the time of construction, it reports to WASA-F.
- G. The customer's water equipment must be able to withstand the specified water pressure and construction of WASA - F.

2. Work Flow of Installation

In order to implement water service pipe/equipment installation construction, work flow is shown below.

1. Preparatory Work
Grasp of existing situation (Site place, Road surface pavement, Private pump) Check of other enterprise pipe/canal (Gus, Telephone, Cable Network, etc.) Selection of construction method Planning of construction schedule Planning of water cut-off (if necessary)
2. Adjustment before construction
Explanation to customers Negotiate with customers Application for road permission
3. Construction work
Implementation of construction work by Manual and SOP Supervise by WASA-F
4. After construction work
Check of completion (Meter counting, Leakage, Water pressure, Water quality) As-built drawing Completion report
5. After completion
Submit completion report to WASA-F Inspection of completion by WASA-F(if necessary)

3. Construction Work

(1) Branch

In branch construction, it is necessary to pay attention to breakage of the water distribution pipe. And in order not to cause water leakage, the construction worker must properly install. During construction, the construction contractor must be particularly careful about the following.

- A. New branch should be 0.3m or more away from other branches.
- B. Construction of new branch must be done from directly above pipe.
- C. New branch must be constructed from the straight pipe section of the distribution branch pipe.
- D. New branch shall not be made from the non-straight pipe (Bend pipe or T-shape pipe) and coupling pipe.

E. The diameter of new branch pipe shall be two ranks or less of the diameter of the water distribution pipe. (Distribution pipe: 100mm → Service pipe: Less than 50mm)

(2) Service Pipe Installation

The water supply pipe shall be installed at an appropriate depth and position in order to avoid damage to the pipe due to the load from the road. And in the case of exposed piping, it shall be installed at a place not external damaged. During construction, the construction contractor must be particularly careful about the following.


- A. When installing water service pipe under the road, it shall be buried at a depth of 30cm or more.
- B. In a place where the load from the road is not applied to the water service pipe, it may be buried at a depth of 10cm or more.
- C. In the case of exposed piping, the water service pipe shall be GIP.
- D. For connection between water service pipes, hose pipe shall not be used.
- E. For connection between PE pipe and stopcock, check valve and water meter, the socket must be used.
- F. If the angle of PE pipe is less than the minimum bending radius, the bend pipe must be placed in that location. For the minimum bending radius, see Table 1.

Table-1 Minimum Bending Radius

PE Pipe Diameter	1/2 inch 13 mm	3/4 inch 20 mm	1 inch 25 mm	1 1/2 inch 40 mm	2 inch 50 mm
1st Grade	45 mm	55 mm	70 mm	100 mm	120 mm
2nd Grade	65 mm	85 mm	105 mm	145 mm	180 mm

[Reference]





(3) Meter Installation

1) Location of Meter Installation

Installation of the water meter shall be prescribed by WASA-F. The installation conditions shall be as follows.

- A. The water meter should be place that can easily be surveyed by meter reader.
- B. The water meter should be installed outside the customer premises.
- C. The water meter should be installed in location that does not impede traffic.
- D. The water meter should be installed on sidewalk concrete.
- E. In order to ensure the precision of the water meter, it must be installed horizontally using leveling instrument.
- F. Since the water meter needs to measure the total amount of water consumption of the customer used, it must be confirmed that there is no branch upstream of the its water meter.
- G. Since the direction in which the water meter is installed must coincide with the direction of flowing water, the arrow on the side of the water meter body must be confirmed.
- H. As a countermeasure to theft, the water meter must be stored in the iron cage water meter box. The design of the meter box is as follows.

2) Meter Box

In principle, the water meter box must be installed on the ground using iron grill.

- A. Cage of the iron grating

Except in special cases, the water meter box must be installed using iron gratings.




Fig. 1 Cage of Iron Grating

B. Lid type

When iron grating cannot be installed on the ground. It is a form to install at a place where the possibility of theft or external damage is high.





Fig. 2 Lid Type

C. Concrete Box type

This underground type should be installed where there is a high possibility of theft or external damage.





Fig. 3 Case that cannot be handled with iron grating and lid type

3) Installation of Magnetic Valve

When installing the meter, it is better to install the magnetic valve on the upstream side of the meter. This is used when exchanging meters or when stopping unpaid customers.

4) Installation of Check Valve

A. Case that new water meter is installed in existing water service pipe

Since check valve is not always installed properly when branching construction of starting of water supply, check valve should be installed upstream of the water meters.

B. Case that new water meter is installed in new water service pipe

Since check valve is installed at the branch point of the water supply, there is no need to install check valve around new water meter. In the case that water meter has the function of check valve, installation of check valve can be omitted.

(4) Approval Materials

Regulations on materials used are as follows

1) Pipe and Joint/Fitting

Pipes and joints/fittings that make up the water supply system must be used that is considered to be the most appropriate. Details are shown in Table-2.

2) Valve (Main cock, Magnetic valve, Check valve, etc.)

Valves that make up the water supply system must be used that is considered to be the most appropriate. Details are shown in Table-2.

3) Water Meter

It is based on specification of Panjab Government. Details are 【Government of Punjab Housing, Urban Development & Public Health Engineering Department. / Notification No. SO (UD) 10-26/2015】

Table-2 List of material specification

Material name	Standard	Diameter	Symbol	Remark
Saddle clump		1/2 inch		
Check valve		1/2 inch		
Magnetic valve		1/2 inch		
Adopter		1/2 inch		
Main cock		1/2 inch		
Short pipe for connecting meter		1/2 inch		
Meter		1/2 inch		
Meter cage				
Meter cover				
Meter box				
GP Pipe		1/2 inch		
Nipple for GP pipe		1/2 inch		
Bend pipe for GP pipe		1/2 inch		
PVC Pipe		1/2 inch		
Nipple for PVC Pipe		1/2 inch		
Bend pipe for PVC pipe		1/2 inch		
Polyethylene pipe		1/2 inch		
Plug for Polyethylene pipe		1/2 inch		
Collar Joint for Polyethylene pipe		1/2 inch		
Male Joint for Polyethylene pipe		1/2 inch		
Female Joint for Polyethylene pipe		1/2 inch		
Bend pipe for Polyethylene pipe		1/2 inch		
T-Pipe for Polyethylene pipe		1/2 inch		

(5) Installation of Float Valve at Individual Tank

Based on article 90; Wastage of Drinking Water of "WATER SUPPLY FAISALABAD REGULATIONS - 2015"; WASA-F can ask customers to install float valve at individual tank in order to prevent overflow from their tanks.

When installing new service connection or installing meter to existing service pipe, WASA-F should check whether or not the float valve is installed at their individual tank.

(6) Removal of Illegal Sucking Pump

Based on article 33; Pump Directly Connected of "WATER SUPPLY FAISALABAD REGULATIONS - 2015"; WASA-F can force the customers to remove the illegal sucking pumps.

When installing new service connection or installing water meter to existing service pipe, WASA-F should check whether the sucking pump is connected directly to WASA-F system or not.

If the sufficient water pressure for water to flow into the tank is secured, WASA-F orders the customer to remove their sucking pump or stop supplying water to this customer.

If the sufficient water pressure cannot be secured, WASA-F orders to the customer to install the intermediate tank or stop supplying water to this customer.

It is illegal to directly connect customers' pumps to WASA-F's water distribution system, as it may reduce the water pressure of WASA-F's water distribution system and cause foreign matter to enter the water distribution pipe. Therefore, measures to remove illegal pumps are necessary.

(7) Earth Work

1) Excavation

- A. During excavation, the construction worker must be careful not to damage the surrounding structures, other enterprise pipes and existing water pipes.
- B. When installing a water supply pipe, it is necessary to excavate both sides more than 10cm from pipe center.
- C. When installing a water supply pipe, it is necessary to excavate 10cm downward from pipe center.
- D. The surroundings of installed pipes must be backfilled with fine material from 10cm downward to 10cm above them. For example, Fine material is sand.

2) Back filling

- A. Do not use large stones or bricks as backfilling material.
- B. Do not backfill other than small gravel

3) Road surface restoration

- A. Recovery of road surface should be restored to the state before construction as much as possible.
- B. If it is difficult to restore to the above, the construction worker must consult with WASA-F and follow the results.

(8) Inspection of service connection inside the customer's property

Based on article 9; Inspection of Premises of "WATER SUPPLY FAISALABAD REGULATIONS - 2015"; WASA-F can enter the customer's property and inspect and test the customer's piping and equipment when new installation of service connection.

When installing new service connection, WASA-F should check the in-hoe piping whether it is suitable or not, and if not, WASA-F stop supplying water to this customer.

1) Completion inspection

After completion of construction, completion inspection must be carried out before backfilling. The completion inspection refers to the following.

A. Water flow inspection

It is necessary to let water flow through the installed water service pipe and check water leakage and construction failure.

B. Water quality inspection

It is necessary to sample with tap and confirm the Residual Chlorine reaction.

C. Water meter setting inspection


It is necessary to confirm whether the water meter is properly installed by the water meter setting check sheet.

(9) Submission of As-built Drawings and Material List (Completion Report)

- A. The construction contractor shall submit completed documents after completion of the completion inspection.
- B. The format of Table 2 designated by WASA-F must be used for completed documents.
- C. WASA-F supervises before and after construction, if there is doubt; WASA-F conducts construction attendance and completion inspection

Meter Installation SOP in WASA-F

Overall Figure of coverage




1. Branch







It should be confirmed that rubber is set at branch point.

No 1/4" ferrule




Service connection should be branched directly from water distribution pipe by 1/2" and 90° of bent pipe is used instead of 1/4" ferrule.

2. Service Pipe

	<p>When improving existing service pipe, it is necessary to confirm that pipe comes from WASA-F's system.</p>
	<p>GI should be selected if pipe is installed above ground. If pipe is installed underground, UPVC/HDPE or non-corrosive pipe & fittings shall be used.</p>
	<p>The pipe should be cut with suitable equipment.</p>
	<p>The cut of the polyethylene pipe must be straight.</p>
	<p>Use of meaningless bend pipe should be avoided.</p>

3. Meter



3-1. Location of Meter Installation



	<p>Meter should be installed <u>outside</u> of customer's <u>premises</u> within 50cm from boundary and without vehicle load. (If meter is installed inside the customer's premises, it is difficult to read the meter for meter readers because of gate lock or customer absence)</p>
---	--

3-2. Three types of meter cage for thief prevention measure of meter




Measures to prevent theft of the meter are selected depending on the site situation, but in principle, installation of **(1) MS cage** should be adopted. Under difficult circumstances for various reasons, underground installation such as **(2) Steel lid** or **(3) Concrete Box** will be considered.

(1) MS Cage type


	<p>In principle, MS cage should be selected with concrete base and meter should be installed on the ground.</p>
	<p>MS cage should be installed as left figure.</p>

	<p>For opening the meter cover, 7cm or more of interval is required at the top. At the site, meter cover should be opened and ease of meter reading should be confirmed.</p>
	<p>For opening/closing the magnetic valve, 5cm or more of interval is required around magnetic valve. At the site, valve operation should be carried out and confirmed.</p>

(2) Steel lid type

	<p>When the cage installed on the ground interferes with the opening and closing of the door or the passage of the vehicle, or when the space cannot be secured on the ground, underground installation should be selected for thief prevention measure of meter.</p>
	<p>If there is a concrete part where the lid can be fixed with the anchor, (2) Steel lid type should be selected instead of (1) MS cage type. The meter installation place is excavated. Excavation range: Width20cm x Length30cm x Depth20cm or more. Drainage function should be considered.</p>
	<p>Even on a slope, the lid can be installed as the left figure. However, it is necessary to pay attention to the lid installation location so that the anchor does not penetrate.</p>

(3) Concrete Box type




If there is no concrete to fix the lid with anchor, **(3) Concrete Box Type** should be selected for thief prevention measure of meter instead of **(2) Steel Lid type**.


Drainage function should be considered.

(Installation of (1) and (2) is considered as much as possible, because (3) is expensive)


3-3. Basics for Meter Installation




Piping around the meter consists of non-return valve, magnetic valve, meter and adopter.



All water consumption should be captured. It is necessary to confirm that there is no water supply branch upstream of the meter.







Meter should be installed horizontally, therefore horizontal should be confirmed using spirit level etc.




It should be confirmed that the arrow on the side of the meter body with water flow direction.

3-4. Reuse of existing meter

	<p>Whether there is existing meter should be confirmed.</p>
	<p>If customer already has existing meter, meter should be read and recorded and this value should be reported to IT section.</p>
	<p>Removed meter should be brought the meter test yard and checked the accuracy. If meter has good accuracy, WASA-F can reuse it.</p>
	<p>If test meter is available, you can utilize it.</p>


4. Storage Tank

 A diagram of a blue storage tank with a float valve mechanism. A green pipe enters from the left, and another green pipe exits from the bottom right. A float valve is shown inside the tank, connected to the inlet pipe.	<p>It should be confirmed whether the customer has a storage tank. If customer has tank, it should be confirmed that the float valve is installed. If not, WASA-F should instruct customer to install it.</p>
--	---


5. Sucking Pump


In principle, illegal sucking pump must be removed. If WASA-F cannot ensure the proper water pressure or customer denies removing it, for countermeasure of illegal pump sucking, **(1) Intermediate Tank** or **(2) Air Valve** should be installed.

(1) Intermediate Tank

 A cross-sectional diagram of a water system. On the left, a meter is installed on a pipe. To its right, an intermediate storage tank is installed. The tank is labeled "Intermediate Tank (pump sucking measure)". A pump is located to the right of the tank. Further right, another storage tank is shown. The diagram illustrates the placement of the intermediate tank between the meter and the pump.	<p>For one of the countermeasure of sucking pump, intermediate storage tank should be installed between meter and pump. When installing intermediate tank, float valve should be installed.</p>
--	---

(2) Air Valve

 A cross-sectional diagram of a water system, similar to the one above. It shows a meter, an air valve, and a pump. The air valve is labeled "Air Valve (pump sucking measure)". The air valve is installed between the meter and the pump, and is positioned at a higher elevation than the meter.	<p>For another countermeasure of sucking pump, air valve should be installed between meter and pump, and it should be installed at higher position than meter.</p>
--	--

 A detailed diagram of an air valve. It shows a vertical pipe with a valve mechanism on top. Two blue spheres are shown near the valve, representing air or water flow.	<p>It is confirmed that water does not come out from the air valve.</p>
--	---

Water Meter Installation Check Sheet

No.	Check items	Check
1	Meter is checked for proper functioning of low-flow dial before installing it.	
2	Meter is horizontally installed with correct flow direction.	
3	Magnetic valve is installed upstream and non-return valve is installed downstream of meter with no branches upstream of meter.	
4	Illegal sucking pump is not installed ^{*1} and there are no suspected, illegal connections around customer's premises ^{*2} .	
5	If customer has storage tank, float valve is installed ^{*3} .	
6	Proper water pressure is secured at customer's tap.	
7	Meter is easy to read and remove by WASA-F maintenance workers.	
8	Meter is not an obstacle to traffic and has theft prevention.	

*1 If not, WASA-F should instruct and ask the customer to improve the situations (removal of pump/installation of intermediate tank/installation of air valve), and reconfirm later.

*2 If not, WASA-F should instruct and ask the customer to improve the situations (disconnect the connections) and reconfirm later.

*3 If not, WASA-F should instruct and ask the customer to improve the situations (installation of float valve) and reconfirm at later date.

Book No: _____

Meter reading date: _____

METER READING BOOK



WASA-F

Section: _____


In-charge: _____

Water Distribution Area: _____

Meter Reading and Inspection SOP for WASA-F

Apart from meter reading, the staff has three other responsibilities. The ability to understand the situation at hand is required in them.

- Inspection of a water meter.
- Discovery of a leakage or illegal connection and grasping any unique case.
- Providing means for effective conversation between WASA-F and consumers.



Meter installation scheme

Meter Reading:

The meter reader must have a thorough understanding of water meters and meter reading book. Each page of the book belongs to one customer and only his/her data would be mentioned there every month. Staff should follow these steps:

- Check meter number and open respective page on book.
- Meter consists of 8 digits and meter reading column in book is divided in two. Black digits on meter will be recorded on left column and red digits in right column.
- Staff will inspect the meter and add remarks in “Remarks” column.
- Date will be marked in “Date” column.
- After completing meter reading of all houses in one book, reader will check the map at the end of book before handing it over to the IT section.


Meter readers need to take care of following issues when recording consumption volume as it is of substantial importance.

1. Inspection of water meter:



Meter readers need to check the meter and report if the dial isn't moving smoothly or the glass is broken. Staff should measure reading and record it precisely. Meter reading should be done after regular time intervals to ensure uniformity in data.


2. Discovering leakage/illegal or some unique case:

 A cross-sectional diagram of the ground showing a brown pipe with a blue water droplet falling from a hole in it. The ground surface is indicated by a green grassy line.	<p>When improving existing service pipe, it is necessary to confirm that pipe comes from WASA-F's system.</p> <p>If installation is above ground, use GI pipes and use UPVC/HDPE or non-corrosive pipes underground.</p>
---	--

3. Providing means for effective conversation between WASA-F and consumers:

- Delivering new messages from WASA-F to customers door-to-door. Providing information to them about meter installation distance and proper conditions.
- Informing WASA-F and CRC in case of any complaints or requests from consumers.
- Selection of appropriate measures for preventing meter theft. If circumstances are not feasible for MS cage, adopt steel lid or concrete box.

3.1 Storage Tank:

 A diagram of a blue storage tank with a green pipe entering from the left. Inside the tank, a float valve mechanism is shown, consisting of a grey float ball connected to a vertical rod that controls a valve.	<p>Check if the customer has storage tank present and float valve installed in it or not. If not present, instruct customer to install it.</p>
--	--

3.2 Sucking Pump:

Use of sucking pumps is prohibited because:

- Its vibrations damage the meter.
- It increases chances of water contamination.
- Pressure created reduces water supply for those who do not use sucking pump.

WASA-F needs to educate consumers about these drawbacks of sucking pumps through bills or pamphlets. If WASA-F cannot ensure the proper water pressure or customer denies removing it, then Intermediate tank or Air valve might be used as countermeasure of illegal pump sucking.

Pilot Area Map Sarfraz Colony (Block-A)

