

APPENDIX FOR CHAPTER C3 PRESENT SEWERAGE SYSTEM

AC3.1 Present Sewer Capacity Assessment

To assess the present sewer capacity, the sewer calculation has been done to check the estimated present sewer against the sewer capacity. Table AC3.1 shows that the results and the ratio of the flow against the capacity more than 1.0 indicating insufficient capacity.

Ratio of Design Flow against Capacity			
More than 2.0	From 1.2 to 1.4		
From 1.8 to 2.0	From 1.0 to 1.2		
From 1.6 to 1.8	Less than 1.0		
From 1.4 to 1.6			

Ratio of Design Flow against Capacity			
More than 2.0	From 1.2 to 1.4		
From 1.8 to 2.0	From 1.0 to 1.2		
From 1.6 to 1.8	Less than 1.0		
From 1.4 to 1.6			

Population (x10 ³)			
Up to 5	4.5	Peaking Factor	Peaking Factor
From 5 to 10	4.0		3.0
From 10 to 25	3.5		2.5
From 25 to 50			2.0
From 50 to 100			
More than 100			

Sewer No.	Incoming Sewer	Sewerage Area (ha)		Sewer Length (m)	Domestic Wastewater					Point Source			Design	Sewer Line Design				Remarks	Ratio of Design Flow against Capacity
					Unit Generation Rate (LPCD)			Domestic WW Flow (m³/sec)	Industrial WW Flow (m³/sec)	Commercial WW Flow (m³/sec)	I/I of Ground water Flow (m³/sec)	Max. Flow (m³/sec)		Dia. (mm)	Slope (%)	Velocity (m/sec)	Capacity (m³/sec)		
					Population (thousand)	Service Population (thousand)	Peaking Factor												
		Increment	Total		Increment	Total	Increment	Total	Max. Flow (m³/sec)	Industrial WW Flow (m³/sec)	Commercial WW Flow (m³/sec)	I/I of Ground water Flow (m³/sec)	Max. Flow (m³/sec)	Dia. (mm)	Slope (%)	Velocity (m/sec)	Capacity (m³/sec)		
16	14	148.30 1,020.80	1,972.00	12,016 99,845	3,935 61,452	2.5	0.231	0.442	0.029	0.726	1650	0.20	0.60	1.289		0.56			
		To WP10			PS-19(OP/S), 84.9 m³/m²=1.415m³/s														
17		81.80	409.00	14,811 13,358	13,358	3.5	0.070	0.035	0.002	0.109	600	0.75	0.60	0.168		0.65			
18		81.80 85.40 167.20	747.00	14,811 14,811 29,173	13,358 12,953 26,311	3.0	0.119	0.072	0.004	0.200	750	0.60	0.62	0.272		0.73			
19		18.90 186.10	286.00	3,785 32,958	3,414 29,725	3.0	0.134	0.081	0.004	0.224	825	0.50	0.60	0.321		0.70			
20		57.30 243.40	339.00	8,108 41,066	7,313 37,038	3.0	0.167	0.105	0.006	0.285	900	0.45	0.60	0.384		0.74			
		To Sewer No. 22																	
21		17.60	458.00	2,523	2,276	4.5	0.015	0.008	0.001	0.024	600	0.75	0.60	0.168		0.15			
22	20	17.60 278.00	607.00	3,785 47,374	3,414 42,728	3.0	0.193	0.120	0.007	0.328	900	0.45	0.60	0.384		0.85			
		To Sewer No. 26																	
23		33.10	177.00	16,128	14,546	3.5	0.077	0.014	0.001	0.093	600	0.75	0.60	0.168		0.55			
24		33.10 17.00 70.20	472.00	16,128 9,964 26,092	14,546 8,987 23,533	3.5	0.124	0.030	0.002	0.158	675	0.65	0.60	0.214		0.74			
25		4.70 74.90	86.00	2,275 28,366	2,052 25,585	3.0	0.115	0.032	0.002	0.151	675	0.65	0.60	0.214		0.71			
26	22	43.70 396.60	248.00	7,945 83,686	7,166 75,479	2.5	0.284	0.172	0.009	0.476	900	0.45	0.60	0.384	Insufficient capacity	1.24			
27		24.90 421.50	68.00	2,898 86,584	2,614 78,093	2.5	0.294	0.183	0.010	0.499	1050	0.40	0.63	0.546		0.91			
28		128.70 550.20	1,082.00	21,287 107,871	19,199 97,292	2.5	0.366	0.238	0.013	0.633	1200	0.30	0.60	0.675	The Lift PS (PS-28) is operated.	0.94			
29		67.60 617.80	709.00	6,645 114,516	4,980 102,272	2.0	0.308	0.268	0.015	0.609	1200	0.30	0.60	0.675		0.90			
30		34.90 652.70	574.00	2,178 116,694	1,964 104,236	2.0	0.314	0.283	0.015	0.631	1350	0.30	0.65	0.924		0.68			
		To Sewer No. 32																	
31		154.20 154.20	531.00	12,682 12,682	1,364 1,364	4.5	0.009	0.067	0.004	0.084	1350	0.30	0.65	0.924		0.09			
32	30	15.10 822.00	180.00	0,882 130,258	0,242 105,842	2.0	0.319	0.356	0.019	0.718	1350	0.30	0.65	0.924		0.78			

Ratio of Design Flow against Capacity									
More than 2.0									
From 1.2 to 1.4									
From 1.8 to 2.0									
From 1.0 to 1.2									
From 1.6 to 1.8									
From 1.4 to 1.6									

Sewer No.	Sewerage Area (ha)		Sewer Length	Domestic Wastewater					Point Source				Design	Sewer Line Design				Remarks	Ratio of Design Flow against Capacity
				Unit Generation Rate (LPCD)			Peaking Factor	Domestic WW Flow (m³/sec)	Industrial WW Flow (m³/sec)	Commercial WW Flow (m³/sec)	I/I of Ground water Flow (m³/sec)	Max. Flow (m³/sec)		Dia. (mm)	Slope (%)	Velocity (m/sec)	Capacity (m³/sec)		
				Population (thousand)	Service Population (thousand)	Increment													
33	261.70	1,083.70	1,128.00	18,272	3,972	109,814	2.0	0.330	0.470	0.025	0.031	0.856	Ø 1650	0.60	1.289			0.66	
	148,530			109,814	2.0														0.330
34	36.70		735.00	8,222	7,416														
35	36.70	61.60	884.00	8,222	7,416	5,617	4.0	0.045	0.016	0.001	0.001	0.063	Ø 525	0.90	0.129			0.49	
	24.90			5,066	0.001														0.001
	61.60			13,839	12,482	12,482	3.5	0.066	0.027	0.001	0.002	0.096	Ø 600	0.75	0.168			0.57	
				pumped up to Nishatabad(L/P/S) 0.8m³/min=0.013m³/s															
				Insufficient capacity															
36	845.00		2,524.00	110,651	3,282														
37	845.00	858.10	398.00	110,651	3,282	2,377	4.5	0.022	0.366	0.020	0.024	0.432	Ø 750	0.60	0.272	Insufficient capacity		1.59	
	13.10			2,636	5,659														4.0
			To Sewer No. 42																
38	63.30		324.00	16,916	11,714														
39	63.30	7.40	340.00	16,916	11,714	3,025	3.5	0.062	0.027	0.001	0.002	0.092	Ø 525	0.90	0.129			0.71	
	70.70			3,025	2,728														3.5
40	92.30	163.00	279.00	23,677	20,193	20,193	3.0	0.156	0.071	0.004	0.005	0.236	Ø 675	0.65	0.214	Insufficient capacity		1.10	
	43,618			34,635	6,821														41,456
41	31.60		438.00	7,563	6,821														
42	194.60	8.50	393.00	51,180	41,456	1,313	3.0	0.187	0.084	0.005	0.006	0.282	Ø 750	0.60	0.272	Insufficient capacity		1.04	
	1,061.20			165,923	48,428														3.0
			To Sewer No. 47																
43	75.70		286.00	15,715	14,174														
	75.70			15,715	14,174		3.5	0.075	0.033	0.002	0.002	0.112	Ø 600	0.75	0.168			0.66	
			To Sewer No. 46																
44	27.00		292.00	6,080	5,484														
45	27.00	4.20	383.00	6,080	5,484	2,819	4.0	0.033	0.012	0.001	0.001	0.047	Ø 600	0.75	0.168			0.28	
	31.20			8,303	9,207														0.001
46	8.40	115.30	180.00	5,828	5,256	27,733	3.0	0.125	0.050	0.014	0.001	0.066	Ø 600	0.75	0.168			0.39	
	31.20			8,303	9,207														0.001

Ratio of Design Flow against Capacity			
More than 2.0	From 1.2 to 1.4		
From 1.8 to 2.0	From 1.0 to 1.2		
From 1.6 to 1.8	Less than 1.0		
From 1.4 to 1.6			

Ratio of Design Flow against Capacity			
More than 2.0	From 1.2 to 1.4		
From 1.8 to 2.0	From 1.0 to 1.2		
From 1.6 to 1.8	Less than 1.0		
From 1.4 to 1.6			

Population (x10 ³)			
Up to 5	4.5	Peaking Factor	Peaking Factor
From 5 to 10	4.0		3.0
From 10 to 25	3.5		2.5
More than 100			2.0

Sewer No.	Incoming Sewer	Sewerage Area (ha)		Sewer Length (m)	Domestic Wastewater (LPCD)						Point Source				Design	Sewer Line Design				Remarks	Ratio of Design Flow against Capacity
					Unit Generation Rate (LPCD)		130	Industrial WW Flow (m³/sec)	Commercial WW Flow (m³/sec)	I/I of Ground water Flow (m³/sec)	Max. Flow (m³/sec)	Dia. (mm)	Slope (%)	Velocity (m/sec)		Capacity (m³/sec)					
																	Population (thousand)	Service Population (thousand)	Peaking Factor		
		Increment	Total		Increment	Total	Increment	Total	Increment	Total	Increment	Total	Increment	Total	Increment	Total	Increment	Total	Increment		
47	35, 42	65.20	14,422	15,990	103,065	2.0	0.310	0.565	0.031	0.038	0.944	1200	0.30	0.60	0.675	Insufficient capacity	1.40				
		1,303.30		226,502																	
48		76.30	27,645	30,652	27,645	3.0	0.125	0.033	0.002	0.002	0.162	600	0.75	0.60	0.168		0.96				
		76.30	27,645	30,652	27,645	3.0	0.125	0.033	0.002	0.002	0.162	600	0.75	0.60	0.168						
49	47	15.80	4,230	4,690	4,230	2.0	0.406	0.605	0.033	0.040	1.084	1200	0.30	0.60	0.675	Insufficient capacity	1.61				
		1,395.40	134,940	261,843	134,940	2.0	0.406	0.605	0.033	0.040	1.084	1200	0.30	0.60	0.675	Insufficient capacity					
50		14.40	6,155	6,824	6,155	2.0	0.425	0.611	0.033	0.041	1.110	1200	0.30	0.60	0.675	Insufficient capacity	1.64				
		1,409.80	141,095	268,667	141,095	2.0	0.425	0.611	0.033	0.041	1.110	1200	0.30	0.60	0.675	Insufficient capacity					
51		11.20	4,526	5,018	4,526	4.5	0.031	0.005	0.000	0.000	0.036	525	0.90	0.60	0.129		0.28				
		11.20	4,526	5,018	4,526	4.5	0.031	0.005	0.000	0.000	0.036	525	0.90	0.60	0.129						
52		30.80	3,977	4,410	3,977	4.0	0.051	0.018	0.001	0.001	0.071	525	0.90	0.60	0.129		0.55				
		42.00	8,503	9,428	8,503	4.0	0.051	0.018	0.001	0.001	0.071	525	0.90	0.60	0.129						
53	50	14.40	5,144	5,703	5,144	2.0	0.466	0.635	0.034	0.042	1.177	1200	0.30	0.60	0.675	Insufficient capacity	1.74				
		1,466.20	154,742	283,798	154,742	2.0	0.466	0.635	0.034	0.042	1.177	1200	0.30	0.60	0.675	Insufficient capacity					
		Galistan Colony(LP/S) 88.3m³/min=1.472m³/s																			
54		42.30	4,590	5,089	4,590	4.5	0.031	0.018	0.001	0.001	0.051	750	0.60	0.62	0.272		0.19				
		42.30	4,590	5,089	4,590	4.5	0.031	0.018	0.001	0.001	0.051	750	0.60	0.62	0.272						
		Galistan Colony(LP/S) 88.3m³/min=1.472m³/s										1.228									
55	53	2.70	1,041	1,154	1,041																
		1,511.20	160,373	290,041	160,373	2.0	0.483	0.655	0.036	0.044	1.218	1350	0.30	0.65	0.924	Insufficient capacity	1.32				
56	77	28.60	4,162	4,615	4,162																
		1,793.80	181,228	313,164	181,228	2.0	0.545	0.777	0.042	0.052	1.416	1350	0.30	0.65	0.924	Insufficient capacity	1.53				
57		68.30	2,579	2,859	2,579																
		1,862.10	183,807	316,024	183,807	2.0	0.553	0.807	0.044	0.054	1.458	1650	0.20	0.60	1.289	Insufficient capacity	1.13				
		To Sewer No. 79																			
58		11.00	0,556	0,617	0,556	4.5	0.004	0.005	0.000	0.000	0.009	525	0.90	0.60	0.129		0.07				
		11.00	0,556	0,617	0,556	4.5	0.004	0.005	0.000	0.000	0.009	525	0.90	0.60	0.129						
59		15.20	1,091	1,091	1,091	4.5	0.010	0.011	0.001	0.001	0.023	525	0.90	0.60	0.129		0.18				
		26.20	1,540	1,708	1,540	4.5	0.010	0.011	0.001	0.001	0.023	525	0.90	0.60	0.129						
60		8.20	0,428	0,475	0,428																
		34.40	1,968	2,183	1,968	4.5	0.013	0.015	0.001	0.001	0.030	600	0.75	0.60	0.168		0.18				
		To Sewer No. 62																			
61		18.10	0,856	0,949	0,856	4.5	0.006	0.008	0.000	0.001	0.015	675	0.65	0.60	0.214		0.07				
		18.10	0,856	0,949	0,856	4.5	0.006	0.008	0.000	0.001	0.015	675	0.65	0.60	0.214						
62	60	4.20	0,428	0,475	0,428	4.5	0.022	0.025	0.001	0.002	0.050	675	0.65	0.60	0.214		0.23				
		56.70	3,252	3,606	3,252	4.5	0.022	0.025	0.001	0.002	0.050	675	0.65	0.60	0.214						

Ratio of Design Flow against Capacity			
More than 2.0	From 1.2 to 1.4	From 25 to 50	Peaking Factor
From 1.8 to 2.0	From 1.0 to 1.2	From 50 to 100	3.0
From 1.6 to 1.8	Less than 1.0	More than 100	2.5
From 1.4 to 1.6			2.0

Ratio of Design Flow against Capacity			
More than 2.0	From 1.2 to 1.4	From 25 to 50	Peaking Factor
From 1.8 to 2.0	From 1.0 to 1.2	From 50 to 100	3.0
From 1.6 to 1.8	Less than 1.0	More than 100	2.5
From 1.4 to 1.6			2.0

Sewer No.	Sewerage Area (ha)		Sewer Length (m)	Domestic Wastewater					Point Source				Design	Sewer Line Design				Remarks	Ratio of Design Flow against Capacity
				Unit Generation Rate (LPCD)			Domestic W W Flow (m ³ /sec)	Industrial W W Flow (m ³ /sec)	Commercial W W Flow (m ³ /sec)	I/I of Ground water Flow (m ³ /sec)									
				Service Population (thousand)		Peaking Factor													
				Population Increment	Total														
	Total				Shadman (LP/S) 30, 6m ³ /min=0.51m ³ /s														
63		19.30	165.00	0.925	0.834	4.5	0.006	0.008	0.000	0.001	0.015	○ 525	0.90	0.60	0.129		0.11		
64		19.30	341.00	0.925	0.834	4.5	0.008	0.011	0.001	0.001	0.021	○ 525	0.90	0.60	0.129		0.16		
65		25.70	120.00	1.233	1.112	4.5	0.013	0.020	0.001	0.001	0.035	○ 525	0.90	0.60	0.129		0.27		
66		20.50	384.00	0.925	0.834	4.5	0.019	0.034	0.002	0.002	0.057	○ 675	0.65	0.60	0.214		0.27		
67		46.20	906.00	2.158	1.946	4.5	0.028	0.041	0.002	0.003	0.074	○ 900	0.45	0.60	0.384		0.19		
		31.90		0.949	0.856														
		78.10		3.107	2.802	4.5	0.019	0.034	0.002	0.002									
		15.50		1.284	1.284														
		93.60		4.531	4.086	4.5	0.028	0.041	0.002	0.003									
		To Sewer No. 70																	
68		9.30	585.00	0.475	0.428	4.5	0.003	0.004	0.000	0.000	0.007	○ 1050	0.40	0.63	0.546		0.01		
69		9.30	63.00	0.475	0.428	4.5	0.003	0.004	0.000	0.000	0.007	○ 1050	0.40	0.63	0.546		0.01		
70	67	1.00	133.00	0.000	0.000	4.5	0.031	0.045	0.002	0.003	0.081	○ 900	0.45	0.60	0.384	Dia. of sewer of down stream is reduced. (Confirmed the GIS data)	0.21		
71		104.10	475.00	5.006	4.514	4.5	0.036	0.050	0.003	0.003	0.092	○ 1050	0.40	0.63	0.546		0.17		
		115.70		6.629	5.978	4.0	0.036	0.050	0.003	0.003									
		To Sewer No. 77																	
72		13.20	306.00	0.949	0.856	4.5	0.006	0.006	0.000	0.000	0.012	○ 525	0.90	0.60	0.129		0.09		
73		13.20	791.00	0.949	0.856	4.5	0.023	0.018	0.001	0.001	0.043	○ 600	0.75	0.60	0.168		0.26		
74		27.50	97.00	2.569	2.569	4.5	0.023	0.018	0.001	0.001	0.043	○ 1200	0.30	0.60	0.675		0.07		
		40.70		3.797	3.425														
		5.20		0.475	0.428														
		45.90		4.272	3.853	4.5	0.026	0.020	0.001	0.001	0.048								
		To Sewer No. 76																	
75	62	23.10	1,177.00	1.899	1.713		0.034	0.035	0.002	0.002	0.073	○ 900	0.45	0.60	0.384		0.19		
		79.80		5.505	4.965	4.5	0.034	0.035	0.002	0.002									
76	74	2.90	232.00	0.000	0.000	4.0	0.053	0.056	0.003	0.004	0.116	○ 1200	0.30	0.60	0.675		0.17		
		128.60		9.777	8.818														
77	71	9.70	282.00	2.103	1.897		0.088	0.110	0.006	0.007	0.211	○ 1200	0.30	0.60	0.675		0.31		
		254.00		18.509	16.693	3.5	0.088	0.110	0.006	0.007	0.211								
		To Sewer No. 56																	
78		4.40	236.00	0.000	0.000	4.5	0.000	0.002	0.000	0.000	0.002	○ 1050	0.40	0.63	0.546		0.00		
		4.40		0.000	0.000														
79	57	93.70	1,059.00	3.461	3.122		0.563	0.849	0.046	0.057	1.515	○ 1800	0.20	0.64	1.625		0.93		
		1,960.20		319.484	186.929	2.0	0.563	0.849	0.046	0.057	1.515								
		To Sewer No. 91																	

Ratio of Design Flow against Capacity			
More than 2.0	From 1.2 to 1.4	From 25 to 50	Peaking Factor
From 1.8 to 2.0	From 1.0 to 1.2	From 50 to 100	Peaking Factor
From 1.6 to 1.8	Less than 1.0	More than 100	Peaking Factor
From 1.4 to 1.6			

Ratio of Design Flow against Capacity			
More than 2.0	From 1.2 to 1.4	From 25 to 50	Peaking Factor
From 1.8 to 2.0	From 1.0 to 1.2	From 50 to 100	Peaking Factor
From 1.6 to 1.8	Less than 1.0	More than 100	Peaking Factor
From 1.4 to 1.6			

Sewer No.	Incoming Sewer	Sewerage Area (ha)		Sewer Length (m)	Domestic Wastewater					Point Source			Design	Sewer Line Design				Remarks	Ratio of Design Flow against Capacity
					Unit Generation Rate (LPCD)		Domestic WW Flow (m³/sec)	Industrial WW Flow (m³/sec)	Commercial WW Flow (m³/sec)	I/I of Ground water Flow (m³/sec)	Max. Flow (m³/sec)	Dia. (mm)		Slope (%)	Velocity (m/sec)	Capacity (m³/sec)			
					Population (thousand)	Service Population (thousand)											Peaking Factor		
		Increment	Total	Total	Total														
80		91.50	693.00	5.070	4.573	4.5	0.031	0.040	0.002	0.003	0.076	Ø 600	0.75	0.60	0.168		0.45		
		91.50	545.00	5.070	4.573	4.5	0.031	0.040	0.002	0.003	0.076	Ø 600	0.75	0.60	0.168				
81		100.60	545.00	5.796	5.228	4.0	0.031	0.044	0.002	0.003	0.080	Ø 675	0.65	0.60	0.214		0.38		
82		52.60	415.00	3.351	3.022	4.5	0.020	0.023	0.001	0.002	0.046	Ø 675	0.65	0.60	0.214		0.22		
		52.60		3.351	3.022														
83		182.00	242.00	13.387	12.074	3.5	0.064	0.079	0.004	0.005	0.152	Ø 675	0.65	0.60	0.214		0.71		
		182.00	249.00	13.387	12.074	3.5	0.064	0.079	0.004	0.005	0.152	Ø 675	0.65	0.60	0.214				
84		2.40	514.00	0.238	0.215	3.5	0.065	0.080	0.004	0.005	0.154	Ø 750	0.60	0.62	0.272		0.56		
		184.40	514.00	13.625	12.289	3.5	0.065	0.080	0.004	0.005	0.154	Ø 750	0.60	0.62	0.272				
85	82	10.60	432.00	0.477	0.430	3.5	0.083	0.107	0.006	0.007	0.203	Ø 750	0.60	0.62	0.272		0.74		
		247.60	432.00	17.453	15.741	3.5	0.083	0.107	0.006	0.007	0.203	Ø 750	0.60	0.62	0.272				
86		21.30		0.964	0.869	3.5	0.087	0.117	0.006	0.008	0.218	Ø 1200	0.30	0.60	0.675		0.32		
		268.90		18.417	16.610	3.5	0.087	0.117	0.006	0.008	0.218	Ø 1200	0.30	0.60	0.675				
87		28.10	321.00	5.270	4.753	4.5	0.032	0.012	0.001	0.001	0.046	Ø 525	0.90	0.60	0.129		0.36		
		28.10	371.00	5.270	4.753	4.5	0.032	0.012	0.001	0.001	0.046	Ø 525	0.90	0.60	0.129				
88		60.80	339.00	7.883	7.110	4.0	0.043	0.026	0.001	0.002	0.072	Ø 675	0.65	0.60	0.214		0.34		
			339.00	7.883	7.110	4.0	0.043	0.026	0.001	0.002	0.072	Ø 675	0.65	0.60	0.214				
89		13.00		0.726	0.655	4.0	0.047	0.032	0.002	0.002	0.083	Ø 750	0.60	0.62	0.272		0.30		
		73.80		8.609	7.765	4.0	0.047	0.032	0.002	0.002	0.083	Ø 750	0.60	0.62	0.272				
90	86	10.20	494.00	0.363	0.327	3.5	0.130	0.153	0.008	0.010	0.301	Ø 1200	0.30	0.60	0.675		0.45		
		352.90	494.00	27.389	24.702	3.5	0.130	0.153	0.008	0.010	0.301	Ø 1200	0.30	0.60	0.675				
91	79	135.20	2,614.00	12.906	7.011	2.0	0.674	1.105	0.060	0.073	1.912	Ø 1800	0.20	0.64	1.625	Insufficient capacity	1.18		
		2,548.90		365.575	223.870	2.0	0.674	1.105	0.060	0.073	1.912	Ø 1800	0.20	0.64	1.625	Insufficient capacity			
					PS-38 (DP/S) 152.9 m³/min=2.548m³/s														
92		182.70	1,111.00	11.384	10.267	3.5	0.054	0.079	0.004	0.005	0.142	Ø 525	0.90	0.60	0.129	Insufficient capacity	1.10		
		182.70		11.384	10.267	3.5	0.054	0.079	0.004	0.005	0.142	Ø 525	0.90	0.60	0.129	Insufficient capacity			
93		77.10	772.00	15.613	14.082	3.5	0.074	0.033	0.002	0.002	0.111	Ø 525	0.90	0.60	0.129		0.86		
		77.10		15.613	14.082	3.5	0.074	0.033	0.002	0.002	0.111	Ø 525	0.90	0.60	0.129				

Ratio of Design Flow against Capacity	
More than 2.0	
From 1.8 to 2.0	From 1.2 to 1.4
From 1.6 to 1.8	From 1.0 to 1.2
From 1.4 to 1.6	Less than 1.0

[illegible]

Ratio of Design Flow against Capacity									
More than 2.0				From 1.2 to 1.4					
From 1.8 to 2.0				From 1.0 to 1.2					
From 1.6 to 1.8				Less than 1.0					
From 1.4 to 1.6									

Sewer No.	Sewerage Area (ha)		Sewer Length (m)	Domestic Wastewater					Point Source			Design	Sewer Line Design				Remarks	Ratio of Design Flow against Capacity
				Unit Generation Rate (LPCD)		Peaking Factor	Domestic WW Flow (m³/sec)	Industrial WW Flow (m³/sec)	Commercial WW Flow (m³/sec)	I/I of Ground water Flow (m³/sec)	Max. Flow (m³/sec)		Dia. (mm)	Slope (%)	Velocity (m/sec)	Capacity (m³/sec)		
	Increment	Total																
133		18.60	275.00	4.160	3.752	4.5	0.025	0.008	0.000	0.001	0.034	○ 525	0.90	0.60	0.129		0.27	
134		18.60	183.00	4.160	3.752	4.5	0.025	0.008	0.000	0.001	0.034	○ 525	0.90	0.60	0.129		0.49	
		14.00		4.477	4.038	4.0	0.047	0.014	0.001	0.001	0.063	○ 525	0.90	0.60	0.129			
135		32.60	688.00	8.638	7.790	4.0	0.047	0.014	0.001	0.001	0.063	○ 525	0.90	0.60	0.129			
		22.20		3.635	3.278	3.5	0.058	0.024	0.001	0.002	0.085	○ 675	0.65	0.60	0.214		0.40	
		54.80		12.272	11.068	3.5	0.058	0.024	0.001	0.002	0.085	○ 675	0.65	0.60	0.214			
136	127	48.90	548.00	11.217	10.117	2.0	0.595	0.430	0.023	0.029	1.077	○ 1350	0.30	0.65	0.924	Insufficient capacity	1.17	
		992.70		219.386	197.861	2.0	0.595	0.430	0.023	0.029	1.077	○ 1350	0.30	0.65	0.924	Insufficient capacity		
		To Sewer No. 143																
137		58.30	744.00	14.111	12.727													
		58.30		14.111	12.727	3.5	0.067	0.025	0.001	0.002	0.095	○ 525	0.90	0.60	0.129		0.74	
138		12.20	401.00	0.909	0.820													
		70.50		15.020	13.547	3.5	0.071	0.031	0.002	0.002	0.106	○ 675	0.65	0.60	0.214		0.50	
		To Sewer No. 143																
139		5.60	309.00	0.646	0.583	4.5	0.004	0.002	0.000	0.000	0.006	○ 750	0.60	0.62	0.272		0.02	
		5.60		0.646	0.583	4.5	0.004	0.002	0.000	0.000	0.006	○ 750	0.60	0.62	0.272			
		To Sewer No. 142																
140		59.40	306.00	7.050	6.358													
		59.40		7.050	6.358	4.0	0.038	0.026	0.001	0.002	0.067	○ 525	0.90	0.60	0.129		0.52	
141		15.60	261.00	4.388	3.958													
		75.00		11.438	10.316	3.5	0.054	0.033	0.002	0.002	0.091	○ 675	0.65	0.60	0.214		0.43	
142	139	39.50	956.00	9.889	8.919													
		120.10		21.973	19.818	3.5	0.104	0.052	0.003	0.003	0.162	○ 750	0.60	0.62	0.272		0.60	
143	136	9.80	385.00	0.909	0.820													
138		1,193.10		257.288	232.046	2.0	0.698	0.517	0.028	0.034	1.277	○ 1950	0.20	0.67	2.012		0.63	
		To Sewer No. 145																
144		90.40	1,164.00	17.842	16.092													
		90.40		17.842	16.092	3.5	0.085	0.039	0.002	0.003	0.129	○ 750	0.60	0.62	0.272		0.47	
145	143	11.40	274.00	2.474	2.231													
		1,294.90		277.605	250.369	2.0	0.753	0.561	0.030	0.037	1.381	○ 1950	0.20	0.67	2.012		0.69	
		To Sewer No. 148																
146		17.70	360.00	3.734	3.368													
		17.70		3.734	3.368	4.5	0.023	0.008	0.000	0.001	0.032	○ 525	0.90	0.60	0.129		0.25	
147		29.50	707.00	4.860	4.383													
		47.20		8.594	7.751	4.0	0.047	0.020	0.001	0.001	0.069	○ 675	0.65	0.60	0.214		0.32	
148	145	6.10	333.00	0.909	0.820													
		1,348.20		287.107	258.940	2.0	0.779	0.584	0.032	0.039	1.434	○ 1950	0.20	0.67	2.012		0.71	
		To Sewer No. 151																
149		106.50	705.00	24.584	22.173													
		106.50		24.584	22.173	3.5	0.117	0.046	0.003	0.003	0.169	○ 750	0.60	0.62	0.272		0.62	

Ratio of Design Flow against Capacity			
More than 2.0	From 1.2 to 1.4	From 25 to 50	Peaking Factor
From 1.8 to 2.0	From 1.0 to 1.2	From 50 to 100	Up to 5
From 1.6 to 1.8	Less than 1.0	More than 100	From 5 to 10
From 1.4 to 1.6			From 10 to 25
			3.5
			4.5
			2.5
			3.0

Ratio of Design Flow against Capacity			
More than 2.0	From 1.2 to 1.4	From 25 to 50	Peaking Factor
From 1.8 to 2.0	From 1.0 to 1.2	From 50 to 100	Up to 5
From 1.6 to 1.8	Less than 1.0	More than 100	From 5 to 10
From 1.4 to 1.6			From 10 to 25
			3.5
			4.5
			2.5
			3.0

Sewer No.	Sewerage Area (ha)		Sewer Length (m)	Domestic Wastewater					Point Source				Design	Sewer Line Design				Remarks	Ratio of Design Flow against Capacity
				Unit Generation Rate (LPCD)					Domestic WW Flow (m³/sec)	Industrial WW Flow (m³/sec)	Commercial WW Flow (m³/sec)	I/I of Ground water Flow (m³/sec)		Dia. (mm)	Slope (%)	Velocity (m/sec)	Capacity (m³/sec)		
				Population (thousand)		Service Population (thousand)	Peaking Factor	Total											
	Increment	Total																	
167	27.80	27.80	312.00	4.224	3.810	3.810	4.5	0.026	0.012	0.001	0.001	0.040	525	0.90	0.60	0.129		0.31	
						Liaquat Town(OP/S) 0.5m³/min=0.008m³/s													
						Insufficient capacity													
168	107.20	107.20	922.00	3.280	1.134	1.134	4.5	0.008	0.046	0.003	0.003	0.060	525	0.90	0.60	0.129		0.46	
169	560.10	667.30	126.00	12.034	0.000	1.134	4.5	0.008	0.289	0.016	0.019	0.332	675	0.65	0.60	0.214	Insufficient capacity	1.55	
						Jhang Road(OP/S) 40.8m³/min=0.680m³/s													
170	104.80	104.80	654.00	14.141	12.754	12.754	3.5	0.067	0.045	0.002	0.003	0.117	600	0.75	0.60	0.168		0.70	
171	106.30	106.30	107.00	0.957	0.863	13.617	3.5	0.072	0.046	0.002	0.003	0.123	600	0.75	0.60	0.168		0.73	
172	9.10	115.40	224.00	0.957	0.863	14.480	3.5	0.076	0.050	0.003	0.003	0.132	675	0.65	0.60	0.214		0.62	
173	27.10	142.50	219.00	4.503	4.061	18.541	3.5	0.098	0.062	0.003	0.004	0.167	675	0.65	0.60	0.214		0.78	
						Jhang Road(OP/S) 40.8m³/min=0.680m³/s													
174	53.10	53.10	765.00	18.695	11.955	11.955	3.5	0.063	0.023	0.001	0.002	0.089	525	0.90	0.60	0.129		0.69	
						To Sewer No. 176													
175	70.10	70.10	593.00	17.897	8.070	8.070	4.0	0.049	0.030	0.002	0.002	0.083	525	0.90	0.60	0.129		0.64	
176	7.60	130.80	316.00	1.368	1.234	21.259	3.5	0.112	0.057	0.003	0.004	0.176	750	0.60	0.62	0.272		0.65	
						To Sewer No. 179													
177	9.90	9.90	304.00	1.368	1.234	1.234	4.5	0.008	0.004	0.000	0.000	0.012	675	0.65	0.60	0.214		0.06	
178	0.00	140.70	325.00	0.000	0.000	22.493	3.5	0.118	0.061	0.003	0.004	0.186	750	0.60	0.62	0.272		0.68	
179	8.10	148.80	718.00	2.735	2.467	24.960	3.5	0.131	0.064	0.003	0.004	0.202	750	0.60	0.62	0.272		0.74	
						To Sewer No. 181													
180	166.90	166.90	296.00	16.488	9.782	9.782	4.0	0.059	0.072	0.004	0.005	0.140	600	0.75	0.60	0.168		0.83	

Ratio of Design Flow against Capacity									
More than 2.0		From 1.2 to 1.4							
From 1.8 to 2.0		From 1.0 to 1.2							
From 1.6 to 1.8		Less than 1.0							
From 1.4 to 1.6									

Sewer No.	Incoming Sewer	Sewerage Area (ha)		Sewer Length (m)	Domestic Wastewater					Point Source			Design		Sewer Line Design				Remarks	Ratio of Design Flow against Capacity										
					Unit Generation Rate (LPCD)		Peaking Factor	Domestic WW Flow (m³/sec)	Industrial WW Flow (m³/sec)	Commercial WW Flow (m³/sec)	I/I of Ground water Flow (m³/sec)	Max. Flow (m³/sec)	Dia. (mm)	Slope (%)	Velocity (m/sec)	Capacity (m³/sec)														
		Population (thousand)	Service Population (thousand)		Total	Total											Total	Total			Total	Total								
																							Increment	Increment	Increment	Increment	Increment	Increment	Increment	Increment
181	179	10.10 325.80	2.940 61.490	2.652 37.394	3.0	0.169	0.141	0.008	0.009	0.327	1050	0.40	0.63	0.546		0.60														
182		14.00 14.00	0.279 0.279	0.252 0.252	4.5	0.002	0.006	0.000	0.000	0.008	675	0.65	0.60	0.214		0.04														
183		2.70 16.70	0.279 0.557	0.252 0.504	4.5	0.003	0.007	0.000	0.000	0.010	675	0.65	0.60	0.214		0.05														
184	181	28.10 370.60	4.571 66.619	4.123 42.021	3.0	0.190	0.161	0.009	0.011	0.371	1050	0.40	0.63	0.546		0.68														
185		34.50 34.50	1.672 1.508	1.508 1.508	4.5	0.010	0.015	0.001	0.001	0.027	525	0.90	0.60	0.129		0.21														
186	184	3.80 408.90	1.236 69.527	1.115 44.644	3.0	0.202	0.177	0.010	0.012	0.401	1050	0.40	0.63	0.546		0.73														
187		77.30 77.30	13.627 13.627	12.290 12.290	3.5	0.065	0.033	0.002	0.002	0.102	525	0.90	0.60	0.129		0.79														
188		62.50 139.80	14.784 28.411	13.334 25.624	3.0	0.116	0.061	0.003	0.004	0.184	600	0.75	0.60	0.168	Insufficient capacity	1.09														
189		65.70 205.50	7.282 35.693	6.568 32.192	3.0	0.145	0.089	0.005	0.006	0.245	675	0.65	0.60	0.214	Insufficient capacity	1.15														
190		3.10 3.10	0.086 0.086	0.078 0.078	4.5	0.001	0.001	0.000	0.000	0.002	525	0.90	0.60	0.129		0.01														
191		1.50 1.50	0.504 0.504	0.455 0.455	4.5	0.003	0.001	0.000	0.000	0.004	525	0.90	0.60	0.129		0.03														
192	190	14.70 19.30	0.173 0.763	0.156 0.689	4.5	0.005	0.008	0.000	0.001	0.014	525	0.90	0.60	0.129		0.11														
193		29.20 29.20	0.849 0.849	0.766 0.766	4.5	0.005	0.013	0.001	0.001	0.020	525	0.90	0.60	0.129		0.16														
194	192	0.20 48.70	0.000 1.612	0.000 1.455	4.5	0.010	0.021	0.001	0.001	0.033	525	0.90	0.60	0.129		0.25														
195		77.40 126.10	1.774 3.397	1.610 3.065	4.5	0.021	0.055	0.003	0.004	0.083	600	0.75	0.60	0.168		0.49														

Ratio of Design Flow against Capacity																
More than 2.0																
From 1.2 to 1.4																
From 1.8 to 2.0																
From 1.6 to 1.8																
From 1.4 to 1.6																

Sewer No.	Sewerage Area (ha)		Sewer Length (m)	Domestic Wastewater (LPCD)				Point Source			Design	Sewer Line Design				Remarks	Ratio of Design Flow against Capacity	
				Unit Generation Rate (LPCD)		Peaking Factor	Domestic WW Flow (m ³ /sec)	Industrial WW Flow (m ³ /sec)	Commercial WW Flow (m ³ /sec)	I/I of Ground water Flow (m ³ /sec)		Max. Flow (m ³ /sec)	Dia. (mm)	Slope (%)	Velocity (m/sec)			Capacity (m ³ /sec)
				Population (thousand)	Service Population (thousand)													
196		Increment	Total	10.10			0.173	0.156										
				136.20			3.569	3.221	4.5	0.022	0.059	0.003	0.004	0.088	750	0.60	0.62	0.272
							To Sewer No. 198											
197		Increment	Total	43.20			0.777	0.701										
				43.20			0.777	0.701	4.5	0.005	0.019	0.001	0.001	0.026	525	0.90	0.60	0.129
198	196	Increment	Total	16.70			0.173	0.156										
				196.10			4.518	4.078	4.5	0.028	0.085	0.005	0.006	0.124	750	0.60	0.62	0.272
199		Increment	Total	316.50			5.980	1.253										
				512.60			10.498	5.331	4.0	0.032	0.222	0.012	0.015	0.281	1050	0.40	0.63	0.546
							To WP19											
301		Increment	Total	7.30			1.022	1.022										
				7.30			1.022	1.022	4.5	0.007	0.002	0.000	0.000	0.009	1200	0.30	0.60	0.675
							To Sewer No. 303											
302		Increment	Total	62.10			7.184	7.184										
				62.10			7.184	7.184	4.0	0.043	0.015	0.001	0.001	0.060	1350	0.30	0.65	0.924
303	301	Increment	Total	7.90			1.022	1.022										
				77.30			9.228	9.228	4.0	0.056	0.019	0.001	0.001	0.077	1350	0.30	0.65	0.924
304		Increment	Total	239.00			0.000	0.000										
				78.50			9.228	9.228	4.0	0.056	0.019	0.001	0.001	0.077	1350	0.30	0.65	0.924
							To Sewer No. 342											
305		Increment	Total	23.70			2.025	2.025										
				23.70			2.025	2.025	4.5	0.014	0.006	0.000	0.000	0.020	600	0.75	0.60	0.168
							To EP9 and discharge to Sewer No. 306											
306	305	Increment	Total	10.20			0.617	0.617										
				33.90			2.642	2.642	4.5	0.018	0.008	0.001	0.001	0.028	900	0.45	0.60	0.384
							To Sewer No. 309											
307		Increment	Total	8.90			0.925	0.925										
				8.90			0.925	0.925	4.5	0.006	0.002	0.000	0.000	0.008	600	0.75	0.60	0.168
308		Increment	Total	25.90			0.925	0.925										
				34.80			1.850	1.850	4.5	0.013	0.008	0.001	0.001	0.023	675	0.65	0.60	0.214
309	306	Increment	Total	5.70			0.308	0.308										
				74.40			4.800	4.800	4.5	0.033	0.018	0.001	0.001	0.053	1050	0.40	0.63	0.546
							To Sewer No. 312											
310		Increment	Total	24.20			1.289	1.289										
				24.20			1.289	1.289	4.5	0.009	0.006	0.000	0.000	0.015	600	0.75	0.60	0.168
311		Increment	Total	11.70			0.799	0.799										
				35.90			2.088	2.088	4.5	0.014	0.009	0.001	0.001	0.025	750	0.60	0.62	0.272
312	309	Increment	Total	5.50			0.491	0.491										
				115.80			7.378	7.379	4.0	0.044	0.028	0.002	0.002	0.076	1050	0.40	0.63	0.546

Ratio of Design Flow against Capacity		Population (x10 ³)	Peaking Factor	Population (x10 ³)	Peaking Factor
More than 2.0	From 1.2 to 1.4	Up to 5	4.5	From 25 to 50	3.0
From 1.8 to 2.0	From 1.0 to 1.2	From 5 to 10	4.0	From 50 to 100	2.5
From 1.6 to 1.8	Less than 1.0	From 10 to 25	3.5	More than 100	2.0
From 1.4 to 1.6					

Sewer No.	Incoming Sewer	Sewerage Area (ha)		Sewer Length (m)	Domestic Wastewater					Point Source				Design	Sewer Line Design				Remarks	Ratio of Design Flow against Capacity
					Unit Generation Rate (LPCD)			Domestic WW Flow (m³/sec)	Industrial WW Flow (m³/sec)	Commercial WW Flow (m³/sec)	I/I of water Flow (m³/sec)	Max. Flow (m³/sec)	Dia. (mm)		Slope (%)	Velocity (m/sec)	Capacity (m³/sec)			
					Population (thousand)	Service Population (thousand)	Peaking Factor													
														Increment				Total		
313				630.00	14.300 21.678	14.300 21.679	3.5	0.114	0.052	0.004	0.004	0.174	○ 1200	0.30	0.60	0.675	0.26			
314				460.00	2.852 2.852	2.852 2.852	4.5	0.019	0.004	0.000	0.000	0.023	○ 600	0.75	0.60	0.168	0.14			
315				546.00	1.269 4.121	1.269 4.121	4.5	0.028	0.006	0.000	0.000	0.034	○ 750	0.60	0.62	0.272	0.12			
316				200.00	0.000 0.000	0.000 0.000		0.000	0.019	0.001	0.001	0.021	○ 600	0.75	0.60	0.168	0.12			
317				405.00	0.792 0.792	0.792 0.792	4.5	0.005	0.021	0.002	0.002	0.030	○ 750	0.60	0.62	0.272	0.11			
318				248.00	0.308 0.308	0.308 0.308	4.5	0.002	0.002	0.000	0.000	0.004	○ 600	0.75	0.60	0.168	0.02			
319				221.00	0.308 5.529	0.308 5.529	4.0	0.033	0.029	0.002	0.002	0.066	○ 900	0.45	0.60	0.384	0.17			
320				318.00	4.883 4.883	4.883 4.883	4.5	0.033	0.012	0.001	0.001	0.047	○ 600	0.75	0.60	0.168	0.28			
321				165.00	33.460 43.871	33.460 43.872	3.0	0.198	0.090	0.007	0.007	0.302	○ 1050	0.40	0.63	0.546	0.55			
322				348.00	2.557 2.557	2.557 2.557	4.5	0.017	0.005	0.000	0.000	0.022	○ 525	0.90	0.60	0.129	0.17			
323				656.00	60.30 50.218	3.790 50.219	2.5	0.189	0.109	0.008	0.008	0.314	○ 1050	0.40	0.63	0.546	0.57			
324				287.00	0.000 0.000	0.000 0.000	4.5	0.000	0.001	0.000	0.000	0.001	○ 600	0.75	0.60	0.168	0.01			
325				1,194.00	9.357 59.575	9.357 59.576	2.5	0.224	0.111	0.008	0.008	0.351	○ 1050	0.40	0.63	0.546	0.64			
326				1,362.00	79.50 102.032	20.778 102.033	2.0	0.307	0.183	0.014	0.013	0.517	○ 1200	0.30	0.60	0.675	0.77			

Ratio of Design Flow against Capacity			
More than 2.0	From 1.2 to 1.4	From 25 to 50	Peaking Factor
From 1.8 to 2.0	From 1.0 to 1.2	From 50 to 100	Up to 5
From 1.6 to 1.8	Less than 1.0	More than 100	From 5 to 10
From 1.4 to 1.6			From 10 to 25
			Peaking Factor
			4.5
			4.0
			3.5
			2.5
			2.0

Ratio of Design Flow against Capacity			
More than 2.0	From 1.2 to 1.4	From 25 to 50	Peaking Factor
From 1.8 to 2.0	From 1.0 to 1.2	From 50 to 100	Up to 5
From 1.6 to 1.8	Less than 1.0	More than 100	From 5 to 10
From 1.4 to 1.6			From 10 to 25
			Peaking Factor
			4.5
			4.0
			3.5
			2.5
			2.0

Sewer No.	Sewerage Area (ha)		Sewer Length (m)	Domestic Wastewater (LPCD)						Point Source			Design	Sewer Line Design				Remarks	Ratio of Design Flow against Capacity
				Unit Generation Rate (LPCD)		Peaking Factor	Domestic WW Flow (m³/sec)	Industrial WW Flow (m³/sec)	Commercial WW Flow (m³/sec)	I/I of Ground water Flow (m³/sec)	Max. Flow (m³/sec)	Dia. (mm)		Slope (%)	Velocity (m/sec)	Capacity (m³/sec)			
				Population (thousand)	Service Population (thousand)														
																	Total		
327	3.50	1.124	425.00	1.124	1.124	4.5	0.008	0.001	0.000	0.000	0.009	600	0.75	0.60	0.168	0.05			
328	3.50	1.124	439.00	1.124	1.124	4.5	0.008	0.001	0.000	0.000	0.009	600	0.75	0.60	0.168	0.05			
	7.70	2.249		2.249	2.249	4.5	0.023	0.002	0.000	0.000	0.025	675	0.65	0.60	0.214	0.12			
329	2.60	1.124	332.00	1.124	1.124	4.5	0.008	0.001	0.000	0.000	0.009	600	0.75	0.60	0.168	0.05			
330	2.60	1.124	260.00	1.124	1.124	4.5	0.008	0.001	0.000	0.000	0.009	600	0.75	0.60	0.168	0.05			
	7.10	2.249		2.249	2.249	4.5	0.015	0.002	0.000	0.000	0.017	750	0.60	0.62	0.272	0.06			
331	17.90	4.170	150.00	4.170	4.170	4.0	0.059	0.008	0.001	0.001	0.069	750	0.60	0.62	0.272	0.25			
332	32.70	9.791	227.00	9.791	9.791	4.0	0.059	0.008	0.001	0.001	0.070	1050	0.40	0.63	0.546	0.13			
	6.40	0.000		0.000	0.000	4.0	0.059	0.009	0.001	0.001	0.070	1050	0.40	0.63	0.546	0.13			
	39.10	9.791		9.791	9.791	4.0	0.059	0.009	0.001	0.001	0.070	1050	0.40	0.63	0.546	0.13			
333	30.20	3.114	443.00	3.114	3.114	4.5	0.021	0.007	0.001	0.001	0.030	675	0.65	0.60	0.214	0.14			
	30.20	3.114		3.114	3.114	4.5	0.021	0.007	0.001	0.001	0.030	675	0.65	0.60	0.214	0.14			
334	16.60	2.882	288.00	2.882	2.882	3.5	0.083	0.021	0.002	0.002	0.108	1050	0.40	0.63	0.546	0.20			
	85.90	15.787		15.787	15.787	3.5	0.083	0.021	0.002	0.002	0.108	1050	0.40	0.63	0.546	0.20			
335	2.20	0.961	460.00	0.961	0.961	3.5	0.088	0.021	0.002	0.002	0.113	1050	0.40	0.63	0.546	0.21			
	88.10	16.748		16.748	16.748	3.5	0.088	0.021	0.002	0.002	0.113	1050	0.40	0.63	0.546	0.21			
336	13.80	2.050	97.00	2.050	2.050	3.5	0.099	0.025	0.002	0.002	0.128	1050	0.40	0.63	0.546	0.23			
	101.90	18.798		18.798	18.798	3.5	0.099	0.025	0.002	0.002	0.128	1050	0.40	0.63	0.546	0.23			
337	33.80	6.679	204.00	6.679	6.679	4.0	0.040	0.008	0.001	0.001	0.050	525	0.90	0.60	0.129	0.39			
	33.80	6.679		6.679	6.679	4.0	0.040	0.008	0.001	0.001	0.050	525	0.90	0.60	0.129	0.39			
338	1.40	0.000	240.00	0.000	0.000	4.0	0.040	0.008	0.001	0.001	0.050	525	0.90	0.60	0.129	0.39			
	35.20	6.679		6.679	6.679	4.0	0.040	0.008	0.001	0.001	0.050	525	0.90	0.60	0.129	0.39			
339	0.50	0.000	158.00	0.000	0.000	4.0	0.040	0.009	0.001	0.001	0.051	525	0.90	0.60	0.129	0.40			
	35.70	6.679		6.679	6.679	4.0	0.040	0.009	0.001	0.001	0.051	525	0.90	0.60	0.129	0.40			
340	121.00	23.910	741.00	23.910	23.910	3.0	0.223	0.062	0.005	0.005	0.295	1050	0.40	0.63	0.546	0.54			
	258.60	49.387		49.387	49.387	3.0	0.223	0.062	0.005	0.005	0.295	1050	0.40	0.63	0.546	0.54			
341	87.50	15.412	1,329.00	15.412	15.412	2.0	0.502	0.266	0.020	0.019	0.807	1650	0.20	0.60	1.289	0.63			
	1,105.20	166.831		166.831	166.831	2.0	0.502	0.266	0.020	0.019	0.807	1650	0.20	0.60	1.289	0.63			
342	91.10	17.623	1,370.00	17.623	17.623	2.0	0.583	0.307	0.023	0.022	0.935	1800	0.20	0.64	1.625	0.58			
	1,274.80	193.682		193.682	193.682	2.0	0.583	0.307	0.023	0.022	0.935	1800	0.20	0.64	1.625	0.58			
343	15.20	0.981	248.00	0.981	0.981	4.5	0.007	0.004	0.000	0.000	0.011	600	0.75	0.60	0.168	0.06			
	15.20	0.981		0.981	0.981	4.5	0.007	0.004	0.000	0.000	0.011	600	0.75	0.60	0.168	0.06			
344	2.20	0.000	197.00	0.000	0.000	4.5	0.007	0.004	0.000	0.000	0.011	825	0.50	0.60	0.321	0.03			
	17.40	0.981		0.981	0.981	4.5	0.007	0.004	0.000	0.000	0.011	825	0.50	0.60	0.321	0.03			

Ratio of Design Flow against Capacity	
More than 2.0	
From 1.8 to 2.0	From 1.2 to 1.4
From 1.6 to 1.8	From 1.0 to 1.2
From 1.4 to 1.6	Less than 1.0

AC3 - 18

Ratio of Design Flow against Capacity			
More than 2.0	From 1.2 to 1.4	From 25 to 50	Peaking Factor
From 1.8 to 2.0	From 1.0 to 1.2	From 50 to 100	Up to 5
From 1.6 to 1.8	Less than 1.0	More than 100	From 5 to 10
From 1.4 to 1.6			From 10 to 25
			Peaking Factor
			4.5
			4.0
			3.5
			2.5
			2.0

Ratio of Design Flow against Capacity			
More than 2.0	From 1.2 to 1.4	From 25 to 50	Peaking Factor
From 1.8 to 2.0	From 1.0 to 1.2	From 50 to 100	Up to 5
From 1.6 to 1.8	Less than 1.0	More than 100	From 5 to 10
From 1.4 to 1.6			From 10 to 25
			Peaking Factor
			4.5
			4.0
			3.5
			2.5
			2.0

Sewer No.	Incoming Sewer	Sewerage Area (ha)		Sewer Length (m)	Domestic Wastewater						Point Source			Design	Sewer Line Design				Remarks	Ratio of Design Flow against Capacity
					Unit Generation Rate (LPCD)			Domestic WW Flow (m³/sec)	Industrial WW Flow (m³/sec)	Commercial WW Flow (m³/sec)	I/I of Ground water Flow (m³/sec)	Max. Flow (m³/sec)	Dia. (mm)		Slope (%)	Velocity (m/sec)	Capacity (m³/sec)			
					Population (thousand)	Service Population (thousand)	Peaking Factor													
		Increment	Total	Increment	Total	Increment	Total	Increment	Total	Increment	Total	Increment	Total	Increment	Total	Increment	Total	Increment	Total	
362	360	52.90 334.10	14.380 70.338		14.380 70.341			2.5	0.265	0.080	0.006	0.006	0.357	1350	0.30	0.65	0.924		0.39	
363		263.90 263.90	54.146 38.426		38.426 38.426			3.0	0.173	0.064	0.005	0.005	0.247	525	0.90	0.60	0.129	Insufficient capacity	1.92	
364	362	1.90 599.90	1.195 125.679		1.195 109.962			2.0	0.331	0.144	0.011	0.011	0.497	1350	0.30	0.65	0.924		0.54	
365		34.00 34.00	6.751 6.751		6.751 6.751			4.0	0.041	0.008	0.001	0.001	0.051	525	0.90	0.60	0.129		0.39	
366		625.80 625.80	40.812 40.812		12.363 12.363			3.5	0.065	0.151	0.011	0.011	0.238	900	0.45	0.60	0.384		0.62	
367		64.90 64.90	6.705 4.652		4.652 4.652			4.5	0.031	0.016	0.001	0.001	0.049	600	0.75	0.60	0.168		0.29	
368	366	48.80 739.50	6.146 53.663		4.824 21.839			3.5	0.115	0.178	0.013	0.013	0.319	900	0.45	0.60	0.384		0.83	
369		51.70 791.20	4.401 58.064		3.449 25.288			3.0	0.114	0.190	0.014	0.014	0.332	1050	0.40	0.63	0.546		0.61	
370		52.40 843.60	5.430 63.494		5.430 30.718			3.0	0.139	0.203	0.015	0.015	0.372	1050	0.40	0.63	0.546		0.68	
371		18.80 862.40	2.387 65.880		2.387 33.105			3.0	0.149	0.208	0.016	0.015	0.388	1350	0.30	0.65	0.924		0.42	
372		4.60 867.00	0.961 66.841		0.961 34.066			3.0	0.154	0.209	0.016	0.015	0.394	1350	0.30	0.65	0.924		0.43	
373		35.50 902.50	3.171 71.405		3.171 37.237			3.0	0.168	0.217	0.016	0.016	0.417	1350	0.30	0.65	0.924		0.45	
374		26.30 928.80	5.817 77.222		5.817 43.054			3.0	0.194	0.224	0.017	0.016	0.451	1350	0.30	0.65	0.924		0.49	
375		1,791.70 1,791.70	55.504 1.775		1.775 1.775			4.5	0.012	0.431	0.032	0.031	0.506	750	0.60	0.62	0.272	Insufficient capacity	1.86	
376	374	6.90 2,727.40	29.790 74.619		29.790 74.619			2.5	0.281	0.656	0.049	0.048	1.034	1500	0.25	0.63	1.116		0.93	

Ratio of Design Flow against Capacity			
More than 2.0	From 1.2 to 1.4	From 25 to 50	Peaking Factor
From 1.8 to 2.0	From 1.0 to 1.2	From 50 to 100	3.0
From 1.6 to 1.8	Less than 1.0	More than 100	2.5
From 1.4 to 1.6			2.0

Ratio of Design Flow against Capacity			
More than 2.0	From 1.2 to 1.4	From 25 to 50	Peaking Factor
From 1.8 to 2.0	From 1.0 to 1.2	From 50 to 100	3.0
From 1.6 to 1.8	Less than 1.0	More than 100	2.5
From 1.4 to 1.6			2.0

Sewer No.	Incoming Sewer	Sewerage Area (ha)		Sewer Length (m)	Domestic Wastewater					Point Source			Design	Sewer Line Design				Remarks	Ratio of Design Flow against Capacity
					Unit Generation Rate (LPCD)			Domestic WW Flow (m³/sec)	Industrial WW Flow (m³/sec)	Commercial WW Flow (m³/sec)	I/I of Ground water Flow (m³/sec)	Max. Flow (m³/sec)		Dia. (mm)	Slope (%)	Velocity (m/sec)	Capacity (m³/sec)		
					Population (thousand)	Service Population (thousand)	Peaking Factor												
408		4.50 27.80		278.00	1.010 2.821	1.010 2.821	4.5	0.019	0.007	0.001	0.000	0.027	Ø 825	0.50	0.60	0.321		0.08	
			To Sewer No. 424																
409		27.60 27.60		194.00	8.003 8.003	8.003	4.0	0.048	0.007	0.000	0.000	0.055	Ø 600	0.75	0.60	0.168		0.33	
410		33.10 60.70		327.00	4.915 12.918	4.915	3.5	0.068	0.015	0.001	0.001	0.085	Ø 675	0.65	0.60	0.214		0.40	
411		77.00 14.90		331.00	3.686 16.604	3.686	3.5	0.087	0.019	0.001	0.001	0.108	Ø 675	0.65	0.60	0.214		0.51	
412		91.90 2.00		184.00	3.686 20.290	3.686	3.5	0.107	0.022	0.002	0.002	0.133	Ø 675	0.65	0.60	0.214		0.62	
413		93.90 2.00		165.00	0.000 20.290	0.000	3.5	0.107	0.023	0.002	0.002	0.134	Ø 825	0.50	0.60	0.321		0.42	
			To Sewer No. 418																
414		2.50 2.50		153.00	4.818 4.818	4.818	4.5	0.033	0.001	0.000	0.000	0.034	Ø 600	0.75	0.60	0.168		0.20	
			To Sewer No. 416																
415		26.60 26.60		533.00	7.082 7.082	7.082	4.0	0.043	0.006	0.000	0.000	0.049	Ø 525	0.90	0.60	0.129		0.38	
416	414	29.30 31.70		73.00	0.000 11.900	0.000	3.5	0.063	0.007	0.001	0.001	0.072	Ø 600	0.75	0.60	0.168		0.43	
417		61.00		643.00	6.863 18.762	6.863	3.5	0.099	0.015	0.001	0.001	0.116	Ø 750	0.60	0.62	0.272		0.43	
418	413	0.70 155.60		148.00	0.000 39.053	0.000	3.0	0.176	0.037	0.003	0.003	0.219	Ø 825	0.50	0.60	0.321		0.68	
419		65.50 221.10		423.00	11.008 50.060	11.008	2.5	0.188	0.053	0.004	0.004	0.249	Ø 1050	0.40	0.63	0.546		0.46	
420		2.70 223.80		154.00	0.000 50.060	0.000	2.5	0.188	0.054	0.004	0.004	0.250	Ø 1200	0.30	0.60	0.675		0.37	
			To Sewer No. 424																
421		40.80 40.80		637.00	7.128 7.128	7.128	4.0	0.043	0.010	0.001	0.001	0.055	Ø 675	0.65	0.60	0.214		0.26	
422		2.50 43.30		205.00	1.010 8.138	1.010	4.0	0.049	0.010	0.001	0.001	0.061	Ø 600	0.75	0.60	0.168		0.36	
423		15.30 58.60		303.00	3.029 11.167	3.029	3.5	0.059	0.014	0.001	0.001	0.075	Ø 675	0.65	0.60	0.214		0.35	
424	408 420	0.50 310.70		109.00	0.000 64.049	0.000	2.5	0.241	0.075	0.006	0.005	0.327	Ø 1200	0.30	0.60	0.675		0.48	
			To EP7																
					D-Type (OP/S) 23.8 m³/min=0.396m³/s Insufficient capacity Sewer No. 405+42= 0.411														

Ratio of Design Flow against Capacity									
More than 2.0				From 1.2 to 1.4					
From 1.8 to 2.0				From 1.0 to 1.2					
From 1.6 to 1.8				Less than 1.0					
From 1.4 to 1.6									

Sewer No.	Sewerage Area (ha)	Sewer Length (m)	Domestic Wastewater						Point Source				Design	Sewer Line Design				Remarks	Ratio of Design Flow against Capacity
			Unit Generation Rate (LPCD)			Peaking Factor	Domestic WW Flow (m³/sec)	Industrial WW Flow (m³/sec)	Commercial WW Flow (m³/sec)	I/I of Ground water Flow (m³/sec)	Max. Flow (m³/sec)	Dia. (mm)		Slope (%)	Velocity (m/sec)	Capacity (m³/sec)			
			Population (thousand)	Service Population (thousand)	Total														
																	Increment		
425		359.00	51.90	7.651	7.651	4.0	0.046	0.012	0.001	0.001	0.060	525	0.90	0.60	0.129	0.47			
			51.90	7.651															
426		243.00	6.50	1.010	1.010	4.0	0.052	0.014	0.001	0.001	0.068	600	0.75	0.60	0.168	0.41			
			58.40	8.661															
427		331.00	5.20	0.000	0.000	4.0	0.052	0.015	0.001	0.001	0.069	675	0.65	0.60	0.214	0.32			
			63.60	8.661															
428		676.00	7.10	1.010	1.010	4.0	0.058	0.017	0.001	0.001	0.077	1350	0.30	0.65	0.924	0.08			
			70.70	9.671															
429		334.00	2.20	0.176	0.176	4.0	0.059	0.018	0.001	0.001	0.079	1350	0.30	0.65	0.924	0.09			
			72.90	9.847															
			To Sewer No. 431																
430		138.00	20.80	0.956	0.956	4.5	0.006	0.005	0.000	0.000	0.011	525	0.90	0.60	0.129	0.09			
			20.80	0.956															
431	429	805.00	8.90	0.352	0.352	3.5	0.059	0.025	0.002	0.002	0.088	1350	0.30	0.65	0.924	0.09			
			102.60	11.156															
432		254.00	7.20	0.257	0.257	3.5	0.060	0.026	0.002	0.002	0.090	1350	0.30	0.65	0.924	0.10			
			109.80	11.413															
			To EP3																
433		129.00	108.00	5.132	2.904	4.5	0.020	0.026	0.002	0.002	0.050	600	0.75	0.60	0.168	0.30			
			108.00	5.132	2.904														
434		194.00	2.10	1.580	1.580	4.5	0.030	0.026	0.002	0.002	0.060	600	0.75	0.60	0.168	0.36			
			110.10	6.712															
			To EP5 and discharge to Sewer No. 438																
435		838.00	10.80	0.557	0.557	4.5	0.004	0.003	0.000	0.000	0.007	600	0.75	0.60	0.168	0.04			
			10.80	0.557	0.557														
436		324.00	83.20	23.572	23.572	3.5	0.127	0.023	0.002	0.002	0.154	600	0.75	0.60	0.168	0.92			
			94.00	24.129	24.129														
437		417.00	4.20	0.000	0.000	3.5	0.127	0.024	0.002	0.002	0.155	675	0.65	0.60	0.214	0.72			
			98.20	24.129	24.129														
			To EP5 and discharge to Sewer No. 438								Sewer No. 434+437 = 0.215								
438	434	261.00	8.70	0.081	0.081	3.0	0.130	0.052	0.004	0.004	0.190	675	0.65	0.60	0.214	0.88			
	437		217.00	30.922	28.694														
439		311.00	11.40	3.160	3.160	3.0	0.144	0.055	0.004	0.004	0.207	675	0.65	0.60	0.214	0.97			
			228.40	34.082	31.854														
440		935.00	266.40	23.749	23.749	2.5	0.209	0.119	0.009	0.009	0.346	750	0.60	0.62	0.272	Insufficient capacity			
			494.80	57.831	55.603														
			To Sewer No. 445																

Ratio of Design Flow against Capacity			
More than 2.0	From 1.2 to 1.4		
From 1.8 to 2.0	From 1.0 to 1.2		
From 1.6 to 1.8	Less than 1.0		
From 1.4 to 1.6			

Ratio of Design Flow against Capacity			
More than 2.0	From 1.2 to 1.4		
From 1.8 to 2.0	From 1.0 to 1.2		
From 1.6 to 1.8	Less than 1.0		
From 1.4 to 1.6			

Population (x10 ³)		Peaking Factor	Peaking Factor
Up to 5	From 25 to 50	4.5	3.0
From 5 to 10	From 50 to 100	4.0	2.5
From 10 to 25	More than 100	3.5	2.0

Sewer No.	Incoming Sewer	Sewerage Area (ha)		Sewer Length (m)	Domestic Wastewater					Point Source				Design	Sewer Line Design				Remarks	Ratio of Design Flow against Capacity
					Unit Generation Rate (LPCD)			Domestic WW Flow (m³/sec)	Industrial WW Flow (m³/sec)	Commercial WW Flow (m³/sec)	I/I of Ground water Flow (m³/sec)	Max. Flow (m³/sec)	Dia. (mm)		Slope (%)	Velocity (m/sec)	Capacity (m³/sec)			
					Population (thousand)	Service Population (thousand)	Peaking Factor													
		Increment	Total		Increment	Total	Increment	Total	Increment	Total	Increment	Total	Increment	Total	Increment	Total	Increment	Total		
441		39.30 39.30	1,018.00	7,270 7,270	7,270 7,270	4.0	0.044		0.009	0.001	0.001	0.055	600	0.75	0.60	0.168		0.33		
		To Sewer No. 445																		
442		71.90 71.90	649.00	3,422 3,422	1,470 1,470	4.5	0.010		0.017	0.001	0.001	0.029	525	0.90	0.60	0.129		0.22		
443		3.30 75.20	364.00	1,454 4,876	1,454 2,924	4.5	0.020		0.018	0.001	0.001	0.040	600	0.75	0.60	0.168		0.24		
		To Sewer No. 445																		
444		66.70 66.70	193.00	4,339 4,339	4,339 4,339	4.5	0.029		0.016	0.001	0.001	0.047	525	0.90	0.60	0.129		0.37		
445		441 678.60	377.00	2,600 75,769	1,454 71,590	2.5	0.269		0.163	0.012	0.012	0.456	750	0.60	0.62	0.272		1.68		
		To Sewer No. 450																		
446		48.40 48.40	270.00	6,163 6,163	6,163 6,163	4.0	0.037		0.012	0.001	0.001	0.051	600	0.75	0.60	0.168		0.30		
		To Sewer No. 448																		
447		8.70 8.70	358.00	0,490 0,490	0,490 0,490	4.5	0.003		0.002	0.000	0.000	0.005	600	0.75	0.60	0.168		0.03		
448	446	8.50 65.60	343.00	0,279 6,931	0,279 6,932	4.0	0.042		0.016	0.001	0.001	0.060	600	0.75	0.60	0.168		0.36		
449		45.90 111.50	2,151.00	9,312 16,243	9,312 16,244	3.5	0.086		0.027	0.002	0.002	0.117	675	0.65	0.60	0.214		0.54		
450	445	18.20 808.30	1,005.00	4,115 96,127	4,115 91,949	2.5	0.346		0.195	0.015	0.014	0.570	750	0.60	0.62	0.272		2.09		
		To Sewer No. 453																		
451		0.00 0.00	193.00	0,000 0,000	0,000 0,000	4.5	0.000		0.000	0.000	0.000	0.000	525	0.90	0.60	0.129		0.00		
452		139.10 139.10	129.00	2,735 2,735	2,735 2,735	4.5	0.019		0.033	0.003	0.002	0.057	825	0.50	0.60	0.321		0.18		
453	450	0.00 947.40	310.00	0,000 98,862	0,000 94,684	2.5	0.356		0.228	0.017	0.017	0.618	825	0.50	0.60	0.321	Insufficient capacity	1.93		
454		129.90 1,077.30	668.00	5,589 104,451	4,769 99,453	2.5	0.374		0.259	0.019	0.019	0.671	1200	0.30	0.60	0.675		0.99		
455		12.10 1,089.40	336.00	1,370 105,821	1,370 100,823	2.0	0.303		0.262	0.020	0.019	0.604	1350	0.30	0.65	0.924		0.65		
		To Sewer No. 457																		
456		7.70 7.70	178.00	0,000 0,000	0,000 0,000	4.5	0.000		0.002	0.000	0.000	0.002	675	0.65	0.60	0.214		0.01		
457	455	60.60 1,157.70	674.00	1,050 106,871	0,851 101,674	2.0	0.306		0.279	0.021	0.020	0.626	1350	0.30	0.65	0.924		0.68		

Ratio of Design Flow against Capacity			
More than 2.0	From 1.2 to 1.4	Population (x10 ³)	Peaking Factor
From 1.8 to 2.0	From 1.0 to 1.2	Up to 5	4.5
From 1.6 to 1.8	Less than 1.0	From 5 to 10	4.0
From 1.4 to 1.6		From 10 to 25	3.5
			3.0
			2.5
			2.0

Ratio of Design Flow against Capacity			
More than 2.0	From 1.2 to 1.4	Population (x10 ³)	Peaking Factor
From 1.8 to 2.0	From 1.0 to 1.2	Up to 5	4.5
From 1.6 to 1.8	Less than 1.0	From 5 to 10	4.0
From 1.4 to 1.6		From 10 to 25	3.5
			3.0
			2.5
			2.0

Sewer No.	Sewerage Area (ha)		Sewer Length	Domestic Wastewater					Point Source			Design	Sewer Line Design				Remarks	Ratio of Design Flow against Capacity
				Unit Generation Rate (LPCD)				130	Industrial WW Flow (m³/sec)	Commercial WW Flow (m³/sec)	I/I of Ground water Flow (m³/sec)							
				Population (thousand)		Service Population (thousand)							Peaking Factor	Domestic WW Flow (m³/sec)				
	Increment	Total		Increment	Total	Increment	Total	Increment	Total	Max. Flow (m³/sec)	Dia. (mm)	Slope (%)			Velocity (m/sec)	Capacity (m³/sec)		
458	8.80	1,166.50	197.00	0.121	0.081	101.755	2.0	0.306	0.281	0.021	0.020	0.628	1350	0.30	0.65	0.924	0.68	
		To EP3		PS-36(OP/S) 135.9 m³/min=2,265 m³/s					Sewer No. 432+438 = 0.718									
459	70.30	70.30	659.00	0.863	0.863	0.863	4.5	0.006	0.017	0.001	0.001	0.025	525	0.90	0.60	0.129	0.19	
460	23.40	93.70	487.00	0.345	0.345	1.208	4.5	0.008	0.023	0.002	0.002	0.035	525	0.90	0.60	0.129	0.27	
461	0.00	93.70	393.00	0.000	0.000	1.208	4.5	0.008	0.023	0.002	0.002	0.035	600	0.75	0.60	0.168	0.21	
		To EP12		Sitara Colony(OP/S)														
EP11	17.30	17.30		2.001	2.001	2.001	4.5	0.014	0.004	0.000	0.000	0.018	300	2.00	0.61	0.043	0.41	
				Jhal Khumana(LP/S) 6.8 m³/min=0.113 m³/s												Because no sewer data available, pumping scheme is assumed.		
				the upper area (17.3 ha) covered by Sewer No. 302: total area of 62.10 ha, population of 7,184.														
				The service population in the upper area is estimated as 2,001 (=7,184×17.3/62.1).														

AC3.2 General Plan of Present Sewer System


The existing sewers in the western zone and in the eastern zones are shown in the following drawings, the lists of drawings are summarized in the following table.


Table AC3.2.1 General Plan of the Present Sewer System in the Western Zone


Drawing No.	Contents
SD-P- 001	Key Plan of Existing Sewer in the Western Zone
SD-P- 002	General Plan of Existing Sewers in the Western Zone (1/8)
SD-P- 003	General Plan of Existing Sewers in the Western Zone (2/8)
SD-P- 004	General Plan of Existing Sewers in the Western Zone (3/8)
SD-P- 005	General Plan of Existing Sewers in the Western Zone (4/8)
SD-P- 006	General Plan of Existing Sewers in the Western Zone (5/8)
SD-P- 007	General Plan of Existing Sewers in the Western Zone (6/8)
SD-P- 008	General Plan of Existing Sewers in the Western Zone (7/8)
SD-P- 009	General Plan of Existing Sewers in the Western Zone (8/8)

Table AC3.2.2 General Plan of the Present Sewer System in the Eastern Zone

Drawing No.	Contents
SD-P- 010	Key Plan of Existing Sewer in the Eastern Zone
SD-P- 011	General Plan of Existing Sewers in the Eastern Zone (1/7)
SD-P- 012	General Plan of Existing Sewers in the Eastern Zone (2/7)
SD-P- 013	General Plan of Existing Sewers in the Eastern Zone (3/7)
SD-P- 014	General Plan of Existing Sewers in the Eastern Zone (4/7)
SD-P- 015	General Plan of Existing Sewers in the Eastern Zone (5/7)
SD-P- 016	General Plan of Existing Sewers in the Eastern Zone (6/7)
SD-P- 017	General Plan of Existing Sewers in the Eastern Zone (7/7)










DRAWING NO.:
SD-P-003

TITLE:
General Plan of Existing Sewer in the Western Zone (2/8)

PROJECT:
THE PROJECT FOR WATER SUPPLY, SEWERAGE AND DRAINAGE MASTER PLAN
OF FAISALABAD IN ISLAMIC REPUBLIC OF PAKISTAN









DRAWING NO.:
SD-P-006

TITLE:
General Plan of Existing Sewer in the Western Zone (5/8)

PROJECT:
THE PROJECT FOR WATER SUPPLY, SEWERAGE AND DRAINAGE MASTER PLAN
OF FAISALABAD IN ISLAMIC REPUBLIC OF PAKISTAN






DRAWING NO.:
SD-P-008


TITLE:
General Plan of Existing Sewer in the Western Zone (7/8)


PROJECT:
THE PROJECT FOR WATER SUPPLY, SEWERAGE AND DRAINAGE MASTER PLAN
OF FAISALABAD IN ISLAMIC REPUBLIC OF PAKISTAN

2 kilometers

Chak
No. 225
Majhanwala
0.5










DRAWING NO.:
SD-P-011


TITLE:
General Plan of Existing Sewer in the Eastern Zone (1/7)

PROJECT:
THE PROJECT FOR WATER SUPPLY, SEWERAGE AND DRAINAGE MASTER PLAN
OF FAISALABAD IN ISLAMIC REPUBLIC OF PAKISTAN









PROJECT: THE PROJECT FOR WATER SUPPLY, SEWERAGE AND DRAINAGE MASTER PLAN OF FAISALABAD IN ISLAMIC REPUBLIC OF PAKISTAN	TITLE:	General Plan of Existing Sewer in the Eastern Zone (6/7)
DRAWING NO.:		SD-P-016

