

**CHAPTER 7 Transmission Network
Development Plan**

Chapter 7 Transmission network development plan

7-1 Outline of Transmission Network in Nigeria

7-1-1 Geographical Structure of the Transmission Company of Nigeria (TCN)

TCN has created eight Transmission Planning Regions for better planning.

The actual regions under the field and maintenance services sector are shown in Figure 7-1.1. Since new regions, Abuja Region (FCT (Abuja), Nasarawa and Kogi states) were settled in July, 2018, there are currently nine Transmission Planning Regions.



Source: TCN

Figure 7-1.1 Geographical Structure of TCN

The electricity supply to Nigerian consumers is handled by 11 privatized distribution companies, each with its own area, as shown in Figure 7-1.2.



Source: JICA Study Team

Figure 7-1.2 Areas of Distribution Companies in Nigeria

The electricity consumption of the southern DisCos far exceeds their northern equivalents because the former are far more densely populated and most industries are concentrated there.

7-1-2 Existing and Planned Power System and Network Configuration

The two latest maps with the existing, ongoing and planned Nigerian 330 and 132 kV transmission network are shown in Annexes 7.1a and 7.1b (respectively dated January and March, 2018).

The latest version of the single-line diagram of the existing network (dated July, 2016), is shown in Annex 7.1c. TCN has advised that there has not been further updated.

Technical data on transmission lines and transformers is shown in Annexes 7.1d and 7.1e respectively.

The present status of reactors and capacitors installed in the TCN network is summarized in Table 7-1.1 and Table 7-1.2. Introducing additional capacitors, as necessary, takes the status of pre-existing units into consideration, as shown in Table 7-1.2, assuming all faulty and repairable capacitors will, if necessary, be repaired and the others will be commissioned as planned.

Table 7-1.1 Shunt Reactors

S/N	Substation	Voltage (kV)	MX (MVar)	Switchable
1	KANO	330	-75.00	Y
2	GOMBE	330	-50.00	Y
3	GOMBE	330	-50.00	Y
4	YOLA	330	-75.00	Y
5	KADUNA	330	-75.00	Y

S/N	Substation	Voltage (kV)	MX (MVar)	Switchable
6	JOS	330	-75.00	Y
7	JEBBA T.S.	330	-75.00	Y
8	JEBBA T.S.	330	-75.00	Y
9	OSHOGBO	330	-75.00	N
10	BENIN	330	-75.00	Y
11	BENIN	330	-75.00	Y
12	ALAOJI	330	-75.00	Y
13	IKEJA WEST	330	-75.00	Y
14	IKEJA WEST	330	-75.00	Y
15	KATAMPE	330	-75.00	Y
16	MAKURDI	330	-75.00	Y
17	ONITSHA	330	-75.00	Y
18	OKEARO	330	-75.00	Y
19	GOMBE	33	-30.00	Y
20	GOMBE	33	-30.00	Y
21	YOLA	33	-30.00	Y
22	YOLA	33	-30.00	Y

Source: JICA Study Team

Table 7-1.2 Fixed capacitors

S/N	Substation	Voltage (kV)	Capacitor (MVar)	Status	Planned Action
1	Kumbotso	330	50	In operation	
2	Kumbotso	330	50	In operation	
3	Akangba A	132	72	Installed but not commissioned yet	To be commissioned
4	Akangba B	33	24	Installed but not commissioned yet	To be commissioned
5	Akoka	33	24	Installed but not commissioned yet	To be commissioned
6	Alausa	33	24	Installed but not commissioned yet	To be commissioned
7	Alimoso	33	24	Installed but not commissioned yet	To be commissioned
8	Ejigbo	33	24	Installed but not commissioned yet	To be commissioned
9	Ijoro	33	24	Installed but not commissioned yet	To be commissioned
10	Isolo	33	24	Installed but not commissioned yet	To be commissioned
11	Ogba	33	24	Installed but not commissioned yet	To be commissioned
12	Otta	33	24	Installed but not commissioned yet	To be commissioned
13	Yandev	33	20	Installed but not commissioned yet	To be commissioned
14	Ikorodu	33	20	Faulty, mainly due to CB fault	Can be repaired
15	Ikorodu	33	20	Faulty, mainly due to CB fault	Can be repaired
16	Abeokuta	33	20	Faulty, mainly due to CB fault	Can be repaired
17	Abeokuta	33	20	Faulty, mainly due to CB fault	Can be repaired
18	Iseyin	33	20	Faulty, mainly due to CB fault	Can be repaired
19	Aiyede	33	20	Faulty, mainly due to CB fault	Can be repaired
20	Aiyede	33	20	Faulty, mainly due to CB fault	Can be repaired
21	Agbara	33	20	Commissioned, can be switched on	
22	Ijebuode	33	20	Commissioned, can be switched on	
23	Sagamu	33	20	Commissioned, can be switched on	
24	Irua	33	20	Faulty, mainly due to CB fault	Can be repaired
25	Ilorin	33	20	Faulty, mainly due to CB fault	Can be repaired
26	Akure	33	20	Faulty, mainly due to CB fault	Can be repaired
27	Awka	33	20	Faulty, mainly due to CB fault	Can be repaired
28	Uyo	33	20	Faulty, mainly due to CB fault	Can be repaired
29	Effurum	33	20	Faulty, mainly due to CB fault	Can be repaired

S/N	Substation	Voltage (kV)	Capacitor (MVar)	Status	Planned Action
30	Amkpe	33	20	Faulty, mainly due to CB fault	Can be repaired
31	Akwanga	33	20	Faulty, mainly due to CB fault	Can be repaired
32	Akwanga	33	20	Faulty, mainly due to CB fault	Can be repaired
33	Minna	33	20	Faulty, mainly due to CB fault	Can be repaired
34	Minna	33	20	Faulty, mainly due to CB fault	Can be repaired
35	Kontagora	33	20	Faulty, mainly due to CB fault	Can be repaired
36	Kontagora	33	20	Faulty, mainly due to CB fault	Can be repaired
37	Zaria	33	20	Faulty, mainly due to CB fault	Can be repaired
38	Zaria	33	20	Faulty, mainly due to CB fault	Can be repaired
39	Kaduna Town	33	20	Faulty, mainly due to CB fault	Can be repaired
40	Kaduna Town	33	20	Faulty, mainly due to CB fault	Can be repaired
41	Dakata	33	20	Faulty, mainly due to CB fault	Can be repaired
42	Dakata	33	20	Faulty, mainly due to CB fault	Can be repaired
43	Apir	33	20	Faulty, mainly due to CB fault	Can be repaired
44	Kumbotso	33	20	Installed but not commissioned yet	To be commissioned
45	Okene	33	20	Installed but not commissioned yet	To be commissioned
46	Dan-Agundi	33	20	Installed but not commissioned yet	To be commissioned
47	Katsina	33	20	Installed but not commissioned yet	To be commissioned
48	Ife	33	20	Installed but not commissioned yet	To be commissioned
49	Ayede	33	20	Installed but not commissioned yet	To be commissioned
50	Ijebu-Ode	33	20	Installed but not commissioned yet	To be commissioned
51	Shagamu	33	20	Installed but not commissioned yet	To be commissioned
52	Iseyin	33	20	Installed but not commissioned yet	To be commissioned
53	Ilorin	33	20	Installed but not commissioned yet	To be commissioned
54	Akure	33	20	Installed but not commissioned yet	To be commissioned
55	Apo	33	20	Installed but not commissioned yet	To be commissioned
56	Apo	33	20	Installed but not commissioned yet	To be commissioned

Source: JICA Study Team

7-1-3 Operating Frequency and Voltage Limits

In accordance with the Grid Code and to maintain the security and integrity of the transmission system, it is necessary that the System Operator operate and dispatch the transmission system in such a manner as to provide adequate frequency control and achieve operation within applicable frequency limits at all times.

The nominal system frequency shall be 50 Hz. The National Control Center endeavors to control this to within a narrow operating band of +/- 0.5% from 50 Hz (49.75 – 50.25 Hz), but under system stress the frequency on the power system may vary within the limits of 50 Hz +/- 2.5% (48.75 – 51.25 Hz).

The nominal voltage levels of the transmission and distribution system are 330, 132, 66, 33 and 11 kV respectively. Under normal operation, the limits of the 330 and 132 kV systems are 0.85-1.05 and 0.85-1.10 pu respectively. Under contingency conditions the emergency limits for the same are 0.80-1.10 and 0.80-1.15 pu.

7-1-4 System Peak Demand and Generation

7-1-4-1 Development of Peak Output and Energy Generated

The installed capacity (less de-commissioned units) in the grid as of December, 2016 was 12,310 MW. In 2016, the plant average MW availability was 7,877 MW, which was 23.07% higher than the 6,401 MW obtained in 2015. The Thermal Station average MW availability contribution was 6,669 MW – exceeding the, 2015 figure of 5,312 MW by 25.53%. The Hydro Station average MW availability was 1208 MW, which exceeded the, 2015 figure of 1,088 MW by 120 MW (11.07%). The maximum daily energy of 109,372 MWh occurred on 2 February, 2016, exceeding the maximum daily energy of 106,825 MWh recorded on 24 November, 2015 by 2,546 MWh (2.38%). The peak generation of 5,074 MW. which was attained on 2 February, 2016 exceeds the peak generation of 4,883 MW recorded on 23 November, 2015 by 190 MW (3.91%).

Peak output of power stations depends on the availability of generation units, water inflow for hydro power plants and gas supply for thermal power plants and not on actual demand. Demand is always much higher than the available generation capacity.

NCC daily operational report on 08.12.2015 shows a Peak Demand Forecast (connected + suppressed load) of 14,630 MW.

The peak generation of 5,074 MW, which was attained on 2 February, 2016 exceeded the peak generation of 4,883 MW recorded on 23 November, 2015 by 190 MW (3.91%).”

In general, only approximately 40% of the estimated demand could be supplied.


NCC’s operational reports show that many generation units are not in operation due to the unavailability of gas. On December 8, 2015 for example, about 1,500 MW of generation capacity were was offline for this reason. The gas supply was interrupted due to sabotage of the pipeline system.

7-1-4-2 Transition of Energy Generation and Peak Demand

Records on annual energy generated and simultaneous national peak demand of electricity show permanent growth with two periods of stagnation/decline.


Figure 7-1.3 and Figure 7-1.4 indicate that periods of stagnation/decline of energy generation and peak demand were offset rapidly in the following years.

Between 1973 and 2016, peak generation increased from 385 to 5,074 MW, i.e. with an average growth rate of about 6.2%. During the same period the annual energy generated increased from 2,493 to 28,412 GWh, i.e. with an average growth rate of about 6%.



Source: TCN Annual Report, 2016

Figure 7-1.3 Annual Energy Generated



Source: TCN Annual Report, 2016

Figure 7-1.4 National Peak

7-1-4-3 Transmission Losses

The overall transmission losses and substation consumptions amounted to 9.92% of the energy sent out in 2016, as shown in Table 7-1.3. The losses in 2016 were lower than the previous year, signifying a steady decline over the past three years.

Table 7-1.3 Energy balance summary (Dec-Jan, 2016)

Energy generated (MWh)	Energy sent out (MWh)	Energy available for sales, incl distr losses (MWh)	Transformer losses and substations consumption (MWh)	Transformer losses and substations consumption (% of energy sent out)	Energy available for sales and distr losses (% of energy)
28,532	28,033	25,251	27,821	9.92	90.08

Source: JICA Study Team

7-1-4-4 Existing Generation and Generation Expansion

Based on information provided, the already installed gross power generation capacity is about 13,300 MW, of which some 11,800 MW are noted as net available capacity.

Considering the latest information provided by generating companies, about 9,500 MW (80%) of this capacity should have been available at the end of the year, 2015. However, only 5,900 MW net capacity has been made available, as reflected in the statistics of the National Control Center (NCC).

The reasons for the unavailability include: planned outages for maintenance or forced outages due to technical deficiencies of assets, as well as unplanned unavailability due to fuel supply shortages or sabotage of gas pipelines.

A further analysis of information provided shows that about 20% of the installed generation capacity is based on plants which are 25 or more years old, some of which have efficiency of under 30%.

It is obvious that most of the old thermal power plants are - or will be – subject to more frequent forced outages or long- term planned maintenance outages in the near future. Accordingly, they should be replaced by new and more efficient facilities.

Together with TCN, it was agreed that all existing power plant units not being currently available should be made available by 2020 at the latest, even if currently unavailable for technical reasons.

The Master Plan shows a program for step-by-step modernization of these plants in parallel to implementing new units at existing sites, as well as completely new power plants.

It further shows technical data for all existing and new generation facilities and the respective implementation timetable. Newly proposed power plants are considering diversification of primary energy sources in the form of solar/wind/hydro technology, as well as modern gas- and coal-fired thermal plants.

Installation of new assets will follow the assumed increasing power demand, as well as the need for replacement of existing power generation assets.

7-1-4-5 Daily Load Curve

Electrical power demand in Nigeria peaks in the evening, between 20:00 and 23:00 hours, while power demand is lowest in the early morning between 03:00 and 05:00 hours.




Figure 7-1.5 Daily Load Curve on 1 October, 2014

7-1-5 Difficulties and Challenges Faced by TCN

7-1-5-1 General

The electric power system of Nigeria has long suffered from a lack of generation capacity which requires permanent load shedding. Furthermore, frequent transmission and distribution system disturbances exacerbate the unreliability of the power system.

The main reasons for power shortages are outages of generation units and a lack of gas to generate power. The gas supply is frequently interrupted due to the pipeline network being sabotaged.

The main concern for the future expansion of generation, however, is the availability of gas for additional generation capacity and the expansion of the gas pipeline network. Currently, most power plants are installed in southern Nigeria close to oil and gas fields. To ensure a reliable and optimally expanded transmission system, there will be a need to install new power plants also elsewhere in Nigeria.

There are some plans for new hydro power plants, while photovoltaic and wind power plants are also under consideration.

However, to provide sufficient base load power in future, large coal-fired power plants may have to be

included in the generation expansion program.

In terms of generation and load balance in the eight TCN planning regions, four or five have a significant generation deficit. With the exception of Benin and Port Harcourt regions, demand exceeds available generation power in all others. In the Shiroro region however, the situation will be reversed once new HPP plants (e.g. Zugeru) come into operation.

The reason for this imbalance is due to the generation being mainly concentrated in South (thermal stations in Port Harcourt, Enugu, Benin and Lagos) and Central West (hydro stations of Jebba, Kainji and Shiroro in Shiroro region). The Central, North and North-East in particular are characterized by the total absence of generating stations, while load demand is mainly in the South and South-West.

To supply power in areas with little or no generation such as the North-East, long 330 kV transmission lines are built (radial system), which means voltage regulation problems may occur and the reactive power flowing through them necessitates large reactive power compensation equipment (reactors) at the corresponding substations (Kano, Gombe, Maiduguri).

Additional 330 kV lines running in parallel are expected to exacerbate overvoltage issues, necessitating additional compensation equipment at Yola, Jalingo and other substations.

7-1-5-2 Frequency Control

The Grid Code frequency range is 50 Hz + 0.50%, i.e. 49.75 to 50.25 Hz (Grid Code chapter 4 Section 15.3.1), however due to the low availability of units on free governor control coupled with serious demand/generation imbalance, it was practically difficult to maintain and only Omotosho gas and NIPP and Olorunsogo gas units that were on free governor at one point or the other in recent years.

NCC was therefore constrained on numerous occasions to operate the grid outside the statutory frequency limits.

The frequency fluctuations which are mostly due to load rejection by DisCos and volatile loads from steel mills create harmonics and cause voltage flickering within the system. Most of the UFLS relay schemes installed in some substations to mitigate the impact of system collapses were not functional most of the time, which is why the characteristically strenuous manual frequency control technique, achieved through load shedding, defined year-round operations.

7-1-5-3 Voltage Control

In 2016, the voltage limits specified by the Grid Code were achieved largely on the upper voltage limit. The lower voltage limit meanwhile, formally experienced in the northern axis of the grid and plagued by voltage instability/decay, has been improved by installing capacity banks at Kano T.S. The AVR's of some GenCos are not functional.

7-1-5-4 Transmission Constraints

Transmission is plagued with incessant tripping of transmission lines, improper relay coordination, line

limitation, ageing lines and inability to satisfy the N-1 contingency.

Transformers loaded to 100% and above of their rating require very urgent attention. Circumstances where some have to be loaded for hours above 100% reflects the urgent need to reinforce affected transformer banks.

7-1-5-5 Power Pool With Neighboring Countries

The sphere of operations of the Transmission Company of Nigeria transcends the geographical landscape of the country; the Republics of Niger and Benin are interconnected with the Nigerian transmission network.

The energy supplied to Benin Republic in 2016 was 1,275 GWH, signifying a decrease of 16.95% when compared with the 2015 figure of 1,535 GWH. The Republic of Niger was furnished with energy of 666 GWH in 2016, which is lower than the 2015 supply of 692 by 3.77% (ref. Table 7-1.4). These values represent only energy delivered through the 132kV transmission lines only. A fraction of the total supply to that country was through some 33kV distribution feeders.

Table 7-1.4 Cross-border electricity transactions (MWH)

Month	BENIN REPUBLIC		NIGER REPUBLIC	
	2016	2015		2016
JANUARY	139,232	131,851	JANUARY	139,232
FEBRUARY	137,028	128,821	FEBRUARY	137,028
MARCH	117,525	133,755	MARCH	117,525
APRIL	104,796	134,685	APRIL	104,796
MAY	86,139	111,132	MAY	86,139
JUNE	63,542	125,313	JUNE	63,542
JULY	88,775	114,134	JULY	88,775
AUGUST	97,162	133,044	AUGUST	97,162
SEPTEMBER	85,785	120,276	SEPTEMBER	85,785
OCTOBER	122,435	137,372	OCTOBER	122,435
NOVEMBER	116,345	137,028	NOVEMBER	116,345
DECEMBER	116,487	128,131	DECEMBER	116,487
TOTAL	1,275,251	1,535,542	TOTAL	1,275,251
AVERAGE	106,271	127,962	AVERAGE	106,271

Source: JICA Study Team

7-2 Ongoing Projects

7-2-1 Contents of Projects

In July 2018, the JICA study team received two updated lists of recently completed and ongoing projects from TCN:

- One list with TCN projects and
- One list with NIPP projects.

These are included in Annexes 7.2a and 7.2b respectively.

While executing the Transmission Expansion Plan Study, it was agreed with TCN that as a basis for preparing the plan, we will assume that all ongoing projects will be completed by 2020.

Based on this network configuration, power system studies to identify further transmission system expansions between 2020 and 2040 were carried out.

The challenging nature of implementing transmission projects identified in the Transmission Expansion Plan by 2020 is acknowledged, given that it takes a minimum of three years from now to implement such projects (one year to prepare tender documents and select the implementation contractor and two years for project implementation). Accordingly, projects that may not be completed by 2020 should be prioritized for completion as soon as possible after 2020.

The TCN and NIPP projects that are expected to be implemented by 2020 have been included in the new PSS/E case for 2020. They are listed in Annexes 7.2a and 7.2b and the PSS/E case has also been modified to include the decisions made, following an exchange of dialog between TCN and the JICA study team.

7-2-2 Donors Assistance and Prospective Donors

7-2-2-1 Inclusion of TCN, NIPP, JICA and AFD projects

Annexes 7.2c and 7.2d show the 330 kV network configurations in the Lagos region including the projects that will be implemented under JICA financing. Furthermore, the following ongoing projects financed by AFD (Agence Française de Développement) for Abuja area have been considered:

New transmission lines:

- 142km of new 330 kV Double-Circuit line from Lafia 330 kV Substation (new) to New Apo 330/132/33 kV Substation.
- 7km of new 132 kV Double-Circuit line from New Apo 330/132/33 kV substation to Old Apo 132/33 kV substation
- 35km of new 132 kV Double-Circuit line from New Apo 330/132/33 kV substation to the new Kuje132/33 kV substation
- 29km of new 132 kV Double-Circuit line from the proposed Kuje 132/33 kV Substation to West Main (Lugbe) 330/132/33V substation.

New substations:

- 330/132/33 kV substation at New Apo
- 132 kV line bay extension at Old Apo 132 kV SS
- 330/132/33 kV substation at WestMain (Lugbe)
- 132/33 kV substation at Kuje to be equipped with 3 × No. 60MVA
- 132/33 kV Substation at Wumba/Lokogomato
- 132/33 kV GIS substation at Gwarimpa

7-2-2-2 Additional Transmission System Expansions and Rehabilitation Measures Proposed by TCN

In the latest Transmission Expansion Plan submitted to TCN in December 2017, TCN has requested the inclusion of additional transmission system expansions and rehabilitation/reinforcement measures which have been identified by TCN. Six EXCEL lists have been provided with proposed projects, see Annexes 7.2e1 to 7.2e5.

The annexes also show the costs of the individual measures as estimated by TCN.

TCN plans to implement the measures and finance them via development banks as shown in Table 7-2.1.

Table 7-2.1 Prospective Development Banks Finance

Project	Development Bank	Total Cost (million US\$)
Annex 7.2e1	AFD (French Development Agency - Agence Française de Développement)	170
Annex 7.2e2	JICA (Japan International Cooperation Agency)	To be determined
Annex 7.2e3	AfDB (African Development Bank)	410
Annex 7.2e4	World Bank	486
Annex 7.2e5	AFD (French Development Agency - Agence Française de Développement)	272
Total		1,538

Source: JICA Study Team

There are plans to implement all network expansions and rehabilitation/reinforcement measures as soon as possible, but considerable preparatory work (e.g. feasibility studies, tender documents etc.) is required in most cases. At this stage only implementation of system expansions according to Annex 7.2e1 (AFD-Project) is going-on and commissioning by 2020 may be achievable.

For projects financed by other banks (Annexes 7.2e2 to 7.2e5) implementation between 2020 and 2025 can be considered feasible. Usually about two to three years are required for feasibility studies, environmental impact studies, route survey, preparation of technical specifications and tender documents, bidding, tender evaluation and contracting and arrangement financing agreements. Two to three years can also be assumed for constructing and commissioning the projects.

Table 7-2.2 Main TCN 330 and 132 kV transmission line projects

Area	Region	Location	Description	Voltage (kV)	in operation by
PROPOSED ABUJA TRANSMISSION RING PROJECT (AFD1)					
North-Central	Abuja	New Apo	Construction of about 172km of a new 330 kV Double-Circuit line from Lafia 330 kV Substation (new) to the proposed New Apo 330/132/33 kV Substation.	330	2020
North-Central	Abuja	Old Apo	Construction of about 7km of a new 132 kV Double-Circuit line from New Apo 330/132/33 kV substation to Old Apo 132/33 kV substation:	132	2020
North-Central	Abuja	Old Kuje	Construction of 35km of a new 132 kV Double-Circuit line from New Apo 330/132/33 kV substation to the proposed Kuje 132/33 kV substation.	132	2020
North-Central	Abuja	West Main Lugbe	Construction of 29 km of a new 132 kV Double-Circuit line from the proposed Kuje 132/33 kV Substation to West Main (Lugbe) 330/132/33 V substation.	132	2020
LAGOS/OGUN TRANSMISSION PROJECTS (JICA)					
South-West	Lagos	New Abeokuta (Kobape)	Ejio (Arigbajo) – New Abeokuta (Kobape) 132 kV D/C Transmission Line (37.8km).	132	2022
South-West	Lagos	Ejio (Arigbajo)	Olorunsogo – Ejio (Arigbajo) 330 kV D/C Transmission Line (12.9km).	330	2022
South-West	Lagos	Ikeja West	Ejio (Arigbajo) – Ikeja West/Osogbo 330 kV D/C Turn-in-out (5.9km).	330	2022
South-West	Lagos	Ejio (Arigbajo)	Likosi (Ogijo) - Aribajo D/C Transmission Line (43.7km).	330	2022
South-West	Lagos	Shagamu	132 kV Quad Line (2.3km) from Likosi (Ogijo) – Existing Ikorodu/Shagamu 132 kV 2x D/C Transmission Line	132	2022
South-West	Lagos	Abule Oba (Redeem)	132 kV D/C Transmission Line (10.3km) from Likosi (Ogijo) – Abule Oba (Redeem).	132	2022
South-West	Lagos	Ikeja West	MAKOGI (MFM) – Existing Benin (Omotosho)/Ikeja West 330 kV 2 x D/C Transmission Line (4.2km).	330	2022
South-West	Lagos	Ajgunle (New Agbara)	Ejio (Arigbajo) – Ajgunle (New Agbara) 330 kV D/C Transmission Line (30.6km).	330	2022
South-West	Lagos	Agbara	Ajgunle (New Agbara) – Agbara 132 kV D/C Transmission Line (20.8km).	132	2022
South-West	Lagos	Badagry	Ajgunle (New Agbara) – Badagry 132 kV D/C Transmission Line (34.2km).	132	2022
PROPOSAL FOR NORTH-EAST TRANSMISSION INFRASTRUCTURE PROJECT TO BE FINANCED BY AfDB					
North-East	Bauchi	Maiduguri - Manguno - Marte - Dikwa - Bama	Construction of a new 321km, 132 kV Double-Circuit Line Between Maiduguri - Manguno - Marte - Dikwa -Bama.	132	after 2020
North-East	Bauchi	Maiduguri - Bama - Goza - Gulak	Construction of a new 165km, 132 kV Double-Circuit Line from Maiduguri - Bama - Goza - Gulak.	132	after 2020
North-East	Bauchi	Mayo Belwa - Jada - Ganye	Construction of a new 78km, 132 kV Double-Circuit Line from Mayo Belwa - Jada - Ganye.	132	after 2020
North-East	Bauchi	Biu - BuniYadi - Damaturu	Construction of a new 134km, 132 kV Double-Circuit Line from Biu - BuniYadi - Damaturu.	132	after 2020
North-East	Bauchi	Dambua - Chibok - Uba - Mubi	Construction of a new 130km, 132 kV Double-Circuit Line from Dambua - Chibok - Uba -	132	after 2020

Area	Region	Location	Description	Voltage (kV)	in operation by
			Mubi.		
North-East	Bauchi	Mayo Belwa - Jada - Ganye	Construction of a new 78km, 132 kV Double-Circuit Line from Mayo Belwa - Jada - Ganye.	132	after 2020
North-East	Bauchi	Biu - BuniYadi - Damaturu	Construction of a new 134km, 132 kV Double-Circuit Line from Biu - BuniYadi - Damaturu.	132	after 2020
North-East	Bauchi	Dambua - Chibok - Uba - Mubi	Construction of a new 130km, 132 kV Double-Circuit Line from Dambua - Chibok - Uba - Mubi.	132	after 2020
North-West	Kaduna	Construction of Quad 330 kV on Kaduna-Kano 330 kV Single DC Transmission Line	Construction of Double-Circuit 330 kV Quad Conductor Kaduna-Kano Transmission line.	330	after 2020
North-West	Kaduna	Zaria	Turn-in Turn-out and Installation of 2x150 MVA 330/132/33 kV Transformer, 6x330 kV bay extension, 2x60MVA 132/33 kV Transformer, associated 132 kV line bays and 6 number 33 kV feeder bays at Zaria.	330	after 2020
North-West	Kaduna	Millennium City Kaduna	Turn-in Turn-Out and Installation of 2x150 MVA 330/132/33 kV Transformer, 2 x330 kV bay extension and 2x60MVA 132/33 kV Transformer and 2x3number associated outgoing 33 kV feeders.	330	after 2020
North-West	Kaduna	Rigasa town, Kaduna	Turn-in Turn-out and Installation of 2x60 MVA 132/33 kV Transformer and 5 number outgoing 33 kV feeders.	132	after 2020
North-West	Kaduna	Jaji, Kaduna	Turn-in Turn-out and Installation of 2x60 MVA 132/33 kV Transformer and 6 number outgoing 33 kV feeders.	132	after 2020
South-South	Benin	Reconstruction of Delta to Benin 330 kV Transmission Line	Reconstruction of one of Delta-Benin 330 kV Transmission Line Double-Circuit to Quad Conductor 330 kV Double-Circuit Line.	330	after 2020
South-South	Port Harcourt	Reconstruction of Alaoji to Onitsha 330 kV Transmission Line	Double-Circuit Alaoji-Ihiala-Onitsha to Quad conductor 330 kV transmission line.	330	after 2020
South-South	Ahoda, Gilili and Sapele	Environmental Impact Assessment and Resettlement Action Plan and Payment of Compensation	Double-Circuit (DC) 132 kV Ahoda-Gilli-Gilli DC Transmission Line and 2x60MVA 132/33 kV Transformer at Gilli plus associated 6 number outgoing 33 kV feeders and DC 132 kV Sapele - Odilli DC Transmission Line and 2x60MVA 132/33 kV Transformer at Gilli plus associated 6 number outgoing 33 kV feeders.	132	after 2020
North-East	Bauchi	Environmental Impact Assessment and Resettlement Action Plan and Payment of Compensation	132 kV line and associated substations: Maiduguri-Manguno-Marte-Dikwa-Bama, Maiduguri-Bama-Gwoza; Hadeja-Nguru-Gashua-Damaturu; Biu-Miringa-Buni Yadi-Damaturu; Dambua-Chibok-Askira-Uba-Mubi; Mayo Belwa-Jada-Ganye	132	after 2020
PROPOSED NETAP PACKAGE AS OF 03 APRIL, 2017 - \$486 MILLION					
South-West	Osogbo	Osogbo- Offa -Ganmo - Ilorin	Reconductoring of 150km, 132 kV Line Between Osogbo-Offa/Omuan to Ganmo and Ilorin T.S.	132	2020
South-West	Osogbo	Ayede - Shagamu	Reconstruction and Conversion of SC to Double-Circuit of Ayede -Ajebo-Ishara-Shagamu 132 kV Line (54km) and Creation of Additional Bays 132	132	2020

Area	Region	Location	Description	Voltage (kV)	in operation by
			kV Line Bays at Ayede, Ajebo, Ishara and Shagamu.		
South-West	Osogbo	Osogbo- Ife/Ilesha	Reconstruction and Conversion to Double-Circuit of Osogbo-Ife/Ilesha 132 kV Line (39.21 km) and Osogbo-Ilesha 132 kV Line Tie-Off (22.1km) and Creation of Additional 132 kV Line Bays at Osogbo and Ilesha.	132	2020
South-East	Port Harcourt	AFAM - PH Main	Reconstruction of Existing Double 132 kV Line Circuit to 4 x 132 kV Line Circuit Using the Same Right of Way from AFAM to Port Harcourt Main (37.8km) and Creating Additional 3 x 132 kV Line Bays.	132	2020
South-East	Port Harcourt	PH Main - PH Town	Reconductoring of 132 kV Double-Circuit of Port Harcourt Main to Port Harcourt Town 132 kV Line (6km).	132	2020
North-West	Kaduna	Kumbotso - Hadelja	Reconductoring of Kumbotsho- Hadeji 132 kV Line (165 km).	132	2020
North-West	Kaduna	Kumbotso - Kankia	Reconductoring of Kumbotsho- Kankia 132 kV Line (100 km).	132	2020
South-East	Enugu	Onitsha - Oji River	Reconductoring of Onitsha- Orji 132 kV Line (87km) with Turn-In- Turn-Out Tower at Nibo (Agu Awka) in Awka 132 kV Substation.	132	2020
South-East	Enugu	Alaoji to Aba Town	Reconductoring of Alaoji - Aba Town Double-Circuit 132 kV line (8km) Including Rehabilitation of Two Nos. Towers along the Line.	132	2020
South-South	Benin	Irrua - Benin	Reconductoring of Irrua - Benin 132 kV line (81 km).	132	2020
South-South	Benin	Irrua - Okpila	Reconductoring of Irrua- Okpilai 132 kV line (43 km).	132	2020
South-South	Benin	Okpila - Okene	Reconductoring of Okpilai - Okene 132 kV line (65 km).	132	2020
South-South	Benin	Ajakuta-Okene	Reconductoring of Ajakuta- Okene 132 kV line (60 km).	132	2020
North-East	Bauchi	Gombe-Biu-Damboa-Maiduguri	Reconductoring of the Entire Route Length from Gombe -Dadin Kowa- Biu -Damboa - Maiduguri 132 kV line of 356 km Route Length.	132	2020
NORTHERN CORRIDOR TRANSMISSION PROJECT 2 (AFD2)					
North-West	Shiroro	Kainji - Birnin-Kebbi 330 kV Double-Circuit (DC) Line (310km)	330 kV DC Transmission Line Kainji-Birnin-Kebbi (following the existing ROW of the SC 330 kV line) and 4x 330 kV bay extension at B/ Kebbi and 2 x 330 kV bay extension at Kainji	330	after 2020
North-West	Shiroro	Birnin-Kebbi-Sokoto 330 kV Double-Circuit (DC) Line (130km)	(1) Birnin-Kebbi-Sokoto 330 kV DC Transmission Line on the existing 132 kV Birnin-Kebbi Sokoto ROW and reconducting the existing 132 kV Single-Circuit Birnin-Kebbi Line to double its capacity	330	after 2020
North-West	Kaduna	Katsina-Daura-Gwiwa-Minjibir-Kura (234KM)	Construction of length of 330 kV DC Twin line between Katsina-Daura-Gwiwa-Jogana- Kura.	330	after 2020
North-Central	Shiroro	Lambata (Mina-Suleja Rd)	Turn-in Turn-out Mina - Suleja 132 kV DC and Construction of 1 x 60 MVA 132/33 kV Complete substation.	132	after 2020
North-West	Shiroro	Fakon Sarki-Argungu	Turn-in Turn-Out on Brinin Kebbi-Sokoto 132 kV Line and Construction of 2 x 60MVA 132/33 kV Complete substation.	132	after 2020

Area	Region	Location	Description	Voltage (kV)	in operation by
North-West	Shiroro	Yelwa- Yawuri	Construction of 1 x 60MVA 132/33 kV Complete substation and High-Voltage Switchgears and Associated Equipment.	132	after 2020
North-Central	Shiroro	Birnin Gwari	Construction of 1 x 60MVA 132/33 kV Complete substation and High-Voltage Switchgears and Associated Equipment.	132	after 2020
North-West	Kaduna	Daura-Katsina State	Installation of 2x150MVA 330/132/33 kV Double-Circuit Substation and with associated 132 kV bay extension and Installation of 2x60MVA 132/33 kV transformers, 6number outgoing 33 kV feeder bays.	330	after 2020
North-West	Kaduna	Jogana-Kano	Installation of 2x150MVA 330/132/33 kV Double-Circuit Substation and with associated 132 kV bay extension and Installation of 2x60 MVA 132/33 kV transformers, 6number outgoing 33 kV feeder bays.	330	after 2020
North-West	Shiroro	330 kV Sokoto Transmission Substation	Installation of 2x150 MVA 330/132/33 kV Transformers at Sokoto New 330 Double-Circuit Substation and with associated 132 kV bay extension and Installation of 2 x 60 MVA 132/33 kV transformers, 6 number outgoing 33 kV feeder bays.	330	after 2020
North-Central	Shiroro	Shiroro –Kaduna (Mando) 330 kV Lines 1 & 2 SC Transmission Lines (96km)	Reconstruction and upgrading of two Single-Circuit 330 kV Transmission Lines 1 & 2 from Shiroro PS to Mando (Kaduna) to a two Double-Circuit, Quad conductor Shiroro-Mando (Kaduna) Transmission lines 1 and 2. The line bay extension at Mando and Shiroro.	330	after 2020
North-East	Bauchi	Bauchi 330 kV Transmission Substation (2km)	Turn-in-out of the existing 330 kV SC Jos-Gombe line at Bauchi and installation of 2x150 MVA 330/132/33 kV Transformers with associated 132 kV bay extension and 2 x 60 MVA 132/33 kV transformers, 6 number outgoing 33 kV feeder bays.	330	after 2020

Source: JICA Study Team

Some of these projects are critical to operate the system in 2020 and if a load exceeding 9 GW is to be served adequately, these projects will have to be expedited, targeting completion by 2020 or as soon as possible after 2020.

7-2-2-3 Transmission System Expansions Financed by AFD

A financing agreement is in place to improve the transmission system in the Greater Abuja area.

The transmission system expansions included in the ADF-financed project will strengthen the 330/132 kV system supplying power to the capital Abuja. A new 132 kV Double-Circuit transmission line (172 km) between New Apo 330/132/33 kV Substation and the planned Lafia 330 kV Substation will establish a third infeed to the Abuja 132 kV ring allowing power supply from the power plants in the Delta Area and the planned Mambilla Hydro Power Plant.

These network expansions are planned to be commissioned in 2020, see Table 7-2.2.

A detailed list of the transmission system expansions with their cost as estimated by TCN is shown in Annex 7.2e1. The planned transmission lines and substations are shown in Annex 7.1 on a map of Nigeria.

7-2-2-4 Transmission System Expansions to Be Financed by JICA

To improve the transmission system operation and reliability of the transmission network in the Lagos region, there are plans to install new transmission lines and substations financed by JICA, which is currently preparing a feasibility study.

The planned 330 kV substations Likosi (Ogijo) and Ejio (Arigbajo) will reconfigure the transmission system from single- to Double-Circuit configuration improving rehabilitation during line maintenance and outages. The 330-kV Double-Circuit line to Ejio (Arigbajo) - Ajegunle (New Agbara) and Ajegunle (New Agbara) substation will allow power export to Benin bypassing the heavily loaded Ikeja Substation. The new 132/33 kV substations Abule Oba (Redeem), MAKOGI (MFM) and Badagry will provide additional infeed capacity into the distribution system.

Commissioning of these network expansions is scheduled for 2020, see Table 7-2.2.

Annex 7.2d shows the present network configuration in the Lagos area and the future configuration after commissioning new lines and substations.

A detailed list of the transmission system expansions with their cost as estimated by TCN is shown in Annex 7.2e2.

7-2-2-5 Transmission System Expansions to Be Financed by AfDB

The transmission system in the North-East of Nigeria is not well developed. Many north-eastern cities are not yet connected to the transmission system and rely on local generation only.

To improve the electricity supply from the national grid, TCN is planning to install various 132 kV transmission lines and new 132/33 kV substations as follows:

New Transmission Lines

- 321 km, 132 kV Double-Circuit Line Between Maiduguri - Manguno - Marte - Dikwa -Bama
- 165 km, 132 kV Double-Circuit Line from Maiduguri - Bama - Goza - Gulak
- 78 km, 132 kV Double-Circuit Line from Mayo Belwa - Jada - Ganye
- 134 km, 132 kV Double-Circuit Line from Biu - BuniYadi - Damaturu
- 130 km, 132 kV Double-Circuit Line from Dambua - Chibok - Uba - Mubi

132/33 kV Substations

- New 132/33 kV Manguno Substation, 2 x 60 MVA,
- Extension of Old Maiduguri 132 kV switchgear by 2 bays,
- New 132/33 kV Marte Substation, 2 x 60 MVA,

- New 132/33 kV Dikwa Substation, 1 x 60 MVA,
- New 132/33 kV Bama Substation, 2 x 60 MVA,
- Extension of New Maiduguri 132 kV switchgear by 2 bays,
- New 132/33 kV Gwoza Substation, 1 x 60 MVA,
- Extension of Gulak 132 kV switchgear by 2 bays,
- New 132/33 kV Jada Substation, 2 x 60 MVA,
- New 132/33 kV Ganye Substation, 2 x 60 MVA,
- New 132/33 kV Uba Substation, 2 x 60 MVA,
- New 132/33 kV Chibok Substation, 1 x 60 MVA,
- New 132/33 kV Biu Substation, 1 x 60 MVA,
- New 132/33 kV Bunyadi Substation, 1 x 60 MVA,
- Extension of Damaturu 132 kV switchgear by four bays,
- New 132/33 kV Kwaya Kusar Substation, 1 x 60 MVA,
- Extension of Gulak 132 kV switchgear by 2 bays,

In addition to the above, the following lines are planned:

In the North-West planning region of Nigeria there are plans to build a 330-kV Double-Circuit line between Kaduna and Kano, two 330/132 kV substations and two 132/33 kV substations.

In the South planning region, the reconstruction of two 330 kV transmission lines is planned. The 330 kV lines Delta-Benin and Alaoji-Ihiala-Onitsha shall be replaced by Double-Circuit lines with Quad conductors.

Furthermore, environmental impact assessments for various transmission lines are included in the scope.

A detailed list of transmission system expansion measures included in the scope of financing is shown in Annex 7.2e3 with their cost as estimated by TCN.

The planned transmission lines and substations are shown in Annex 7.1 on a map of Nigeria.

7-2-2-6 Transmission System Rehabilitations and Reinforcements/Upgrading to Be Financed by the World Bank

Under the Nigeria - Electricity Transmission Project (NETAP) it is proposed to carry out numerous rehabilitations/reinforcements of existing substations and transmission lines, financed by the World Bank.

The reinforcement and upgrading of substations includes the installation of additional 330/132 kV and 132/33 kV transformers, replacement of existing transformers by units with a higher rated capacity and installation of associated switchgear equipment and control and protection equipment. The rehabilitation measures include replacing high-voltage switchgear and associated equipment as well as control and protection equipment.

The rehabilitation/reinforcement of transmission lines includes mostly reconductoring of lines.

A detailed list of system rehabilitations and reinforcements/upgrading with their cost as estimated by TCN is shown in Annex 7.2e4. The annex shows that the substations and transmission lines are located throughout all the TCN planning regions of Nigeria.

7-2-2-7 Transmission System Expansions to Be Financed by AFD

Under a second financing agreement with AFD, there are plans to build new transmission lines and substations and rehabilitate transmission lines and substations in various northern planning areas of TCN, to improve power transmission in the northern transmission corridor. The scope includes also various rehabilitation measures for substations and transmission lines.

A detailed list of transmission system expansion measures included in the scope of financing is shown in Annex 7.4e5 with their cost as estimated by TCN.

7-3 Criteria to Formulate a Transmission Network Development Plan

7-3-1 Appraisal Criteria for TCN Network Expansions

Each of the main 330 and 132 kV projects has been appraised using ENTSO-E methodology. As such, the benefit of each project is assessed against a number of indicators, ranging from technical and socio-economic issues to their environmental impact.

The analysis has been performed for projects with implementation in the transmission network scheduled for 2025. Applying the ENTSO-E methodology, expected benefits were weighted and individually applied for each project. For this study, the projects were appraised against the following criteria:

Increase of Network Transfer Capacity, estimating the incremental power transfer capacity between two points of the transmission system (MW);

Social and Environmental Impacts, reflecting the level of certainty with respect to the planned commissioning time of the project and its impacts on the environment;


Security of Power Supply, evaluating the project impact on the reliability status of connected parts of the network;

Integration of Renewable Energy Sources (RES), Support for RES integration is defined as the ability of the system to allow the connection of new RES plants and unlock existing and future “green” generation;

Effect on Transmission Losses (Energy Efficiency), comparing losses (in MWs) relevant to scenarios with and without projects (or their specific components);

Technical resilience/system safety margin, evaluating the project influence on overall system reliability;

The radar format graph of Figure 7-3.1 shows, for example, the points scored by certain projects and hence their priority ranking. When comparing for the five projects, the 132 kV Ayade – Ibadan North project has the highest score and thus the highest priority. Other projects are also calculated and prioritized accordingly.



Source: JICA Study Team

Figure 7-3.1 Project Appraisal Criteria and Scores

7-3-2 Methodology Overview

The methodology of the power system analysis is summarized as follows:

7-3-2-1 Definition of the Security Reference Level

The goal of the study is to propose the necessary updates and reinforcements to the TCN power system to achieve secure operation for the system for the period 2020 to 2040. First, the present system model is analyzed, taking into account the recently completed and ongoing TCN and NIPP projects scheduled for completion by 2020. It has also been assumed that certain projects in the Lagos area undertaken by JICA will be completed for the period 2020-2025.

(1) Voltage criteria

The Grid Code of, 2014, v2, states that the System Operator shall endeavor to control the different busbar voltages to be within the voltage control ranges specified in Table 7-3.1:

Table 7-3.1 Voltage criteria

Voltage Level (kV)	Normal Operation		Contingency Operation	
	Minimum Voltage (kV) (pu)	Maximum Voltage (kV) (pu)	Minimum Voltage (pu)	Maximum Voltage (pu)
330 kV	280.5 (0.85)	346.5 (1.05)	0.80	1.10
132 kV	112.2 (0.85)	145.2 (1.10)	0.80	1.15
66 kV	62.04 (0.94)	69.96 (1.06)	0.89	1.11
33 kV	31.02 (0.94)	34.98 (1.06)	0.89	1.11
11 kV	10.45 (0.95)	11.55 (1.05)	0.90	1.10

Source: JICA Study Team

Under system stress or following system faults, voltages can be expected to deviate outside the above limits by a further +/-5% (excluding transient and sub-transient disturbances).

7-3-2-2 Thermal Criteria

The maximum permissible thermal overloading for all branches at 330 and 132 kV level is 100% of the nominal rating (Rate A) under normal (N) system conditions and 110% of the nominal rating under contingency (N-1) system conditions.

7-3-2-3 Policy of the Power System Analysis

(1) Execution of analyses on the 2020 model

The initial analysis relates to the static security assessment. Using the outcome of this analysis, an initial reinforcement list and recommendations for new lines and transformers are provided.

(2) Execution of the analysis on the 2025, 2030, 2035 and 2040 models

Considering the recommendations and reinforcements provided in b) already implemented in the 2020 network model, the same analysis is carried out on the 2025, 2030, 2035 and 2040 scenarios. The reinforcements and recommendations for these years constitute the outcome of this analysis.

The proposed transmission expansion projects from 2020 to 40 are detailed in the following sections.

Five milestone study years have been selected to cover the planning horizon of the Master Plan: 2020, 2025, 2030, 2035 and 2040.

7-3-3 Load Demand

The load demand in each of the DisCos areas in Nigeria is summarized in Table 7-3.2

In the 2020 network configuration, the assumed total demand is 9,023 MW, to closely match the validated DisCos load demand, as presented by the 11 DisCos in the workshop of January 2017 in Abuja. Thereafter, the load demand to be served depends on two factors: (a) the rate of increase in forecast demand as presented in Section 5 and, more importantly, (b) the limits of the generation expansion plan.

The maximum load demand that can be realistically supplied will, accordingly, have to follow the development of the generation planning schedule and will be limited by associated financial and time constraints.

The total demand that can be served includes the export requirements to neighboring countries.


Table 7-3.2 Load demand per DisCo

DisCo	2020	incr	2025	incr	2030	incr	2035	incr	2040
1-Ikeja	1,166	76%	2,058	42%	2,921	21%	3,536	22%	4,300
2-Ibadan	1,104	107%	2,285	43%	3,267	24%	4,054	25%	5,055
3-Abuja	865	169%	2,329	50%	3,500	26%	4,398	21%	5,336
4-Benin	954	94%	1,852	34%	2,489	17%	2,901	17%	3,391
5-Kaduna	495	136%	1,169	81%	2,117	20%	2,533	20%	3,045

DisCo	2020	incr	2025	incr	2030	incr	2035	incr	2040
6-Jos	309	109%	646	60%	1,035	4%	1,079	5%	1,131
7-Enugu	924	81%	1,668	19%	1,979	3%	2,037	4%	2,112
8-Port Harcourt	794	122%	1,762	35%	2,385	17%	2,802	18%	3,305
9-EKO	1,087	69%	1,837	22%	2,240	6%	2,382	5%	2,512
10-Kano	708	121%	1,565	64%	2,570	38%	3,549	13%	4,023
11-Yola	230	131%	532	77%	942	54%	1,448	16%	1,680
Country (MW)	8,636	105%	17,703	44%	25,447	21%	30,719	17%	35,890
Export (MW)	387		1,540		1,830		2,000		2,000
Total Load (MW)	9,023	113%	19,243	42%	27,277	20%	32,719	16%	37,890

Source: JICA Study Team

The increase in load that can be supplied by the planned generation for the period 2020-2040 is shown in Figure 7-3.2. The development of the generation system and associated demand can thus be referred to as the 9 GW in 2020, 18 GW in 2025, 26 GW in 2030, 31 GW in 2035 and 36 GW in 2040 respectively.



Source: JICA Study Team

Figure 7-3.2 Increase in Served Nigerian Load 2020-2040


Based on the installed generation, the maximum generation that can be made available to supply the peak demand is calculated as shown in the following Table 7-3.3 and Figure 7-3.3.

The generation expansion assumed for this study, for an average exceeding 2 GW per year for the period 2020-2034, is considered rather optimistic.

Table 7-3.3 Installed and available generation for 2020, 2025, 2030, 2035 and 2040

	2020	2025	2030	2035	2040
Installed generation (GW)	14.1	29.2	41.2	51.3	54.9
Proposed candidates (GW)	0.7	9.1	18.5	28.6	32.4
Less PV (not available during peak load) in GW	-1.08	-1.31	-2.11	-2.11	-2.11
Less a% of proposed candidates (in% and GW)	0%	20%	20%	20%	20%
	0.0	-1.8	-3.7	-5.7	-6.5
Less a min% on planned and unplanned outages (in% and GW)	20%	20%	20%	20%	20%
	-2.6	-5.2	-7.1	-8.7	-9.3
Available generation (max./rated) in GW	10.4	20.9	28.3	34.8	37.1
Available generation (running) during peak demand (GW)	9.9	19.8	26.9	33.4	35.6
Available generation (max), as% of the total (installed+planned+proposed).	74%	71%	69%	68%	67%

Source: JICA Study Team



Source: JICA Study Team

Figure 7-3.3 Installed and Available Generation for 2020, 2025, 2030, 2035 and 2040

7-4 Expansion Plan for 2020

7-4-1 Static Security Analysis, Year 2020

7-4-1-1 Network Configuration

The network configuration for 2020 is shown in the single-line diagrams of Annexes 7.4.2 and 7.4.1. The SLDs include all the ongoing and committed TCN, NIPP and JICA new projects, assuming completion in all cases by 2020.

The new transmission expansion projects identified on the basis of the load-flow studies carried out are shown on the map of Annexes 7.4.3 and 7.4.4.


The input data used and the assumptions made with regard to the load demand, generation capacities and expansion, transmission lines and reactive power compensation equipment are detailed in the following sections.

Figure 7-4.1 below shows the 330-kV transmission system in 2020 (red lines), assuming all the ongoing

and committed TCN, NIPP and certain JICA new projects will be completed by 2020.

The diagram shows the running generation and load in each DisCo area and the power flows between DisCos.

Dotted lines and lines in magenta denote future projects beyond 2020, which were analyzed in the study of the corresponding year and reported accordingly in this report.



Source: JICA Study Team

Figure 7-4.1 330 kV Transmission System 2020

7-4-1-2 Load Demand

In the 2020 network configuration the assumed total demand is 9,023 MW, closely matching the validated DisCos load demand, as presented by the 11 DisCos in the workshop of January 2017 in Abuja.

The load in each of the DisCo areas in Nigeria is shown in Figure 7-4.2 and summarized in Table 7-4.1.

The total demand includes the export requirements to neighboring countries as follows:

To Benin (Sakete, 330 kV):

To Niger (Niamey, 132 kV):

To Niger (Gazoua, 132 kV):

The export requirements modeled for 2020, 2025, 2030 and 2035 were based on information provided by TCN and the results of earlier WAPP studies and reports.

In the 2020 load model representation in PSS/E, a pessimistic power factor of around 0.85 has been assumed, despite the new Grid Code requirements calling for a pf of 0.95, as it is believed that most users at distribution level are not in full compliance yet with this requirement. It is noted that the Grid Code requirements (ref. article 15.6 on Demand power factor corrections and 16.7 on provision of voltage control) states that The Off-takers shall maintain a power factor of at least 0.95 at the Connection Point.

Accordingly, the loads in the 2020 models are based on a pf of 0.85, those in the 2025 model on a still-conservative pf of 0.92 and only the 2030 loads have a pf of 0.95.

Table 7-4.1 Load demand per DisCo

SCO	Load (MW)
1-Ikeja	1,166
2-Ibadan	1,104
3-Abuja	866
4-Benin	954
5-Kaduna	495
6-Jos	309
7-Enugu	924
8-Port Harcourt	794
9-Eko	1,087
10-Kano	708
11-Yola	230
Total for Nigeria	8,637
Export	387
Total load	9,024

Source: JICA Study Team

The modeled loads of individual substations within each DisCo are detailed in Annex 7.4.5.

The total generation required to meet the load in Nigeria is 9,421 MW and total losses are 397 MW.

7-4-1-3 Generation Capacity

The ratings of the conventional generating units in Nigeria for 2020 are shown in Table 7-4.2.

Table 7-4.2 Ratings of power generating units (P_{max})

Station Name	Company Name	Primary Energy Resource	Commercial Operation Date	No of Units	Gross Unit Capacity (MW)	Gross Plant Capacity (MW)	Total 2020
Existing generation capacity							
AFAM IV - GT13-18	AFAM POWER PLC.	GAS	1982	6	75	450	150
AFAM V - GT19-20	AFAM POWER PLC.	GAS	2002	2	138	276	276
AFAM VI - GT11-13	SHELL ROT	GAS	2009	3	166	498	450
AFAM VI - ST1	SHELL ROT	STEAM	2010	1	230	230	200
ALAOJI – NIPP	NIPP	GAS	2013	4	120	480	480
CALABAR / ODUKPANI NIPP	NIPP	GAS	2015	5	113	565	338
DELTA II - GT3-8	TRANSCORP POWER LTD	GAS	2002	6	24	143	123
DELTA III - GT9-14	TRANSCORP POWER LTD	GAS	2005	6	24	143	128
DELTA IV - GT15-20	TRANSCORP POWER LTD	GAS	1990	6	99	594	630
EBUTE BARGE (CYREX) AES	AES / CYREX ENERGY LTD	GAS	2002	9	31	279	0
EGBIN	EGBIN POWER PLC	STEAM	1985	6	220	1,320	1,320
GBARAIN - GT2 NIPP	NIPP	GAS	2016	1	113	113	113
GEREGU FGN 1	GEREGU GENERATION COMPANY LTD	GAS	2007	3	138	414	414
GEREGU NIPP 1	NIPP	GAS	2013	3	148	444	220
IBOM 1	IBOM POWER	GAS	2009	1	42	42	0
IBOM 1	IBOM POWER	GAS	2010	1	114	114	114
IBOM 1	IBOM POWER	GAS	2016	1	40	40	0
IHOVBOR (EYAEN) NIPP	NIPP	GAS	2013	4	113	452	339
JEBBA	POWER HOLDING CO OF NIGERIA	HYDRO	1983	6	101.15	606.9	607
KAINJI - G11-12	POWER HOLDING CO OF NIGERIA	HYDRO	1976	2	100	200	200
KAINJI - G5-6	POWER HOLDING CO OF NIGERIA	HYDRO	1968	2	120	240	240
KAINJI - G7-10	POWER HOLDING CO OF NIGERIA	HYDRO	1978	4	80	320	160
OKPAI IPP	NIGERIAN AGIP OIL CO	GAS	2005	2	165	330	300
OKPAI IPP	NIGERIAN AGIP OIL CO	STEAM	2005	1	140	140	140
OLORUNSOGO I	PACIFIC ENERGY	GAS	2007	8	42	335	335
OLORUNSOGO II NIPP	NIPP	GAS	2011	4	120	480	240
OLORUNSOGO II NIPP	NIPP	STEAM	2012	2	120	240	120
OMOKU IPP	FIRST INDEPENDENT POWER	GAS	2006	6	25	150	150
OMOTOSHO I	OMOTOSHO ELECTRIC ENERGY COMPANY	GAS	2007	8	42	335	304
OMOTOSHO II NIPP	NIPP	GAS	2012	4	120	480	240
PARAS ENERGY	PARAS ENERGY & NATURALS RES. DEV. LTD	GAS	2016	9	9	79	170
RIVERS IPP	FIRST INDEPENDENT POWER	GAS	2012	1	191	191	191
SAPELE	SAPELE POWER PLC	STEAM	1978	6	88	528	400
SAPELE OGORODE 1 NIPP	NIPP	GAS	2011	4	113	454	454
SHIRORO	SHIRORO HYDRO ELECTRIC	HYDRO	1990	4	150	600	600
TRANS-AMADI IPP	FIRST INDEPENDENT POWER	GAS	2010	4	25	100	100
Subtotal 1-Existing generation capacity							10,098
Additional generation capacity by 2020							
AFAM III		GAS	2018	8	30	240	240

Station Name	Company Name	Primary Energy Resource	Commercial Operation Date	No of Units	Gross Unit Capacity (MW)	Gross Plant Capacity (MW)	Total 2020
AFRINERGIA SOLAR	AFRINIGER SOLAR	PV	2020			50	50
ANJEED KAFACHAN SOLAR IPP	ANJEED KAFACHAN SOLAR IPP	PV	2020			100	100
AZURA		GAS	2018	3	150	450	450
CT COSMOS	CT COSMOS	PV	2020			70	70
EGBEMA I - NIPP	NIPP	GAS	2018	1	113	113	113
EGBEMA I - NIPP	NIPP	GAS	2019	1	113	113	113
EGBEMA I - NIPP	NIPP	GAS	2019	1	113	113	113
EN Consulting & Projects - Kaduna		PV	2020			100	50
GBARAIN / UBIE I	NIPP	GAS	2017	1	113	113	113
GURARA	SALINI NIGERIA LTD	HYDRO	2017	2	15	30	30
IBOM II		GAS	2020	4	138	552	276
KADUNA IPP	KADUNA IPP	GAS	2019	1	215	215	215
KASHIMBILLA		HYDRO	2019		40	40	40
KVK POWER NIGERIA LTD	KVK POWER NIGERIA LTD	PV	2020			55	55
LR AARON SOLAR POWER PLANT	LR AARON SOLAR	PV	2019			100	100
MABON - DADIN KOWA	MABIN LTD.	HYDRO	2018	1	39	39	39
MIDDLE BAND SOLAR	MIDDLE BAND SOLAR	PV	2020			100	100
MOTIR DUSABLE	MOTIR DUSABLE LTD	PV	2020			100	100
NIGERIA SOLAR CAPITAL PARTNERS	NIGERIA SOLAR CAPITAL PARTNERS	PV	2020			100	100
NOVA SCOTIA POWER	Nova Scotia Power Development Ltd	PV	2018			80	80
NOVA SOLAR	NOVA SOLAR POWER LTD	PV	2018			100	100
OKPAI IPP II - AGIP (NNPC POWER BUSINESS PLAN)	NIGERIAN AGIP OIL CO	GAS	2020	2	150	300	300
OKPAI IPP II - AGIP (NNPC POWER BUSINESS PLAN)	NIGERIAN AGIP OIL CO	STEAM	2020	1	150	150	150
OMOKU - NIPP	NIPP	GAS	2018	1	113	113	113
OMOKU - NIPP	NIPP	GAS	2019	1	113	113	113
ORIENTAL		PV	2020			50	50
PAN AFRICA SOLAR	PAN AFRICA SOLAR LTD	PV	2019			75	75
QUAINT ENERGY SOLUTIONS	QUAINT ENERGY SOLUTIONS	PV	2019			50	50
ZUNGERU		HYDRO	2019	4	700	700	700
Subtotal 2-Additional generation capacity by 2020							4,198
Total by 2020							14,296

Source: JICA Study Team

The PV plants shown in Table 7-4.3, are planned to be installed mainly in northern Nigeria and are most likely to go into operation by 2020.

Table 7-4.3 PV plants in operation by 2020

PN Plant	Location	Installed Capacity (MW)
Pan Africa Solar	Kankia	75
Nova Solar	Katsina	100
LR Aaron Power	Abuja/Gwangwalada	100
Nova Scotia	Dutse/Jigawa	80

PN Plant	Location	Installed Capacity (MW)
KVK Power	Sokoto	55
Quaint Power/Energy	Kaduna	50
Anjeed Kafanchan	Kafanchan	100
Nigeria Solar Capital Partners	Gombe/Bauchi	100
Motir Dusable	Oji	100
Afrinergia Solar	Karu-Keffi	50
CT Cosmos	Jos/Makeri/Pankshin	70
Oriental	Dutse	50
EN Consulting-Kaduna	Kaduna-Zaria	50
Middle Band Solar	Lokoja	100

Source: JICA Study Team

7-4-1-4 Study Cases 2020

Four scenarios, as shown in Table 7-4.4 have been studied for 2020. The focus was on the two cases, (Dry Season Peak and Dry Season Off-Peak), which capture the extreme combinations of generation and load. Other scenarios, such as Wet Season Peak and Wet Season Off-Peak, are less onerous, as it has emerged that their requirements are covered by the extreme case studied:

Table 7-4.4 2020 study cases

Case		Description	Generation	Load (MW)	
Dry Season Peak	DP	Dry Night Peak Load	Dry-Reduced HPP generation (1,322 MW) No PV generation Increased requirement from GTs	Peak load (night)	8637 + export (387)
Wet Season Peak	WP	Wet Night Peak Load	Wet-Normal HPP generation (2,100 MW) No PV generation Increased requirement from GTs	Peak load (night)	8637 + export
Dry Season Off-Peak	DOP	Dry Day Off-Peak Load	Dry-Reduced HPP generation (1,100 MW) PV generation (400 MW)	Off-Peak load (day)	7340+ export (387)
Wet Season Off-Peak	WOP	Wet Day Off-Peak Load	Wet-Normal HPP generation (2,100 MW) PV generation (400 MW)	Off-Peak load (day)	7340 + export (387)

Source: JICA Study Team

7-4-2 2020 Base Case Load-flow Results

The load-flow results are shown in Annexes 7.4.2 and 7.4.6 to 7.4.9

In the base case (N-0) load-flow calculations the following observations are made:

7-4-2-1 Power Flows Between DisCos and Regions

The diagram of Figure 7-4.1 and the SLD in Annex 7.4.1 indicate the power flows between the 11 DisCos areas in Nigeria using green arrows, for general peak load and generation case. The DisCos are:

- | | | |
|----------|-----------------|---------|
| 1-Ikeja | 5-Kaduna | 9-Eko |
| 2-Ibadan | 6-Jos | 10-Kano |
| 3-Abuja | 7-Enugu | 11-Yola |
| 4-Benin | 8-Port Harcourt | |

The Nigeria planning *regions* are:

- 1-Lagos 5-Kaduna 9-Abuja (July 2018~)
- 2-Osogbo 6-Bauchi
- 3-Shiroro 7-Enugu
- 4-Benin 8-Port Harcourt

The generation (installed and running) and the load in each DisCo are summarized in Table 7-4.5 and Figure 7-4.2. The running generation is approximately 74% of the total installed capacity.

Table 7-4.5 Running generation and load in different areas (DisCos)

Region	Running Generation (MW)	Load (MW)	Generation deficit/surplus (MW)	Remarks
1-Ikeja	735	1,166	-431	Generation deficit
2-Ibadan	476	1,104	-628	Generation deficit
3-Abuja	1,979	866	1,113	Generation surplus
4-Benin	1,775	954	821	Generation surplus
5-Kaduna	344	495	-151	Generation deficit
6-Jos	105	309	-204	Generation deficit
7-Enugu	796	924	-128	Generation deficit
8-Port Harcourt	3,202	794	2,408	Generation surplus
9-Eko	0	1,087	-1,087	Generation deficit
10-Kano	9	708	-699	Generation deficit
11-Yola	0	230	-230	Generation deficit
Total for Nigeria	-	8,637	-	
Export	-	387	-	
Totals	9,421	9,024	397 (losses)	


Source: JICA Study Team



Source: JICA Study Team

Figure 7-4.2 Generation and Load per DisCo

The general voltage profile is shown in Figure 7-4.3, with blue and red indicating relatively low and high voltages respectively. Lagos, Osogbo and Kaduna are clearly areas with low voltages encountered due to high demand, insufficient local generation, voltage drop in radial feeders and overloaded 132 kV lines and 132/33 kV transformers, even in some areas with high generation.



Source: JICA Study Team


Figure 7-4.3 Voltage Profile of 330, 132 and 33 kV Systems

It can be seen that:

- The generation is mainly concentrated in the South (thermal stations in Port Harcourt, Enugu, Benin and Lagos) and Central West (hydro stations of Jebba, Kainji and Shiroro in the Shiroro region). The Central, North and North-East regions in particular are characterized by the total absence of generating stations.
- Load demand centers in the South and South-West. Table 7-4.5 shows that with the exception of Benin, Abuja and Port Harcourt areas, where there is a significant generation surplus, demand exceeds available supply in all other regions of Nigeria.

- To supply load to areas with little or no generation such as the North-East, long 330 kV transmission lines are built (radial system), which are then prone to voltage regulation problems. Moreover, the excessive reactive power flowing through these lines necessitates large reactive power compensation equipment (reactors) at the corresponding substations (Kano, Gombe, Maiduguri).
- Any addition of more 330 kV lines running in parallel, as planned, may require additional compensation equipment, as of Yola and Jalingo and possibly elsewhere to limit the overvoltages due to line charging currents.

The general profile of power flows in the TCN system is shown graphically in Figure 7-4.4



Source: JICA Study Team


Figure 7-4.4 Power flows in the TCN system

7-4-2-2 Dry Season Peak Case

(1) Prerequisites for analysis

- (a) Generation from PVs = 0 MW and
- (b) Reduced generation from HPP plants of 1,322 MW)

The running generation and load for each DisCo are shown in Figure 7-4.5 and Table 7-4.6. The total running generation to meet the load and losses is 9,417 MW.



Source: JICA Study Team

Figure 7-4.5 Dry Season Peak Generation and Load Per DisCo


Table 7-4.6 2020 Dry Season Peak - Running Generation

Bus Name	P _{Gen} (MW)	Bus Name	P _{Gen} (MW)	Bus Name	P _{Gen} (MW)
AARON PV 15.000	0	EGBIN ST 2 16.000	171.4	NOVA SOLA PV33.000	0
AES BERG202 11.000	0	EGBIN ST 3 16.000	171.4	NSCP PV 15.000	0
AES BERG203 11.000	0	EGBIN ST 4 16.000	171.4	O REN SOL PV15.000	0
AES BERG204 11.000	0	EGBIN ST 5 16.000	171.4	OBAJANA 15.000	0
AES BERG205 11.000	0	EGBIN ST 6 16.000	171.4	OKPAI GT11 11.500	135
AES BERG207 11.000	0	ELEME 15.000	0	OKPAI GT12 11.500	135
AES BERG208 11.000	0	EN ARFICA PV15.000	0	OKPAI ST18 11.500	126
AES BERG209 11.000	0	ETHIOPE 15.000	0	OKPAI_IPPII 11.500	400
AES BERG210 11.000	0	GBARAIN_GTB115.000	102	OLOR NIPPST110.500	108
AES BERG211 11.000	0	GBARAIN_GTB215.000	102	OLOR NIPPST210.500	0
AFAM VI GT1111.500	150	GEN DANGOTE 15.000	0	OLORNIPPGT1110.500	0
AFAM VI GT1211.500	150	GEN_AMADI 15.000	90	OLORNIPPGT1210.500	0
AFAM VI GT1311.500	105	GEN_KADUNA 15.000	194	OLORNIPPGT2110.500	108
AFAM VI ST1011.500	180	GEOMETRIC_AB15.000	0	OLORNIPPGT2210.500	108
AFAM1GT1-2 11.500	0	GER NIPPST2110.500	100	OLORUNSO GT110.500	22
AFAM1GT3-4 11.500	0	GER NIPPST2210.500	0	OLORUNSO GT210.500	22

Bus Name	P _{Gen} (MW)	Bus Name	P _{Gen} (MW)	Bus Name	P _{Gen} (MW)
AFAM2 GT5-6 11.500	54	GER NIPPGT2310.500	100	OLORUNSO GT310.500	20
AFAM2GT 7-8 11.500	54	GEREGU GT11 10.500	83	OLORUNSO GT410.500	0
AFAM3 GT9-1011.500	54	GEREGU GT12 10.500	83	OLORUNSO GT510.500	22
AFAM3GT11-1211.500	54	GEREGU GT13 10.500	83	OLORUNSO GT610.500	22
AFAM4GT13-1411.500	67	GR COWRI PV 33.000	0	OLORUNSO GT710.500	22
AFAM4GT15-1611.500	0	GURARA GBUS 11.500	0	OLORUNSO GT810.500	22
AFAM4GT17-1811.500	0	IBOM GT1 11.500	34	OMOKU1 GT1 15.000	68
AFAMV GT 19 11.500	125	IBOM GT2 11.500	34	OMOKU1 GT2 15.000	50
AFAMV GT 20 11.500	125	IBOM GT3 11.500	34	OMOKU2 GT1 15.000	102
AFRINEGIA PV15.000	0	IBOM II 11.500	260	OMOKU2 GT2 15.000	102
ALAOJI_GTB1 15.000	81	IHOVBOR_GTB115.000	110	OMOTNIPP GT110.500	108
ALAOJI_GTB2 15.000	81	IHOVBOR_GTB215.000	110	OMOTNIPP GT210.500	108
ALAOJI_GTB3 15.000	81	IHOVBOR_GTB315.000	110	OMOTNIPP GT310.500	0
ALAOJI_GTB4 15.000	81	IHOVBOR_GTB415.000	0	OMOTNIPP GT410.500	0
ALAOJI_STB1 17.000	0	IJORA GT 4-611.000	0	OMOTOSO GT1 10.500	70
ALAOJI_STB1 17.000	0	JBS WIND 15.000	70	OMOTOSO GT3 10.500	66
ALSCON GT1 11.500	0	JEBBA 2G1 16.000	90	OMOTOSO GT5 10.500	0
ALSCON GT2 11.500	0	JEBBA 2G2 16.000	90	OMOTOSO GT7 10.500	0
ANJEED PV 15.000	0	JEBBA 2G3 16.000	0	PAN AFRIC PV15.000	0
ASCO G1 11.000	0	JEBBA 2G4 16.000	0	PARAS 11.500	0
ASCO G2 11.000	0	JEBBA 2G5 16.000	0	PARASGT1-9 11.000	81
AZURA GT 15.000	280	JEBBA 2G6 16.000	90	QUAINT PV 15.000	0
AZURA ST 15.000	125	KAINJ 1G11 16.000	90	RIVERS_GT1 10.500	172
BRESSON GTS 11.000	0	KAINJ 1G12 16.000	90	RIVERS_GT2 10.500	0
CALABAR_GTB115.000	100	KAINJ 1G5 16.000	45	SAP_NIPP_GT115.800	77
CALABAR_GTB215.000	102	KAINJ 1G6 16.000	45	SAP_NIPP_GT215.800	77
CALABAR_GTB315.000	102	KAINJ 1G7-8 16.000	160	SAP_NIPP_GT315.800	76
CALABAR_GTB415.000	0	KAINJ 1G9-1016.000	0	SAP_NIPP_GT415.800	76
CALABAR_GTB515.000	0	KASHIMB HP2 15.000	0	SAPELE GT1-215.800	0
CT COSMO PV 15.000	0	KASHIMB HP3 15.000	0	SAPELE GT3-415.800	0
DELT3 GT9-1111.500	38	KASHIMB HP4 15.000	0	SAPELE ROT 15.800	0
DELT3GT12-1411.500	0	KASHIMB HPP 15.000	21	SAPELE ST1 15.800	0
DELTA GT 15 11.500	96	KAZAURE PV1 11.000	0	SAPELE ST2 15.800	0
DELTA GT16 11.500	96	KAZAURE PV1011.000	0	SAPELE ST3 15.800	0
DELTA GT17 11.500	97	KAZAURE PV2 11.000	0	SAPELE ST4 15.800	0
DELTA GT18 11.500	0	KAZAURE PV3 11.000	0	SAPELE ST5 15.800	0
DELTA GT19 11.500	0	KAZAURE PV4 11.000	0	SAPELE ST6 15.800	0
DELTA GT20 11.500	0	KAZAURE PV5 11.000	0	SHIROR 411G116.000	140
DELTA1 GT1 11.500	0	KAZAURE PV6 11.000	0	SHIROR 411G216.000	140
DELTA1 GT2 11.500	0	KAZAURE PV7 11.000	0	SHIROR 411G316.000	0
DELTA2 GT3-511.500	45	KAZAURE PV8 11.000	0	SHIROR 411G416.000	0
DELTA2 GT6-811.500	10	KAZAURE PV9 11.000	0	SINOSUN PV 15.000	0
DKOWA G1 11.000	14	KT WF 33 33.000	9	SYNER GEN PV15.000	0
DUSABLE PV 15.000	0	KVKPOWER PV 15.000	0	ZUNGE_G1 16.000	107
EGBEMA_GTB1 15.000	102	LAFARAGE 1 11.000	0	ZUNGE_G2 16.000	107
EGBEMA_GTB2 15.000	102	MIDBAND PV 15.000	0	ZUNGE_G3 16.000	0
EGBEMA_GTB3 15.000	102	NOVA SCOT PV132.00	0	ZUNGE_G4 16.000	107
EGBIN ST 1 16.000	171.4	NOVA SOLA PV15.000	0		

Source: JICA Study Team

The power flows are shown in Figure 7-4.6.



Source: JICA Study Team

Figure 7-4.6 2020 Dry Season Peak Power Flows in 330 kV System

(2) Overloads of lines and transformers

The base case (N-0) overloaded 132 kV lines as well as the 330/132 kV and 132/33 kV transformers are listed in Table 7-4.7, Table 7-4.8 and Table 7-4.9.

It should be noted that introducing the 330kV substation at Ijora eliminates the overloads of the 132kV line Alagbon - Ijora and the need to have this line reinforced. It will become even more crucial in subsequent years, so it should be integrated into the system as soon as possible.

Table 7-4.7 2020 Dry Season Peak - Overloaded Lines (base case)

Bus Number	Bus name	Bus Number	Bus name	CKT	Contingency label	Rating (MVA)	Flow (MVA)	Loading (%)
82024	IBOM IPP 1 132.00	82031	IKOT_ABASI 132.00	1	BASE CASE	125.7	182.1	144.8

Source: JICA Study Team

Table 7-4.8 2020 Dry Season Peak - Overloaded 330/132 kV transformers (base case)

Bus Number	Bus Name	Voltage (kV)	Area	Bus Number	Bus Name	Wind Number	CKT	Loading (MVA)	Rating (MVA)	Loading (%)
330/132 kV 3-W and A/T										
23003	GANMO 3	330	2	3WNDTR	GANMO TR2A	1	1	157.4	150	104.9
33002	BKEBBI 3	330	3	3WNDTR	B_KEBBI T1	1	1	176.9	150	118
43002	BENIN 3	330	4	3WNDTR	BENIN TR1	1	1	156	150	104
43002	BENIN 3	330	4	3WNDTR	BENIN TR2	1	1	156	150	104
43002	BENIN 3	330	4	3WNDTR	BENIN TR3	1	1	156	150	145.6
43011	B.NORTH_3	330	4	3WNDTR	BENIN 9T1	2	1	88	67.5	131.6

Source: JICA Study Team

Table 7-4.9 2020 Dry Season Peak - Overloaded 2-winding transformers (base case)


Bus Number	Bus Name	Voltage (kV)	Area	Bus Number	Bus Name	Voltage (kV)	cct	Loading (MVA)	Rating (MVA)	Loading (%)
132/33 and 132/11 kV 2-W transformers										
32017	SULEJA 1	132	3	36016	SULEJA 11	11	1	18.6	7.5	247.6
42004	BENIN 1	132	4	45029	BENIN T22 33	33	1	85.9	60	143.1
52001	KANO 1	132	5	55058	KUMB T3 MOB	33	3	41.9	30	139.6
42004	BENIN 1	132	4	45031	BENIN T24 33	33	1	82.9	60	138.1
42004	BENIN 1	132	4	45030	BENIN T23 33	33	1	80.9	60	134.8
52016	FUNTUA 1	132	5	56000	FUNTUA 11	11	1	9.6	7.5	127.6
42005	B_ NORTH 1	132	4	45015	B_ NORTH_33	33	1	73.9	60	123.2
22015	OMUARAN 1	132	2	25016	OMUARAN 33	33	1	33.4	30	111.4
52016	FUNTUA 1	132	5	55003	FUNTUA 33	33	1	33	30	109.9
52016	FUNTUA 1	132	5	56005	FUNTUA T2	11	2	7.9	7.5	105.9
22013	OFFA 1	132	2	25015	OFFA 33	33	1	31.8	30	105.8
12029	OJO 1	132	1	15030	OJO 33	33	1	30.4	30	101.4

Source: JICA Study Team

7-4-2-3 Wet Season Peak Case**(1) Prerequisites for analysis**

- (a) Generation from PVs = 0 MW and
- (b) Normal generation from HPP plants of 2,100 MW,

The running generation and load for each DisCo are shown in Figure 7-4.7.



Source: JICA Study Team

Figure 7-4.7 Wet Season Peak Generation and Load Per DisCo

(2) Overloads of lines and transformers

The base case (N-0) overloaded 132 kV lines are listed in Table 7-4.10.

Table 7-4.10 2020 Wet Season Peak - Overloaded Lines (base case)

Bus Number	Bus name	Bus Number	Bus name	CKT	Contingency label	Rating (MVA)	Flow (MVA)	Loading (%)
82024	IBOM IPP 1 132.00	82031	IKOT_ABASI 132.00	1	BASE CASE	125.7	182.6	145.2

Source: JICA Study Team


No new overloaded lines are reported, in addition to those overloaded in the Dry Season Peak case. The same applies for the overloaded transformer.

7-4-2-4 Dry Season Off- Peak Case

(1) Prerequisites for analysis

- (a) Generation from PVs = 400 MW and
- (b) Reduced generation from HPP plants of 1,100 MW,

The running generation and load for each DisCo are shown in Figure 7-4.8.



Source: JICA Study Team

Figure 7-4.8 Dry Season Off-Peak Generation and Load per DisCo

(2) Overloads of lines and transformers

The base case (N-0) overloaded 132 kV lines are listed in Table 7-4.11.

Table 7-4.11 2020 Dry Season Off-Peak - Overloaded Lines (base case)

Bus Number	Bus name	Bus Number	Bus name	CKT	Contingency label	Rating (MVA)	Flow (MVA)	Loading (%)
82024	IBOM IPP 1 132.00	82031	IKOT_ABASI 132.00	1	BASE CASE	125.7	189.6	150.9

Source: JICA Study Team

The overloaded line(s) are the same as in the Dry Season Peak case.

The overloaded transformers are fewer than the Dry Season Peak case, as shown in the following tables, Table 7-4.12 and Table 7-4.13.

Table 7-4.12 2020 Dry Season Off-Peak - Overloaded 330/132 kV transformers (base case)

Bus Number	Bus Name	Voltage (kV)	Area	Bus Number	Bus Name	Wind	CKT	Loading (MVA)	Rating (MVA)	Loading (%)
43011	B.NORTH_3	330	4	3WNDTR	BENIN 9T1	2	1	74.3	67.5	110

Source: JICA Study Team

Table 7-4.13 2020 Dry Season Off-Peak - Overloaded 2-winding transformers (base case)

Bus Number	Bus Name	Voltage (kV)	Area	Bus Number	Bus Name	Voltage (kV)	cct	Loading (MVA)	Rating (MVA)	Loading (%)
132/33 and 132/11 kV 2-W transformers										
32017	SULEJA 1	132	3	36016	SULEJA 11	11	1	15.5	7.5	206
42004	BENIN 1	132	4	45029	BENIN T22 33	33	1	72.4	60	120.6
52001	KANO 1	132	5	55058	KUMB T3	33	3	34.9	30	116.3

Bus Number	Bus Name	Voltage (kV)	Area	Bus Number	Bus Name	Voltage (kV)	cct	Loading (MVA)	Rating (MVA)	Loading (%)
					MOB					
42004	BENIN 1	132	4	45031	BENINT24 33	33	1	69.9	60	116.4
42004	BENIN 1	132	4	45030	BENINT23 33	33	1	68.2	60	113.7
52016	FUNTUA 1	132	5	56000	FUNTUA 11	11	1	9.6	7.5	127.6
42005	B_NORTH 1	132	4	45015	B_NORTH_33	33	1	62.4	60	104


Source: JICA Study Team

7-4-2-5 Wet Season Off-Peak Case

(1) Prerequisites for analysis

- (a) Generation from PVs = 400 MW and
- (b) Normal generation from HPP plants of 2,100 MW,

The running generation and load for each DisCo are shown in Figure 7-4.9.



Source: JICA Study Team

Figure 7-4.9 Wet Season Off-Peak Generation and Load Per DisCo

(2) Overloads of lines and transformers

The base case (N-0) overloaded 132 kV lines are listed in Table 7-4.14.

Table 7-4.14 2020 Wet Season Off-peak - Overloaded Lines (base case)

Bus Number	Bus name	Bus Number	Bus name	CKT	Contingency label	Rating (MVA)	Flow (MVA)	Loading (%)
82024	IBOM IPP 1 132.00	82031	IKOT_ABASI 132.00	1	BASE CASE	125.7	189.4	150.7

Source: JICA Study Team

No new overloaded lines are reported, in addition to those overloaded in the Dry Season Peak case.

The same applies for the overloaded transformer.

7-4-3 2020 Contingency Analysis Load-flow Results

An N-1 contingency analysis using ACCC in PSS/E has been carried out for the 330 and 132 kV transmission lines, using their RATE B as short-term overload ratings.

The N-1 criterion is not applicable for transformer circuits. The results are summarized in tables from Table 7-4.15 to Table 7-4.19.

Table 7-4.15 Non-converged cases

Contingency	LINE	Bus Number	Bus Name	Voltage (kV)	Bus Number	Bus name	CKT
SINGLE 53001-53005(2)	OPEN LINE	53001	KANO 3	330	53005	KANO_NEW330	2
SINGLE 63000-63002(1)	OPEN LINE	63000	GOMBE 3	330	63002	YOLA 3	1
SINGLE 63000-63007(1)	OPEN LINE	63000	GOMBE 3	330	63007	DAMATURU 3	1
SINGLE 32003-32041(3)	OPEN LINE	32003	BKEBBI 1	132	32041	KVKPOWER PV	3
SINGLE 32016-32041(3)	OPEN LINE	32016	SOKOTO 1	132	32041	KVKPOWER PV	3
SINGLE 52015-52016(1)	OPEN LINE	52015	ZARIA 1	132	52016	FUNTUA 1	1

Source: JICA Study Team

In the above contingency cases of the loss of 330 kV lines from Gombe to Yola and Damaturu, the load-flow case did not converge as expected, due to the absence of a second parallel circuit and insufficient support from alternative routes.

Converting to a Double-Circuit will resolve these issues.

The overloads reported for the 132 kV circuits will have to be resolved by either reinforcing these lines or providing new alternative routes for the power flow.

In all N-1 contingencies, a number of 132 kV voltages are lower than the minimum permissible level of 0.8p.u. However, this is due to overloads of the associated 132 kV lines and transformers and the remedial actions for the U/V are linked to the solutions initially required for overloads of these circuits.

7-4-3-1 2020 Dry Season Peak Case-ACCC

The base case and N-1 contingency analysis results are shown in Table 7-4.16.

It can be seen that the loadings of all the 330 kV lines are within their thermal rating limits with the exception of the Double-Circuit 330 kV lines from Benin to Omotosho and from Shiroro to Kaduna.

Table 7-4.16 shows the overloaded 132 kV lines.

Table 7-4.16 2020 Dry Season Peak - Overloaded Lines (base case and under N-1)

Bus Number	Bus Name	Bus Number	Bus Name	cct	Contingency Label	Rating (MVA)	Flow (MVA)	Loading (%)
330 kV System								
None								
132 kV System								
82024	IBOM IPP 1	82031	IKOT_ABASI	1	BASE CASE	125.7	182.1	144.8
82019	OMOKU 1	82036	RUMUSOI 1	2	SINGLE 82019-82036(1)	138.3	219	158.3
82019	OMOKU 1	82036	RUMUSOI 1	1	SINGLE 82019-82036(2)	138.3	219	158.3
42000	AJAOKUTA 1	42009	OKENE 1	1	SINGLE 42004-42008(1)	138.3	211.5	152.9
42004	BENIN 1	42008	IRRUA 1	1	SINGLE 42000-42009(1)	138.3	203.5	147.1
22002	OSOGBO 4T2	22008	IWO 1	1	SINGLE 22000-22006(1)	138.3	201.9	146
82017	YENAGOA 1	82022	GBARAIN UBIE	2	SINGLE 82017-82022(1)	138.3	191.2	138.2
82017	YENAGOA 1	82022	GBARAIN UBIE	1	SINGLE 82017-82022(2)	138.3	191.2	138.2
12003	IKEJA W 1BB1	12019	ALIMOSHO 1	2	SINGLE 12003-12019(1)	138.3	176.8	127.9
12003	IKEJA W 1BB1	12019	ALIMOSHO 1	1	SINGLE 12003-12019(2)	138.3	176.8	127.9
52033	MANDO T4A BB	52035	KUDENDA 1	2	SINGLE 52033-52035(1)	138.3	172.5	124.8
52033	MANDO T4A BB	52035	KUDENDA 1	1	SINGLE 52033-52035(2)	138.3	172.5	124.8
22000	AYEDE 1	22006	IBADAN NORTH	1	SINGLE 22002-22008(1)	138.3	172	124.4
82017	YENAGOA 1	82018	AHOADA 1	2	SINGLE 82017-82018(1)	138.3	171.4	123.9
82017	YENAGOA 1	82018	AHOADA 1	1	SINGLE 82017-82018(2)	138.3	171.4	123.9
62009	BIU 1	62026	DADINKOWA 1	1	SINGLE 63005-63007(1)	76.7	94.7	123.5
82005	EKET 1	82024	IBOM IPP 1	1	SINGLE 82024-82031(1)	150.4	184.2	122.4
82005	EKET 1	82024	IBOM IPP 1	2	SINGLE 82024-82031(1)	150.4	184.2	122.4
82007	PHCT MAIN1	82036	RUMUSOI 1	2	SINGLE 82007-82036(1)	138.3	166	120
82007	PHCT MAIN1	82036	RUMUSOI 1	1	SINGLE 82007-82036(2)	138.3	166	120
82000	AFAM 1-2-3	82002	AFAM IV	2	SINGLE 82000-82002(1)	138.3	160.2	115.8
82000	AFAM 1-2-3	82002	AFAM IV	1	SINGLE 82000-82002(2)	138.3	160.2	115.8
52015	ZARIA 1	52016	FUNTUA 1	1	SINGLE 32016-52004(1)	99.3	110.4	111.2
82005	EKET 1	82024	IBOM IPP 1	2	SINGLE 82005-82024(1)	150.4	166.5	110.7
82005	EKET 1	82024	IBOM IPP 1	1	SINGLE 82005-82024(2)	150.4	166.5	110.7

Source: JICA Study Team

7-4-3-2 2020 Wet Season Peak case-ACCC

The base case and N-1 contingency analysis results are shown in Table 7-4.17.

Table 7-4.17 2020 Wet Season Peak - Overloaded Lines (base case and under N-1)

Bus Number	Bus Name	Bus Number	Bus Name	cct	Contingency Label	Rating (MVA)	Flow (MVA)	Loading (%)
330 kV System								
None								
132 kV System								
82024	IBOM IPP 1	82031	IKOT_ABASI	1	BASE CASE	125.7	182.6	145.2
82019	OMOKU 1	82036	RUMUSOI 1	1	SINGLE 82019-82036(2)	138.3	220	159.1
42000	AJAOKUTA 1	42009	OKENE 1	1	SINGLE 42004-42008(1)	138.3	208.8	151
42004	BENIN 1	42008	IRRUA 1	1	SINGLE 42000-42009(1)	138.3	201.9	146
22002	OSOGBO 4T2	22008	IWO 1	1	SINGLE 22000-22006(1)	138.3	200.8	145.2
52033	MANDO T4A BB	52035	KUDENDA 1	2	SINGLE 52033-52035(1)	138.3	200.2	144.8
52033	MANDO T4A BB	52035	KUDENDA 1	1	SINGLE 52033-52035(2)	138.3	200.2	144.8
82017	YENAGOA 1	82022	GBARAIN UBIE	2	SINGLE 82017-82022(1)	138.3	191.2	138.3
82017	YENAGOA 1	82022	GBARAIN UBIE	1	SINGLE 82017-82022(2)	138.3	191.2	138.3
12003	IKEJA W 1BB1	12019	ALIMOSHO 1	2	SINGLE 12003-12019(1)	138.3	180	130.1

Bus Number	Bus Name	Bus Number	Bus Name	cct	Contingency Label	Rating (MVA)	Flow (MVA)	Loading (%)
12003	IKEJA W 1BB1	12019	ALIMOSHO 1	1	SINGLE 12003-12019(2)	138.3	180	130.1
62009	BIU 1	62026	DADINKOWA 1	1	SINGLE 63005-63007(1)	76.7	98.1	128
22000	AYEDE 1	22006	IBADAN NORTH	1	SINGLE 22002-22008(1)	138.3	172.9	125
82017	YENAGOA 1	82018	AHOADA 1	2	SINGLE 82017-82018(1)	138.3	171.5	124
82017	YENAGOA 1	82018	AHOADA 1	1	SINGLE 82017-82018(2)	138.3	171.5	124
82005	EKET 1	82024	IBOM IPP 1	1	SINGLE 82024-82031(1)	150.4	184.5	122.7
82005	EKET 1	82024	IBOM IPP 1	2	SINGLE 82024-82031(1)	150.4	184.5	122.7
82007	PHCT MAIN1	82036	RUMUSOI 1	2	SINGLE 82007-82036(1)	138.3	167.1	120.8
82007	PHCT MAIN1	82036	RUMUSOI 1	1	SINGLE 82007-82036(2)	138.3	167.1	120.8
82000	AFAM 1-2-3	82002	AFAM IV	2	SINGLE 82000-82002(1)	138.3	160.2	115.8
82000	AFAM 1-2-3	82002	AFAM IV	1	SINGLE 82000-82002(2)	138.3	160.2	115.8
23002	OMOTOSHO3	43002	BENIN 3	2	SINGLE 23002-43002(1)	855.1	948.8	111
23002	OMOTOSHO3	43002	BENIN 3	1	SINGLE 23002-43002(2)	855.1	948.8	111
82005	EKET 1	82024	IBOM IPP 1	2	SINGLE 82005-82024(1)	150.4	166.4	110.6
82005	EKET 1	82024	IBOM IPP 1	1	SINGLE 82005-82024(2)	150.4	166.4	110.6
52015	ZARIA 1	52016	FUNTUA 1	1	SINGLE 32016-52004(1)	99.3	106.3	107
82013	ONNE 1	82040	TRAMADI	2	SINGLE 82013-82040(1)	138.3	139.6	100.9
82013	ONNE 1	82040	TRAMADI	1	SINGLE 82013-82040(2)	138.3	139.6	100.9

Source: JICA Study Team

7-4-3-3 2020 Dry Season Off-Peak Case-ACCC

The base case and N-1 contingency analysis results are shown in Table 7-4.18. The 330 kV lines overloaded under N-1 are shown in red fonts.

Table 7-4.18 2020 Dry Season Off-Peak - Overloaded Lines (base case and under N-1)

Bus Number	Bus Name	Bus Number	Bus Name	cct	Contingency Label	Rating (MVA)	Flow (MVA)	Loading (%)
330 kV								
23002	OMOTOSHO3	43002	BENIN 3	2	SINGLE 23002-43002(1)	855.1	1,081.6	126.5
23002	OMOTOSHO3	43002	BENIN 3	1	SINGLE 23002-43002(2)	855.1	1,081.6	126.5
132 kV								
82024	IBOM IPP 1	82031	IKOT_ABASI	1	BASE CASE	125.7	189.6	150.9
62000	GOMBE 1	62013	T_JUNCTION 1	1	SINGLE 63000-63002(1)	76.7	151.3	197.2
82019	OMOKU 1	82036	RUMUSOI 1	2	SINGLE 82019-82036(1)	138.3	213.6	154.5
82019	OMOKU 1	82036	RUMUSOI 1	1	SINGLE 82019-82036(2)	138.3	213.6	154.5
62003	YOLA 1	62013	T_JUNCTION 1	1	SINGLE 63000-63002(1)	76.7	114.4	149.2
52033	MANDO T4A BB	52035	KUDENDA 1	2	SINGLE 52033-52035(1)	138.3	202.6	146.5
52033	MANDO T4A BB	52035	KUDENDA 1	1	SINGLE 52033-52035(2)	138.3	202.6	146.5
82017	YENAGOA 1	82022	GBARAIN UBIE	2	SINGLE 82017-82022(1)	138.3	191.5	138.5
82017	YENAGOA 1	82022	GBARAIN UBIE	1	SINGLE 82017-82022(2)	138.3	191.5	138.5
82000	AFAM 1-2-3	82002	AFAM IV	2	SINGLE 82000-82002(1)	138.3	181.4	131.1
82000	AFAM 1-2-3	82002	AFAM IV	1	SINGLE 82000-82002(2)	138.3	181.4	131.1
22002	OSOGBO 4T2	22008	IWO 1	1	SINGLE 22000-22006(1)	138.3	175.5	126.9
62009	BIU 1	62026	DADINKOWA 1	1	SINGLE 63005-63007(1)	76.7	97.0	126.5
82017	YENAGOA 1	82018	AHOADA 1	2	SINGLE 82017-82018(1)	138.3	174.5	126.2
82017	YENAGOA 1	82018	AHOADA 1	1	SINGLE 82017-82018(2)	138.3	174.5	126.2
82005	EKET 1	82024	IBOM IPP 1	1	SINGLE 82024-82031(1)	150.4	185.3	123.2
82005	EKET 1	82024	IBOM IPP 1	2	SINGLE 82024-82031(1)	150.4	185.3	123.2
42000	AJAKUTA 1	42009	OKENE 1	1	SINGLE 42004-42008(1)	138.3	169.9	122.9
82007	PHCT MAIN1	82036	RUMUSOI 1	2	SINGLE 82007-82036(1)	138.3	169.5	122.5

Bus Number	Bus Name	Bus Number	Bus Name	cct	Contingency Label	Rating (MVA)	Flow (MVA)	Loading (%)
82007	PHCT MAIN1	82036	RUMUSOI 1	1	SINGLE 82007-82036(2)	138.3	169.5	122.5
42004	BENIN 1	42008	IRRUA 1	1	SINGLE 42000-42009(1)	138.3	169.1	122.3
82013	ONNE 1	82040	TRAMADI	2	SINGLE 82013-82040(1)	138.3	157.5	113.9
82013	ONNE 1	82040	TRAMADI	1	SINGLE 82013-82040(2)	138.3	157.5	113.9
12003	IKEJA W 1BB1	12019	ALIMOSHO 1	2	SINGLE 12003-12019(1)	138.3	153.1	110.7
12003	IKEJA W 1BB1	12019	ALIMOSHO 1	1	SINGLE 12003-12019(2)	138.3	153.1	110.7
82005	EKET 1	82024	IBOM IPP 1	2	SINGLE 82005-82024(1)	150.4	155	103.1
82005	EKET 1	82024	IBOM IPP 1	1	SINGLE 82005-82024(2)	150.4	155	103.1
22000	AYEDE 1	22006	IBADAN NORTH	1	SINGLE 22002-22008(1)	138.3	142.4	103

Source: JICA Study Team

7-4-3-4 2020 Wet Season Off-Peak case-ACCC

The base case and N-1 contingency analysis results are shown in Table 7-4.19. The 330 kV lines overloaded under N-1 are shown in red fonts.

Table 7-4.19 2020 Wet Season Off- peak - Overloaded Lines (base case and under N-1)

Bus Number	Bus Name	Bus Number	Bus Name	cct	Contingency Label	Rating (MVA)	Flow (MVA)	Loading (%)
330 kV System								
23002	OMOTOSHO3	43002	BENIN 3	2	SINGLE 23002-43002(1)	855.1	944.4	110.4
23002	OMOTOSHO3	43002	BENIN 3	1	SINGLE 23002-43002(2)	855.1	944.4	110.4
132 kV System								
82024	IBOM IPP 1	82031	IKOT_ABASI	1	BASE CASE	125.7	189.4	150.7
62000	GOMBE 1	62013	T_JUNCTION 1	1	SINGLE 63000-63002(1)	76.7	153.2	199.7
62003	YOLA 1	62013	T_JUNCTION 1	1	SINGLE 63000-63002(1)	76.7	116.3	151.6
52033	MANDO T4A BB	52035	KUDENDA 1	2	SINGLE 52033-52035(1)	138.3	202.5	146.4
52033	MANDO T4A BB	52035	KUDENDA 1	1	SINGLE 52033-52035(2)	138.3	202.5	146.4
62009	BIU 1	62026	DADINKOWA 1	1	SINGLE 63005-63007(1)	76.7	98.2	128.1
22002	OSOGBO 4T2	22008	IWO 1	1	SINGLE 22000-22006(1)	138.3	175.5	126.9
42004	BENIN 1	42008	IRRUA 1	1	SINGLE 42000-42009(1)	138.3	171.2	123.8
82005	EKET 1	82024	IBOM IPP 1	1	SINGLE 82024-82031(1)	150.4	184.6	122.7
82005	EKET 1	82024	IBOM IPP 1	2	SINGLE 82024-82031(1)	150.4	184.6	122.7
42000	AJAKUTA 1	42009	OKENE 1	1	SINGLE 42004-42008(1)	138.3	169.4	122.5
82007	PHCT MAIN1	82014	RIVERS_IPP	2	SINGLE 82007-82014(1)	138.3	155.2	112.2
82007	PHCT MAIN1	82014	RIVERS_IPP	1	SINGLE 82007-82014(2)	138.3	155.2	112.2
12003	IKEJA W 1BB1	12019	ALIMOSHO 1	2	SINGLE 12003-12019(1)	138.3	153.8	111.2
12003	IKEJA W 1BB1	12019	ALIMOSHO 1	1	SINGLE 12003-12019(2)	138.3	153.8	111.2
82005	EKET 1	82024	IBOM IPP 1	2	SINGLE 82005-82024(1)	150.4	156.7	104.2
82005	EKET 1	82024	IBOM IPP 1	1	SINGLE 82005-82024(2)	150.4	156.7	104.2
22000	AYEDE 1	22006	IBADAN NORTH	1	SINGLE 22002-22008(1)	138.3	142.4	103.0

Source: JICA Study Team

7-4-4 Summary of Results of Load-flow Analysis for 2020

The results of the static security analysis for 2020 are summarized as follows:

7-4-4-1 Overloaded 330 and 132 kV Transmission Lines

There are no overloads in 330 kV lines under normal operation. However, when tripping the 330 kV lines from Gombe to Yola and Damaturu, the load-flow case did not converge, as expected, due to the absence of

a second parallel circuit and insufficient support from alternative routes. Converting to a Double-Circuit will resolve these issues.

Under N-1, if any of the following 132 kV lines are tripped, the case will also not converge:

From BKebbi to KVK Power PV

From Zaria to Funtua

These 132 kV N-1 cases will have to be resolved by providing new alternative routes for the power flow.

Priority is to resolve the overloads occurring under normal (N-0) operation of the 132 kV lines shown in Table 7-4.20.

Table 7-4.20 Reinforcements of 132 kV lines overloaded under N-0

Bus Name	Bus Name	Proposed Solution
Ibom IPP	Ikot Abasi	convert to DC

Source: JICA Study Team

As a next priority, the overloaded 330 and 132 kV lines under N-1 contingencies must be reinforced. This entails either reconductoring to higher rating conductors or, in the case of SC, converting to DC by installing a second parallel circuit.

The lines in Table 7-4.21 are ranked according to their percentage overload. The table lists the worst scenarios in terms of overloads, out of the four study cases (DP, DoP, WP, WoP). The shaded lines are DC lines for which reconductoring is recommended. The 330 kV lines overloaded under N-1 are shown in red fonts.

Table 7-4.21 Reinforcements of 330 and 132 kV lines overloaded under N-1

Bus Number	Bus Name	Bus Number	Bus Name	cct	Contingency Label	Rating (MVA)	Flow (MVA)	Loading (%)
330 kV								
23002	OMOTOSHO3	43002	BENIN 3	cct1	SINGLE 23002-43002(1)	855.1	1,081.6	126.5
23002	OMOTOSHO3	43002	BENIN 3	cct2	SINGLE 23002-43002(2)	855.1	1,081.6	126.5
132 kV								
82024	IBOM IPP 1	82031	IKOT_ABASI	1	BASE CASE	125.7	189.6	150.9
62000	GOMBE 1	62013	T_JUNCTION 1	1	SINGLE 63000-63002(1)	76.7	151.3	197.2
82019	OMOKU 1	82036	RUMUSOI 1	1	SINGLE 82019-82036(2)	138.3	220	159.1
82019	OMOKU 1	82036	RUMUSOI 1	2	SINGLE 82019-82036(1)	138.3	213.6	154.5
42000	AJAOKUTA 1	42009	OKENE 1	1	SINGLE 42004-42008(1)	138.3	211.5	152.9
62003	YOLA 1	62013	T_JUNCTION 1	1	SINGLE 63000-63002(1)	76.7	116.3	151.6
42004	BENIN 1	42008	IRRUA 1	1	SINGLE 42000-42009(1)	138.3	203.5	147.1
52033	MANDO T4A BB	52035	KUDENDA 1	2	SINGLE 52033-52035(1)	138.3	202.6	146.5
52033	MANDO T4A BB	52035	KUDENDA 1	1	SINGLE 52033-52035(2)	138.3	202.6	146.5
22002	OSOGBO 4T2	22008	IWO 1	1	SINGLE 22000-22006(1)	138.3	201.9	146
82017	YENAGOA 1	82022	GBARAIN UBIE	2	SINGLE 82017-82022(1)	138.3	191.5	138.5
82017	YENAGOA 1	82022	GBARAIN UBIE	1	SINGLE 82017-82022(2)	138.3	191.5	138.5
82000	AFAM 1-2-3	82002	AFAM IV	2	SINGLE 82000-82002(1)	138.3	181.4	131.1
82000	AFAM 1-2-3	82002	AFAM IV	1	SINGLE 82000-82002(2)	138.3	181.4	131.1
12003	IKEJA W 1BB1	12019	ALIMOSHO 1	2	SINGLE 12003-12019(1)	138.3	180	130.1
12003	IKEJA W 1BB1	12019	ALIMOSHO 1	1	SINGLE 12003-12019(2)	138.3	180	130.1

Bus Number	Bus Name	Bus Number	Bus Name	cct	Contingency Label	Rating (MVA)	Flow (MVA)	Loading (%)
62009	BIU 1	62026	DADINKOWA 1	1	SINGLE 63005-63007(1)	76.7	98.2	128.1
82017	YENAGOA 1	82018	AHOADA 1	2	SINGLE 82017-82018(1)	138.3	174.5	126.2
82017	YENAGOA 1	82018	AHOADA 1	1	SINGLE 82017-82018(2)	138.3	174.5	126.2
22000	AYEDE 1	22006	IBADAN NORTH	1	SINGLE 22002-22008(1)	138.3	172.9	125
82005	EKET 1	82024	IBOM IPP 1	1	SINGLE 82024-82031(1)	150.4	184.5	122.7
82005	EKET 1	82024	IBOM IPP 1	2	SINGLE 82024-82031(1)	150.4	184.5	122.7
82007	PHCT MAIN1	82036	RUMUSOI 1	2	SINGLE 82007-82036(1)	138.3	169.5	122.5
82007	PHCT MAIN1	82036	RUMUSOI 1	1	SINGLE 82007-82036(2)	138.3	169.5	122.5
82013	ONNE 1	82040	TRAMADI	2	SINGLE 82013-82040(1)	138.3	157.5	113.9
82013	ONNE 1	82040	TRAMADI	1	SINGLE 82013-82040(2)	138.3	157.5	113.9
82007	PHCT MAIN1	82014	RIVERS_IPP	2	SINGLE 82007-82014(1)	138.3	155.2	112.2
82007	PHCT MAIN1	82014	RIVERS_IPP	1	SINGLE 82007-82014(2)	138.3	155.2	112.2
52015	ZARIA 1	52016	FUNTUA 1	1	SINGLE 32016-52004(1)	99.3	110.4	111.2

Source: JICA Study Team

Note: It should be noted that with regard to the overloaded 330 kV lines in 2020 (Benin-Omosho), remedial actions are already planned and these lines will not be overloaded in 2025, as shown in Section 7.5.

7-4-4-2 Overloaded Transformers

(1) Overloads above 100% of transformer ratings

The 330/132 kV 3-W and A/T transformers overloaded above their 100% rating MVA under normal (base case) operation, listed in Table 7-4.22, must be upgraded:

Table 7-4.22 Upgrading requirements of 330/132 kV 3-winding transformers overloaded under N-0

Bus Number	Bus Name	Voltage (kV)	Bus Name	Loading (MVA)	Rating (MVA)	Loading (%)
330/132 kV 3-W transformers						
43002	BENIN 3	330	BENIN TR3	156	150	145.6
43011	B.NORTH_3	330	BENIN 9T1	88	67.5	131.6
33002	BKEBBI 3	330	B_KEBBI T1	176.9	150	118
23003	GANMO 3	330	GANMO TR2A	157.4	150	104.9
43002	BENIN 3	330	BENIN TR1	156	150	104
43002	BENIN 3	330	BENIN TR2	156	150	104

Source: JICA Study Team

The 132/33 kV and 132/11 kV transformers overloaded above their 100% rating MVA under normal (base case) operation, listed in Table 7-4.23, must be upgraded:

Table 7-4.23 Upgrading requirements of 132/33 kV and 132/11 kV 2W transformers overloaded under N-0

Bus Number	Bus Name	Voltage (kV)	Bus Number	Bus Name	Voltage (kV)	Loading (MVA)	Rating (MVA)	Loading (%)
132/33 and 132/11 kV 2-W transformers								
32017	SULEJA 1	132	36016	SULEJA 11	11	18.6	7.5	247.6
42004	BENIN 1	132	45029	BENIN T22 33	33	85.9	60	143.1
52001	KANO 1	132	55058	KUMB T3 MOB	33	41.9	30	139.6
42004	BENIN 1	132	45031	BENIN T24 33	33	82.9	60	138.1
42004	BENIN 1	132	45030	BENIN T23 33	33	80.9	60	134.8
52016	FUNTUA 1	132	56000	FUNTUA 11	11	9.6	7.5	127.6
42005	B_NORTH 1	132	45015	B_NORTH_33	33	73.9	60	123.2

Bus Number	Bus Name	Voltage (kV)	Bus Number	Bus Name	Voltage (kV)	Loading (MVA)	Rating (MVA)	Loading (%)
22015	OMUARAN 1	132	25016	OMUARAN 33	33	33.4	30	111.4
52016	FUNTUA 1	132	55003	FUNTUA 33	33	33	30	109.9
52016	FUNTUA 1	132	56005	FUNTUA T2	11	7.9	7.5	105.9
22013	OFFA 1	132	25015	OFFA 33	33	31.8	30	105.8
12029	OJO 1	132	15030	OJO 33	33	30.4	30	101.4

Source: JICA Study Team

(2) Overloads above 85% of transformer ratings

Table 7-4.24 shows 330/132 kV, 132/33 kV and 132/11 kV transformers which are overloaded above their 85% rating MVA under normal (base case) operation and shall be considered for upgrading.

Table 7-4.24 Upgrading requirements of 330/132 kV, 132/33 kV and 132/11 kV transformers overloaded over 85% under N-0

Bus Number	Bus Name	Voltage (kV)	Bus Number	Bus Name	Voltage (kV)	cct	Load (MVA)	Rating (MVA)	Loading (%)
330/132 kV Transformers 3-W									
52001	KANO 1	132	3WNDTR	KANO T3A	WND 2	1	112.3	120	93.6
42005	B_NORTH 1	132	3WNDTR	BENIN 9T1	WND 1	1	82.8	90	92
132/33 kV and 132/11 kV Transformers									
82005	EKET 1	132	85002	EKET T1B	33	1	43.7	45	97.2
12055	ODOGUNYAN 1	132	15063	ODOGUNYA 33	33	1	57.9	60	96.5
12055	ODOGUNYAN 1	132	15063	ODOGUNYA 33	33	2	57.9	60	96.5
22022	GANMO T1 BB	132	25032	GANMO T1	33	1	57.1	60	95.2
12023	EJIGBO 1	132	15128	EJIGBO 33	33	1	28.4	30	94.5
12023	EJIGBO 1	132	15128	EJIGBO 33	33	2	28.4	30	94.5
12029	OJO 1	132	15047	OJO T3_T4	33	5	55.8	60	92.9
12019	ALIMOSHO 1	132	15072	ALIMOSHO T1	33	3	27.5	30	91.8
42002	UGHELLI 1	132	45001	UGHELLI 33	33	1	53.6	60	89.3
12037	PARAS_1	132	15116	AFR FOUNDRY	33	1	35.6	40	89
22027	SHAGAMU 1	132	25035	SHAGAMU 33	33	1	26.5	30	88.3
82000	AFAM 1-2-3	132	86000	AFAM 11	11	1	55.1	64	86.1
22008	IWO 1	132	25002	IWO 33	33	1	12.9	15	85.9
22008	IWO 1	132	25002	IWO 33	33	2	34.3	40	85.9
82005	EKET 1	132	85002	EKET T1B	33	1	43.7	45	97.2

Source: JICA Study Team

7-4-4-3 Undervoltages Under N-1 Conditions

In all N-1 contingencies, a number of 132 kV voltages are lower than the minimum permissible level of 0.8p.u. However, this is due to overloads of the associated 132 kV lines and transformers and the remedial actions for the undervoltages (U/V) is linked with the solutions required first for overloads of these circuits, as well as with the implementation of reactive power compensation equipment.

The reactive power requirements, i.e. the need to have existing reactors and capacitors in operation and/or install new ones by 2020, including the need for new SVCs, are summarized in the following sections:

(1) SVC requirements

No SVC at Gombe is necessary by 2020.

(2) Reactors

The status of reactors required in the Dry Season Peak case is shown in Table 7-4.25. It can be seen that only reactors at Gombe, Yola and Maiduguri are required. The new equipment required is shown in bold:

Table 7-4.25 Reactor requirements for 2020 Dry Season Peak

Bus Number	Bus Name	Voltage (kV)	Id	In Service	B-Shunt (MVar)
63005	MAIDUGURI 3	330.00	2	1	-75.00
63002	YOLA 3	330.00	1	1	-75.00
63002	YOLA 3	330.00	2	1	-75.00
63000	GOMBE 3	330.00	1	1	-50.00
63000	GOMBE 3	330.00	2	1	-50.00
65001	YOLA T1	33.000	1	1	-30.00
65014	GOMBE T4A	33.000	1	1	-30.00

Source: JICA Study Team

The status of reactors required in Dry Season Off-Peak and in Wet Season Off-Peak cases is shown in Table 7-4.26. The new equipment required is shown in bold:

Table 7-4.26 Reactor requirements for 2020 dry and wet season off-peak

Bus Number	Bus Name	Voltage (kV)	Id	In Service	B-Shunt (MVar)
53001	KANO 3	330	1	1	-75
63001	JOS 3	330	1	1	-75
63002	YOLA 3	330	1	1	-75
63002	YOLA 3	330	2	1	-75
63005	MAIDUGURI 3	330	2	1	-75
63000	GOMBE 3	330	1	1	-50
63000	GOMBE 3	330	2	1	-50
65001	YOLA T1	33	1	1	-30
65014	GOMBE T4A	33	1	1	-30

Source: JICA Study Team

(3) Capacitors

The status of capacitors required in the Dry Season Peak case is shown in Table 7-4.27. The new equipment required is shown in bold:

Table 7-4.27 Capacitor requirements for 2020 Dry Season Peak

Bus Number	Bus Name	Voltage (kV)	Id	In Service	Capacity (MVar)
62021	MAIDUGURI 1	132	1	1	10.8
52022	HADEJIA 1	132	1	1	20
22017	ONDO2 1	132	1	1	24
42008	IRRUA 1	132	1	1	24
52011	GUSAU 1	132	1	1	50
12004	AKANGBA BBII	132	1	1	72

Bus Number	Bus Name	Voltage (kV)	Id	In Service	Capacity (MVar)
15002	AGBARA 33	33	1	1	20
15022	IKORODU 33	33	2	1	20
15027	ILUPEJU 33	33	1	1	20
25018	AKURE T3A 33	33	1	1	20
45003	OKENE 33	33	1	1	20
55001	DAN AGUNDI 3	33	2	1	20
55010	KATSINA 33	33	1	1	20
15037	NEW ABEOK 33	33	1	1	20
25004	AYEDE 33	33	1	1	20
25012	ISEYIN 33	33	1	1	20
25035	SHAGAMU 33	33	1	1	20
25038	IJEBU-ODE 33	33	1	1	20
15006	AKANGBA 33	33	1	1	24
15007	AKOKA T1 33	33	1	1	24
15009	ALAUUSA 33	33	1	1	24
15010	ALIMOSHO 33	33	1	1	24
15014	EJIGBO 33	33	1	1	24
15015	IJORA 33	33	1	1	24
15018	OGBA 33	33	1	1	24
15028	ISOLO 33	33	1	1	24
15128	EJIGBO 33	33	1	1	24
15079	OTTA T2	33	1	1	24
15080	OLD ABEOK T2	33	3	1	24
25011	ILORIN 33	33	1	1	24

Source: JICA Study Team

The status of capacitors required in Dry Season Off-Peak case is shown in Table 7-4.28.

Table 7-4.28 Capacitor requirements for 2020 Dry Season Off-Peak

Bus Number	Bus Name	Voltage (kV)	Id	In Service	Capacity (MVar)
62021	MAIDUGURI 1	132	1	1	10.8
52022	HADEJIA 1	132	1	1	20
22017	ONDO2 1	132	1	1	24
42008	IRRUA 1	132	1	1	24
52011	GUSAU 1	132	1	1	50
12004	AKANGBA BBII	132	1	1	72
15002	AGBARA 33	33	1	1	20
15022	IKORODU 33	33	2	1	20
15027	ILUPEJU 33	33	1	1	20
15037	NEW ABEOK 33	33	1	1	20
25004	AYEDE 33	33	1	1	20
25012	ISEYIN 33	33	1	1	20
25018	AKURE T3A 33	33	1	1	20
25035	SHAGAMU 33	33	1	1	20
25038	IJEBU-ODE 33	33	1	1	20
45003	OKENE 33	33	1	1	20
55001	DAN AGUNDI 3	33	2	1	20
55010	KATSINA 33	33	1	1	20
15006	AKANGBA 33	33	1	1	24

Bus Number	Bus Name	Voltage (kV)	Id	In Service	Capacity (MVar)
15007	AKOKA T1 33	33	1	1	24
15009	ALAUSA 33	33	1	1	24
15010	ALIMOSHO 33	33	1	1	24
15014	EJIGBO 33	33	1	1	24
15015	IJORA 33	33	1	1	24
15018	OGBA 33	33	1	1	24
15028	ISOLO 33	33	1	1	24
15079	OTTA T2	33	1	1	24
15080	OLD ABEOK T2	33	3	1	24
15128	EJIGBO 33	33	1	1	24
25011	ILORIN 33	33	1	1	24

Source: JICA Study Team

7-4-4-4 Power Factor Correction at DisCo's Level

With reference to the Grid Code requirements (ref. article 15.6 on Demand power factor corrections and 16.7 on the provision of voltage control stating that The Off-takers shall maintain a power factor not less than 0.95 at the Connection Point), since the resulting power factor of loads connected at 33 kV level and below is less than the 0.95 required, all DisCos shall be required to undertake a program of having capacitors installed at distribution level to ensure the power factor at all 33 kV S/S is not less than 0.9 by 2020 and 0.95 by 2025, in line with the Grid Code requirements. (Note: the loads in the 2025 model however have been based on a conservative power factor of 0.92 and only the 2030 loads have a pf of 0.95)

7-4-5 Expansion Plan for 2020

7-4-5-1 Transmission Lines

As shown in the SLDs of Annexes 7.4.1 and 7.4.2, the transmission lines shown in Table 7-4.29 must be implemented by 2020 or as soon as possible thereafter. Line Nos. 1 to 5 in Table 7-4.29 require reconductoring only. A priority ranking from 1 to 3 has been included in this table, with 1 denoting the highest priority.

Table 7-4.29 New transmission lines required by 2020

No		From	To		kV	km	Remarks	Priority/ Ranking
1	Part of North-East Ring	Damaturu	Maiduguri	DC	330	260	An SC already exists.	1
2		Gombe	Damaturu	DC	330	180	An SC already exists.	1
3		Gombe	Yola	DC	330	240	An SC already exists.	1
4		Yola	Jalingo	DC	330	160	Can be delayed beyond 2020 but ASAP thereafter. One circuit via Mayo Belwa.	3
5		Jos	Gombe	DC	330	270	Via Bauchi. Should be completed by 2020 or ASAP thereafter. A SC already exists.	1
6	Part of North-West ring	Kainji	Birnin-Kebbi	DC	330	310	An SC already exists. Needs to be expedited by 2020 if possible or ASAP thereafter.	3
7		Kaduna	Kano	DC	330	230	Undertaken by TCN as part of the NTEP to be financed by IDB. Needs to be expedited by 2020 if possible or ASAP thereafter.	2
8		Akangba	Ijora	DC	330	14	A 330kV substation at Ijora and associated 330kV lines are necessary after 2020, but since they remove in 2020 the overloads at 132kV Ijora-Alagbon line and improve voltage profile in the area, it is recommended to implement as soon as possible after 2020.	2
9		Ijora	Alagbon	DC	330	8		2
10		Arigbajo	New Agbara	DC	330	40	If not undertaken by JICA. Not considered necessary for 2020, as it is lightly loaded. However, it is necessary for meeting the N-1 criterion for the export lines to Sakete.	2
11		Ugwaji	Abakaliki	DC	330	85		1
12		Osogbo	Arigbajo	DC	330	183	If not undertaken by JICA.	1
13		Ayede	Ibadan North	DC	132	15	An SC exists. A second circuit in parallel is needed.	1
14		New Agbara	Agbara	DC	132	18		2
15		Ogijo	Redeem	DC	132	14	If not undertaken by JICA.	2
16		Birmin Kebbi	Dosso	DC	132	128	An SC already exists.	2

Source: JICA Study Team

Notes:

- The lines recommended for the North-East ring above must comply with the N-1 static security criterion, as well as improving the voltage stability of the area. It is recognized however that in implementation terms it will be challenging to complete it all by 2020. However, if it is not possible to implement by 2020, they should be implemented as soon as possible thereafter within the period 2020-2025, based on which the investment plan detailed in Section 9 has been drawn up.
- The JICA project of new 330 kV lines (DC) from Ogijo to Arigbajo is not considered necessary in 2020, as it is lightly loaded under all scenarios (it will be required, though, in 2025).
- The JICA project of new 330 kV lines (DC) from Arigbajo to New Agbara is not considered necessary for 2020, as it is lightly loaded. It is necessary only for meeting the N-1 criterion for the export lines to Sakete.

As shown in Section 8, the first priority is to resolve the overloads occurring under normal (N-0) operation of the following 132 kV lines shown in Table 7-4.30:

Table 7-4.30 Reinforcements of 132 kV lines overloaded under N-0

From	To	Proposed solution
Ibom IPP	Ikot Abasi	Convert to DC

Source: JICA Study Team

As a next priority, the overloaded 330 and 132 kV lines under N-1 contingencies must be reinforced. This entails either reconductoring to higher rating conductors or, in case of SC, conversion to DC by installing a second parallel circuit.

The lines in Table 7-4.31 are ranked according to their percentage overload. The shaded lines are DC lines for which reconductoring is recommended.

Table 7-4.31 Reinforcements of 132 kV lines overloaded under N-1

FROM Bus No.	Bus name	TO Bus No.	Bus name	cct	Contingency label	Rating (MVA)	Flow (MVA)	Loading (%)
330 kV								
23002	OMOTOSHO3	43002	BENIN 3	cct1	SINGLE 23002-43002(1)	855.1	1081.6	126.5
23002	OMOTOSHO3	43002	BENIN 3	cct2	SINGLE 23002-43002(2)	855.1	1081.6	126.5
132 kV								
82024	IBOM IPP 1	82031	IKOT_ABASI	1	BASE CASE	125.7	189.6	150.9
62000	GOMBE 1	62013	T_JUNCTION 1	1	SINGLE 63000-63002(1)	76.7	151.3	197.2
82019	OMOKU 1	82036	RUMUSOI 1	1	SINGLE 82019-82036(2)	138.3	220	159.1
82019	OMOKU 1	82036	RUMUSOI 1	2	SINGLE 82019-82036(1)	138.3	213.6	154.5
42000	AJAKUTA 1	42009	OKENE 1	1	SINGLE 42004-42008(1)	138.3	211.5	152.9
62003	YOLA 1	62013	T_JUNCTION 1	1	SINGLE 63000-63002(1)	76.7	116.3	151.6
42004	BENIN 1	42008	IRRUA 1	1	SINGLE 42000-42009(1)	138.3	203.5	147.1
52033	MANDO T4A BB	52035	KUDENDA 1	2	SINGLE 52033-52035(1)	138.3	202.6	146.5
52033	MANDO T4A BB	52035	KUDENDA 1	1	SINGLE 52033-52035(2)	138.3	202.6	146.5
22002	OSOGBO 4T2	22008	IWO 1	1	SINGLE 22000-22006(1)	138.3	201.9	146
82017	YENAGOA 1	82022	GBARAIN UBIE	2	SINGLE 82017-82022(1)	138.3	191.5	138.5
82017	YENAGOA 1	82022	GBARAIN UBIE	1	SINGLE 82017-82022(2)	138.3	191.5	138.5
82000	AFAM 1-2-3	82002	AFAM IV	2	SINGLE 82000-82002(1)	138.3	181.4	131.1
82000	AFAM 1-2-3	82002	AFAM IV	1	SINGLE 82000-82002(2)	138.3	181.4	131.1
12003	IKEJA W 1BB1	12019	ALIMOSHO 1	2	SINGLE 12003-12019(1)	138.3	180	130.1
12003	IKEJA W 1BB1	12019	ALIMOSHO 1	1	SINGLE 12003-12019(2)	138.3	180	130.1
62009	BIU 1	62026	DADINKOWA 1	1	SINGLE 63005-63007(1)	76.7	98.2	128.1
82017	YENAGOA 1	82018	AHOADA 1	2	SINGLE 82017-82018(1)	138.3	174.5	126.2
82017	YENAGOA 1	82018	AHOADA 1	1	SINGLE 82017-82018(2)	138.3	174.5	126.2
22000	AYEDE 1	22006	IBADAN NORTH	1	SINGLE 22002-22008(1)	138.3	172.9	125
82005	EKET 1	82024	IBOM IPP 1	1	SINGLE 82024-82031(1)	150.4	184.5	122.7
82005	EKET 1	82024	IBOM IPP 1	2	SINGLE 82024-82031(1)	150.4	184.5	122.7
82007	PHCT MAIN1	82036	RUMUSOI 1	2	SINGLE 82007-82036(1)	138.3	169.5	122.5
82007	PHCT MAIN1	82036	RUMUSOI 1	1	SINGLE 82007-82036(2)	138.3	169.5	122.5
82013	ONNE 1	82040	TRAMADI	2	SINGLE 82013-82040(1)	138.3	157.5	113.9
82013	ONNE 1	82040	TRAMADI	1	SINGLE 82013-82040(2)	138.3	157.5	113.9
82007	PHCT MAIN1	82014	RIVERS_IPP	2	SINGLE 82007-82014(1)	138.3	155.2	112.2
82007	PHCT MAIN1	82014	RIVERS_IPP	1	SINGLE 82007-82014(2)	138.3	155.2	112.2
52015	ZARIA 1	52016	FUNTUA 1	1	SINGLE 32016-52004(1)	99.3	110.4	111.2

Source: JICA Study Team

Note: It should be noted that with regard to the overloaded 330 kV lines in 2020 (Benin-Omotosho), remedial actions are already planned and these lines will not be overloaded in 2025.

7-4-5-2 Transformers

- The upgrading of 6 x 330/132 kV 3-W and A/T transformers which are overloaded above their 100% rating MVA under normal (base case) operation, is required, as listed in Table 7-4.22.
- The upgrading of 12 x 132/33 kV and 132/11 kV transformers which are overloaded above their 100% rating MVA under normal (base case) operation, is required, as listed in Table 7-4.23.
- The upgrading of the following types of transformers overloaded above their 85% rating MVA under normal (base case) operation shall be upgraded, as listed in Table 7-4.24:
 - a) 2 x 330/132 kV 3-w and A/T,
 - b) 15 x 132/33 kV and 132/11 kV transformers

7-4-5-3 Reactive Power Compensation

(1) SVC requirements

No SVC at Gombe is necessary by 2020.

(2) Reactors

The new reactors required in the Dry Season Peak and Dry Season Off-Peak cases are shown in Table 7-4.32. Only reactors at Gombe, Yola and Maiduguri must be in operation. The new reactor at Maiduguri is shown in bold:

Table 7-4.32 Reactor requirements for 2020

Bus Number	Bus Name	Voltage (kV)	Id	In Service	B-Shunt (MVar)
63005	MAIDUGURI 3 330.00	330	2	1	-75.00

Source: JICA Study Team

(3) Capacitors

The new capacitors required in the Dry Season Peak, *Dry Season Off-Peak* and *Wet Season Off-Peak* cases are shown in Table 7-4.33:

Table 7-4.33 Capacitor requirements for 2020

Bus Number	Bus Name	Voltage (kV)	Id	In Service	B-Shunt (MVar)
22017	ONDO2 1	132	1	1	24
42008	IRRUA 1	132	1	1	24
52011	GUSAU 1	132	1	1	50

Source: JICA Study Team

7-4-6 Fault Analysis

Short-circuit calculations were carried out for three-phase faults under all load scenarios. As a result of the calculations, design parameters for new substations and lines, short-circuit levels on existing substations and the impact of the expansion measures are shown. It is important to calculate the short-circuit currents since they are a measure to indicate the strength of both systems which will be interconnected.

The short-circuit calculations were performed according to the IEC 60909 standard and the following

values were determined at all 330 and 132 kV substations in the TCN network:

- 3-phase symmetrical short-circuit power S_{k3} (MVA)
- I_{k3} total symmetrical short-circuit current for three-phase solid faults

The calculations are based on the operational condition available in the corresponding load-flow scenarios.

The results of the preliminary fault analysis are summarized in Annex 7.4.10 (Table 1) for all 330 and 132 kV substations. The generators sub-transient reactance are used.

The most critical 330 and 132 kV substations are shown in Table 7-4.34.

Table 7-4.34 Fault analysis results 2020

Bus Number	Bus Name	Voltage (kV)	I (A)	Bus Number	Bus Name	Voltage (kV)	I (A)
43002	BENIN 3	330	30,340	82000	AFAM 1-2-3	132	29,882
83000	AFAM IV 3	330	29,491	82002	AFAM IV	132	29,767
83002	ALAOJI 3	330	28,225	12003	IKEJA W 1BB1	132	28,156
83001	ALAOJI NIPP3	330	27,810	82019	OMOKU 1	132	26,663
43011	B_NORTH_3	330	27,132	12042	OKE_ARO_1	132	25,624

Source: JICA Study Team

The most critical 330 kV substations are BENIN, AFAM IV, ALAOJI and BENIN NORTH, with fault levels ranging from 30.3 kA to 27.1 kA for a 3ph busbar fault.

The most relatively critical 132 kV substation is AFAM and IKEJA WEST, with fault levels of 29.8 and 28.1 kA. It is clear from this analysis that the TCN standard switchgear ratings of 31.5 kA will be inadequate in future when new power plants are commissioned in later years.

- Install switchgear with higher capacity breakers (63 kA).
- Study different topological configurations of the elements connected to the different bus sections.
- Install Current Limiting Reactors (CLR) aiming to reduce the short-circuit current contributions from adjacent bus sections.

7-5 Expansion Plan for 2025

7-5-1 Static Security Analysis, Year 2025

7-5-1-1 Transmission lines

The network configuration for 2025 is shown in the PSS/E SLD of Annex 7.5.1

7-5-1-2 Evacuation from Mambilla HPP


(1) New transmission lines

A major development for 2025 is the operation of the first units of the Mambilla HPP. The new transmission lines required to evacuate the power from Mambilla will have to be designed to evacuate full power, assuming power of 2,400 MW is to be evacuated from the Mambilla Hydro Power Plant:

1. If the N-1 criterion is to be maintained, as per the current Grid Code, the following is proposed:
 - a) 330/132/33 kV substation at Wukari
 - b) Double-Circuit with Quad Bison conductors from Mambilla to Wukari
 - c) Double-Circuit with Quad Bison conductors from Wukari to Makurdi
 - d) Double-Circuit with Quad Bison conductors from Mambilla to Jalingo (to close the 330-kV loop)
2. Due to the importance of the power station and in line with international practice by other utilities, it is proposed to apply the N-2 criteria only for the transmission lines leaving the power plant. If this is adopted, it would be necessary to have:
 - a) Two Double Circuits with Quad Bison conductors from Mambilla to Wukari
 - b) Two Double Circuits with Quad Bison conductors from Mambilla to Jalingo

Each Quad Bison circuit will be rated 1,550MVA approx. The scheme is shown on the Single-Line Diagram of Figure 7-5.1.

In both cases, two evacuation routes must be maintained (one towards Makurdi and another towards Jalingo) at all times, since 2,400MW will not be able to be evacuated through one route only, given that bottlenecks will occur downstream, beyond Makurdi and Jalingo respectively.



Source: JICA Study Team



Figure 7-5.1 Evacuation from Mambilla HPP

(2) PV analysis

A PV analysis was carried out to determine the maximum power that can be evacuated from Mambilla HPP (MHPP).

The starting scenario was set up with an initial generation of 1,000 MW at MHPP and both base case and contingency (N-1) conditions were analyzed. It was determined that:

- Under base case (normal) conditions, an additional 2,000 MW can be evacuated, i.e. a total of 3,000 MW, before a 330-kV line in the TCN system reaches its limit.
- Under contingency conditions, an additional 1,700 MW can be evacuated, i.e. total 2,700 MW, before a line in the TCN system reaches its thermal limit (777 MVA), in this case the Gombe-Yola 330 kV line (cct1) when the other Gombe-Yola 330 kV line (cct 2) is tripped. This is shown in the graphs of Figure 7-5.2.



Source: JICA Study Team

Figure 7-5.2 PV Analysis for Mambilla Evacuation

Considering that the Mambilla plant is rated 3,000 MW and is highly unlikely to reach production exceeding 2,400 MW, it is concluded that all power can be evacuated without any additional reinforcements in the transmission system required.

(3) Specifications of transmission lines

The following data is used: the 330-kV conductor is 4-bundle ACSR350 per phase, spaced at 400 mm. The conductor types (aluminum conductor steel reinforced):


ACSR 350 'Bison' (381-AL1/49-ST1A; 54 Al wires diameter 3.0 mm; seven Fe wires diameter 3.0 mm, i.e. 54/7), Outside diameter 27 mm. The Basic Conductor Characteristics are in Table 7-5.1

Table 7-5.1 Basic Conductor Characteristics for 330 kV OHL

Description	Value
Cross-section	
Aluminum (mm ²)	381.6
Steel (mm ²)	49.4
Total (mm ²)	431
Stranding and wire diameter	
Aluminum (mm)	54 / 3.0
Steel (mm)	7 / 3.0
Overall diameter (mm)	27

(4) 330 kV Transmission Line R, X and B

The tower design is shown in Figure 7-5.3 and the conductors' arrangements in Figure 7-5.4.




Source: JICA Study Team

Figure 7-5.3 Tower Design

Based on the above, with $d=400\text{mm}$ (1.32 ft):

$$d=400\text{mm}=1.32\text{ft}$$



Source: JICA Study Team


Figure 7-5.4 Conductors Spacing 330 kV Line

In general:


2-strand bundle



3-strand bundle



4-strand bundle



The Geometric Mean Radius (GMR) of bundled conductors:

$$D_s^b = \sqrt{D_s \cdot d}$$

$$D_s^b = \sqrt[3]{D_s \cdot d^2}$$

$$D_s^b = 1.09 \sqrt[4]{D_s \cdot d^3}$$

where D_s is the GMR of one stranded conductor.

For Bison conductors, the GMR (= D_s) of one conductor, as taken from tables, is:

$$\text{GMR} = D_s = 0.0363 \text{ ft}$$

For bundled conductors the equivalent GMR is

$$D_s^b = \sqrt{D_s \cdot d} \quad \text{for 2-bundle conductors} \quad (1)$$

$$D_s^b = \sqrt[3]{D_s \cdot d^2} \quad \text{for 3-bundle conductors} \quad (2)$$

$$D_s^b = 1.09 \sqrt[4]{D_s \cdot d^3} \quad \text{for 4-bundle conductors} \quad (3)$$

In this case, for 4-b (Quad):

$$D_s^b = 1.09 \sqrt[4]{D_s \cdot d^3} = 1.09 \sqrt[4]{0.0363 \times 1.32^3} = 0.586 \text{ ft}$$

The equivalent spacing between phases is:

$$D_{eq} = D_m = \sqrt[3]{D_{12} \cdot D_{23} \cdot D_{31}} = \sqrt[3]{34.44 \times 34.44 \times 68.88} = 43.4 \text{ ft}$$

Inductive Reactance:

$$X_L = 4.657 \cdot 10^{-3} \cdot f \cdot \log \frac{D_m}{D_s^b} = 0.4353 \text{ ohms/mile} = 0.27 \text{ ohms/km (for SC)}$$

$$= 0.25 \text{ ohms/km (for DC)}$$

Capacitance:

$$C_n = \frac{0.0388}{\log \frac{D_{eq}}{D_s^b c}} \quad \mu\text{F/mile}$$

where $D_s^b c$ is the equivalent GMR for capacitance calculations and derived from eqs. (1), (2) and (3) used for inductance calculations, except that the D_s is replaced by the radius r of the conductor in ft, i.e.

$$r = \frac{D_{out}}{2 \times 12} \text{ ft, where } D_{out} \text{ is the conductor outside diameter in inches}$$

Accordingly, for capacitance:

$$D_s^b c = \sqrt{r \cdot d} \quad \text{for 2-bundle conductors} \quad (4)$$

$$D_s^b c = \sqrt[3]{r \cdot d^2} \quad \text{for 3-bundle conductors} \quad (5)$$

$$D_s^b c = 1.09 \sqrt[4]{r \cdot d^3} \quad \text{for 4-bundle conductors} \quad (6)$$

For Bison conductors: $r = \frac{D_{out}}{2 \times 12} = \frac{1.062}{2 \times 12} = 0.04425 \text{ ft}$

$$D_s^b c = 1.09 \sqrt[4]{r \cdot d^3} = 1.09 \sqrt[4]{0.04425 \times 1.32^3} = 0.6156 \text{ ft}$$

$$C_n = \frac{0.0388}{\log \frac{D_{eq}}{D_s^b c}} = \frac{0.0388}{\log \frac{43.4}{0.6156}} = 0.021 \mu\text{F/mile} = 0.013 \mu\text{F/km (for SC)}$$

$$= 0.014 \mu\text{F/km (for DC)}$$

Susceptance $B = \omega C = 314 \times 0.013 = 4.08 \mu\text{mho/km} = \underline{4.08 \mu\text{S/km}}$, for SC

$$= 4.39 \mu\text{S/km}), \text{ for DC}$$

Resistance: $R = 0.0762 \text{ ohms/km}$ ($R = 0.019 \text{ ohms/km}$ for four bundle conductors)

The electrical parameters in PSS/E of the DC 330 kV line Mambila-Wukari and Mambilla-Jalingo are summarized in Table 7-5.2.

Conductor Type	3 x AC 381/49
Wind Speed	0.6 m/s
Air temperature	40 °C
Maximum conductor temperature	75 °C

Thermal Ratings:

Capacity	1,555 MVA
Capacity	1,400 MW

7-5-1-3 2025 Load demand

Table 7-5.3 shows that the increase in load demand follows an approximately equivalent increase (in percentage terms) in the load forecast.

Table 7-5.3 Load demand per DisCo

DisCo	Load demand 2020 (MVA)	Increase 2020-2025	Load demand 2025 (MVA)
1-Ikeja	1,166	76%	2,058
2-Ibadan	1,104	107%	2,285
3-Abuja	865	169%	2,329
4-Benin	954	94%	1,852
5-Kaduna	495	136%	1,169
6-Jos	309	109%	646
7-Enugu	924	81%	1,668
8-Port Harcourt	794	122%	1,762
9-EKO	1,087	69%	1,837
10-Kano	708	121%	1,565
11-Yola	230	131%	532
Country MW	8,636	105%	17,703
Export* MW	387	-	1,540
Tota Load MW	9,023	113%	19,243

Source: JICA Study Team

Ref: 330 kV export lines: To Sakete 360MW, To Faraku 400MW, To Zabori 631MW

7-5-1-4 Study cases 2025

Table 7-5.4 shows the two scenarios studied for 2025, to capture the extreme combinations of generation and load.

Table 7-5.4 2025 study cases

Case		Description	Generation	Load (MW)	
Dry Season Peak	DP	Dry Night Peak Load	Reduced HPP generation (2228 MW) No PV generation Increased requirement from GTs	Peak load (night)	17703 + export (1540)
Dry Season Off-Peak	DOP	Dry Day Off-Peak Load	Reduced HPP generation PV generation Increased requirement from GTs	Off-Peak load (day)	15000 + export (1540)

Source: JICA Study Team


7-5-2 2025 Base Case Load-flow Results

7-5-2-1 Dry Season Peak-2025

(1) Prerequisites for analysis

- (a) Generation from PVs = 0 and
- (b) Reduced generation from HPP plants of 2,228 MW,

The running generation and load for each DisCo is as shown in **Figure 7-5.5**.



Source: JICA Study Team


Figure 7-5.5 Dry Season Peak Generation and Load per DisCo

Table 7-5.5 Dry Season Peak Generation and Load per DisCo

Bus Number	Bus Name	P _{Gen} (MW)	Bus Number	Bus Name	P _{Gen} (MW)	Bus Number	Bus Name	P _{Gen} (MW)
16040	AES BERG202	31	16004	EGBIN ST 5	274.8	76022	OKPAI STPH2	135
16041	AES BERG203	31	16005	EGBIN ST 6	274.8	16064	OLOR NIPPST1	108
16042	AES BERG204	31	16006	EGBIN ST_123	600	16065	OLOR NIPPST2	108
16043	AES BERG205	31	86050	ELEME	68	16060	OLORNIPPST11	132
16045	AES BERG207	31	96012	ETHIOPE	450	16061	OLORNIPPST12	100
16046	AES BERG208	31	46037	ETHIOPE GTS	344	16062	OLORNIPPST21	100
16047	AES BERG209	31	46038	ETHIOPE ST	156	16063	OLORNIPPST22	100
16048	AES BERG210	31	86068	GBARAIN_GTB1	112.5	16050	OLORUNSO GT1	30
16049	AES BERG211	31	86069	GBARAIN_GTB2	112.5	16051	OLORUNSO GT2	30
86012	AFAM VI GT11	150	86055	GEN_AMADI	100	16054	OLORUNSO GT5	30
86013	AFAM VI GT12	150	56010	GEN_KADUNA	200	16055	OLORUNSO GT6	30
86014	AFAM VI GT13	150	46023	GER NIPPST21	140	16056	OLORUNSO GT7	30
86015	AFAM VI ST10	180	46024	GER NIPPST22	140	86047	OMA_GT	225
86003	AFAM2 GT5-6	48	46025	GER NIPPST23	140	86023	OMOKU1 GT1	75
86004	AFAM2GT 7-8	48	46020	GEREGU GT11	124	86024	OMOKU1 GT2	75
86005	AFAM3 GT9-10	50	56003	GURARA GBUS	18	86021	OMOKU2 GT1	113
86006	AFAM3GT11-12	50	86025	IBOM GT1	32	86022	OMOKU2 GT2	113
86080	AKWA-IBOM NU	600	86026	IBOM GT2	32	26026	OMOTNIPP GT1	110
86039	ALAOJI_GTB1	112.5	86027	IBOM GT3	32	26027	OMOTNIPP GT2	110
86040	ALAOJI_GTB2	112.5	86028	IBOM II	260	26028	OMOTNIPP GT3	110
86041	ALAOJI_GTB3	112.5	46031	IHOVBOR_GTB1	110	26029	OMOTNIPP GT4	110
86042	ALAOJI_GTB4	112.5	46032	IHOVBOR_GTB2	110	26020	OMOTOSO GT1	70
86043	ALAOJI2_STB1	257	46033	IHOVBOR_GTB3	110	26022	OMOTOSO GT3	70
86031	ALSCON GT1	90	46034	IHOVBOR_GTB4	110	26024	OMOTOSO GT5	62
46027	ASCO G1	55	66033	JBS WIND	70	26025	OMOTOSO GT7	62
46028	ASCO G2	55	36006	JEBBA 2G1	90	96008	ONDO IPP	405
46035	AZURA GT	280	36007	JEBBA 2G2	90	16012	PARAS	270
46036	AZURA ST	140	36008	JEBBA 2G3	90	16011	PARASGT1-9	93
16008	BRESSON GTS	80	36009	JEBBA 2G4	40	46070	PROTON	135
96009	CABLE INLAND	900	36011	JEBBA 2G6	90	86070	QUA IBOE PP	480
86062	CALABAR_GTB1	100	36004	KAINJ 1G11	80	86035	RIVERS_GT1	190
86061	CALABAR_GTB2	100	36005	KAINJ 1G12	80	46050	SAP_NIPP_GT1	100
86060	CALABAR_GTB3	100	36000	KAINJ 1G5	80	46051	SAP_NIPP_GT2	100
86063	CALABAR_GTB4	100	36001	KAINJ 1G6	80	46052	SAP_NIPP_GT3	100
76011	CENTURY IPP	480	36002	KAINJ 1G7-8	160	46012	SAPELE GT1-2	175
86030	CUMMINS	135	36003	KAINJ 1G9-10	160	46013	SAPELE GT3-4	95
46010	DELTAIV GT19	133	46080	KOJI NUCLEAR	600	36012	SHIROR 411G1	140
46011	DELTAIV GT20	133	55075	KT WF 33	9	36013	SHIROR 411G2	140
66005	DKOWA G1	14	16010	LAFARAGE 2	100	36014	SHIROR 411G3	80
86065	EGBEMA_GTB1	100	66007	MAMBILA GT1	250	96016	TURBINE DR	300
86066	EGBEMA_GTB2	100	66008	MAMBILA GT2	250	96017	YELLOW STONE	162
86067	EGBEMA_GTB3	100	76000	OKPAI GT11	145	46029	ZUMA	540
16000	EGBIN GT 1	274.8	76001	OKPAI GT12	145	86071	ZUMA (GAS)	337
16001	EGBIN GT 2	274.8	76020	OKPAI GT4PH2	135	36024	ZUNGE_G1	150
16002	EGBIN GT 3	274.8	76021	OKPAI GT5PH2	135	36025	ZUNGE_G2	150
16003	EGBIN GT 4	274.8	76002	OKPAI ST18	126	36027	ZUNGE_G4	10

Source: JICA Study Team

The power flows are shown in Figure 7-5.6.



Source: JICA Study Team


Figure 7-5.6 2025 Dry Season Peak Power Flows in 330 kV System

7-5-2-2 Dry Season Off-Peak-2025

(1) Prerequisites for analysis

- (a) Generation from PVs = 750MW and
- (b) Reduced generation from HPP plants of 1,390 MW,


The running generation and load for each DisCo are shown in Figure 7-5.7.



Source: JICA Study Team

Figure 7-5.7 Dry Season Off-Peak Generation and Load per DisCo

The power flows are shown in Figure 7-5.8.



Source: JICA Study Team

Figure 7-5.8 2025 Dry Season Off- Peak Power Flows in 330 kV System

7-5-3 Contingency (N-1) Analysis for 330 kV Circuits

The contingency N-1 analysis carried out for the 330 kV lines has shown that the following 330 kV DC lines are overloaded and require reinforcement by converting to Quad conductors.

Table 7-5.6 Overloaded 330 kV lines under N-1

Substation Name	Substation Name	Rating (MVA)	Flow (MVA)	Loading (%)	Length (km)
AJA	LEKKI	856	1,372	160.4	7
ALAGBON	LEKKI	856	1,184	138.5	14
LOKOJA	ZUMA	856	1,117	130.7	24

Source: JICA Study Team

Reconductoring to Quad-bundle conductors has already been implemented by TCN. This is also assumed to be possible for these lines, but must be verified to ensure the structures are suitable. If not, the DC lines will need to be replaced.

7-5-4 2025 Base Case Load-flow Results

7-5-4-1 Overloads of 330 kV or 132 kV Lines

There are no overloaded 330 kV or 132 kV lines which are overloaded under normal operation (base case).

7-5-4-2 Overloads of Transformers

The 330/132 kV 3-W and A/T transformers overloaded above their 100% rating MVA under normal (base case) operation, in addition to those reported for the 2020 case, are listed in Table 7-5.7 and must be upgraded.

Table 7-5.7 Overloaded 330/132 kV transformers

Bus Number	Bus Name	Voltage (kV)	Bus Number	Bus Name	Voltage (kV)	cct	Load (MVA)	Rating (MVA)	Loading (%)
83003	ADIAGBO_3	330	3WNDTR	ADIAGB T1A	WND 1	1	188.2	150	125.5
83003	ADIAGBO_3	330	3WNDTR	ADIAGB T1B	WND 1	2	188.2	150	125.5
12000	AJA 132	132	3WNDTR	AJA T4	WND 1	1	68.9	45	153.2
13000	AJA 3	330	3WNDTR	AJA T2A	WND 1	3	194.6	150	129.8
42000	AJAOKUTA 1	132	3WNDTR	AJAOK T1A	WND 2	1	86	80	107.5
42000	AJAOKUTA 1	132	3WNDTR	AJAOK T2A	WND 2	1	86	80	107.5
42000	AJAOKUTA 1	132	3WNDTR	AJAOK T3A	WND 2	1	86	80	107.5
13001	AKANGBA 3	330	3WNDTR	AKANGBA5T4A	WND 1	1	152.4	150	101.6
13001	AKANGBA 3	330	3WNDTR	AKANGBA5T4B	WND 1	1	152.4	150	101.6
12016	AKOKA 1	132	3WNDTR	AKOKA T1	WND 1	1	53.8	45	119.6
23005	AKURE 3	330	3WNDTR	AKURE T1A	WND 1	1	182.2	150	121.5
23005	AKURE 3	330	3WNDTR	AKURE T1B	WND 1	2	182.2	150	121.5
12022	APAPA RD 1	132	3WNDTR	APAPA RD T1	WND 1	1	46.4	45	103.2
23000	AYEDE 3	330	3WNDTR	AYEDE TR1	WND 1	1	198.9	150	132.6
23000	AYEDE 3	330	3WNDTR	AYEDE TR2	WND 1	1	197.1	150	131.4
23000	AYEDE 3	330	3WNDTR	AYEDE TR3	WND 1	1	197.1	150	131.4
42003	DELTA 1	132	43003	DELTA IV 3	330	1	270.1	150	180.1
42003	DELTA 1	132	43003	DELTA IV 3	330	2	270.1	150	180.1
23003	GANMO 3	330	3WNDTR	GANMO TR1A	WND 1	1	212.4	150	141.6
72036	IHALA 1	132	3WNDTR	IHALA TR	WND 2	1	124.2	120	103.5

Bus Number	Bus Name	Voltage (kV)	Bus Number	Bus Name	Voltage (kV)	cct	Load (MVA)	Rating (MVA)	Loading (%)
13003	IKEJA W 3	330	3WNDTR	IKW T2B	WND 1	3	163.1	150	108.7
12027	ISOLO 1	132	3WNDTR	ISOLO TR3	WND 1	1	53.3	45	118.3
22012	JERICOHO 1	132	3WNDTR	JERICO TR1	WND 1	1	73.7	45	163.8
53001	KANO 3	330	3WNDTR	KANO OLD T5A	WND 1	2	169.6	150	113
53001	KANO 3	330	3WNDTR	KANO T3A	WND 1	1	169.6	150	113
52030	KUMB T1A BB	132	3WNDTR	KANO T1A	WND 2	1	242.5	225	107.8
73007	NNEWI 3	330	3WNDTR	NNEWI T2A	WND 2	1	91.8	67.5	136
22014	OMOTOSHO 1	132	3WNDTR	OMOTOSHO TR1	WND 2	1	134.3	120	111.9
22024	OMOTOSHO 2	132	3WNDTR	OMOTOSHO TR2	WND 2	1	137.7	120	114.8
73001	ONITSHA 3	330	3WNDTR	ONITSH T3A	WND 1	1	152.4	150	101.6
73001	ONITSHA 3	330	3WNDTR	ONITSHA T4	WND 1	1	157.6	150	105.1
22001	OSOGBO 1	132	3WNDTR	OSOGBO 4T1	WND 2	1	134.9	120	112.5
22001	OSOGBO 1	132	3WNDTR	OSOGBO 4T6	WND 2	1	134.9	120	112.5
22001	OSOGBO 1	132	3WNDTR	OSOGBO N T5	WND 2	5	134.9	120	112.5
82028	OWERRI 1	132	3WNDTR	OWERRI TR1	WND 1	1	70.1	60	116.8
83005	OWERRI_3	330	3WNDTR	OWERRI T1A	WND 1	1	160.6	150	107.1
32027	WESTMAIN_1	132	3WNDTR	EASTMAIN TR1	WND 2	1	135.3	120	112.7
32027	WESTMAIN_1	132	3WNDTR	EASTMAIN2	WND 2	2	135.3	120	112.7

Source: JICA Study Team

The 132/33 kV and 132/11 kV transformers overloaded above their 100% MVA rating under normal (base case) operation, listed in Table 7-5.8, are in addition to those overloaded in 2020 and must be upgraded. Some of these transformers, shown in bold, have already been reported in the 2020 case as being overloaded above their 85% rating:

Table 7-5.8 Overloaded 132/33 kV transformers

Bus Number	Bus Name	Voltage (kV)	Bus Number	Bus Name	Voltage (kV)	cct	Load (MVA)	Rating (MVA)	Loading (%)
82026	ABA 1	132	86020	ABA T1A 6.6	6.6	1	8.6	7.5	114
82026	ABA 1	132	85023	ABA T4A(MOB)	33	1	17.5	15	116.4
72016	ABAKALIKI 1	132	75001	ABAKALIKI 33	33	1	72.1	60	120.2
82000	AFAM 1-2-3	132	86000	AFAM 11	11	1	119.3	64	186.4
82018	AHOADA 1	132	85038	AHOADA T2	33	2	42.9	40	107.4
12000	AJA 132	132	15003	AJA 33	33	1	107.2	60	178.6
42000	AJAOKUTA 1	132	45033	AJAOKUTA T2	33	1	64.8	60	107.9
12004	AKANGBA BBII	132	15053	AKANGBA 33	33	1	67.8	60	113
12016	AKOKA 1	132	15067	AKOKA T2	33	1	47.6	40	119
22005	AKURE 1	132	25003	AKURE 33	33	1	40.9	30	136.4
22005	AKURE 1	132	25028	AKURE T2A	33	2	46.7	30	155.6
22005	AKURE 1	132	25018	AKURE T3A 33	33	1	82.6	60	137.7
12017	ALAGBON 1	132	15008	ALAGBON 33	33	1	70.9	66	107.4
12017	ALAGBON 1	132	15008	ALAGBON 33	33	2	70.9	66	107.4
12019	ALIMOSHO 1	132	15010	ALIMOSHO 33	33	1	37.8	30	125.9
12019	ALIMOSHO 1	132	15072	ALIMOSHO T1	33	3	48.5	30	161.6
42015	AMUKPE 1	132	45026	AMUKPE BB 33	33	1	68.3	60	113.9
12054	ARIGBAJO 1	132	15062	ARIGBAJO 33	33	1	61.1	60	101.9
12054	ARIGBAJO 1	132	15062	ARIGBAJO 33	33	2	61.1	60	101.9
22000	AYEDE 1	132	25004	AYEDE 33	33	1	107.1	100	107.1
22000	AYEDE 1	132	25045	AYEDE 33	33	3	81.3	60	135.5
42004	BENIN 1	132	45000	BENIN 33	33	1	67.8	60	112.9
42004	BENIN 1	132	45000	BENIN 33	33	9	67.8	60	112.9

Bus Number	Bus Name	Voltage (kV)	Bus Number	Bus Name	Voltage (kV)	cct	Load (MVA)	Rating (MVA)	Loading (%)
52007	DAN AGUNDI 1	132	55001	DAN AGUNDI 3	33	1	73.2	60	122
12002	EGBIN 1	132	15033	EGBIN 33	33	1	46.9	40	117.2
12023	EJIGBO 1	132	15014	EJIGBO 33	33	1	46.2	30	153.9
12023	EJIGBO 1	132	15014	EJIGBO 33	33	2	46.2	30	153.9
12023	EJIGBO 1	132	15128	EJIGBO 33	33	1	46.2	30	153.9
12023	EJIGBO 1	132	15128	EJIGBO 33	33	2	46.2	30	153.9
12023	EJIGBO 1	132	15016	EJIGBO BBI 3	33	1	104.6	100	104.6
82005	EKET 1	132	85003	EKET 33	33	2	80.2	60	133.6
82005	EKET 1	132	85002	EKET T1B	33	1	96.3	45	213.9
82035	ELELENWO 1	132	85036	ELENLEWO 33	33	1	42.1	40	105.3
82035	ELELENWO 1	132	85036	ELENLEWO 33	33	2	42.1	40	105.3
22022	GANMO T1 BB	132	25032	GANMO T1	33	1	118.5	60	197.5
62029	GASHUWA 1	132	65062	GASHUWA T2A	33	2	54.9	45	122
62029	GASHUWA 1	132	65061	GASHUWAT1A	33	1	54.9	45	122
52011	GUSAU 1	132	55004	GUSAU 33	33	1	40.6	30	135.4
52011	GUSAU 1	132	55046	GUSAU T1	33	2	35.6	30	118.5
22006	IBADAN NORTH	132	25007	IBADAN NORTH	33	1	88.3	60	147.2
22006	IBADAN NORTH	132	25042	IBADAN T2 BB	33	2	79.3	60	132.2
22028	IJEBU-ODE 1	132	25041	IJEBU T1 BB	33	1	60.6	60	101
12024	IJORA 1	132	15045	IJORA T1A&B	33	2	33.2	30	110.8
12024	IJORA 1	132	15046	IJORA T2B	33	2	36.1	30	120.4
12025	IKORODU	132	15050	IKORODU T3	33	3	102.5	100	102.5
82031	IKOT_ABASI	132	85092	IKOT ABAS 33	33	1	52.3	40	130.9
82031	IKOT_ABASI	132	85092	IKOT ABAS 33	33	2	52.3	40	130.9
22009	ILESHA 1	132	25010	ILESHA 33	33	1	40.1	40	100.3
22009	ILESHA 1	132	25031	ILESHA T1	33	2	40.1	40	100.3
12026	ILLUPEJU 1	132	16033	ILLUPEJU T2	11	3	31	30	103.2
12026	ILLUPEJU 1	132	16025	ILUPEJU 11	11	2	15.1	15	100.8
12026	ILLUPEJU 1	132	15027	ILUPEJU 33	33	1	32	30	106.7
42008	IRRUA 1	132	45002	IRRUA 33	33	1	79.1	60	131.9
22011	ISEYIN 1	132	25012	ISEYIN 33	33	1	46.8	45	104
22011	ISEYIN 1	132	25049	ISEYIN T2 33	33	1	40.8	30	136.1
12027	ISOLO 1	132	15028	ISOLO 33	33	1	77.6	60	129.4
12020	ITIRE 1	132	16034	ITERE T3	11	2	44.9	40	112.1
12020	ITIRE 1	132	16032	ITIRE 11	11	1	33.4	30	111.2
22008	IWO 1	132	25002	IWO 33	33	1	45.8	40	114.5
22008	IWO 1	132	25002	IWO 33	33	2	45.8	40	114.5
62020	JALINGO 1	132	65015	JALINGO 33B	33	1	32.4	30	108
22012	JERICO 1	132	25013	JERICO2 33	33	1	66.4	40	166.1
62001	JOS 1	132	65005	JOS T4 60MVA	33	2	99.7	60	166.2
52003	KADUNA TOWN	132	55006	KADUNA TOWN	33	1	33.6	30	111.9
52003	KADUNA TOWN	132	55061	KD TWN T1	33	2	33.6	30	111.9
62025	KAFANCHAN 1	132	65037	KAFANC M TR1	33	3	55.2	40	138.1
52001	KANO 1	132	55057	KUMB T2	33	1	53	40	132.5
52001	KANO 1	132	55059	KUMB T4	33	4	68.8	60	114.7
52029	KANO_NEW132	132	55070	KANOII 33	33	1	72.7	60	121.2
52029	KANO_NEW132	132	55070	KANOII 33	33	2	72.7	60	121.2
52012	KATSINA 1	132	55056	KATSINA T3	33	3	41.7	30	139.1
52042	KAZAURE 1	132	55092	KAZAURE 33	33	1	32.4	30	108
52042	KAZAURE 1	132	55092	KAZAURE 33	33	2	32.4	30	108
62024	MAKERI 1	132	65033	MAKERI 33	33	1	30.3	30	101.1

Bus Number	Bus Name	Voltage (kV)	Bus Number	Bus Name	Voltage (kV)	cct	Load (MVA)	Rating (MVA)	Loading (%)
72002	NHAVEN 1	132	75039	NHAV TR2	33	2	32	30	106.6
72002	NHAVEN 1	132	75041	NHAV TR4	33	4	68	60	113.4
72011	NKALAGU 1	132	75044	NKALGU T1A	33	2	31.9	30	106.3
12055	ODOGUNYAN 1	132	15063	ODOGUNYA 33	33	1	84.4	60	140.6
12055	ODOGUNYAN 1	132	15063	ODOGUNYA 33	33	2	84.4	60	140.6
12032	OGBA 1	132	16027	OGBA 11	11	1	20.4	20	102
12029	OJO 1	132	15030	OJO 33	33	2	33.5	30	111.6
12029	OJO 1	132	15047	OJO T3_T4	33	5	85.2	60	142
22017	ONDO2 1	132	25017	ONDO1 33	33	1	63.7	60	106.2
72001	ONITSHA 1	132	75037	ONITSH TR14	33	5	42.9	40	107.2
72001	ONITSHA 1	132	75038	ONITSHA TR11	33	4	65.1	60	108.4
22001	OSOGBO 1	132	25026	OSOGBO 33	33	3	64.8	60	108
22001	OSOGBO 1	132	25029	OSOGBO T1	33	1	41.3	30	137.7
22001	OSOGBO 1	132	25030	OSOGBO T2	33	2	34.9	30	116.3
12033	OTTA 1	132	15079	OTTA T2	33	2	76.8	60	127.9
82028	OWERRI 1	132	85020	OWERR T1MOB	33	1	40.2	40	100.6
12034	OWOROSOKI 1	132	15020	OWOROSOKI 33	33	1	64.7	60	107.8
12037	PARAS_1	132	15116	AFR FOUNDRY	33	1	62.9	40	157.2
12037	PARAS_1	132	15115	PARAS IPP	33	1	43.8	40	109.6
12037	PARAS_1	132	15115	PARAS IPP	33	2	65.8	60	109.6
82008	PHCT TOWN1 1	132	85027	PHCT T1A	33	2	63.4	60	105.6
82009	PHCT TOWN2 1	132	86018	PHCT TOWN 11	11	1	65.6	60	109.3
82036	RUMUSOI 1	132	85060	RUMUSOI T133	33	1	70	60	116.7
82036	RUMUSOI 1	132	85061	RUMUSOI T233	33	1	70	60	116.7
62012	SAVANNAH 1	132	65010	SAVANNAH 33	33	1	18.4	15	122.5
22027	SHAGAMU 1	132	25040	SHAGAM T2 BB	33	2	38	30	126.6
22027	SHAGAMU 1	132	25035	SHAGAMU 33	33	1	59.1	30	197.1
12036	SHAGAMU CEME	132	16007	SHAG CEM 11	11	1	16.1	15	107.4
12036	SHAGAMU CEME	132	16038	SHAG CEM 11	11	2	16.1	15	107.4
32001	SHIRORO 1	132	35013	SHIRORO 33	33	1	51.3	30	171
32016	SOKOTO 1	132	35050	SOKOTO T3	33	3	41.8	30	139.5
32017	SULEJA 1	132	35047	SULEJA T3	33	2	41.4	30	138.1
32014	TEGINA 1	132	35015	TEGINA 33	33	1	42.6	30	142.1
42002	UGHELLI 1	132	45001	UGHELLI 33	33	1	92.6	60	154.3
82027	UMUAHIA 1	132	85024	UMUAHIA 33	33	1	44.5	40	111.2
82027	UMUAHIA 1	132	85024	UMUAHIA 33	33	2	44.5	40	111.2
82010	UYO 1	132	85007	UYO 33	33	3	95.2	60	158.7
82010	UYO 1	132	85030	UYO T2B	33	1	51	40	127.4
82010	UYO 1	132	85030	UYO T2B	33	2	51	40	127.4

7-5-4-3 Reactive Power Compensation Requirements

(1) SVC requirements

No SVC is needed in 2025, but more detailed and dedicated studies will subsequently be necessary stage to determine any need for such equipment in the post-2025 period.

In 2025, in addition to the reactors and capacitors listed in Table 7-5.9, Table 7-5.10, Table 7-5.11 and

Table 7-5.12, reactive power compensation (150 MVar capacitors) will be required at Bernin Kebbi due to export requirements to WAPP. It should be noted however that in 2030, the proposed supergrid will be extended with a Kainji-Bernin Kebbi line. Once this is implemented, there will be no further need for reactive power compensation at Bernin Kebbi.

With regards to Gombe, should additional reactive power compensation be required at lightly loaded conditions, instead of SVC, a more cost-effective option would be relocating from other S/S to Gombe approximately 100-150 MVar of reactors that, as this analysis has shown, are no longer needed there.

As was shown in the static security analysis for 2025, a more appropriate candidate for an SVC (or in fact only capacitors, given the lack of MVars) could be the Lagos/Ikeja/Eko region, where there is a reactive power deficit of approximately 400-500 MVar. It should be noted however that this deficit is expected to ease when the DisCos implement the reactive power control program at distribution level, as proposed and in line with the Grid Code requirements, as well as when transmission lines and transformers are upgraded, as has been shown in previous chapters of this report.

(2) Reactors

The status of reactors required in the Dry Season Peak case is shown in Table 7-5.9.

Table 7-5.9 Reactor requirements for the 2025 Dry Season Peak

Bus Number	Bus Name	Voltage (kV)	Id	In Service	B-Shunt (MVar)
63005	MAIDUGURI 3	330	2	1	-75
65001	YOLA T1 33	33	1	1	-30
65014	GOMBE T4A	33	1	1	-30

Source: JICA Study Team

The status of reactors required in the Dry Season Off-Peak case is shown in Table 7-5.10.

Table 7-5.10 Reactor requirements for the 2025 Dry Season Off-Peak

Bus Number	Bus Name	Voltage (kV)	Id	In Service	B-Shunt (MVar)
53001	KANO 3	330	1	1	-75
53005	KANO_NEW330	330	1	1	-75
63001	JOS 3	330	1	1	-75
63002	YOLA 3	330	1	1	-75
63002	YOLA 3	330	2	1	-75
63005	MAIDUGURI 3	330	2	1	-75
63000	GOMBE 3	330	1	1	-50
63000	GOMBE 3	330	2	1	-50
65001	YOLA T1 33	33	1	1	-30
65014	GOMBE T4A	33	1	1	-30
63006	JALINGO_3	330	1	1	-10

Source: JICA Study Team

(3) Capacitors

The status of capacitors required in the Dry Season Peak case is shown in Table 7-5.11.

Table 7-5.11 Capacitor requirements for the 2025 Dry Season Peak

Bus Number	Bus Name	Voltage (kV)	Id	In Service	Capacity (MVar)
75004	AWKA 33	33	1	1	10
75012	OJI RIVER 33	33	1	1	10
15002	AGBARA 33	33	1	1	20
15011	ABEOKUTA OLD	33	2	1	20
15022	IKORODU 33	33	2	1	20
15027	ILUPEJU 33	33	1	1	20
15030	OJO 33	33	1	1	20
25004	AYEDE 33	33	1	1	20
25012	ISEYIN 33	33	1	1	20
25018	AKURE T3A 33	33	1	1	20
25035	SHAGAMU 33	33	1	1	20
25038	IJEBU-ODE 33	33	1	1	20
35000	AKWANGA 33	33	1	1	20
35001	APO 33	33	2	1	20
35009	KONTAGORA 33	33	1	1	20
35012	MINNA 33	33	1	1	20
35048	MINNA T2	33	2	1	20
42014	EFFURUN 1	132	2	1	20
42015	AMUKPE 1	132	1	1	20
45003	OKENE 33	33	1	1	20
52022	HADEJIA 1	132	1	1	20
55001	DAN AGUNDI 3	33	2	1	20
55010	KATSINA 33	33	1	1	20
55011	ZARIA 33	33	1	1	20
55032	MALUMFASHI_3	33	1	1	20
55051	DAKATA T2	33	1	1	20
55057	KUMB T2	33	1	1	20
55069	KD TWN T2	33	1	1	20
55072	KD TWN T3	33	1	1	20
72009	AWKA 1	132	1	1	20
75002	APIR 33	33	1	1	20
75017	YANDEV 33	33	1	1	20
75048	APIR_33B	33	1	1	20
15006	AKANGBA 33	33	1	1	24
15007	AKOKA T1 33	33	1	1	24
15009	ALAUSA 33	33	1	1	24
15010	ALIMOSHO 33	33	1	1	24
15014	EJIGBO 33	33	1	1	24
15015	IJORA 33	33	1	1	24
15018	OGBA 33	33	1	1	24
15028	ISOLO 33	33	1	1	24
15079	OTTA T2	33	1	1	24
15080	OLD ABEOK T2	33	3	1	24
15128	EJIGBO 33	33	1	1	24
22017	ONDO2 1	132	1	1	24
25011	ILORIN 33	33	1	1	24

Bus Number	Bus Name	Voltage (kV)	Id	In Service	Capacity (MVar)
25012	ISEYIN 33	33	2	1	24
42008	IRRUA 1	132	1	1	24
45027	IRRUA BBII33	33	1	1	24
32012	KEFFI 1	132	1	1	25
82006	ITU 1	132	1	1	40
22015	OMUARAN 1	132	1	1	50
35036	GWAGWALAD 33	33	1	1	50
52022	HADEJIA 1	132	2	1	50
53001	KANO 3	330	2	1	50
53001	KANO 3	330	3	1	50
32006	APO 1	132	1	1	60
32017	SULEJA 1	132	1	1	60
12004	AKANGBA BBII	132	1	1	72
12032	OGBA 1	132	1	1	72
82010	UYO 1	132	1	1	100

Source: JICA Study Team

The status of capacitors required in the Dry Season Off-Peak case is shown in Table 7-5.12.

Table 7-5.12 Capacitor requirements for the 2025 Dry Season Off-Peak

Bus Number	Bus Name	Voltage (kV)	Id	In Service	Capacity (MVar)
15002	AGBARA 33	33	1	1	20
15011	ABEOKUTA OLD	33	2	1	20
15022	IKORODU 33	33	2	1	20
15027	ILUPEJU 33	33	1	1	20
25004	AYEDE 33	33	1	1	20
25012	ISEYIN 33	33	1	1	20
25018	AKURE T3A 33	33	1	1	20
25035	SHAGAMU 33	33	1	1	20
25038	IJEBU-ODE 33	33	1	1	20
35001	APO 33	33	2	1	20
35012	MINNA 33	33	1	1	20
42014	EFFURUN 1	132	2	1	20
42015	AMUKPE 1	132	1	1	20
45003	OKENE 33	33	1	1	20
52022	HADEJIA 1	132	1	1	20
55001	DAN AGUNDI 3	33	2	1	20
55010	KATSINA 33	33	1	1	20
15006	AKANGBA 33	33	1	1	24
15007	AKOKA T1 33	33	1	1	24
15009	ALAUSA 33	33	1	1	24
15010	ALIMOSHO 33	33	1	1	24
15014	EJIGBO 33	33	1	1	24
15015	IJORA 33	33	1	1	24
15028	ISOLO 33	33	1	1	24
15079	OTTA T2	33	1	1	24
15128	EJIGBO 33	33	1	1	24
22017	ONDO2 1	132	1	1	24
25011	ILORIN 33	33	1	1	24
25012	ISEYIN 33	33	2	1	24
42008	IRRUA 1	132	1	1	24

Bus Number	Bus Name	Voltage (kV)	Id	In Service	Capacity (MVar)
45027	IRRUA BBII33	33	1	1	24
52022	HADEJIA 1	132	2	1	24
32012	KEFFI 1	132	1	1	25
82006	ITU 1	132	1	1	40
32021	NIAMEY 1	132	2	1	45
22015	OMUARAN 1	132	1	1	50
32006	APO 1	132	1	1	60
12004	AKANGBA BBII	132	1	1	72
82010	UYO 1	132	1	1	100

Source: JICA Study Team

7-5-5 Expansion Plan for 2025

In addition to the projects undertaken by TCN and NIPP, the following 330 and 132 kV lines, shown in Table 7-5.13, are included in the 2025 model. These are also in addition to those included in the 2020 model. A priority ranking from 1 to 3 has been included in the table, with 1 denoting the highest priority.

Table 7-5.13 Additional lines required by 2025 (1)

No	Area	From	To		Voltage (kV)	Length (km)	Remarks	Priority/ Ranking
1		Ejio (Arigbajo)	Ayede	SC	330	50	Turn-in/out Ejio (Arigbajo)-Osogbo line at Ayede, or have one direct line Ikeja West-Ayede, instead of two lines: Ikeja West Ejio (Arigbajo) and Ejio (Arigbajo)-Osogbo	1
2		Birnin-Kebbi	Sokoto	DC	330	130	in parallel of existing 132 kV	3
3	Part of North-West Ring	Sokoto	Talata Mafara	DC	330	100		3
4		Talata Mafara	Gusau	DC	330	125		3
5		Gusau	Funtua	DC	330	70		2
6		Funtua	Zaria	DC	330	70		2
7		Olorusongo	Ejio (Arigbajo)	DC	330	20	JICA. Already a DC. 4 circuits are required, or conversion of the two circuits from twin to Quad-bundle conductors.	2
8		Katsina	Daura	DC	330	40	Undertaken by TCN as part of the Northern Corridor Transmission projects 2, to be financed by AFD	2
9		Daura	Kazaure	DC	330	25	Undertaken by TCN as part of the Northern Corridor Transmission projects 2, to be financed by AFD	2
10	Part of North-East Ring	Damaturu	Maiduguri	DC	330	260	If not by 2020, implement as soon as possible thereafter (An SC already exists.)	3
11		Gombe	Daimaturu	DC	330	160	If not by 2020, implement as soon as possible thereafter (An SC already exists.)	3
12		Gombe	Yola	DC	330	240	If not by 2020, implement as soon as possible thereafter (An SC already exists.)	3
13		Yola	Jalingo	DC	330	160	If not by 2020, implement as soon as possible thereafter (1 SC via Mayo Belwa)	3
14	Mambila evacuation	Mambila	Jalingo	2xDC	330	95	2xDC only if N-2 is adopted, otherwise 1xDC	1

No	Area	From	To		Voltage (kV)	Length (km)	Remarks	Priority/ Ranking
15		Mambila	Wukari	2xDC	330	159	2xDC only if N-2 is adopted, otherwise 1xDC	1
16		Wukari	Makurdi	DC	330	159		1
16		Wukari	Lafia	DC	330	95	after 2025	3
18		Shiroro	Kaduna	DC	330	96	or upgrade to 4-b (Quad). Two DC project with Quad conductors is undertaken by TCN as part of the Northern Corridor Transmission projects 2, to be financed by AFD	3
19		Ejio (Arigbajo)	Ajgunle (New Agbara)	DC	330	40	JICA.	2
20		Ejio (Arigbajo)	Likosi (Ogijo)	DC	330	48	JICA.	2
21		Ajgunle (New Agbara)	Badagry	DC	132	32	JICA.	2
22		Ejio (Arigbajo)	New Ajeokuta	DC	132	37	JICA.	2
23		Gwangwalada	Shiroro	DC	330		a SC exists	1
24		Benin North	Omosho	DC	330	110	Quad conductors. May be required before 2025 and as early as 2022 for the evacuation of new Ethiope PP	1
25		Zungeru	Kainji	DC	330	200		2
26		Zungeru	Shiroro	DC	330	25		2
27	Part of the future Supergrid	Ikot-Ekpene	Makurdi	DC	330	320		1
28		Makurdi	Gwangwalada	DC	330	180		1
29		Ajaokuta	Gwangwalada	DC	330	150		1
30		Osogbo	Gwangwalada	DC	330	250		1
31		Gwangwalada	Funtua	DC	330	250		1

Source: JICA Study Team

Furthermore, since a number of undervoltages were encountered in the Dry Season Peak case and also to meet the N-1 security criterion, the following additions, shown in Table 7-5.14, were made at 132 kV level:

Table 7-5.14 Additional 132 kV lines required by 2025 (2)

No	From	To		Voltage (kV)	Length (km)	Remarks	Priority/ Ranking
1	Shiroro	Tegina	SC	132	65	SC only exists. Add a second SC	1
2	Tegina	Kontagora	SC	132	90	SC only exists. Add a second SC	1
3	Kontagora	Yelwa-Yauri	SC	132	88	SC only exists. Add a second SC	1
5	Ganmo	Ilorin	SC	132	10.5	SC only exists. Add a second SC	3
6	Obajana	Egbe	DC	132	97	new DC	1
7	Omosho	Ondo	DC	132	98	new DC	1
8	Benin	Irrua	SC	132	88	SC only exists. Add a second SC	2
9	Irrua	Ukpilla	SC	132	43	SC only exists. Add a second SC	2
10	Ukpilla	Okene	SC	132	33	SC only exists. Add a second SC	3
11	Shagamu	Ijebu-Ode	SC	132	41	SC only exists. Add a second SC	3
12	Dakata	Gagarawa	SC	132	89	SC only exists. Add a second SC	3
13	Gagarawa	Hadejia	SC	132	60	SC only exists. Add a second SC	3
14	Dakata	Kumboso	SC	132	30	SC only exists. Add a second SC	3
15	Obajana	Okene	DC	132	97	New DC	2
16	Kainji	Iseyin	DC	132	200	New DC	1

Source: JICA Study Team

Due to the thermal overloads encountered under normal (N-0) operation, it is necessary for a number of 132kV lines rated 125 MVA to be reconducted with ZTACIR conductors or ACCC Oriole CTC Global conductors, already used by TCN.

The following lines shall be reconducted, as per Table 7-5.15.

The table shows the new ratings after reconductoring:

Table 7-5.15 132 kV lines to be reconducted

From Bus	Bus name	To bus	Bus name	Id	Rating (MVA)	Length (km)
12002	EGBIN 1	12025	IKORODU	1	225	20
12002	EGBIN 1	12025	IKORODU	2	225	20
12046	OGIJO 1	22027	SHAGAMU 1	1	188	16
12046	OGIJO 1	22027	SHAGAMU 1	2	188	16
22000	AYEDE 1	22006	IBADAN NORTH	1	188	12
22000	AYEDE 1	22006	IBADAN NORTH	2	188	12
22000	AYEDE 1	22012	JERICH0 1	2	188	6
82001	ALAOJI 1	82026	ABA 1	1	188	10
82001	ALAOJI 1	82026	ABA 1	2	188	10
82005	EKET 1	82024	IBOM IPP 1	1	188	45
82005	EKET 1	82024	IBOM IPP 1	2	188	45
82007	PHCT MAIN1	82009	PHCT TOWN2 1	1	188	6
82007	PHCT MAIN1	82036	RUMUSOI 1	1	188	10
82007	PHCT MAIN1	82036	RUMUSOI 1	2	188	10
82019	OMOKU 1	82036	RUMUSOI 1	1	225	20
82019	OMOKU 1	82036	RUMUSOI 1	2	225	20

Source: JICA Study Team

7-6 Examination of the Need for a Supergrid

7-6-1 Requirement for Supergrid (330, 500 or 750 kV)

The load-flow simulations with generation and load, as detailed in the previous Section, showed that without a major upgrade of the transmission system, widespread undervoltages and overloads will proliferate throughout the system and at all voltage levels, leading to high system losses. It is therefore considered necessary and appropriate at this stage to roll out the new “supergrid” in full, i.e. a backbone for bulk transmission at 330, 500 or 750 kV. In addition to the supergrid transmission lines, other 330 kV transmission lines have also been considered and assessed, as per TCN’s request, such as:

- Yola-Little Gombi-Biu-Damaturu
- Damaturu-Potiskum-Azare-Dutse-Jogana
- Osogbo-Okene-Ajeokuta-Ayangba-Makurdi
- Mambila-Kashimbila-Ogoja-Ibom-Calabar
- Ugheli (Delta)-Onne (PH)
- Ugheli-Okpai

The following lines, requested to be assessed by TCN, were already introduced in 2025:

- Zunkeru-Kainji
- Zunkeru-Shiroro

With regards to the conductor necessary for each supergrid option, the following arrangements are

recommended:

- At 330 kV a Double-Circuit is proposed with 4-bundle (Quad) Bison conductors for each circuit.
- At 500 kV a Single-Circuit is proposed with 4-bundle (Quad) Bison conductors.
- At 750 kV a Single-Circuit is proposed with 5-bundle Bison conductors, which is typical at this voltage level due to corona phenomenon.


The main electrical characteristics are summarized in Table 7-6.1.

Table 7-6.1 Conductor parameters for the proposed supergrid

Voltage Level		No of Conductors of bundle	R (ohms/km)	L (mH/km)	X (Ω /km)	C (μ F/km)	C (nF/km)	Thermal Rating (MVA)	Zs (ohms)	SIL (MW)
330 kV	DC	4	0.019	0.7962	0.25	0.014	14	2x1,550	238.5	456
500 kV	SC	4	0.019	0.8908	0.2797	0.0127	12.7	2,350	264.8	944
750 kV	SC	5	0.015	0.9201	0.2889	0.0123	12.3	4,400	273.5	2,057

Source: JICA Study Team

The proposed tower configurations for a typical SC 500 and/or 750 kV EHV grid are shown in Figure 7-6.1.



Source: JICA Study Team

Figure 7-6.1 Towers for 500 and 750 kV EHV Grids

7-6-1-1 Comparison of Load-flow Results Between the Two EHV Options

The comparison of load-flow results for 2030 between the two EHV options is summarized in Table 7-6.2. The system loading is taken between the peak and off-peak values.

Table 7-6.2 Load-flow results for 2030

Voltage Level (kV)	O/V and U/V of 330 kV and above (outside 0.9-1.05)	O/L of 330 kV above 80%	Losses (MW)	Remarks
330	None	7 circuits*	1,124 (4.69%)	Lower losses than 500 kV (line losses are higher but no transformer losses are involved)
500	None	12 circuits *	1,264 (5.25%)	206 MW (0.85%) higher losses compared to the 750-kV option
750	None	6 circuits**	1,058 (4.42%)	Slighter lower losses than the 330-kV option

Source: JICA Study Team

(1) 330 kV System

BUS#	X--	NAME	--X	BASKV	AREA	BUS#	X--	NAME	--X	BASKV	AREA	CKT	LOADING	RATING	PERCENT
23001		OSOGBO	3	330.00*	2	23003		GANMO	3	330.00	2	1	626.5	777.3	80.6
23005		AKURE	3	330.00	2	43011		EYEAN_3		330.00*	4	3	641.0	777.3	82.5
43000		AJAOKUTA	3	330.00	4	43005		GEREGU		330.00*	4	1	647.7	777.3	83.3
43000		AJAOKUTA	3	330.00	4	43005		GEREGU		330.00*	4	2	647.7	777.3	83.3
43002		BENIN	3	330.00	4	43004		SAPELE	3	330.00*	4	1	648.7	777.3	83.5
43002		BENIN	3	330.00	4	43004		SAPELE	3	330.00*	4	2	648.7	777.3	83.5
43002		BENIN	3	330.00	4	43004		SAPELE	3	330.00*	4	3	648.7	777.3	83.5

(2) 500 kV System

BUS#	X--	NAME	--X	BASKV	AREA	BUS#	X--	NAME	--X	BASKV	AREA	CKT	LOADING	RATING	PERCENT
13000		AJA	3	330.00*	1	13034		LEKKI	330	330.00	1	1	637.0	777.0	82.0
13000		AJA	3	330.00*	1	13034		LEKKI	330	330.00	1	2	637.0	777.0	82.0
13028		ARIGBAJO		330.00*	1	23000		AYEDE	3	330.00	2	1	689.7	777.3	88.7
23001		OSOGBO	3	330.00*	2	23003		GANMO	3	330.00	2	1	651.0	777.3	83.7
23005		AKURE	3	330.00	2	43011		EYEAN_3		330.00*	4	3	760.6	777.3	97.9
43000		AJAOKUTA	3	330.00	4	43005		GEREGU		330.00*	4	1	648.6	777.3	83.4
43000		AJAOKUTA	3	330.00	4	43005		GEREGU		330.00*	4	2	648.6	777.3	83.4
43002		BENIN	3	330.00	4	43004		SAPELE	3	330.00*	4	1	651.2	777.3	83.8
43002		BENIN	3	330.00	4	43004		SAPELE	3	330.00*	4	2	651.2	777.3	83.8
43002		BENIN	3	330.00	4	43004		SAPELE	3	330.00*	4	3	651.2	777.3	83.8
43008		LOKOJA	_3	330.00	4	43012		ZUMA		330.00*	4	1	662.9	777.3	85.3
43008		LOKOJA	_3	330.00	4	43012		ZUMA		330.00*	4	2	662.9	777.3	85.3

(3) 750 kV System

BUS#	X--	NAME	--X	BASKV	AREA	BUS#	X--	NAME	--X	BASKV	AREA	CKT	LOADING	RATING	PERCENT
23005		AKURE	3	330.00	2	43011		EYEAN_3		330.00*	4	3	648.8	777.3	83.5
43000		AJAOKUTA	3	330.00*	4	43005		GEREGU		330.00	4	1	662.1	777.3	85.2
43000		AJAOKUTA	3	330.00*	4	43005		GEREGU		330.00	4	2	662.1	777.3	85.2
43002		BENIN	3	330.00	4	43004		SAPELE	3	330.00*	4	1	631.4	777.3	81.2
43002		BENIN	3	330.00	4	43004		SAPELE	3	330.00*	4	2	631.4	777.3	81.2
43002		BENIN	3	330.00	4	43004		SAPELE	3	330.00*	4	3	631.4	777.3	81.2

7-6-1-2 Conclusion on Supergrid/EHV Options

The load-flow simulations have shown that without a major upgrade of the transmission system, widespread undervoltages and overloads will proliferate system-wide and at all voltage levels, meaning high system losses.


It is therefore considered necessary and appropriate at this stage to introduce the full new “supergrid”, i.e. a backbone for bulk transmission at either 330, 500 or 750 kV. It was found necessary to introduce part of this supergrid.

A number of configurations have been examined and compared in terms of efficacy in voltage support, system losses and easing the line loadings of the existing and planned 330 kV systems.

The optimum configuration of a 330, 500 or 750 kV EHV grid is shown in Figure 7-6.2.

Table 7-6.3 Evaluation of 330, 500 or 750 kV supergrid

Voltage level	Voltage support	System loss	Stability	Cost	Comprehensive evaluation
330 kV	A	A	A	B	1
500 kV	B	A	B	A	2
750 kV	B	A	B	C	3



Source: JICA Study Team

Figure 7-6.2 Supergrid Configuration

The supergrid will encompass the following substations: Ikot-Ekpene, Benin, Egbin, Ajegunle (New Agbara), Osogbo, Gwangwalada, Makurdi, Ajeokuta, Funtua, Kainji, Bernin Kebbi.

From technical perspectives, both the 330 and 500 kV options are adequate. Furthermore, taking into consideration that:

- Capacity of 330 kV supergrid lines: 3,100 MVA
- Capacity of 500 kV supergrid lines: 2,350 MVA
- Difference in losses between 330 and 500 kV supergrids: Marginal
- Impact on O/U voltages and overloads: 330 kV advantageous
- Higher static N-1 security of the 330 kV supergrid due to the Double-Circuit lines involved

It appears that the 330 kV supergrid system is technically the preferred option.

There is no justification to adopt and/or consider further any higher (750 kV) option for the EHV grid, particularly when the implications in cost differences are taken into account.

The higher transmission capacity (4,400 MVA) is not required at this stage and the marginal differences in losses cannot offset the high investment cost required in the planning horizon of this Master Plan.

7-6-1-3 Supergrid Transmission Lines

The following table summarizes the Double-Circuit 330kV transmission lines required to complete the supergrid for the 2030 system requirements. Part of this supergrid transmission system is required by 2025, as mentioned in the previous sections:

Table 7-6.4 Supergrid lines for 2030

From	To	Thermal rating (MVA)	Length (km)	Remarks
Ikot-Ekpene	Benin	2 x 1,550	300	
Ikot-Ekpene	Makurdi	2 x 1,550	320	Required in 2025
Benin	Egbin	2 x 1,550	230	
Egbin	Ajegunle (New Agbara)	2 x 1,550	50	
Benin	Osogbo	2 x 1,550	200	
Ajegunle (New Agbara)	Osogbo	2 x 1,550	150	
Osogbo	Kainji	2 x 1,550	200	
Benin	Ajeokuta	2 x 1,550	150	
Ajeokuta	Gwangwalada	2 x 1,550	150	Required in 2025
Gwangwalada	Makurdi	2 x 1,550	180	Required in 2025
Gwangwalada	Kainji	2 x 1,550	250	
Gwangwalada	Funtua	2 x 1,550	260	Required in 2025
Gwangwalada	Osogbo	2 x 1,550	250	Required in 2025
Kainji	Bernin Kebbi	2 x 1,550	300	

Source: JICA Study Team

(*) Note on the introduction of the “supergrid” in 2025:

The supergrid is to be fully rolled out in 2030 and its necessity is demonstrated in Section 7-6. However, due to the forecast high increase in load demand in the Abuja region and elsewhere by 2025 plus resulting overloads and undervoltages, the most cost-effective approach will involve introducing part of the supergrid in 2025, to avoid other temporary and potentially costly measures which will not be needed after the full roll-out of the supergrid in 2030.

A full analysis of the supergrid and justifications for the selection of the appropriate voltage level and conductor type option is given in Section 7-6.

In addition to the supergrid transmission lines, other 330 kV transmission lines have also been considered and assessed, as per TCN's request, such as:

- Yola-Little Gombi-Biu-Damaturu
- Damaturu-Potiskum-Azare-Dutse-Jogana
- Osogbo-Okene-Ajeokuta-Ayangba-Makurdi
- Mambila-Kashimbila-Ogoja-Ibom-Calabar
- Ugheli (Delta)-Onne (PH)
- Ugheli-Okpai

However, with the introduction of the supergrid, these lines will be lightly loaded. Furthermore, during off-peak loading periods their charging MVar will necessitate the operation of reactors, particularly in the north-eastern area of Nigeria. Accordingly, before a final decision is made, it is recommended that their benefits be reassessed at a later stage, once more updated information is available on load demand in the corresponding regions.

7-7 Expansion Plan for 2030

7-7-1 2030 Base Cases Load-flow Analysis

7-7-1-1 Load demand

The demand load in 2030 in each DisCo area is shown in Table 7-7.1.

Table 7-7.1 Load demand per DisCo

DisCo		Load Demand 2025 (MW)	Increase (2025-2030)	Load Demand 2030 (MW)
IKEDC	1-Ikeja	2,058	42%	2,921
IBEDC	2-Ibadan	2,285	43%	3,267
AEDC	3-Abuja	2,329	50%	3,500
BEDC	4-Benin	1,852	34%	2,489
KAEDCO	5-Kaduna	1,169	81%	2,117
JEDC	6-Jos	646	60%	1,035
EEDC	7-Enugu	1,668	19%	1,979
PHEDC	8-Port Harcourt	1,762	35%	2,385
EKEDC	9-Eko	1,837	22%	2,240
KEDCO	10-Kano	1,565	64%	2,570
YOLA	11-Yola	532	77%	942
Total	-	17,703	43.75%	25,447
Export*	-	1,541	-	1,831
Total load	-	19,244	-	27,278

Source: JICA Study Team

Ref: 330 kV export lines: To Sakete 550 MW, To Faraku 500 MW, To Zabori 631 MW


The total generation assumed to be running in each DisCo area is shown in Table 7-7.2 and Figure 7-7.1. It includes 640 MW from PV and 3,240 MW from HPP.

Table 7-7.2 Generation per DisCo running in 2030

DisCo	Generation (MW)	
IKEDC	1-Ikeja	3,041
IBEDC	2-Ibadan	1,415
AEDC	3-Abuja	5,399
BEDC	4-Benin	5,834
KAEDCO	5-Kaduna	212
JEDC	6-Jos	105
EEDC	7-Enugu	1,051
PHEDC	8-Port Harcourt	8,029
EKEDC	9-Eko	1,350
KEDCO	10-Kano	649
YOLA	11-Yola	1,501

Source: JICA Study Team

The load and total running generation for each DisCo is shown graphically in Figure 7-7.1.



Source: JICA Study Team

Figure 7-7.1 2030 Generation and Loads Per DisCo


Analytically, the generation assumed running is listed in Table 7-7.3. The new generation added, or increase in power plant output, in comparison to the 2025 case, is shown in bold.

Table 7-7.3 Generation running in 2030

Bus Number	Bus Name	P _{Gen} (MW)	Bus Number	Bus Name	P _{Gen} (MW)	Bus Number	Bus Name	P _{Gen} (MW)
86012	AFAM VI GT11	150	86069	GBARAIN_GTB2	102	46026	NIPP2 ST	257
86013	AFAM VI GT12	150	86055	GEN_AMADI	45	96007	OATS	270
86014	AFAM VI GT13	105	56010	GEN_KADUNA	194	96021	ODUGPANI NIP	508
86015	AFAM VI ST10	180	46023	GER NIPPGT21	140	96020	ODUGPANI NIP	229
86003	AFAM2 GT5-6	48	46024	GER NIPPGT22	140	76000	OKPAI GT11	149
86004	AFAM2GT 7-8	48	96015	GEREGU 2	266	76001	OKPAI GT12	148
86005	AFAM3 GT9-10	54	96014	GEREGU 2	248	76020	OKPAI GT4PH2	135
86006	AFAM3GT11-12	54	46020	GEREGU GT11	124	76021	OKPAI GT5PH2	135
86080	AKWA-IBOM NU	1800	56003	GURARA GBUS	18	76002	OKPAI ST18	126
86039	ALAOJI_GTB1	112.5	96002	HUDSON	135	76022	OKPAI STPH2	135
86040	ALAOJI_GTB2	112.5	86025	IBOM GT1	32	16064	OLOR NIPPST1	100
86041	ALAOJI_GTB3	112.5	86026	IBOM GT2	32	16065	OLOR NIPPST2	100
86042	ALAOJI_GTB4	112.5	86027	IBOM GT3	32	16060	OLORNIPPGT11	100
86043	ALAOJI2_STB1	257	86028	IBOM II	497	16061	OLORNIPPGT12	100
86031	ALSCON GT1	90	96013	IHOVBOR 2	229	16062	OLORNIPPGT21	100
86032	ALSCON GT2	117	46031	IHOVBOR_GTB1	110	16063	OLORNIPPGT22	100
46027	ASCO G1	50	46032	IHOVBOR_GTB2	110	16050	OLORUNSO GT1	30
46028	ASCO G2	50	46033	IHOVBOR_GTB3	110	16055	OLORUNSO GT6	15
96011	AZIKEL	440	46034	IHOVBOR_GTB4	110	16057	OLORUNSO GT8	30
46035	AZURA GT	280	66033	JBS WIND	70	86047	OMA_GT	450
96001	BRESSON	135	36006	JEBBA 2G1	80	86022	OMOKU2 GT2	102
16008	BRESSON GTS	80	36007	JEBBA 2G2	80	26026	OMOTNIPP GT1	115
96009	CABLE INLAND	1350	36008	JEBBA 2G3	80	26027	OMOTNIPP GT2	115

Bus Number	Bus Name	P _{Gen} (MW)	Bus Number	Bus Name	P _{Gen} (MW)	Bus Number	Bus Name	P _{Gen} (MW)
86061	CALABAR_GTB2	100	36009	JEBBA 2G4	80	26030	OMOTOSHO 2+	230
86060	CALABAR_GTB3	100	36011	JEBBA 2G6	80	26020	OMOTOSO GT1	74
76011	CENTURY IPP	223	36004	KAINJ 1G11	80	96008	ONDO IPP	400
96006	CHEVRON TEX	702	36005	KAINJ 1G12	80	16012	PARAS	270
86030	CUMMINS	135	36000	KAINJ 1G5	80	16011	PARASGT1-9	54
46006	DELTA IV 2-1	140	36001	KAINJ 1G6	80	46070	PROTON	135
46007	DELTA IV 2-2	140	36002	KAINJ 1G7-8	160	86070	QUA IBOE PP	468
46008	DELTA IV 2-3	140	36003	KAINJ 1G9-10	160	86035	RIVERS_GT1	172
46010	DELTAIV GT19	133	76013	KASHIMB HPP	21	46050	SAP_NIPP_GT1	100
46011	DELTAIV GT20	133	56011	KAZAURE PV1	80	46051	SAP_NIPP_GT2	100
66005	DKOWA G1	14	56012	KAZAURE PV2	80	46052	SAP_NIPP_GT3	100
96018	EGBEMA II	114	56013	KAZAURE PV3	80	46012	SAPELE GT1-2	180
86067	EGBEMA_GTB3	100	56014	KAZAURE PV4	80	46013	SAPELE GT3-4	90
16000	EGBIN GT 1	254.1	56015	KAZAURE PV5	80	46060	SAPELE ROT	140
16001	EGBIN GT 2	254.1	56016	KAZAURE PV6	80	46061	SAPELE ROT 2	140
16002	EGBIN GT 3	254.1	56017	KAZAURE PV7	80	46062	SAPELE ROT 2	130
16003	EGBIN GT 4	254.1	56018	KAZAURE PV8	80	36012	SHIROR 411G1	120
16004	EGBIN ST 5	254.1	46080	KOJI NUCLEAR	1800	36013	SHIROR 411G2	120
16005	EGBIN ST 6	254.1	55075	KT WF 33	9	36014	SHIROR 411G3	120
86050	ELEME	68	16010	LAFARAGE 2	200	96016	TURBINE DR	300
86056	ESSAR GTS	150	66008	MAMBILA GT2	250	96004	WESCOM	225
86057	ESSAR ST	140	66009	MAMBILA GT3	250	96017	YELLOW STONE	324
96012	ETHIOPE	450	66010	MAMBILA GT4	250	46029	ZUMA	810
46037	ETHIOPE GTS	310	66011	MAMBILA GT5	250	86071	ZUMA (GAS)	337
46038	ETHIOPE ST	140	66014	MAMBILA GT8	250	36024	ZUNGE_G1	150
86048	GBARAIN 2 GT	511	66015	MAMBILA GT9	250	36025	ZUNGE_G2	150
86068	GBARAIN_GTB1	102	96005	MBH	270			

Source: JICA Study Team




Source: JICA Study Team

Figure 7-7.2 Configuration of the 330-kV grid in 2030

7-7-2 Summary of the Load-flow Calculations for 2030

The ratings of the 330kV DC option are found adequate for meeting the Grid Code requirements. Using this option, the transmission system loading is shown in Figure 7-7.3.



Source: JICA Study Team

Figure 7-7.3 Transmission Line Loadings in 2030

No overloads or voltage violation encountered in the 330 and 132 kV systems.

One or two minor voltage violations at 132 kV (0.84 pu) will be corrected when the 132-kV network is reinforced to meet the N-1 criterion, as proposed earlier.

7-7-3 Reactive Power Compensation

In addition to the requirements described for the 2025 case, the following reactive power compensation would be required by 2030:

- At 330 kV Gombe substation, 100 MVar Capacitors or SVC.
- With regards to Bernin Kebbi, for the 2025 case, power compensation (150 MVar capacitors) will be required at Bernin Kebbi due to export requirements to WAPP. It should be noted however that in 2030 the proposed supergrid will be extended with a Kainji-Bernin Kebbi line. Once this implemented, there will be no further need for reactive power compensation at Bernin Kebbi.
- Due to the sharp increase in forecast load in Abuja, the largest reactive power compensation is required at the Abuja area (Gwangwalada 330kV substation) of approx. 700 MVar. It is recommended that this,

too, be the subject of a separated and dedicated reactive power compensation study, to determine the optimum locations and sizes required. Such a study shall be conducted at a later stage, when the current information on generation expansion plans and load forecast is updated.

However, if the Gwangwalada Power Plant of 1,000MW is in operation in 2030, instead of later, there will be no need for reactive power compensation in that area.


- 20 MVar capacitor at Gashuwa 132 kV
- 60 MVar capacitor at Apo 132 kV
- 25 MVar capacitor at Keffi 132 kV
- 40 MVar capacitor at Uba 132kV

7-8 Expansion Plan for 2035

7-8-1 2035 Base Cases Load-flow Analysis

7-8-1-1 Transmission system

Figure 7-8.1 below shows the 330kV transmission system in 2035.



Source: JICA Study Team

Figure 7-8.1 Configuration of 330 kV grid in 2035

Table 7-8.1 shows that the increase in load demand in 2035.

Table 7-8.1 Load demand per DisCo

DisCo		Load Demand 2030 (MW)	Increase (2030-2035)	Load Demand 2035 (MW)
IKEDC	1-Ikeja	2,921	21.06%	3,536
IBEDC	2-Ibadan	3,267	24.08%	4,054
AEDC	3-Abuja	3,500	25.66%	4,398
BEDC	4-Benin	2,489	16.54%	2,901
KAEDCO	5-Kaduna	2,117	19.61%	2,533
JEDC	6-Jos	1,035	4.24%	1,079
EEDC	7-Enugu	1,979	2.93%	2,037
PHEDC	8-Port Harcourt	2,385	17.49%	2,802
EKEDC	9-Eko	2,240	6.33%	2,382
KEDCO	10-Kano	2,570	38.06%	3,549
YOLA	11-Yola	942	53.72%	1,448
Total	-	25,447	20.72%	30,719
Export*	-	1,830	-	2,000
Total load	-	27,277	-	32,719

Source: JICA Study Team

Ref: 330 kV export lines: To Sakete 550 MW, To Faraku 550 MW, To Zabori 750 MW

7-8-1-2 Generation

The total generation assumed to be running in each DisCo area is shown in Table 7-8.2, as well as in Figure 7-8.1. It includes 840 MW from PV and 4,239 MW from HPP.


Table 7-8.2 Generation per DisCo running in 2035

DisCo	Generation (MW)	
IKEDC	1-Ikeja	2,640
IBEDC	2-Ibadan	1,314
AEDC	3-Abuja	6,789
BEDC	4-Benin	6,465
KAEDCO	5-Kaduna	712
JEDC	6-Jos	1,605
EEDC	7-Enugu	1,667
PHEDC	8-Port Harcourt	9,022
EKEDC	9-Eko	1,350
KEDCO	10-Kano	1,029
YOLA	11-Yola	2,350

Source: JICA Study Team

7-8-2 Summary of the Load-flow Calculations for 2035

The loading of the transmission system is shown in Figure 7-8.2.



Source: JICA Study Team

Figure 7-8.2 Transmission Line Loadings in 2035

7-8-2-1 Transmission Line Overloads and Voltage Violations

No overloads or voltage violations encountered in the 330 and 132 kV systems.

Two or three minor voltage violations at 132 kV (0.84 pu) will be corrected when the 132-kV network is reinforced to meet the N-1 criterion, as proposed earlier.

7-8-3 New Transmission Lines and Reactive Power Requirements

7-8-3-1 New transmission lines

- The 330 kV DC line Zuma-Lokoja (25 km) is overloaded due to the Zuma power plant output. Reconductoring is recommended to Quad conductors.
- The 330 kV DC line Makurdi-Lafia is overloaded due to the new Ramos 900 MW coal-fired power plant.

A new Wukari-Lafia 330 kV DC line (95 km) is proposed, which will remove these overloads and improve voltage profiles.

- The following 330 kV lines are overloaded between 101 and 107% under normal (N-0) operation and need to be converted to Quad conductors

Aja - Lekki

Benin North - Akure

- To meet the N-1 criterion and also remove undervoltages, a conversion to a DC circuit is recommended for the following SC 132 kV lines:

Kwaya Kusar - Biu

Biu - Damboa

Damboa - Maiduguri

To meet the N-1 criterion and also eliminate overload, new transmission lines are required, as listed in Table 7-8.3.

Table 7-8.3 New transmission lines and reinforcements required for 2035

Substation Name	Substation Name	Voltage (kV)	Length (km)	Type	Proposed Solution
Wukari	Lafia	330	95	DC	New DC transmission line
Zuma	Lokoja	330	25	DC	Reconductoring of DC to Quad conductor
Aja	Lekki	330	7	DC	Reconductoring of DC to Quad conductor
Benin North	Akure	330	130	SC	Reconductoring to Quad conductor or conversion to DC
Kwaya Kusar	Biu	132	42	SC	Convert from SC to DC
Biu	Damboa	132	140	SC	Convert from SC to DC
Damboa	Maiduguri	132	64	SC	Convert from SC to DC

Source: JICA Study Team

7-8-3-2 Reactive Power Compensation

In addition to the requirements described for the 2030 case, the following reactive power compensation would be required by 2035:

- Due to the sharp increase in forecast load in Abuja, reactive power compensation is required at the Abuja area (Gwangwalada 330 kV substation).

However, if the Gwangwalada Power Plant of 1,200 MW is in operation in 2035, instead of later, there will be no need for reactive power compensation in that area.

- 250 MVar capacitors at Gombe 330 kV
- 700 MVar capacitors at Benin Kebbi 330 kV
- 300 MVar capacitors at Ikeja West 132 kV

7-8-3-3 Comparison of Load-flow Results Between the EHV Options

The comparison of load-flow results for 2035 between the two EHV options is summarized in Table 7-8.4.

Table 7-8.4 LF results for 2035

Voltage Level (kV)	Generation (MW)	O/V and U/V of 330 kV and above (outside 0.9-1.05)	O/L of 330 kV above 80%	Losses (MW)	Remarks
330	28763	5 buses	16 circuits*	1,471 (5.11%)	Slightly lower losses compared to the 500-kV option
500	28974	10 buses	20 circuits *	1,737 (5.99%)	266 MW (0.91%) higher losses compared to the 330-kV option
750	28688	1 bus	12 circuits**	1,359 (4.73%)	Slightly lower losses compared to the 330-kV option

Source: JICA Study Team

7-8-3-4 Conclusion on EHV Options for 2035

The conclusions are the same as for 2030 cases. Based on technical considerations both the 330 and 500 kV options are adequate. Furthermore, taking into consideration that:

- Capacity of 330 kV supergrid lines: 3,100 MVA
- Capacity of 500 kV supergrid lines: 2,350 MVA
- Difference in losses between 330 and 500 kV supergrids: Marginal
- Impact on O/U voltages and overloads: 330 kV advantageous
- Higher static N-1 security of the 330 kV supergrid due to Double-Circuit lines involved

It appears that the 330 kV supergrid system is technically the preferred option.


There is no justification for adopting and/or further considering any higher (750 kV) option for the EHV grid, particularly when the implications in cost differences are taken into account. The higher transmission capacity (4,400 MVA) is not required at this stage and the marginal differences in losses cannot offset the high investment cost required in the planning horizon of this Master Plan.

7-9 Expansion Plan for 2040

7-9-1 2040 Base Cases Load-flow Analysis

7-9-1-1 Transmission system

Figure 7-9.1 below shows the 330kV transmission system in 2040.



Source: JICA Study Team

Figure 7-9.1 Configuration of 330 kV grid in 2040

7-9-1-2 Load demand

Table 7-9.1 shows that the increase in load demand follows approximately the same increase (in percentage) as in the load forecast detailed in Section 5.4.2.

Table 7-9.1 Load demand per DisCo

DisCo		Load Demand 2035 (MW)	Increase (2035-2040)	Load Demand 2040 (MW)
IKEDC	1-Ikeja	3,536	21.61%	4,300
IBEDC	2-Ibadan	4,054	24.70%	5,055
AEDC	3-Abuja	4,398	21.31%	5,336
BEDC	4-Benin	2,901	16.90%	3,391
KAEDCO	5-Kaduna	2,533	20.23%	3,045
JEDC	6-Jos	1,079	4.83%	1,131
EEDC	7-Enugu	2,037	3.67%	2,112
PHEDC	8-Port Harcourt	2,802	17.94%	3,305
EKEDC	9-Eko	2,382	5.44%	2,512
KEDCO	10-Kano	3,549	13.38%	4,023
YOLA	11-Yola	1,448	16.05%	1,680
Total	-	30,719	16.83%	35,890
Export	-	2,000	-	2,000
Total load	-	32,719	-	37,890

Source: JICA Study Team

Ref: 330 kV export lines: To Sakete 550 MW, To Faraku 550 MW, To Zabori 750 MW

7-9-1-3 Generation

The total generation assumed to be running in each DisCo area is shown in Table 7-9.2 as well as in Figure 7-9.1 and includes 990 MW from PV and 4,369 MW from HPP.

Table 7-9.2 Generation per DisCo running in 2040


DisCo	Generation (MW)
IKEDC	4,125
IBEDC	1,575
AEDC	7,949
BEDC	7,635
KAEDCO	832
JEDC	1,745
EEDC	1,904
PHEDC	10,842
EKEDC	1,350
KEDCO	1,019
YOLA	2,470

Source: JICA Study Team

It should be noted that to meet the high load forecast for 2040, an additional power plant is necessary with a minimum capacity of 1,000 MW (such as Ethiopia ph 2) to be located near Egbin S/S.

7-9-2 Summary of Load-flow Calculations for 2040

The loading of the transmission system is shown in Figure 7-9.2.



Source: JICA Study Team

Figure 7-9.2 Transmission Line Loadings in 2040

7-9-2-1 Transmission Line Overloads and Voltage Violations

No voltage violation encountered in the 330 and 132 kV systems.

A few minor voltage violations at 132 kV will be corrected when the 132-kV network is reinforced to meet the N-1 criterion, as proposed earlier.

With regards to thermal overloads of the 330-kV system, the following lines are overloaded and need to be reinforced:

- Aladja - Delta IV
- Osogbo – Ganmo

7-9-3 New Transmission Lines and Reactive Power Requirements

7-9-3-1 New transmission lines

The following new 330 kV transmission lines are recommended at this stage in the North and North-East of the country:

- Yola-Little Gombi-Biu-Damaturu
- Damaturu-Potiskum-Azare-Dutse-Jogana

The required new transmission lines for 2040 are shown in Table 7-9.3.

Table 7-9.3 New transmission lines and reinforcements required for 2040

Substation Name	Substation Name	Voltage (kV)	Length (km)	Type	Proposed Solution
Aladja	Delta IV	330	32	SC	Convert to DC
Osogbo	Ganmo	330	50	SC	Convert to DC
Yola	Little Gombi	330	100	DC	New DC transmission line
Little Gombi	Biu	330	80	DC	New DC transmission line
Biu	Daimaturu	330	130	DC	New DC transmission line
Daimaturu	Potiscum	330	100	DC	New DC transmission line
Potiscum	Azare	330	100	DC	New DC transmission line
Azare	Dutse	330	90	DC	New DC transmission line
Dutse	Jogana	330	76	DC	New DC transmission line

Source: JICA Study Team

7-9-3-2 Reactive Power Compensation

In addition to the requirements described for the 2035 case, reactive power compensation would be required by 2040, considering the following:

- Due to the sharp increase in the forecast load in Abuja, there is an additional reactive power deficit in the Abuja area of approx. 1,500 MVar.
- Additional reactive power deficit at Kano of approx. 600 MVar
- Additional reactive power deficit at Bernin Kebbi of approx. 400 MVar
- Additional reactive power deficit at Ikeja West of approx. 200 MVar

It is recommended that more detailed reactive power compensation studies be conducted at a later stage to determine the optimal sizes and locations of the reactive power equipment for 2040.

7-10 Cost Estimation of Transmission Network Development Plan

7-10-1 Basis for Cost Estimation

For calculation of cost of new transmission lines and substations of the proposed transmission system expansions, a simplified cost model has been prepared. For transmission lines it is based on cost per km of transmission line for each voltage level. For substations, the costs for high-voltage feeders have been estimated and comprise two components: one for high-voltage equipment and another for all other substation components (civil works, steel protection & control equipment, auxiliary power supply, etc.). Furthermore, the costs for main power transformers, reactors and capacitors have also been estimated.

For new 132/33 kV substations, the costs for new 33 kV switchgear have been taken into account. If increasing the transformer capacity in existing 132/33 kV substations, it has been assumed that additional 33 kV switchgear will also be installed. Based on this approach, cost estimation accuracy of $\pm 25\%$ can usually be assumed. Table 7-10.1 below shows the cost components considered in the cost estimation, based on experience with similar projects. The cost estimation is compared with TCN's cost estimations and both agreed that they generally correlate effectively.

Table 7-10.1 Cost components

Unit Costs	
Transmission Lines (million US\$/km)	
132 kV SC Line	0.17
330 kV SC Line	0.22
500 kV SC Line	0.28
750 kV SC Line	0.35
132 kV DC Line	0.26
330 kV DC Line	0.45
132 kV SC Line Reconductoring	0.04
330 kV SC Line Reconductoring	0.08
132 kV DC Line Reconductoring	0.08
330 kV DC Line Reconductoring	0.15
Substations (million US\$)	
132 kV HV equipment	0.70
330 kV HV equipment	1.00
500 kV HV equipment	1.30
750 kV HV equipment	2.20
132 kV feeder (= 132 kV HV equipment + Other components)	1.60
330 kV feeder (= 330 kV HV equipment + Other components)	1.90
30 MVA Transformer 132/11 kV	0.60
60 MVA Transformer 132/33 kV	0.80
150 MVA Transformer 330/132 kV	1.50
1000 MVA Transformer 750/330 kV	10.00
11 kV Switchgear	0.50
33 kV Switchgear	0.70
30 MVar Shunt Reactor – 33 kV (including 33 kV switchgear)	0.50
75 MVar Shunt Reactor – 330 kV	0.80
25 MVar Shunt Capacitor – 33 kV (including 33 kV switchgear)	0.25
25 MVar Shunt Capacitor – 132 kV	0.30
100 MVar Shunt Capacitor – 330kV	1.00
Other components (Civil Works, Steel, Protection, Station Control, Auxiliary Power Supply, Installation etc.)	0.90

Source: JICA Study Team

The following are needed to enhance the power transmission line:

- SC : Installation of Single-Circuit transmission line/Installing a second parallel circuit
- DC : Installation of Double-Circuit transmission line
- RE(SC) : Reconductoring of Single-Circuit transmission line
- RE(DC) : Reconductoring of Double-Circuit transmission line

7-10-2 Transmission Reinforcements Required by 2020

Power system studies have shown that most of the transmission system expansion required by 2025 is needed in northern Nigeria, particularly for the 330-kV system. Under the current transmission system expansion program of TCN and NIPP (see Annexes 7.2a and 7.2b) most of the transmission system expansions have been commissioned in the southern and central parts of Nigeria. Some of the transmission system expansions have already been completed and it is expected that the remainder will be commissioned by 2020 or very soon afterwards.

Based on the results of Chapter 8: Power System Analysis, the costs of additional 330 and 132 kV transmission lines, additional 330/132 kV, 132/33 kV and 132/11 kV transformers as well as additional shunt reactors and shunt capacitors have been estimated.

Although it will be challenging to implement all measures by 2020 as required for over 9 GW power supply of the Nigerian transmission network, a major part of the network expansions is related to the 132-kV network and to additional 330/132 kV and 132/33 kV transformers.

7-10-2-1 Cost estimation of each project

Table 7-10.2 to Table 7-10.8 show the cost estimations for the individual groups of system expansion measures, i.e. transmission lines, transformers and reactive power compensation.

Table 7-10.9 summarizes all additional investments in transmission lines and substations by 2020.

Table 7-10.2 Reinforcements of 132 kV lines overloaded under N-0

Cost Estimation of Reinforcement of 132 kV Transmission Lines overloaded under N-0 by 2020															
No.	Project	Transmission Line						Substation							
		Rated Voltage (kV)	Length (km)	Alternative 1		Alternative 2		Cost of Alternative 1 (Length × Unit Cost) (Million US\$)	Cost of Alternative 2 (Length × Unit Cost) (Million US\$)	330 kV Feeder	132 kV Feeder	33 kV Switchgear	150 MVA, 330/132kV Transformer	60 MVA, 132/33 kV Transformer	Cost (Million US\$)
				Reinforcement	Unit Cost (Million US\$/km)	Reinforcement	Unit Cost (Million US\$/km)								
Overhead Lines															
1	Ibom IPP - Ikot Abasi	132	30	SC	0.17	DC	0.26	5.1	7.8						
Subtotal I								5.1	7.8						
Substations															
1	Ibom IPP									0	1	0	0	0	1.6
2	Ikot Abasi									0	1	0	0	0	1.6
Subtotal II															3.2
Grand Total (Alternative 1)								8.3							
Grand Total (Alternative 2)								14.2							

Source: JICA Study Team

Table 7-10.3 Reinforcements of 132 kV transmission lines overloaded under N-1

Cost Estimation of Reinforcement of 132 kV Transmission Lines overloaded under N-1 by 2020															
No.	Project	Transmission Line						Substation							
		Rated Voltage	Length	Alternative 1		Alternative 2		Cost of Alternative 1 (Length × Unit Cost)	Cost of Alternative 2 (Length × Unit Cost)	330 kV Feeder	132 kV Feeder	33 kV Switchgear	150 MVA, 330/132kV Transformer	60 MVA, 132/33 kV Transformer	Cost
		(kV)	(km)	Reinforcement	Unit Cost (Million US\$/km)	Reinforcement	Unit Cost (Million US\$/km)	(Million US\$)	(Million US\$)						(Million US\$)
Overhead Lines															
1	Gombe - T-Junction	132	40	SC	0.17	DC	0.26	6.8	10.4						
2	Yola - T-Junction	132	56	SC	0.17	DC	0.26	9.5	14.6						
3	Omoku - Rumusoi	132	20	RE	0.08	DC	0.26	1.6	5.2						
4	PHCT Main - Rumusoi	132	10	RE	0.08	DC	0.26	0.8	2.6						
5	Ajaokuta - Okene	132	60	SC	0.17	DC	0.26	10.2	15.6						
6	Benin - Irrua	132	88	SC	0.17	DC	0.26	15.0	22.9						
7	Mando - Kudenda	132	20	RE	0.08	DC	0.26	1.6	5.2						
8	Osogbo - Iwo	132	80	SC	0.17	DC	0.26	13.6	20.8						
9	Yenagoa - Gbarain	132	5	RE	0.08	DC	0.26	0.4	1.3						
10	Afam 1-2-3 - Afam IV	132	1	RE	0.08	DC	0.26	0.1	0.3						
11	Ikeja West - Alimoso	132	4	RE	0.08	DC	0.26	0.3	0.9						
12	Blu - Dadinkowa	132	82	SC	0.17	DC	0.26	13.9	21.3						
13	Yenagoa - Ahoada	132	46	RE	0.08	DC	0.26	3.7	12.0						
14	Ayede - Idaban North	132	12	SC	0.17	DC	0.26	2.0	3.1						
15	Eket - Ibomi IPP	132	45	RE	0.08	DC	0.26	3.6	11.7						
16	Onne - Tramadi	132	10	RE	0.08	DC	0.26	0.8	2.6						
17	PHCT Main - Rivers IPP	132	12	RE	0.08	DC	0.26	1.0	3.1						
18	Zaria - Funtua	132	7	SC	0.17	DC	0.26	1.2	1.8						
Subtotal I								86.1	155.4						
Substations															
1	Ajaokuta									0	1	0	0	0	1.6
2	Okene									0	1	0	0	0	1.6
3	Yenagoa									0	0	0	0	0	0.0
4	Gbarain									0	0	0	0	0	0.0
5	Osogbo									0	1	0	0	0	1.6
6	Iwo									0	1	0	0	0	1.6
7	Blu									0	1	0	0	0	1.6
8	Dadinkowa									0	1	0	0	0	1.6
9	Benin									0	1	0	0	0	1.6
10	Irrua									0	1	0	0	0	1.6
11	Ikeja West									0	0	0	0	0	0.0
12	Alimoso									0	0	0	0	0	0.0
13	Mando									0	0	0	0	0	0.0
14	Kudenda									0	0	0	0	0	0.0
15	PHCT Main									0	0	0	0	0	0.0
16	Rumusoi									0	0	0	0	0	0.0
17	Eket									0	0	0	0	0	0.0
18	Zaria									0	1	0	0	0	1.6
19	Funtua									0	1	0	0	0	1.6
20	Onne									0	1	0	0	0	1.6
21	Tramadi									0	0	0	0	0	0.0
Subtotal II										17.6					
Grand Total - Alternative 1								103.7							

Source: JICA Study Team

Table 7-10.4 Upgrading requirements of 330/132 kV 3-winding transformers overloaded under N-0

Cost Estimation of Upgrading of 330/132 kV 3-winding Transformers overloaded under N-1 by 2020											
No.	Project	Transmission Line				Substation					
		Rated Voltage	Length	Unit Cost	Cost	330 kV Feeder	132 kV Feeder	33 kV Switchgear	150 MVA, 330/132kV Transformer	60 MVA, 132/33 kV Transformer	Cost
		(kV)	(km)	(Million US\$/km)	(Million US\$)						(Million US\$)
Overhead Lines											
Subtotal I					0.0						
Substations											
1	Benin					2	2	0	2	0	10.0
2	Benin North					1	1	0	1	0	5.0
3	Birnin Kebbi					1	1	0	1	0	5.0
4	Ganmo					1	1	0	1	0	5.0
Subtotal II					25.0						
Grand Total					25.0						

Source: JICA Study Team

Table 7-10.5 Upgrading requirements of 132/33 kV and 132/11 kV transformers under N-0 by 2020

Cost Estimation of Upgrading of Transformers overloaded under N-0 by 2020													
No.	Project	Transmission Line				Substation							
		Rated Voltage	Length	Unit Cost	Cost	330 kV Feeder	132 kV Feeder	33 kV Switchgear	11kV Switchgear	150 MVA, 330/132kV Transformer	60 MVA, 132/33 kV Transformer	30 MVA, 132/11 kV Transformer	Cost
		(kV)	(km)	(Million US\$/km)	(Million US\$)								(Million US\$)
Overhead Lines													
Subtotal I					0.0								
Substations													
1	Suleja					0	1	0	1	0	0	1	2.7
2	Benin					0	3	3	0	0	3	0	9.3
3	Benin North					0	1	1	0	0	1	0	3.1
4	Kano					0	1	1	0	0	1	0	3.1
5	Funtua					0	1	1	0	0	1	0	3.1
6	Funtua					0	1	0	1	0	0	1	2.7
7	Ojo					0	1	1	0	0	1	0	3.1
8	Omuaran					0	1	1	0	0	1	0	3.1
Subtotal II					30.2								
Grand Total					30.2								

Source: JICA Study Team

Table 7-10.6 Upgrading requirements of 330/132 kV, 132/33 kV and 132/11 kV transformers loaded above 85% under N-0 by 2020

Cost Estimation of Upgrading of Transformers loded about 85% under N-0 by 2020													
No.	Project	Transmission Line				Substation							
		Rated Voltage	Length	Unit Cost	Cost	330 kV Feeder	132 kV Feeder	33 kV Switchgear	11kV Switchgear	150 MVA, 330/132kV Transformer	60 MVA, 132/33 kV Transformer	30 MVA, 132/11 kV Transformer	Cost
		(kV)	(km)	(Million US\$/km)	(Million US\$)								(Million US\$)
Subtotal I					0.0								
Overhead Lines													
Substations													
1	Kano					1	1	0	0	1	0	0	5.0
2	Benin North					1	1	0	0	1	0	0	5.0
3	Odogunyan					0	1	1	0	0	1	0	3.1
4	Ganmo					0	1	1	0	0	1	0	3.1
5	Ejigbo					0	1	1	0	0	1	0	3.1
6	Ojo					0	1	1	0	0	1	0	3.1
7	Alimosho					0	1	1	0	0	1	0	3.1
8	Ughelli					0	1	1	0	0	1	0	3.1
9	Paras					0	1	1	0	0	1	0	3.1
10	Shagamu					0	1	1	0	0	1	0	3.1
11	Afam 1-2-3					0	1	0	1	0	0	1	2.7
12	Iwo					0	1	1	0	0	1	0	3.1
13	Shiroro					0	1	1	0	0	1	0	3.1
Subtotal II					43.7								
Grand Total					43.7								

Source: JICA Study Team

Table 7-10.7 New reactors and capacitors

Cost Estimation of New Reactors and Capacitors required by 2020													
No.	Project	Transmission Line				Substation							
		Rated Voltage	Length	Unit Cost	Cost	330 kV Feeder	132 kV Feeder	33 kV Switchgear	11kV Switchgear	132 kV Capacitor	330 kV Reactor	32 kV Reactor	Cost
		(kV)	(km)	(Million US\$/km)	(Million US\$)								(Million US\$)
Subtotal I					0.0								
Overhead Lines													
Substations													
1	Maiduguri					1	0	0	0	0	1	0	2.7
2	Ondo2					0	1	0	0	1	0	0	1.9
3	Irrua					0	1	0	0	1	0	0	1.9
4	Gusau					0	1	0	0	1	0	0	1.9
Subtotal II					8.4								
Grand Total					8.4								

Source: JICA Study Team

Table 7-10.8 New transmission lines required by 2020

Cost Estimation of New 132 kV Transmission Lines required by 2020													
No.	Project	Transmission Line				Substation							
		Rated Voltage	Length	Unit Cost	Cost	330 kV Feeder	132 kV Feeder	33 kV Switchgear	150 MVA, 330/132kV Transformer	60 MVA, 132/33 kV Transformer	Cost		
		(kV)	(km)	(Million US\$/km)	(Million US\$)						(Million US\$)		
Overhead Lines													
1	Kaduna - Kano	330	230	0.45	103.5								
2	Akangba - Ijora	330	14	0.45	6.3								
3	Ijora - Alagbon	330	8	0.45	3.6								
4	Arigbso - New Agbara	330	40	0.45	18.0								
5	Ugwaji - Abakaliki	330	85	0.45	38.3								
6	Osogbo - Arigbajo	330	183	0.45	82.4								
7	Ayede - Idaban North	132	15	0.26	3.9								
8	New Agbara - Agbara	132	18	0.26	4.7								
9	Ogijo - Redeem	132	14	0.26	3.6								
10	Birmin Kebbi - Dosso	132	128	0.26	33.3								
Subtotal I					297.5								
New Substations / Extension of Substations													
1	Kaduna					4	2	1	2	2			16.1
2	Kano					2	1	1	1	1			8.4
3	Akangba					4	2	1	2	2			16.1
4	Ijora					4	2	1	2	2			16.1
5	Arigbajo					12	2	1	2	2			31.3
6	Agbara					0	2	1	0	1			4.7
7	New Agbara					4	2	1	2	2			16.1
8	Ugwaji					2	0	0	0	0			3.8
9	Abakaliki					2	0	0	0	0			3.8
10	Osogbo					0	2	0	0	0			3.2
11	Ayede					0	2	0	0	0			3.2
12	Ibadan North					0	2	0	0	0			3.2
13	Ogijo					0	2	0	0	0			3.2
14	Redeem					0	4	1	0	2			8.7
15	Dosso					0	2	0	0	0			3.2
16	Ibom IPP					0	2	0	0	0			3.2
17	Ikot Abasi					0	2	0	0	0			3.2
Subtotal II					147.5								
Grand Total					445.0								

Source: JICA Study Team

Note: The 330 kV lines which are part of the North-East Ring and North-West Ring, are considered in the cost estimation for 2025 because implementation by 2020 is not possible.

7-10-2-2 Summary of Additional Investments by 2020

Table 7-10.9 shows a summary of all additional investments in transmission lines and substations by 2020. The 330 kV North-East Ring and the 330-kV line Kainji - Birnin-Kebbi are also necessary to supply the forecast load of over 9 GW. However, considering the necessary implementation time, these lines are more likely to be available between 2020 and 2025. Accordingly, these costs are included in the 2025 investment costs.

Table 7-10.9 Summary of additional investments by 2020

Total Cost required by 2020			
Transmission System Expansions	Transmission Line	Substation (Million US\$)	Total Cost (Million US\$)
Reinforcements of 132 kV lines overloaded under N-0	5.1	3.2	8.3
Reinforcements of 132 kV lines overloaded under N-1	86.1	17.6	103.7
Upgrading requirements of 330/132 kV 3-winding transformers overloaded under N-0	0.0	25.0	25.0
Upgrading requirements of 132/33 kV and 132/11 kV transformers overloaded under N-0	0.0	30.2	30.2
Upgrading requirements of 330/132 kV, 132/33 kV and 132/11 kV transformers overloaded loaded over 85% under N-0	0	43.7	43.7
New Reactor and Capacitors	0	8.4	8.4
New Transmission Lines by 2020	297.5	147.5	445.0
Total Additional Investment Cost by 2020			664.3

Source: JICA Study Team

7-10-3 Transmission Reinforcements Required by 2025

To allow power transmission of approximately 20 GW by 2025, it will be necessary to build numerous new 330 and 132 kV transmission lines, to increase the transmission capacity of existing 132 kV transmission lines by reconductoring existing lines and installing additional 330/132 kV and 132/33(11) kV transformers.

7-10-3-1 Cost Estimation of Each Project

The cost estimate for additional 132 kV lines, 330/132 kV transformers and 132/33 (11) kV transformers is shown in Table 7-10.10 to Table 7-10.19.

Table 7-10.10 Additional Lines by 2025 - North-West Ring

Cost Estimation of Additional Transmission Lines required by 2025 (330 kV North West Ring)											
No.	Project	Transmission Line				Substation					Cost (Million US\$)
		Rated Voltage	Length	Unit Cost	Cost	330 kV Feeder	132 kV Feeder	33 kV Switchgear	150 MVA, 330/132kV Transformer	60 MVA, 132/33 kV Transformer	
		(kV)	(km)	(Million US\$/km)	(Million US\$)						
Overhead Lines											
1	Kainji - Birnin Kebbi 330 kV DC Line	330	310	0.45	139.5						
2	Birnin Kebbi - Sokoto 330 kV DC Line	330	130	0.45	58.5						
3	Sokoto - Talata Mafara 330 kV DC Line	330	125	0.45	56.3						
4	Talata Mafara - Gusau 330 kV DC Line	330	85	0.45	38.3						
5	Gusau - Funtua 330 kV DC Line	330	70	0.45	31.5						
6	Funtua - Zaria 330 kV DC Line	330	70	0.45	31.5						
Subtotal I					355.5						
Substations											
1	Kainji					2	0	0	0	0	3.8
2	Birnin Kebbi					7	1	1	1	1	17.9
3	Sokoto					7	9	1	2	1	32.2
4	Talata Mafara					7	9	1	2	1	32.2
5	Gusau					7	9	1	2	1	32.2
6	Funtua					7	9	1	2	1	32.2
7	Zaria					4	2	1	2	1	15.3
Subtotal II											165.8
Grand Total						521.3					

Source: JICA Study Team

Table 7-10.11 Additional Lines by 2025 - North-East Ring

Cost Estimation of Additional Transmission Lines required by 2025 (330 kV North East Ring)											
No.	Project	Transmission Line				Substation					
		Rated Voltage	Length	Unit Cost	Cost	330 kV Feeder	132 kV Feeder	33 kV Switchgear	150 MVA, 330/132kV Transformer	60 MVA, 132/33 kV Transformer	Cost
		(kV)	(km)	(Million US\$/km)	(Million US\$)						(Million US\$)
Overhead Lines											
1	Jos - Gombe 330 kV DC Line	330	270	0.45	121.5						
2	Gombe - Damaturu 330 kV DC Line	330	180	0.45	81.0						
3	Damaturu - Maiduguri 330 kV DC Line	330	260	0.45	117.0						
4	Gombe - Yola 330 kV DC Line	330	240	0.45	108.0						
5	Yola - Jalingo 330 kV DC Line	330	160	0.45	72.0						
Subtotal I					499.5						
Substations											
1	Jos					2	0	0	0	0	3.8
2	Gombe					9	7	1	2	2	33.6
3	Damaturu					7	7	1	2	2	29.8
4	Maiduguri					5	5	1	2	2	22.8
5	Yola					7	7	1	2	2	29.8
6	Jalingo					7	9	1	2	1	32.2
Subtotal II											152.0
Grand Total						651.5					

Source: JICA Study Team

Table 7-10.12 Additional Lines by 2025 - Mambilla Network Connection

Cost Estimation of Additional Transmission Lines required by 2025 (330 kV Mambilla Network Con-nections)											
No.	Project	Transmission Line				Substation					
		Rated Voltage	Length	Unit Cost	Cost	330 kV Feeder	132 kV Feeder	33 kV Switchgear	150 MVA, 330/132kV Transformer	60 MVA, 132/33 kV Transformer	Cost
		(kV)	(km)	(Million US\$/km)	(Million US\$)						(Million US\$)
Overhead Lines											
1	Mambilla - Wukari 330 kV DC Line	330	159	0.45	71.6						
2	Mambilla - Jalingo	330	95	0.45	42.8						
3	Wukari - Makurdi	330	159	0.45	71.6						
4	Wukari - Lafia	330	95	0.45	42.8						
Subtotal I					228.6						
Substations											
1	Mambilla					2	0	0	0	0	3.8
2	Wukari					5	5	0	2	2	22.1
3	Makurdi					2	0	0	0	0	3.8
4	Lafia					2	0	0	0	0	3.8
5	Jalingo					2	0	0	0	0	3.8
Subtotal II											37.3
Grand Total						265.9					

Source: JICA Study Team

Table 7-10.13 Other Additional Lines by 2025 (1)

Cost Estimation of Transmission Lines required by 2025 (Others 1)											
No.	Project	Transmission Line				Substation					
		Rated Voltage	Length	Unit Cost	Cost	330 kV Feeder	132 kV Feeder	33 kV Switchgear	150 MVA, 330/132kV Transformer	60 MVA, 132/33 kV Transformer	Cost
		(kV)	(km)	(Million US\$/km)	(Million US\$)						(Million US\$)
Overhead Lines											
1	Arigbajo - Ayede Loop-in at Ayede	330	1	0.22	0.2						
2	Katsina - Daura	330	40	0.45	18.0						
3	Daura - Kazaure	330	25	0.45	11.3						
4	Shiroro - Kaduna	330	96	0.45	43.2						
5	Gwangwalada - Shiroro	132	145	0.26	37.7						
6	Benin North - Omotosho	330	110	0.45	49.5						
7	Zungeru - Kainji	330	200	0.45	90.0						
8	Zungeru - Shiroro	330	25	0.45	11.3						
Subtotal I					261.1						
Substations											
1	Ayede					2	0	0	0	0	3.8
2	Katsina					2	0	0	0	0	3.8
3	Daura					4	0	0	0	0	7.6
4	Kazaure					2	0	0	0	0	3.8
5	Shiroro					6	0	0	0	0	11.4
6	Kaduna					2	0	0	0	0	3.8
7	Gwangwalada					2	0	0	0	0	3.8
8	Benin North					2	0	0	0	0	3.8
9	Omotosho					2	0	0	0	0	3.8
10	Zungeru					4	0	0	0	0	7.6
11	Kainji					2	0	0	0	0	3.8
Subtotal II											57.0
Grand Total						318.1					

Source: JICA Study Team

Table 7-10.14 Other Additional Lines by 2025 (2)

Cost Estimation of Transmission Lines required by 2025 (Others 2)											
No.	Project	Transmission Line				Substation					
		Rated Voltage	Length	Unit Cost	Cost	330 kV Feeder	132 kV Feeder	33 kV Switchgear	150 MVA, 330/132kV Transformer	60 MVA, 132/33 kV Transformer	Cost
		(kV)	(km)	(Million US\$/km)	(Million US\$)						(Million US\$)
Overhead Lines											
1	Shiroro - Tegina	132	65	0.26	16.9						
2	Tegina - Kontagora	132	90	0.26	23.4						
3	Kontagora - Yelwa-Yauri	132	88	0.26	22.9						
4	Ganmo - Ilorin	132	10.5	0.26	2.7						
5	Obajana - Egbe	132	97	0.26	25.2						
6	Omotosho - Ondo	132	98	0.26	25.5						
7	Benin - Irrua	132	88	0.26	22.9						
8	Irrua - Ukpilla	132	43	0.26	11.2						
9	Ukpilla - Okene	132	33	0.26	8.6						
10	Shamagu - Ijebu Ode	132	41	0.26	10.7						
11	Dakata - Gagarawa	132	89	0.26	23.1						
12	Gagarawa - Hadejia	132	60	0.26	15.6						
13	Dakata - Kumbotso	132	30	0.26	7.8						
14	Obajana - Okene	132	97	0.26	25.2						
15	Kainji - Iseyin	132	200	0.26	52.0						
Subtotal I					293.7						
Substations											
1	Shiroro					0	2	0	0	0	3.2
2	Tegina					0	2	0	0	0	3.2
3	Kontagora					0	2	0	0	0	3.2
4	Yelwa-Yauri					0	2	0	0	0	3.2
5	Ganmo					0	2	0	0	0	3.2
6	Ilorin					0	2	0	0	0	3.2
7	Obajana					0	2	0	0	0	3.2
8	Egbe					0	2	0	0	0	3.2
9	Omotosho					0	2	0	0	0	3.2
10	Ondo					0	2	0	0	0	3.2
11	Benin					0	2	0	0	0	3.2
12	Ukpilla					0	2	0	0	0	3.2
13	Shamagu					0	2	0	0	0	3.2
14	Ijebu Ode					0	2	0	0	0	3.2
15	Dakata					0	2	0	0	0	3.2
16	Gagarawa					0	2	0	0	0	3.2
17	Hadejia					0	2	0	0	0	3.2
18	Dakata					0	2	0	0	0	3.2
19	Kumbotso					0	2	0	0	0	3.2
20	Birmin Kebbi					0	2	0	0	0	3.2
21	Dosso					0	2	0	0	0	3.2
Subtotal II						0	2	0	0	0	67.2
Grand Total						360.9					

Source: JICA Study Team

Table 7-10.15 First transmission lines of the Supergrid by 2025

Cost Estimation of Transmission Lines for Supergrid required by 2025											
No.	Project	Transmission Line				Substation					
		Rated Voltage	Length	Unit Cost	Cost	330 kV Feeder	132 kV Feeder	33 kV Switchgear	150 MVA, 330/132kV Transformer	60 MVA, 132/33 kV Transformer	Cost
		(kV)	(km)	(Million US\$/km)	(Million US\$)						(Million US\$)
Overhead Lines											
1	Ikot-Ekpene - Makurdi	330	320	0.45	144.0						
2	Makurdi - Gwangwalada	330	180	0.45	81.0						
3	Ajaokuta - Gwangwalada	330	150	0.45	67.5						
4	Osogbo - Gwangwalada	330	250	0.45	112.5						
5	Gwangwalada - Funtua	330	250	0.45	112.5						
Subtotal I					517.5						
Substations											
1	Ikot-Ekpene					2	2	0	2	0	10.0
2	Makurdi					2	2	0	2	0	10.0
3	Ajaokuta					2	2	0	2	0	10.0
4	Gwangwalada					8	2	0	2	0	21.4
5	Osogbo					2	2	0	2	0	10.0
6	Funtua					2	2	0	2	0	10.0
Subtotal II						2	2	0	2	0	71.4
Grand Total						588.9					

Source: JICA Study Team

Table 7-10.16 Reconductoring of 132 kV lines by 2025

Cost Estimation of Reconductoring of 132 kV Transmission Lines required by 2025											
No.	Project	Transmission Line				Substation					
		Rated Voltage	Length	Unit Cost	Cost	330 kV Feeder	132 kV Feeder	33 kV Switchgear	150 MVA, 330/132kV Transformer	60 MVA, 132/33 kV Transformer	Cost
		(kV)	(km)	(Million US\$/km)	(Million US\$)						
Overhead Lines											
1	Egbin - Ikorodu	132	20	0.08	1.6						
2	Ogijo - Shagamu	132	16	0.08	1.3						
3	Ayede - Idaban North	132	12	0.04	0.5						
4	Ayede - Jericho	132	6	0.08	0.5						
5	Alaoji - Aba	132	10	0.08	0.8						
6	Eket - Ibom IPP	132	45	0.08	3.6						
7	PHCT Main - PHCT Town	132	6	0.04	0.2						
Subtotal I					8.5						
Substations											
Subtotal II											0.0
Grand Total											8.5

Source: JICA Study Team

Table 7-10.17 Upgrading requirements of 330/132kV transformers

Cost Estimation of Upgrading of 330/132 kV 3-winding Transformers required by 2025											
No.	Project	Transmission Line				Substation					
		Rated Voltage	Length	Unit Cost	Cost	330 kV Feeder	132 kV Feeder	33 kV Switchgear	150 MVA, 330/132kV Transformer	60 MVA, 132/33 kV Transformer	Cost
		(kV)	(km)	(Million US\$/km)	(Million US\$)						
Overhead Lines											
Subtotal I											0.0
Substations											
1	Adiagbo					2	2	0	2	0	10.0
2	Aja					2	2	0	2	0	10.0
3	Ajaokuta					2	2	0	2	0	10.0
4	Akangba					2	2	0	2	0	10.0
5	Akoka					2	2	0	2	0	10.0
6	Akure					2	2	0	2	0	10.0
7	Apapa					2	2	0	2	0	10.0
8	Ayede					2	2	0	2	0	10.0
9	Delta					2	2	0	2	0	10.0
10	Ganmo					2	2	0	2	0	10.0
11	Ihala					2	2	0	2	0	10.0
12	Ikeja West					2	2	0	2	0	10.0
13	Isolo					2	2	0	2	0	10.0
14	Jericho					2	2	0	2	0	10.0
15	Kano					2	2	0	2	0	10.0
16	Kumbotoso					2	2	0	2	0	10.0
17	Nnewi					2	2	0	2	0	10.0
18	Omotosho					2	2	0	2	0	10.0
19	Onitsha					2	2	0	2	0	10.0
20	Osogbo					2	2	0	2	0	10.0
21	Oweri					2	2	0	2	0	10.0
22	West Main					2	2	0	2	0	10.0
Subtotal II											210.0
Grand Total											210.0

Source: JICA Study Team

Table 7-10.18 Upgrading requirements of 132/33(11) kV transformers

Cost Estimation of Upgrading of 132/33, 132/11 kV Transformers required by 2025													
No.	Project	Transmission Line				Substation							
		Rated Voltage	Length	Unit Cost	Cost	330 kV Feeder	132 kV Feeder	33 kV Switchgear	11kV Switchgear	150 MVA, 330/132kV Transformer	60 MVA, 132/33 kV Transformer	30 MVA, 132/11 kV Transformer	Cost
		(kV)	(km)	(Million US\$/km)	(Million US\$)								(Million US\$)
Subtotal I		0.0											
Overhead Lines													
Substations													
1	Aba					0	2	2	0	0	2	0	6.2
2	Abakaliki					0	2	2	0	0	2	0	6.2
3	Afam 1-2-3					0	2	0	2	0	0	2	5.4
4	Ahoada					0	2	2	0	0	2	0	6.2
5	Ajaokuta					0	2	2	0	0	2	0	6.2
6	Akangba					0	2	2	0	0	2	0	6.2
7	Akoka					0	2	2	0	0	2	0	6.2
8	Akure					0	2	2	0	0	2	0	6.2
9	Alagbon					0	2	2	0	0	2	0	6.2
10	Alimosho					0	2	2	0	0	2	0	6.2
11	Amukpe					0	2	2	0	0	2	0	6.2
12	Arigbajo					0	2	2	0	0	2	0	6.2
13	Ayede					0	2	2	0	0	2	0	6.2
14	Benin					0	2	2	0	0	2	0	6.2
15	Dan Agundi					0	2	2	0	0	2	0	6.2
16	Egbin					0	2	2	0	0	2	0	6.2
17	Ejigbo					0	2	2	0	0	2	0	6.2
18	Eket					0	2	2	0	0	2	0	6.2
19	Eielenwo					0	2	2	0	0	2	0	6.2
20	Ganmo					0	2	2	0	0	2	0	6.2
21	Gashuwa					0	2	2	0	0	2	0	6.2
22	Gusau					0	2	2	0	0	2	0	6.2
23	Idaban North					0	2	2	0	0	2	0	6.2
24	Ijebu Ode					0	2	2	0	0	2	0	6.2
25	Ijora					0	2	2	0	0	2	0	6.2
26	Ikordu					0	2	2	0	0	2	0	6.2
27	Ikot Abasi					0	2	2	0	0	2	0	6.2
28	Ilesha					0	2	2	0	0	2	0	6.2
29	Illupeju					0	2	0	2	0	0	2	5.4
30	Irrua					0	2	2	0	0	2	0	6.2
31	Iseyin					0	2	2	0	0	2	0	6.2
32	Isolo					0	2	2	0	0	2	0	6.2
33	Itire					0	2	0	2	0	0	2	5.4
34	Iwo					0	2	2	0	0	2	0	6.2
35	Jalingo					0	2	2	0	0	2	0	6.2
36	Jos					0	2	2	0	0	2	0	6.2
37	Kaduna Town					0	2	2	0	0	2	0	6.2
38	Kafanchan					0	2	2	0	0	2	0	6.2
39	Kano					0	2	2	0	0	2	0	6.2
40	Katsina					0	2	2	0	0	2	0	6.2
41	Kazaire					0	2	2	0	0	2	0	6.2
42	Makeri					0	2	2	0	0	2	0	6.2
43	New Haven					0	2	2	0	0	2	0	6.2
44	Nkalagu					0	2	2	0	0	2	0	6.2
45	Odogunyan					0	2	2	0	0	2	0	6.2
46	Ogba					0	2	0	2	0	0	2	5.4
47	Ojo					0	2	2	0	0	2	0	6.2
48	Ondo2					0	2	2	0	0	2	0	6.2
49	Onitsha					0	2	2	0	0	2	0	6.2
50	Osogbo					0	2	2	0	0	2	0	6.2
51	Otta					0	2	2	0	0	2	0	6.2
52	Oweri					0	2	2	0	0	2	0	6.2
53	Oworosoki					0	2	2	0	0	2	0	6.2
54	Paras					0	2	2	0	0	2	0	6.2
55	PHCT Town					0	2	0	2	0	0	2	5.4
56	Rumusol					0	2	2	0	0	2	0	6.2
57	Savannah					0	2	2	0	0	2	0	6.2
58	Shagamu					0	2	2	0	0	2	0	6.2
59	Shagamu Cement					0	2	0	2	0	0	2	5.4
60	Shiroro					0	2	2	0	0	2	0	6.2
61	Suleja					0	2	2	0	0	2	0	6.2
62	Tegina					0	2	2	0	0	2	0	6.2
63	Ughelli					0	2	2	0	0	2	0	6.2
64	Umuahia					0	2	2	0	0	2	0	6.2
65	Uyo					0	2	2	0	0	2	0	6.2
Subtotal II		398.2											
Grand Total		398.2											

Source: JICA Study Team

Table 7-10.19 New reactors and capacitors by 2025

Cost Estimation of New Reactors and Capacitors required by 2025														
No.	Project	Transmission Line				Substation								
		Rated Voltage (kV)	Length (km)	Unit Cost (Million US\$/km)	Cost (Million US\$)	330 kV Feeder	132 kV Feeder	33 kV Switchgear	11 kV Switchgear	132 kV Capacitor	132 kV Reactor	33 kV Capacitor	33 kV Reactor	Cost (Million US\$)
Overhead Lines														
Subtotal I				0.0										
Substations														
1	Iseyin					0	0	0	0	0	0	2	0	0.50
2	Irrua					0	0	0	0	0	0	1	0	0.25
3	Keffi					0	1	0	0	1	0	0	0	1.90
4	Omuaran					0	2	0	0	2	0	0	0	3.80
5	Hadejia					0	2	0	0	2	0	0	0	3.80
6	Apo					0	2	0	0	2	0	0	0	3.80
7	Sulejia					0	2	0	0	2	0	0	0	3.80
8	Uyo					0	4	0	0	4	0	0	0	7.60
9	Ondo					0	1	0	0	1	0	0	0	1.90
Subtotal II				27.35										
Grand Total				27.35										

Source: JICA Study Team

7-10-3-2 Summary of Additional Investments between 2021 and 2025

Table 7-10.20 shows a summary of all additional investments in transmission lines and substations between 2021 and 2025.

Table 7-10.20 Summary of additional investments in transmission lines and substations between 2021 and 2025

Transmission System Expansions	Transmission Line (Million US\$)	Substation (Million US\$)	Total Cost (Million US\$)
Project 1: 330 kV North West Ring by 2025	355.5	165.8	521.3
Project 2: 330 kV North East Ring by 2025	499.5	152.0	651.5
Project 3: 330 kV Mambilla Network Connections by 2025	228.6	37.3	265.9
Additional Transmission Lines by 2025 - Part 1	261.1	57.0	318.1
Additional Transmission Lines by 2025 - Part 2	293.7	67.2	360.9
First Transmission Lines of the Supergrid by 2025	517.5	71.4	588.9
Reconductoring of 132 kV Lines	8.5	0.0	8.5
Additional 330/132 kV Transformers by 2025	0.0	210.0	210.0
Additional 132/33 and 132/11 kV Transformers	0.0	398.2	398.2
New Reactive Power Compensation	0.0	27.4	27.4
Costs for converting 330 kV DC lines to quad conductors	10.0	0.0	10.0
Total Additional Investment Cost by 2025			3,360.7

Source: JICA Study Team

7-10-4 Transmission Reinforcements Required by 2030

A further extension of the 330 kV Supergrid will be required by 2030. Furthermore, there will be a need to install capacitor banks at various substations to maintain voltages within permissible limits.

7-10-4-1 Cost Estimation of Each Project

The cost estimate for the additional transmission lines, transformers and capacitor banks is shown in Table 7-10.21 and 7-10.22.

Table 7-10.21 Additional investments in 330 kV Supergrid transmission lines and substations by 2030

Cost Estimation of Additional 330 kV Supergrid Transmission Lines and Substations required by 2030											
No.	Project	Transmission Line				Substation					
		Rated Voltage	Length	Unit Cost	Cost	330 kV Feeder	132 kV Feeder	33 kV Switchgear	150 MVA, 330/132kV Transformer	60 MVA, 132/33 kV Transformer	Cost
		(kV)	(km)	(Million US\$/km)	(Million US\$)						(Million US\$)
Overhead Lines											
1	Ikot Ekpene - Benin	330	300	0.45	135.0						
2	Benin - Egbin	330	230	0.45	103.5						
3	Egbin - New Agbara	330	50	0.45	22.5						
4	Benin - Osogbo	330	200	0.45	90.0						
5	Osogbo - Kainji	330	200	0.45	90.0						
6	Benin - Ajeokuta	330	150	0.45	67.5						
7	Gangwalada - Kainji	330	250	0.45	112.5						
8	Kainji - Bernin Kebbi	330	300	0.45	135.0						
9	New Agbara - Osogbo	330	150	0.45	67.5						
Subtotal I					823.5						
Substations											
1	Ikot Ekpene					2	0	0	0	0	3.8
2	Benin					6	5	0	0	0	19.4
3	Egbin					4	0	0	0	0	7.6
4	New Agbara					4	0	0	0	0	7.6
5	Osogbo					6	0	0	0	0	11.4
6	Ajaokuta					2	0	0	0	0	3.8
7	Gangwalada					2	0	0	0	0	3.8
8	Kainji					4	0	0	0	0	7.6
9	Bernin Kebbi					2	0	0	0	0	3.8
Subtotal II											68.8
Grand Total						892.3					

Source: JICA Study Team

Table 7-10.22 Additional Capacitor Banks to be installed by 2030

Cost Estimation of New Reactors and Capacitors required by 2030														
No.	Project	Transmission Line				Substation								
		Rated Voltage	Length	Unit Cost	Cost	330 kV Feeder	132 kV Feeder	33 kV Switchgear	11 kV Switchgear	132 kV Capacitor	132 kV Reactor	33 kV Capacitor	33 kV Reactor	Cost
		(kV)	(km)	(Million US\$/km)	(Million US\$)									(Million US\$)
Overhead Lines														
Subtotal I					0.0									
Substations														
1	Gombe					0	4	0	0	4	0	0	0	7.6
2	Bernin Kebbi					0	3	0	0	6	0	0	0	6.6
3	Gashuwa					0	1	0	0	1	0	0	0	1.9
4	Apo					0	2	0	0	2	0	0	0	3.8
5	Keffi					0	1	0	0	1	0	0	0	1.9
6	Uba					0	2	0	0	2	0	0	0	3.8
Subtotal II													25.6	
Grand Total						25.6								

Source: JICA Study Team

7-10-5 Transmission Reinforcements Required by 2035

Table 7-10.23 Additional investments in transmission lines and substations by 2035

Cost Estimation of New Transmission Line required by 2035															
No.	Project	Rated Voltage	Length	Transmission Line				Substation							
				Alternative 1		Alternative 2		Cost of Alternative 1	Cost of Alternative 2	330 kV Feeder	132 kV Feeder	33 kV Switchgear	150 MVA, 330/132kV Transformer	60 MVA, 132/33 kV Transformer	Cost
				Reinforce ment	Unit Cost (Million US\$/km)	Reinforce ment	Unit Cost (Million US\$/km)	(Million US\$)	(Million US\$)						(Million US\$)
Overhead Lines															
1	Wukari - Lafia	330	95	DC	0.45	DC	0.45	42.8	42.8						
2	Zuma - Lokoja	330	25	RE	0.15	DC	0.45	3.8	11.3						
3	Aja - Lekki	330	7	RE	0.15	DC	0.45	1.1	3.2						
4	Benin North - Akure	330	130	RE	0.08	DC	0.45	10.4	58.5						
5	Kwaya Kusar - Biu	132	42	SC	0.17	DC	0.26	7.1	10.9						
6	Biu - Damboa	132	140	SC	0.17	DC	0.26	23.8	36.4						
7	Damboaa - Maiduguri	132	64	SC	0.17	DC	0.26	10.9	16.6						
Subtotal I								99.8	179.6						
Substations															
1	Wukari							2	0	0	0	0	3.8		
2	Lafia							2	0	0	0	0	3.8		
3	Zuma							0	0	0	0	0	0.0		
4	Lokoja							0	0	0	0	0	0.0		
5	Aja							0	0	0	0	0	0.0		
6	Lekki							0	0	0	0	0	0.0		
7	Benin North							0	0	0	0	0	0.0		
8	Akure							0	0	0	0	0	0.0		
9	Kwaya Kusar							0	1	0	0	0	1.6		
10	Biu							0	2	0	0	0	3.2		
11	Damboaa							0	2	0	0	0	3.2		
12	Maiduguri							0	1	0	0	0	1.6		
Subtotal II													17.2		
Grand Total - Alternative 1						117.0									

Source: JICA Study Team

Table 7-10.24 Additional Capacitor Banks to be installed by 2035

Cost Estimation of New Reactors and Capacitors required by 2035															
No.	Project	Transmission Line				Substation							Cost (Million US\$)		
		Rated Voltage (kV)	Length (km)	Unit Cost (Million US\$/km)	Cost (Million US\$)	330 kV Feeder	132 kV Feeder	33 kV Switchgear	11 kV Switchgear	330 kV Capacitor	132 kV Capacitor	132 kV Reactor		33 kV Capacitor	33 kV Reactor
Overhead Lines															
Subtotal I													0.0		
Substations															
1	Gombe					3	0	0	0	1	3	0	0	0	7.6
2	Bernin Kebbi					7	0	0	0	1	7	0	0	0	16.4
3	Ikeja West					0	12	0	0	1	12	0	0	0	23.8
Subtotal II													47.8		
Grand Total													47.8		

Source: JICA Study Team

7-10-6 Transmission Reinforcements Required by 2040

Table 7-10.25 Additional investments in transmission lines and substations by 2035

Cost Estimation of New Transmission Lines required by 2040															
No.	Project	Rated Voltage (kV)	Length (km)	Transmission Line			Cost of Alternative 1 (Million US\$)	Cost of Alternative 2 (Million US\$)	Substation					Cost (Million US\$)	
				Alternative 1 Reinforcement	Alternative 2 Unit Cost (Million US\$/km)	Unit Cost (Million US\$/km)			330 kV Feeder	132 kV Feeder	33 kV Switchgear	150 MVA, 330/132kV Transformer	60 MVA, 132/33 kV Transformer		
Overhead Lines															
1	Aladja - Delta IV	330	32	SC	0.22	DC	0.45	7.0	14.4						
2	Osogbo - Ganmo	330	50	SC	0.22	DC	0.45	11.0	22.5						
3	Yola - Little Gombe	330	100	DC	0.45	DC	0.45	45.0	45.0						
4	Little Gombi - Biu	330	80	DC	0.45	DC	0.45	36.0	36.0						
5	Biu - Daimaturu	330	130	DC	0.45	DC	0.45	58.5	58.5						
6	Daimaturu - Potiscum	330	100	DC	0.45	DC	0.45	45.0	45.0						
7	Potiscum - Azare	330	100	DC	0.45	DC	0.45	45.0	45.0						
8	Azare - Dutse	330	90	DC	0.45	DC	0.45	40.5	40.5						
9	Dutse - Jogana	330	76	DC	0.45	DC	0.45	34.2	34.2						
Subtotal I									322.2	341.1					
Substations															
1	Aladja									2	0	0	0	0	3.8
2	Osogbo									2	0	0	0	0	3.8
3	Ganmo									2	0	0	0	0	3.8
4	Little Gombi									4	0	0	0	0	7.6
5	Biu									4	0	0	0	0	7.6
6	Daimaturu									4	0	0	0	0	7.6
7	Potiscum									4	0	0	0	0	7.6
8	Azare									4	0	0	0	0	7.6
9	Dutse									4	1	0	0	0	9.2
10	Jogana									2	2	0	0	0	7.0
Subtotal II															65.6
Grand Total - Alternative 1									387.8						

Source: JICA Study Team

Table 7-10.26 Additional Capacitor Banks to be installed by 2040

Cost Estimation of New Reactors and Capacitors required by 2040															
No.	Project	Transmission Line				Substation							Cost (Million US\$)		
		Rated Voltage (kV)	Length (km)	Unit Cost (Million US\$/km)	Cost (Million US\$)	330 kV Feeder	132 kV Feeder	33 kV Switchgear	11 kV Switchgear	330 kV Capacitor	132 kV Capacitor	132 kV Reactor		33 kV Capacitor	33 kV Reactor
Overhead Lines															
Subtotal I													0.0		
Substations															
1	Abuja					15	0	0	0	15	0	0	0	0	43.5
2	Kano					6	0	0	0	6	0	0	0	0	17.4
3	Bernin Kebbi					4	0	0	0	4	0	0	0	0	11.6
4	Ikeja West					2	0	0	0	2	0	0	0	0	5.8
Subtotal II													78.3		
Grand Total													78.3		

Source: JICA Study Team

7-10-7 Summary of Cost Comparison for Three Voltage Levels

This Section compares the cost of a super grid based on 330 kV (presently the highest voltage) with the costs of a super grid based on 500 and 750 kV nominal voltages (respectively 550- and 800 kV-rated voltages).

- In the case of a 330-kV super grid, it is assumed that the transmission line will be Double-Circuit lines with Quad Bison conductors.

- In the case of a 500-kV super grid, it is assumed that the transmission lines will be Single-Circuit lines with Quad Bison conductors.
- In the case of a 750-kV super grid, it is assumed that the transmission lines will be Single-Circuit lines with five-bundle Bison conductors.

Regarding substations, it is assumed that for a 330-kV double busbar system with an auxiliary busbar, a bus coupler will be installed whereas for 500 and 750 kV units, one-and-half circuit-breaker schemes will be installed.

Table 7-10.27, Table 7-10.28 and Table 7-10.29 show the cost estimation for the three voltage levels.

Table 7-10.27 Cost estimation for the 330-kV super grid

Cost Estimation of 330 kV Super Grid									
No.	Project	Transmission Lines				変電所			
		Rated Voltage	Length	Cost per km	Total Cost	330 kV Line Feeder	330 kV Transformer Feeder	330 kV Shunt Reactor	Total Cost
		(kV)	(km)	(Million US\$/km)	(Million US\$)				(Million US\$)
Overhead Lines									
1	Ikot Ekpene - Benin	330	300	0.45	135	/			
2	Ikot Ekpene - Makurdi	330	300	0.45	135				
3	Benin - New Agbara	330	250	0.45	113				
4	Benin - Osogbo	330	160	0.45	72				
5	Benin - Ajaokuta	330	300	0.45	135				
6	New Agbara - Osogbo	330	160	0.45	72				
7	Osogbo - Gwagwalad	330	260	0.45	117				
8	Makurdi - Gwagwalad	330	200	0.45	90				
9	Makurdi - Ajaokuta	330	200	0.45	90				
10	Ajaokuta - Gwagwalad	330	200	0.45	90				
11	Gwagwalad - Funtua	330	250	0.45	113				
Subtotal I					1,161				
Substations									
1	Ikot Ekpene	/				9	2	2	25
2	Benin		11	2	2	29			
3	Makurdi		11	2	2	29			
4	Osogbo		11	2	2	29			
5	New Agbara		9	2	2	25			
6	Ajaokuta		11	2	2	29			
7	Gwagwalad		13	2	2	33			
8	Funtua		7	2	2	21			
Subtotal II									220
Grand Total						1,381			

Source: JICA Study Team

Table 7-10.28 Cost estimation for the 500-kV super grid

Cost Estimation of 500 kV Super Grid										
No.	Project	Transmission Lines				Substations				
		Rated Voltage	Length	Cost per km	Total Cost	500kV feeder	330kV feeder	500MVA 500/330 kV Transformer	500kV Shunt Reactor	Total Cost
		(kV)	(km)	(Million US\$/km)	(Million US\$)					(Million US\$)
Overhead Lines										
1	Ikot Ekpene - Benin	500	300	0.28	84	/				
2	Ikot Ekpene - Makurdi	500	300	0.28	84					
3	Benin - New Agbara	500	250	0.28	70					
4	Benin - Osogbo	500	160	0.28	45					
5	Benin - Ajaokuta	500	300	0.28	84					
6	New Agbara - Osogbo	500	160	0.28	45					
7	Osogbo - Gwagwalad	500	260	0.28	73					
8	Makurdi - Gwagwalad	500	200	0.28	56					
9	Makurdi - Ajaokuta	500	200	0.28	56					
10	Ajaokuta - Gwagwalad	500	200	0.28	56					
11	Gwagwalad - Funtua	500	250	0.28	70					
Subtotal I					722					
Substations										
1	Ikot Ekpene					6	2	2	2	64
2	Benin					8	2	2	2	72
3	Makurdi					7	2	2	2	68
4	Osogbo					7	2	2	2	68
5	New Agbara					6	2	2	2	64
6	Ajaokuta					7	2	2	2	68
7	Gwagwalad					8	2	2	2	72
8	Funtua					5	2	2	2	60
Subtotal II										533
Grand Total						1,256				

Source: JICA Study Team

Table 7-10.29 Cost estimation for the 750-kV super grid

Cost Estimation of 750 kV Super Grid										
No.	Project	Transmission Lines				Substations				
		Rated Voltage	Length	Cost per km	Total Cost	750kV feeder	330kV feeder	500MVA 750/330 kV Transformer	750kV Shunt Reactor	Total Cost
		(kV)	(km)	(Million US\$/km)	(Million US\$)					(Million US\$)
Overhead Lines										
1	Ikot Ekpene - Benin	750	300	0.35	105	/				
2	Ikot Ekpene - Makurdi	750	300	0.35	105					
3	Benin - New Agbara	750	250	0.35	88					
4	Benin - Osogbo	750	160	0.35	56					
5	Benin - Ajaokuta	750	300	0.35	105					
6	New Agbara - Osogbo	750	160	0.35	56					
7	Osogbo - Gwagwalad	750	260	0.35	91					
8	Makurdi - Gwagwalad	750	200	0.35	70					
9	Makurdi - Ajaokuta	750	200	0.35	70					
10	Ajaokuta - Gwagwalad	750	200	0.35	70					
11	Gwagwalad - Funtua	750	250	0.35	88					
Subtotal I					903					
Substations										
1	Ikot Ekpene					6	2	2	2	82
2	Benin					8	2	2	2	92
3	Makurdi					7	2	2	2	87
4	Osogbo					7	2	2	2	87
5	New Agbara					6	2	2	2	82
6	Ajaokuta					7	2	2	2	87
7	Gwagwalad					8	2	2	2	92
8	Funtua					5	2	2	2	77
Subtotal II										686
Grand Total						1,589				

Source: JICA Study Team

The cost comparison is summarized in Table 7-10.30.

Table 7-10.30 Summary of cost comparison

Voltage Level	Transmission Lines (Million US\$)	Substations (Million US\$)	Total (Million US\$)
330 kV	1,161	220	1,381
500 kV	722	533	1,256
750 kV	903	686	1,589

Source: JICA Study Team

A rough cost comparison indicates that the 500-kV super grid will require less investment. However, the cost difference to 330 kV is relatively small. Considering that in terms of technical performance (MVA transmission capacity, losses, impact on under/overvoltages and overloads as well as static security issues) the 330-kV system appears more advantageous, its 10% higher investment cost could be justified.

In view of the above, it is apparent that more detailed studies must confirm the conclusions of this study. It is therefore recommended to have these detailed studies carried out in due course and as soon as possible, before a final decision can be made on the selection of the voltage level (330 or 500 kV) for a future super grid.

The cost for 750 kV is far higher compared to 330 and 500 kV. The transmission capacity of a 330-kV Double-Circuit line and a 500-kV Single-Circuit line are 3,100 and 2,350 MVA respectively, compared to 4,400 MW for a 750-kV Single-Circuit line. The network calculations (Chapter 8), however, have indicated that the transmission capacity of the 330 and 500 kV supergrid systems suffices.

There is no justification for adopting and/or further considering any higher (750 kV) option for the EHV grid, particularly when the implications in cost differences are taken into account, as detailed in Section 8. The higher transmission capacity (4,400 MVA) is not required at this stage and the marginal differences in losses cannot offset the high investment cost required in the planning horizon of this Master Plan.