

**Energy Efficiency & Conservation (EEC) Materiel
Technical Cooperation to Promote
Energy Efficiency in Caribbean Countries**



Contents

- Energy Audit including Walk Through Survey -

Jamaica, February 2023

Nippon Koei Co.
PADECO Co.

1. Overview of Government Office Building (GOB) in Bridgetown
2. Current Situation on Power Consumption
3. Comparison with Other Buildings in Tropical Weather
4. Examination of Energy Savings Opportunities



1. Overview of Government Office Building (GOB) in Bridgetown

1. Overview of Government Office Building (GOB) in Bridgetown

Overview of GOB in Bridgetown, Barbados (entrance)



1. Overview of Government Office Building (GOB) in Bridgetown



1. Overview of Government Office Building (GOB) in Bridgetown



Basic Data of the Building

Number of floors	2
Floor area	966 m ²
Building use	Government
Annual power consumption	167,635 kWh
Annual power consumption per floor area	174 kWh/m ²

1. Overview of Government Office Building (GOB) in Bridgetown




Bird 'eye view of GOB




1. Overview of Government Office Building (GOB) in Bridgetown



Bird 'eye view of GOB



More than 20 outdoor units of mini split air-conditioners and couple of outdoor units of central air-conditioners are observed.



Outdoor units of roof top air-conditioners

Outdoor units of mini split air-conditioners

1. Overview of Government Office Building (GOB) in Bridgetown



Floor plan of the building (ground floor)




Floor area of ground floor = 346 m²

1. Overview of Government Office Building (GOB) in Bridgetown



Floor plan of the building (top floor)



Floor area of top floor = 620 m² → Total floor area of the building = 966 m²

2. Current Situation on Power Consumption



2. Current Situation on Power Consumption




Monthly Power Consumption Trends at GOB (actual data, Aug.2021 - Aug.2022)



2. Current Situation on Power Consumption



Annual Power Consumption Share by Each Office
(actual data, Sep.2021 - Aug.2022)




Office #8 is the largest power consumer and Office #8 and #7 share more than half of the total power consumption.

2. Current Situation on Power Consumption



Annual Power Consumption Share by Month
(actual data, Sep.2021 - Aug.2022)




Power consumption in August is the largest month through a year. However, there is no significant difference by month.

2. Current Situation on Power Consumption



Power Consumption Trends at the Building (actual data, Sep.2021 - Aug.2022)




	9	10	11	12	1	2	3	4	5	6	7	8	TOTAL	AVE	MAX	MIN
Office #2	540	1,070	943	1,082	846	840	680	596	1,055	977	911	1,068	10,608	884	1,082	540
Office #3	695	1,055	978	1,136	929	1,275	1,209	1,186	1,455	1,342	1,166	1,442	13,868	1,156	1,455	695
Office #4	987	839	620	1,060	756	1,243	1,355	1,409	1,383	1,239	1,135	1,277	13,303	1,109	1,409	620
Office #5	660	692	677	928	676	958	851	758	707	661	767	927	9,252	771	958	650
Office #6	1,854	1,402	1,186	1,233	1,091	1,236	1,169	1,215	1,335	1,384	1,453	1,310	15,868	1,322	1,854	1,091
Office #7	3,506	2,993	2,655	2,662	2,268	2,302	2,615	2,611	2,819	2,725	3,090	3,008	33,254	2,771	3,506	2,268
Office #8	4,562	4,760	4,600	4,862	3,986	3,523	4,026	3,984	4,311	4,188	4,468	4,575	51,845	4,320	4,862	3,523
Office #9	1,820	1,905	1,456	1,490	1,252	1,290	1,463	1,410	1,560	1,973	1,998	2,020	19,637	1,636	2,020	1,252
Total	14,614	14,716	13,115	14,453	11,804	12,667	13,368	13,169	14,625	14,489	14,988	15,627	167,635	13,970	15,627	11,804

2. Comparison with Other Buildings in Tropical Weather




Annual Power Consumption Data (Okinawa & Hawaii)



Summary Table of Annual Power Consumption per Floor Area



Location	Building use	Data number of buildings	Floor area (m2)	Annual power consumption (kWh)	Annual power consumption per floor area (kWh/m2)
Okinawa	Office	5	7,807 (average)	7,678,185	197
Hawaii	State gvrnt office 1	1	15,989	1,641,600	103
	State gvrnt office 2	1	5,442	618,920	114
	State gvrnt office 3	1	6,140	942,400	153
	State gvrnt office 4	1	22,146	3,184,800	144
	State gvrnt office 5	1	20,688	1,828,400	88
Barbados	GOB	1	966	167,635	174

Graph of Annual Power Consumption per Floor Area




Monthly Power Consumption


- A bit larger difference has been observed in GOB by season compared with those in Okinawa and Hawaii.




Average Temperature Bridgetown, Barbados



Average Temperature Naha (Okinawa), Japan



Average Temperature Honolulu (Hawaii), USA




3. Examination of Energy Savings Opportunities

3. Examination of Energy Savings Opportunities

- Examination of energy savings by adopting efficient air conditioning technologies and approaches
 - (i-a) Adoption of **Inverter** mini split air conditioners
 - Reduction of 50% power consumption


Ref: Results of power consumption measurement of Inverter vs Non-Inverter AC



3. Examination of Energy Savings Opportunities



(i-b) Adoption of **Variable Refrigerant Flow (VRF, Inverter always equipped)** as an alternative of roof top air conditioners (Non-Inverter)




VRF (Inverter equipped) outdoor unit

3. Examination of Energy Savings Opportunities




Ref: Measured power consumption data in 2 office rooms on Jun.12.2022 (24 hours, highest temp: 32.2 °C, lowest temp: 26.1 °C)

Measured Data of Electricity Consumption in Office 1



■ Lighting ■ AC ■ Business machine

Measured Data of Electricity Consumption in Office 2




■ Lighting ■ AC ■ Business machine

Note: All lighting equipment is LED.

3. Examination of Energy Savings Opportunities



Ref: Energy Consumption Data in Office Building, Japan



Source: Energy Conservation Center, Japan

3. Examination of Energy Savings Opportunities



(ii) Heat shielding of outdoor units


> 10 % power reduction was observed by heat shielding



Construction of heat shielding

	Room A inv [kWh]	Room B inv [kWh]	Effect of EE&C [%]
Jan.14	150	164	-9%
Jan.16	207	202	3%
Jan.20	93	86	8%
Jan.22	115	84	27%
Jan.28	146	122	16%
Jan.30	129	116	10%
Feb.3	148	141	4%
Feb.5	119	107	10%
Feb.9	152	132	13%
Feb.11	129	100	22%
Feb.13	126	103	18%
Feb.17	108	108	1%
ave.	135	122	10%

Source: "Data collection survey on energy efficiency in the D.R. final report" (Jan. 2016, JICA)




(iii) Higher temperature setting of air conditioner

➤ 10 % power reduction by setting 1 °C higher temperature

Note: 13 % of power reduction with setting 1 °C higher temperature (by Ministry of Environment)

Ref: Setting temperature of air conditioner in Okinawa



❑ Results of Examination (1) : power & cost savings

		Present situation		
Annual power consumption for cooling	kWh	83,818		
Power consumption by INV AC	kWh	27,939		
Power consumption by Non-INV AC	kWh	55,879		
Cooling loads by INV AC	kWh	139,697		
Cooling loads by Non-INV AC	kWh	139,697		
Total cooling loads	kWh	279,393		
		EE measure (i)	EE measure (i)+(ii)	EE measure (i)+(ii)+(iii)
Power consumption after EE measures	kWh	55,879	50,291	45,262
Power savings per year	kWh	27,939	33,527	38,556
Power saving ratio	%	33	40	46
Cost savings per year	\$	17,881	21,457	24,676
Annual power consumption per floor area	kWh/m ²	145	139	134

Assumption:
 • 50% of ACs are INVERTER at present
 • Efficiency of INV AC = 5 in kW/kW
 • Efficiency of Non-INV AC = 2.5 in kW/kW

Note: Unit rate of power (customer charge + demand charge + energy charge + fuel charge) = \$0.64/kWh

❑ Results of Examination (2) : Investment in INVERTER ACs

Item	Unit	Value
Total power capacity of building	kVA	85
Power factor	%	90
Total power demand of building	kW	76.5
Power demand of ACs	kW	38.3
Power demand of INV ACs	kW	12.8
Power demand of Non-INV ACs	kW	25.5
Cooling capacity of Non-INV ACs	kW	63.8


Item	Unit	Value
INV AC cost (5.27 kW in cooling capacity)	\$	1,700
Necessary number of AC	Unit	13
Total investment cost of INV AC	\$	22,100

Estimation of cooling capacity of existing Non-INV ACs

Note: AC market survey conducted in Barbados by JET in 2019


Simple payback year = 22,100 / 17,881 = 1.2 year

Graph of Annual Power Consumption per Floor Area with EE Measures



4. References

Ref: Measured Power Consumption Data of Refrigerator in GOB (Sep.12 – 16, 2022)



➔ Existing refrigerator (Non-INVERTER) can be replaced with efficient one with INVERTER

4. Reference (2): Illuminance standards for offices

Illuminance standards for offices in Japan (JIS Z 9110)

Illuminance (lux)	Place	Work
2000	office (a) ^(*) , sales room, design room, entrance hall (daytime) ^(**)	---
1500		<ul style="list-style-type: none"> ● design ● drawing ● type
1000		<ul style="list-style-type: none"> ● calculation ● keypunch
750		

(Note)
 (*) In the event that the office is used for **detailed visual work** or where daylight makes the room feel dark inside and bright outside the window, (a) should be selected.
 (**) In the entrance hall, the illuminance should be high because the interior of the hall appears dark when the eye is applying the tens of thousands of lux from outdoor natural light during the day. The entrance hall (nighttime) and (daytime) may be adjusted with staged flashing.

4. References (2): Illuminance standards for offices

Illuminance (lux)	Place	Work
750		
500	Office (b), boardroom, conference room, printing room, computer room, control room, clinic room <ul style="list-style-type: none"> • switchboards and instrument panels in electrical and machine rooms, etc. • reception (desk) 	
300	reception room, waiting room, dining room, cooking room, recreation room, guard room, entrance hall (at night), elevator hall warehouse, electrical room, auditorium, machine room, miscellaneous workroom, elevator	
200		washing area, hot water heating area, bathrooms, corridors, stairs, lavatories
150		
100	coffee room, rest room, lodging room, changing rooms, storage, entrance (porch)	
75		
50	indoor emergency staircase	
30		

Source: JET based on EEC guidebook for building, 2022 (Energy Efficiency and Conservation Center of Japan)
 Japan International Cooperation Agency | 36

EEC Promotion System

- ✓ Do you have a mechanism for continuous EEC (e.g. **EEC committee**, etc.)?
- ✓ Are **PDCA cycles** for EEC activities being implemented with **management participation**?
- ✓ Have you designated a person or leader responsible for promoting EEC?
- ✓ Have you set **EEC targets**?
- ✓ Are energy consumption statuses posted for employees to see?
- ✓ Have you established **a policy and implementation plan for EEC measures**?
- ✓ Do you conduct personnel training and EEC awareness activities?
- ✓ Do you have the **time and budget for EEC efforts**?

Source: JET based on EEC guidebook for building, 2022 (Energy Conservation Center of Japan)

Energy Management

- ✓ Do you tabulate (graphs, etc.) and **visualize energy consumption by month/year**?
- ✓ Is energy consumption **measured and recorded by type and use**, and constantly monitored?
- ✓ Do you measure **hourly power usage** and manage peak power?
- ✓ Do you analyze energy consumption taking into account outside temperatures and other factors?

Management of Energy Intensity, etc.

- ✓ Have you calculated a common **energy unit cost for the office** (e.g. \$/kWh, \$/litre, \$/m3)?
- ✓ Do you manage **intensity ("energy use/floor area", "energy cost/floor area", etc.)**?
- ✓ Do you manage energy intensity / expenses by each department?

Management Cycle -PDCA-

- ✓ Are you reviewing your EEC targets?
- ✓ Are you verifying the effectiveness of improvement measures implemented to date?
- ✓ Are you reviewing your plans for implementing future facility improvements and measures?

Source: JET based on EEC guidebook for building, 2022 (Energy Efficiency and Conservation Center of Japan)

Measurement, Recording and Maintenance

- ✓ Do you maintain equipment ledger, drawings and other documents?
- ✓ Have you **identified equipment that should be intensively managed for EEC**?
- ✓ Do you have **operation records (daily, monthly, etc.)** for major facilities?
- ✓ Have you set values to be managed and their ranges to check operating conditions?
- ✓ Do you perform daily inspection and maintenance of equipment?
- ✓ Are there management standards for major facilities (air conditioning, ventilation, lighting, production facilities, etc.)?
- ✓ Do you perform periodic calibration and inspection of measuring instruments?
- ✓ Are **filters, strainers, etc. cleaned** and replaced regularly?
- ✓ Do you conduct periodic repairs and leak inspections (water, steam, compressed air, etc.) of piping, etc.?

Source: JET based on EEC guidebook for building, 2022 (Energy Conservation Center of Japan)

Improvements of Air Conditioning Efficiency

- ✓ Are **outdoor units shaded** and watered during the summer months?
- ✓ Are **window blinds utilized** to reduce heat gain through windows?
- ✓ Are **filters cleaned** regularly?
- ✓ Are **shading films attached to window glass, and has plantings near windows** implemented?
- ✓ Is air introduced into the room at night when the outside temperature is cooler (**night purge**)?
- ✓ Can we reduce the size of the air-conditioned area (partitions, high ceiling linings, etc.)
- ✓ Are spot coolers used when the air-conditioned area is large and the number of people is small?
- ✓ Are air-conditioned areas blocking drafts?
- ✓ Are you **updating to high-efficiency air conditioners**?

Source: JET based on EEC guidebook for building, 2022 (Energy Conservation Center of Japan)

Lighting Fixture Management and EEC

- ✓ Is the illuminance standard for each room determined and controlled?
- ✓ Are window lights turned off (using daylight)?
- ✓ Are lights turned off when not needed, such as in unoccupied rooms or during lunch breaks?
- ✓ Do you adjust the lighting hours and number of exterior lights according to the hours of daylight?
- ✓ Have you cleaned the lamps and replaced old lamps?
- ✓ Are motion sensors used in restrooms, warehouses, etc.?
- ✓ Is the installation position (height and placement) of the lighting fixture appropriate for the required brightness?
- ✓ Are lighting circuits subdivided so that lights can be turned off in unoccupied areas, etc.?
- ✓ Are lights dimmed or turned off by automatic control?
- ✓ Are you updating to LED lighting?
- ✓ Have you considered task ambient lighting (all room lighting => overall + hand lighting)?

Source: JET based on EEC guidebook for building, 2022 (Energy Conservation Center of Japan)

Thank you very much for your kind attention !




Energy Efficiency & Conservation (EEC) Materiel Technical Cooperation to Promote Energy Efficiency in Caribbean Countries

Information and knowledge sharing material - Energy Management & Energy Audit -

Jamaica, February 2023

Nippon Koei Co., Ltd.
PADECO Co., Ltd.



1. Energy Management System (EnMS), ISO 50001, and its Case Study


Key Points

- ISO 50001 specifies the energy management system (EnMS) requirements for an organization. Successful implementation of an EnMS supports a culture of energy performance improvement that depends upon **commitment from all levels of the organization, especially top management**. In many instances, this involves **cultural changes** within an organization.
- EnMS includes an **energy policy, objectives, energy targets and action plans** related to its energy efficiency, energy use, and energy consumption.
- Energy performance is a concept which is related to energy efficiency, energy use and energy consumption. **Energy performance indicators (EnPIs) and energy baselines (EnBs)** are two interrelated elements to enable organizations to demonstrate energy performance improvement.
 - Energy performance indicators (EnPIs)**
The organization shall determine EnPIs that:
 - are appropriate for measuring and monitoring its energy performance;
 - enable the organization to demonstrate energy performance improvement.
 - Energy baseline (EnBs)**
The organization shall establish (an) EnB(s) using the information from the energy review(s), taking into account a suitable period of time.


Plan-Do-Check-Act (PDCA) cycle

- The EnMS described is based on the Plan-Do-Check-Act (PDCA) continual improvement framework and incorporates energy management into existing organizational practices.
- In the context of energy management, the PDCA approach can be outlined as table below.

Plan	Understand the context of the organization, establish an energy policy and an energy management team , consider actions to address risks and opportunities, conduct an energy review, identify significant energy uses (SEUs) and establish energy performance indicators (EnPIs), energy baseline(s) (EnBs), objectives and energy targets, and action plans necessary to deliver results that will improve energy performance in accordance with the organization's energy policy.
Do	Implement the action plans , operational and maintenance controls, and communication, ensure competence and consider energy performance in design and procurement.
Check	Monitor, measure, analyze, evaluate, audit and conduct management review(s) of energy performance and the EnMS.
Act	Take actions to address nonconformities and continually improve energy performance and the EnMS.



Plan-Do-Check-Act (PDCA) cycle



1. Planning for Collection of Energy Data


- The organization shall ensure that **key characteristics of its operations affecting energy performance are identified, measured, monitored and analyzed** at planned intervals. The organization shall define and implement an **energy data collection plan** appropriate to its size, its complexity, its resources and its measurement and monitoring equipment.
- The plan shall specify the data necessary to monitor the key characteristics and state how and at what frequency the data shall be collected and retained.
- Data to be collected (or acquired by measurement as applicable) and retained documented information shall include:
 - the relevant variables for **SEUs**;
 - energy consumption related to **SEUs and to the organization**;
 - operational criteria related to **SEUs**;
 - static factors, if applicable;
 - data specified in action plans.
- The energy data collection plan shall be reviewed at defined intervals and updated as appropriate.

2. Scope of EnMS

The scope of ISO 50001 certification covers the manufacture of automotive undercarriage parts at the X Plant.

3. Promotion Structure

The X Plant Manager was appointed as top management to establish an EnMS based on ISO 50001, including an energy manager in accordance with the EE Law, a facility management section in the administration division, and a person in charge of promotion in each division.



EnMS Promotion Structure at X Plant

4. Energy Policy


Energy Philosophy

We aim to be the top environmental runner in the automotive industry, and we will do our utmost to build a low-carbon and nature-rich future by deepening each employee's correct understanding of global environmental issues and actively engaging in ongoing environmental conservation activities in all areas of our corporate activities.


Basic policy

- We will continuously implement energy conservation activities in our production activities.
- Collect appropriate information to achieve our goals and objectives
- We will strive to use appropriate resources to achieve our goals and objectives
- We will comply with all laws and regulations related to energy use and other agreed upon requirements.
- Set objectives and review them regularly.
- We will strive to install energy-efficient product equipment and utilize energy-efficient services
- We will develop environmentally conscious people through energy conservation activities.

5. Overall Energy Review



6. Energy Review Flow



7. Methodology for Setting Energy Baselines and Energy Performance Indicators

- The energy baseline was based on FY 2010, when operations were relatively normal.
- The energy performance indicators (EnPIs) are basic units obtained by dividing the respective energy consumption (total amount) by a more closely related variable.
- The intensity is set more precisely than that used for reporting under the EE Law, so that energy usage can be more clearly understood.

Energy Baselines and Energy Performance Indicators (EnPIs)

	Electricity	City gas	LPG	Air
Baseline	FY2010	FY2010	FY2010	FY2012
EnPIs	<ul style="list-style-type: none"> • Total amount • Intensity (Value added) 	<ul style="list-style-type: none"> • Total amount • Intensity (Production) 	<ul style="list-style-type: none"> • Total amount • Intensity (Average temperature) 	<ul style="list-style-type: none"> • Total amount • Intensity (Value added)

Note: Parameter of intensity in parentheses

9. Preparation of Energy Management System Documents

- The following management system documents were prepared as applicable to the X plant.
 - Energy Management System Manual
 - Energy Review Implementation Procedures
 - Environmental Meeting Procedures
- In addition, several forms mainly related to energy reviews were newly prepared, including an "Efficiency Improvement Feasibility Check Sheet" and an "Energy Review Survey Sheet" that lists:
 - Energy use classification of each process facility
 - Determination of equipment capacity suitability
 - Determination of renewal timing
 - EE improvement items
 - Implementation status of measures.

10. Management Review Outputs

The management review included detailed reports on the improvement of energy performance through the efforts of each division. Specific instructions were given to include total energy consumption in an energy performance indicators / targets, and "improving the energy management team's data analysis" and "improvements in implementation capabilities" were suggested.


8. Energy Objectives and Targets

- Targets were set for a single year (FY2012) and for the medium term (through FY2015).
- In setting the targets, target values were set for each energy source without CO2 conversion or crude oil conversion in order to clarify the effect of energy improvement.

Energy Objectives and Targets (Mid term and FY2012)

		Electricity	City gas	LPG	Air
Intensity	FY2015	5% improvement	5% improvement	Less than FY2012	3% improvement
	FY2012	3% improvement	3% improvement	Less than FY2012	1% improvement
Total amount	FY2015	30% reduction	5% reduction	15% reduction	3% reduction
	FY2012	10% reduction	Less than FY2010	15% reduction	1% reduction

11. Schedule for ISO 50001 – from System Establishment to Certification



12. Results of Activities

Identified specific outcomes of the ISO 50001 are as follows;

- Regrading data collected by the energy management system, the steps formulation (e.g. data analysis, EE measures planning, implementation and effectiveness verification) has been standardized. This will **enable permanent and systematic EE&C implementation**.
- Persons in charge of implementation in each division improved skills in **analyzing energy management data**.
- **Know-how on EE&C measures** has been accumulated.
- Morale / passion for EE&C increased at the plant.
- Improved energy performance.

Improved Energy Performance Results

Total effect by measures conducted in FY2012	CO2 reductions (total)	81.2 t-CO2
	Reduction cost (total)	JPY 2,844,000
Total effect by measures conducted in FY2013 (estimates)	CO2 reductions (total)	130.3 t-CO2
	Reduction cost (total)	JPY 4,801,000

2. Energy Management Best Practice at District Heating & Cooling (DHC) plant in Japan

13. Potential for Future Improvement


Future issues for the development of ENMS improvements include the following.

- Further strengthen data analytical capabilities of energy management system as well as implementation capabilities.
- Accumulation of **improvement know-how through energy use visualization**.
- Support for ISO 50001 certification for overseas subsidiaries as a global mother.

Outline of District Heating & Cooling System




Harumi Island District Heating & Cooling, DHC




Energy flow diagram of chilled and hot water supply

Energy / Environment Management Structure



- Periodical meeting (Every other month)
 - ✓ Comprehensive data examination
 - ✓ Each operational improvement
 - ✓ Feedback of the outcome



Key Points 1 for Achieving EEC

Adoption of the most efficient chiller


Space cooling demand exceeds space heating demand in the offices, etc.

In order to increase the overall system efficiency, it is crucial to adopt the equipment that produces chilled water efficiently.



The most efficient centrifugal chillers at the time of design and construction were adopted.

As for heat demand for air-conditioning in offices, etc., demand for chilled water largely exceeds that for hot water.





Key Points 2 for Achieving EEC

Adoption of Thermal Storage Systems

Heat pumps (chillers) can operate at high load factor where its efficiency is high with thermal storage system. Thus, large-scale thermal storage tank was adopted (19,060 m³).

Note: Thermal storage system has similar effects with inverter in terms of improving operational efficiency.




Key Points 3 for Achieving EEC



Adoption of large temperature difference water

To reduce the power consumption by pumps, the temperature difference of supply and return water was designed at **10 degrees**, while the standard is typically 7 degrees.



Weighted average ΔT
Daytime : 9.9°C
Nighttime : 7.5°C

Difference in temperature of supply and return water at chilled water header ΔT[°C]

Annual Results of difference in temperature of coming and going water

Key Points 4 for Achieving EEC



Adoption of heat recovery heat pumps

Heat recovery heat pumps save energy drastically by recycling waste heat from cooling operation. Most of the waste heat is recovered and utilized as heat for space heating.





Image of heat recovery heat pump (COP=8)



Data of waste heat recovery through a year


Key Points 5 for Achieving EEC



Implementation of continuous commissioning

Creation of "performance evaluation and review committee" including people of academic standing, designer and constructor. It lasted 3 years after completion of construction.

- Understanding situation of operation through close and careful measurements and analyses.
- Evaluation of performance and identification of issues.
- Implementation of measures toward better performance and review of the effects thereof.




Achieved Top Energy Efficiency Rating




- ✓ Among high-efficiency DHC systems, Harumi DHC achieved a **top energy efficiency** rating in Japan.

COP on primary energy base



COP on the primary energy basis for DHC in Japan


3. Energy Audits, ISO 50002, and its Case Study



Key Points of ISO 50002 (Energy audits)

Energy Audit Process Flow

- ISO 50002 stipulates the energy audit process consists of the following stages.



Energy Audit Process Flow Diagram

Key Points of ISO 50002 (Energy audits)

Data Collection

Where available, the energy auditor shall collect, collate and record the appropriate energy data that support the audit objectives. This includes the following information:

- a list of energy consuming systems, processes and equipment;
- detailed characteristics of the energy uses within the defined energy audit scope, including relevant variables and how the organization believes they influence energy performance;
- historical and current energy performance data, including:
 - energy consumption, relevant variables, relevant related measurements (e.g. power factor measurements; results from a thermographic or compressed air survey);
 - operational history and past events that could have affected energy consumption in the period covered by the data collected;
- monitoring equipment, configuration and analysis information (e.g. local gauges, distributed control systems, instrumentation types);
- future plans, design, operation and maintenance documents;
- energy audits or previous studies related to energy performance;
- current energy rate schedule(s) (or tariffs) or a reference rate (or tariff) to be used for financial analysis;

Key Points of ISO 50002 (Energy audits)

Analysis of Current Energy Performance

The current energy performance provides the basis for evaluating improvements and shall include:

- a breakdown of the energy consumption by use and source;
- energy uses accounting for substantial energy consumption;
- where available and comparable, comparison with reference values of similar processes;
- a historical pattern of energy performance;
- expected improvements for energy performance.
- where appropriate, relationships between energy performance and relevant variables;
- an evaluation of the existing energy performance indicator(s) and, if necessary, proposals for (a) new energy performance indicator(s).

Identification of Improvement Opportunities

The energy auditor shall identify energy performance improvement opportunities based on analysis and the following:

- A) their own competency and expertise;
- B) evaluation of the **design and configuration options** to address the system needs;
- C) the operating **lifetime, condition, operation and level of maintenance** of the audited objects;
- D) the technology of existing energy uses in **comparison to the most efficient on the market**;
- E) **best practices, including operational controls** and behaviours;
- F) **future energy use and changes in operation**.

Evaluation of Improvement Opportunities

The energy auditor shall **evaluate the impact of each opportunity** on the current energy performance based on the following:

- A) **energy savings** over an agreed time period or expected operating lifetime; (e.g. Energy savings, improvements in specific energy consumption).
- B) **financial savings** anticipated from each improvement opportunity;
- C) **necessary investments**;
- D) agreed economic and other criteria identified in the energy audit planning;
- E) other **non-energy gains (such as productivity or maintenance)**;
- F) the **ranking of energy performance opportunities**;
- G) potential interactions between various opportunities.

Energy Audit Report Contents

The energy audit report shall include the following topics:

- A) Executive summary:**
 - i. summary of **energy use and consumption**;
 - ii. **ranking of opportunities** for improving energy performance;
 - iii. **suggested implementation** programme;
- B) Background:**
 - i. **general information** on the organization, energy auditor and energy audit methods;
 - ii. relevant **legal and other requirements** applicable to the energy audit;
 - iii. statement of confidentiality;
 - iv. context of the energy audit;
 - v. energy audit description, **defined scope and boundaries**, audited **objective(s) and timeframe**;

- C) Energy audit details**
 - i. information on **data collection**;
 - ii. **analysis** of energy performance and any energy performance indicator(s);
 - iii. **basis for calculations, estimates and assumptions** and the resulting accuracy;
 - iv. criteria for ranking opportunities for improving energy performance.
- D) Opportunities for improving energy performance**
 - i. **recommendations and the suggested implementation** programme;
 - ii. **assumptions and methods used** in calculating energy savings, and the resulting accuracy of calculated energy savings and benefits;
 - iii. **assumptions used** in calculating costs of implementation, and the resulting accuracy;
 - iv. appropriate **economic analysis**, including known financial incentives and any non-energy gains;
 - v. potential interactions with other proposed recommendations;
 - vi. **measurement and verification methods recommended for use in post-implementation assessment** of the recommended opportunities;
- E) Conclusions and recommendations.**

< Reference > Energy Audit Principles

The energy audit shall be conducted according to the following principles:

- A) the audit is consistent with the agreed energy audit scope, boundary and audit objective(s);
- B) the measurements and observations are appropriate to the energy uses and consumption;
- C) the collected energy performance data are representative of the activities, processes, equipment and systems;
- D) the used data for quantifying energy performance and identifying improvement opportunities are consistent and unique;
- E) the process of collecting, validating and analysing data is traceable;
- F) the energy audit report provides energy performance improvement opportunities based on appropriate technical and economic analysis.

Logistics Center Project (2 large warehouses + offices)



Case Study of Energy Audits (1)

Energy Dynamic Simulation

Part of Building Design Data (Project Data)

Design data (Assumptions & Project data)					
Areas	Lighting (installed)		People	Shifts	T @
	GL	FF			
	kW	kW			
Warehouse 1	13176	96336		70	3 14
Warehouse 2	13608	100224		70	3 14
Warehouse 3	17496	123552		80	3 14
Office 1_1	15	W/m ²		13	2 18
Office 1_2	15	W/m ²		13	2 18
Office 2_1	15	W/m ²		13	2 18
Office 2_2	15	W/m ²		13	2 18
Office 3_1	15	W/m ²		24	2 18
Office 3_2	15	W/m ²		24	2 18
Toilets 1	15	W/m ²		24	2 18
Toilets 2	15	W/m ²		24	2 18
Toilets 3	15	W/m ²		24	2 18
Toilets 4	15	W/m ²		24	2 18
Toilets 5	15	W/m ²		24	2 18
Toilets 6	15	W/m ²		24	2 18
Plantrooms	8	W/m ²			16

Screen of General Information of Dynamic Energy Calculation

Simulation program: Integrated Environmental Solutions Virtual Environment version: 2013 Platform Pack 2

Energy Code: ASHRAE 90.1 - 2007 Appendix G

Model data: Project file: 131_ERP_JANDA LOGISTIC PAPER BUILDING A REDUCE

Heating calculation data: Principal heating source: Electricity; Results file: 1321_34_1912_200918; Calculated: 30860586; Unit: 30860586; Heating source: 30860586; Building floor area: 455247.75; Number of conditioned rooms: 27; No. of floors: 2


Cooling calculation data: Principal cooling source: Electricity; Results file: 1321_34_1912_200918; Calculated: 30860586; Unit: 30860586

Design weather: Station: ASHRAE design weather database; Weather location: Moline, Illinois, USA; Weather file: 1912_Moline_071212_ASHC


Climate zone: ASHRAE 90.1; Response factor: 6; DB

Construction: New construction %: 100; Existing construction %: 0

Case Study of Energy Audits (1)



Facade and Roof of Warehouse




Sun Trajectory

Summary of Dynamic Energy Calculation of the Building for BREEAM Assessment

Indicator	Baseline	The Project
Overall final energy performance (electricity + fuel) (kWh/m ² /year)	215	95
Overall final energy consumption (electricity + fuel) (MWh/year)	7,856	3,474
Energy savings of electricity (kWh/m ² /year)	-	31
Energy savings of electricity (MWh/year)	-	1,132
Energy savings of heat and fuel (kWh/m ² /year)	-	89
Energy savings of heat and fuel (MWh/year)	-	3,250
Primary energy savings (KJ/m ² /year)	-	2,754
Primary energy savings (MJ/year)	-	100,697

Evaluation of Building Thermal Properties



Examined EE&C Technologies (additional study)

Examined technologies	Examination / Evaluation	Financial Analysis
Combined Heat & Power (co-generation)	Proposed	<ul style="list-style-type: none"> Investment cost Cash-flow Pay back period IRR NPV
Variable speed control units (inverters)	Proposed	
Efficient transformer	Proposed	
Renewable energy	Already included	-
Peak shaving	Not necessary (high load factor)	-
Building envelope performance	Good (see next slide)	-

Mining Plant Project



Complete view of the existing crushing plant

Case Study of Energy Audits (2)



Examined EE&C Technologies

Examined technologies	Examination / Evaluation	Financial Analysis
Efficient motors	Proposed	<ul style="list-style-type: none"> Investment cost Cash-flow Pay back period IRR NPV
PV system	Proposed	
PV system with financial incentives	Proposed	
Inverter to motors	Already included	-
Improvement of power factor of receiving ends	Analyzed high enough	-
Inverter to compressors	Recommended	-
Efficient transformers	Recommended	-
Efficient lighting	Recommended	-
Electrically-driven dump trucks for a mine	Recommended	-
Trolley dump trucks for a mine	Recommended	-

Case Study of Energy Audits (2)



Source Energy Conservation Centre of Japan




Source Energy Conservation Centre of Japan

Electrically-driven dump trucks for a mine

Electrically-driven dump trucks for a mine

Case Study of Energy Audits (2)



Structure of EMS for 17 Power Distribution Panels

Estimates for the introduction of EMS

Item	Cost (USD)
The cost of the hardware and software	XXXXX
The cost of design, installation and construction	XXXXX
The total cost of introduction of EMS	XXXXX

Case Study of Energy Audits (2)



Representative Monitoring Items and Functions with the EMS

Monitoring items and functions	Comments
Peak demand of electric power	Alarm function included. (in case of exceeding threshold value)
Demand history of electric power	Displaying the power demand history.
Power consumption history by the distribution panel	Displaying the power demand history by the equipment groups.
Analysis by the output level (e.g. in manufacturing) and energy management (targets/actual results)	Analysis by the output level and equipment groups. The following targets and actual results to be displayed in the tables and the graphs on monthly basis. a. Electric power consumption b. Primary energy consumption c. CO ₂ emissions d. Costs
Creation of the reports	Creation of the reports on daily, monthly and yearly basis regarding energy consumption.
Creation of the reports required by the government	Creation of the reports to be submitted to the government.

4. Energy Audit Best Practice at Aquarium & Amusement Park in Japan

Outline of the Aquarium & Amusement Park


- ✓ The company was Established in 1990.
- ✓ The amusement park was opened in 1993.
- ✓ Annual number of visitors; 4 to 5 million (Top 5 in Japan).
- ✓ The park is type-1 designated energy management factory under “the law concerning the Rational Use of Energy”.

◆ Three-story **aquarium** with thousands of fish which is one of the largest in Japan.
 ⇒ A lot of cold energy & heat (chilled & hot water) are necessary to maintain water temperature in water tanks constant all year around as well as space heating & cooling for visitors.

- ◆ Other attractions
 - Vertical fall amusement (**BLUE FALL**) with 107 meters high.
 - Japan's first **roller coaster** that swings out over the ocean.
 - World famous **Merry-Go-Round** with thousands of lights glittering.

Outline of the Aquarium & Amusement Park


4 WANTS in the Company



1. Cut energy cost
2. Improve the efficiency of maintenance and operation of facilities
3. Promote further energy savings and environmental measures
4. Asset-light business operation by reducing investments

Two major backgrounds in Japan

- ✓ Increasing interests in energy savings by **the law concerning the Rational Use of Energy**.
- ✓ Increasing interests in CO₂ emissions reduction.



- Several companies proposed new system.
- Amusement park company itself analyzed and examined each proposal for more than a year.
- In the process of examination, the responsible person was appointed by the company played an important role on;
 - Providing suggestion to management from technical angle.
 - Verification of various figures indicated in proposals such as consumption of electric power, city gas, water.

Adoption of high efficiency heat pumps

- The industry's first large-scale heat pumps with high efficiency.
- This heat pump won the **Minister of Economy, Trade and Industry Prize** at the Energy Conservation Awards.




Picture of high efficiency heat pumps

1. Reduction of maintenance fee for co-generation
2. High efficiency system which contributes to energy savings and CO₂ reductions
3. Simple system toward the realization of efficient operation




Stop operation of co-gen (2 units) and introduction of high efficiency air-source heat pumps instead.

- In case of air-source HPs, cooling water necessary in the existing system will not become necessary by air-source HPs.




System Comparison – renewed system -



New system is more simple.
⇒ Needs no water and less space.


Construction Cost



Composition on payment for construction cost


- 10% out of total cost are interests.
- Term of installment payment is 15 yrs.

Comparison of Life Cycle Cost



Comparison of LCC (15yrs)

Primary Energy & CO₂ Emissions Reduction



■ Operational cost reduction

- ➡ **Approx. 70 million JPY (0.5 million USD) was reduced annually.**



Construction cost was already recovered within 2 years.

■ CO₂ emissions reductions

- **Obligated amounts of reductions by MOE**
= **Approx. 600 t-CO₂/year**
- ➡ **Approx. 1,800 t-CO₂ was reduced within 2 years.**



CO₂ emissions clears the designated level by MOE.

Thank you very much for your kind attention !

The Technical Cooperation Project to Promote Energy Efficiency in Caribbean Countries

Market Study of EV

February 2023

Nippon Koei Co., Ltd.
PADECO Co., Ltd.

Today's Agenda

- ✓ **Market analysis of EVs**
- ✓ **Market analysis of storage batteries**
- ✓ **Introduction of new technologies**

1. Different Types of EVs

■ Different types of EVs

	Automobile
With battery for drive	BEV: Battery-powered vehicle HV: Hybrid vehicle PHEV: Plug-in hybrid vehicle
No battery for drive	FCV: Fuel-cell vehicle (hydrogen vehicle) Solar car Trolley bus



Ref. UZABASE

ICV: Internal Combustion Engine Vehicle

Different Types of EVs

■ Pros & Cons of EVs

ICV: Internal Combustion Engine Vehicle
 BEV: Battery-powered vehicle
 PHEV: Plug-in hybrid vehicle
 FCV: Fuel-cell vehicle (hydrogen vehicle)



	Pros	Cons
ICV 	<ul style="list-style-type: none"> Cheaper to buy Longer driving range Wider cabin space Good infrastructure (many gas stations) Short refueling time 	<ul style="list-style-type: none"> Higher CO2 emission Higher running cost
BEV 	<ul style="list-style-type: none"> No CO2 emission Cheap running cost Can be charged at home 	<ul style="list-style-type: none"> More expensive than ICV Shorter driving range Limited cabin space Limited number of charging stations Longer charging time (rapid charging takes 30 mins)

Ref. UZABASE

Different Types of EVs

■ Pros & Cons of EV

ICV: Internal Combustion Engine Vehicle
 BEV: Battery-powered vehicle
 PHEV: Plug-in hybrid vehicle
 FCV: Fuel-cell vehicle (hydrogen vehicle)


	Pros	Cons
HV/PHEV 	<ul style="list-style-type: none"> Longer driving range Lower CO2 emission Cheaper running cost than ICV Good infrastructure (many gas stations) Short refueling time PHEV can be recharged at home 	<ul style="list-style-type: none"> More expensive to buy (because there are 2 driving systems of ICV and BEV) Limited cabin space
FCV 	<ul style="list-style-type: none"> Longer driving range No CO2 emission Wider cabin space Short filling time (takes 5 mins) 	<ul style="list-style-type: none"> Limited number of hydrogen filling stations Limited car models

Ref. UZABASE, ENEOS

2. Market Analysis of EVs & Storage Batteries

Market size of EVs

The EV market is rapidly growing, and sales of EVs were 6.6 million units in the world in 2021. There were over 16.5 million EVs on the road. EVs are 10% of all vehicles.



Notes: BEV = battery electric vehicle; PHEV = plug-in hybrid electric vehicle. Electric car stock in this figure refers to passenger light-duty vehicles.
 Other includes Australia, Brazil, Canada, Chile, India, Japan, Korea, Malaysia, Mexico, New Zealand, South Africa and Thailand. Europe in this figure includes the EU27, Norway, Iceland, Switzerland and United Kingdom.
 Sources: IEA analysis based on country submissions, complemented by ACEA, CAAM, FAFO, EV Volumes, Marklines.


Ref. Global EV Outlook 2022, IEA

Market Analysis of EVs

Market Analysis of EVs

Market size by countries/regions

China and Europe are the top 2 growing markets of EV sales.




Notes: The countries/regions shown are the world's largest EV markets and are ordered by size of the total car market (i.e. all powertrains) in the upper half of the figure and by sales share of electric cars in the lower charts. Acronyms and geographic groupings are defined in the Notes of the previous figure. Regional EV registration data can be interactively explored via the [Global EV Data Explorer](#).

Sources: IEA analysis based on country submissions, complemented by ACEA, CAAM, FAFO, EV Volumes, Marklines.

Ref. Global EV Outlook 2022, IEA

Increase of EV models


Status and evolution of electric vehicle model availability, 2015-2021



70% was BEV, 30% was PHEV in the road in 2021

SUVs were the most popular

Available EV models by vehicle segments and powertrain



Notes: BEV = battery electric vehicle; PHEV = plug-in hybrid vehicle. Small cars include A and B segments. Medium cars include C and D segments. Crossovers are a type of sports utility vehicle (SUV) built on a passenger car platform. Large cars include E and F segments and multi-purpose vehicles. Vehicle models do not include the various trim levels.


Sources: IEA analysis based on EV Volumes and Marklines.

Ref. Global EV Outlook 2022, IEA

Market Analysis of EVs



■ Increase of EV models and sales



Notes: EVs = BEVs and PHEVs. Vehicle models do not include the various trim levels.
Sources: IEA analysis based on [EV Volumes](#).

Ref. Global EV Outlook 2022, IEA

Market Analysis of EVs



■ Future EV market size

- The total sales of EVs is expected to be 18 million units in 2025 and over 30 millions in 2030.
- ICV will be 13% of new car sales in 2025, and over 20% in 2030. EV will be the main passenger car in the world.

	2021	2025	2030
EV	16.5 mil units	18 mil units	30 mil units



Ref. Global EV Outlook 2022, IEA

Market Analysis of EVs



■ Policy and Regulation

Automobile regulation of each country, subsidy and policy for EVs


Country	Regulation	EV Subsidy & Policy
China	Introduce NEV regulation to produce and import 10% of NEV (EV, PHEV, FCV) out of 30,000 units of yearly production and import vehicle.	Subsidy for BEV, PHEV No tax for purchasing BEV, PHEV Mitigation measure of issuing number plate of BEV Increase number of NEV sales to 20% by 2025.
EU	The "Green Deal Policy" launched by the European Union in 2019 aims to reduce carbon emissions by at least 50% by 2030 and achieve carbon neutrality targets by 2050. ● Germany Stop selling ICV (Internal Combustion Engine Vehicle) by 2030. ● France Stop selling ICV (Internal Combustion Engine Vehicle) by 2040.	● Germany Subsidy for BEV, PHEV 10yrs preferential treatment of car tax (5yrs no tax and 5yrs 50% tax reduction) ● France Subsidy for BEV, PHEV Penalty in case CO2 emission is over 120g/km
US	Introduced ZEV regulation to promote sales of new generation vehicle to reduce CO2 emission	Subsidy for BEV, PHEV
Japan	Reach 30% of EV sales by 2030 Set goal of fuel consumption of new car to 25.4km/l by 2030 (19.2km/l in 2016).	Subsidy for BEV, PHEV No tax for purchasing BEV Preferential treatment of car tax by regional government

Market Analysis of EVs



■ Policy and Regulation

Zero emissions vehicle announcements by automakers are more ambitious than policy targets



IEA. All rights reserved.

Ref. Global EV Outlook 2022, IEA


Market Analysis of EVs




Subsidies

Chinese and European governments spent more money on EVs.
Sales price of EVs remain cheaper in China.

Consumer and government spending on electric cars, 2016-2021



Government spending on electric cars by region, 2016-2021



IEA. All rights reserved.

Ref. Global EV Outlook 2022, IEA


Japan International Cooperation Agency | 15

Market Analysis of EV Batteries




Increase market demand of EV batteries

Battery demand by mode, 2015-2021



Battery demand by region, 2015-2021



Notes: GWh = gigawatt-hours; PLDV = passenger light-duty vehicles; other includes medium- and heavy-duty trucks and two/three-wheelers. This analysis does not include conventional hybrid vehicles.
Sources: IEA analysis based on [EV Volumes](#).

IEA. All rights reserved.

Japan International Cooperation Agency | 16

Market Analysis of EV Batteries



Market size of EV batteries

- The EV battery market is expected to be worth 218.47 billion USD by 2027, from 34.08 billion USD in 2020 (CAGR of 31.56%).
- The lithium-ion battery segment is expected to dominate the market.
- There are technological advancements of the lithium-ion battery market and reduced the overall cost of lithium-ion battery production.
- Asia Pacific is expected significant growth in the EV battery market due to increasing demand from China, India, Japan, and other countries.
- The increasing share of EVs and rising sales volumes are also driving demand for lithium-ion battery in the U.S. and Europe ("Green Deal Policy").



Japan International Cooperation Agency | 17


Market Analysis of EV Batteries



Increase market demand of EV batteries

Demand side measures such as limiting the growth of battery size can help bridge the gap

Measures to lower metal demand in 2030 in the Net Zero Scenario




Notes: NZE = Net Zero Emissions by 2050 Scenario; STEPS = Stated Policies Scenario; APS = Announced Pledges Scenario.
Sources: IEA analysis based on [Benchmark Mineral Intelligence](#) for supply capacity.

IEA. All rights reserved.

Japan International Cooperation Agency | 18

■ Increase number of EV charging stations
China and Europe boast the largest EV charging networks in the world. Governments provide subsidies for installation of charging stations.

Government funding for publicly available charging infrastructure normalised by LDV stock and funding period, 2021



Ref. Global EV Outlook 2022, IEA

IEA. All rights reserved.

3. Analysis of EV Markers

Analysis of EV Markers

■ EV auto makers



Ref) UZABASE

Analysis of EV Markers

■ EV auto makers


Companies included in the EV, battery and top-ten automaker indices

EV index	Battery index	Top-ten automaker index
<ul style="list-style-type: none"> • Tesla • Lucid Group • Rivian Automotive • NIO • Li Auto • XPeng • Fisker • Nikola • Arrival • Proterra • Lion Electric • Hyzon Motors • Canoo • Hyliion Holdings Corp 	<ul style="list-style-type: none"> • LG Energy Solution • BYD • Contemporary Amperex Technology Ltd • Samsung SDI • Gotion High-Tech • Eve Energy Co • Farasis Energy Gan Zhou 	<ul style="list-style-type: none"> • Toyota Motor • Volkswagen • Kia • General Motors • Ford Motor • Nissan Motor • Stellantis • Renault • Hyundai Motor • Mercedes-Benz Group

■ Main players of EV makers

Main players

- 1 Tesla
- 2 BYD Company Ltd
- 3 Mercedes-Benz Group
- 4 Volkswagen
- 5 Toyota




4. Case Study

■ EV storage battery makers

Main players

- 1 Panasonic Corporation
- 2 Contemporary Amperex Technology Co Ltd
- 3 Samsung SDI Co. Ltd.
- 4 BYD Company Limited
- 5 LG Energy Solution Ltd



Case Study (Japan)

■ Cost analysis of each vehicles in Japan
BEV is the lowest running cost. Shorter driving range and longer charging time are challenges.


	Car Type	Sales Price	Pay on a spot	Driving range	Distance that can be traveled for 1,000 yen
BEV	Tesla Model S 	12,000,000 yen	600 yen	650 km	923km
PHEV	Toyota SIENTA (PHEV) 	2,910,000 yen	6,720 yen	1,142 km	169 km
ICV	Toyota SIENTA (ICV)	2,560,000 yen	6,560 yen	850 km	129 km
FCV	Toyota MIRAI 	7,100,000 yen	6,720 yen	850 km	126 km

Ref. Tesla Japan, Toyota, <https://car.rakuten.co.jp/magazine/articles/2022/carlife05/>

Case Study (Japan)



Car Sales by Fuel Type in Japan (January to October 2022)




HV	ICV (gasolin)	ICV (diesel)	PHV	BEV	FCV	Others	Total
883432	786897	100418	29738	22861	810	68	1824224
48.43%	43.14%	5.50%	1.63%	1.25%	0.04%	0%	100%

Ref: Japan Automobile Dealer Association


Case Study (Japan)



Increase no. of EV charging stations in Japan



Limited no. of hydrogen filling stations in Japan



Ref. GoGoEV, NeV, ENEOS, Toyota Mirai

Case Study (Japan)




Comparison of infrastructure in Japan

Fuel stations: 28,500
EV charging stations: 21,000
FCV hydrogen filling stations: 161
 (as of Nov. 2022)

ICV: Internal Combustion Engine Vehicle
 BEV: Battery-powered vehicle
 FCV: Fuel-cell vehicle (hydrogen vehicle)

Increase no. of EV charging stations



Location of EV charging stations in central Tokyo

Limited no. of hydrogen filling stations



Location of FCV hydrogen stations in central Tokyo (5 stations only)

Case Study (Japan)



Different types of EV stations



Cost of installation of charging station in Japan

Rapid charging station: 21,500-36,000USD
 Normal charging station: 1,500 -2,900USD

Plan of EV stations for general customers in Japan

Plan to use EV charging station	Rapid charge plan	Normal Charge plan	Combine plan
Charging machine	Rapid charger	Normal charger	Both
Monthly plan	28.5 USD/mo	10 USD/mo	31.5 USD/mo
Pay on a spot	0.1 USD/min	0.02 USD/min	0.1 USD/min 0.02 USD/min
Registration charge	10 USD		

Ref. Guliver, GoGoEV, NeV, ENEOS

Case Study (Japan)



Household EV charger




◆ Installation of household charging plugs:
JPY 40,000-120,000 (USD 270-820)

◆ Running cost: EV < ICV
When you drive 10,000km with EV (Nissan Leaf) and ICV (Toyota Prius), running cost of Nissan Leaf is JPY 30,000 (USD 200) cheaper than Toyota Prius.

Subsidy in Japan

Details can be access from <http://www.cev-pc.or.jp/english/cev-subsidy.html>



Example of subsidies for household EV charger

Ref. ENECHANGE

Case Study (Japan)



Japanese EV makers analysis

Name	Area	Analysis
Toyota	Automobile	<ul style="list-style-type: none"> Focused on PHEV, FCV & BEV. By 2025, Toyota will introduce EV (PHEV, BEV, FCV) in all models. BEV for personal mobility (car for 1-2 passenger use), connected EV & MaaS (Mobility as a Service). Creating EV platform called 'e-TNGA' with Subaru for efficiency of EV development.
Nissan	Automobile	<ul style="list-style-type: none"> Nissan set goal of EV & e-POWER sales ratio as 30% by 2022. Nissan developed a simple Hybrid system called 'e-POWER', which uses engine only for power creation. E-POWER can realize shorter charging time and cheap selling price. Nissan also develops small EVs.
Panasonic	Electronics	<ul style="list-style-type: none"> Operating EV battery factory 'GIGA factory' with Tesla. In April 2022, Panasonic established 'Prime Planet Energy & Solutions' with Toyota to produce EV battery. Panasonic launched EV with self-driving system called Spacy.
Prime Earth EV energy	Battery	<ul style="list-style-type: none"> Toyota and Panasonic established together in 1996 to produce EV battery. Increasing production capacity based on Toyota's plan. A factory for HEV battery (nickel metal hydride battery) was established in 2021.

Case Study (Japan)



Different types of FCV hydrogen filling stations



@Hydrogen filling station



@ Convenience store



@ Gas station



@ Compressed Natural gas station



@ Liquefied petroleum gas station



@ Airport

Consumer price: 8-8.7 USD/Litter

- Cost of installation of hydrogen filling station in Japan
 - Installation : 500 million yen (3.6 million USD)
 - Subsidy of govt : 350 million yen (2.5 million USD)
 - Initial cost: 150 million yen (1.1 million USD)

Ref. <https://www.jhym.co.jp/station/>
<https://www.etic.co.jp/feature/hydrogen-station118/>

Case Study (Japan)



Each Japanese makers analysis

Name	Area	Analysis
Prime Planet Energy & Solutions	Battery	<ul style="list-style-type: none"> EV battery maker for Lithium-ion battery funded by Toyota (51%) and Panasonic (49%). Developed EV battery for all-solid battery and started operation in April 2020. Provide batteries not only for Toyota but also for other makers.
Denso	Electronic parts for automobile	<ul style="list-style-type: none"> Toyota was agreed to business transfer and Denso of main electronic parts business (such as inverter, motor, semiconductor) to increase competitive advantage. To develop auto driving car, Denso strength cooperation with Toyota.
Aishin Seiki	Powertrain	<ul style="list-style-type: none"> For development of auto driving car, management integration with subsidiary named Aishin AW in April 2021, and changed company name to Aishin. Mass production of EV motor parts started in 2020 and supply the parts to Toyota EV production in China.
Hitachi Automotive Systems	Electronic parts for automobile	<ul style="list-style-type: none"> Provide EV motor to GM (General Motors), Inverter to GM, Ford Motors, Mercedes, BMW etc. In October 2019, management integration with Honda suppliers (Kehin, Nisshin Kogyo, and Showa) in purpose to become a maga player in the field of auto powertrain, chassis, self-drive, and ADAS (Advanced driver-assistance systems).

Case Study (Japan)



Each Japanese makers analysis

Name	Area	Analysis
Meidensha	Heavy power (Power equipment)	<ul style="list-style-type: none"> Provide EV motor and inverter to Mitsubishi auto factory. Invested 7 billion yen to equipment facility at 3 factories in 2018. Invested to subsidiary Meidensha for EV production in China in 2019. Established new factory development for motor and inverter with investment of 5 billion yen in Feb 2020.
NiDec	Motor	<ul style="list-style-type: none"> Produce EV motor, and parts of together with motor and inverter. Order of EV motor was rapidly increased by 2023, decided to expand production lines in Poland and Mexico in addition to a current factory in China.
Mitsubishi Electric	Electronics	<ul style="list-style-type: none"> Provide inverter to Honda, Suzuki and Daimler. Develop V2H (Vehicle to Home) system, that utilize EV battery for household power supply.
TDK Automotive Technologies	Inverter	<ul style="list-style-type: none"> EV inverter maker funded by TDK (75%) and Toshiba (25%). Provide inverter to Volkswagen and Ford Motors etc.

Ref. SPEEDA

Case Study (Barbados)



EV Dealers in Barbados

- Megapower Barbados
<https://www.megapower365.com/>

Private vehicles

MG
NISSAN
JAGUAR

Commercial vehicles

BYD (bus, van, trucks etc.)

- Courtesy Garage Barbados
<https://www.courtesygarage.com/showroom/>

Private vehicles

Hyundai (EV and HV)



NISSAN ARIYA (BEV)
@Megapower
150,000 BBD



NISSAN X-TRAIL (ICV)
@COURTESY
117,995 BBD



NISSAN JUKE 2015 (ICV)
@qv motors
55,900 BBD

Case Study (Barbados)



Cost of charging station

- 0.15 kWh/km to 0.2 kWh/km
- About 2,200 to 2,900 kWh of electricity per year
- About \$1,300 to \$1,700 per year in electricity based on our residential tariff

Megapower rate

Top-up charger (Garo)	\$1.5/kWh
Medium & fast chargers (DBT)	\$1.75/kWh
All you can charge	\$600/month
All you can charge (non-megapower Evs)	\$1,000/month

- Charging speed
- Ultra charger 100kW: 30-45 mins
- Rapid charger 25kW: 2-3 hours
- Fast charger 7.2kW 10-16 hours

Flat road. More charging stations. Commercial & tourist areas.

Map of EV Charging Station



Ref) The Barbados Light & Power Company Limited, Megapower

Case Study (Barbados)



New Incentives of the Barbados Government

- Government workers who can borrow up to \$100,000 interest-free for purchase an electric or hybrid vehicle (it was \$50 000 for vehicle purchase)
- Tax and VAT holiday on electric vehicles for 24 from April 1, 2022. Also, 10% import duty for the next two years on the purchase of electric vehicles*.

Ref) Electric cars tax breaks, but new alternate levy
<https://barbadostoday.bb/2022/03/15/electric-cars-tax-breaks-but-new-alternate-levy/>

5. Introduction of New Technology

■ Toyota's Woven City: a Prototype City of the Future

YouTube Video:
<https://www.youtube.com/watch?v=ng3X39lenvg>

Toyota has revealed plans to build a prototype "city" of the future on a 175-acre site at the base of Mt. Fuji in Japan.

Called the Woven City, it will be a full connected ecosystem powered by hydrogen fuel cells. Envisioned as a "living laboratory," the Woven City will serve as a home to full-time residents and researchers who will be able to test and develop technologies such as autonomy, robotics, personal mobility, smart homes and artificial intelligence in a real-world environment.


Read more about Toyota's Woven C
<https://blog.toyota.co.uk/toyota-wove...>



Introduction of New Technology

Introduction of New Technology

Smart Grid is the integration of our existing Electrical Grid with 2-way communication and digital sensing technology in order to enhance the capabilities of the current grid and make it more secure, reliable, efficient, and self-sufficient.



■ Wireless Transmission




Image of wireless charging of EV

Ref) https://www.toyota.co.jp/jpn/tech/partner_robot/news/202112_01.html



Experiment of PV and wireless charging system

<https://media.dglab.com/2022/05/02-dwpt-01/>

Wireless Transmission



Image of wireless transmission to a large flying object for use in a communication network




Image of wireless transmission to remote islands
*There is a plan to build a PV generation facility in space for wireless transmission.

Ref. https://www.ieice.org/~cs-edit/magazine/ieice/spsec/Bplus57_sp.pdf

Electric carrier ship

Power X is an electric carrier ship that stores electricity generated from the ocean in batteries and transports it. Power X Inc. manufactures and operates large storage batteries and deliver clean power generated by offshore wind power stations to around the world. Conventional power transmission systems using submarine cables are problematic in terms of installation costs (e.g., drilling of the seabed) and environmental impact, but Power X does not require large-scale construction work and has minimal environmental impact.



Ref. Power X, [PowerX, Inc. \(power-x.jp\)](http://PowerX, Inc. (power-x.jp))

Thank you!

Anna Miyaura (Ms.)
JICA Expert of Human Resources Development/Monitoring
Project Consultant @PADECO

Battery VS Hydrogen Storage


Feb-9, 2023
 JET (JICA Expert Team)
 Nippon Koei Co., Ltd.
 PADECO Co., Ltd.

Contents

- Battery VS Hydrogen Storage
- Characteristics and Cost of Batteries
- Hydrogen Storage Applications and Introduction Example
- An example of the cost of producing electricity with green hydrogen

Prerequisites of contents


Battery



Source: Solar Thermal Energy Promotion Inc.

VS

Hydrogen



Source: Macrovector / Freepik

Please note ...

- Technologies related to batteries and hydrogen storage are still developing.
- Presentation material include examples of a sort of study.

Battery VS Hydrogen Storage (1)

What are the strengths of Battery and Hydrogen storage?

	Power to Gas (Hydrogen)	Lead battery	Lithium-ion battery	NAS battery	Redox flow battery
Energy Density	1,290 Wh/L *1	40 - 80 Wh/L	200 - 300 Wh/L	140 Wh/L	10 Wh/L
Energy Conversion Efficiency	75 - 80% *2	75 - 85%	95%	90%	70%
Response Time	10 seconds *3	Max. tens of milliseconds	Max. tens of milliseconds	Max. tens of milliseconds	Max. tens of milliseconds

*1 In case of 70 MPa Compressed H2
 *2 Efficiency of water electrolyzer
 *3 Response time of water electrolyzer

Source: JET created this table based on the report of CO2 Free Hydrogen Working Group, Ministry of Economic, Technology and Industry, Japan, 2017

Battery VS Hydrogen Storage (2)



What are the strengths of Battery and Hydrogen storage?

1. Battery

Fast response speed

⇒ Superior ability to follow output fluctuations of renewable energy

2. Hydrogen Storage

High energy density

⇒ Suitable for large-volume and long-term energy storage



Before discussing costs, let's first look at the different characteristics of each

Characteristics of Batteries (1)



The characteristics of each typical battery are shown below.

	Advantage	Disadvantage
Lead-Acid battery	<ul style="list-style-type: none"> ➢ Low manufacturing costs result in lower unit power costs ➢ Easy maintenance 	<ul style="list-style-type: none"> ❑ Faster deterioration as the number of charge/discharge cycles increases ❑ Physically large
Lithium-Ion battery	<ul style="list-style-type: none"> ➢ Compact size and large capacity ➢ High-current charging and discharging 	<ul style="list-style-type: none"> ❑ Fire hazard ❑ Extreme degradation after around 500 charge-discharge cycles
NaS battery	<ul style="list-style-type: none"> ➢ Durability ➢ High energy density ➢ Low cost 	<ul style="list-style-type: none"> ❑ Requires about 300 Celsius degrees to operate ❑ Handling and disposal of hazardous materials such as sodium and sulfur
Redox-flow battery	<ul style="list-style-type: none"> ➢ Easy to scale up and suitable for large-capacity facilities ➢ Long cycle life, can be used for more than 10 years 	<ul style="list-style-type: none"> ❑ Relatively low energy density ❑ Long installation period for large facilities ❑ Requires a large site

Source: JET created this table based on the report of CO2 Free Hydrogen Working Group, Ministry of Economic, Technology and Industry, Japan, 2017

Batteries Energy Storage System



1. Battery

Fast response speed

⇒ Superior ability to follow output fluctuations of renewable energy




1. How much capacity do they have?
2. How many hours can it be discharged?
3. Which battery should I choose?

Characteristics of Batteries (2)



Storage batteries depend on capacity and discharge time.



Source: <https://www.mynewsdesk.com/ngk-insulators/news/sodium-sulfur-battery-technology-nas-battery-enables-megawatt-hour-energy-storage-realizes-a-stable-supply-of-renewable-energy-410813>

Hydrogen Storage(1)



2. Hydrogen Storage


High energy density

⇒ Suitable for large-volume and long-term energy storage




1. How long is “long term storage”?
2. How large is “large-volume”?
3. In what cases is hydrogen storage advantageous over batteries?

Hydrogen Storage(2)




It is difficult to compare the cost of hydrogen with that of batteries. The areas of expertise are totally different.

Battery VS Hydrogen Storage (3)




A combination of batteries and hydrogen storage is effective.

Case Studies in Japan (1)



Could be used in a house or building as an example.

Case Studies in Japan (2)




➔ See a case study of hydrogen storage.

Case Studies in Japan (3)



Buildings of wholesales market



Specifications	
Location	Wholesales Market
Power Demand	100 kW
PV	64 kW
Water Electrolyzer	5 Nm ³ /h
Hydrogen absorbing alloy tank	(1) 80 Nm ³ (2) 100 Nm ³
Fuel cell	14 kW
Batteries	20 kW - 20 kWh Lithium-Ion

Source: Hydro Q-BiC, Shimizu Corporation, Japan, <https://www.shimz.co.jp/solution/tech362/>

Case Studies in Japan (4)



Office Building (Zero Emission Building)



Specifications	
Location	Office building
PV	140 kW
Hydrogen absorbing alloy tank	2,000 kWh


Hydrogen Facilities Basement



- Various energy-saving technologies
- PV system
- Hydrogen production and storage with PV surplus power

Source: Hydro Q-BiC, Shimizu Corporation, Japan,
<https://www.shimz.co.jp/company/about/news-release/2021/2021006.html>

Hydrogen Storage System




Source: Hydro Q-BiC, Shimizu Corporation, Japan (JET translated in EN)
<https://www.shimz.co.jp/solution/tech362/>

What is “Hydrogen absorbing alloy”?




Alloy that absorbs hydrogen and releases.

- Compact storage of large volumes of hydrogen: compressed to about 1/1000th of its original volume
- Low cylinder pressure reduces the possibility of leakage (Less than 1 MPa)



当社水素吸蔵合金の一例(Ti-Mn1.9) Ti:38~40wt%, Mn:残
Source: <http://www.daido-100th.com/topics/327/>



Source: <https://kompas.hosp.keio.ac.jp/sp/contents/medical.info/science/201912.html>


Japan International Cooperation Agency | 17

Image of Hydrogen Utilization



Power generation facilities in the suburbs

Source: Hydro Q-BiC, Shimizu Corporation, Japan
<https://www.shimz.co.jp/solution/tech362/>




Japan International Cooperation Agency | 19

What is “Hydrogen absorbing alloy”?



The issue with hydrogen storage alloy tanks

- ❑ The tanks will be made of alloy, so they are heavier than cylinders such as compressed hydrogen
- ❑ Alloy prices are expensive as of 2022.



Source: <https://kompas.hosp.keio.ac.jp/sp/contents/medical.info/science/201912.html>

Japan International Cooperation Agency | 18


Cost of Hydrogen Production



Systems using hydrogen storage alloy tanks are **not yet at the commercial stage.**

An example calculation of hydrogen production using RE through grid in one study and its generation costs as applied to the CARICOM region is presented below.

[Equipment configuration]



Japan International Cooperation Agency | 20

Cost estimation of H₂ Production (1)

This trial calculation based on purchasing electricity produced from renewable energy sources via the grid and using that electricity to produce green hydrogen.

Cost Estimation		
Water electrolyzer rated capacity (Rated input power)	17.5	MW
Annual hydrogen production (ton)	2,936	ton/year
Annual hydrogen production (Nm ³)	264,462	Nm ³ /year
Amount of electricity required per year	151,620	MWh/year
Variable-OPEX(Water)	67,714	USD/year
Variable-OPEX(Electricity)	24,115,195	USD/year
LCOH (price of equalized hydrogen)	9.89	USD/kg-H ₂

Source: Created by JET

Conclusion

◆ Battery Storage

Batteries and hydrogen storage have different areas of expertise, so choose based on features, not cost.

◆ Method of Hydrogen Storage

In addition to compressed hydrogen and liquefied hydrogen, there are also storage methods using hydrogen storage alloys.

◆ Cost of Green Hydrogen


The unit cost of producing green hydrogen is high, but the cost can be reduced to some extent by direct using of renewable energy.

Cost estimation of H₂ Production (2)


Green hydrogen price in 2022 is **5.5 - 9.5 USD/kg-H₂**,

* Depending on location and conditions.

Source: S&P Global Commodity Insights, USA
<https://www.spglobal.com/commodityinsights/en/our-methodology/price-assessments/energy-transition/hydrogen-price-assessments>

 In the CARICOM region, it is impractical to purchase electricity from renewable energy sources via the grid to produce green hydrogen.

If they can get the electricity needed for water electrolysis from their own renewable energy generation facilities

 The cost of hydrogen production can be reduced.

Thank you.

Appendix 3-1-2 Attendant list, and Q&A, of the 1st Energy Efficiency Workshop (Jamaica)

Technical Cooperation to Promote Energy Efficiency in Caribbean Countries

Energy Efficiency Workshop

List of Participants (Jamaica)

List of Participants for Online Attendance (9 Feb 2023)

Venue: Zoom

No	Name	Agency	Title	Department
1	Craig Rattary	Office of Utilities Regulation		
2	Horace Buckley	MSET	Director of Projects	Prog. Implementation Div.
3	Steve Windross	JPS		

List of Participants for Online Attendance (10 Feb 2023)

Venue: Zoom

No	Name	Agency	Title	Department
1	Craig Rattary	Office of Utilities Regulation		
2	Andre Lindsay	Office of Utilities Regulation	Junior Engineer	
3	Horace Buckley	MSET	Director of Projects	Prog. Implementation Div.

Technical Cooperation to Promote Energy Efficiency in Caribbean Countries

1st EE Workshop: Q&A

No	Day	Item	Content	Name	Answer
1	9-Feb	Question	How were the targets determined? Technology vs process/activity.	Craig Rattray	Energy managements needs to be carried out through actual data collection as it is a successful element.
2	9-Feb	Question	Does the cost of energy influence the pursued targets and if so, how?	Craig Rattray	The energy cost is very much an important factor particularly in Jamaica as the power rate is increasing and there is a spike in the energy price all over the world as well. Electric power, fuel cost, etc are all increasing and the user will determine the investment by various aspects. Based on experience, the payback period needs to be less than five years. Also, there are some incentives in many countries, Japan for instance gives financial support to invest in efficient technologies and the key point is how many years will it take to recover the investment. Oftentimes efficient technology is very expensive and cannot recover which commonly happens so governmental support is a key factor.
3	9-Feb	Question	What is your opinion on the competition between hydrogen fuel cell and technology? Which one do you see becoming predominant on the global scene?	Craig Rattray	It is difficult to decide/answer which will become predominant in the 2020s however possibly the answer will come in the 2030s.
4	10-Feb	Question	In your review, did you come across any situation where management had challenges getting persons complying with the requirements of energy efficiency improvements?	Craig Rattray	Yesterday, the standards of energy management was introduced and to implement successful energy management there first needs to be an establishment of an energy management team in the organization in which top management will supervise the team. An energy management manager needs to be appointed and relevant persons from various sections will join the team. The team must consider what will be the energy efficiency policies in their organization and discuss their energy saving targets. The energy management international standards mentions some steps to be taken to implement the successful energy management and to improve energy efficiency.

Technical Cooperation to Promote Energy Efficiency in Caribbean Countries

1st EE Workshop: Q&A

No	Day	Item	Content	Name	Answer
5	10-Feb	Question	Is the practice of offering incentives or benefits to the employees, was it considered in the approaches you reviewed?	Craig Rattray	There is some award system in Japan. If a very excellent job is carried out by a company/individual, the prize or reward will go to the energy efficiency manufacturers or an individual. This is the overall frame regarding awards as a governmental policy. In the private sector, in the case of Japan, we are a little bit more cautious with energy consumption. Also, two decades ago carbon reduction was very much an important task for Japanese private companies. For instance, Japanese major private sector federations such as electric power and large energy consumption organizations had to develop their plan to reduce carbon emissions about 20 or more years ago. So with this situation, the Japanese showed a lot of interest in carbon emissions and when the persons successfully implemented the cost reduction or energy efficiency improvement, I believe the person or the team is very proud of their achievements. I am not sure if the salary will become more however having been successful, they are proud of it because the people interested in energy efficiency improvement are very much satisfied to be recognized by their achievement in their entity/organization.
6	10-Feb	Question	How did they control compatibility issues with the different connectors in Barbados?	Craig Rattray	At the front of your car, you can connect the plug to your car. The connectors operate similar to an electricity plug as there is a convertor plug; the market sells the convertor plug. Because they are only selling the limited types of electric vehicles in Barbados, there have been no issues heard of in relation to the difference of connectors however there can be problems like this and we will try to check about the information.
7	10-Feb	Question	With the technology of wireless transmission of power, do you have any idea what frequency is used for long distance?	Craig Rattray	No, actually this is just an introduction of this technology. My background is business administration so I am not really sure about the technical aspects.

Energy Efficiency & Conservation (EEC) Materiel Technical Cooperation to Promote Energy Efficiency in Caribbean Countries - Energy Consumption Analysis & EEC Roadmap -

Jamaica, March 2023

Nippon Koei Co., Ltd.
PADECO Co., Ltd.

1. Energy Consumption Analysis from Energy Balance Table
2. EEC Roadmap - Residential Sector -
3. EEC Roadmap - Commercial Sector -
4. Promising Energy Efficient Technologies in non-industrial sectors
5. References

1. Energy Consumption Analysis from Energy Balance Table

- **Current situation :Energy consumption outlook by sector and energy source**
 - **Transportation** is the largest energy consuming sector (40%) followed by **non-industrial sector** (31%, Residential & Commercial).
 - **Oil products** is the largest energy source (54%) followed by **electricity** (33%).

Energy consumption by sector and energy source on primary energy basis
(2021, Thousand Barrels of Oil Equivalent (KBOE))

	Industry	Commercial	Residential	Other	Transportation	Total	
Coal	497	-	-	-	-	497	3%
Natural gas	518	-	-	-	-	518	3%
Oil products	1,405	346	518	67	6,676	9,012	54%
Bio/RE	266	236	387	366	-	1,255	7%
Electricity (Primary energy basis)	1,757	1,980	1,726	32	-	5,494	33%
Total	4,443	2,561	2,632	465	6,676	16,777	100%
	26%	15%	16%	3%	40%	100%	


Note 1: Primary energy conversion factor of electricity is utilized to evaluate the effect of energy saving by reduction of 1kWh of electricity consumption at demand side.

Note 2: To calculate primary energy consumption of electricity, energy efficiency at end use (39.0%) was used based on the energy balance by Government of Jamaica.

Source: JET with reference to energy balances (2021) by the Government of Jamaica.
<https://www.mset.gov.jm/documents/energy-balances/>


- National Energy consumption should be evaluated on primary energy basis.
- Commercial & residential sectors share 31% of the primary energy consumption.

Energy consumption by sector on final consumption basis (2021)



1 kWh consumption corresponds to 2.56 kWh as primary energy supply.
 • 1 kWh / 0.39 = 2.56 kWh

Energy consumption by sector on primary energy basis (2021)



Source: JET with reference to energy balances (2021) by the Government of Jamaica.

Energy Consumption by Fuel and by Sector on Final Consumption Basis (2010, KBOE)

Fuel	Industry	Commercial	Residential	Other	Transportation	Total	Percentage
Coal	159	-	-	-	-	159	1%
Oil products	3,072	330	327	335	5,460	9,524	74%
Bio/RE	418	533	228	-	-	1,179	9%
Electricity (Final consumption basis)	654	702	675	14	-	2,045	16%
Total	4,303	1,565	1,230	349	5,460	12,907	100%
	33%	12%	10%	3%	42%		


Energy Consumption by Fuel and by Sector on Primary Energy Basis (2010, KBOE)

Fuel	Industry	Commercial	Residential	Other	Transportation	Total	Percentage
Coal	159	-	-	-	-	159	1%
Oil products	3,072	330	327	335	5,460	9,524	54%
Bio/RE	418	533	228	-	-	1,179	7%
Electricity (Primary energy basis)	2,148	2,306	2,217	46	-	6,718	38%
Total	5,797	3,169	2,772	381	5,460	17,580	100%
	33%	18%	16%	2%	31%		

Note: To calculate primary energy consumption of electricity, energy efficiency at end use (30.4%) was used based on the energy balance by Government of Jamaica.

- Fuel consumption
 - ✓ Power consumption has been reduced by 5%.
 - ✓ Natural gas consumption has been observed.
- Consumption by sector
 - ✓ Transportation sector has increased by 9% while Industrial & non-industrial sector has been reduced between 2010 and 2021.

Changes in Energy Consumption Ratio by Fuel (left) and by Sector (right) on Primary Energy Consumption Basis from 2010 (upper) to 2021 (lower)



Source: JET with reference to energy balances (2010, 2021) by the Government of Jamaica.

Energy Consumption by Fuel and by Sector on Final Consumption Basis (2021, KBOE)


Fuel	Industry	Commercial	Residential	Other	Transportation	Total	Percentage
Coal	497	-	-	-	-	497	4%
Natural gas	518	-	-	-	-	518	4%
Oil products	1,405	346	518	67	6,676	9,012	67%
Bio/RE	266	236	387	366	-	1,255	9%
Electricity (Final consumption basis)	686	773	674	12	-	2,145	16%
Total	3,372	1,355	1,579	445	6,676	13,428	100%
	25%	10%	12%	3%	50%		

Energy Consumption by Fuel and by Sector on Primary Energy Basis (2021, KBOE)

Fuel	Industry	Commercial	Residential	Other	Transportation	Total	Percentage
Coal	497	-	-	-	-	497	3%
Natural gas	518	-	-	-	-	518	3%
Oil products	1,405	346	518	67	6,676	9,012	54%
Bio/RE	266	236	387	366	-	1,255	7%
Electricity (Primary energy basis)	1,757	1,980	1,726	32	-	5,494	33%
Total	4,443	2,561	2,632	465	6,676	16,777	100%
	26%	15%	16%	3%	40%		

Note: To calculate primary energy consumption of electricity, energy efficiency at end use (39.0%) was used based on the energy balance by Government of Jamaica.

- In past 10 years, final energy consumption has **not changed much with slight increase of AAGR=0.1%**
- Regarding fuel type, electricity consumption **has increased with AAGR=1.1%** while oil consumption has been decreasing.




Trend of Final Consumption by Fuel (2010 – 2020) (Tj)

	2010	Share	2020	Share	AAGR
Electricity	11650	15%	12977	17%	1.1%
Bio & Waste	4944	7%	5676	7%	1.4%
Natural Gas	-	-	2225	3%	
Oil	58012	77%	52590	69%	-1.0%
Coal	1187	2%	2831	4%	9.1%
Total	75793	100%	76299	100%	0.1%

Source: United Nations Statistics Division.

Note: AAGR = Annual Average Growth Rate

- In past 10 years from 2010 to 2020, **commercial, transport and residential sectors have been increasing its final consumption while reduction has been observed in industrial sector.**




Trend of Final Consumption by Sector (2010 – 2020) (Tj)

	2010	Share	2020	Share	AAGR
Transport	29839	39%	37493	49%	2.3%
Commerce	4328	6%	6188	8%	3.6%
Households	9200	12%	9904	13%	0.7%
Industry	25598	34%	21400	28%	-1.8%
Other	1424	2%	818	1%	-5.4%
Non-energy Use	4232	6%	494	1%	-19.3%
Agriculture	1172	2%	-	-	-
Total	75793	100%	76297	100%	0.1%

Source: United Nations Statistics Division.


- **Energy efficiency efforts at demand side should be evaluated by final consumption basis when efficiency at supply side changes significantly.**
- **Non-industrial sector shares 67% of annual electricity consumption.**
- **AAGR between 2010 – 2021 was 100.4% (very slight increase).**

Trend of Power Consumption by Final Consumption Basis (2010 – 2021)



	Industry	Commercial	Residential	Other	Total
2010	1,111	1,193	1,147	24	3,475
2021	1,166	1,314	1,145	21	3,646
AAGR	100.4%	100.9%	100.0%	98.9%	100.4%


Ratio of Power Consumption by Sector in 2021



Source: JET with reference to energy balances (2021) by the Government of Jamaica.

2. Energy Efficiency & Conservation (EEC) Roadmap - Residential Sector -



Method of EEC Roadmap Development



Energy Efficiency & Conservation (EEC) Roadmap





- Electric power consumption of refrigerator has been estimated to be **reduced by 68%** with EE Scenario compared with BAU Scenario in 2038.
- Energy efficiency of refrigerator in use at households will be **3.1 times more efficient** compared with that of currently used in 2038 in EE Scenario with Introduction of MEPS.



Energy Efficiency & Conservation (EEC) Roadmap





- Electric power consumption of air conditioner has been estimated to be **reduced by 61%** with EE Scenario compared with BAU Scenario in 2038.
- Energy efficiency of air conditioner in use at households will be **2.6 times more efficient** compared with that of currently used in 2038 in EE Scenario with Introduction of MEPS.




Energy Efficiency & Conservation (EEC) Roadmap



- Electric power consumption of lighting equipment has been estimated to be **reduced by 78%** with EE Scenario compared with BAU Scenario in 2038.
- Energy efficiency of lighting equipment in use at households will be **4.7 times more efficient** compared with that of currently used in 2038 in EE Scenario with Introduction of MEPS.




- With MEPS introduction targeting refrigerator, lighting equipment and air conditioner, it has been estimated power consumption will be **reduced by 51% in 2038**.




3. Energy Efficiency & Conservation Roadmap -Commercial Sector-

- Electric power consumption of air conditioner has been estimated to be **reduced by 61%** with EE Scenario compared with BAU Scenario in 2038.
- Energy efficiency of air conditioner in use at households will be **2.6 times more efficient** compared with that of currently used in 2038 in EE Scenario with Introduction of MEPS.




- Electric power consumption of lighting equipment has been estimated to be **reduced by 66%** with EE Scenario compared with BAU Scenario.
- Energy efficiency of lighting equipment in use at households will be **2.9 times more efficient** compared with that of currently used in 2038 in EE Scenario with Introduction of MEPS.




- Electric power consumption of refrigerator has been estimated to be **reduced by 59%** with EE Scenario compared with BAU Scenario in 2038.
- Energy efficiency of refrigerator in use at commercial field will be **2.5 times more efficient** compared with that of currently used in 2038 in EE Scenario with Introduction of MEPS.

Electric Power Consumption by Refrigerator up to 2038 (BAU and EE Scenario)




Assumed MEPS (EE Index) introduction for refrigerator in EE Scenario




- With MEPS introduction targeting refrigerator, lighting equipment and air conditioner, it has been estimated power consumption will be **reduced by 57%** in 2038.

Energy Saving Potential in Commercial Sector up to 2038 (BAU and EE Scenario)




Energy Saving Share by Equipment in 2038 (EE Scenario)




- With MEPS introduction targeting refrigerator, lighting equipment and air conditioner, it has been estimated power consumption will be **reduced by 55%** in residential and commercial sectors in 2038.

Energy Saving Potential in Residential + Commercial Sector up to 2038 (BAU and EE Scenario)




Energy Saving Share by Equipment and Sector in 2038 (EE Scenario)



- Ref: Current situation: Electricity consumption by sector and end-use


Electricity sales by demand group (last 10 years) and end-use



Source: JET with reference to Barbados NATIONAL ENERGY POLICY (2019-2030) and material by the Government of Barbados


4. Promising Energy Efficient Technologies in non-industrial sectors

Trends in Annual Energy Consumption of Refrigerator (401-450ℓ, 2003 - 2013)



Source: Energy Saving Catalogue 2014 Summer (METI)


Trends in Annual Energy Consumption (2016 - 2020)



Source: Energy Saving Catalogue 2021 (METI)

EE Improvement of Refrigerator (Commercial), Japan

Comparison of Annual Energy Consumption of Refrigerator (Commercial)




Source: HOSHIZAKI CORPORATION





Trends of EE Improvement of various ACs, Japan

Energy Efficiency Trends of Heat Pump Technologies



Source: Manufacturers' Catalogue, Energy Saving Catalogue (METI)

Note 1: COP stands for Coefficient of Performance, energy efficiency at rated operation (kWh/kWh)
 Note 2: APF stands for Annual Performance Factor, energy efficiency throughout a year (kWh/kWh)




Source: Ministry of Economy and Trade and Industry, METI

Comparison of heat generation (Incandescent lamp vs LED lamp)

Incandescent Lamp (810 lm, 54W)	LED lamp (810 lm, 9W)
30 minutes after lighting	
<p>80 °C</p> <p>110 °C</p>	<p>26 °C</p> <p>55 °C</p>

↓
Contributes less AC demand

Variable Refrigerant Flow (VRF, Inverter always equipped) is efficient AC equipment for middle scale buildings




Daytime view	Before refurbishment: Mercury lamp 80W	After refurbishment: LED 33W																				
<table border="1"> <tr><td>Road width</td><td>4.8 m</td></tr> <tr><td>Installation interval</td><td>Approx. 35 m</td></tr> <tr><td>Installation height</td><td>Approx. 4.5 m</td></tr> </table>	Road width	4.8 m	Installation interval	Approx. 35 m	Installation height	Approx. 4.5 m	<table border="1"> <tr><td>Horizontal plane (average)</td><td>2.75 Lux</td></tr> <tr><td rowspan="2">Vertical plane (Min.)</td><td>Road center</td><td>0.41 Lux</td></tr> <tr><td>Both sides of the road</td><td>0.39 Lux</td></tr> </table>	Horizontal plane (average)	2.75 Lux	Vertical plane (Min.)	Road center	0.41 Lux	Both sides of the road	0.39 Lux	<table border="1"> <tr><td>Horizontal plane (average)</td><td>7.09 Lux</td></tr> <tr><td rowspan="2">Vertical plane (Min.)</td><td>Road center</td><td>1.59 Lux</td></tr> <tr><td>Both sides of the road</td><td>1.49 Lux</td></tr> </table>	Horizontal plane (average)	7.09 Lux	Vertical plane (Min.)	Road center	1.59 Lux	Both sides of the road	1.49 Lux
Road width	4.8 m																					
Installation interval	Approx. 35 m																					
Installation height	Approx. 4.5 m																					
Horizontal plane (average)	2.75 Lux																					
Vertical plane (Min.)	Road center	0.41 Lux																				
	Both sides of the road	0.39 Lux																				
Horizontal plane (average)	7.09 Lux																					
Vertical plane (Min.)	Road center	1.59 Lux																				
	Both sides of the road	1.49 Lux																				

Source: Japan security systems association


Daytime view



Before refurbishment:
CFL 20W



After refurbishment:
LED 17W



Road width	5.1 m
Installation interval	Approx. 30 m
Installation height	Approx. 5.0 m

Horizontal plane (average)		1.76 Lux
Vertical plane (Min.)	Road center	0.17 Lux
	Both sides of the road	0.12 Lux

Horizontal plane (average)		5.56 Lux
Vertical plane (Min.)	Road center	0.78 Lux
	Both sides of the road	0.64 Lux



Source: IWASAKI ELECTRIC CO., LTD.

5. References


- Outline of the building
 - Location: Tokyo
 - Floor area: 19,550m²
 - Building structure: RC (Basement 1F – 4 floors)
 - AC system: DHC (District Heating and Cooling) + AC units (partially)
 - Number of workers: Approx.200 persons

- EEC approaches (STEP by STEP)
 - Introduction of auto timer to lighting and AC in 2009. (ON/OFF switch was operated manually in the past)
 - Introduction of LED to spot lighting equipment (approx. 1,000 units) in 2012
 - Introduction of LED to regular lighting equipment (approx. 2,000 units) in 2014




Trend of Power Consumption Reductions

(approx.8years: Apr.2009-Jan.2017)



Source: The Consultant based on the material by the Tokyo metropolitan government (Jul.2017)

Effects on Cooling Demand Reductions with Introduction of LED to Regular Lighting System



Source: JET based on the material by the Tokyo Metropolitan government (Jul.2017)

Introduction of LED realized reductions of waste heat from lighting equipment and achieved cooling demand reductions (30%) in summer.

Evaluation of Energy Consumption Reductions on Primary Energy Basis

Energy	Before		After		Primary energy consumption reductions
	2009	2013	2015	2016	
Electric power consumption	275 MWh x 12 = 3,300 MWh/year			171 MWh x 12 = 2,052 MWh/year	
Primary energy consumption	3,300 x 9.97 = 32,901 GJ/year			2,052 x 9.97 = 20,458 GJ/year	32,901 – 20,458 = 12,443 GJ/year
Cooling& heating demand		445 GJ x 12 = 5,340 GJ/year	325 GJ x 12 = 3,900 GJ/year		
Primary energy consumption		5,340 GJ x 1.36 = 7,262 GJ/year	3,900 GJ x 1.36 = 5,304 GJ/year		7,262 – 5,304 = 1,958 GJ/year
Total	32,901 + 7,262 = 40,163 GJ/year		20,458 + 5,304 = 25,762 GJ/year		14,401 GJ/year (36%)

Note1: Calculation was made by JET
 Note2: Conversion factors for electric power and DHC were based on the guide for compiling periodical report regarding EE law. (METI, Aug.2017)
 Note3: Changes of both heating and cooling demands by the introduction of LED are taken into account.
 Source: JET based on the material by the Tokyo Metropolitan government (Jul.2017)

Thank you very much for your kind attention !


Information Sharing Material - Energy Efficiency Policy in Japan -

Jamaica, March 2023

Nippon Koei Co., Ltd.
PADECO Co., Ltd.

Year	Policy
2002	Basic Act on Energy Policy
2003-2014	Released Basic Energy Policies 4 times in 2003, 2007, 2010, 2014
2015	Long-term outlook for energy demand and supply ● Energy Mix in 2030 (ratio of power sources): RE: 22-24%, Nuclear: 20-22%
2018	5th Basic Energy Policy ● 2030: To achieve Energy Mix surely ● 2050: Challenge to energy conversion and decarbonization
Oct.2020	Prime Minister's speech ● Greenhouse gas emissions to zero by 2050 ● Establishment of a stable energy supply by thorough EE as well as introducing RE to the maximum extent.


EE&C Target for 2030 in Long-term Outlook for Energy Demand and Supply (energy mix)



Source: JET based on the Ministry of Economy, Trade and Industry's (METI) material. Mar.2021

- EE&C 2030 targets were developed sector by sector as well as technology by technology (bottom-up approach)

EE&C 2030 Targets by Sector (in Energy Mix)



- Various EE&C technologies / approaches could be applied across the sectors, and these exceeded 40% of the energy-saving target amount.

Cross Sectorial EE&C Approaches (in Energy Mix targets)

	Industrial	Commercial	Residential	Total (%)
Improvement of energy performance in new buildings/homes		6.6	6.2	12.8
High efficiency lighting	2.1	4.5	4	10.6
Energy management by utilizing BEMS / HEMS		4.7	3.5	8.2
Improvement of energy performance of specified equipment (Top runner program)		5.5	2.7	8.2
Energy saving (retrofit) of buildings/homes		0.8	0.8	1.6
Total	2.1	22.1	17.2	41.4


	FY 2018 results	Targets in FY 2030	Progress
1. Energy-originated CO ₂ emissions (total GHG emissions)	1.06 billion Ton (GHG:1.24 billion Ton)	0.93 billion Ton (GHG:1.04 billion Ton)	
2. Electricity cost (fuel cost + FIT purchase cost)	8.5 Tera Yen • Fuel cost: 5.7 Tera Yen (Crude oil cost: 63\$/bbl) • FIT cost: 2.8 Tera Yen	9.2~9.5 Tera Yen • Fuel cost: 5.3 Tera Yen (Crude oil cost: 128\$/bbl) • FIT cost: 3.7~4.0 Tera Yen	
3. Energy self-sufficiency rate (whole primary energy)	12%	24%	
4. Zero emission power supply ratio	23% • RE: 17% • Nuclear: 6%	44% • RE: 22~24% • Nuclear: 22~20%	
5. EE&C (final energy consumption in crude oil equivalent)	339 mil kℓ • Commercial/industry: 210 • Residential: 50 • Transport: 80	326 mil kℓ • Commercial/industry: 230 • Residential: 40 • Transport: 60	

- Energy savings achieved in FY 2018 = ▲13.4 mil kℓ
➢ Progress rate = 26.6% # Average progress rate = 33.3% (2013-2030)


Progress of Energy Savings by Sector

Sector	FY 2018 results		
	Energy savings	Progress rate	Progress rate by EE&C measure
Residential	▲2.9 mil kℓ	24.9%	<ul style="list-style-type: none"> • Introduction of LED, etc. 72% • EE improvements of appliances 24% • EE improvements of house 10%
Commercial	▲3.3 mil kℓ	27.1%	<ul style="list-style-type: none"> • Introduction of LED, etc. 63% • Energy management by BEMS, etc. 25% • Introduction of efficient refrigerator-freezer and router / server, etc. 18%
Industrial	▲2.8 mil kℓ	26.3%	<ul style="list-style-type: none"> • Introduction of LED, etc. 66% • Energy management by FEMS, etc. 18% • Introduction of efficient motor 9% • Introduction of industrial heat pump 8%
Transport	▲4.4 mil kℓ	27.6%	<ul style="list-style-type: none"> • Other measures in transport sector 47% • Diffusion of next generation vehicle 14%


Progress of Major EE&C Measures in Residential Sector




Progress of Major EE&C Measures in Industrial Sector



Progress of Major EE&C Measures in Commercial Sector



Progress of Major EE&C Measures in Transport Sector



Major Issues and EE&C Regulations by Sector

	Industrial	Commercial	Residential	Transport	
				Passenger	Freight
Major issues	Improving EE remains at a standstill ⇒ Promotion of EE&C investment	Limitations of improving equipment efficiency ⇒ Utilization of IoT, AI, etc., EE&C promotion for houses and buildings		⇒ Full-scale spread of EV / PHV / FCV	More frequent and smaller ⇒ Promotion of cooperation between shipper and freight operator
Regulation	Top Runner Program (Energy saving standards for equipment, etc.) ⇒ Examination of appropriate system design, etc.		Regulation on factories, etc. ⇒ Strengthen execution, etc.		Regulation of shipper Regulation on freight operator ⇒ Examination on EE&C efforts of supply chain, etc.
		EE law of buildings ⇒ Take highly effective measures for each scale / use to ensure compliance with EE standards			

Source: JET based on METI's material, Mar.2021

Thank you very much for your kind attention !

● Top runner program started in 1998 which was defined in EE law (establishment: 1979)

- Standards for performance of appliances, etc. are set at the top runner performance in that year.
- Other products (runner-up, etc.) are required to catch up and qualify the top runner level in designated duration.

Current Target Products of Top Runner Program (32 products)

Passenger Vehicles	Video Tape Recorders	Vending Machines	Printers
Freight Vehicles	Electric Refrigerators	Transformers	Heat Pump Water Heaters
Air Conditioners	Electric Freezers	Electric Rice Cookers	AC Motors
TV Sets	Space Heaters (Gas/Oil)	Microwave Ovens	Bulbs
Copying Machines	Gas Cooking Appliances	DVD Recorders	Refrigerating Showcases
Computers	Gas Water Heater	Routers	Insulation Materials
Magnetic Disk Units	Oil Water Heaters	Switches	Sashes
Lighting equipment	Electric Toilet Seats	Multi-function Printers	Double Glazing

Source: JET based on METI's homepage

Energy Efficiency & Conservation (EEC) Materiel
Technical Cooperation to Promote
Energy Efficiency in Caribbean Countries

- Energy Efficiency Building Code -

Jamaica, March 2023

Nippon Koei Co., Ltd.
PADECO Co., Ltd.


1. Outline of EE Regulations in Residential Building
2. Examples of Simplified Calculation in Residential Building (Region-6)
3. Examples of Simplified Calculation in Residential Building (Region-8)
4. EEC Unique Approaches in Residential Building, Okinawa

1. Outline of EE Regulations in Residential Building

● Overview of the Energy Efficiency Standards for Residential Buildings

The evaluation of energy efficiency (EE) performance for residential buildings uses the following two standards:

- Standards to evaluate **envelope performance** (e.g. windows, exterior walls of residential buildings)
- Standards to evaluate the **primary energy consumption amount of equipment and appliances** etc.



1. Outline of EE Regulations in Residential Building


1. Outline of EE Regulations in Residential Building

● Envelope performance

- Average outer shell heat transmission coefficient (U_A)

$$U_A = \frac{\text{Amount of total heat loss per unit of temperature difference}}{\text{Total surface area of exterior}}$$

- U_A
 - ✓ An indicator of the ease of heat transfer between indoor and outdoor air.
 - ✓ When the temperature difference between the inside and outside of the building is 1 °C, the amount of heat released per unit time from the inside of the building to the outside of building is divided by the total surface area of exterior.
 - ✓ The smaller the value, the more difficult it is for heat to enter and exit, and the higher the insulation performance.



1. Outline of EE Regulations in Residential Building




● Envelope performance

- Average solar heat gain coefficient during cooling period (η_{AC})

$$\eta_{AC} = \frac{\text{Amount of total solar heat gain per unit of solar radiation intensity}}{\text{Total surface area of exterior}} \times 100$$

- η_{AC}
 - ✓ An indicator of how easily solar radiation enters the room.
 - ✓ Amount of heat acquired inside the building from solar radiation per unit of solar radiation intensity averaged by the cooling season and divided by the total surface area of exterior.
 - ✓ The smaller the value, the less sunlight enters and the higher the shielding performance.



1. Outline of EE Regulations in Residential Building



● Primary energy consumption amount

- + heating/cooling system primary energy consumption amount
- + ventilation system primary energy consumption amount
- + lighting system primary energy consumption amount
- + hot water supply primary energy consumption amount
- + other (household appliances) primary energy consumption amount
- reduction amount of primary energy consumption through PV, etc

= primary energy consumption amount

□ Evaluation of primary energy consumption amount

$$\frac{\text{Design value (excludes home appliances etc.)}}{\text{Standard value (excludes home appliances etc.)}} \leq 1.0$$

1. Outline of EE Regulations in Residential Building




□ Envelope performance

$$U_A \text{ Design Value} \leq \text{Standard Value}$$

$$\eta_{AC} \text{ Design Value} \leq \text{Standard Value}$$

- ✓ Standard values of U_A and η_{AC} are defined by region by region. (regions are classified in 8 regions in Japan)



Region	1&2	3	4	5	6	7	8
Standard Value of U_A	0.46	0.56	0.75	0.87	0.87	0.87	-
Standard Value of η_{AC}	-	-	-	3.0	2.8	2.7	6.7

Revised in Apr.2020 as previous value was too strict (3.2)

1. Outline of EE Regulations in Residential Building



□ Promulgated on June 17, 2022 (Ministry of Land, Infrastructure, Transport and Tourism Housing Bureau)

- Mandate that all new residential and nonresidential buildings comply with EEC standards
- Conducted as part of the building permit process, integrated with the structural safety regulation conformity assessment.
- Enforcement will be made by FY2025, while ensuring a sufficient preparation period in consideration of small and medium-sized construction firms and the development of the screening system.

	current		➔	revision	
	Non-residential	Residential		Non-residential	Residential
large-scale 2,000m ² or more	Compliance obligation	Notification obligation		Compliance obligation	Compliance obligation
mid-scale	Compliance obligation	Notification obligation		Compliance obligation	Compliance obligation
Less than 300m ² small scale	Explanation obligation	Explanation obligation		Compliance obligation	Compliance obligation

2. Examples of Simplified Calculation in Residential Building (6 Region)

Simplified Calculation	
Envelope performance	
Region	Legend of sheet number
6 Region	6 - 1 - 1 ↓ ↓ Category 1: Wooden 2: Reinforced Steel, Steel, etc.
wooden	1: Floor-insulated dwelling (Bathroom floor insulation) 2: Floor-insulated dwelling (Bathroom foundation insulation) 3: Floor-insulated dwelling (no bathroom floor in contact with outside air, etc.) 4: Foundation-insulated dwelling

2. Examples of Simplified Calculation in Residential Building (6 Region)

Average heat transmission coefficient U_A Please fill in the values in the bold frame below.

In the case where a single part has several different specifications, the heat transfer coefficient shall be that of the specification with the largest heat transfer coefficient. If the area of a window is less than or equal to the total floor area of the unit dwelling multiplied by 0.02, the window specification concerned may be excluded.

		Heat transmission coefficient U	Result
Roof or ceiling	0.194	× 0.258	= 0.051 (1)
Outer wall	general section	× 0.489	= 0.211 (2)
	Foundation wall (Entrance)	× 0.004	= 0.017 (3)
Floor	Bathroom	× 0.009	= 0.031 (4)
	Other Floors	× 0.121	= 0.060 (5)
Window	0.107	× 2.91	= 0.312 (6)
Door	0.014	× 3.49	= 0.049 (7)
↑ Rounded up to the fourth decimal place			
Periphery of dirt floor, etc.	Entrance etc.	0.021	× 0.99 = 0.021 (8)
↑ Rounded up to the fourth decimal place			

Average heat transmission coefficient of envelope: U_A [W/(m²·K)] Sum of (1)-(8) = **0.76**

*Rounded up to the third decimal place (Conforming if the standard value is 0.87 [W/(m²·K)] or less)

2. Examples of Simplified Calculation in Residential Building (6 Region)

Average solar heat gain during cooling season η_{AC} Please fill in the values in the bold frame below.

If a site has several different specifications, the thermal transmittance of the specification with the largest thermal transmittance should be used. If a window has several different specifications, the vertical solar heat gain shall be the vertical solar heat gain of the specification with the largest vertical solar heat gain. If the area of a window is less than or equal to the total floor area of the unit dwelling multiplied by 0.04, the window specification concerned may be excluded.

		Heat transmission coefficient U	Result
Roof or ceiling	0.659	× 0.258	= 0.171 (9)
Outer wall	General section	× 0.762	= 0.328 (10)
	Foundation Wall (Entrance)	× 0.004	= 0.017 (11)
Door	0.020	× 3.49	= 0.070 (12)
↑ Rounded up to the fourth decimal place			
Window	4.356	× 0.32	= 1.394 (13)
↑ Rounded up to the fourth decimal place			

Coefficient of Vertical Surface Solar Heat Gain Coefficient η_g Results

Average solar heat gain during cooling season η_{AC} [-] Sum of (9)-(13) = **2.0**

*Rounds up to the second decimal place (Conforming if the standard value is 2.8 [-] or less)

Average solar heat gain during the heating season η_{AH} Please enter the values in the bold boxes below.

If a site has several different specifications, the thermal transmittance of the specification with the largest thermal transmittance should be used.
If a window has several different specifications, the vertical surface solar heat gain shall be that of the specification with the lowest vertical surface solar heat gain. If the area of the window is less than or equal to the total floor area of the unit dwelling multiplied by 0.04, the window specification concerned may be excluded.

		Heat transmission coefficient U	Result
Roof or ceiling	0.658	× 0.258	= 0.169 (14)
Outer wall	general section	× 0.882	= 0.379 (15)
	Foundation Wall (Entrance)	× 0.002	= 0.008 (16)
door (Western-style)	0.014	× 3.49	= 0.048 (17)

↑Rounded down to the fourth decimal place

		Coefficient of Vertical Surface Solar Heat Gain Coefficient η_g	Results
window	4.786	× 0.32	= 1.531 (18)

↑Rounded down to the fourth decimal place

Average solar heat gain during the heating season η_{AH} [-] Sum of (14)-(18) = **2.1**

*Rounded down to the second decimal place (Reference value: None)

Simplified Calculation
Primary energy consumption performance

6
Region


Sheet No.	Principal living space	Other living space
6-ENE-1	Not installed	
6-ENE-2	Room air conditioner	
6-ENE-3	Hot water floor heating (Oil latent heat recovery hot water heater)	Room air conditioner
6-EN-4	Hot water floor heating (Gas latent heat recovery hot water heater)	Room air conditioner

Please fill in the envelope performance.

Please fill in the figures in the bold frame below.

Average heat transmission coefficient U_A [W/(m ² · K)]	0.76
Average solar heat gain during cooling season η_{AC} [-]	2.0
Average solar heat gain during the heating season η_{AH} [-]	2.1

From the Point Listing page, post the points you selected in (1) through (5) in the bolded box below and calculate the total.



Reference] Approximate points for each facility (excluding other facilities)

		Please fill in the points in the bold frame below.	
heating facilities	Transcribe the numbers in (1)	= 29	(a)
air-conditioning facilities	Transcribe the numbers in (2)	= 10	(b)
ventilation equipment	Transcribe the numbers in (3)	= 8	(c)
hot-water supply system	Transcribe the numbers in (4)	= 36	(d)
Lighting equipment	Transcribe the numbers in (5)	= 10	(e)

Primary energy consumption performance points Total of (a)-(e) = **93**

(Conforming if less than or equal to 100 points)

(1) **Envelope performance and heating system**

*Confirm the average heat transmission coefficient and the average solar heat gain during the heating season for the house in question, and check the points of the heating equipment with the relevant envelope performance value. (However, only if the average solar heat gain during the heating season is 1.8 or higher.

Average heat transmission coefficient U_A [W/(m ² · K)]	Average solar heat gain during the heating season η_{AH} [-]	point
<input checked="" type="checkbox"/> Greater than 0.69 0.78 or less	<input checked="" type="checkbox"/> 1.8 or Less than 2.3 <input type="checkbox"/> higher	29
	<input type="checkbox"/> 2.3 or Less than 2.8 <input type="checkbox"/> higher	28
	<input type="checkbox"/> 2.8 or Less than 3.3 <input type="checkbox"/> higher	26
	<input type="checkbox"/> 3.3 or Less than 3.8 <input type="checkbox"/> higher	25
	<input type="checkbox"/> 3.8 or Less than 4.3 <input type="checkbox"/> higher	24
	<input type="checkbox"/> 4.3 or higher	21

2. Examples of Simplified Calculation in Residential Building (6 Region)



(2) Envelope performance and cooling system

*Confirm the average heat transfer coefficient of the external envelope of the house in question and the average solar heat gain during the cooling season, and check the points of the cooling system with the relevant external envelope performance value. (However, only if the average solar heat gain during the cooling season is 4.3 or less.

Average heat transmission coefficient U_A [W/($m^2 \cdot K$)]	Average solar heat gain during the cooling season η_{sc} [-]	point
<input checked="" type="checkbox"/> 0.69 or more Less than 0.78	<input type="checkbox"/> 1.8 or less	9
	<input checked="" type="checkbox"/> 1.8 Larger 2.3 or less	10
	<input type="checkbox"/> 2.3 Larger 2.8 or less	11
	<input type="checkbox"/> 2.8 Larger 3.3 or less	13
	<input type="checkbox"/> 3.3 Larger 3.8 or less	14
	<input type="checkbox"/> 3.8 Larger 4.3 or less	16

(3) Ventilation equipment

*Please check the points by ticking the appropriate ones.

type	point
<input type="checkbox"/> Ducted Type 1 Ventilation System	13
<input type="checkbox"/> Ducted Type 2 ventilation equipment or ducted Type 3 ventilation equipment	10
<input type="checkbox"/> Wall-mounted Type 1 ventilation equipment	10
<input checked="" type="checkbox"/> Wall-mounted Type 2 ventilation equipment or Wall-mounted Type 3 ventilation equipment	8

2. Examples of Simplified Calculation in Residential Building (6 Region)



(5) Lighting equipment

*Check the points for all fixtures in the main living room and all other living rooms by in the appropriate combination. However, lighting fixtures in non-occupied rooms must be non-incandescent.

type	point
Lighting fixtures in principal living rooms* ²	
<input type="checkbox"/> Not installed	9
<input type="checkbox"/> LED	9
<input type="checkbox"/> Other than incandescent lamps	10
<input type="checkbox"/> Incandescent lamp	13
<input checked="" type="checkbox"/> LED	9
<input type="checkbox"/> Other than incandescent lamps	10
<input type="checkbox"/> Incandescent lamp	13
<input type="checkbox"/> Other than incandescent lamps	11
<input type="checkbox"/> LED	11
<input type="checkbox"/> Other than incandescent lamps	11
<input type="checkbox"/> Incandescent lamp	14
<input type="checkbox"/> Incandescent lamp	15
<input type="checkbox"/> LED	15
<input type="checkbox"/> Other than incandescent lamps	16
<input type="checkbox"/> Incandescent lamp	18

2: "LED": LEDs are used in all devices.

"Non-incandescent": All equipment uses non-incandescent lamps.

"Incandescent": Incandescent lamps are used in any of the devices.

2. Examples of Simplified Calculation in Residential Building (6 Region)



(4) Hot-water supply system

*Please check the points by ticking the appropriate ones.

type	Hot water-saving faucet* ¹	point
<input type="checkbox"/> Not installed	-	43
<input type="checkbox"/> Conventional gas water heater	<input type="checkbox"/> No	47
	<input type="checkbox"/> Yes	44
<input type="checkbox"/> Gas latent heat recovery water heater	<input type="checkbox"/> No	40
	<input type="checkbox"/> Yes	38
<input type="checkbox"/> Conventional oil water heaters	<input type="checkbox"/> No	42
	<input type="checkbox"/> Yes	39
<input type="checkbox"/> Oil latent heat recovery water heater	<input type="checkbox"/> No	40
	<input type="checkbox"/> Yes	38
<input type="checkbox"/> Electric heat pump water heater (CO ₂ refrigerant)	<input checked="" type="checkbox"/> No	36
	<input type="checkbox"/> Yes	34

*1: "Yes" can be selected for hot water-saving faucets when faucets with the following functions are installed in all "kitchen", "bathroom shower", and "washbasin" areas.

Kitchen": water shut-off function or priority water dispensing function

Bathroom shower: Hand-held shut-off function or low-flow discharge function

Washbasin": Priority water dispensing function

2. Examples of Simplified Calculation in Residential Building (6 Region)



Primary energy consumption calculation results (residential version)

1. Design primary energy consumption etc.

(1) Name of housing type	○○○○ residence (detached house)			
(2) Floor area.	Principal living space	Other living space	Non-living space	Total
	29.81 m ²	51.34 m ²	38.93 m ²	120.08 m ²
(3) Regional classification	6 Region		*****	
(4) Primary energy consumption (per dwelling)			Design primary [MJ].	Standard Primary [MJ].
	heating facilities		17236	15382
	air-conditioning facilities		5390	5611
	ventilation equipment		4583	4542
	hot-water supply system		20940	25091
	lighting equipment		5964	10763
	Other equipment.		21241	21241
	On-site consumption of electricity generated by power generation facilities #1		--	--
	Deductions related to the amount of electricity sold from cogeneration facilities #2		--	--
	total amount		75353	82629
(5) BEI	Primary energy consumption (excluding others) [GJ/(unit/year)].		54.2	61.4
	BEI		0.89	

*1: Power generation facilities include cogeneration facilities and photovoltaic facilities. *2: This is the amount of primary energy consumption required to generate the electricity sold by the cogeneration facility.

3. Examples of Simplified Calculation in Residential Building (8 Region)

Simplified Calculation Envelope performance

Region	Legend of sheet number
8 Region	8 - 1 - 1 ↓ ↓ Category Legend
wooden	<div style="border: 1px solid black; padding: 5px; display: inline-block;"> Category 1: Wooden 2: Reinforced Steel, Steel, etc. </div> <div style="border: 1px solid black; padding: 5px; display: inline-block; margin-left: 20px;"> 1: Floor-insulated dwelling (Bathroom floor insulation) 2: Floor-insulated dwelling (Bathroom foundation insulation) 3: Floor-insulated dwelling (no bathroom floor in contact with outside air, etc.) 4: Foundation-insulated dwelling </div>

3. Examples of Simplified Calculation in Residential Building (8 Region)

3. Examples of Simplified Calculation in Residential Building (8 Region)

Average heat transmission coefficient U_A Please fill in the values in the bold frame below.

In the case where a single part has several different specifications, the heat transfer coefficient shall be that of the specification with the largest heat transfer coefficient. If the area of a window is less than or equal to the total floor area of the unit dwelling multiplied by 0.02, the window specification concerned may be excluded.

		Heat transmission coefficient U	Result
Roof or ceiling		0.194 × 0.99	= 0.192 (1)
Outer wall	general section	0.489 × 0.430	= 0.211 (2)
	Foundation wall (Entrance)	0.004 × 4.11	= 0.017 (3)
Floor	Bathroom	0.009 × 3.34	= 0.031 (4)
	Other Floors	0.121 × 0.492	= 0.060 (5)
Window		0.107 × 6.0	= 0.642 (6)
Door		0.014 × 3.49	= 0.049 (7)
Periphery of dirt floor, etc. Entrance etc.		0.021 × 0.99	= 0.021 (8)

↑ Rounded up to the fourth decimal place

Average heat transmission coefficient of envelope: U_A [W/(m²·K)] Sum of (1)-(8) = **1.22**

Note 1: U_A of roof /ceiling was adopted the standard value in region 8 while other values are set at same value as region 6 (there is no standard values for them).
 Note 2: For window, adopted coefficient of vertical surface solar heat gain of single-layer glass.

Average solar heat gain during cooling season η_{AC} Please fill in the values in the bold frame below.

If a site has several different specifications, the thermal transmittance of the specification with the largest thermal transmittance should be used. If a window has several different specifications, the vertical solar heat gain shall be the vertical solar heat gain of the specification with the largest vertical solar heat gain. If the area of a window is less than or equal to the total floor area of the unit dwelling multiplied by 0.04, the window specification concerned may be excluded.

		Heat transmission coefficient U	Result
Roof or ceiling		0.959 × 0.99	= 0.949 (9)
Outer wall	General section	0.762 × 0.430	= 0.330 (10)
	Foundation Wall (Entrance)	0.004 × 4.11	= 0.016 (11)
Door		0.019 × 3.49	= 0.066 (12)
Window		4.55 × 0.63	= 2.867 (13)

↑ Rounded up to the fourth decimal place

Average solar heat gain during cooling season η_{AC} [-] Sum of (9)-(13) = **4.2**

*Rounds up to the second decimal place (Conforming if the standard value is 6.7 [-] or less)

Note : For window, adopted coefficient of vertical surface solar heat gain of single-layer glass.

Simplified Calculation

Primary energy consumption performance

**8
Region**

Sheet No.	Principal living space	Other living space
8-ENE-1	Not installed	
8-ENE-2	Room air conditioner	

(1) Envelope performance and cooling system

*Confirm the average heat transfer coefficient of the external envelope of the house in question and the average solar heat gain during the cooling season, and check the points of the cooling system with the relevant external envelope performance value. (However, only if the average solar heat gain during the cooling season is 8.7 or less.


Average heat transmission coefficient U_A [W/(m ² · K)]	Average solar heat gain during the cooling season η_{ac} [-]	point
<input checked="" type="checkbox"/> 1.05 or more Less than 1.50	<input type="checkbox"/> 1.7 or less	19
	<input type="checkbox"/> 1.7 Larger 2.7 or less	25
	<input type="checkbox"/> 2.7 Larger 3.7 or less	30
	<input checked="" type="checkbox"/> 3.7 Larger 4.7 or less	35
	<input type="checkbox"/> 4.7 Larger 5.7 or less	40
	<input type="checkbox"/> 5.7 Larger 6.7 or less	45
	<input type="checkbox"/> 6.7 Larger 7.7 or less	50
	<input type="checkbox"/> 7.7 Larger 8.7 or less	55
<input type="checkbox"/> 1.50 or more Less than 1.95	<input type="checkbox"/> 1.7 or less	17
	<input type="checkbox"/> 1.7 Larger 2.7 or less	22
	<input type="checkbox"/> 2.7 Larger 3.7 or less	26
	<input type="checkbox"/> 3.7 Larger 4.7 or less	30
	<input type="checkbox"/> 4.7 Larger 5.7 or less	35
	<input type="checkbox"/> 5.7 Larger 6.7 or less	40
	<input type="checkbox"/> 6.7 Larger 7.7 or less	45
	<input type="checkbox"/> 7.7 Larger 8.7 or less	49

Please fill in the envelope performance.

Please fill in the figures in the bold frame below.

Average heat transmission coefficient U_A [W/(m ² · K)]	1.22
Average solar heat gain during cooling season η_{ac} [-]	4.2

From the Point Listing page, post the points you selected in (1) through (4) in the bolded box below and calculate the total.



Reference) Approximate points for each facility (excluding other facilities)

Facility	Transcribe the numbers in (1)	=	Points	Label
air-conditioning facilities	(1)	=	35	(a)
ventilation equipment	(2)	=	10	(b)
hot-water supply system	(3)	=	26	(c)
Lighting equipment	(4)	=	12	(d)

Please fill in the points in the bold frame below.

Primary energy consumption performance points Total of (a)-(d) = **83**

(Conforming if less than or equal to 100 points)

(2) Ventilation equipment

*Please check the points by ticking the appropriate ones.

type	point
<input type="checkbox"/> Ducted Type 1 Ventilation System	16
<input type="checkbox"/> Ducted Type 2 ventilation equipment or ducted Type 3 ventilation equipment	13
<input type="checkbox"/> Wall-mounted Type 1 ventilation equipment	13
<input checked="" type="checkbox"/> Wall-mounted Type 2 ventilation equipment or Wall-mounted Type 3 ventilation equipment	10

(3) Hot-water supply system

*Please check the points by ticking the appropriate ones.

type	Hot water-saving faucet*.1	point
<input type="checkbox"/> Not installed	-	38
<input type="checkbox"/> Conventional gas water heater	<input type="checkbox"/> No	42
	<input type="checkbox"/> Yes	39
<input type="checkbox"/> Gas latent heat recovery water heater	<input type="checkbox"/> No	36
	<input type="checkbox"/> Yes	33
<input type="checkbox"/> Conventional oil water heaters	<input type="checkbox"/> No	38
	<input type="checkbox"/> Yes	35
<input type="checkbox"/> Oil latent heat recovery water heater	<input type="checkbox"/> No	36
	<input type="checkbox"/> Yes	33
<input type="checkbox"/> Electric heat pump water heater (CO ₂ refrigerant)	<input checked="" type="checkbox"/> No	26
	<input type="checkbox"/> Yes	25


(4) Lighting equipment

*Check the points for all fixtures in the main living room and all other living rooms by in the appropriate combination. However, lighting fixtures in non-occupied rooms must be non-incandescent.

type		point
Lighting fixtures in principal living rooms* ²	Lighting fixtures in other living rooms* ²	
<input type="checkbox"/> Not installed	<input type="checkbox"/> Not installed	11
	<input type="checkbox"/> LED	11
	<input type="checkbox"/> Other than incandescent lamps	12
	<input type="checkbox"/> Incandescent lamp	16
<input checked="" type="checkbox"/> LED	<input type="checkbox"/> Not installed	11
	<input type="checkbox"/> LED	11
	<input checked="" type="checkbox"/> Other than Incandescent lamps	12
	<input type="checkbox"/> Incandescent lamp	16
<input type="checkbox"/> Other than incandescent lamps	<input type="checkbox"/> Not installed	13
	<input type="checkbox"/> LED	13
	<input type="checkbox"/> Other than incandescent lamps	14
	<input type="checkbox"/> Incandescent lamp	17
	<input type="checkbox"/> Incandescent lamp	19
<input type="checkbox"/> Incandescent lamp	<input type="checkbox"/> Not installed	19
	<input type="checkbox"/> LED	19
	<input type="checkbox"/> Other than incandescent lamps	20
	<input type="checkbox"/> Incandescent lamp	23

2: "LED": LEDs are used in all devices.
 "Non-incandescent": All equipment uses non-incandescent lamps.
 "Incandescent": Incandescent lamps are used in any of the devices.

[Ref] Rainfall level & average temperature in Okinawa, 8 Region, 2019



Data source: Japan Meteorological Agency

1. Design primary energy consumption etc.

(1) Name of housing type	○○○○ residence (detached house)			
(2) Floor area.	Principal living space	Other living space	Non-living space	Total
	29.81 m2	51.34 m2	38.93 m2	120.08 m2
(3) Regional classification	8 Region		*****	
(4) Primary energy consumption (per dwelling)			Design primary [MJ].	Standard Primary [MJ].
	heating facilities		0	0
	air-conditioning facilities		15483	21289
	ventilation equipment		4583	4542
	hot-water supply system		12338	17922
	lighting equipment		5964	10763
	Other equipment.		21241	21241
total amount		59609	75756	
(5) BEI	Primary energy consumption (excluding others) [GJ/(unit/year)].		38.4	54.6
	BEI		0.71	

*1: Power generation facilities include cogeneration facilities and photovoltaic facilities. *2: This is the amount of primary energy consumption required to generate the electricity sold by the cogeneration facility.

4. EEC Unique Approaches in Residential Building, Okinawa, Japan

Energy Reduction Effects by Applying Efficient Technologies in Okinawa

Use	Energy consumption standard value (GJ)	Efficient technology	Energy consumption rate (standard value is set at 1.0) more efficient →			
			Level 1	Level 2	Level 3	Level 4
Cooling	10.3 (15%)	Use and control of natural wind	0.96	0.91	0.88	
		Solar radiation shielding method	0.9	0.8	0.75	0.7
		Cooling system plan (efficient AC, etc.)	0.9	0.8	0.75	0.65
Ventilation	3.1 (5%)	Ventilation equipment	ducted	0.7	0.5	
	2.8		wall-mounted	0.8		
Hot water supply	13.8 (21%)	Solar hot water supply	0.9	0.7	0.5	0.3
		Hot water supply system	0.9	0.8		0.6
Lighting	13.6 (20%)	Daylight use	0.97~0.98	0.95	0.9	
		Lighting Equipment planning	0.85	0.8	0.7	
Appliances	21.4 (32%)	Introduction of high-efficiency appliances	0.8	0.6		
Other (Cooking)	4.4 (7%)					
Total amount	66.6					
	66.3					

Source: Energy efficient house guidelines (Okinawa prefecture, 2015)

Adopted EE Methods and Estimation of Energy Saving Effects - Example of the Model House - (1)

Use	Efficient technologies	Evaluation level	Energy consumption rate	Adopted EE methods
Cooling	Use of natural wind	3	0.88	<ul style="list-style-type: none"> • Openings on ventilation paths • Openings with consideration of the prevailing wind direction • Use of high windows
	Solar radiation shielding method	4	0.7	<ul style="list-style-type: none"> • Thermal barrier paint • Thermal barrier block
	Cooling system planning	3	0.75	<ul style="list-style-type: none"> • High-efficiency air conditioner (COP 4 or higher) + fan
Hot water supply	Hot water supply system planning	4	0.6	<ul style="list-style-type: none"> • CO2 heat pump water heater
Ventilation	Ventilation system planning	1	0.8	<ul style="list-style-type: none"> • Simplified ventilation system
Lighting	Daylight use	2	0.95	<ul style="list-style-type: none"> • LD and individual rooms
	Lighting Equipment Planning	3	0.7	<ul style="list-style-type: none"> • High efficiency, control, and design ingenuity
Appliances		2	0.6	<ul style="list-style-type: none"> • Efficient products + reduced standby power

Adopted EE Methods and Estimation of Energy Saving Effects - Example of the Model House - (2)

Use	Standard value (GJ)	A	B	C	Design value (GJ)	Energy saving rate (%)	Note
Cooling	10.3	0.88	0.7	0.75	4.76	53.7	$4.76 = 10.3 \times 0.88 \times 0.7 \times 0.75$
Hot water supply	13.8	0.6			8.28	40.0	$8.28 = 13.8 \times 0.6$
Ventilation	3.1	0.8			2.48	20.0	$2.48 = 3.1 \times 0.8$
Lighting	13.6	0.95	0.7		9.04	33.5	$9.04 = 13.6 \times 0.95 \times 0.7$
Appliances	21.4	0.6			12.84	40.0	$12.84 = 21.4 \times 0.6$
Other	4.4				4.4	0	
Total	66.6				41.8	37.2	


Energy saving rate



Key Points 1: Sunshine Shield

●Methods to shield sunshine

- ✓ It is basic to keep the building skeleton close to the ambient temperature, **not to heat it.**
- ✓ The strong sunshine of Okinawa **should be blocked outside.**



Sunshine Shield in Urban Area



Sunshine Shield in Suburban Area

Key Points 1: Sunshine Shield

➤ Green roof




➤ Solar Heat Shielding Paint



Key Points 1: Sunshine Shield

➤ Solar Heat Shielding Block



Key Points 1: Sunshine Shield

➤ HANA Block



Key Points 1: Sunshine Shield

➤ Wall-surface Greening



Key Points 1: Sunshine Shield

➤ AMAHAJI



AMAHAJI is Okinawa's traditional eaves where customers are welcomed as there is not entrance in Okinawa's unique houses.

Key Points 1: Sunshine Shield

➤ Eaves




Key Points 1: Sunshine Shield

➤ Louver



Key Points 1: Sunshine Shield


Example of Solar Heat Shielding Measures for Opening and Roof



Key Points 2: Create Cool Breeze, Bring Cool Breeze

● Methods to Create Cool Breeze, Bring Cool Breeze

- ✓ It is basic to **bring cool breeze in rooms**
- ✓ Ingenuity in **building layout and window positions**
 - In summer, cool breezes are drawn into the building from the south.
 - In winter, the wind from the north should be blocked.



Key Points 2: Create Cool Breeze, Bring Cool Breeze

➢ Windows at high position



Windows at high position (from outside)



Windows at high position (from inside)

Key Points 2: Create Cool Breeze, Bring Cool Breeze

➢ Security-friendly small window




Key Points 3: Make good use of daylight

● Methods to Make good use of daylight

- ✓ It is basic to **allow light to enter a room while blocking direct sunshine.**
- ✓ Utilization of **inner court, high sidelight (windows on high position) and louver, etc.**

➢ High Sidelight




High Sidelight



High Sidelight (sunshine enters indirectly)

Key Points 3: Make good use of daylight

➤ Introduction of light shelf concept



- If the eaves on the south side of the building are made two-tiered, the eaves blocks direct sunshine from entering the window.
- The light reflected on the upper part of the eaves is diffusely reflected on the ceiling of the room and light up the back of the room.



Thank you very much for your kind attention !

Key Points 3: Make good use of daylight

➤ HANA Block



Lighting with utilization of HANA block