資料 - 7: その他の活動実績

I. 流量モニタリングシステム

## 7.I Flow Monitoring System

#### **Table of Contents**

1.	Purpose of flowmeter monitoring system	7-2
2.	Configuration of flow meter and installation location	7-2
3.	Demarcation of flow meter system installation	7-3
4.	Progress of installation work	7-3
5.	Operation status	7-9
6.	YCDC-WRAWSA central data room	7-11
7.	OJT	7-11
8.	Remaining issues	7-12

#### 1. Purpose of flowmeter monitoring system

It was decided at the 1<sup>st</sup> JCC to establish a monitoring system for the following purposes;

- 1) To monitor the volume of water delivered and distributed, which is the most basic data required for the operation of water services
- 2) To utilize the flow data for non-revenue water management
- 3) To prepare an efficient water transmission and distribution management plan and to aim at fair water transmission and distribution.

In order to achieve the above objectives, the following flow measurements will be carried out;

- 1) Water deliveries from WTP (Nyaunghnapin WTP)
- 2) Water deliveries in backbone pipeline (reservoir deliveries and water pump deliveries)
- 3) Distribution volume in backbone distribution pipeline (inflow and outflow at core distribution pumping stations and distribution reservoirs)

Note: In Nyaunghnapin WTP, two flow meters are already installed and this flow data is also included in the monitoring.

#### 2. Configuration of flow meter and installation location

The configuration of flowmeter is shown in Figure 1. The flowmeter consists of an ultrasonic sensor and flowmeter body (both from Tokyo Keiki), a Remote Terminal Unit (RTU) and a data logger (both from Delairco Japan). The ultrasonic sensor (hereafter, "sensor") is installed directly on the pipe, while the flowmeter body, RTU and data logger are installed on the kiosk.




Figure 1 Configuration of flow meter system

Location of flowmeter is shown in Table 1. Flow meter was installed in 21 locations and these flow meters were connected to 9 kiosks. Detailed location of flow meter is shown in Attachment 1. From

these 9 kiosks, measured flow data is periodically transmitted via mobile phone lines to central data room located in the YCDC-WRAWSA HQ. Measured data sent from kiosks are collected in the server in the central data room and monitored and analyzed in the central data room.

Table 1 No. of flowmeter and location of kiosk

Location of kiosk	No. of flow meter
After Gyobyu Reservoir	1
After Phugyi Reservoir and Aqueduct	2
Phugyi and Gyobyu pipe connection at	3, 4
Pyawbwesu PS	
Naunghnapin Phase 1&2 WTP and PS	5, 6
	Existing Nyaunghnapin 1, Existing Nyaunghnapin 2
Hlawga PS No.1	7
Hlawga PS No.2	8
Yegu PS	9, 10, 11, 12, 13, 14
Kokkine SR	15, 16, 17
Shwedagon SR	18, 19, 20, 21

#### 3. Demarcation of flow meter system installation

Installation of flow meter was carried out in cooperation with the following three parties.

- ✓ WRAWSA: Construction of kiosk and related preparatory works
- ✓ Tokyo Keiki Inc.: Installation of flow meter and sensor
- ✓ Delairco Japan KK: Installation of RTU and communication equipment, data collection and analysis equipment (central data room) and remote monitoring

#### 4. Progress of installation work

The progress of flowmeter installation work is shown in Table 2. Photos of flow meter installed are also shown in Table 3. The installation work of flowmeter and communication device started in February 2019. Initially, it was planned that the installation work would be completed in August 2019 and the equipment would be handed over to WRAWSA after on-the-job training on its operation. However, during the verification work in August 2019, it became clear that the data reading errors of the Yegu No.9 and No.12 exceeded the specified error value (1%). Therefore, it was decided to postpone the handover to EDWS and to take measures to eliminate the reading error. In addition, during the work in October 2019, it was observed that the sensor of Nyaunghnapin Existing No. 2 had dropout and fixing wire of Yegu No. 11 had corroded. However, after January 2020, travel to Yangon is no longer possible due to COVID-19 pandemic. For this reason, no measures have been taken to address the above issues.

Table 2 Progress of flow meter installation work until Nov. 2019

Period	Work description	Problems and actions to be taken
18 - 27	Installation of Data logger	
Feb. 2019	and RTU	
5 May – 30	Installation of flow meter	
June 2019	and sensor	

Period	Work description	Problems and actions to be taken
7-15July 2019	Server and PC setup in YCDC-WRAWSA HQ (Central data room)  Checking the communication status between each kiosk and central data room	Operation the facility  ✓ UPS battery trouble at Gyobyu kiosk.  ✓ It was caused by improper operation (breaker manually turned off for and leaving more than a month).  ✓ OJT on correct operation including handling of power supply.  Initial failure of monitoring equipment  ✓ The initial fault was found on the circuit board of the communication device.  ✓ The circuit boards were replaced at the time of dispatch in
		August 2019.  Noise in YeguPS  ✓ High input voltage of RTU was observed.  ✓ It was presumed that the noise was superimposed from motor (pump of Yegu PS).  Note: At this time, the source of the noise was presumed to be the motor at Yegu pumping station.
		<ul> <li>Shwedagon SR</li> <li>✓ It was found that all three outlets of Shwedagon SR were not always full because of the low volume of water transmitting to Shwedagon SR.</li> <li>✓ Expert proposed to WRAWSA to relocate the location of flow meter sensor.</li> <li>✓ CE stated that this problem will be solved in the future when more water is transmitted to Shwedagon SR.</li> <li>✓ Therefore, the relocation of flow meter sensor was not implemented.</li> </ul>
18 – 23 Aug. 2019	Checking flowmeter reading error of measured values	Flowmeter performance  ✓ Checking flowmeter reading data errors for all 9 kiosks  ✓ No.9, 10, 12 and 13 flowmeters at Yegu PS had large data reading errors (>1%).
		The cause of data reading error and noise in the Yegu PS was unclear, therefore, it was decided to continue investigating countermeasures.
21 Oct. – 1 <sup>st</sup> Nov. 2019	Checking flow meter performance and taking action to eliminate noise that cause flow meter reading error	<ul> <li>Meter reading error</li> <li>✓ Checking flow meter reading error of all 9 kiosks</li> <li>✓ For Yegu PS kiosk, grounded earth and high frequency filters have been installed.</li> <li>✓ However, noise could not be eliminated completely from Yegu No. 9 and 12 flowmeters and significant data reading errors (&gt;1%) remained.</li> </ul>
		Noise investigation  ✓ As a result of the noise investigation, it was confirmed that the noise was a superposition of amplitude modulated (AM) waves with a frequency of around 630KHz.  ✓ From this result, it was presumed that the noise source was a radio transmitter such as a broadcasting station.  Checking the operating condition of all flowmeters  ✓ Checking operational condition of all (21) flowmeters  ✓ Corrosion of mounting rack and dropout of sensor of Nyaunghnapin Existing No.2 was confirmed.  ✓ Corrosion of mounting rack of Yegu No.11 was confirmed.

Table 3 Photos of flow meter installed

Location	No. of flow meter	Photo		
After Gyobyu	1	Sensor No.1 protection box	Inside the protection box and sensor No.1	
Reservoir		RTU and data logger	Kiosk	
After Phugyi	2	Sensor No.2 protection box	Inside of the protection box and sensor No.2	
Reservoir at 2 Aqueduct		No.2 flow meter	Kiosk	
Phugyi and Gyobyu pipe connection at Pyawbwesu Pump Station	3 4	Sensor No.3 protection box	Sensor No.4 protection box	

Location	No. of flow meter	Photo		
		Flow meter No.3 and No.4 (Installed in PS building)	RTU and data logger (Installed in PS building)	
	5	Sensor No.5	Sensor No.6	
Nyaughnapin Phase 1&2 WTP and PS	6	Flow meter	Kiosk	
	Existing No.1 No.2	Existing No.1	Existing No.2	
Hlawga PS No.1	7	Sensor No.7	Flow meter No.7	

Location	No. of flow meter	Photo		
		RTU and data logger	Kiosk	
Hlawga PS	8	Sensor No.8	Flow meter No.8	
No.2 8		RTU and data logger	Equipment booth in PS building	
	9	77		
	10 11	1 Decrease in		
Yegu PS		Sensor No.9	Sensor No.10	
	12		A REAL PROPERTY.	
	13 14	Sensor No.11	Sensor No.12	

Location	No. of flow meter	Photo		
		Sensor No.13	Sensor No.14	
		Flow meter No.9, 10, 11 and 12  RTU and data logger	Flow meter No.13 and 14  Kiosk	
Kokkine	15 16	Sensor No.15	Sensor No.16	
Service Reservoir	17	Sensor No.17	Setup of flow meter	

Location	No. of flow meter	Photo		
		RTU and data logger	Inside the kiosk	
		Sensor No.18	Sensor No.19	
Shwedagon Service Reservoir	18 19 20 21	Sensor No.20	f Sensor No.21	
		Flow meter No.18 and 19	RTU and data logger	

## 5. Operation status

The operational status as of November 2019 is shown in Table 4 and Table 5. After this, the flowmeter system is remotely monitored by Delairco Japan.

Table 4 Operation status as of Nov. 2019

Location	No.	Operation status	Problem
After Gyobyu Reservoir	1	Good	None
After Phugyi Reservoir and Aqueduct	2	Good	None
Phugyi and Gyobyu pipe connection at	3	Good	None
Pyawbwesu PS	4	Good	None

Location	No.	Operation status	Problem
Nyaunghnapin Phase 1&2 WTP and PS	5	Good	None
	6	Good	None
	Existing 1	Good	None
	Existing 2	Inoperative	✓ Dropout of sensor
			✓ Reinstallation of sensor
Hlawga PS No.1	7	Good	None
Hlawga PS No.2	8	Good	None
Yegu PS	9	Inoperative	<ul> <li>✓ Indication of external noise</li> <li>✓ Data reading errors (&gt;1%)</li> <li>✓ Consideration of measures including relocation of flow meters</li> </ul>
	10	Good	None
	11	Good	✓ Corrosion of fixing wire ✓ Replacement of fixing wire
	12	Inoperative	<ul> <li>✓ Indication of external noise</li> <li>✓ Data reading errors (&gt;1%)</li> <li>✓ Consideration of measures including relocation of flow meters</li> </ul>
	13	Good	None
	14	Good	None
Kokkine SR	15	Good	None
	16	Good	None
	17	Good	✓ Noise detected, but measurement is possible
Shwedagon SR	18	Good	None
	19	Good	✓ Flow measurement is not possible
	20	Good	because pipe is not always full.  Expert team proposed CE to
	21	Good	relocate flowmeter

Table 5 Result of data reading test

No.	Location	Simulation flow value (m <sup>3</sup> /h)	RTU read out (m³/h)	Error (%) 2019/10	Error (%) 2019/8
1	After Gyobyu Reservoir	10,000	9973.6	0.26	0.19
2	After Phugyi Reservoir at Aqueduct	10,000	9996.17	0.04	0.02
3	Phugyi and Gyobyu pipe connection	10,000	9996.2	0.04	0.00
4	at Pyawbwesu Pump Station	10,000	10001.4	0.01	0.08
5	Nyaughnapin Phase 1&2 WTP	5,000	5035.27	0.71	0.71
6	Nyaughnapin Phase 1&2 W 1P	5,000	4997.22	0.06	0.05
-	Nyaughnapin Existing No.1 (PS)	5,000	4995.48	0.09	0.04
-	Nyaughnapin Existing No.2 (PS)	5,000	5002.42	0.05	0.03
7	Hlawga PS No.1	10,000	9990.00	0.1	0.07
8	Hlawga PS No.2	10,000	10006.58	0.07	0.08
9		5,000	4855.83	2.88	15.04
10		5,000	4932.78	1.34	1.02
11	V DC	5,000	4939.78	1.22	0.44
12	Yegu PS	5,000	4939.16	1.25	3.70
13		5,000	4978.88	0.42	1.84
14		5,000	4937.61	1.25	0.82
15		5,000	5000.69	0.01	0.01
16	Kokkine Service Reservoir	5,000	4992.9	0.14	0.14
17		5,000	4998.08	0.04	0.03
18	Shwedagon Service Reservoir	5,000	4957.33	0.85	0.21

No.	Location	Simulation flow value (m <sup>3</sup> /h)	RTU read out (m³/h)	Error (%) 2019/10	Error (%) 2019/8
19		5,000	4990.27	0.19	0.07
20		5,000	4984.2	0.32	0.04
21		5,000	4999.82	0	0.01

#### 6. YCDC-WRAWSA central data room

Central data room has been set up in YCDC-WRAWSA HQ for the collection, monitoring and analysis of flow data from 21 flow meters.





Photo 1 Central data room




Figure 2 Display of flow data analysis system

#### 7. **OJT**

6 times of on-the-job training (OJT) sessions have been carried out. Table 6 shows the summary of OJT. The teaching materials, photographs and a list of participants are shown in Attachment 2.

Table 6 Summary of OJT

No.	Date	Venue	Trainer	Participants	ants Contents of OJT	
1	28 Jun.	Yegu PS	Tokyo	Kiosk manager at each	Flowmeter O&M training using	
	2019		Keiki Inc.	flow meter site	UFL-30 Maintenance manual	
				Staffs of central data	Practical training in Yegu PS flow	
				room	meter kiosk	
2	13 July	Yegu PS	Delairco	Kiosk manager at each	Management of UPS	
	2019		Japan KK	flow meter site	(Uninterruptible Power Supply)	
				Staffs of central data	Operation of data collection system	
				room		
3	15 July	Central	Delairco	Staffs of central data	Remote operation of flow meter	
	2019	data room	Japan KK	room	Collection, analysis and	
					management of flow data	
4	21 Aug.	Central	Delairco	Staffs of central data	Remote operation of flow meter	
	2019	data room	Japan KK	room	Collection, analysis and	
					management of flow data	
5	30 Oct.	Yegu PS	Tokyo	Kiosk manager at each	O& M of kiosk	
	2019		Keiki Inc.	flow meter site		
			Delairco	Staffs of central data		
			Japan KK	room		
6	1st Nov	Central	Delairco	Staffs of central data	Flow data management	
	2019	data room	Japan KK	room		

#### 8. Remaining issues

Since the start of operation of flowmeter and data correction system in 2019, the following issues are remaining. However, due to COVID-19 pandemic (Jan. 2020-) and the outbreak of political upheaval (Feb. 2021-), travel to Yangon has been difficult and the measures have not been implemented.

#### (1) Sensor dropout of Nyaunghnapin Existing No.2 and fixing wire corrosion of Yegu No.11

The status of Nyaunghnapin Existing No.2 and Yegu No.11 at the time the problem was identified is shown in Photo 2. In Nyaunghnapin Existing No.2, the sensor attached on the side of pipe dropped out due to corrosion of steel fixing wire. In Yegu No. 11, the sensor is still on the pipe but the steel fixing wire are corroded and need to be replaced as soon as possible.

The reasons for the use of steel wire, which are the cause of these problems, are described below.

#### Nyaunghnapin existing No.2

Nyaunghnapin Existing No.2 was planned to carry out only coaxal cable extension and connection works. However, on checking the inside of the flowmeter chamber, it was found that the fixing wire was already corroded and needed to be replaced.

Because re-installation work of existing No. 2 sensor had not been planned, there was no extra stainless-steel wire for this purpose. Therefore, it was decided to purchase an alternative fixing wire in Yangon. However, stainless-steel wire was not available in Yangon, it was decided to use steel wire which was available in Yangon.

#### Yegu No.11

Yegu No.11 sensor was originally planned to be installed on a pipe with a diameter of 600 mm,

but after installation it was found that the pipe was not always full. Therefore, it was decided to replace the No. 11 sensor on the 1200 mm diameter pipe, which is always full.

However, there was no extra stainless-steel wire because this re-location work was not planned. Therefore, it was decided to purchase an alternative fixing wire (steel wire) in Yangon.



Nyaunghnapin Existing No.2 Dropped sensor: In the red circle



Yegu No.11 Corroded steel wire: In the red circle

Photo 2 Problems that have occurred in Nyaunghnapin Existing No.2 and Yegu No.11

#### (2) The effect of electrical noise on Yegu No.9 and No.12

The location of the sensors installed in Yegu PS is shown in Figure 3. The sensors that cannot be measured due to noise are No. 9 and No. 12 are installed on Gyobyu - Kokkine 56-inch MS pipeline. Photos of Gyobyu - Kokkine 56-inch MS pipeline are shown in Photo 3. Near Yegu PS, the pipeline is installed above ground.




Figure 3 Location of sensors in YeguPS





Photo 3 Gyobyu – Kokkine 56 inch MS pipeline

An investigation of the sources and transmission pathways of noise in YeguPS has been carried out. The current findings are presented below.

#### Noise transmission path

Figure 4 shows the presumed transmission path of the noise. It is assumed that the noise is transmitted through the MS pipeline. Furthermore, it was thought that the noise transmitted through the MS pipeline was picked up by the sensor (No.9 and / or No.12) and transmitted through the signal line (coaxal cable) and flowmeter, then reach to the data logger.



Source: Delairco Japan KK, Dispatch report, Nov. 2019.

Figure 4 Estimated noise path way

#### Estimation of noise source

To estimate the noise source, the frequency and waveform of the noise of No.9 and No.12 were measured. As a result, it was found that

- ✓ Frequency of the noise: around 630kHz
- ✓ Waveform of the noise: Sine wave
- ✓ Characteristics of amplitude modulation (AM) (Photo 4)




Photo 4 Obtained waveform of noise

Based on the above observations, the noise was assumed to be interference caused by high-frequency waves. Thus, the Gyobyu-Kokkine MS pipeline installed on the ground acts as an aerial, and receives high frequency waves, then reach the data logger through the sensor and signal line.

Near YeguPS, there is a Ministry of Information broadcast station (Yay-Kuu broadcast station) (Figure 5). The broadcasting station is used for Myanmar radio national service and relay broadcasting of NHK (Nihon Housou Kyoukai) on medium and short-wave band with maximum power 50KW. The Gyobyu-Kokkine MS tube is located along the Yay-Kuu transmitter station, and the shortest distance between the transmitter station (aerial) and the pipeline is about 100m.



Figure 5 Location of Yegu PS and Yay-Kuu broadcasting station

The relationship between the broadcasting schedule of Yay-Kuu broadcasting station and the noise was examined in the terms of the time of the occurrence of the noise and the broadcast frequency.

Figure 6 shows the flow data of Yegu No.9 and No.12. The flow rate fluctuates strongly from 6 am to 8 pm. This fluctuation in the data was considered to be due to the influence of noise, and the noise was considered to have occurred between 6am and 8pm.

Next, the broadcasting schedule of Yay-Kuu transmitter station was checked (Table 7). There were no broadcasts on 630 kHz in the medium wave band, and no broadcasts that matched the time of day when the noise occurred appeared to be made.

However, the Yay-Kuu transmitter station near YeguPS is the most likely source of AM modulated noise. Therefore, for the time being, the Yay-Kuu transmitter station is assumed to be the source of the noise, and countermeasures will be studied.




Figure 6 flow data record of YeguPS No.9and No.12

Table 7 Broadcasting schedule of Yay-Kuu broadcasting station (Mid wave band)

Frequency	Service				
(1) Myanmar Radio National Service					
576 kHz	576 kHz 2300-1700Z (05:30-23:30 MMT), Power: 100 kW.				
729 kHz	2300/2330-1630Z (05:30 / 06:00 – 23:00 MMT), Power: 50 kW.				
(2) NHK World					
576kHz Wed / Sat, 1445 – 1505Z (21:15 – 21:35 MMT)					
Source; (1) https://www.asiawaves.net/myanmar-radio.htm (2) https://www3.nhk.or.jp/nhkworld/resources/brochure/pdf/rj frequency.pdf					

### Noise reduction measures taken in 2019

The noise reduction measures taken in 2019 are shown in Photo 5. However, in this case, the noise was directly superimposed on the sensor output, therefore, installation of frame ground and radio frequency filter (RF filter) were not effective.

#### Measures implemented in Yegu PS

- ✓ Installation of Frame Ground (FG)
- ✓ Installation of RF filter using ferrite core






Photo 5 Implemented measure in Yegu PS

**Attachment 1** 


Location of kiosk and flow meter







Note: Diameter (mm) is reference only.

D: Detector, T: Transducer, RTU: Remote Terminal Unit, UPS: Uninterruptible Power System







Flow Monitoring Locations and Flow Meters

Monitoring location (RTU)		Nos of		0-1-1-		
Location No.	Location	Flow meters	No.	(m)	Pipe material and diameter for flow meter	
1	After Gyobyu Reservoir	1	1	20	MS56in.(1400mm)	
2	After Phugyi Reservoir at Aqueduct	1	2	30	MS48 in. (1200mm) MS part in Concrete pipe (56in.)	
3	Phugyi and Gyobyu pipe connection at Pyawbwesu Pump Station	2	3	60	MS56in(1400mm)	
			4	130	MS56in.(1400mm)	
	Naughnapin Phase 1&2 WTP and PS	2	5	240	1000mm	
4			6	240	1000mm	
4		Existing		300	e e	
		Existing	=	220	4	
5	Hlawga PS NO1	1	7	30	MS66in.(1600mm) MS part in concrete pipe (66in.)	
6	Hlawga PS NO2	1	8	70	Cl42in.(1000mm)	
	Yegu Pump Station	6	9	170	Inlet: MS56in.(1400mm)	
			10	170	Cl42in.(1000mm)	
_			11	40	Cl24in.(600mm)	
7			12	140	Outlet: MS56in.(1400mm)	
			13	130	Cl42in.(1000mm)	
			14	120	MS36in.(900mm)	
8	Kokine Service Reservoir	3	15	50	MS56in.(1400mm)	
8			16	210	MS54in.(1350mm)	
			17	270	MS42in.(1000mm)	
	Shwedagon Service Reservoir	4	18	150	MS42in.(1000mm)	
6			19	150	Cl27in.(700mm)	
9			20	100	Cl27in.(700mm)	
			21	110	Cl27in.(700mm)	
		21	21	3,150		

Note: Diameter( mm) is reference only.

#### **Attachment 2**

Training material

Note:  $2^{nd}$ ,  $3^{rd}$  and  $5^{th}$  OJT were practical training in Yegu PS kiosk and central data room

1st OJT: 28 July 2019



# UFL-30 MAINTENANCE MANUAL




#### Troubleshooting

Main flowmeter (electronics) unit and components

In the event of problems, please review this section to identity causes and suggested remedies. If the steps shown in this section cannot solve a problem, contact Tokyo Kelki.

- Unit does not startup when the system is powered up.
   Is the main circuit breaker activated?
- Is the fuse burned out?
- · LCD display is dim.
  - Was contrast adjusted?
  - Has the specification life been exceeded?



- Flow values do not vary.
   Does 'R', 'D' marks or 'ERR" 'appear? (Values are held)
- Analog output does not vary.
   Is analog check mode activated? (Is <A > displayed?)

#### Measurement

The following is a description of some general problems and remedies relating to measurement. If the steps shown in this section cannot solve a problem, contact Tokyo Kelkii.

 Fluids which cannot be measured
 The presence of continuous and large amounts of bubbles in the fluid will greatly attenuate the accustic signal, cause missed measurements, or make measurement impossible. Even ultrasonic flowmeters employing the Doppier method which works better under such entrained bubble conditions compared to transit-time flowmeters also encounter missed measurements or are unable to make measurements when there is a continuous and large amount of bubbles contained in the fluid being measured.


## (2) Given measurement accuracy cannot be obtained - Check pipe specification.

- · Cause may also be attributable to changes in fluid cross sectional area due to pipe rust and scale and partially filled pipe conditions.




[Tokyo Kelki Inc. Profile]
Tokyo Kelki Inc.
2-16-46, Minami-Kamata, Ohta-Ku, Tokyo JAPAN
Phone:+81337378664
Fax:+81337378665
Email:overseas-sales03@tokyo-kelki.co.jp
Website:http://www.tokyo-kelki.co.jp/e/company.html
Contact person: Mr. Takayuki Shirakawa

# Water Flow Monitoring Operation Handbook -Admin Function-Delairee Assa Login - admin Water Flow Monitoring monitoring manage monitor setting




#### Stations - List




1

#### Stations - Details



6





#### Station - Sensors




if need to add new Water Flow meter, add new column. if need to change or delete Sensor, Edit or Delete.

8







7 - 34

#### Schedule Report Generation



Delairco Japan KK will add function and update the WFM Software within maintenance period.

Contact person:

Dlairco Japan : Kinya TODA (toda@delairco.com)

YCDC :\_\_\_\_\_

56

# Water Flow Monitoring Operation Handbook -Error Report -Report Function

Deteiree Ann

#### **Error Report**

#### What was happed

2019/9/20

WFM system ran "re-install" script, then all database were overwritten by incorrect version.

Delairco recover the database setting manually.

>> Browser was recovered but database is not created.

#### What was wrong

- 1. the system included inappropriate function which can work from local browser.
- 2. Backup data was able to be overwritten accidentally.

#### **Error Report**

### What Delairco have done to fix them

- 1. make inactive "re-install" script.
- 2. The backup policy is reviewed and longer retention options are available

  - Monthly retention of Daily Full backups
     Vearly retention of Monthly Full backups
     Daily retention of 2 hourly backups

all data (from start) will keep in HDD more than 10 years. (as calculated HDD volume)

#### Report Function

Daily Scheduled reporting is implemented for the purpose of data analysis by client. The reports cannot be deleted by client and can serve as backup as well.

Advise to client: Maintain copy of Reports outside of Water Flow Monitoring Server.

Annual data growth: 365 files per folder, total: 100MB.


File format: CSV (import in Excel or LibreOffice Calc)


Server folder and subfolders:

/home/wfycdc/Downloads/reports/ 5/05/u hiswgs1 hiswgs2 kokine naughnapin phugyi pyawbwesu shwedagon yegu

Contents format: Station code, Tx DateTime, 8V1 (V), CC1(V), TA1 (oC), WF1, ... WF6 (m3/hr) Example import in excel:

7 - 37





#### ② DUM Operation and Maintenance Manual 10 page

#### 3.2.4 (4) Off-load Data to USB flash memory

Allows the user to download the data log for further analysis. The data format is \*.cov and is compatible with Microsoft Excel and other spreadsheet applications.

The Filename Stream is < syrumdeF>.CSV e.g. 181029F,CSV




#### Storage Data

One unit of data: appx. 100 byte (6 sensors) Volume of Memory in DLM: 4Mbyte Sampling period: 5 min (288 times /day)

4M/(100 x288) =138 days

Stick the memory stick in the lower USB input of the DLM, upside down, Once you have relacted how exact to agG-load, type "Y" tot start off-load.

Important: Please check the devolvaded data file before erasing the log.



### Photo of OJT

1st: 28 June 2019





2<sup>nd</sup>: 13 July 2019





3<sup>rd</sup>: 15 July 2019






4th: 23 Aug. 2019





## 5<sup>th:</sup> 30 Oct. 2019





6<sup>th</sup>: 1<sup>st</sup> Nov.2019





### **OJT Participant list**

#### 1st: 28 June 2019 jica Tu To to Title: NHtm. Snic Flowmater Off (Yegu) Date: 28.6-2019 ( Fri) 2 craving bout Lin Yaequ Pemping Stotion 09250180221 AB 3 Daw Naw Eblinder Yegu Pumping Startion SAE 09450091518 Daw HoyThawTar Oo. Nyaunghnapin WTP Flat Ĭ\$. 09-979872950 5 U Aung Aung Nyaunghnapin WTP 9. 250 957 517 W. A cy 6 LL SOP Min Tun 8008001 SOE GNO Bya 09-78053880G 7 11 Sow william ayo Byth my 1.8: 1190 09799912906 BUSALAUNG PWINT PYAW BWESU NW800 M 80./81 09420041223 9 U Aung Moe Kyas Head Office. SAE 09250792934 10 Daw Naw Sox Eh Dor Hlawga Pumping Station Flat 108Epps8Fp0 11 saw E. Nyein Heay Yegu Pumping Station Ngin 1F180848FP0 Flat 12 D Bhone The Hoirs. Hlawgo Pomping Station 09.43094616 SAE jica TEC TO PE Organization/ Department Title/ Position Telephone/Mobile Signature Name cpipez) water and sanitation Leler 09-260999190 13 IL Zayor Win Htun Flot 15 19

#### 2<sup>nd</sup>: 13 July 2019 jica Tu a ga Delairco(OJT) Part. Date: 13/07/2019(Sat) Venue: Yegu Pumping Station Title/ Position 1 Naw Sor Eh Dav Hlawga Pumping Station 4 Ha 1,2 Flat 1088498861 2 Than Than Nive Hlawga Pumping Station incosons ener; The PP155995490 3 Mg Mg Zaw Yella Pumping station consumpling (19) 09420152404 4 Kyan That ಲ್ಲೆಯ 09794286493 5 Tin Mor Aye 09420038790 S.A.E 6 U Saw william Gyo Byon y ayo 1 306166660 26, 201.99w1500 " U SOE Min Tun Giro Byce 80 09720538226 206 8 U Kyaw Zin Os Puggi MA 09767279901 Pa. 1/2 wreaver Blats 6. 09799343400 9 U Sai Aung Paint Pyan Bue Su 09420041223 10 11 Zayor Win Houn 400G + KOK A'Ae-3 4600 09260999190 Her 19597966 16807 11 Daw Tin Far Lwin Yegu P/S Deputy Supervisor 4959264242825 <sup>12</sup> Daw Ei Nyein. Hbay Syan Flot 09784808171 Yegu P15 IICA Tu de ga Title: Delairco(OJT) Date: 13/07/2019(Sat) Venue: Yegu Pumping Station Name Organization/ Department Title/ Position Telephone/Mobile Signature 13 Daw Kyi Kyi Than Yegu PIS 09420152397 Lem 14 U Aung Mockyau Lary Head Office. 50€ 09250792934 15 Kinya Toda 16 DAW NYO NYO KHATNA 17 Dan Nan Ehinder Delairco Japan 095101331 DERECTOR, SCT ENGINGENG DIRECTOR Yegu Almping station S.A.E 09450091518 18 Yaquhilo Morita JICA Expert. JICA. Expert. 09-4584-96177 19 U Pyae Phyo Aung Nga moe Yeik WTP D.S 09-420000344 21 22 23 24

### 3<sup>rd</sup>: 15 July 2019



Tu a ga

Title: Delairco (OJT) Part 2 Date: 15/07/2019(Mon)

	Name	Department	Title/ Position	Telephone/Mobile	Signature
1	Dew Aye Ay Mar	Computer	ŧe.	09-51-84098	6 Fris
Z	V U		SHE	09250792939	, ta
3	U Ag Moe Kyan Dow Hrin las las Corn	Castomes Service	Flat	09-674577994	-6
4	Daw Ayo Nyo Khainp	SCT Engineering	Director	09-5101331	2h
5	U Hoin Haun	6,7,3 30chon	Flot	09-953168165	M
6	Dan Ret Het Myat	Design section	Flat	09.44250 2253	TI
7	Yasaha Morita	JLCA Expert	DLCA / TECI		学的
8					
9					
0					
11					

### 4th: 23 Aug. 2019



Tu a ?:

Date: 23/08/2019 (Fri) 1 Dan Br Zax Lush Departy Supervisor +959 26 9 29 2825 Yoga Pla 2 Daw Phyo Po Po Thet JICA Advisor Room flat Engineer 09422466146 Del Post 3 13 Hein Hton G.1.8 09-43168165 H. 4 Jan That Hot Mat Design Section 09-445402253 Total <sup>5</sup> Sacu El Ngein, Htag Yegu P19 1F180848F PO Agir. 6 U Aung Kyan linn 09791673648 615 7 Dan Huin lac Lac Win Contomer Service Section 09674577994 8 Daw Naw Ehinber Yegu Pumping Starting S.A.E 09450091518 9 Duny Mac Kyan Reserver. 09250792939

### 5th: 30 Oct. 2019



Tu a ga

<u>Title: Tokyo Keiki (OJT)</u>
Date: 30/10/2019 (Wed) 3:00 PM

	Name	Department	Title/ Position	Telephone/Mobile	Signature
1	Me Pin Far Lwin	Water Resources & Water Supply Authority, Jegu P/S	Deputy Supervisor	4959264242825	an
2	Me. Kyr Kyi Than	и	Flat	+959480158397	Les
3	· Mg Mg Tou.	Year Rumping station	Full worker - 5	+09420168464	Con.
4	Daw Naw Ehlander	Yegu Pumping Station	S. A.E	09 450091518	for
5	Daw Tin Moc Mye	Yegu Pumping station	S'A. E	09420038790	af
6	Aung Melya.	40DC.	30 E	09250792934	As
7	,				-
8					
9					
10			-		
11					
12					

### 6th: 1st Nov.2019



Tu a 🔐

Signature Title/ Position Telephone/Mobile Department Name 1 Mg. Pan For Luin Deputy Supervisor +959264242825 Yegu P13 and 2 Ms Kyi Kyi Thom +959480150897 3 Me E Nyern Htay Flat Ljun. 17808178FP7P+ 4 Me Hron las laction Customer Service Section 1969674677994 85 5 Daw Naw Ehlinder 4 Yegu Rimping Station 3.A.F 09450091518 6 Naw Sor Elo Dor Hlawga Pemping Station Flat So. 09782943801 7 Ye Zay Ya GIS FLAT 09795286322 400 8 hyen than Aung ENIS FLAT 09-969657902 As Sll 9 U Hein Htur G. I.3 FLAT 09-43168165 Hu 10 Daw Khine Cho Win Dasign Section FLAT 09-799498973 11 Daw HaytHoo Aug Khlu. Electrical Section FLAI 09. 42 1727525

Date: 1/11/2019 (Fri) 10:00AM

資料-8: 専門家派遣実績

						2017				_														_						20
氏名 (担当業務)	格付	╽┟	6	,	8	9	10	11	12	1		2	3	4	5	6	2018		8	9	10	11	12	1	-	2	3	4	5	6
佐藤 弘孝 総括/水道事業運営)	1	計画実績	(45) (11-6/24 7/16-7/	28 8/21	(31 8/31 9/1 (11) (13	) -9/13		(3	0) 12/10-12/22		2/18-	2/28 3/1-	(30) 3/4		5/21-5/30		(30)	8/20-8/	(31 9/1 (12) (1)	(30) 10/7-1 (13)	<u>/1</u> 9	1	(30) 2/12-12/25 (14)		2/19-2	/28 3/1-3	(30)	5/1	5-5/31 6/1	1-6/8
大野 教生  総括/水道事業計画・ モニタリング)	2	計画	(30)	(15)			(35)	-	(13)	(:	30)	(11) (4) 2/19-			(25)	-			(30)			30)		(:	30)	(10) (9)			(17) (8)	)
	<u> </u>	実績計画	/27-6/30 7/1-7/2 (4) (20)	(15)	8/31 9/1 (5) (16		10/23-10/27		(17)	1/10-1/16 (7)		(9) (15)	(5)(7)	(1-4/74/22- ) (6)	5/30-5/31	6/1-6/21	7/22-7/31	8/1-8/3 ) (B)	(19	22 10/3-1	/18		12/1-12/21 (21)	1/15-1/31 (17)	(1)		30)	5/2	28-5/31 6/1 (4) (2	20)
松井 庸司 (財務/経営)	3	実績	(30) /11-6/30 7/1-7/8 (20) (8)	(15)	9/2	(7)	(30) 10/1-10/21 (21)	11/26-	(30) 12/1-12/16 (16)		2/12-	(15) 2/28 3/1- (17) (10)	3/10			(30) 6/3-6/	)	8/19-8	(30) (31 9/1-9/ (13) (8)	8	11/25	-11/30	(30) 12/1-12/15 (15)		2/17-2	/28 3/1- (12) (9)	3/24-3/30 (7)		6/2	(30) 2- <b>6/22</b> (1)
斎藤 豊 客管理/料金徴収)	4	計画 実績	(28) (11-6/30 7/1-7/8 (20) (8)			(2		11/1-11/18	(25)		2/13-	2/28 3/1- (16) (9)	3/9		(7	7) 6/17-6/	3		(7)		11/25-1	11/30 1	(7) 2/1- 12/10- (2) (6)		2/24-2	/28 3/1-3 (5) (2)	1/2			
狩野 利夫 客管理/料金徴収)	4	計画実績	(20) (8)				(10)	110)				(10) (9)										(6)	2) (0)			28 3/1-3			6/2	2-6/15
岡田 明大 双水管理(物理的損	5	計画	(45) /10-6/30 7/1-7/2	2 9/26/	(30)			10/26-	(41)		(50)		1		(30)		7/20 7/21	0/1.0/1	(30)		10/31		(30)	1/9-1/31		(12) (9) /26- 3/1-	(30)		(35)	)
失)) 赤沼 正 以水管理(商業的損		実績計画	(21) (22) (45) /12-6/30 7/1-7/3		(6) (9 (30)	•	1	0/25- (53)		40)		2/25- 3/1- (4) (10)	3/10		5/8-5/31 (24)	(9)	7/30-7/31	2) (18)	(30	(4) (13)		-	12/2-12/22 (21)	(23)	(15)	(3) (	31) (14)		(31)	
失))	3	実績計画	(19) (30)	_	9/1	(15)	(7) (7)	(30)	30 12/1-12/1 (16)	6	2/1-2	/28 3/1	3/31	4/30	(31)	6/1-6/2	7/30-7/31 (2	8/1-8	/18	10/24-1	(8)	-11/30 (30)	12/1-12/22	1/9-1/31	(28)	3/1-3/20 8 (20)	3/27-3/31 4/1-4/ (5) (13)	/29-4/30 3 5/1-5/1 (2) (16	.6 5/28-5 <i>[2</i> ]	
岸田 晋輔 (GIS)	4	実績	(45) 6/20 6/23 (1) (1)		8/31 9/1	9/7-9/8	(45)	11/1-11/11		1/21-1/3	11) (20)	2/23- 3/1- (6) (6)	3/6		(30) 5/27-5/31 (5)	6/1-6/9			9/27-5	0) 9/30 10/1- (4)(10) (1	0/12-				2/17-2	/28 3/1-3 (12) (15)	/15			(34
寺嶋 勝彦 道施設運転維持管 理)	3	計画 実績	(30) 6/11-6/30 (20)	(20) 8/7-8	/26 9/1 0)	(30 8-9/30 1	10/1-10/4	11/13-	(30) 12/1-12/2	1/9-1/27	(21	n)	3/24		(30) 5/6-5/25	- 1	(20) 0 7/1-7/13 (6) (13)	8/13-8	/31 9/1	(3 10/1-10 (19)	19 11	/25-	(30) 12/1-12/14 (14)	1/21-1/31	(20)			5/6-		24-6/30 7
守田 康彦 (水質管理)	4	計画実績	(20) 6/11-6/26	(30)	(2)	2)	0/9-10/14	(30) 11/20-	12/1.12/5	(30) 1/21·1/3	31 2/1-2	(20	)		(20) 5/21-5/31 (11)		(30) 7/8-7/28		(19) (1)	10/1-1	(13 (13	(b)	(14)	(30) 1/15-1/26 (12)	(8)	(4) (14)	(20)		5/11 6	(30) i/S-6/30
山田 紹子	4	計画	(16)	7/21 9/1	9/11		10/10-10/21	(11)	(\$)	1/8-1/13		1 7	30)		(11)	) (9)				(13) (3 10/9-1	3)			(12)	2/20.2	-				(26)
道事業運営補助) 上岡 基眞 量計室設計施工支		実績計画	(8)	-7/31 8/1 (9) (11)			(12)			(6)	2/21	(8) (7)	3/1				7/10-7/25	1		10/9-1	6)				2/20-2	(9) (8)	1/8	5/1-	)	+
接)	3	実績			9)	10-9/17 (8)																								
スモン・ウィン	5	計画 実績	(30) (12-6/30 7/1-7/1 (19) (11)	1																										
紫藤 真由 8調整/水道事業計 モニタリング補助)	5	計画 実績							(30)											10/3-1		+	(30) 12/4-12/22 (19)	1/26-1/31	2/1- 2	/24. 3/1-3 (5)(9)	/9		(30)	-
																				(19)			(19)	(6)	(4)	(>)(h)				
日内業務 氏名 (担当業務)	格付				8	2017	10		12	<u> </u>		2					2018				10		12	L.				4		20
佐藤 弘孝 括/水道事業運営)	1	計画	(2) (3) (2)				10	11		(2)		2	3	4		(5)	(2)				10	11	12	(2)			3	4/22-4/23	5	Ì
+E 9/4	2	実績計画	7/3-7/4			(2)			(2) (2)	(2)							(2)							(2)				(2)		+
ハガ 秋王 括/水道事業計画・ モニタリング)		実績計画		25 8/4-5, (2) (2) (3						1/17-	(2)						(2)							(2)				4/22, 24-26	(2)	_
松井 庸司 (財務/経営)	3	実績	5) (2)	8/7-8/9 (2) (2) (3	8/22-8/23	9/5-9/6				1/25,	26,29,30						(2)							(2)						
狩野 利夫 学管理/料金徴収)	4	計画 実績								$\vdash$																			++	+
図田 明大 双水管理(物理的損 失))	5	計画	5) (2) 7/2	7-7/28			10/16-10/1	,	1/9	(2) 9 1/11, 1/ (3) (2	/15-1/16						(2)							(2)						
赤沼 正 双水管理(商業的損	3	計画	(2)	(2)						2)							(2)							(2)						
失))		実績計画	(2)				10/16-10/1			1/25-1	2)						(2)					+		(2)					++	+
岸田 晉輔 (GIS)	4	実績				10/	(2)			(2)																				
寺嶋 勝彦 道施設運転維持管 理)	3	計画 実績	(2) 7/3-7/- (2)	+	+					(2)							(2)							(2)	+					+
	_	計画	5) (2)			-			_	•	_	+	_		_	_	(2)	_	_	_		_		(2)	_	_		+	+	-

凡例: 業務従事実績 ※ 自社負担の人月数は合計から除く

山田 紹子 (水道事業運営補助) 福田 健一郎 (PPP) 工藤 陽作 (業務調整/水道事業計 面・モニタリング補助)

[注記] 以下のMM変更を反映している。 [注記] 1018年8月17日付け合士増・業務従事者間のM/M振り替えによる無替後のM/Mを反映している。 [注記] 2018年8月17日付け合士増・業務従事を目のM/M振り替えによる無替後のM/Mを反映している。 [注記] 2018年8月17日付き付金地買約の変更についてによる無替後のM/Mを反映している。 [注記] M/Mが変更となった第2回。第4回、第5回の変更契約を反映している。

業務計画書 ▲ ワークブラン △ 案△ 確定版 事業進捗/充了報告書 報告書等 △ 進捗報告書 △ 進捗報告書

