







29 26-2-2020 (Consumer Comments: low water pressure, use water by pumping)





30 24-10-2019(Consumer Comments: Pressure is very low and water quality problem)




31 29-10-2019(Consumer Comments: water not come whole day)





32 9-3-2020 (Consumer Comments: Low water pressure, not used daily due to low pressure)





33 5-3-2020 (Consumer Comments: disconnect water connection due to low pressure)





34 4-3-2020 (Consumer Comments: not using water due to low pressure and mixing with sewerage)




35 31-10-2019(Consumer Comments: Water pressure and water quality problem)




36 5-11-2019(Consumer Comments: Water has zero pressure)



Appendix7 References
(2) Results on Geotechnical Survey



LOCATION OF BH1 AND BH2











LOCATION OF BH3 AND BH4

FINITE ENGINEERING (PVT) LIMITED						BOREHOLE NO.		1															
PROJECT		Improvement of Water Treatment Plant and Water Distribution System, Faisalabad				TOTAL DEPTH		40 m															
LOCATION		Rakh Branch Canal, Abdullah Pur, Faisalabad				LOGGED		0.00 to 10.00 m															
TYPE OF BORING		Rotary				START		15-May-19															
						FINISH		16-May-19															
						NORTHING		73° 6' 49.95"															
						EASTING		31° 25' 31.20"															
PRELIMINARY BORING LOG																							
DEPTH (m)	TYPE OF SAMPLING	Recovery			Consistency	N - VALUE											DESCRIPTION	SOIL SYMBOL	REMARKS				
		Length (cm)	CR (%)	RQD (%)		NV	0	10	20	30	40	50	60	70	80								
1.00	SPT	-	-	-	SOFT	2	○											Sample washed out NB: (1)(1)(1)					
2.00	SPT	55			SOFT	2	○											(CL- ML) Brown to light Brown SILTY CLAY, soft, low Plasticity, moist NB: (1)(1)(1)					
3.00	UDS	-	-	-	-	-	●											-					
4.00	SPT	34			SOFT	3	○											(CL- ML) Brown to light Brown SILTY CLAY, soft, low Plasticity, moist NB: (1)(1)(2)					
5.00	UDS	-	-	-	-	-	●											-					
6.00	SPT	34			FIRM	8	○											(MC) Brown to light Brown CLAYEY SILT, firm, low Plasticity, moist NB: (2)(3)(5)					
7.00	SPT	32			LOOSE	7	○											(SM) Grey to light Grey, SILTY SANDS, medium to fine grained, loose, moist NB: (04)(03)(04)					
8.00	SPT	30			DENSE	37	○											(SW) Grey to light Grey Medium to Fine SANDS, dense, moist NB: (16)(17)(20)					
9.00	SPT	35			MEDIUM DENSE	30	○											(SW) Grey to light Grey Medium to Fine SANDS, medium dense, moist NB: (12)(15)(15)					
10.00	SPT	30			DENSE	33	○											(SW) Grey to light Grey, Medium to Fine SANDS, dense, moist NB: (12)(16)(17)					
CONTINUE NEXT PAGE																							
Type of Sampling				CONSISTENCY																			
	Standard Penetration Test (SPT)	- Sand		COHESIONLESS SOILS								COHESIVE SOILS											
	UDS	- Silty Sand		N-Value	Consistency	N-Value	Consistency																
		- Clay		0 - 4	Very Loose	0 - 2	Very Soft																
		- Silty Clay		4 - 10	Loose	2 - 4	Soft																
		- Silt		10 - 30	Medium Dense	4 - 8	Medium Stiff																
		- Clayey Silty		30 - 50	Dense	8 - 15	Stiff																
				> 50	Very Dense	15 - 30	Very Stiff																
						> 30	Hard																
NV	= N - Value	SW	= Sand	MC	= Clayey Silt	Prepared by:																	
NMC	= Natural Moisture Content	SM	= Silty Sand	Checked by:																			
RQD	= Rock Quality Designation	CL-ML	= Silty Clay	Certified by:																			
NB	= Number of Blows	ML	= Silt	Date Issued:																			
UDS	= Undisturbed Sampling	CL	= Clay																				
Description of strata is according to ASTM Classification																							

FINITE ENGINEERING (PVT) LIMITED						BOREHOLE NO.		1											
PROJECT		Improvement of Water Treatment Plant and Water Distribution System, Faisalabad				TOTAL DEPTH		40 m											
LOCATION		Rakh Branch Canal, Abdullah Pur, Faisalabad				LOGGED		10.00 to 20.00 m											
TYPE OF BORING		Rotary				START		15-May-19											
						FINISH		16-May-19											
						NORTHING		73° 6' 49.95"											
						EASTING		31° 25' 31.20"											
PRELIMINARY BORING LOG																			
DEPTH (m)	TYPE OF SAMPLING	Recovery			Consistency	N - VALUE						DESCRIPTION	SOIL SYMBOL	REMARKS					
		Length (cm)	CR (%)	RQD (%)		NV	0	10	20	30	40				50	60	70	80	
11.00	SPT	29			MEDIUM DENSE	26											(SW) Grey to light Grey, Medium to Fine SANDS , medium dense, moist NB: (11)(12)(14)		
12.00	UDS	-	-	-	-	-											-		
13.00	SPT	29			MEDIUM DENSE	30											(SW) Grey to light Grey, Medium to Fine SANDS , medium dense, moist NB: (09)(13)(17)		
14.00	SPT	26			DENSE	31											(SW) Grey to light Grey, Medium to Fine SANDS , dense, moist NB: (10)(14)(17)		
15.00	SPT	35			MEDIUM DENSE	13											(SM) Grey to light Grey, Fine grained, SILTY SANDS , medium dense, moist NB: (08)(06)(07)		
16.00	SPT	29			MEDIUM DENSE	28											(SW) Grey to light Grey, Medium to Fine SANDS , medium dense, moist NB: (09)(13)(15)		
17.00	UDS	-	-	-	-	-											-		
18.00	SPT	31			MEDIUM DENSE	30											(SW) Grey to light Grey, Medium to Fine SANDS , medium dense, moist NB: (12)(14)(16)		
19.00	SPT	28			DENSE	36											(SW) Grey to light Grey, Medium to Fine SANDS , dense, moist NB: (14)(16)(18)		
20.00	SPT	34			MEDIUM DENSE	30											(SW) Grey to light Grey, Medium to Fine SANDS , medium dense, moist NB: (15)(16)(14)		
CONTINUE NEXT PAGE																			
Type of Sampling				CONSISTENCY															
	Standard Penetration Test (SPT)	- Sand		COHESIONLESS SOILS			COHESIVE SOILS												
	uds	- Silty Sand		N-Value	Consistency	N-Value	Consistency												
		- Clay		0 - 4	Very Loose	0 - 2	Very Soft												
		- Silty Clay		4 - 10	Loose	2 - 4	Soft												
		- Silt		10 - 30	Medium Dense	4 - 8	Medium Stiff												
		- Silty		30 - 50	Dense	8 - 15	Stiff												
				> 50	Very Dense	15 - 30	Very Stiff												
						> 30	Hard												
NV	= N - Value	SW	= Sand	Prepared by:															
NMC	= Natural Moisture Content	SM	= Silty Sand	Checked by:															
RQD	= Rock Quality Designation	CL-ML	= Silty Clay	Certified by:															
NB	= Number of Blows	ML	= Silt	Date Issued:															
UDS	= Undisturbed Sampling	CL	= Clay																
Description of strata is according to ASTM Classification																			

FINITE ENGINEERING (PVT) LIMITED							BOREHOLE NO.		1										
PROJECT		Improvement of Water Treatment Plant and Water Distribution System, Faisalabad					TOTAL DEPTH		40 m		SHEET		3 of 4						
LOCATION		Rakh Branch Canal, Abdullah Pur, Faisalabad					LOGGED		20.00 to 30.00 m		GROUND LEVEL		186.54 m						
							START		17-May-19		WATER LEVEL		0.9 m						
TYPE OF BORING		Rotary					FINISH		18-May-19										
							NORTHING		73° 6' 49.95"		EASTING		31° 25' 31.20"						
PRELIMINARY BORING LOG																			
DEPTH (m)	TYPE OF SAMPLING	Recovery			Consistency	N - VALUE											DESCRIPTION	SOIL SYMBOL	REMARKS
		Length (cm)	CR (%)	RQD (%)		NV	0	10	20	30	40	50	60	70	80				
21.00	SPT	29			DENSE	33											(SW) Grey to light Grey, Medium to Fine SANDS, dense, moist NB: (14)(16)(17)		
22.00	UDS	-	-	-	-	-													
23.00	SPT	31			DENSE	36											(SW) Grey to light Grey, Medium to Fine SANDS, dense, moist NB: (17)(17)(19)		
24.00	SPT	42			DENSE	38											(SW), Grey to light Grey, Medium to Fine SANDS, medium dense, moist, (CL) Brown to light Brown CLAY of few centimeter NB: (20)(21)(17)		
25.00	SPT	39			DENSE	49											(SW) Grey to light Grey, Medium to Fine SANDS, dense, moist NB: (23)(24)(25)		
26.00	SPT	31			DENSE	46											(SW) Grey to light Grey, Medium to Fine SANDS, dense, moist NB: (22)(22)(24)		
27.00	UDS	-	-	-	-	-													
28.00	SPT	28			VERY DENSE	48											(SW) Grey to light Grey, Medium to Fine SANDS, very dense, moist NB: (21)(23)(25)		
29.00	SPT	24			VERY DENSE	50											(SW) Grey to light Grey, Medium to Fine SANDS, very dense, moist NB: (23)(24)(26)		
30.00	SPT	26			VERY DENSE	45											(SW) Grey to light Grey, Medium to Fine SANDS, very dense, moist NB: (23)(24)(21)		
CONTINUE NEXT PAGE																			
Type of Sampling				CONSISTENCY															
	Standard Penetration Test (SPT)	- Sand		COHESIONLESS SOILS				COHESIVE SOILS											
	UDS	- Silty Sand		N-Value	Consistency	N-Value	Consistency												
		- Clay		0 - 4	Very Loose	0 - 2	Very Soft												
		- Silty Clay		4 - 10	Loose	2 - 4	Soft												
		- Silt		10 - 30	Medium Dense	4 - 8	Medium Stiff												
		- Silty		30 - 50	Dense	8 - 15	Stiff												
				> 50	Very Dense	15 - 30	Very Stiff												
						> 30	Hard												
NV	= N - Value	SW	= Sand	Prepared by:															
NMC	= Natural Moisture Content	SM	= Silty Sand	Checked by:															
RQD	= Rock Quality Designation	CL-ML	= Silty Clay	Certified by:															
NB	= Number of Blows	ML	= Silt	Date Issued:															
UDS	= Undisturbed Sampling	CL	= Clay																
Description of strata is according to ASTM Classification																			


FINITE ENGINEERING (PVT) LIMITED							BOREHOLE NO.		1										
PROJECT		Improvement of Water Treatment Plant and Water Distribution System, Faisalabad					TOTAL DEPTH		40 m		SHEET		4 of 4						
LOCATION		Rakh Branch Canal, Abdullah Pur, Faisalabad					LOGGED		30.00 to 40.00 m		GROUND LEVEL		186.54 m						
TYPE OF BORING		Rotary					START		17-May-19		WATER LEVEL		0.9 m						
							FINISH		18-May-19										
							NORTHING		73° 6' 49.95"		EASTING		31° 25' 31.20"						
PRELIMINARY BORING LOG																			
DEPTH (m)	TYPE OF SAMPLING	Recovery			Consistency	N - VALUE											DESCRIPTION	SOIL SYMBOL	REMARKS
		Length (cm)	CR (%)	RQD (%)		NV	0	10	20	30	40	50	60	70	80				
31.00	SPT	35			DENSE	46											(SW) Grey to light Grey , Medium to Fine SANDS, dense, moist NB: (21)(23)(23)		
32.00	UDS	-	-	-	-	-													
33.00	SPT	27			DENSE	47											(SW) Grey to light Grey , Medium to Fine SANDS, dense, moist NB: (04)(22)(25)		
34.00	SPT	26			VERY DENSE	51											(SW) Grey to light Grey , Medium to Fine SANDS, very dense, moist NB: (22)(25)(26)		
35.00	SPT	25			VERY DENSE	55											(SW) Grey to light Grey , Medium to Fine SANDS, very dense, moist NB: (23)(27)(28)		
36.00	SPT	40			VERY DENSE	R											(SW) Grey to light Grey , Medium to Fine SANDS, very dense, moist NB: (35) (R)		
37.00	SPT	29			VERY DENSE	57											(SW) Grey to light Grey , Medium to Fine SANDS, very dense, moist NB: (12)(29)(28)		
38.00	SPT	31			VERY DENSE	67											(SW) Grey to light Grey , Medium to Fine SANDS, very dense, moist NB: (30)(31)(36)		
39.00	SPT	28			VERY DENSE	79											(SW) Grey to light Grey , Medium to Fine SANDS, very dense, moist NB: (35)(38)(41)		
40.00	SPT	26			VERY DENSE	84											(SW) Grey to light Grey , Medium to Fine SANDS, very dense, moist NB: (35)(41)(43)		
CONTINUE NEXT PAGE																			
Type of Sampling				CONSISTENCY															
	Standard Penetration Test (SPT)	- Sand		COHESIONLESS SOILS						COHESIVE SOILS									
	UDS	- Silty Sand		N-Value			Consistency			N-Value		Consistency							
		- Clay		0 - 4	Very Loose			0 - 2	Very Soft										
		- Silty Clay		4 - 10	Loose			2 - 4	Soft										
		- Silt		10 - 30	Medium Dense			4 - 8	Medium Stiff										
		- Silty		30 - 50	Dense			8 - 15	Stiff										
				> 50	Very Dense			15 - 30	Very Stiff										
								> 30	Hard										
NV	= N - Value	SW	= Sand	Prepared by:															
NMC	= Natural Moisture Content	SM	= Silty Sand	Checked by:															
RQD	= Rock Quality Designation	CL-ML	= Silty Clay	Certified by:															
NB	= Number of Blows	ML	= Silt	Date Issued:															
UDS	= Undisturbed Sampling	CL	= Clay																
Description of strata is according to ASTM Classification																			

FINITE ENGINEERING (PVT) LIMITED							BOREHOLE NO.		2										
PROJECT		Improvement of Water Treatment Plant and Water Distribution System, Faisalabad					TOTAL DEPTH		40 m		SHEET		1 of 4						
LOCATION		Rakh Branch Canal, Abdullah Pur, Faisalabad					LOGGED		0.00 to 10.00 m		GROUND LEVEL								
TYPE OF BORING		Rotary					START		17-May-19		WATER LEVEL		7 m						
							FINISH		18-May-19		NORTHING		73° 6' 48.96"						
											EASTING		31° 25' 31.35"						
PRELIMINARY BORING LOG																			
DEPTH (m)	TYPE OF SAMPLING	Recovery			Consistency	N - VALUE											DESCRIPTION	SOIL SYMBOL	REMARKS
		Length (cm)	CR (%)	RQD (%)		NV	0	10	20	30	40	50	60	70	80				
1.00	SPT	16			SOFT	3											(CL) Brown to light Brown CLAY, soft, lowly Plastic, moist NB: (1)(1)(2)		
2.00	SPT	20			SOFT	2											(CL) Brown to light Brown CLAY, soft, lowly Plastic, moist NB: (1)(1)(1)		
3.00	UDS	-	-	-	-	-											-		
4.00	SPT	30			FIRM	7											(CL-ML) Brown to light Brown Silty CLAY, firm, lowly Plastic, moist NB: (3)(3)(4)		
5.00	UDS	-	-	-	-	-											-		
6.00	SPT	27			STIFF	14											(CL-ML) Grey to light Grey Silty CLAY, stiff, lowly Plastic, moist NB: (5)(7)(7)		
7.00	SPT	32			MEDIUM DENSE	26											(SM) Grey to light Grey Silty SANDS, medium dense, moist NB: (06)(11)(15)		
8.00	SPT	36			DENSE	31											(SW) Grey to light Grey Medium to Fine SANDS, dense, moist NB: (12)(14)(17)		
9.00	SPT	32			DENSE	33											(SW) Grey to light Grey Fine SANDS, dense, moist NB: (12)(16)(17)		
10.00	SPT	25			MEDIUM DENSE	30											(SW) Grey to light Grey Fine SANDS, dense, moist NB: (11)(15)(15)		
CONTINUE NEXT PAGE																			
Type of Sampling				CONSISTENCY															
 Standard Penetration Test (SPT)  UDS	- Sand		COHESIONLESS SOILS				COHESIVE SOILS												
	- Silty Sand		N-Value	Consistency			N-Value	Consistency											
	- Clay		0 - 4	Very Loose			0 - 2	Very Soft											
	- Silty Clay		4 - 10	Loose			2 - 4	Soft											
	- Silt		10 - 30	Medium Dense			4 - 8	Medium Stiff											
	- Silty		30 - 50	Dense			8 - 15	Stiff											
		> 50	Very Dense			15 - 30	Very Stiff												
						> 30	Hard												
NV	= N - Value	SW	= Sand	Prepared by:															
NMC	= Natural Moisture Content	SM	= Silty Sand	Checked by:															
RQD	= Rock Quality Designation	CL-ML	= Silty Clay	Certified by:															
NB	= Number of Blows	ML	= Silt	Date Issued:															
UDS	= Undisturbed Sampling	CL	= Clay																
Description of strata is according to ASTM Classification																			

FINITE ENGINEERING (PVT) LIMITED							BOREHOLE NO.		2										
PROJECT		Improvement of Water Treatment Plant and Water Distribution System, Faisalabad					TOTAL DEPTH		40 m		SHEET		2 of 4						
LOCATION		Rakh Branch Canal, Abdullah Pur, Faisalabad					LOGGED		10.00 to 20.00 m		GROUND LEVEL								
TYPE OF BORING		Rotary					START		17-May-19		WATER LEVEL		7 m						
							FINISH		18-May-19										
							NORTHING		73° 6' 48.96"		EASTING		31° 25' 31.35"						
PRELIMINARY BORING LOG																			
DEPTH (m)	TYPE OF SAMPLING	Recovery			Consistency	N - VALUE											DESCRIPTION	SOIL SYMBOL	REMARKS
		Length (cm)	CR (%)	RQD (%)		NV	0	10	20	30	40	50	60	70	80				
11.00	SPT	29			MEDIUM DENSE	28											(SW) Grey to light Grey, Fine SANDS, medium dense, moist NB: (11)(13)(15)		
12.00	UDS	-	-	-	-	-													
13.00	SPT	26			DENSE	41											(SW) Grey to light Grey, Medium to Fine SANDS, dense, moist NB: (04)(19)(22)		
14.00	SPT	30			MEDIUM DENSE	28											(SW) Grey to light Grey, Medium to Fine SANDS, medium dense, moist NB: (11)(13)(15)		
15.00	SPT	29			DENSE	32											(SW) Grey to light Grey, Medium to Fine SANDS, dense, moist NB: (13)(15)(17)		
16.00	SPT	27			DENSE	33											(SW) Grey to light Grey, Medium to Fine SANDS, dense, moist NB: (15)(10)(17)		
17.00	UDS	-	-	-	-	-													
18.00	SPT	32			DENSE	32											(SW) Grey to light Grey, Medium to Fine SANDS, dense, moist NB: (13)(15)(17)		
19.00	SPT	28			DENSE	36											(SW) Grey to light Grey, Medium to Fine SANDS, dense, moist NB: (14)(17)(19)		
20.00	SPT	32			MEDIUM DENSE	34											(SW) Grey to light Grey, Medium to Fine SANDS, dense, moist NB: (10)(18)(16)		
CONTINUE NEXT PAGE																			
Type of Sampling				CONSISTENCY															
	Standard Penetration Test (SPT)	- Sand		COHESIONLESS SOILS						COHESIVE SOILS									
	uds	- Silty Sand		N-Value	Consistency					N-Value	Consistency								
		- Clay		0 - 4	Very Loose					0 - 2	Very Soft								
		- Silty Clay		4 - 10	Loose					2 - 4	Soft								
		- Silt		10 - 30	Medium Dense					4 - 8	Medium Stiff								
		- Silty		30 - 50	Dense					8 - 15	Stiff								
				> 50	Very Dense					15 - 30	Very Stiff								
										> 30	Hard								
NV	= N - Value	SW	= Sand	Prepared by:															
NMC	= Natural Moisture Content	SM	= Silty Sand	Checked by:															
RQD	= Rock Quality Designation	CL-ML	= Silty Clay	Certified by:															
NB	= Number of Blows	ML	= Silt	Date Issued:															
UDS	= Undisturbed Sampling	CL	= Clay																
Description of strata is according to ASTM Classification																			

FINITE ENGINEERING (PVT) LIMITED							BOREHOLE NO.		2										
PROJECT		Improvement of Water Treatment Plant and Water Distribution System, Faisalabad					TOTAL DEPTH		40 m		SHEET		3 of 4						
LOCATION		Rakh Branch Canal, Abdullah Pur, Faisalabad					LOGGED		20.00 to 30.00 m		GROUND LEVEL								
TYPE OF BORING		Rotary					START		17-May-19		WATER LEVEL		7 m						
							FINISH		18-May-19		NORTHING		73° 6' 48.96"						
							EASTING		31° 25' 31.35"										
PRELIMINARY BORING LOG																			
DEPTH (m)	TYPE OF SAMPLING	Recovery			Consistency	N - VALUE											DESCRIPTION	SOIL SYMBOL	REMARKS
		Length (cm)	CR (%)	RQD (%)		NV	0	10	20	30	40	50	60	70	80				
21.00	SPT	26			DENSE	37											(SW) Grey to light Grey, Medium to Fine SANDS, dense, moist NB: (15)(18)(19)		
22.00	UDS																		
23.00	SPT	31			DENSE	38											(SW) Grey to light Grey, Medium to Fine SANDS, dense, moist NB: (16)(18)(20)		
24.00	SPT	29			DENSE	41											(SW), Grey to light Grey, Medium to Fine SANDS, medium dense, moist, (CL) Brown to light Brown CLAY of few centimeter NB: (18)(19)(22)		
25.00	SPT	35			DENSE	46											(SW) Grey to light Grey, Medium to Fine SANDS, dense, moist NB: (20)(22)(24)		
26.00	SPT	31			DENSE	49											(SW) Grey to light Grey, Medium to Fine SANDS, dense, moist NB: (22)(23)(26)		
27.00	UDS																		
28.00	SPT	26			VERY DENSE	53											(SW) Grey to light Grey, Medium to Fine SANDS, very dense, moist NB: (24)(26)(27)		
29.00	SPT	33			VERY DENSE	56											(SW) Grey to light Grey, Medium to Fine SANDS, very dense, moist NB: (25)(27)(29)		
30.00	SPT	27			VERY DENSE	62											(SW) Grey to light Grey, Medium to Fine SANDS, very dense, moist NB: (27)(30)(32)		
CONTINUE NEXT PAGE																			
Type of Sampling				CONSISTENCY															
	Standard Penetration Test (SPT)	- Sand		COHESIONLESS SOILS						COHESIVE SOILS									
	UDS	- Silty Sand		N-Value	Consistency					N-Value	Consistency								
		- Clay		0 - 4	Very Loose					0 - 2	Very Soft								
		- Silty Clay		4 - 10	Loose					2 - 4	Soft								
		- Silt		10 - 30	Medium Dense					4 - 8	Medium Stiff								
		- Silty		30 - 50	Dense					8 - 15	Stiff								
				> 50	Very Dense					15 - 30	Very Stiff								
										> 30	Hard								
NV	= N - Value	SW	= Sand	Prepared by:															
NMC	= Natural Moisture Content	SM	= Silty Sand	Checked by:															
RQD	= Rock Quality Designation	CL-ML	= Silty Clay	Certified by:															
NB	= Number of Blows	ML	= Silt	Date Issued:															
UDS	= Undisturbed Sampling	CL	= Clay																
Description of strata is according to ASTM Classification																			


FINITE ENGINEERING (PVT) LIMITED							BOREHOLE NO.		2										
PROJECT		Improvement of Water Treatment Plant and Water Distribution System, Faisalabad					TOTAL DEPTH		40 m		SHEET		4 of 4						
LOCATION		Rakh Branch Canal, Abdullah Pur, Faisalabad					LOGGED		30.00 to 40.00 m		GROUND LEVEL								
TYPE OF BORING		Rotary					START		17-May-19		WATER LEVEL		7 m						
							FINISH		18-May-19										
							NORTHING		73° 6' 48.96"		EASTING		31° 25' 31.35"						
PRELIMINARY BORING LOG																			
DEPTH (m)	TYPE OF SAMPLING	Recovery			Consistency	N - VALUE											DESCRIPTION	SOIL SYMBOL	REMARKS
		Length (cm)	CR (%)	RQD (%)		NV	0	10	20	30	40	50	60	70	80				
31.00	SPT	29			VERY DENSE	61											(SW) Grey to light Grey , Medium to Fine SANDS, very dense, moist NB: (26)(29)(32)		
32.00	SPT	32				63											(SW) Grey to light Grey , Medium to Fine SANDS, very dense, moist NB: (26)(30)(33)		
33.00	SPT	29			VERY DENSE	56											(SW) Grey to light Grey , Medium to Fine SANDS, very dense, moist NB: (20)(27)(29)		
34.00	SPT	29			VERY DENSE	58											(SW) Grey to light Grey , Medium to Fine SANDS, very dense, moist NB: (22)(27)(31)		
35.00	SPT	26			VERY DENSE	67											(SW) Grey to light Grey , Medium to Fine SANDS, very dense, moist NB: (29)(32)(35)		
36.00	UDS	-	-	-	-	-											-		
37.00	SPT	29				55											(SW) Grey to light Grey , Medium to Fine SANDS, very dense, moist NB: (25)(26)(29)		
38.00	SPT	26			VERY DENSE	56											(SW) Grey to light Grey , Medium to Fine SANDS, very dense, moist NB: (16)(27)(29)		
39.00	SPT	31			VERY DENSE	66											(SW) Grey to light Grey , Medium to Fine SANDS, very dense, moist NB: (8)(32)(34)		
40.00	SPT	27			VERY DENSE	73											(SW) Grey to light Grey , Medium to Fine SANDS, very dense, moist NB: (29)(35)(38)		
CONTINUE NEXT PAGE																			
Type of Sampling				CONSISTENCY															
	Standard Penetration Test (SPT)	- Sand		COHESIONLESS SOILS						COHESIVE SOILS									
	UDS	- Silty Sand		N-Value		Consistency				N-Value		Consistency							
		- Clay		0 - 4		Very Loose				0 - 2		Very Soft							
		- Silty Clay		4 - 10		Loose				2 - 4		Soft							
		- Silt		10 - 30		Medium Dense				4 - 8		Medium Stiff							
		- Silty		30 - 50		Dense				8 - 15		Stiff							
				> 50		Very Dense				15 - 30		Very Stiff							
										> 30		Hard							
NV	= N - Value	SW	= Sand	Prepared by:															
NMC	= Natural Moisture Content	SM	= Silty Sand	Checked by:															
RQD	= Rock Quality Designation	CL-ML	= Silty Clay	Certified by:															
NB	= Number of Blows	ML	= Silt	Date Issued:															
UDS	= Undisturbed Sampling	CL	= Clay																
Description of strata is according to ASTM Classification																			

FINITE ENGINEERING (PVT) LIMITED							BOREHOLE NO.		3											
PROJECT		Improvement of Water Treatment Plant and Water Distribution System, Faisalabad					TOTAL DEPTH		5 m		SHEET		1 of 1							
LOCATION		Old Jhal Khanuana Water Treatment Plant					LOGGED		0.00 to 5.00 m		GROUND LEVEL		181.25 m							
TYPE OF BORING		Rotary					START		19-May-19		FINISH		19-May-19							
							NORTHING		73° 5' 32.87"		EASTING		31° 24' 36.78"							
PRELIMINARY BORING LOG																				
DEPTH (m)	TYPE OF SAMPLING	Recovery			Consistency	N - VALUE											DESCRIPTION	SOIL SYMBOL	REMARKS	
		Length (cm)	CR (%)	RQD (%)		NV	0	10	20	30	40	50	60	70	80					
1.00	SPT	28			MEDIUM DENSE	18												(SM) Grey to light Grey, Fine to very Fine grained, SILTY SANDS, medium dense NB: (05)(08)(10)		
2.00	SPT	-	-	-	-	-														
3.00	UDS	30			MEDIUM DENSE	21												(SM) Grey to light Grey, Fine to very Fine grained, SILTY SANDS, medium dense NB: (08)(09)(12)		
4.00	SPT	-	-	-	-	-														
5.00	UDS	26			MEDIUM DENSE	29												(SW) Grey to light Grey, Fine to very Fine grained, SANDS, medium dense NB: (09)(14)(15)		
Type of Sampling					CONSISTENCY															
					COHESIONLESS SOILS						COHESIVE SOILS									
					N-Value			Consistency			N-Value			Consistency						
0 - 4			Very Loose			0 - 2			Very Soft											
4 - 10			Loose			2 - 4			Soft											
10 - 30			Medium Dense			4 - 8			Medium Stiff											
30 - 50			Dense			8 - 15			Stiff											
> 50			Very Dense			15 - 30			Very Stiff											
						> 30			Hard											
NV = N - Value					SW = Sand					MC = Clayey Silt			Prepared by:							
NMC = Natural Moisture Content					SM = Silty Sand					Checked by:										
RQD = Rock Quality Designation					CL-ML = Silty Clay					Certified by:										
NB = Number of Blows					ML = Silt					Date Issued:										
UDS = Undisturbed Sampling					CL = Clay															
Description of strata is according to ASTM Classification																				

FINITE ENGINEERING (PVT) LIMITED						BOREHOLE NO.		4																																											
PROJECT		Improvement of Water Treatment Plant and Water Distribution System, Faisalabad				TOTAL DEPTH		5 m																																											
LOCATION		Old Jhal Khanuana Water Treatment Plant				LOGGED		0.00 to 5.00 m																																											
TYPE OF BORING		Rotary				START		19-May-19																																											
						FINISH		19-May-19																																											
						NORTHING		73° 5' 29.46"																																											
						EASTING		31° 24' 34.78"																																											
PRELIMINARY BORING LOG																																																			
DEPTH (m)	TYPE OF SAMPLING	Recovery			Consistency	N - VALUE											DESCRIPTION	SOIL SYMBOL	REMARKS																																
		Length (cm)	CR (%)	RQD (%)		NV	0	10	20	30	40	50	60	70	80																																				
1.00	SPT	27	-	-	MEDIUM DENSE	14												(SM) Grey to light Grey, Fine to very Fine grained, SILTY SANDS, medium dense NB: (04)(07)(07)																																	
2.00	SPT	-	-	-	-	-																																													
3.00	UDS	28	-	-	MEDIUM DENSE	26												(SM) Grey to light Grey, Fine to very Fine grained, SILTY SANDS, medium dense NB: (08)(12)(14)																																	
4.00	UDS	-	-	-	-	-																																													
5.00	SPT	35	-	-	MEDIUM DENSE	30												(SW) Grey to light Grey, Fine to very Fine grained, SANDS, medium dense NB: (10)(14)(16)																																	
Type of Sampling					CONSISTENCY																																														
					<table border="1"> <thead> <tr> <th colspan="2">COHESIONLESS SOILS</th> <th colspan="2">COHESIVE SOILS</th> </tr> <tr> <th>N-Value</th> <th>Consistency</th> <th>N-Value</th> <th>Consistency</th> </tr> </thead> <tbody> <tr> <td>0 - 4</td> <td>Very Loose</td> <td>0 - 2</td> <td>Very Soft</td> </tr> <tr> <td>4 - 10</td> <td>Loose</td> <td>2 - 4</td> <td>Soft</td> </tr> <tr> <td>10 - 30</td> <td>Medium Dense</td> <td>4 - 8</td> <td>Medium Stiff</td> </tr> <tr> <td>30 - 50</td> <td>Dense</td> <td>8 - 15</td> <td>Stiff</td> </tr> <tr> <td>> 50</td> <td>Very Dense</td> <td>15 - 30</td> <td>Very Stiff</td> </tr> <tr> <td></td> <td></td> <td>> 30</td> <td>Hard</td> </tr> </tbody> </table>															COHESIONLESS SOILS		COHESIVE SOILS		N-Value	Consistency	N-Value	Consistency	0 - 4	Very Loose	0 - 2	Very Soft	4 - 10	Loose	2 - 4	Soft	10 - 30	Medium Dense	4 - 8	Medium Stiff	30 - 50	Dense	8 - 15	Stiff	> 50	Very Dense	15 - 30	Very Stiff			> 30	Hard
COHESIONLESS SOILS		COHESIVE SOILS																																																	
N-Value	Consistency	N-Value	Consistency																																																
0 - 4	Very Loose	0 - 2	Very Soft																																																
4 - 10	Loose	2 - 4	Soft																																																
10 - 30	Medium Dense	4 - 8	Medium Stiff																																																
30 - 50	Dense	8 - 15	Stiff																																																
> 50	Very Dense	15 - 30	Very Stiff																																																
		> 30	Hard																																																
NV = N - Value					SW = Sand					MC = Clayey Silt					Prepared by:																																				
NMC = Natural Moisture Content					SM = Silty Sand										Checked by:																																				
RQD = Rock Quality Designation					CL-ML = Silty Clay										Certified by:																																				
NB = Number of Blows					ML = Silt										Date Issued:																																				
UDS = Undisturbed Sampling					CL = Clay																																														
Description of strata is according to ASTM Classification																																																			

Table 6: Summary of Laboratory Results

BH No.	Depth (m)	Sample	NMC (%)	Specific G _s	Bulk (kN/m ³)	Particle Size Distribution			Particle Size Distribution			Direct Share Test	
						Gravel (%)	Sand (%)	Silt & Clay (%)	L.L. (%)	P.L. (%)	P.I	Cohesion (kPa)	Angle of internal Friction
BH-1	1	1 (DS)	19.3	2.68	-	0	11	89	-	-	-	-	-
	3	29 (UDS)	27.3	2.67	19.3	0	9	91	29	20	9	-	-
	5	30 (UDS)	22	2.68	20	0	10	90	27	20	7	-	-
	10	2 (DS)	14	2.65	-	0	96	4	-	-	-	-	-
	12	15 (UDS)	-	-	17.3	-	-	-	-	-	-	1.4	29
	17	16 (UDS)	-	-	17.9	-	-	-	-	-	-	0.8	30
	20	3 (DS)	10.6	2.66	-	0	97	3	-	-	-	-	-
	22	17 (UDS)	-	-	16.7	-	-	-	-	-	-	1	31
	27	18 (UDS)	-	-	18.1	-	-	-	-	-	-	0.9	32
	32	19 (UDS)	-	-	17.2	-	-	-	-	-	-	1.1	32
BH-2	40	4 (DS)	28.3	2.67	-	0	97	3	-	-	-	-	-
	1	5 (DS)	17.3	2.68	-	26	23	51	-	-	-	-	-
	3	31 (UDS)	17	2.67	18.4	0	12	88	25	20	5	-	-
	5	32 (UDS)	14.1	2.69	19.6	12	7	81	28	20	8	-	-
	10	6 (DS)	13.6	2.67	-	0	96	4	-	-	-	-	-
	12	20 (UDS)	-	-	17.3	-	-	-	-	-	-	0.4	29
	17	21 (UDS)	-	-	16.2	-	-	-	-	-	-	0.8	30
	20	7 (DS)	22.7	2.65	-	0	97	3	-	-	-	-	-
	22	22 (UDS)	-	-	17.6	-	-	-	-	-	-	1.1	32
	27	23 (UDS)	-	-	16.6	-	-	-	-	-	-	0.4	32
BH-3	36	24 (UDS)	-	-	16.9	-	-	-	-	-	-	1.2	33
	40	8 (DS)	20.1	2.66	-	12	68	20	-	-	-	-	-
	1	9 (DS)	4.7	2.69	-	0	93	7	-	-	-	-	-
	2	25 (UDS)	-	-	16	-	-	-	-	-	-	1.8	27
	3	10 (DS)	5.8	2.65	-	0	89	11	-	-	-	-	-
	4	26 (UDS)	-	-	16.6	-	-	-	-	-	-	1.6	29
	5	11 (DS)	4.8	2.66	-	0	93	7	-	-	-	-	-
	1	12 (DS)	10.1	2.67	-	0	92	8	-	-	-	-	-
	2	27 (UDS)	-	-	16.1	-	-	-	-	-	-	1.6	28
	BH-4	3	13 (DS)	6.1	2.66	-	0	95	5	-	-	-	-
4		86 (UDS)	-	-	16.1	-	-	-	-	-	-	1.4	29
5		14 (DS)	4.7	2.67	-	1	92	7	-	-	-	-	-



ECOS Ltd.; GEOTECHNICAL SERVICES

BORE HOLE LOG		Location: WTP- Jhal							Project: WASA Master Plan																																														
		Bore Hole No.: 01							Fig No.																																														
		Type of Boring: Rotary							Date Started: 30-11-17																																														
		Termination Depth: 40 m							Date Completed: 02-12-17																																														
		Ground Water Table: 3 m							Logger: Umer																																														
Depth(m)	Sample Description	Classification Symbol	Legend	Sample Type	Moisture	Penetration Values			N-Values	N- Profile	Recovery			Remarks																																									
						150 mm	150 mm	150 mm			SPT (cm)	CR %	RQD %																																										
2	clay	CL		DS		1	1	1	2	<table border="1"> <caption>N-Profile Data</caption> <thead> <tr> <th>Depth (m)</th> <th>SPT (cm)</th> </tr> </thead> <tbody> <tr><td>2</td><td>29</td></tr> <tr><td>4</td><td>27</td></tr> <tr><td>6</td><td>30</td></tr> <tr><td>8</td><td>23</td></tr> <tr><td>10</td><td>36</td></tr> <tr><td>12</td><td>33</td></tr> <tr><td>14</td><td>34</td></tr> <tr><td>16</td><td>36</td></tr> <tr><td>18</td><td>40</td></tr> <tr><td>20</td><td>38</td></tr> <tr><td>22</td><td>40</td></tr> <tr><td>24</td><td>40</td></tr> <tr><td>26</td><td>25</td></tr> <tr><td>28</td><td>30</td></tr> <tr><td>30</td><td></td></tr> <tr><td>32</td><td>27</td></tr> <tr><td>34</td><td>35</td></tr> <tr><td>36</td><td>28</td></tr> <tr><td>38</td><td></td></tr> <tr><td>40</td><td></td></tr> </tbody> </table>	Depth (m)	SPT (cm)	2	29	4	27	6	30	8	23	10	36	12	33	14	34	16	36	18	40	20	38	22	40	24	40	26	25	28	30	30		32	27	34	35	36	28	38		40				
Depth (m)	SPT (cm)																																																						
2	29																																																						
4	27																																																						
6	30																																																						
8	23																																																						
10	36																																																						
12	33																																																						
14	34																																																						
16	36																																																						
18	40																																																						
20	38																																																						
22	40																																																						
24	40																																																						
26	25																																																						
28	30																																																						
30																																																							
32	27																																																						
34	35																																																						
36	28																																																						
38																																																							
40																																																							
4	Silty clay	CL-ML		DS		1	1	2	3																																														
6	Silty sand	SM		DS		5	9	9	18																																														
8	Fine graind sand	SW		DS		8	11	12	23																																														
10	do	SW		DS		8	10	14	24																																														
12	do	SW		DS		9	11	12	23																																														
14	do	SW		DS		10	14	19	33																																														
16	do	SW		DS		18	22	23	45																																														
18	do	SW		DS		10	12	15	27																																														
20	do	SW		DS		17	20	18	38																																														
22	do	SW		DS		12	10	10	20																																														
24	do	SW		DS		12	12	21	33																																														
26	Silty clay	CL-ML		DS		9	13	27	40																																														
28	Silty sand	SM		DS		10	14	27	41																																														
30	Medium graind sand	SW		DS		11	19	20	39																																														
32	do	SW		DS		11	26	45	71																																														
34	do	SW		DS		13	27	50	77																																														
36	Med-course sand	SW		DS		14	28	50	78																																														
38	do	SW		DS		20	26	38	64																																														
40	do	SW		DS		30	36	50	86																																														

Checked By: _____

ECOS Ltd.; GEOTECHNICAL SERVICES

BORE HOLE LOG		Location: WTP- Jhal				Project: WASA Master Plan																																																	
		Bore Hole No.: 02				Fig No.																																																	
		Type of Boring: Rotary				Date Started: 03-12-2017																																																	
		Termination Depth: 40 m				Date Completed: 04-12-17																																																	
		Ground Water Table: 10 m				Logger: Umer																																																	
Depth(m)	Sample Description	Classification Symbol	Legend	Sample Type	Moisture	Penetration Values			N-Values	N- Profile	Recovery			Remarks																																									
						150 mm	150 mm	150 mm			SPT (cm)	CR %	RQD %																																										
2	clay	CL		DS		5	5	7	12	<table border="1"> <caption>N-Profile Data</caption> <thead> <tr> <th>Depth (m)</th> <th>SPT (cm)</th> </tr> </thead> <tbody> <tr><td>2</td><td>39</td></tr> <tr><td>4</td><td>33</td></tr> <tr><td>6</td><td>36</td></tr> <tr><td>8</td><td>30</td></tr> <tr><td>10</td><td>29</td></tr> <tr><td>12</td><td>30</td></tr> <tr><td>14</td><td>31</td></tr> <tr><td>16</td><td>35</td></tr> <tr><td>18</td><td>34</td></tr> <tr><td>20</td><td>30</td></tr> <tr><td>22</td><td>22</td></tr> <tr><td>24</td><td>25</td></tr> <tr><td>26</td><td>32</td></tr> <tr><td>28</td><td>27</td></tr> <tr><td>30</td><td>39</td></tr> <tr><td>32</td><td>28</td></tr> <tr><td>34</td><td>38</td></tr> <tr><td>36</td><td>28</td></tr> <tr><td>38</td><td>25</td></tr> <tr><td>40</td><td>14</td></tr> </tbody> </table>	Depth (m)	SPT (cm)	2	39	4	33	6	36	8	30	10	29	12	30	14	31	16	35	18	34	20	30	22	22	24	25	26	32	28	27	30	39	32	28	34	38	36	28	38	25	40	14			
Depth (m)	SPT (cm)																																																						
2	39																																																						
4	33																																																						
6	36																																																						
8	30																																																						
10	29																																																						
12	30																																																						
14	31																																																						
16	35																																																						
18	34																																																						
20	30																																																						
22	22																																																						
24	25																																																						
26	32																																																						
28	27																																																						
30	39																																																						
32	28																																																						
34	38																																																						
36	28																																																						
38	25																																																						
40	14																																																						
4	Silty clay	CL-ML		DS		5	6	8	14																																														
6	Silty sand	SM		DS		6	7	11	18																																														
8	Fine graind sand	SW		DS		8	13	14	27																																														
10	do	SW		DS		9	11	13	24																																														
12	do	SW		DS		9	11	16	28																																														
14	do	SW		DS		10	14	16	30																																														
16	do	SW		DS		25	30	31	61																																														
18	do	SW		DS		20	24	25	49																																														
20	do	SW		DS		17	25	29	54																																														
22	do	SW		DS		15	16	16	32																																														
24	do	SW		DS		16	18	20	38																																														
26	do	SW		DS		8	17	25	42																																														
28	Clay	CL		DS		15	14	31	45																																														
30	Medium graind sand	SW		DS		16	19	26	45																																														
32	do	SW		DS		18	21	24	45																																														
34	do	SW		DS		22	26	28	54																																														
36	Med-course sand	SW		DS		25	30	35	65																																														
38	do	SW		DS		30	45	40	75																																														
40	do	SW		DS		40	40	50	90																																														

Checked By: _____

ECOS Ltd.; GEOTECHNICAL SERVICES

BORE HOLE LOG	Location: WTP- Jhal	Project: WASA Master Plan
	Bore Hole No.: 03	Fig No.
	Type of Boring: Rotary	Date Started: 05-12-2017
	Termination Depth: 40 m	Date Completed: 06-12-2017
	Ground Water Table: 20.6 m	Logger: Umer

Depth(m)	Sample Description	Classification Symbol	Legend	Sample Type	Moisture	Penetration Values			N-Values	N- Profile	Recovery			Remarks
						150 mm	150 mm	150 mm			SPT (cm)	CR %	RQD %	
2	clay	CL		DS		2	3	4	7		30			
4	Silty Sand	SM		DS		2	6	10	16		20			
6	Silty sand	SM		DS		8	11	12	23		32			
8	Fine graind sand	SW		DS		10	12	15	27		29			
10	do	SW		DS		12	18	20	38		27			
12	do	SW		DS		12	17	22	39		29			
14	do	SW		DS		22	32	35	67		35			
16	do	SW		DS		17	17	29	37		35			
18	do	SW		DS		11	14	18	32		32			
20	do	SW		DS		22	26	23	39		32			
22	do	SW		DS		15	18	21	39		32			
24	do	SW		DS		15	19	21	40		30			
26	do	SW		DS		15	20	35	55		28			
28	Silty sand	SM		DS		23	30	32	62		35			
30	Medium graind sand	SW		DS		19	29	38	67		33			
32	do	SW		DS		14	38	50	88		30			
34	do	SW		DS		20	29	30	59		32			
36	Med-course sand	SW		DS		11	36	50	88		40			
38	do	SW		DS		20	39	50	89		35			
40	do	SW		DS		12	30	50	80		38			

Checked By: _____

ECOS Ltd.; GEOTECHNICAL SERVICES

BORE HOLE LOG	Location: WTP- Jhal	Project: WASA Master Plan
	Bore Hole No.: 04	Fig No.
	Type of Boring: Rotary	Date Started: 07-12-2017
	Termination Depth: 40 m	Date Completed: 08-12-17
	Ground Water Table: 20.60 m	Logger: Umer

Depth(m)	Sample Description	Classification Symbol	Legend	Sample Type	Moisture	Penetration Values			N-Values	N- Profile	Recovery			Remarks	
						150 mm	150 mm	150 mm			SPT (cm)	CR %	RQD %		
2	clay	CL	Orange	DS		4	9	10	19		35				
4	Silty clay	CL		DS		5	9	12	21		39				
6	Silty sand	SM	Grey	DS		10	10	13	23		33				
8	Fine graind sand	SW		DS		7	11	12	23		30				
10	do	SW		DS		9	14	16	30		33				
12	do	SW		DS		11	14	15	29		33				
14	do	SW		DS		9	16	19	35		28				
16	do	SW		DS		13	15	15	30		34				
18	do	SW		DS		11	13	16	29		38				
20	do	SW		DS		17	17	15	32		28				
22	do	SW		DS		11	14	16	30		32				
24	do	SW		DS		18	21	23	44		35				
26	Silty clay	CL		Orange	DS		10	35	34		69	31			
28	Silty sand	SM		Grey	DS		24	27	36		63	32			
30	Medium graind sand	SW	DS			25	34	39	73		28				
32	do	SW	DS			11	27	35	62		25				
34	do	SW	DS			25	29	37	66		33				
36	Med-course sand	SW	DS			27	30	28	58		25				
38	do	SW	DS			25	30	31	61		33				
40	do	SW	DS			19	18	24	42		34				

Checked By: _____

ECOS Ltd.; GEOTECHNICAL SERVICES

BORE HOLE LOG	Location: Abdullah Pur OHR	Project: WASA Master Plan
	Bore Hole No.: 05	Fig No.
	Type of Boring: Rotary	Date Started: 10-12-2017
	Termination Depth: 40 m	Date Completed: 11-12-2017
	Ground Water Table: 19 m	Logger: Umer

Depth(m)	Sample Description	Classification Symbol	Legend	Sample Type	Moisture	Penetration Values			N-Values	N- Profile	Recovery			Remarks
						150 mm	150 mm	150 mm			SPT (cm)	CR %	RQD %	
												0 20 40 60 80 100		
2	Silty clay	CL-ML		DS		3	2	4	6		30			
4	Silty Sand	SM		DS		5	6	8	14		34			
6	Silty sand	SM		DS		8	12	14	26		32			
8	Fine graind sand	SW		DS		10	13	16	29		34			
10	do	SW		DS		11	13	12	25		30			
12	do	SW		DS		13	15	19	34		29			
14	do	SW		DS		20	22	23	45		30			
16	Claye Silt	ML		DS		16	19	21	40		35			
18	Fine graind sand	SW		DS		10	17	19	36		35			
20	do	SW		DS		7	14	27	41		33			
22	do	SW		DS		9	15	30	45		22			
24	do	SW		DS		14	22	16	38		38			
26	Silty clay	CL-ML		DS		4	15	26	41		25			
28	Silty sand	SM		DS		18	20	24	44		34			
30	Medium graind sand	SW		DS		14	15	22	37		29			
32	do	SW		DS		13	40	50	90		25			
34	do	SW		DS		10	20	39	59		29			
36	Med-course sand	SW		DS		12	33	29	62		32			
38	do	SW		DS		19	26	33	63		28			
40	do	SW		DS		30	45	50	95		32			

Checked By: _____

ECOS Ltd.; GEOTECHNICAL SERVICES

BORE HOLE LOG	Location: Madina Town OHR NO.2	Project: WASA Master Plan
	Bore Hole No.: 06	Fig No.
	Type of Boring: Rotary	Date Started: 13-12-2017
	Termination Depth: 40 m	Date Completed: 14-12-2017
	Ground Water Table: 17	Logger: Umer

Depth(m)	Sample Description	Classification Symbol	Legend	Sample Type	Moisture	Penetration Values			N-Values	N- Profile	Recovery			Remarks
						150 mm	150 mm	150 mm			SPT (cm)	CR %	RQD %	
2	clay	CL		DS		4	5	7	12		25			
4	Clayey Silt	ML		DS		5	7	10	17		30			
6	Silty sand	SM		DS		11	14	16	30		35			
8	Silty sand	SM		DS		10	16	17	33		22			
10	Fine graind sand	SW		DS		9	10	12	22		31			
12	do	SW		DS		15	15	21	36		33			
14	do	SW		DS		11	14	18	32		28			
16	do	SW		DS		15	10	22	32		30			
18	do	SW		DS		15	17	21	38		30			
20	do	SW		DS		13	17	18	35		28			
22	do	SW		DS		9	29	45	74		27			
24	do	SW		DS		22	34	35	69		33			
26	do	SW		DS		12	18	35	53		27			
28	do	SW		DS		18	28	37	65		27			
30	Medium graind sand	SW		DS		20	31	42	73		35			
32	do	SW		DS		30	41	50	91		35			
34	do	SW		DS		29	42	47	89		48			
36	Med-course sand	SW		DS		30	37	49	86		28			
38	do	SW		DS		30	33	35	68		26			
40	do	SW		DS		32	35	40	75		22			

Checked By: _____



SUMMARY OF THE TEST RESULTS

Project: Geotechnical Investigation for WASA Master Plan, Faisalabad

Client: M/S ECOS Ltd

BH/ TP No.	Sample No	Depth (m)	NMC (%)	Bulk Density (kN/m ³)	Specific Gravity G _s
BH-01	1 (UDS)	1	21.68	19.21	2.7
	2 (UDS)	7	25.05	18.64	2.67
	3 (UDS)	14	17.96	14.55	2.65
	4 (UDS)	19	18.27	16.08	2.67
	5 (UDS)	25	24.24	20.55	2.65
	6 (UDS)	30	23.88	15.74	2.66
	7 (UDS)	35	25.17	13.48	2.69
	8 (UDS)	40	17.67	15.90	2.68
BH-02	9 (UDS)	3	9.61	20.48	2.7
	10 (UDS)	7	7.50	18.93	2.67
	11 (UDS)	15	7.32	16.97	2.67
	12 (UDS)	20	4.32	16.31	2.66
	13 (UDS)	25	17.34	19.79	2.65
	14 (UDS)	30	27.66	18.30	2.67
	15 (UDS)	35	14.41	12.48	2.67
	16 (UDS)	40	19.27	18.44	2.65



Prepared by:


SUMMARY OF THE TEST RESULTS

Project: Geotechnical Investigation for WASA Master Plan, Faisalabad

Client: M/S ECOS Ltd

BH/ TP No.	Sample No	Depth (m)	NMC (%)	Bulk Density (kN/m ³)	Specific Gravity G _s
BH-03	17 (UDS)	5	2.37	16.54	2.66
	18 (UDS)	11	7.22	20.71	2.67
	19 (UDS)	15	9.19	17.99	2.67
	20 (UDS)	21	20.48	17.94	2.66
	21 (UDS)	25	21.92	20.86	2.67
	22 (UDS)	31	26.52	16.14	2.66
	23 (UDS)	35	24.92	20.47	2.65
	24 (SPT)	40	16.53		2.65
	25 (UDS)	5	4.32	16.20	2.67
	26 (UDS)	11	6.41	17.78	2.67
BH-04	27 (UDS)	15	12.36	17.35	2.67
	28 (UDS)	21	9.82	26.16	2.66
	29 (UDS)	25	17.35	19.44	2.65
	30 (UDS)	31	22.79	18.65	2.67
	31 (SPT)	36	32.67		2.66
	32 (SPT)	40	22.86		2.65




Prepared by: 


SUMMARY OF THE TEST RESULTS

Project: Geotechnical Investigation for WASA Master Plan, Faisalabad

Client: M/S ECOS Ltd

BH/ TP No.	Sample No	Depth (m)	NMC (%)	Bulk Density (kN/m ³)	Specific Gravity G _s
BH-05	33 (UDS)	5	9.23	17.74	2.65
	34 (UDS)	11	7.28	16.47	2.65
	35 (UDS)	15	15.10	16.46	2.66
	36 (UDS)	21	23.43	18.48	2.67
	37 (UDS)	25	24.64	17.79	2.67
	38 (UDS)	31	23.30	17.50	2.67
	39 (SPT)	36	19.62		2.67
BH-06	40 (SPT)	40	20.11		2.67
	41 (UDS)	1.5	20.39	17.17	2.70
	42 (UDS)	5	21.26	16.61	2.65
	43 (UDS)	11	7.78	15.98	2.67
	44 (UDS)	15	9.63	18.34	2.68
	45 (UDS)	21	6.79	16.12	2.67
	46 (UDS)	25	18.72	18.05	2.66
	47 (SPT)	32	20.46		2.65
	48 (SPT)	36	22.78		2.67



Prepared by: 

Appendix7 References

(3) Results on Excavation and Underground Infrastructure Observation Survey

Survey List (Excavation and underground structure observation survey)


Sr.#	MAP #	Pit/ Chamber Name	Excavation date	Pipe to be identified	Actual identified pipe	Road	Pavement	Notes
1	6	⑤-II-1-1	27-Jun	Installation point of a valve on Ex. Distribution Main (DN250)	PVC DN100, DP=1.8m PVC DN100, DP=1.9m	Main Rd (Susan Rd)	No pavement (green belt)	
2	3	⑥-PM-7	28-Jun	Intersection point of Ex. Distribution Main (DN300) and proposed Distribution Primary Main (DN450)	CIP DN250, DP=1.43m CIP DN250, DP=1.43m	Main Rd (Susan Rd)	No pavement (green belt)	
3	9	⑥-EX-01	28-Jun	Intersection point of Ex. Distribution Main (DN600) and proposed Interconnecting Main.	AC DN600, DP=1.65m	Inside Old JK WTP	No pavement	
4	9	⑥-EX-02	29-Jun	Intersection point of Ex. Distribution Main (DN600) and proposed Interconnecting Main.	No pipe	Inside Old JK WTP	No pavement	
5	7	⑥-TM-3	1-Jul	Intersection point of Ex. Distribution Main (DN250) and proposed Transmission Main (DN450)	AC DN250, DP=1.52m	Main Rd (Green Belt Rd)	No pavement (shoulder)	
6	7	⑥-PM-9	1-Jul	Intersection point of Ex. Distribution Main (DN250) and proposed Distribution Primary Main (DN450)	AC DN250, DP=1.18m	Main Rd (Green Belt Rd)	Brick (shoulder)	
7	11	②-II-3-1	2-Jul	Point of cutting or installation of a valve on Ex. Distribution Main (DN150)	AC DN200, DP=1.1m	Town Rd (Madina Town)	No pavement (shoulder)	
8	12	⑥-PM-13	2-Jul	Intersection point of Ex. Distribution Main (DN200) and proposed Distribution Primary Main (DN300)	AC DN200, DP=1.43m CIP DN75, DP=1.43m	Town Rd (Madina Town)	Asphalt	
9	15	⑥-PM-12	3-Jul	Intersection point of Ex. Distribution Main (DN300) and proposed Distribution Primary Main (DN300)	Steel DN300, DP=0.23m Steel DN200, DP=0.23m	Main Rd (Jaranwala Rd)	Asphalt	
10	3	⑥-TM-2	4-Jul	Intersection point of Ex. Distribution Main (DN600) and proposed Transmission Main (DN450)	No pipe	Main Rd (Service road of Canal Expy)	Asphalt	
11	11	①-II-3-1	13-Jul	Connecting point of Ex. Distribution Main (DN100) and proposed Distribution Secondary Main (DN200)	No pipe	Town Rd (Madina Town)	No pavement (shoulder)	
12	11	①-II-3-1A	13-Jul	Connecting point of Ex. Distribution Main (DN100) and proposed Distribution Secondary Main (DN200)	AC DN150, DP=1.25m	Town Rd (Madina Town)	No pavement (shoulder)	
13	2	①-I-1-1	14-Jul	Connecting point of Ex. Distribution Main (DN75) and proposed Distribution Secondary Main (DN200)	AC DN100, DP=1.50m	Town Rd (Abdullar Pur)	Concrete	
14	2	①-I-2-2	15-Jul	Connecting point of Ex. Distribution Main (DN100) and proposed Distribution Secondary Main (DN150)	AC DN100, DP=1.27m	Town Rd (Abdullar Pur)	Asphalt	
15	2	④-I-1-2	15-Jul	Cutting point of Ex. Distribution Main (DN150)	No pipe	Town Rd (Abdullar Pur)	Asphalt	
16	7	①-II-1-6	16-Jul	Connecting point of Ex. Distribution Main (DN75) and proposed Distribution Secondary Main (DN150)	AC DN250, DP=1.75m CIP DN75, DP=1.75m	Main Rd (Susan Rd)	No pavement (green belt)	
17	7	①-II-1-5	16-Jul	Connecting point of Ex. Distribution Main (DN75) and proposed Distribution Secondary Main (DN150)	AC DN250, DP=1.24m CIP DN150, DP=1.24m	Main Rd (Susan Rd)	No pavement (green belt)	
18	6	①-II-1-1	17-Jul	Connecting point of Ex. Distribution Main (DN100) and proposed Distribution Secondary Main (DN150)	AC DN100, DP=1.5m (new) AC DN50, DP=1.2m (old)	Town Rd (Madina Town)	Tile, Asphalt	
19	6	①-II-1-2	17-Jul	Connecting point of Ex. Distribution Main (DN100) and proposed Distribution Secondary Main (DN150)	AC DN100, DP=0.57m AC DN100, DP=0.57m	Town Rd (Madina Town)	Asphalt	
20	11	⑤-II-4-1	18-Jul	Installation point of a valve to Ex. Distribution Main (DN200)	AC DN200, DP=1.74m	Town Rd (Madina Town)	Asphalt	
21	12	①-II-4-3	18-Jul	Connecting point of Ex. Distribution Main (DN75) and proposed Distribution Secondary Main (DN150)	PVC DN75, DP=1.10m	Town Rd (Madina Town)	Asphalt	
22	7	①-II-3-2	19-Jul	Connecting point of Ex. Distribution Main (DN75) and proposed Distribution Secondary Main (DN150)	PVC DN75, DP=0.70m	Town Rd (Madina Town)	Asphalt	
23	3	①-II-1-8	19-Jul	Connecting point of Ex. Distribution Main (DN75) and proposed Distribution Secondary Main (DN150)	PVC DN100, DP=1.00m PVC DN75, DP=1.00m	Town Rd (Madina Town)	Asphalt	
24	3	①-II-1-7	19-Jul	Connecting point of Ex. Distribution Main (DN75) and proposed Distribution Secondary Main (DN150)	PVC DN75, DP=0.90m PVC DN75, DP=0.90m	Town Rd (Madina Town)	Asphalt	



Sr.#	MAP #	Pit/Chamber Name	Excavation date	Pipe to be identified	Actual identified pipe	Road	Pavement	Notes
25	2	①-I-2-1	21-Jul	Connecting point of Ex. Distribution Main (DN75) and proposed Distribution Secondary Main (DN150)	PVC DN75, DP=1.05m	Town Rd (Abdullar Pur)	Concrete, Asphalt	
26	2	④-I-1-3	21-Jul	Cutting point of Ex. Distribution Main (DN75)	ACP DN75, DP=0.96m	Town Rd (Abdullar Pur)	Concrete, Asphalt	
27	12	①-II-4-4	22-Jul	Connecting point of Ex. Distribution Main (DN75) and proposed Distribution Secondary Main (DN200)	ACP DN200, DP=1.45m	Town Rd (Madina Town)	Asphalt	
28	11	①-II-4-2	22-Jul	Connecting point of Ex. Distribution Main (DN75) and proposed Distribution Secondary Main (DN150)	ACP DN100, DP=1.75m	Town Rd (Madina Town)	Tile (shoulder)	
29	7	③-II-1-1	23-Jul	Cutting point of Ex. Distribution Main (DN100)	PVC DN150, DP=0.80m	Main Rd (Susan Rd)	No pavement (green belt)	Count as 2 pits because of more than 3m2 of excavation area
30	7	③-II-1-3	23-Jul	Cutting point of Ex. Distribution Main (DN75)	No pipe	Main Rd (Susan Rd)	No pavement (green belt)	
31	11	①-II-4-1	24-Jul	Connecting point of Ex. Distribution Main (DN75) and proposed Distribution Secondary Main (DN150)	ACP DN100, DP=1.45m	Town Rd (Madina Town)	Asphalt	
32	7	①-II-2-1	24-Jul	Connecting point of Ex. Distribution Main (DN100) and proposed Distribution Secondary Main (DN150)	PVC DN150, DP=0.93m	Town Rd (Madina Town)	Asphalt	
33	3	④-II-1-2	26-Jul	Cutting point of Ex. Distribution Main (DN75)	ACP DN100, DP=0.68m PVC DN75, DP=0.68m	Town Rd (Madina Town)	Asphalt	
34	7	⑥-PM-8	26-Jul	Intersection point of Ex. Distribution Main (DN250) and proposed Distribution Primary Main (DN400)	ACP DN250, DP=1.30m PVC DN150, DP=0.30m	Main Rd (Green Belt Rd)	No pavement (shoulder)	
35	9	⑥-EX-03	27-Jul	Connecting point of Ex.Arterial Main (DN800) and proposed Interconnecting Main.	DIP DN800, DP=2.30m	Town Rd (Jhal)	Asphalt	
36	7	①-II-3-3	27-Jul	Connecting point of Ex. Distribution Main (DN75) and proposed Distribution Secondary Main (DN150)	No pipe	Town Rd (Madina Town)	Tile	
37	8	④-II-4-2	28-Jul	Cutting point of Ex. Distribution Main (DN75)	PVC DN150, DP=0.66m PVC DN75, DP=0.66m	Town Rd (Madina Town)	Asphalt	
38	8	④-II-4-1	28-Jul	Cutting point of Ex. Distribution Main (DN75)	PVC DN150, DP=0.67m PVC DN75, DP=0.67m	Town Rd (Madina Town)	Asphalt	
39	7	③-II-2-2	29-Jul	Cutting point of Ex. Distribution Main (DN150)	ACP DN250, DP=1.70m	Main Rd (Green Belt Rd)	No pavement (shoulder)	
40	7	③-II-2-3	29-Jul	Cutting point of Ex. Distribution Main (DN150)	ACP DN100, DP=1.45m	Town Rd (Madina Town)	Brick (shoulder)	Count as 2 pits because of more than 3m2 of excavation area
41	7	③-II-3-1	30-Jul	Cutting point of Ex. Distribution Main (DN200)	No pipe	Main Rd (Susan Rd)	Tile, Asphalt	
42	11	③-II-4-1	31-Jul	Cutting point of Ex. Distribution Main (DN75)	PVC DN200, DP=1.40m	Town Rd (Madina Town)	Asphalt	
43	12	③-II-4-6	31-Jul	Cutting point of Ex. Distribution Main (DN75)	ACP DN200, DP=1.43m	Town Rd (Madina Town)	Asphalt	
44	12	③-II-4-2	1-Aug	Cutting point of Ex. Distribution Main (DN75)	No pipe	Town Rd (Madina Town)	Asphalt	
45	12	③-II-4-4	1-Aug	Cutting point of Ex. Distribution Main (DN150)	PVC DN200, DP=0.60m	Town Rd (Madina Town)	Asphalt	
46	12	③-II-4-5	1-Aug	Cutting point of Ex. Distribution Main (DN75)	ACP DN200, DP=1.30m (OLD) PVC DN200, DP=0.50m (NEW)	Town Rd (Madina Town)	Asphalt	
47	6	②-I-1-1	2-Aug	Installation point of a valve to Ex. Distribution Main (DN250)	ACP DN250, DP=1.45m	Main Rd (Faisalabad Sangla Hill Rd)	Asphalt	
48	2	④-I-1-1	2-Aug	Cutting point of Ex. Distribution Main (DN100)	ACP DN150, DP=1.13m	Town Rd (Abdullar Pur)	Concrete, Asphalt	
Valve chambers surveyed								
Chamber # 1	6	⑤-II-1-1	-	Installation point of a valve on Ex. Distribution Main (DN250)	AC DN250, DP=1.98m	Main Rd (Susan Rd)	-	
Chamber # 2	11	⑥-PM-10	-	Intersection point of Ex.Distribution Main (DN300) and proposed Distribution Primary Main (DN400)	DN250, DP=1.98m	Main Rd (Jaranwala Rd)	-	
Chamber # 3	11	⑥-PM-11	-	Intersection point of Ex.Arterial Main (DN500) and proposed Distribution Primary Main (DN300)	AC DN300, DP=0.92m	Main Rd (Jaranwala Rd)	-	

Sr.#	MAP #	Pit/Chamber Name	Excavation date	Pipe to be identified	Actual identified pipe	Road	Pavement	Notes
Chamber # 4	3	④-II-1-5	-	Cutting point of Ex. Distribution Main (DN75)	DN75, DP=0.92m	Town Rd (Madina Town)	-	
Chamber # 5	6	⑥-PM-4	-	Intersection point of Ex.Arterial Main (DN800) and proposed Distribution Primary Main (DN300)	DIP DN800, DP=3.66m	Main Rd (Canal Expy)	-	
Chamber # 6	6	⑥-PM-5	-	Intersection point of Ex.Arterial Main (DN600) and proposed Distribution Primary Main (DN300)	DIP DN800, DP=4.58m	Main Rd (Canal Expy)	-	
Chamber # 7	6	⑥-PM-6	-	Intersection point of Ex.Arterial Main (DN800) and proposed Distribution Primary Main (DN300)	DIP DN800, DP=3.66m	Main Rd (Jaranwala Rd)	-	
Chamber # 8	6	⑥-TM-1 / ⑥-PM-1	-	Intersection point of Ex.Arterial Main (DN800) and proposed Transmission Main (DN450) and proposed Distribution Primary Main (DN300)	DIP DN800, DP=2.44m	Main Rd (Faisalabad Sangla Hill Rd)	-	
Chamber # 9	9	⑥-EX-01 / ⑥-EX-02	-	Intersection point of Ex.Distribution Main (DN600) and proposed Interconnecting Main.	DIP DN600, DP=1.98m	Inside Old JK WTP	-	
Chamber # 10	7	③-II-1-1	-	Cutting point of Ex. Distribution Main (DN100)	AC DN250, DP=1.52m AC DN150, DP=1.52m	Main Rd (Susan Rd)	-	
No need to be excavated								
-	3	⑥-PM-2	-	Intersection point of Ex. Distribution Main (DN250) and proposed Distribution Primary Main (DN400)	-	Main Rd (Susan Rd)	-	
-	3	⑥-PM-3	-	Intersection point of Ex. Distribution Main (DN300) and proposed Distribution Primary Main (DN400)	-	Main Rd (Susan Rd)	-	
-	12	⑤-II-4-2	-	Installation point of a valve to Ex. Distribution Main (DN200)	-	Town Rd (Madina Town)	-	
-	6	①-I-1-2	-	Connecting point of Ex. Distribution Main (DN75) and proposed Distribution Secondary Main (DN200)	-	Main Rd (Canal Expy)	-	
-	6	①-II-1-3	-	Connecting point of Ex. Distribution Main (DN75) and proposed Distribution Secondary Main (DN150)	-	Town Rd (Madina Town)	-	
-	6	①-II-1-4	-	Connecting point of Ex. Distribution Main (DN75) and proposed Distribution Secondary Main (DN150)	-	Town Rd (Madina Town)	-	
Cannot be excavated								
-	3	④-II-1-1	-	Cutting point of Ex. Distribution Main (DN75)	-	Town Rd (Madina Town)	-	
-	3	④-II-1-3	-	Cutting point of Ex. Distribution Main (DN75)	-	Town Rd (Madina Town)	-	
-	3	④-II-1-4	-	Cutting point of Ex. Distribution Main (DN75)	-	Town Rd (Madina Town)	-	
-	7	③-II-1-2	-	Cutting point of Ex. Distribution Main (DN75)	-	Main Rd (Susan Rd)	-	
-	3	③-II-2-1	-	Cutting point of Ex. Distribution Main (DN200)	-	Main Rd (Susan Rd)	-	
-	11	④-II-2-1	-	Cutting point of Ex. Distribution Main (DN75)	-	Town Rd (Madina Town)	-	
-	11	④-II-2-2	-	Cutting point of Ex. Distribution Main (DN75)	-	Town Rd (Madina Town)	-	
-	7	④-II-2-3	-	Cutting point of Ex. Distribution Main (DN75)	-	Town Rd (Madina Town)	-	
-	7	④-II-2-4	-	Cutting point of Ex. Distribution Main (DN75)	-	Town Rd (Madina Town)	-	
-	12	③-II-4-3	-	Cutting point of Ex. Distribution Main (DN75)	-	Town Rd (Madina Town)	-	


Notes:

- ① To identify actual connecting point of new distribution secondary main and existing distribution tertiary main.
- ② To identify actual isolation point (installing valve or cutting & plugging) between existing distribution primary main (to be used) and existing distribution secondary main (not to be used).
- ③ To identify actual isolation point (installing valve or cutting & plugging) between existing distribution secondary main and existing distribution tertiary main.
- ④ To identify actual isolation point (installing valve or cutting & plugging) of existing distribution tertiary main at boundary of DMA.
- ⑤ To identify actual valve installation point on existing primary or secondary main to isolate distribution area.
- ⑥ To identify actual location (alignment and depth) of existing underground infrastructure (big water supply pipe such as arterial main and primary main, sewerage pipe, drainage channel, commutation cable, etc.) in order to define alignment and depth of new transmission main and new distribution primary main.







- Excavation pit
- Valve chamber surveyed
- No need to be excavated
- Cannot be excavated




Cross Section


The cross-sectional map is based on interviews with WASA staff and does not reflect the excavation results. See the report for the locations of the pipes identified in the survey.



Cross Section
 The cross-sectional map is based on interviews with WASA staff and does not reflect the excavation results. See the report for the locations of the pipes identified in the survey.




- 3"
 - 4"
 - 6"
 - 8"
 - 10"
 - 12"
 - 24"
 - 28"
 - 32"
- ⊗ Excavation pit
 - ⊗ Valve chamber surveyed
 - ⊗ No need to be excavated
 - ⊗ Cannot be excavated




Cross Section
 The cross-sectional map is based on interviews with WASA staff and does not reflect the excavation results. See the report for the locations of the pipes identified in the survey.




- 3"
 - 4"
 - 6"
 - 8"
 - 10"
 - 12"
 - 24"
 - 28"
 - 32"
- ⊗ Excavation pit
 - ⊗ Valve chamber surveyed
 - ⊗ No need to be excavated
 - ⊗ Cannot be excavated




Cross Section
 The cross-sectional map is based on interviews with WASA staff and does not reflect the excavation results. See the report for the locations of the pipes identified in the survey.




- 3"
 - 4"
 - 6"
 - 8"
 - 10"
 - 12"
 - 24"
 - 28"
 - 32"
- ⊗ Excavation pit
 - ⊗ Valve chamber surveyed
 - ⊗ No need to be excavated
 - ⊗ Cannot be excavated



Cross Section
 The cross-sectional map is based on interviews with WASA staff and does not reflect the excavation results. See the report for the locations of the pipes identified in the survey.



4 Cross Section
 The cross-sectional map is based on interviews with WASA staff and does not reflect the excavation results. See the report for the locations of the pipes identified in the survey.




- 3"
- 4"
- 6"
- 8"
- 10"
- 12"
- 24"
- 28"
- 32"
- ⊗ Excavation pit
- ⊗ Valve chamber surveyed
- ⊗ No need to be excavated
- ⊗ Cannot be excavated



4 Cross Section
The cross-sectional map is based on interviews with WASA staff and does not reflect the excavation results. See the report for the locations of the pipes identified in the survey.




- 3"
 - 4"
 - 6"
 - 8"
 - 10"
 - 12"
 - 24"
 - 28"
 - 32"
- ⊗ Excavation pit
 - ⊗ Valve chamber surveyed
 - ⊗ No need to be excavated
 - ⊗ Cannot be excavated





Cross Section
 The cross-sectional map is based on interviews with WASA staff and does not reflect the excavation results. See the report for the locations of the pipes identified in the survey.




- Excavation pit
- Valve chamber surveyed
- No need to be excavated
- Cannot be excavated




Cross Section
 The cross-sectional map is based on interviews with WASA staff and does not reflect the excavation results. See the report for the locations of the pipes identified in the survey.




- Excavation pit
- Valve chamber surveyed
- No need to be excavated
- Cannot be excavated




Section A-A



Section B-B



Section C-C



Cross Section
 The cross-sectional map is based on interviews with WASA staff and does not reflect the excavation results. See the report for the locations of the pipes identified in the survey.

Appendix7 References
(4) Preliminary Design

Preliminary Design

Table of Contents	Page
1	Technical Parameter of Intake and Treatment Facilities..... 1-1
1.1	Intake and Raw Water Transmission Facilities..... 1-1
	(1) Planned Intake Capacity..... 1-1
	(2) Flow Diagram of Intake and Raw Water Transmission 1-1
	(3) Intake and Raw Water Transmission Facilities 1-1
1.2	Water Treatment Plant Facilities..... 1-4
	(1) Pre-Treatment Facilities (Flash Mixing, Flocculation and Sedimentation tanks) ... 1-4
	(2) Rapid Sand Filter and Clear Water Reservoir/Treated Water Transmission Pump Station 1-8
	(3) Waste Water Treatment Facilities 1-13
2	Raw Water Quality and Chemical Dosage..... 2-1
2.1	Raw Water Quality 2-1
	(1) Raw Water Quality Data 2-1
	(2) Estimated Raw Water Quality 2-2
2.2	Chemical Dosage 2-10
	(1) Water Treatment Capacity 2-10
	(2) Raw Water Quality 2-10
	(3) Chemicals..... 2-10
	(4) Chemical Dosage..... 2-10
3	Hydraulic Profile of Intake and Water Treatment Plant 3-1
3.1	Hydraulic Analysis of Intake and Raw Water Transmission..... 3-1
	(1) Flow Diagram..... 3-1
	(2) Hydraulic Analysis..... 3-1
3.2	Hydraulic Analysis of Water Treatment Plant..... 3-4
	(1) Flow Diagram..... 3-4
	(2) Hydraulic Analysis..... 3-4
4	Distribution Center..... 4-1
4.1	Dimensions of Distribution Center DZ I – Abudulah Pur 4-1
	(1) Water Demand..... 4-1
	(2) Distribution Center 4-1
4.2	Dimensions of Distribution Center DZ II - Madina Town No.2..... 4-2

(1)	Water Demand.....	4-2
(2)	Distribution Center.....	4-2
5	Treated Water Transmission and Distribution System.....	5-1
5.1	Brief Description of Water Transmission and Distribution System	5-1
(1)	Service Area	5-1
(2)	Design Criteria	5-2
5.2	Design of Transmission Main.....	5-4
(1)	Hydraulic Analysis and Sizing of Transmission Main.....	5-5
5.3	Distribution Main System.....	5-7
(1)	Hydraulic/Network Analysis and Sizing of Distribution Primary Main (2038).....	5-7
(2)	Network Analysis and Sizing of Distribution Secondary Main	5-9
	Reference: Distribution System for Requirement in Year 2028.....	5-20
(1)	Hydraulic / Network Analysis and Sizing of Distribution Primary Main	5-20
(2)	Network Analysis and Sizing of Distribution Secondary Main	5-22

Attached Table

1-1	Volume of Clear Water Reservoir at Canal Stoppage.....	1-11
1-2	Mass Balance.....	1-17
1-3a	Volume of Sludge Buffer Tank.....	1-18
1-3b	Volume of Waste Water Tank.....	1-19
2-1a	Water Quality Data of RBC and RWSW	2-3
2-1b	Turbidity Change between RBC and RWSR Water.....	2-3
2-1c	Effect of RWSR	2-3
2-2a	Raw Water Quality – Temperature.....	2-4
2-2b	Raw Water Quality – pH	2-5
2-2c	Raw Water Quality – Turbidity.....	2-6
2-3a	Water Quality Test Result by JICA Consultant in M/P	2-7
2-3b	Past Water Test Result in M/P.....	2-7
2-4	Results of Settling Test	2-8
2-5	Clarified Water Turbidity in RWSR.....	2-9

Attachment

1-1	Sludge Extraction of Sedimentation Tank	1-20
3-1	Mixing Intensity of Flash Mixing Tank.....	3-10

3-2	Mixing Intensity and GT-Value of Slow Mixing.....	3-10
3-3	Head Loss of Clarified Water Extraction.....	3-11
3-4	Head Loss of Filter	3-12
4-1	Capacity of Ground Reservoir (Detention Time)	4-3

1. Technical Parameter of Intake and Treatment Facilities

1. Technical Parameter of Intake and Treatment Facilities

1.1 Intake and Raw Water Transmission Facilities

(1) Planned Intake Capacity

Production capacity is set at 45,500 m³/d (10 mgd).


Intake capacity is designed at 5% of production capacity.

Therefore, design capacity of intake becomes 47,900 m³/d (45,500 x 1/(1-5%).

NOTE: Water right from the Irrigation Department is 20 cfs (48,900 m³/d) which exceeds above design capacity of intake.

(2) Flow Diagram of Intake and Raw Water Transmission

Water of the irrigation canal (RBC: Rahk Branch Canal) is transmitted through coarse screen to the existing raw water storage reservoirs (RWSR A and B). Clarified water in RWSR is transmitted to the raw water transmission pump station after screening by fine screen, then it is transferred to the Receiving tank for water purification process. The by-pass line is provided for direct transmission to the raw water transmission pump station during winter season when raw water turbidity becomes low in the irrigation canal. The flow diagram of intake and transmission is shown in flow chart below.



(3) Intake and Raw Water Transmission Facilities

1) Intake Mouth

Water is taken from RBC at its most down stream, where its cross section is about 12m width bottom with no lining and concrete lining at the both sides with slope of 1:1.5. Water depth is measured at a.1.54 m where water level and bottom level is measured as + 184.86 and + 183.32 respectively, thus area of cross section becomes about 22 m². According to the irrigation canal authority, the design flow there is 11. 27 m³/s and velocity is calculated at 0.51 m/s. Right after the intake point, water is diverted to Dijkot Disty (distribution canal). According to the information by a operator in OJK WTP, water level of the canal is stable within a small change.

Dimensions of Intake Mouth

Main road runs along RBC at the intake point, therefore limited space is available for construction of intake mouth (about 3.3 m between road edge and canal shoulder).

Front Yard	front yard level (50 cm higher than canal bed)	+	183.82 m
Inflow velocity		<	0.6 m/s
Cross section	2 intake mouths are provided each having dimensions	width	0.6 m
		water depth	1.01 m
		cross section area	0.606 m ²
		inflow velocity	0.46 m/s < 0.6

Appurtenant Facilities Stop log at mouth screen is provided in the water treatment plant due to limited space available at the site of intake mouth for operation and maintenance.

2) Raw Water Transmission Main (Intake mouth ~ Coarse screen)

Pipe Materials	Ductile Cast Iron
Diameter	800 mm
Velocity	1.10 m/s

3) Coarse Screen and Branch Valve Chamber			
Coarse Screen	Number		1 unit
	Type		Manual operation bar screen
	width		1.6 m
	height		3.0 m
	bar spacing		60 mm
Branch Valve	Number	to RWSR A & B and By-pass to RWS Pump Sta.	3 units
	Type		Short body butterfly valve
	Diameter		800 mm
4) Inflow and Outflow of RWSR			
Inflow	Transmission pipe is installed to prevent short cut flow from inflow to outflow and to utilized capacity and surface area of RWSR effectively.		
	Pipe Materials		Reinforced concrete pipe
	Diameter		900 mm
Outflow pit	Provide two weirs placed at the pit for each RWSR for surface water intake, where submerged weir is used		
	Overflow rate	per one weir	0.277 m ³ /s
	Weir width		1.0 m
	Overflow height		0.5 m
	During canal stoppage period, a gate is provide at the bottom of the pit to intake stored canal water in RWSR		
	Number		1 unit
	Size		600 x 600 mm
Outlet Pipe (RWSR ~ RWT Pump Sta.)			
	Pipe Materials		Ductile Cast Iron
	Diameter		800 mm
	Velocity		1.10 m/s
5) Raw Water Transmission Pump Station			
Receiving Chamber	Fine screen is provided in channels before pump well of RWT Pump Sta. The dimensions of channel are		
	Width		1.15 m
	Length		2.9 m
	Height		4.3 m
	Install a gate at inflow and outflow of the channel respectively for maintenance of fine screen		
	Number	at each channel	2 units
	Size		600 x 600 mm
Fine Screen	Type		Automatic vertical mesh screen
	Number		2 units
	width		1 m
	height		5.4 m
	mesh		12 mm
Pump Well	Dimensions of pump well is determined to fit those pump room (length and height)		
	Width		3.6 m
	Length		19.6 m
	Water depth		4.3 m
	Effective capacity		303 m ³
	Detention time		9 min

Pump Room	Dimensions of pump room is determined based on capacity and number of pumps with appurtenant equipment (flow meter, control valve, etc.)	
	Width	4.2 m
	Length	20.0 m
	Height	below beam soffit 6.6 m
Electric Room	Dimensions of electric room is determined to meet the spaces required for electric panels for power, pumps and control together with hatch room, etc.	
	Width	4.2 m
	Length	20.0 m
	Height	below beam soffit 3.5 m

✓ (6) Raw Water Transmission Main

Dimensions of a flow meter and a control valve which are installed in the pump room.

Flow meter	Type	Electric magnetic flow meter
	Diameter	500 mm
Flow control valve	Type	Butterfly valve
	Diameter	500 mm
Transmission Main (Raw Water Transmission Pump Sta. ~ Receiving Well)	Pipe Materials	Ductile Cast Iron
	Diameter	700 mm

1.2 Water Treatment Plant Facilities

(1) Pre-Treatment Facilities (Flash Mixing, Flocculation and Sedimentation Tanks)

Production Capacity		45,500 m ³ /d
Treatment Capacity	処理過程のロス 5%	47,900 m ³ /d 2,000 m ³ /h 33.3 m ³ /min 0.554 m ³ /s

1) Receiving Tank

Detention time		3 min.
Number of compartments		2 units
Dimensions per compartment	Width	3.0 m
	Length	3.0 m
	Water depth	5.5 m
	Capacity (per tank)	49.5 m ³

Appurtenant	Inlet pipe	Diameter	700 mm		1 no.
	Inflow gate	Size	600 x 600 mm		2 units
	By-pass gate	Size	500 x 500 mm	let channel	1 units
	Outlet pipe	Diameter	600 mm		2 nos.
	Drain pipe	Diameter	150 mm		2 nos.

2) Flash Mixing Tank

Mixing Method		Hydraulic Mixing (Water Fall)
Mixing Intensity		500 sec ⁻¹
Number of Tanks		2 tanks
Treatment Capacity per Tank	23,950 m ³ /d	0.277 m ³ /s

		at Inflow	at Outflow (Mixing)
Detention Time		146 sec	24 sec
Dimensions	Width	3.0 m	3.0 m
	Length	3.0 m	0.8 m
	Water depth	4.5 m	2.8 m
	Capacity	40.5 m ³	6.72 m ³
Mixing Intensity	Water temperature		15 °C
	Mixing intensity	-	497 sec ⁻¹

Mixing Intensity

$$G = (1/\mu \times (\rho \times g \times q \times hf / V))^{0.5} = 497 \text{ sec}^{-1}$$

ここに、	μ : Viscosity	0.00098 kg/m/s
	ρ : Specific gravity of water	1,000 kg/m ³
	g : Gravity acceleration	9.8 m/sec ²
	q : Flow rate	0.277 m ³ /s
	hf : Head loss (freefall depth)	0.60 m
	V : Volume	6.72 m ³

3) Flocculation Tank			
Method		Up-and-Down Flow	
Number of Tanks			4 tanks
Treatment Capacity per Tank	11,975 m ³ /d		0.139 m ³ /s
Mixing Intensity	about		20 ~ 60 sec ⁻¹
Number of Channels			4 列
Dimensions per Channel	Width		1.85 m
	Length		9.75 m
	Water depth		3.5 ~ 3.8 m
Detention Time		about	30 min
Energy of Dissipation (GT-value)		about	80,000

$G = (1/\mu * (\rho * g * q * hf / V))^{0.5}$			
where,	μ :	viscosity (15°C)	0.00098 kg/m/s
	ρ :	specific gravity of water	1,000 kg/m ³
	g :	gravity acceleration	9.8 m/s ²
	q :	flow rate	variable m ³ /s
	V :	volume	variable m ³

Energy Dissipation by Phases

a. Designed Treatment Capacity (Day Maximum Demand in 2038) per Tank 0.1386 m³/s

Dimensions	unit	Channel Number				Total
		No.1	No.2	No.3	No.4	
Baffle Wall	nos.	5	5	5	5	20
Baffle Plate	nos.	3	4	5	6	18
slit dia. and layout	mm	w ³⁰⁰ x h ⁸⁰ x n ⁴				
area of slit	m ²	0.288	0.384	0.480	0.576	-
Velocity at Slit	m/s	0.481	0.361	0.289	0.241	-
Head Loss at Slit	m	0.164	0.092	0.059	0.041	0.356
Volume of Channel	m ³	68.1	65.2	63.5	62.4	259.2
width	m	1.85	1.85	1.85	1.85	-
length	m	9.7	9.7	9.7	9.7	-
water depth	m	3.80	3.63	3.54	3.48	3.61
Detention time of Channel	sec	491	470	458	450	1,869
Mixing Intensity	sec-1	57.8	44.2	35.9	30.2	43.6
GT-value	-	28,400	20,800	16,400	13,600	79,200

b. Designed Treatment Capacity (Day Minimum Demand in 2038) per Tank 0.1048 m³/s

Dimensions	unit	Channel Number				Total
		No.1	No.2	No.3	No.4	
Baffle Wall	nos.	5	5	5	5	20
Baffle Plate	nos.	3	4	5	6	18
slit dia. and layout	mm	w ³⁰⁰ x h ⁸⁰ x n ⁴				
area of slit	m ²	0.288	0.384	0.480	0.576	-
Velocity at Slit	m/s	0.364	0.273	0.218	0.182	-
Head Loss at Slit	m	0.094	0.053	0.034	0.023	0.204
Volume of Channel	m ³	65.5	63.8	62.9	62.3	255
width	m	1.85	1.85	1.85	1.85	-
length	m	9.7	9.7	9.7	9.7	-
water depth	m	3.65	3.56	3.50	3.47	3.55
Detention time of Channel	sec	625	609	600	594	2,428
Mixing Intensity	sec-1	44.6	33.9	27.4	22.6	33.3
GT-value	-	27,900	20,600	16,400	13,400	78,300


c. Designed Treatment Capacity (Day Minimum Demand in 2023) per Tank 0.0626 m³/s

Dimensions	unit	水路ナンバー				Total
		No.1	No.2	No.3	No.4	
Baffle Wall	nos.	5	5	5	5	20
Baffle Plate	nos.	3	4	5	6	18
slit dia. and layout	mm	w ³⁰⁰ x h ⁷⁵ x n ⁴				
area of slit	m ²	0.317	0.384	0.480	0.576	-
Velocity at Slit	m/s	0.198	0.163	0.130	0.109	-
Head Loss at Slit	m	0.028	0.019	0.012	0.008	0.067
Volume of Channel	m ³	63.0	62.5	62.1	61.9	250
width	m	1.85	1.85	1.85	1.85	-
length	m	9.7	9.7	9.7	9.7	-
water depth	m	3.51	3.48	3.46	3.45	
Detention time of Channel	sec	1,007	999	992	989	3,987
Mixing Intensity	sec-1	24.8	20.5	16.4	13.4	19.3
GT-value	-	25,000	20,500	16,300	13,300	75,100

4) Sedimentation Tank

Metod		Inclining Tube
Number of Tank		4 tanks
Treatment Capacity per Tank	12,000 m ³ /d	500 m ³ /h
Surface Loading		1 m ³ /h/m ²
Efficiency		80 %
Inclining Tube	Size of tube	80 x 80 mm
	Installation height	1.0 m
	Installation angle to horizontal	60 deg.
	Effective area	0.577 m ² /m
	Module of inclining tube (1.0 x 1.0m)	7.22 m ² /module
	Effective area of tank	625 m ² /tank
	Number of modules	>87 units/tank
Dimension of Tank	Width	Number of compartments
		2 compartments
		Number of modules per compartment
		4 units
		Distance between module and side wall
		about 10 cm
		Width of clarified water collecting channel (incl. side wall)
		1.3 m
		Width per tank
		9.7 m
	Length	Number of modules (87 x 1/8)
		11 units
		Installation length of modules (incl. space between modules)
		12.0 m
		Stilling zone length (incl. wall) (1.5 + 0.25)
		1.75 m
		Length of tank
		13.75 m
	Water depth	Water depth above inclining tube
		0.8 m
		Installation height of inclining tube (incl. support)
		1.2 m
		Height under the inclining tube
		1.5 m
		Free board
		0.4 m
		Total water depth
		3.5 m
Clarified Water	Method	Pipes
Extraction	Extraction pipe	Diameter
		200 mm
	Number of pipes	4 nos./compartment
	Weir loading	< 200 m ³ /d/m
	Clarified water extraction channel	Reinforced concrete
	Net width	0.8 m

Clarified Water Extraction Hydraulics



- h_p : head loss of pipe
 - h_{do} : outer diameter of pipe
 - h_d : freefall depth
 - h_o : upstream water depth of channel
 - h_c : critical depth at outlet of channel
 - h : head loss of clarified water extraction
- $$h = h_p + h_{do} + h_d + h_o - h_c$$

Head loss of clarified water extraction pipe

Clarified water flow per tank		0.139 m ³ /s
Extraction pipe nominal diameter		200 mm
outer diameter		216 mm
number of slit pipes		8 nos.
velocity		0.98 m/s
number of slit per pipe		10 nos/pipe
total number of slit		80 nos/tank
diameter of slit		65 mm
area of slit		0.265 m ²
velocity at slit		0.522 m/s
head loss of slit		0.039 m
outer diameter of slip	h_{do} :	0.216 m
freedrop at slit pipe outlet		0.051 m
head loss of slit pipe		0.306 m
($h_o + h_{do} + h_d$)		

Head loss of clarified water extraction channel

Critical water depth	$h_c = (\alpha \times q^2 / (g \times b^2))^{1/3} =$	0.150 m
where,	α : coefficient	1.1
	g : gravity accelerati	9.8
	b : width of channel	0.8
Water depth at the most upstream		
	$h_o = 1.732 \times h_c =$	0.260 m
Head loss of clarified water extraction channel		0.110 m

(2) Rapid Sand Filter and Clear Water Reservoir/Transmission Pump Station)

1) Rapid Sand Filter


a. Treatment Capacity

Production	45,500 m ³ /d
Treatment capacity loss	3 %
	46,900 m ³ /d

b. Dimensions

Type	Filter media Filtration Flow control	Sand (single layer) Constant rate Equal split at inlet
Filtration Rate		140 m/d
Filter Media	Filter sand	Effective size 0.9 mm Uniformity coefficient 1.4 Thickness of sand layer 100 cm
	Supporting gravel	Number of layers 4 layers Thickness of each layer 5 cm Range of particle size 2 ~ 50 mm Thickness of gravel layer 20 cm
Underdrain	Type Head loss at backwashing	nozzle type Maximum 70 cm
Number of Filters		8 filters
	Filtration flow per filter	5,860 m ³ /d
Dimensions of Filter	Width Length Filter area	4.5 m 9.4 m 42.3 m ²
	Height	Filtration rate 139 m/d 5.75 m Water depth above sand 1.25 m Clogging loss 1.30 m Thickness of Filter sand and gravel 1.2 m Underdrain 1.1 m Free board 0.9 m
	Backwash drain gutter	Width 0.9 m Length 9.4 m Water depth 4.5 m
	Operation/ Pipe gallery	Width 4 m Length 44.4 m

Filter Washing	Method		Air + Backwash
	Air Scouring	Scouring rate	0.9 ~ 1.0 m/min
		Scouring time	10 min
	Backwash	Rate of initial backwash (Air+Water)	0.25 m/min
		Washing time	2 ~ 3 min
		Backwashing (water only)	8 ~ 10 min
	Backwash water drain trough	Number of (1 池当たり)	4 本
		Width	40 cm
		Height	40 cm
		Length	4.65 m



Pipe, Valves and Gates of Filte

pipe· valve· gate	size (mm)	velocity (m/s)	pipe· valve· gate	size (mm)	velocity (m/s)
Inlet gate	300 x 300	0.76	Backwash main	500	2.01
Wash drain gate	600 x 600	1.10	Air pipe	250	15.3
Filtered water pipe	250	1.51	Air main	300	7.8
Filtered water main	800	1.08	Filter drain pipe	150	-
Backwash pipe	450	2.48	Filter drain main	200	-

2) Clear Water Reservoir and Treated Water Transmission Pump Station

a. Clear Water Reservoir

Detention Time*	apprx.	1.2 h
Capacity		2,280 m ³
Number of Compartment		2 nos.
Dimensions per Compartment	Width	15.8 m
	Length	17.2 m
	Effective water depth	4.5 m
	Total volume	1,223 m
	Effective volume (approx. 98%)	2,400 m ³
	Free board	0.65 m
	Detention time	1.27 hours

注* refer to Attached Table 1-1 volume of Clear Water Reservoir at Canal Stoppage

b. Treated Water Transmission Pump Station

Pump Room	Dimensions of pump room is determined based on capacity and number of pumps with appurtenant equipment (flow meter, control valve, etc.)	
	Width including pipe gallery of pump suction and delivery pipes	9.4 m
	Length	32.4 m
	Height below beam soffit	7.8 m
Electric Room	Dimensions of electric room is determined to meet the spaces required for electric panels of power, pumps and control together with hatch room, etc.	
	Width	4.2 m
	Length	32.4 m
	Height below beam soffit	3.5 m

Attached Table 1 – 1 Volume of Clear Water Reservoir at Canal Stoppage

1 In Year 2028

Water Demand	Day Maximum Water Demand	17,860 m ³ /d	
	Day Minimum Water Demand	13,500 m ³ /d	750 m ³ /h
	Supply hour at 18 hours (5 to 22)		
Supply	Treatment Plant (12 hours operation)	3,700 m ³ /d	310 m ³ /h
	from Arterial Main	9,800 m ³ /d	1,640 m ³ /h

note: Receiving water from Arterial Main for 6 hours/day (3 times each 2 hours)
 water demand is assumed as minimum demand, i.e., about 75% of Day Maximum demand
 Canal close is for 21 days
 Effective capacity of RWSRs of A and B is 78,300 m³ 3,700 m³/d

1.1 Constant Transmission Flow

hr	Supply			Σ	Demand		Balance		Trans. Flow Rate
	WTP	Arterial M.	Total		(Transmission)	Σ			
								750	
1			0	0		0	0	750	
2			0	0		0	0	750	
3			0	0		0	0	750	
4			0	0		0	0	750	
5			0	0	750	750	-750	0	100%
6		1,640	1,640	1,640	750	1,500	140	890	100%
7	310	1,640	1,950	3,590	750	2,250	1,340	2,090	100%
8	310		310	3,900	750	3,000	900	1,650	100%
9	310		310	4,210	750	3,750	460	1,210	100%
10	310		310	4,520	750	4,500	20	770	100%
11	310		310	4,830	750	5,250	-420	330	100%
12	310	1,640	1,950	6,780	750	6,000	780	1,530	100%
13	310	1,640	1,950	8,730	750	6,750	1,980	2,730	100%
14	310		310	9,040	750	7,500	1,540	2,290	100%
15	310		310	9,350	750	8,250	1,100	1,850	100%
16	310		310	9,660	750	9,000	660	1,410	100%
17	310		310	9,970	750	9,750	220	970	100%
18	310	1,640	1,950	11,920	750	10,500	1,420	2,170	100%
19		1,640	1,640	13,560	750	11,250	2,310	3,060	100%
20			0	13,560	750	12,000	1,560	2,310	100%
21			0	13,560	750	12,750	810	1,560	100%
22			0	13,560	750	13,500	60	810	100%
23			0	13,560		13,500	60	810	100%
24			0	13,560		13,500	60	810	100%
	3,720	9,840	13,560		13,500				

(3) Waste Water Treatment Facilities

Waste water treatment facilities are composed of /Sludge Buffer Tank/Waste Water Tank, Sludge Thickener and Sludge Drying Bed

1) Sludge Buffer Tank

a. Sludge Extraction of Sedimentation Tank

Treatment Flow		47,900 m ³ /d
		Maximum Turbidity
Sludge	Sludge extraction (times of extraction)	4 times/d
	Maximum Turbidity (RWST outflow)	200 NTU
	Clarified Water Turbidity	5 mg/l
	Alum Dosage rate (Solid 17%)	33 mg/l
	TS/Turbidity	1.0
Sludge	Solid weight	9,710 kg/d
	Sludge content	1.0%
	Sludge flow	970 m ³ /d
	Allowance	20%
		1,160 m ³ /d
	Sludge flow per extraction	290 m ³ /time

Two tanks of Sludge buffer tank is planned including one stand-by, each having volume of 250 m³ (refer to Attached Table 1-3a Volume of Sludge Buffer Tank)

b. Dimensions of Sludge Holding Tank

Number of Tank		2 tanks
Capacity (at Maximum turbidity,200 NTU)		250 m ³
Time for Sludge Transfer to Sludge Thickener		Continuous pump operation under water level control
Dimensions	Width	4.2 m
	Length	20.0 m
	Effective water depth	3.0 m
	Volume	504 m ³

c. Appurtenant Equipment

Mixer

Submersible mixers to prevent settlement of sludge in tank and transfer sludge with uniform sludge content as possible to sludge thickener. Two mixers per compartment is installed.

Sludge transfer pump

Sludge is transferred by submersible waste water pumps. Two units of pumps including one stand-by are installed in each tank.

Sludge is pumped to a chamber located on top slab of sludge holding tank, from where sludge is transferred to sludge thickener by gravity.

From the said sludge chamber, half of sludge is transferred to sludge thickener and remaining sludge is transferred directly to sludge drying bed by gravity to avoid large scale of sludge thickener when raw water turbidity becomes high.

High turbid raw water of 1,000 NTU or larger will occur only several times in wet season in a year.

2) Waste Water Tank

a. Backwash Waste Water and Supernatant Water

Treatment Flow of Filter		46,900 m ³ /d
Number of Filter		8 filters
Filter Backwash Waste Water		
Filter bed area		42.3 m ²
	Washing	rate (m ³ /min) time(min)
		initial 0.25 2 ~ 3
		Final 0.5 8 ~ 10
		waste water
		21
		169
Filter run		48 h
Washing time per day		4 times/d
Waste water volume		190 m ³ /time
	Allowance	20%
		910 m ³ /d
	Inflow of Backwash waste water per time	230 m ³ /time
Sllid weight	Inflow and outflow turbidity is 5 and 1 respectively	190 kg/d
Solid content		0.21%
Supernatant (24 hours continuous inflow)		
from Sludge Thickener		850 m ³ /d
from Sludge Drying Bed		300 m ³ /d

Number of waste water tank is two tanks including one stand-by, each having volume of 210 m³ (refer to Attached Table 1-3b Volume of Waste Water Tank)

b. Dimensions of Waste Water Tank

Number of Tank		2 tanks
Volume per tank		210 m ³
Time for Dewateringr		Continuous pump operation under water level control
Dimensions	Width	4.2 m
	Length	20.0 m
	Effective water depth	2.5 m
	Volume	210 m ³

c. Appurtenant Equipment

Mixer Submersible mixers to prevent settlement sludge in waste water in tank and transfer waste water with uniform sludge content as possible to receiving tank for recycle use. Two mixers per tank is installed.

Waste water transfer pump

Two submersible waste water pumps including one stand-by are installed in each compartment.

Pumps for Preventing Overflow

Because no appropriate waste water drain facilities is available around the water treatment plant, all waste water and overflows of plant inflow to the waste water tank.

Therefore, drain pumps are planned to be installed in the waste water tank to drain the RWSR in ordinal plant operation. As required, drain water is pumped to drain channel (former irrigation distribution canal which is not utilized at the present) located along north-west boundary wall of the plant.

4) Sludge Thickener				
Type				Gravity Center Feed Thickener
Sludge (solid weight)				10,080 kg
Sludge Loading				20 kg/d/m ²
Number of Thickener				2 池
Surface Area required				504 m ²
				252 m ² /thickener
Dimensions	Diameter			12.8 m
	Effective water depth			3.5 m
	Sludge Depth			0.5 m
	Deposit Sludge volume)			64 m ³
	Slope of basin			10%
	Size of center feed chamber	Dia.		2.5 m
	Size Sludge extraction pit	Dia.		2.2 m
Sludge Extraction	Type of scraper			Rotating type
	Extraction pipe	Dia.		150 mm
5) Thickened Sludge Transfer Pump Station				
Pump Room	Basement Floor			60 m ²
	Width			5 m
	Length			12 m
	Height			5.55 m
Electric Room	Ground Floor			60 m ²
	Width			5 m
	Length			12 m
	Height		below beam soffit	3.5 m
6) Sludge Drying Bed				
Sludge (Solid Weight) ^{*1}				911,400 kg/年
Annual Sludge Loading				220 kg/m ²
Floor Area of Sludge Drying Bed				4,140 m ²
Number of Beds				7 beds
Area				600 m ² /bed
Dimensions	Width			20 m
	Length			30 m
	Filter Sand			30 cm
	Gravel			20 cm
	Water depth above sand			1.5 m
	Free board			50 cm
Appurtenant	Piping	Inlet Pipe	PE	150 mm
Facilities and		Supernatant Drain	RCP	150 mm
Equipment	Stop log	(at supernatant drain pit)	W x H (20cm x 8nos)	0.6 x 1.6 m
	Ramp	(for dried sludge disposal)	W x L (3.0 x 7.5m)	1 pl/bed

Note *1: Sludge (Solid Weight)

$$Q = 47,900 \text{ m}^3/\text{d}$$

Month	Turbidity (average)	Alum	Sludge kg/d	kg/mon
Jan	21	29	1,091	33,800
Feb	16	27	830	23,200
Mar	32	34	1,674	51,900
Apr	46	42	2,435	73,100
May	44	41	2,328	72,200
Jun	67	50	3,530	105,900
Jul	121	59	6,218	192,800
Aug	114	58	5,871	182,000
Sep	52	44	2,744	82,300
Oct	22	30	1,151	35,700
Nov	19	28	984	29,500
Dec	18	28	937	29,000
Ave/Total	48	39	2,483	911,400

Sludge by Seasons

Dry Season Wet Season Annual (kg)

	33,800		
	23,200		
	51,900		
		73,100	
		72,200	
		105,900	
		192,800	
		182,000	
		82,300	
	35,700		
	29,500		
	29,000		
kg/year	203,100	708,300	911,400

Attached Table 1-2 Mass Balance

Maximum Turbidity of Canal Water: 1,000 NTU and Raw Water Storage Reservoir: 200 NTU								
Water & Waste Water Stream		RWSR		Treatment Flow	Flow after Treatment	Waste water/Sludge		note
		Turbidity	Solid weight	Flow		Flow	Solid weight	
		NTU	mg/l	m ³ /d	m ³ /d	m ³ /d	kg/d	
Treatment Process Production				45,500				
Treatment Flow		200	200		47,900	-		Loss of treatment (estimated) 5% TSS/NTU = 1.0
Sedimentation Tank	Inflow	200	200	47,900			10,080	Alum dosage 66, sludge concentration 0.85%
	Outflow				46,720		1,180	Loss of treatment 2.5%
Rapid Sand Filter	Inflow	9.2	5	46,720			190	Washing per Filter 190 m ³ /filter
	Outflow		1		45,810		910	washing time 4 filters/d 1.9%
Clear Water Reservoir	Inflow		1	45,810				treated water turbidity 1 mg/l
	Outflow		1		45,620		190 50	other loses 190 m ³ /d 0.40%

注: Refer to analysis in "losses in treatment process" below for figures shown in the above table

Waste Water Treatment								
		Turbidity	Solid weight	Treatment flow	flow after treatment	Recycle Water	Solid weight	note
		NTU	mg/l	m ³ /d	m ³ /d	m ³ /d	kg/d	
Sludge Buffer Tank	inflow		8,500	1,180	-		10,080	Sludge content 0.85 %
	outflow		8,500		1,180		10,080	Loss: 2.5%
Sludge Thickener	inflow		8,500	1,180			10,080	Sludge content 0.85%
	outflow		30,000		330		9,900	outflow to sludge drying bed 3% 28.3%
			210		850	850	180	supernatant water (sludge content) 0.02%
Sludge Drying Bed	inflow		30,000	330			9,900	
	inflow		329,000		30		9,870	Dewatered sludge (sludge content) 35%
			100		300	300	30	supernatant water
Waste Water Tank	inflow		210			850	180	Inflow from sludge thickener
			100			300	30	Inflow from sludge drying bed
			180			1,150	210	Total of supernatant water
	outflow		180			1,150	210	Turbidity of recycle water 0.02% (200mg/l)
Recycling	inflow		1,150			910	190	from waste water tank
			200			1,150	210	from Recycling Sump
			200			45,840	9,170	from Raw water 4.5%
			200			47,900	9,570	Total inflow

Loss in Treatment Process			
Clarifier: Treatment capacity	47,900 m ³ /d	Filter: Treatment capacity	46,690 m ³ /d
Turbidity	200 NTU	No. of filter for wash	4 filters/d
Alum Dosage (8% liquid Alum)	66 mg/l	Filter area	42.3 m ²
Solid	10,320 kg/d	Washing rate & time	
Sludge extraction		initial w/air	0.25 x 2min
Effluent to filter	5 mg/l	backwashing	0.5 x 8min
or 17,700 x 5(350+80x0.234) =	236 kg/d	Wahing waste water	190 m ³ /filter
	3%		760 m ³ /d
Sludge content	1%	Allowance	20%
Sludge volume	1,010 m ³ /d	Loss of Backwash waste water	910 m ³ /d
Allowance for design of	20%	Solid content in backwash waste water	1.9%
Loss of sludge extraction	2.5%	Turbidity of filtered water	1 mg/l
		Solid	190 kg/d
		Solid content	173 mg/l
Clear Water Reservoir		Total loss in treatment process	2,310 m ³ /s
Sludge content of filtered water	1 mg/l		5%
Minor water loss for plant operation	0.4%		
Loss of water	190 m ³ /d		

Attached Table 1-3a Volume of Sludge Buffer Tank

Maximum Turbidity (Sludge extraction: 4times/d)					
Time	Inflow	Outflow	Balance	Cumulative	
				150	
1		50	-50	100	
2		50	-50	50	
3		50	-50	0	
4	300	50	250	250	Sludge
5		50	-50	200	
6		50	-50	150	
7		50	-50	100	
8		50	-50	50	
9		50	-50	0	
10	300	50	250	250	Sludge
11		50	-50	200	
12		50	-50	150	
13		50	-50	100	
14		50	-50	50	
15		50	-50	0	
16	300	50	250	250	Sludge
17		50	-50	200	
18		50	-50	150	
19		50	-50	100	
20		50	-50	50	
21		50	-50	0	
22	300	50	250	250	Sludge
23		50	-50	200	
24		50	-50	150	
		1,200			
			Volume of Sludge Holding Tank	250	m ³

Attached Table 1-3b Volume of Waste Water Tank

(filter waging: 4 time/d, continuous inflow of supernatant)

Time	Infdlow				Outflow	Balance	Cumulative
	Backwash Waste Water	Spernatant1	Spernatant 2	Total			
							228
1		35	13	48	86	-38	190
2		35	13	48	86	-38	152
3		35	13	48	86	-38	114
4		35	13	48	86	-38	76
5		35	13	48	86	-38	38
6		35	13	48	86	-38	0
7	228	35	13	275	86	190	190
8		35	13	48	86	-38	152
9		35	13	48	86	-38	114
10		35	13	48	86	-38	76
11	228	35	13	275	86	190	266
12		35	13	48	86	-38	228
13		35	13	48	86	-38	190
14		35	13	48	86	-38	152
15	228	35	13	275	86	190	342
16		35	13	48	86	-38	304
17		35	13	48	86	-38	266
18		35	13	48	86	-38	228
19	228	35	13	275	86	190	418
20		35	13	48	86	-38	380
21		35	13	48	86	-38	342
22		35	13	48	86	-38	304
23		35	13	48	86	-38	266
24		35	13	48	86	-38	228
	910	850	300	2,060	2,060	-0	

Volume of Waste Water Tank 418

Backwash waste water and supernatant inflow

(refer to Attached Table 1-2 Mass balance)

backwash waste water	910 m3/d	4times/d
Supernatant 1 Sludge Thickener:	850 m3/d	24hours continuous
Supernatant 2 Sludge Drying Bed:	300 m3/d	24hours continuous

Attachment 1-1 Sludge Extraction of Sedimentation Tank


1 Sludge Volume

Turbidity	Maximum Turbidity			Annual Average Turbidity		
	Flow(m ³ /d)	Turbidity(NTU)	Sludge (kg)	Flow(m ³ /d)	Turbidity(NTU)	Sludge (kg)
	47,900	200	10,010	47,900	45	2,300
Flocculation Tank	5.0%		501			115
Settling Tank	95.0%		9,510			2,185
Sludge						
Sludge content (extraction):			1%			0.5%
Sludge volume (m ³ /d)			1,001			437
Flocculation Tank			50			22
Settling Tank			951			415

note: It is assumed that 5% of sludge is settled in the Flocculation Tank and remaining of 95% is in the Settling Tank.

2 Sludge Extraction

2.1 Layout of Sludge Extraction Piping



2.2 Sludge Extraction

Number of tank for Simultaneous Sludge Extraction	1 tank
Sludge Extraction per day	1 times/d
Interval of Sludge Extraction per Tank	6 h
per sludge hopper (simultaneous extraction from 2 hoppers)	45 min

2.3 Sludge Extraction Hydraulics


1) Levels

Water level of Sedimentation Tank (ST)	+	187.32 m
Overflow Weir Tip Level of Sludge Extraction Chamber (SEC)	+	185.76 m
Level Deference	Overflow height of weir	0.14 m
	Water level of ST - Overflow height of SEC)	1.42 m

2) Sludge Extraction Flow and Extraction Time

Sludge extraction flow per a hopper	35.1 l/s
Sludge extraction time per two hopper2 ホッパー 当たり	7.1 min
per tank	1.5 h

3) Hydraulic Analysis



(Max. Turbidity)

section 0 ~ 1:	$Q = q$ l/s	ND:	150 mm	length:	2.65 m
	$h1 = (f_i + f_b + f^*l/d) * v^2/2g =$				$405.4 q^2$
	where,	$f_i =$	0.5	$f_{b90} =$	0.3
		$f_{be} =$	1.1 ($f_{be} + f_{se}$)	$f \times l/d =$	0.60
		$V^2/2g =$	$163.5 q^2$		
section 1 ~ 2:	$Q = q$ l/s	ND:	200 mm	length-1:	1 m
	$Q = 2q$ l/s	ND:	200 mm	length-1:	12.45 m
	$h2 = f_1 \times l1/d \times v^2/2g + (f_2 \times l2/d + f_\gamma + 2 \times f_{b90} + f_v + f_{be}) \times v^2/2g =$				$491.1 q^2$
	where,	$f_1 \times l1/d =$	0.15	$f_2 \times l2/d =$	1.91
				$f_\gamma =$	0.87
				$f_{b90} =$	0.3
				$f_v =$	0.3 (B.V)
				$f_{be} =$	0.99

$f_\gamma = -(q\beta)^2 \times \{2.59 + 1.62x(-1) - 0.62x\phi\} - q\beta x(1.94 - \phi) + 0.03$			
where,	$q\beta =$	$\phi =$	0.56
$=$	0.874	$D\beta:$	150
		$D\gamma:$	200
$V1^2/2g =$	$51.7 q^2$	$V2^2/2g =$	$103.5 q^2$

section 2 ~ 5: Q = 2q l/s ND: 200 mm length: -
 Q = 2q l/s ND: 250 mm length: 13.8 m
 $h_3 = f_{se1} \times V_1^2/2g + (f \times l/d + 3f_{be} + f_{se2}) \times V_2^2/2g = 85.5 q^2$
 where, $f_{se1} = 0.13 (D_1/D_2 = 0.8)$ $f \times l/d = 0.62$
 $f_{be} = 0.99$
 $f_{se2} = 0.09 (D_1/D_2 = 0.83)$
 $V_1^2/2g = 103.5 q^2$ $V_2^2/2g = 42.4 q^2$

section 5 ~ 6: Q = 2q l/s ND: 300 mm length: 37.3 m
 $h_4 = (f_1 \times l_1/d + f_0) \times V^2/2g = 101.8 q^2$
 where, $f_1 \times l_1/d = 1.49$ $f_0 = 1.0$
 $V^2/2g = 40.89 q^2$

Weir Loss: Q = 2q l/s
 $h_w = (Q/CW)^{2/3} = 0.81 q^{2/3}$
 where, C = 1.84 (approx.)
 W = 1.5 m (weir length)

Total Head Loss:
 $\Delta H = h_1 + h_2 + h_3 + h_4 + h_5 + h_w = 1.5 m$
 $= 1,083.8 q^2 + 0.81 q^{2/3}$

Sludge Extraction

Extraction time		1 times/d
Interval of Sludge Extraction	per tank	6.0 hrs/tank
	per hopper	45 min/two hoppers
	extraction valve	2 hoppers/valve
WL of Sedimentation Tank		+ 187.32
Extraction Volume		951 m ³ /time
		3.7 * m ³ /d/hopper

note *: solid content in hopper is assumed as 4%

		1.41005	1.42005	1.43001
ΔH	m	1.41	1.42	1.43
Flow (q)	l/s	34.95	35.07	35.20
Flow (2q)	l/s	69.90	70.10	70.40
Time	min.			
Over flow height	m	0.137	0.138	0.138
Weir Level	m	185.77	185.76	185.75
Interval of S. Extraction				
per tank	hour	6	6	6
per hopper	min	45	45	45
Extraction time				
per tank	hour	1	1	1
per hopper	min	7.09	7.06	7.03
Velocity & H.Gradient				
	ND150			
Velocity	m/s	1.978	1.986	1.993
H.Gradient	‰	44.2	44.5	44.8
	ND200			
Velocity	m/s	2.226	2.232	2.242
H.Gradient	‰	78.5	79.6	79.6
	ND250			
Velocity	m/s	1.425	1.429	1.435
H.Gradient	‰	13.3	13.3	13.4
	ND300			
Velocity	m/s	0.989	0.992	0.996
H.Gradient	‰	5.5	5.5	5.5

2. Raw Water Quality and Chemical Dosage

2 Raw Water Quality and Chemical Dosage

2.1 Raw Water Quality

(1) Raw Water Quality Data

Existing old Jhal Khanuana water treatment plant (Old JK WTP: slow sand filtration plant) takes raw water from Rakh Branch Canal (RBC). High turbid raw water is reduced its turbidity in Raw Water Storage Reservoirs (RWSRs) for slow sand filtration. The planned rapid filtration plan will continues to intakes the same raw water source.

At the down stream of RBC, rapid sand filtration plant named New Jhal Kanuana Water Treatment Plant (New JK WTP) constructed under the financial aid of French Government is in operation using the same raw water. Water quality data from both water treatment plant, therefore available.

Important water quality parameters for plant design include water temperature, pH, turbidity, alkalinity. Inanition, water quality parameters of ammonium, iron and manganese are also required to grasp chlorine consumption.

Water quality Data of water temperature, pH and turbidity during 2012 ~ 14 period is available from Old JK WTP. And from New JK WTP, daily data is also available for the same water quality parameters during 2016 ~ 18 period. These data is presented in Attached Table 2-1 and 2-2.

Only limited water quality data is available for ammonium, iron and manganese. These water quality parameters are available from Master Plan Study as shown in Attached Table 2-3.

The present plan uses the existing RWSRs to reduce high turbidity of raw water for treatment. The effect of RWSR is able to estimate by comparing turbidities between raw water (canal water) and clarified water by RWSR. Data of Old JK WTP in 2012 ~ 14 show the reduction rate as 60 ~ 90% for raw water turbidity of 50 NTU or lower. For high turbidity raw water, the reduction rate is 80 ~ 90% against raw water turbidity of 50 ~ 500 NTU and very high rate of 96% ~ 97% for raw water turbidity of 500 ~ 800 NTU. These data may indicate large detention time of RWSR affect the above high turbidity reduction rate. However, these data varied widely as shown in Attached Table 2-1.

In the second site survey, settling test was carried out to grasp the effect of RWSR reduction of high turbidity of raw water. The rest results are shown in attached table 2-4 and summarized as follows:.

- Existing two RWSRs are available, each having detention time as 24 hours against planed treatment capacity of 47.900 m³/d.
- The test results show the following reduction of turbidity ranging 80 ~ 800 NTU and settling time.

Turbidity NTU	800	600	400	190	80
Settling time (hour)					
6	320	116	185	58	47
12	185	71	93	-	-
24	76	41	63	16	24

- From the above test results, it is estimated that 90% of reduction rate for high turbid water of 500 NTU or more and 70% of reduction rate for turbidity of 100 NTU or less in 24 hours settling time.

Following reduction rate of raw water is estimated taking the settling efficiency of RWSR into account.

Raw Water Turbidity (NTU)	< 50	100	150	250	> 500
Reduction Rate	60%	65%	70%	75%	80%

The estimated turbidity reduced in RWSR for one year is presented in Attached Table 2-5 using annual data of turbidity in 2017/18 obtained from New JK WTP.

For other water quality parameters of alkalinity, ammonium, iron and manganese, the following test results are shown in below table (refer to attached table 2-3).

Data source	Water Source	Water Quality Parameters			
		Alkalinity mg/l	Iron mg/l	manganese mg/l	Ammonium mg/l
Panjab prvince (2009)	Cenab River ^{*1}	-	0.81	0.02	-
WSA-F (2013 ~ 16)	RBC ^{*2}	-	-	-	0.3 (0.1 ~ 0.5)
JICA Team (2016)	Cenab River	110 ~ 133	0.18 ~ 0.3	< 0.01	< 0.01
in Master Plan Study	RBC ^{*2}	70 ~ 120	0.36 ~ 0.8	< 0.01	< 0.01

Note^{*1}: Water Source of RBC

^{*2}: Rakh Branch Canal figures in paretis show minimum-maximum

(2) Estimated Water Quality

Raw water of RBS is planned to be transfer to RWSR and water is treated using clarified water in RWSR. Turbidity of raw water will be therefore reduced significantly, on the other hand little change is expected for such water quality parameters as water temperature, pH, alkalinity, ammonium, iron and manganese. Reduction of turbidity will affect largely for chemical consumption for coagulation. On the other hand chlorine consumption will not be affected due to little change of ammonium, iron and manganese RWSR which affect chlorine consumption.

Future water quality is estimated for chemical application plan as shown in below table.

Water Quality Parameter	unit	Future Plan (2038)		
		Maximum	Average	Minimum
Water temperature	°C	30	33	11
pH	-	8.7	8.2	7.6
Turbidity	NTU	200	48	10
Alkalinity	mg/l	120	90	70
Ammonium	mg/l	0.05	0.03	0.01
Iron	mg/l	0.8	0.5	0.3
Manganese	mg/l	0.05	0.02	0.01

Note: Past water quality data (2017 ~ 2019) of RBC shows that high turbidities (more than 1000 NTU) occurs 1 ~ 5 times in July ~ August period, where the maximum turbidity was 1400 NTU. In design of water treatment, 1000 NTU is used as the maximum turbidity for consideration of economy.