

**Attached Table 2-1a Water Quality Data of RBC and RWSR**

| Date     | Water Temperature<br>°C | Canal Water      |     |              | Clarified Water  |     |              | Date     | Water Temperature<br>°C | Canal Water      |     |              | Clarified Water  |      |              |
|----------|-------------------------|------------------|-----|--------------|------------------|-----|--------------|----------|-------------------------|------------------|-----|--------------|------------------|------|--------------|
|          |                         | Turbidity<br>NTU | pH  | E.C<br>µs/cm | Turbidity<br>NTU | pH  | E.C<br>µs/cm |          |                         | Turbidity<br>NTU | pH  | E.C<br>µs/cm | Turbidity<br>NTU | pH   | E.C<br>µs/cm |
| 12.02.14 | 15.3                    | 42.1             | 7.4 | 258          |                  |     |              | 12.04.02 | 29.6                    | 103              | 7.7 | 349          | 4.8              | 8.0  | 305          |
| 12.02.15 | 15.3                    | 45.6             | 7.6 | 246          |                  |     |              | 12.04.18 | 28.3                    | 460              | 8.2 | 258          | 17.8             | 8.7  | 280          |
| 12.02.16 | 15.7                    | 22.2             | 7.2 | 246          |                  |     |              | 12.04.24 | 28.4                    | 126              | 8.5 | 282          | 10.2             | 9.0  | 260          |
| 12.02.17 | 15.7                    | 57.0             | 7.2 | 248          |                  |     |              | average  |                         | 230              | 8.1 | 296          | 10.9             | 8.6  | 282          |
| 12.02.18 | 15.8                    | 34.0             | 7.3 | 231          |                  |     |              | 12.05.07 | 33.6                    | 149              | 8.0 | 212          | 28.5             | 8.5  | 234          |
| 12.02.20 | 20.1                    | 52.0             | 7.1 | 227          | 1.5              | 7.3 | 215          | 12.05.12 | 35.0                    | 128              | 7.8 | 199.2        | 1.8              | 7.5  | 213          |
| 12.02.21 | 20.6                    | 7.1              | 7.5 | 244          |                  |     |              | average  |                         | 139              | 7.9 | 206          | 15.1             | 8.0  | 224          |
| 12.02.22 | 20.6                    | 11.9             | 6.5 | 254          |                  |     |              | 12.06.05 | 37.4                    | 138              | 6.7 | 184          | 3.6              | 8.0  | 183.7        |
| 12.02.23 | 20.5                    | 31.5             | 7.5 | 248          |                  |     |              | 12.06.12 | 36.4                    | 202              | 7.6 | 184.6        | 6.3              | 7.6  | 174.6        |
| 12.02.24 | 20.5                    | 36.2             | 7.6 | 250          |                  |     |              | 12.06.26 | 38.3                    | 18.2             | 8.4 | 154          | 5.5              | 8.6  | 151          |
| 12.02.25 | 20.6                    | 36.2             | 7.6 | 247          |                  |     |              | average  |                         | 119              | 7.5 | 174          | 5.1              | 8.1  | 169.8        |
| 12.02.27 | 21.0                    | 35.8             | 7.6 | 240          | 1.4              | 7.7 | 247          |          |                         |                  |     |              |                  |      |              |
| average  | 18.5                    | 34.3             | 7.3 | 245          | 1.4              |     |              | 12.07.24 | 34.6                    | 136              | 8.3 | 156          | 16.1             | 8.7  | 158          |
| 12.03.02 | 20.6                    | 51.0             | 7.6 | 258          |                  |     |              |          |                         |                  |     |              |                  |      |              |
| 12.03.05 | 20.8                    | 48.5             | 7.4 | 274          | 1.9              | 7.2 | 230          | 12.08.01 | 35.3                    | 158              | 7.9 | 176          | 16.6             | 7.75 | 161          |
| 12.03.06 | 20.6                    | 25.5             | 7.3 | 271          |                  |     |              | 12.08.07 | 34.1                    | 799              | 8.0 | 164          | 24.1             | 8.6  | 157          |
| 12.03.07 | 20.5                    | 12.4             | 7.7 | 271          |                  |     |              | 12.08.15 | 33.6                    | 232              | 7.6 | 189          | 16.0             | 8.0  | 167          |
| 12.03.09 | 21.5                    | 103              | 7.7 | 264          |                  |     |              | average  |                         | 396              | 7.8 | 176          | 18.9             | 8.1  | 162          |
| 12.03.10 | 20.5                    | 357              | 7.6 | 258          |                  |     |              |          |                         |                  |     |              |                  |      |              |
| 12.03.12 | 23.6                    | 10.7             | 8.2 | 251          | 4.4              | 8.1 | 246          |          |                         |                  |     |              |                  |      |              |
| 12.03.21 | 22.5                    | 92.0             | 8.2 | 295          |                  |     |              |          |                         |                  |     |              |                  |      |              |
| average  | 21.3                    | 87.5             | 7.7 | 268          | 3.1              |     |              |          |                         |                  |     |              |                  |      |              |

**Attached Table 2-1b**

**Turbidity Change between RBC and RWSR Water**

| Year                  | Season  | Monthly <sup>1</sup><br>Precipitation<br>mm | Canal Water |            |         | Raw Water Tank |            |         |
|-----------------------|---------|---|-------------|------------|---------|----------------|------------|---------|
|                       |         |   | Sample No.  | Range      | Average | Sample No.     | Range      | Average |
| 2012                  |         |   |             | NTU        | NTU     |                | NTU        | NTU     |
| January               | transit | 53.2  | -           | -          | -       | -              | -          | -       |
| February              | dry     | 17.7  | 12          | 7.1 ~ 57   | 34.3    | 2              | 1.4 ~ 1.5  | 1.4     |
| March                 | dry     | 25.0  | 8           | 10.7 ~ 357 | 87.5    | 2              | 1.9 ~ 4.4  | 3.1     |
| April                 | transit | 58.2  | 3           | 103 ~ 460  | 230     | 3              | 4.7 ~ 17.8 | 10.9    |
| May                   | dry     | 15.4  | 2           | 128 ~ 139  | 139     | 2              | 1.8 ~ 28.5 | 15.1    |
| June                  | dry     | 24.6  | 3           | 18.2 ~ 138 | 119     | 3              | 3.6 ~ 6.3  | 5.1     |
| July                  | wet     | 109.6                                       | 1           | 136        | -       | 1              | 16.1       | -       |
| August                | wet     | 89.5  | 3           | 158 ~ 799  | 396     | 3              | 16 ~ 24.1  | 18.9    |
| September             | transit | 34.1  | -           | -          | -       | -              | -          | -       |
| October               | dry     | 5.9   | -           | -          | -       | -              | -          | -       |
| November              | dry     | 3.6   | -           | -          | -       | -              | -          | -       |
| December              | dry     | 9.1   | -           | -          | -       | -              | -          | -       |
| Annual                |         |   | 32          | 7.1 ~ 799  | 163     | 16             | 1.4 ~ 28.5 | 10.1    |
| 2013                  |         |   |             |            |         |                |            |         |
| June                  | dry     | -   | 1           | 273        | -       | -              | -          | -       |
| 2014                  |         |   |             |            |         |                |            |         |
| February              | dry     | 17.7  | 1           | 17.1       | -       | -              | -          | -       |
| March                 | dry     | 25.0  | 4           | 3.2 ~ 5.6  | 3.9     | -              | -          | -       |
| April                 | transit | 58.2  | 5           | 3.4 ~ 4.7  | 3.9     | -              | -          | -       |
| Average               |         |   | 10          | 3.2 ~ 17.6 | 6.3     | -              | -          | -       |
| 2016                  |         |   |             |            |         |                |            |         |
| November <sup>2</sup> | dry     | -   | 1           | 28         | -       | 1              | 8.5        | -       |

note <sup>1</sup>: CLIMATICAL DATA - from M/P by World Bank (1953~1991)

<sup>2</sup>: by JICA Mission Team

**Attached Table 2-1c**

**Effect of RWSR**

| Range     | sample no. | Raw water | Clarified W. | Reduction Rate |
|-----------|------------|-----------|--------------|----------------|
| < 50      | 1          | 36        | 1.4          | 96%            |
|           | 2          | 49        | 1.9          | 96%            |
|           | 3          | 11        | 4.4          | 59%            |
|           | 4          | 18        | 5.5          | 70%            |
|           | average    | 28        | 3.3          | 88%            |
| 50 - 100  | 1          | 52        | 1.5          | 97%            |
| 100 - 150 | 1          | 103       | 4.8          | 95%            |
|           | 2          | 126       | 10.2         | 92%            |
|           | 3          | 149       | 28.5         | 81%            |
|           | 4          | 128       | 1.8          | 99%            |
|           | 5          | 138       | 3.6          | 97%            |
|           | 6          | 136       | 16.1         | 88%            |
|           | average    | 130       | 11           | 92%            |
| 150 - 200 |            | 158       | 16.6         | 90%            |
| 200 - 250 |            | 232       | 16.0         | 93%            |
| 250 - 300 |            | -         | -            | -              |
| 300 - 400 |            | -         | -            | -              |
| 400 - 500 |            | 460       | 17.8         | 96%            |
| >500      |            | 799       | 24.1         | 97%            |

**Attached Table 2-2a Raw Water Quality – Water Temperature**

New Jhal Khanuana WTP  
Year: 2017/18

| Month         | 7    | 8    | 9    | 10   | 11   | 12   | 1    | 2    | 3    | 4    | 5    | 6    |
|---------------|------|------|------|------|------|------|------|------|------|------|------|------|
| 1             | 26.1 | 27.2 | 27.3 | -    | -    | 17.1 | 13.2 | -    | -    | -    | 25.7 | 26.4 |
| 2             | 26.1 | 26.9 | -    | 26.4 | -    | 17.1 | 13.3 | -    | -    | -    | 26.4 | 27.5 |
| 3             | 27.0 | 26.9 | 27.5 | 26.8 | 22.3 | 17.1 | 13.2 | -    | -    | -    | 25.8 | 26.5 |
| 4             | 27.3 | 27.3 | 28.0 | 26.7 | 21.2 | 16.7 | 12.4 | -    | -    | 25.5 | 26.3 | 27.9 |
| 5             | 26.5 | 27.2 | 27.1 | 25.8 | -    | 15.9 | 12.5 | -    | -    | 25.2 | 25.7 | 29.0 |
| 6             | 27.6 | -    | 27.7 | 26.8 | -    | 15.8 | 12.2 | -    | -    | 28.3 | 26.4 | 27.7 |
| 7             | 26.0 | 29.1 | 27.2 | 26.9 | -    | 15.1 | 11.2 | 14.4 | -    | 28.2 | 24.4 | 28.6 |
| 8             | 27.5 | 29.2 | 27.8 | -    | -    | 17.5 | 13.0 | 14.3 | 18.9 | 26.2 | 24.4 | 30.2 |
| 9             | 28.5 | 29.4 | -    | 26.3 | -    | 16.1 | 13.7 | 14.1 | 20.7 | 25.5 | 28.2 | 28.1 |
| 10            | 28.5 | 29.4 | -    | 26.8 | 21.4 | 15.4 | 12.5 | 14.2 | 21.1 | 26.2 | 26.6 | 27.2 |
| 11            | -    | 29.0 | -    | 26.6 | 19.9 | 15.5 | 14.5 | -    | 22.3 | 25.1 | 26.1 | 27.3 |
| 12            | -    | 29.2 | -    | 26.6 | -    | 16.4 | 13.0 | 13.4 | 22.2 | 25.2 | 27.4 | 27.3 |
| 13            | 26.9 | -    | -    | 25.8 | 19.6 | 15.1 | 12.7 | 13.8 | 22.5 | 25.7 | 25.2 | 26.9 |
| 14            | 27.4 | -    | 27.0 | 25.5 | 20.1 | 14.9 | 14.9 | 14.3 | 22.9 | 24.6 | 25.6 | 27.1 |
| 15            | 27.6 | 28.2 | -    | -    | 19.0 | 14.2 | 14.2 | 15.2 | 22.5 | 27.6 | 26.1 | 27.9 |
| 16            | 28.1 | 27.8 | 26.8 | 24.8 | 18.5 | 13.8 | 14.9 | 15.4 | 22.1 | 25.6 | 25.1 | 26.2 |
| 17            | 28.1 | 28.2 | -    | 26.2 | 18.9 | 13.5 | 15.1 | 15.5 | 22.0 | 25.3 | 26.2 | 26.7 |
| 18            | -    | 29.1 | 27.0 | 26.5 | 18.3 | 13.7 | -    | -    | -    | 25.3 | 26.5 | 27.1 |
| 19            | 27.7 | 30.4 | 27.9 | 25.4 | -    | 14.5 | -    | 17.2 | 22.2 | 25.5 | 26.0 | 26.8 |
| 20            | 27.9 | -    | 27.9 | 25.4 | 18.5 | 14.2 | -    | 17.8 | 22.1 | -    | 27.2 | 28.9 |
| 21            | 28.0 | 30.3 | 27.3 | 25.1 | 18.0 | -    | -    | 17.7 | 20.3 | -    | 25.6 | 26.9 |
| 22            | 27.0 | 29.2 | 27.7 | -    | 18.1 | -    | -    | 18.3 | 20.0 | -    | 26.0 | 29.2 |
| 23            | 27.6 | 29.4 | 27.7 | -    | 17.9 | -    | -    | 18.5 | 21.2 | -    | 27.3 | 28.3 |
| 24            | 26.5 | 29.1 | -    | -    | 18.1 | 14.0 | -    | 17.9 | 21.0 | -    | 26.9 | 32.5 |
| 25            | 27.5 | 28.9 | 27.7 | -    | 18.9 | 14.2 | -    | 19.1 | 20.2 | -    | 27.4 | 29.0 |
| 26            | 28.1 | 28.2 | 27.5 | -    | -    | -    | -    | 18.5 | -    | 25.1 | 25.7 | 28.5 |
| 27            | 27.9 | -    | 30.0 | -    | 18.1 | -    | -    | 18.9 | -    | 27.2 | 26.2 | 28.4 |
| 28            | 28.3 | 28.2 | 26.8 | -    | 17.5 | 14.7 | -    | 20.4 | -    | 27.6 | 27.3 | 28.1 |
| 29            | 26.8 | 27.9 | -    | -    | 17.3 | 14.2 | -    | -    | -    | 27.9 | 26.8 | 25.8 |
| 30            | 28.3 | 27.7 | 28.0 | -    | 17.2 | 13.2 | -    | -    | -    | 26.2 | 26.7 | -    |
| 31            | 27.7 | 27.1 | -    | -    | -    | 12.7 | -    | -    | -    | -    | 27.4 | -    |
| No. of Sample | 28   | 26   | 20   | 18   | 20   | 26   | 17   | 20   | 17   | 21   | 31   | 29   |
| Minimum       | 26.0 | 27.1 | 26.8 | 24.8 | 17.2 | 12.7 | 11.2 | 13.4 | 18.9 | 24.6 | 24.4 | 25.8 |
| Average       | 27.4 | 28.5 | 27.6 | 26.1 | 18.9 | 15.1 | 13.3 | 16.4 | 21.4 | 26.1 | 26.3 | 27.9 |
| Maximum       | 28.5 | 30.4 | 28.0 | 26.9 | 22.3 | 17.5 | 15.1 | 20.4 | 22.9 | 28.3 | 28.2 | 30.2 |

| Water Quality Water Temperature (°C) |      | NEW JHAL KHANUANA WTP, 2017/18 |      |      |      |      |      |      |      |      |      |      |      |
|--------------------------------------|------|--------------------------------|------|------|------|------|------|------|------|------|------|------|------|
|                                      | 7    | 8                              | 9    | 10   | 11   | 12   | 1    | 2    | 3    | 4    | 5    | 6    | Ave. |
| <b>Wet Season</b>                    |      |                                |      |      |      |      |      |      |      |      |      |      |      |
| Maximum                              | 28.5 | 30.4                           | 28.0 |      |      |      |      |      |      | 28.3 | 28.2 | 30.2 | 28.9 |
| Average                              | 27.4 | 28.5                           | 27.6 |      |      |      |      |      |      | 26.1 | 26.3 | 27.9 | 27.3 |
| Minimum                              | 26.0 | 27.1                           | 26.8 |      |      |      |      |      |      | 24.6 | 24.4 | 25.8 | 25.8 |
| <b>Dry Season</b>                    |      |                                |      |      |      |      |      |      |      |      |      |      |      |
| Maximum                              |      |                                |      | 26.9 | 22.3 | 17.5 | 15.1 | 20.4 | 22.9 |      |      |      | 20.9 |
| Average                              |      |                                |      | 26.1 | 18.9 | 15.1 | 13.3 | 16.4 | 21.4 |      |      |      | 18.5 |
| Minimum                              |      |                                |      | 24.8 | 17.2 | 12.7 | 11.2 | 13.4 | 18.9 |      |      |      | 16.4 |
| <b>Annal Average</b>                 |      |                                |      |      |      |      |      |      |      |      |      |      |      |
| Maximum                              |      |                                |      |      |      |      |      |      |      |      |      |      | 24.9 |
| Average                              |      |                                |      |      |      |      |      |      |      |      |      |      | 22.9 |
| Minimum                              |      |                                |      |      |      |      |      |      |      |      |      |      | 21.1 |



**Attached Table 2-2b Raw Water Quality - pH**

New Jhal Khanuana WTP

Year: 2018/19

| Month         | 7   | 8   | 9   | 10  | 11   | 12  | 1   | 2    | 3   | 4   | 5   | 6   |
|---------------|-----|-----|-----|-----|------|-----|-----|------|-----|-----|-----|-----|
| 1             | 8.6 | 8.6 | 8.7 | -   | -    | 8.1 | 8.2 | -    | -   | -   | 7.8 | 8.1 |
| 2             | 8.5 | 8.6 | -   | 7.7 | -    | 8.1 | 8.0 | -    | -   | -   | 8.0 | 8.1 |
| 3             | 8.5 | 8.6 | 8.7 | 7.7 | 7.9  | 8.1 | 8.1 | -    | -   | -   | 8.0 | 8.1 |
| 4             | 8.5 | 8.6 | 8.7 | 7.7 | 7.9  | 8.1 | 8.1 | -    | -   | 8.1 | 8.0 | 8.1 |
| 5             | 8.6 | 8.6 | 8.7 | 7.8 | -    | 8.1 | 8.1 | -    | -   | 8.1 | 8.0 | 8.1 |
| 6             | 8.6 | -   | 8.6 | 7.8 | -    | 8.1 | 8.1 | -    | -   | 8.1 | 8.0 | 8.1 |
| 7             | 8.6 | 8.6 | 8.7 | 7.7 | -    | 8.1 | 8.0 | 8.4  | -   | 8.1 | 8.1 | 8.1 |
| 8             | 8.5 | 8.6 | 8.7 | -   | -    | 8.1 | 8.1 | 8.4  | 8.3 | 8.1 | 8.1 | 8.1 |
| 9             | 8.5 | 8.6 | -   | 7.8 | -    | 8.1 | 8.1 | 8.4  | 8.1 | 8.1 | 8.0 | 8.0 |
| 10            | 8.5 | 8.6 | -   | 7.8 | 8.0  | 8.1 | 8.1 | 8.4  | 8.1 | 8.1 | 8.0 | 8.1 |
| 11            | -   | 8.6 | -   | 7.8 | 7.9  | 8.1 | 8.1 | -    | 8.1 | 8.1 | 8.0 | 8.2 |
| 12            | -   | 8.6 | -   | 7.8 | -    | 8.1 | 8.1 | 8.4  | 8.1 | 8.0 | 8.0 | 8.2 |
| 13            | 8.6 | -   | -   | 7.8 | 7.9  | 8.1 | 8.1 | 8.4  | 8.1 | 8.1 | 8.0 | 8.2 |
| 14            | 8.6 | -   | 8.7 | 7.8 | 7.8  | 8.1 | 8.3 | 8.2  | 8.1 | 8.1 | 8.1 | 8.2 |
| 15            | 8.6 | 8.6 | -   | -   | 7.8  | 8.1 | 8.3 | 8.2  | 8.1 | 8.0 | 8.1 | 8.2 |
| 16            | 8.5 | 8.6 | 8.7 | 7.8 | 7.9  | 8.1 | 8.4 | 8.2  | 8.1 | 8.0 | 8.1 | 8.1 |
| 17            | 8.5 | 8.6 | -   | 7.8 | 7.9  | 8.1 | 8.5 | 8.3  | 8.2 | 8.0 | 8.0 | 8.2 |
| 18            | -   | 8.6 | 7.9 | 7.8 | 7.8  | 8.0 | -   | -    | -   | 8.0 | 8.1 | 8.2 |
| 19            | 8.6 | 8.6 | 7.7 | 7.9 | -    | 8.1 | -   | 8.3  | 8.1 | 8.0 | 8.9 | 8.2 |
| 20            | 8.6 | -   | 7.8 | 7.8 | 7.9  | 8.1 | -   | 8.3  | 8.1 | 0.0 | 8.1 | 8.2 |
| 21            | 8.6 | 8.7 | 7.7 | 7.8 | 7.9  | -   | -   | 8.3  | 8.1 | 0.0 | 8.1 | 8.2 |
| 22            | 8.5 | 8.6 | 7.7 | -   | 8.0  | -   | -   | 8.2  | 8.1 | -   | 8.1 | 8.1 |
| 23            | 8.6 | 8.7 | 7.7 | -   | 8.0  | -   | -   | 8.2  | 8.1 | -   | 8.1 | 8.4 |
| 24            | 8.5 | 8.7 | -   | -   | 8.1  | 8.2 | -   | 8.2  | 8.1 | -   | 8.1 | 8.2 |
| 25            | 8.6 | 8.7 | 7.7 | -   | 8.7  | 8.2 | -   | 8.2  | 8.6 | -   | 8.1 | 8.2 |
| 26            | 8.5 | 8.6 | 7.7 | -   | -    | -   | -   | 8.3  | -   | 8.0 | 8.1 | 8.1 |
| 27            | 8.5 | -   | 7.6 | -   | 8.1  | -   | -   | 8.3  | -   | 8.0 | 8.1 | 8.2 |
| 28            | 8.6 | 8.6 | 7.6 | -   | 8.0  | 8.3 | -   | 8.4  | -   | 8.0 | 8.1 | 8.2 |
| 29            | 8.6 | 8.6 | -   | -   | 8.0  | 8.3 | -   | -    | -   | 8.1 | 8.1 | 8.2 |
| 30            | 8.6 | 8.7 | 7.8 | -   | 8.0  | 8.1 | -   | -    | -   | 8.0 | 8.1 | -   |
| 31            | 8.5 | 8.7 | -   | -   | -    | 8.2 | -   | -    | -   | 0.0 | 8.1 | -   |
| No. of Sample | 29  | 31  | 30  | 22  | 28   | 31  | 16  | 7    | 28  |     |     |     |
| Minimum       | 8.5 | 8.6 | 7.6 | -   | 7.97 | 8.2 | 8.1 | 8.2  | -   |     |     |     |
| Average       | 8.3 | 7.2 | 5.4 | 6.4 | 5.7  | 6.8 | 8.7 | 23.7 | 4.9 |     |     |     |
| Maximum       | 8.6 | 8.6 | -   | -   | 8.7  | 8.1 | 8.4 | 8.2  | 8.2 |     |     |     |

Water Quality - pH

NEW JHAL KHANUANA WTP, 2017/18

|               | 7   | 8   | 9   | 10  | 11  | 12  | 1   | 2   | 3   | 4   | 5   | 6   | Ave. |
|---------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|------|
| Wet Season    |     |     |     |     |     |     |     |     |     |     |     |     |      |
| Maximum       | 8.5 | 8.6 | 7.6 |     |     |     |     |     |     | 8.1 | 8.1 | 8.2 | 8.2  |
| Average       | 8.3 | 7.2 | 5.4 |     |     |     |     |     |     | 8.0 | 8.1 | 8.1 | 7.5  |
| Minimum       | 8.5 | 8.6 | 7.6 |     |     |     |     |     |     | 8.0 | 7.8 | 8.0 | 8.1  |
| Dry Season    |     |     |     |     |     |     |     |     |     |     |     |     |      |
| Maximum       |     |     |     | 7.9 | 8.7 | 8.3 | 8.5 | 8.4 | 8.6 |     |     |     | 8.4  |
| Average       |     |     |     | 7.8 | 8.0 | 8.1 | 8.2 | 8.3 | 8.1 |     |     |     | 8.1  |
| Minimum       |     |     |     | 7.7 | 7.8 | 8.0 | 8.0 | 8.2 | 8.1 |     |     |     | 8.0  |
| Annal Average |     |     |     |     |     |     |     |     |     |     |     |     |      |
| Maximum       |     |     |     |     |     |     |     |     |     |     |     |     | 8.3  |
| Average       |     |     |     |     |     |     |     |     |     |     |     |     | 7.8  |
| Minimum       |     |     |     |     |     |     |     |     |     |     |     |     | 8.0  |

**Attached Table 2-2c Raw Water Quality - Turbidity**

New Jhal Khanuana WTP

Year: 2017/18

| Month         | 7    | 8    | 9   | 10  | 11    | 12   | 1     | 2     | 3   | 4     | 5   | 6   |
|---------------|------|------|-----|-----|-------|------|-------|-------|-----|-------|-----|-----|
| 1             | 381  | 792  | 272 | -   | -     | 34   | 30    | -     | -   | -     | 182 | 114 |
| 2             | 306  | 702  | -   | 91  | -     | 32   | 91    | -     | -   | -     | 202 | 127 |
| 3             | 839  | 850  | 250 | 101 | 48    | 35   | 32.5  | -     | -   | -     | 162 | 137 |
| 4             | 719  | 972  | 304 | 94  | 34    | 32   | 40    | -     | -   | 144   | 160 | 180 |
| 5             | 495  | 1310 | 431 | 81  | 60.52 | 29   | 36    | -     | -   | 142   | 149 | 259 |
| 6             | 499  | -    | 423 | 81  | -     | 32   | 43    | -     | -   | 125   | 151 | 155 |
| 7             | 542  | 1365 | 249 | 77  | -     | 30   | 74    | 20    | -   | 116   | 240 | 128 |
| 8             | 522  | 510  | 230 | -   | -     | 28   | 70    | 33.1  | 26  | 113   | 236 | 191 |
| 9             | 298  | 476  | -   | 76  | -     | 32   | 69.1  | 36.35 | 85  | 117   | 150 | 285 |
| 10            | 320  | 610  | -   | 78  | 77    | 30   | 70    | 35.1  | 85  | 139   | 112 | 275 |
| 11            | -    | 726  | -   | 73  | -     | 30.2 | 65.1  | -     | 77  | 159   | 141 | 506 |
| 12            | -    | 580  | -   | 74  | -     | 30   | 42.8  | 34    | 67  | 144   | 130 | 593 |
| 13            | 320  | -    | -   | 74  | 67    | 28   | 43    | 28.4  | 63  | 156.3 | 145 | 655 |
| 14            | 423  | -    | 207 | 109 | 77    | 30   | 27.77 | 28.69 | 72  | 115   | 131 | 465 |
| 15            | 520  | 542  | -   | -   | 65    | 30   | 10    | 29    | 72  | 101   | 82  | 428 |
| 16            | 740  | 576  | 149 | 65  | 63    | 67   | 7.77  | 125   | 68  | 127   | 32  | 300 |
| 17            | 328  | 660  | -   | 72  | 52.67 | 140  | 2.7   | 68    | 67  | 185.1 | 173 | 288 |
| 18            | -    | 517  | 123 | 65  | 60.2  | 115  | -     | -     | -   | 211   | 164 | 346 |
| 19            | 820  | 360  | 128 | 65  | -     | 111  | -     | 38.9  | 94  | 150   | 171 | 360 |
| 20            | 970  | -    | 106 | 45  | 42    | 61   | -     | 39    | 105 | -     | 165 | 388 |
| 21            | 1033 | 297  | 108 | 45  | 40    | -    | -     | 34    | 130 | -     | 141 | 296 |
| 22            | 1436 | 351  | 113 | -   | 34    | -    | -     | 33    | 124 | -     | 127 | 264 |
| 23            | 876  | 322  | 115 | -   | 39    | -    | -     | 32.41 | 108 | -     | 125 | 220 |
| 24            | 792  | 360  | -   | -   | 38    | 22   | -     | 34    | 123 | -     | 122 | 92  |
| 25            | 488  | 267  | 110 | -   | 39    | 28   | -     | 35    | 124 | -     | 119 | 245 |
| 26            | 552  | 324  | 106 | -   | -     | -    | -     | 24    | -   | -     | 115 | 227 |
| 27            | 545  | -    | 107 | -   | 33    | -    | -     | 22    | -   | 160   | 125 | 201 |
| 28            | 600  | 388  | 107 | -   | 31    | 40   | -     | 7.9   | -   | 231   | 110 | 138 |
| 29            | 478  | 458  | -   | -   | 34    | 24   | -     | -     | -   | 227   | 130 | 145 |
| 30            | 508  | 309  | 102 | -   | 35    | 32   | -     | -     | -   | 202   | 113 | -   |
| 31            | 528  | 221  | -   | -   | -     | 30   | -     | -     | -   | -     | 110 | -   |
| No. of Sample | 28   | 26   | 20  | 18  | 20    | 26   | 14    | 19    | 17  | 20    | 31  | 29  |
| Minimum       | 298  | 221  | 102 | 45  | 31    | 22   | 28    | 20    | 26  | 101   | 32  | 92  |
| Average       | 603  | 571  | 187 | 76  | 48    | 44   | 52    | 39    | 88  | 153   | 142 | 276 |
| Maximum       | 1436 | 1365 | 431 | 109 | 77    | 140  | 91    | 125   | 130 | 231   | 240 | 655 |

| Water Quality - Turbidity (NTU) |       |       |     |     |    |     |    |     |     |     |     |     | NEW JHAL KHANUANA WTP, 2017/18 |  |
|---------------------------------|-------|-------|-----|-----|----|-----|----|-----|-----|-----|-----|-----|--------------------------------|--|
|                                 | 7     | 8     | 9   | 10  | 11 | 12  | 1  | 2   | 3   | 4   | 5   | 6   | Ave.                           |  |
| <b>Wet Season</b>               |       |       |     |     |    |     |    |     |     |     |     |     |                                |  |
| Maximum                         | 1,436 | 1,365 | 431 |     |    |     |    |     |     | 231 | 240 | 655 | 726                            |  |
| Average                         | 603   | 571   | 187 |     |    |     |    |     |     | 153 | 142 | 276 | 322                            |  |
| Minimum                         | 298   | 221   | 102 |     |    |     |    |     |     | 101 | 32  | 92  | 141                            |  |
| <b>Dry Season</b>               |       |       |     |     |    |     |    |     |     |     |     |     |                                |  |
| Maximum                         |       |       |     | 109 | 77 | 140 | 91 | 125 | 130 |     |     |     | 112                            |  |
| Average                         |       |       |     | 76  | 48 | 44  | 52 | 39  | 88  |     |     |     | 58                             |  |
| Minimum                         |       |       |     | 45  | 31 | 22  | 28 | 20  | 26  |     |     |     | 29                             |  |
| <b>Annal Average</b>            |       |       |     |     |    |     |    |     |     |     |     |     |                                |  |
| Maximum                         |       |       |     |     |    |     |    |     |     |     |     |     | 419                            |  |
| Average                         |       |       |     |     |    |     |    |     |     |     |     |     | 190                            |  |
| Minimum                         |       |       |     |     |    |     |    |     |     |     |     |     | 85                             |  |



**Attached Table 2-3a**

Water Quality Test Result by JICA Consultant  
In M/P

| Sr. No. | Parameter                              | Unit                 | Chenab River          |                       | RBC                   |                       |
|---------|--|----------------------|-----------------------|-----------------------|-----------------------|-----------------------|
|         |  |                      | 23 Sep'16             | 16 Nov'16             | 23 Sep'16             | 16 Nov'16             |
| 1       | Temperature                            | °C                   | 31.9                  | 21.0                  | 27                    | 18.8                  |
| 2       | Turbidity                              | NTU                  | 8                     | 15                    | 57                    | 36                    |
| 3       | Colour                                 | TCU                  | 11                    | 0.7                   | 5.5                   | 0.8                   |
| 4       | pH                                     | -                    | 8.6                   | 8.09                  | 8.2                   | 8.83                  |
| 5       | EC                                     | µS/cm                | 296                   | 330                   | 193                   | 197                   |
| 6       | Hardness                               | mg/l                 | 82                    | 130                   | 88                    | 104                   |
| 7       | Total Alkalinity                       | mg/l                 | 110                   | 133                   | 70                    | 120                   |
| 8       | Chloride CL                            | mg/l                 | 60                    | 40                    | 70                    | 30                    |
| 9       | Total Dissolved Solids                 | TDS mg/l             | 222                   | 227                   | 140                   | 141                   |
| 10      | Dissolved oxygen                       | DO mg/l              | 3.75                  | 5.08                  | 5.64                  | 5.04                  |
| 11      | Nitrite-N                              | NO <sub>2</sub> mg/l | 0.11                  | 0.04                  | 0.19                  | 0.05                  |
| 12      | Nitrate-N                              | NO <sub>3</sub> mg/l | 3.3                   | 4.7                   | 5.5                   | 4.9                   |
| 13      | Ammonia NH <sub>3</sub>                | mg/l                 | <0.01                 | <0.01                 | <0.01                 | <0.01                 |
| 14      | Chemical Oxygen Demand                 | CODcr mg/l           | 38                    | 71                    | 32                    | 22                    |
| 15      | Sulphate SO <sub>4</sub> <sup>2-</sup> | mg/l                 | 28                    | 33                    | 22                    | 32                    |
| 16      | Fluoride F                             | mg/l                 | 3.0 (1.13)            | 0.30 (0.01)           | 4.8 (0.95)            | 0.11(<0.01)           |
| 17      | Manganese Mn                           | mg/l                 | <0.01                 | 0.01                  | <0.01                 | <0.01                 |
| 18      | Iron Fe                                | mg/l                 | 0.32                  | 0.18                  | 1.83                  | 0.36                  |
| 19      | Calcium Ca                             | mg/l                 | 31                    | 36                    | 21                    | 30                    |
| 20      | Sodium Na                              | mg/l                 | 48                    | 9.2                   | 55                    | 13.8                  |
| 21      | Magnesium Mg                           | mg/l                 | <0.01                 | 10                    | <0.01                 | 7                     |
| 22      | Aluminium Al                           | mg/l                 | <0.020                | <0.020                | <0.020                | <0.020                |
| 23      | Antimony Sb                            | mg/l                 | 0.186                 | 0.115                 | 0.139                 | 0.298                 |
| 24      | Barium Ba                              | mg/l                 | < 0.70                | < 0.70                | < 0.70                | < 0.70                |
| 25      | Cadmium Cd                             | mg/l                 | < 0.002               | < 0.002               | < 0.002               | < 0.002               |
| 26      | Chromium Cr                            | mg/l                 | 0.40                  | <0.01                 | 0.30                  | <0.01                 |
| 27      | Copper Cu                              | mg/l                 | < 0.002               | < 0.002               | < 0.002               | < 0.002               |
| 28      | Lead Pb                                | mg/l                 | <0.01                 | <0.01                 | <0.01                 | <0.01                 |
| 29      | Mercury Hg                             | mg/l                 | <0.001                | <0.001                | <0.001                | <0.001                |
| 30      | Nickel Ni                              | mg/l                 | <0.020                | <0.020                | <0.020                | <0.020                |
| 31      | Selenium Se                            | mg/l                 | 0.37                  | < 0.04                | 0.35                  | < 0.04                |
| 32      | Zinc Zn                                | mg/l                 | < 0.05                | < 0.05                | < 0.05                | < 0.05                |
| 33      | Cyanoid CN                             | mg/l                 | < 0.002               | < 0.002               | < 0.002               | < 0.002               |
| 34      | Total Arsenic As                       | mg/l                 | 0.004                 | 0.006                 | 0.002                 | 0.002                 |
|         | Soluble Arsenic As                     | mg/l                 | 0.004                 | 0.005                 | 0.002                 | 0.002                 |
| 35      | Bacteria                               | MPN/100mg            | 24                    | 3.4 x 10 <sup>2</sup> | 120                   | 4.1 x 10 <sup>2</sup> |
| 36      | E. Coli                                | MPN/100mg            | 5.1 x 10 <sup>2</sup> | 2.0 x 10 <sup>2</sup> | 5.1 x 10 <sup>2</sup> | 2.5 x 10 <sup>2</sup> |

Data Source: The Project for Water Supply, Sewage and Drainage Master Plan of Faisalabad

**Attached Table 2-3b**

Past Water Quality Test Results  
in M/P

| Sr. No. | Parameter                   | Unit | Chenab R <sup>*1</sup> | JBC <sup>*2</sup> | RBC <sup>*3</sup> |
|---------|-----------------------------|------|------------------------|-------------------|-------------------|
|         |                             |      | 2009                   | 2016              | 2013 ~ 16         |
| 1       | Temperature                 | °C   | 15.5 ~ 18.0            | -                 | 20 ~ 31           |
| 2       | pH                          | -    | 7.9 ~ 8.1              | 8.3 ~ 8.8         | 7.7 ~ 8.6         |
| 3       | DO                          | mg/l | 8.0 ~ 8.4              | 4                 | -                 |
| 4       | BOD                         | mg/l | 4.0 ~ 6.0              | -                 | -                 |
| 5       | COD                         | mg/l | 11.6 ~ 24.8            | 15                | -                 |
| 6       | Total Dissolved Solid (TDS) | mg/l | 280 ~ 780              | 140 ~ 176         | 100 ~ 160         |
| 7       | Total Suspended Solid (TSS) | mg/l | 20 ~ 360               | 20.5              | 15 ~ 85           |
| 8       | Chloride (CL)               | mg/l | 10 ~ 60                | 10.6              | -                 |
| 9       | Sulphate (SO <sub>4</sub> ) | mg/l | 44 ~ 76                | 11 ~ 67           | -                 |
| 10      | Sulfide (S)                 | mg/l | < LOD                  | -                 | -                 |
| 11      | Fluoride (F)                | mg/l | 0.10 ~ 0.46            | ND                | -                 |
| 12      | Cyanide (CN)                | mg/l | 0.20 ~ 0.33            | < 0.05            | < 0.05            |
| 13      | Manganese (Mn)              | mg/l | 0.02                   | 0.11              | -                 |
| 14      | Copper (Cu)                 | mg/l | 0.04 ~ 0.06            | 0.08              | -                 |
| 15      | Cadmium (Cd)                | mg/l | 0.005-0.081            | < 0.003           | -                 |
| 16      | Chromium (Cr)               | mg/l | < LOD                  | < 0.005           | -                 |
| 17      | Zinc (Zn)                   | mg/l | 0.01 ~ 0.02            | < 0.04            | -                 |
| 18      | Iron (Fe)                   | mg/l | 0.81 ~ 0.88            | -                 | -                 |
| 19      | Nickel (N)                  | mg/l | 0.02                   | < 0.005           | -                 |
| 20      | Oil & Grease                | mg/l | < LOD                  | -                 | -                 |
| 21      | Sodium                      | mg/l | 12 ~ 37                | 7                 | -                 |
| 22      | Calcium (Ca)                | mg/l | 20 ~ 27                | -                 | 24 ~ 50           |
| 23      | Potassium (K)               | mg/l | 2.7 ~ 5.4              | -                 | -                 |
| 24      | Ammonium (NH <sub>4</sub> ) | mg/l | -                      | 0.1 ~ 0.5         | -                 |

Note <sup>\*1</sup>: Water source of JBC and RBC, LDD: Limit of detection, Date source: Environmental Monitoring of River Chenab, 2009, EPA Laboratory, Punjab

<sup>\*2</sup>: Jang Branch Canal, ND: Not detected, Date source: Feasibility Study for Extension of Water Resources for Faisalabad City, Phase II


<sup>\*3</sup>: Rakh Branch Canal, WASA-F Central Laboratory, 2013 ~ 16

Attached Table 2-4 Results of Settling Test

| Sample #          | 1   |     | 2   |     | 3   |     | 4   |     | 5   |     | 6   |     |
|-------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Initial Turbidity | 960 |     | 790 |     | 620 |     | 400 |     | 190 |     | 80  |     |
| Settling Hour     | NTU | %   | NTU | %   | NTU | %   | NTU | %   | NTU | %   | NTU | %   |
| 1                 | -   |     | 594 | 75% | 200 | 32% | 295 | 74% | 111 | 58% | 75  | 94% |
| 2                 | -   |     | 491 | 62% | 137 | 22% | 242 | 61% | 90  | 47% | 64  | 80% |
| 3                 | 888 | 93% | 429 | 54% | 127 | 20% | 192 | 48% | 78  | 41% | 56  | 70% |
| 4                 | 828 | 86% | 365 | 46% | 116 | 19% | 185 | 46% | 66  | 35% | 50  | 63% |
| 5                 | 757 | 79% | -   | -   | -   | -   | -   | -   | 64  | 34% | 50  | 63% |
| 6                 | 708 | 74% | 320 | 41% | 97  | 16% | 125 | 31% | 58  | 31% | 47  | 59% |
| 8                 | 744 | 78% | 244 | 31% | 85  | 14% | 120 | 30% | -   | -   | -   | -   |
| 10                | 370 | 39% | 216 | 27% | 78  | 13% | 102 | 26% | -   | -   | -   | -   |
| 12                | 685 | 71% | 185 | 23% | 71  | 11% | 93  | 23% | -   | -   | -   | -   |
| 24                | 416 | 43% | 76  | 10% | 41  | 7%  | 63  | 16% | 16  | 8%  | 24  | 30% |

note: RBC water was sampled for settling test and 1 liter cylinder was used for the test taking sample of clarified water from 10 cm below water surface.

SETTLING TEST RESULT





**Attached Table 2-5 Clarified Water Turbidity in RWSR**

| New Jhal Khanuana WTP Data Year: 2017/18 |               |      |      |     |     |     |     |     |     |     |     |     |     |
|--|---------------|------|------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Season                                   | Month         | 7    | 8    | 9   | 10  | 11  | 12  | 1   | 2   | 3   | 4   | 5   | 6   |
|  |               | Wet  | Wet  | Wet | Dry | Dry | Dry | Dry | Dry | Dry | Wet | Wet | Wet |
|  | 1             | 381  | 792  | 272 | -   | -   | 34  | 30  | -   | -   | -   | 182 | 114 |
|  | 2             | 306  | 702  | -   | 91  | -   | 32  | 91  | -   | -   | -   | 202 | 127 |
|  | 3             | 839  | 850  | 250 | 101 | 48  | 35  | 33  | -   | -   | -   | 162 | 137 |
|  | 4             | 719  | 972  | 304 | 94  | 34  | 32  | 40  | -   | -   | 144 | 160 | 180 |
|  | 5             | 495  | 1310 | 431 | 81  | 61  | 29  | 36  | -   | -   | 142 | 149 | 259 |
|  | 6             | 499  | -    | 423 | 81  | -   | 32  | 43  | -   | -   | 125 | 151 | 155 |
|  | 7             | 542  | 1365 | 249 | 77  | -   | 30  | 74  | 20  | -   | 116 | 240 | 128 |
|  | 8             | 522  | 510  | 230 | -   | -   | 28  | 70  | 33  | 26  | 113 | 236 | 191 |
|  | 9             | 298  | 476  | -   | 76  | -   | 32  | 69  | 36  | 85  | 117 | 150 | 285 |
|  | 10            | 320  | 610  | -   | 78  | 77  | 30  | 70  | 35  | 85  | 139 | 112 | 275 |
|  | 11            | -    | 726  | -   | 73  | -   | 30  | 65  | -   | 77  | 159 | 141 | 506 |
|  | 12            | -    | 580  | -   | 74  | -   | 30  | 43  | 34  | 67  | 144 | 130 | 593 |
|  | 13            | 320  | -    | -   | 74  | 67  | 28  | 43  | 28  | 63  | 156 | 145 | 655 |
|  | 14            | 423  | -    | 207 | 109 | 77  | 30  | 28  | 29  | 72  | 115 | 131 | 465 |
|  | 15            | 520  | 542  | -   | -   | 65  | 30  | 10  | 29  | 72  | 101 | 82  | 428 |
|  | 16            | 740  | 576  | 149 | 65  | 63  | 67  | 8   | 125 | 68  | 127 | 32  | 300 |
|  | 17            | 328  | 660  | -   | 72  | 53  | 140 | 3   | 68  | 67  | 185 | 173 | 288 |
|  | 18            | -    | 517  | 123 | 65  | 60  | 115 | -   | -   | -   | 211 | 164 | 346 |
|  | 19            | 820  | 360  | 128 | 65  | -   | 111 | -   | 39  | 94  | 150 | 171 | 360 |
|  | 20            | 970  | -    | 106 | 45  | 42  | 61  | -   | 39  | 105 | -   | 165 | 388 |
|  | 21            | 1033 | 297  | 108 | 45  | 40  | -   | -   | 34  | 130 | -   | 141 | 296 |
|  | 22            | 1436 | 351  | 113 | -   | 34  | -   | -   | 33  | 124 | -   | 127 | 264 |
|  | 23            | 876  | 322  | 115 | -   | 39  | -   | -   | 32  | 108 | -   | 125 | 220 |
|  | 24            | 792  | 360  | -   | -   | 38  | 22  | -   | 34  | 123 | -   | 122 | 92  |
|  | 25            | 488  | 267  | 110 | -   | 39  | 28  | -   | 35  | 124 | -   | 119 | 245 |
|  | 26            | 552  | 324  | 106 | -   | -   | -   | -   | 24  | -   | -   | 115 | 227 |
|  | 27            | 545  | -    | 107 | -   | 33  | -   | -   | 22  | -   | 160 | 125 | 201 |
|  | 28            | 600  | 388  | 107 | -   | 31  | 40  | -   | 8   | -   | 231 | 110 | 138 |
|  | 29            | 478  | 458  | -   | -   | 34  | 24  | -   | -   | -   | 227 | 130 | 145 |
|  | 30            | 508  | 309  | 102 | -   | 35  | 32  | -   | -   | -   | 202 | 113 | -   |
|  | 31            | 528  | 221  | -   | -   | -   | 30  | -   | -   | -   | -   | 110 | -   |
|  | No. of Sample | 28   | 26   | 20  | 18  | 20  | 26  | 14  | 19  | 17  | 20  | 31  | 29  |
|  | Minimum       | 298  | 221  | 102 | 45  | 31  | 22  | 28  | 20  | 26  | 101 | 32  | 92  |
|  | Average       | 603  | 571  | 187 | 76  | 49  | 44  | 53  | 38  | 88  | 153 | 142 | 276 |
|  | Maximum       | 1436 | 1365 | 431 | 109 | 77  | 140 | 91  | 125 | 130 | 231 | 240 | 655 |

not: figures with red color are excluded for average turbidity calculation

| Average Turbidity                  |     |     |     |    |    |    |    |    |    |     |     |     |        |
|------------------------------------|-----|-----|-----|----|----|----|----|----|----|-----|-----|-----|--------|
| Month                              | 7   | 8   | 9   | 10 | 11 | 12 | 1  | 2  | 3  | 4   | 5   | 6   | Annual |
| <b>Canal Water</b>                 |     |     |     |    |    |    |    |    |    |     |     |     |        |
| Wet Season                         | 603 | 571 | 187 | -  | -  | -  | -  | -  | -  | 153 | 142 | 276 | 322    |
| Dry Season                         | -   | -   | -   | 76 | 49 | 44 | 53 | 38 | 88 | -   | -   | -   | 58     |
| Annual                             | -   | -   | -   | -  | -  | -  | -  | -  | -  | -   | -   | -   | 190    |
| <b>Raw Water Storage Reservoir</b> |     |     |     |    |    |    |    |    |    |     |     |     | Annual |
| Wet Season                         | 121 | 114 | 56  |    |    |    |    |    |    | 46  | 43  | 69  | 75     |
| Dry Season                         |     |     |     | 27 | 19 | 17 | 21 | 15 | 31 |     |     |     | 22     |
| Annual                             |     |     |     |    |    |    |    |    |    |     |     |     | 48     |

## 2.2 Chemical Dosage

### (1) Water Treatment Capacity

|                     |                                | Present Plan<br>(2028) | Future Plan<br>(2038)    |
|---------------------|--------------------------------|------------------------|--------------------------|
| Production Capacity | (Day Maximum)                  | 17,900                 | 45,500 m <sup>3</sup> /d |
|                     | (Day Average)                  | 15,600                 | 39,600 m <sup>3</sup> /d |
| Treatment Capacity  | (Loss in Treatment Process) 5% |                        |                          |
|                     | (Day Maximum)                  | 18,800                 | 47,900 m <sup>3</sup> /d |
|                     | (Day Average)                  | 16,400                 | 41,700 m <sup>3</sup> /d |

### (2) Raw Water Quality

Chemical dosage is planned based on water quality of Clarified water in RASR. Estimated water quality is presented in table below.

| Quality Parameters | unit | Raw Water Storage Reservoir |      |      |
|--------------------|------|-----------------------------|------|------|
|                    |      | Max.                        | Ave. | Min. |
| Water Temperature  | °C   | 30                          | 23   | 11   |
| pH                 | -    | 8.7                         | 8.2  | 7.6  |
| Turbidity          | NTU  | 200                         | 48   | 10   |
| Alkalinity         | mg/l | 120                         | 90   | 70   |
| Ammonium           | mg/l | 0.05                        | 0.03 | 0.01 |
| Iron               | mg/l | 0.8                         | 0.5  | 0.3  |
| Mangan             | mg/l | 0.05                        | 0.02 | 0.01 |

### (3) Chemicals

|                     |                                      |
|---------------------|--------------------------------------|
| Aluminum Sulfate    | Coagulant                            |
| Polymer             | Coagulant Aid                        |
| Liquid Chlorine     | Oxidization/Disinfection             |
| Sodium Hypochlorite | Oxidization/Disinfection (Emergency) |

### (4) Chemical Dosage

#### 1) Aluminium Sulfate (Solid ALUM)

|                  |                               |                          |                          |
|------------------|-------------------------------|--------------------------|--------------------------|
| a. Dosage Rate   |                               | Maximum                  | 38 mg/l                  |
|                  |                               | Average                  | 23 mg/l                  |
| b. Dosage Point  |                               | Flash Mixing Tank        |                          |
| c. Solution Tank |                               | Present Plan             | Future Plan              |
| Solid Alum       | Treatment Capacity (Day Max.) | 18,800 m <sup>3</sup> /d | 47,900 m <sup>3</sup> /d |
|                  | Weight                        | 710 kg/d                 | 1,820 kg/d               |
| Solution Rate    |                               | 10 %                     | 10 %                     |
| Solution Tank    | Volume                        | 7.1 m <sup>3</sup>       | 18.2 m <sup>3</sup>      |
|                  | Number of tanks               | 3 nos.                   | 3 nos.                   |
|                  | Dimension Width               | 1.8 m                    | 1.8 m                    |
|                  | Length                        | 1.8 m                    | 1.8 m                    |
|                  | Water depth                   | 2.2 m                    | 2.2 m                    |
|                  | Effective volume              | 21.4 m <sup>3</sup>      | 21.4 m <sup>3</sup>      |
|                  | Free board                    | 0.55 m                   | 0.55 m                   |
|                  | Solution time                 | 1 tanks/d                | 3 tanks/d                |



|                   |   |                          |                          |
|-------------------|---|--------------------------|--------------------------|
| d. ALUM Storage   |   |                          |                          |
| Days for Storage  |   | 30 d                     | 30 d                     |
| Storage Volume    | Average Treatment Capacity  | 16,400 m <sup>3</sup> /d | 41,700 m <sup>3</sup> /d |
|                   | Weight  | 11,300 kg/d              | 28,800 kg/d              |
| Method of Storage | Pallet containers for Alum bags (25kg/bag x 12 bags) are stored in storage yard (width 4.2 x length 3.0m)<br>A storage yard houses 18 pallets (3/width x 2/length x 3 stages) or 5,400 kg<br>Fork lift is used for loading and unloading of pallets<br>Required storage yards is counted as |                          |                          |
|                   |   | 3 lots.                  | 6 lots.                  |
| Area for Storage  |   | 37.8 m <sup>2</sup>      | 57.6 m <sup>2</sup>      |

e. Dosage Equipment Refer to Mechanical and Electric Equipment

2) Polymer

|                     |  |                   |          |
|---------------------|--|-------------------|----------|
| a. Dosage Rate      | Maximum                                    | 1 mg/l            | 1 mg.l   |
|                     | Average                                    | 0.5 mg/l          | 0.5 mg/l |
| b. Dosage Point     | Select 2 placed for effective dosage pints | Flocculation Tank |          |
| c. Dosage Equipment | Refer to Mechanical and Electric Equipment |                   |          |

3) Chlorine

In the present design, Sodium Hypochlorite is used for chlorination. However, liquid chlorine is expected to be applied in the future for increased consumption of chlorine. Therefore, Chemical Building houses chlorination equipment at the space for future Alum storage. Sodium hypochlorite could be utilized as the emergency chlorination for disinfection when chlorine shift to liquid one in the future.

a. Chlorine Requirement and Dosage

Chlorine dosage rates required for contents of 1 mg/l of Ammonium, Iron and Manganese are

|                              | Ammonium                              | Iron | Manganese | Total    |
|------------------------------|---------------------------------------|------|-----------|----------|
|                              | 10                                    | 0.7  | 1.3       |          |
| Contents in Raw Water (mg/l) |                                       |      |           |          |
| Maximum                      | 0.05                                  | 0.8  | 0.05      |          |
| Average                      | 0.03                                  | 0.5  | 0.03      |          |
| Chlorine Requirement (mg/l)  |                                       |      |           |          |
| Maximum                      | 0.5                                   | 0.56 | 0.07      | 1.1 mg/l |
| Average                      | 0.3                                   | 0.35 | 0.03      | 0.7 mg/l |
|                              | Chlorine Requirement for disinfection |      |           | 1 mg/l   |

| Chlorine Dosage   |         | Present Plan | Future Plan |
|-------------------|---------|--------------|-------------|
| Pre-Chlorination  | Maximum | 21 kg/d      | 53 kg/d     |
|                   | Average | 11 kg/d      | 29 kg/d     |
| Post-Chlorination | Maximum | 18 kd/d      | 46 kg/d     |
|                   | Average | 16 kg/d      | 40 kg/d     |
| Total             | Maximum | 39 kd/d      | 99 kg/d     |
|                   | Average | 27 kg/d      | 69 kg/d     |

|                 |                                       |                                 |
|-----------------|---------------------------------------|---------------------------------|
| b. Dosage Point | Pre-Chlorination<br>Post-Chlorination | Receiving Tank<br>Filter Outlet |
|-----------------|---------------------------------------|---------------------------------|

c. Sodium Hypochlorite

|  |  |                |
|--|--|----------------|
| Form of Chemical and Effective Content | Form of Chemical<br>Effective Chlorine Content | Powder<br>12 % |
|--|--|----------------|

| Dosage | Pre-Chlorine  |         | Present Plan | Future Plan* |
|--------|---------------|---------|--------------|--------------|
|        |               |         |              |              |
|        |               | Maximum | 175 kg/d     | -            |
|        |               | Average | 150 kg/d     | -            |
|        |               | Total   | 325 kg/d     | -            |
|        | Post-Chlorine | Maximum | 150 kg/d     | 383 kg/d     |
|        |               | Average | 133 kg/d     | 333 kg/d     |
|        |               | Total   | 283 kg/d     | 716 kg/d     |

Note\*: assuming liquid chlorine will be used in the future, and Sodium hypochlorite will be used for disinfection in emergency case.

|               |                  |   |   |
|---------------|------------------|---|---|
| Solution Tank | Chlorine Content |   | 3%  |
|               | Volume           | 1.3 m3  | 1.5 m2  |
|               | Number of Tank   | Working<br>Stand-by<br>Total                              | 1 tank<br>1 tank<br>2 tanks                   |
|               | Dimensions       | Diameter<br>Water Depth<br>Effective volume<br>Free Board | 1 m<br>1.8 m<br>1.4 m <sup>3</sup><br>0.3 m   |
|               |                  |   | 1.2 m<br>1.8 m<br>2.0 m <sup>3</sup><br>0.3 m |

Tank volume is determined as 2.0 m3 per tank including ample safety factor and taking into account future use of present tank for future.

|                |          |          |
|----------------|----------|----------|
| Solution times | 1 tank/d | 1 tank/d |
|----------------|----------|----------|

Dosage Equipment Refer to Mechanical and Electric Equipment




### **3 Hydraulic Profile of Intake and Treatment Plant**

### 3. Hydraulic Profile of Intake and Treatment Plant


#### 3.1 Hydraulic Analysis of Intake and Raw Water Transmission

(1) Flow Diagram



(2) Hydraulic Analysis

1) Intake Mouth



2) Raw Water Transmission Main (RWTR)

Dimensions of RWTM


|             |                  |
|-------------|------------------|
| Diameter    | 800 mm           |
| Length      | 26.6 m           |
| Velocity    | 1.103 m/s        |
| H. Gradient | (C = 130) 1.30 % |

| Head Loss        | Friction loss               | 0.035 m                |
|------------------|-----------------------------|------------------------|
| Loss of fittings | Inflow: 0.5    Outflow: 1.0 | 0.093 m                |
| Total Loss       | h =                         | 0.128 m    WL + 184.72 |

3) Coarse Screen      1 unit

|  |                        |
|--|------------------------|
| $h_{scr} = C \times v^2/2g =$                  | 0.001 m                |
| $C = c \times (s/b)^{4/3} \times \sin\theta$   | 0.23                   |
| c: Shape co-efficient (flat bar)               | 2.42                   |
| s: Thickness of flat bar                       | 9 mm                   |
| b: Spacing of flat bar                         | 60 mm                  |
| $\theta$ : Installation angle of flat bar      | 70 度                   |
| w: opening area                                | 1.80 m                 |
| h: water depth                                 | 2.30 m                 |
| v: approach velocity                           | 0.134 m/s              |
| $\alpha$ : opening ration due to clogging      | 50 %                   |
| hs = Head loss of coarse screen is set at 2 cm | 0.020 m    WL + 184.70 |


4) Inflow Loss to RWSR (to RWSR B)



| Dimensions of Inlet Pipe |        |
|--------------------------|--------|
| Diameter                 | 800 mm |
| length                   | 28.6 m |

|                                      |           |                         |
|--------------------------------------|-----------|-------------------------|
| Flow rate                            |           | 0.554 m <sup>3</sup> /s |
| Velocity                             |           | 1.103 m/s               |
| H. Gradient                          | (C = 130) | 1.30 ‰                  |
| Friction loss                        |           | 0.037 m                 |
| Other losses (fittings, valve, etc.) |           | 0.170 m                 |
| inlet                                | 0.50      |                         |
| Valve (butterfly)                    | 0.24      |                         |
| Refraction                           | 0.99      |                         |
| Outlet                               | 1.0       |                         |
| Loss of Transfer Pipe(ND900)         |           | 0.010 m                 |
| Total head loss                      | hin =     | 0.217 m WL + 184.48     |

5) Outflow Loss from RWSR  
Loss of Weir





Loss of Submerged Weir - Velmonte Formula

$$h_2 = \{1 - (Q/Q_0)^{2.6}\}^{1.5} \times h_1 = 0.421 \text{ m}$$

|                 |   |                               |      |        |
|-----------------|---|-------------------------------|------|--------|
| Weir length     | 1.0 m   |                               |      |        |
| Overflow rate   | Q : flow rate by submerged weir flow                            | 0.277 m <sup>3</sup> /s• weir |      |        |
|                 | Q <sub>0</sub> : flow rate under overflow height h <sub>1</sub> | 0.651 m <sup>3</sup> /s       |      |        |
| Overflow height | h <sub>1</sub> : overflow height at upstream                    | 0.500 m                       |      |        |
|                 | h <sub>2</sub> : overflow height at downstream                  | 0.421 m                       |      |        |
|                 | Δh: loss of submerged weir flow                                 | 0.079 m                       | WL + | 184.40 |

Out flow from RWST

Dimensions of outlet pipe

|                                       |           |            |  |                         |
|---------------------------------------|-----------|------------|--|-------------------------|
| Diameter                              |           |            |  | 800 mm                  |
| Length                                |           |            |  | 27.6 m                  |
| Flow rate                             |           |            |  | 0.554 m <sup>3</sup> /s |
| Velocity                              |           |            |  | 1.103 m/s               |
| H. Gradient                           | (C=130)   |            |  | 1.30 ‰                  |
| Friction loss                         |           |            |  | 0.036 m                 |
| Other losses (fittings, valves, etc.) |           |            |  | 0.093 m                 |
|                                       | Inlet 0.5 | Outlet 1.0 |  |                         |
| Total Head Loss                       |           |            |  | 0.129 m WL + 184.27     |


6) Raw Water Transmission Pump Station

Receiving Chamber

|                          |                 |                            |  |                         |
|--------------------------|-----------------|----------------------------|--|-------------------------|
| Flow rate                | per one stream  |                            |  | 0.277 m <sup>3</sup> /s |
| Fine screen              | assumed         |                            |  | 0.040 m                 |
| Gate                     | (600/600x 2pls) | $h_g = 1/C^2 \cdot V^2/2g$ |  | 0.168 m                 |
|                          | C: 0.6          | V: 0.770 m/s               |  |                         |
| Total head loss          |                 |                            |  | 0.208 m                 |
| Water level of Pump Well |                 |                            |  | WL + 184.06             |

### 3.2 Hydraulic Analysis of Water Treatment Plant

(1) Flow Diagram



(2) Hydraulic Analysis

|  |                            |                         |             |
|--|----------------------------|-------------------------|-------------|
| <u>Transmission Pump Head</u>            |                            | 10.000 m                |             |
| Transmission flow                        |                            | 0.554 m <sup>3</sup> /s |             |
| Water level of pump well                 |                            |                         | WL + 184.06 |
| Head loss in pump room                   |                            | 1.700 m                 |             |
| Head loss of Raw Water Transmission Main |                            | 0.320 m                 |             |
| Head loss of flow control valve          | v = 2.823 m/s<br>fv = 7.63 | 3.100 m                 |             |
| Total Head Loss                          |                            | 5.120 m                 |             |
| Static Head                              |                            | 4.880 m                 |             |
| Water Level of Receiving Tank            |                            |                         | WL + 188.94 |

Head Loss of Raw Water Transmission Main (Raw Water Pump Sta. ~ Receiving Tank)

Dimensions of Transmission Main

|                 |                               |            |
|-----------------|-------------------------------|------------|
| Diameter        |                               | 700 mm     |
| Length          |                               | 46 m       |
| Fittings/valves | 90 bend: 2<br>Butterfly V.: 1 | 45 bend: 2 |

Head Loss Flow rate

|               |           |                |
|---------------|-----------|----------------|
| Velocity      |           | v = 1.440 m/s  |
| H. Gradient   | C = 130   | i = 2.50 ‰     |
| Friction loss |           | hf = 0.115 m   |
| Other losses  | Σf = 0.70 | hm = 0.074 m   |
| Butterfly V.  | fv = 0.24 | hv = 0.025 m   |
| Outlet        | fo = 1.0  | ho = 0.106 m   |
|               |           | Hrwm = 0.320 m |

1) Receiving Tank


|                       |  |                         |             |
|-----------------------|--|-------------------------|-------------|
| Receiving Water Level |  |                         | WL + 188.94 |
| Treatment Capacity    |  | 0.554 m <sup>3</sup> /s |             |
| Number of units       |  | 2                       |             |
| Flow per unit         |  | 0.277 m <sup>3</sup> /s |             |

|                      |                                    |             |
|----------------------|------------------------------------|-------------|
| Head Loss Inlet gate | Size: 600 x 600 mm                 |             |
|                      | Velocity: 0.769 m/s                |             |
|                      | Loss of gate: co-efficient C = 0.6 | 0.084 m     |
|                      | Water level of Receiving Tank      | WL + 188.86 |

|                                 |                         |             |
|---------------------------------|-------------------------|-------------|
| Rectifying wall Diameter:       | 100 mm                  |             |
| Number:                         | 150 nos.                |             |
| Area:                           | 1.178 m <sup>2</sup>    |             |
| Velocity:                       | 0.235 m <sup>3</sup> /s |             |
| Head loss: co-efficient C = 0.6 | 0.008 m                 | WL - 188.85 |

|                                      |              |             |
|--------------------------------------|--------------|-------------|
| Overflow weir Weir level:            | EL + 188.73  |             |
| Weir width:                          | 3.0 m        |             |
| Head loss: Overflow height: C = 1.84 | hw = 0.123 m |             |
| Freefall depth:                      | hd = 0.225 m |             |
| Head loss:                           | 0.348 m      | WL - 188.50 |

Receiving Tank~Flash Mixing Tank  
Dimension of Interconnection pipeline




|                 |                                      |
|-----------------|--------------------------------------|
| Diameter        | 600 mm                               |
| Length          | 23.1 m                               |
| Fittings/valves | 90 bend 1, 45 bend 2, Butterfly V. 1 |

|            |                     |                         |
|------------|---------------------|-------------------------|
| Head Loss  | Flow rate           | 0.277 m <sup>3</sup> /s |
|            | Velocity            | 0.980 m/s               |
|            | H. gradient (C=130) | 1.47 ‰                  |
|            | Friction loss       | 0.034 m                 |
|            | Other losses        |                         |
|            | inflow:             | 0.5                     |
|            | 90bend:             | 0.24                    |
|            | outflow:            | 1.0                     |
|            | Butterfly v.:       | 0.24                    |
|            | 45bend:             | 0.11                    |
| Total loss |                     | 0.153 m                 |

- 2) Flash Mixing Tank  
Water level of Flash mixing tank  
Rapid mixing method  
Freefall depth

WL + 188.35 m  
Mixing by Waterfall  
0.6 m



|                                     |                         |
|-------------------------------------|-------------------------|
| Number of tank                      | 2 tanks                 |
| Treatment flow                      | 0.277 m <sup>3</sup> /s |
| Overflow height (C = 1.84)          | hw = 0.136 m            |
| Weir width                          | B = 3.0 m               |
| Freefall depth                      | hd = 0.464 m            |
| Head loss (refer to Attachment 3-1) | 0.600 m                 |
| Water level at effluent             | WL + 187.75 m           |

- 3) Flocculation Tank

Slow Mixing Method

Up-and-Down flow

|                                   |  |               |
|-----------------------------------|--|---------------|
| Number of tanks                   | 4 tanks  |               |
| Treatment flow                    | 0.139 m <sup>3</sup> /s  |               |
| Head loss                         | Loss in Inlet channel  |               |
|                                   | Inlet gate   |               |
|                                   | Size   | 450 x 450 mm  |
|                                   | Velocity   | 0.684 m/s     |
|                                   | Head loss co-efficient   | C = 0.6       |
|                                   | hg =   | 0.066 m       |
| Water level of Flocculation tank  | (1st mixing channel)   | WL + 187.68 m |
| Loss of slow mixing               | 0.356 m  |               |
|                                   | (refer to Attachment 3-2 Mixing Intensity and GT-value of slow mixing) |               |
| Water level of Flocculation tank  | (4th mixing channel)   | WL + 187.32 m |
| Rectifying wall                   | Velocity   | 0.2 m/s       |
|                                   | Head loss co-efficient   | C = 0.6       |
|                                   |  | 0.003 m       |
| Water level of Sedimentation Tank |  | WL + 187.32 m |



4) Sedimentation Tank (Inclining Tube)

|   |                         |
|---|-------------------------|
| Number of tanks   | 4 tanks                 |
| Treatment flow  | 0.139 m <sup>3</sup> /s |
| Head loss (refer to Attachment 3-3 Head loss of clarified water extraction) |                         |
| Clarified water extraction pipe   | hs = 0.306 m            |
| Clarified water channel   | he = 0.110 m            |
| Total head loss   | h = 0.415 m             |

5) Rapid Sand Filter

|  |  |
|--|--|
| Filtration Method                                | Equal split constant rate filtration   |
| Treatment flow (3% of loss in process is assume) | 46,900 m <sup>3</sup> /d<br>0.543 m <sup>3</sup> /s<br>0.068 m <sup>3</sup> /s/池 |
| Number of Filter                                 | 8 filters  |

Water level of Filter Inflow Channel WL + 186.91

|           |                 |                 |               |
|-----------|-----------------|-----------------|---------------|
| Head loss | Inlet gate      | Size            | 300 x 300 mm  |
|           |                 | Velocity        | 0.754 m/s     |
|           |                 | Head loss       | 0.081 m       |
|           |                 | co-efficient    | C = 0.6       |
|           | Inflow weir     | Weir width      | 0.9 m         |
|           |                 | Overflow height | C=1.84        |
|           |                 | Freefall depth  | hd = 0.097    |
|           | Inlet pipe      | Diameter        | 300 mm        |
|           |                 | Length          | 1.8 m         |
|           |                 | Velocity        | v = 0.960 m/s |
|           |                 | H. gradient     | i = 3.18 ‰    |
|           |                 | Friction loss   | 0.076 m       |
|           | Total head loss |                 | 0.373 m       |


Water level of Filter WL + 186.53

|                    |   |         |
|--------------------|---|---------|
| Loss of filtration | (refer to Attachment 3-4 Head loss of Filter) |         |
|                    | Clean sand layer, gravel layer and underdra   | 0.325 m |
|                    | Clogging loss                                 | 1.275 m |

Loss of filtered water pipes 0.667 m

Water level of Filyer outlet (before weir) WL + 184.27

Effluent Weir Level EL + 184.15



$$hw = (Q / (C \times B))^{2/3} = 0.116 \text{ m}$$


where, C : coefficient 1.86  
 Q : filtered water flow 0.543 m<sup>3</sup>/s  
 B : weir length 7.4 m

$$hd = 0$$

Water level of Filyer outlet (after weir) WL + 184.15

6) Interconnectin Pipeline (Filter ~ Clear Water Reservoir)


- Loss in Filter House



|                                  |  |                      |  |
|----------------------------------|--|----------------------|--|
| $Q = 0.543 \text{ m}^3/\text{s}$ | $ND = 800$   | $L = 0$              |  |
|                                  | $v = 1.081 \text{ m/s}$  | $i = 1.25 \text{ ‰}$ |  |
|                                  | $ND = 600$   | $L = 8.70 \text{ m}$ |  |
|                                  | $v = 1.921 \text{ m/s}$  | $i = 5.09 \text{ ‰}$ |  |
|                                  | $hf = 1.25 \times 0 \times 1/1000 + 5.09 \times 8.7 \times 1/1000 =$ | $0.044$              |  |
|                                  | $hm = 0.5 \times 1.081^2/2g + 2 \times 0.24 \times 1.921^2/2g =$     | $0.120$              |  |
|                                  | where, $DN800$   | $fi: 0.5$            |  |
|                                  | $DN600$  | $fv: 0.24$           |  |
|                                  | $Hl = hf + hm =$   | $0.164 \text{ m}$    |  |

|                         |       |
|-------------------------|-------|
| Overflow height of weir |       |
| Weir Length             | 7.4   |
| hw                      | 0.117 |

- Filter House to CWR



|                  |  |  |
|------------------|--|--|
| Filter house ~ ① | $Q \text{ ①} = 0.543 \text{ m}^3/\text{s}$ | $Q \text{ ②} = 0.290 \text{ m}^3/\text{s}$ |
|                  | $D1 = 800 \text{ mm}$                      | $D2 = 600 \text{ mm}$                      |
|                  | $L1 = 55.5 \text{ m}$                      | $L2 = 12.1 \text{ m}$                      |
|                  | $V1 = 1.080 \text{ m/s}$                   | $V2 = 1.026 \text{ m/s}$                   |
|                  | $i1 = 1.25 \text{ ‰}$                      | $i2 = 1.60 \text{ ‰}$                      |
| Filter house ~ ② | $Q \text{ ①} = 0.543 \text{ m}^3/\text{s}$ | $Q \text{ ②} = 0.253 \text{ m}^3/\text{s}$ |
|                  | $D1 = 800 \text{ mm}$                      | $D2 = 600 \text{ mm}$                      |
|                  | $L1 = 54.0 \text{ m}$                      | $L2 = 9.8 \text{ m}$                       |
|                  | $V1 = 1.080 \text{ m/s}$                   | $V2 = 0.895 \text{ m/s}$                   |
|                  | $i1 = 1.25 \text{ ‰}$                      | $i2 = 1.24 \text{ ‰}$                      |

- Filter House to ①

Loss of DN800:

|   |                   |
|---|-------------------|
| $hf = 1.25 \times 55.5 \times 1/1000 =$ | $0.070 \text{ m}$ |
| $hm = 0.63 \times 1.081^2/2g =$         | $0.037 \text{ m}$ |
| $h800 =$                                | $0.107 \text{ m}$ |
| where, $f_{ge}: 0.10$                   | $f_{b90}: 0.24$   |
| $f_y: 0.05$                             | $\Sigma f: 0.63$  |

Loss of DN600:  $Q = 0.2900 \text{ m}^3/\text{s}$   
 $v = 1.026 \text{ m/s}$   $i = 1.60 \text{ ‰}$   
 $hf = 1.41 \times 13.4 \times 1/1000 = 0.019 \text{ m}$   
 $hm = 1.48 \times 0.961^2/2g = 0.080 \text{ m}$   
 $h_{600} = 0.099 \text{ m}$   
 where,  $f_{gc}: 0.00$   $f_{b90}: 0.24$   
 $f_o: 1.00$   $\Sigma f: 1.48$   
 Total Loss ①  $0.206 \text{ m}$   
 Total Loss to CWR  $0.370 \text{ m}$

- Filter House to ②  
 Loss of DN800:  
 $hf = 1.25 \times 54 \times 1/1000 = 0.068 \text{ m}$   
 $hm = 1.78 \times 1.081^2/2g = 0.106 \text{ m}$   
 $h_{800} = 0.174 \text{ m}$   
 where,  $f_{ge}: 0.10$   $f_{b90}: 0.24$   
 $f_{\beta}: 1.20$   $\Sigma f: 1.78$

Loss of DN600:  $Q = 0.2528 \text{ m}^3/\text{s}$   
 $v = 0.895 \text{ m/s}$   $i = 1.24 \text{ ‰}$   
 $hf = 1.41 \times 9.8 \times 1/1000 = 0.012 \text{ m}$   
 $hm = 1.24 \times 0.961^2/2g = 0.067 \text{ m}$   
 $h_{600} = 0.079 \text{ m}$   
 where,  $f_{b90}: 0.24$   $f_o: 1.0$   
 $\Sigma f: 1.24$

Total Loss ②  $0.253 \text{ m}$   
 Total Loss to CWR  $H_2 = 0.417 \text{ m}$

Contraction ( $f_{ge}$ )  $12$   
 $100 \quad 480 \quad 0.207912 \quad 0.208333$   
 $\Theta = 20 \quad 0.4$   
 $30 \quad 0.7$   
 $f_{ge}: \Theta = 24 \text{ deg.} \quad f_{ge} = 0.52$   
 $D_1 = 600 \quad D_2 = 800$   
 $f = 0.52 \times (1 - (600/800)^2)^2 = 0.100$

|                          |  |
|--------------------------|--|
| Diversion loss:          | $f_{\beta}: 0.95 \times (1 - q_{\beta})^2 + q_{\beta} \times (1.3 \cot(\Theta/2) - 0.3 + (0.4 - 0.1\phi)/\phi^2) \times (1 - 0.9\sqrt{\rho/\phi}) + 0.4q_{\beta} \times (1 - q_{\beta})(1 - 1/\phi)\cot(\Theta/2)$ |
|                          | when, $\Theta$ is $90^\circ$ and $\rho$ is zero  |
|                          | $f_{\beta}: 0.95 \times (1 - q_{\beta})^2 + q_{\beta} \times (1.3 \cot - 0.3 + (0.4 - 0.1\phi)/\phi^2) + 0.4 \times q_{\beta} \times (1 - q_{\beta}) \times (1 - 1/\phi)$  |
|                          | $f_{\gamma}: 0.58q_{\beta}^2 - 0.26q_{\beta} + 0.03$   |
|                          | where, $q_{\beta} = 0.5$ $\Theta = 90 \text{ deg.}$  |
|                          | $\phi = 0.56$  |
|                          | $f_{\beta} = 1.20$   |
|                          | $f_{\gamma} = 0.05$  |
| Contraction ( $f_{gc}$ ) | $f_{gc} = 0$   |

7) Clear Water Reservoir (Loss of interconnecting pipeline Filter ~ Clear water reservoir)

$H = h_1 + h_2 = 0.370 \text{ m}$   
 Water Level of Clear Water Reservoir  $WL + 183.78$



**Summary of Hydraulic Analysis - Intake & Water Treatment process**

| Facilities   | Head Loss                 | Key Elevation                      | Flow (m <sup>3</sup> /s) | Water level |
|--|---------------------------|------------------------------------|--------------------------|-------------|
| <b>1 Intake &amp; Raw water Transmission</b>           |                           |                                    |                          |             |
| Water Level of RBC                                     |                           |                                    |                          | + 184.86    |
| <b>1.1 Intake Mouth</b>                                | 0.015                     |                                    | 0.554                    |             |
| Transmission Main                                      | 0.128                     |                                    |                          |             |
| (Intake Mouth-Coarse screen)                           |                           |                                    |                          |             |
| <b>1.2 Coarse Screen</b>                               | 0.020                     |                                    | 0.554                    | + 184.72    |
| Inlet Pipe (Coarse Screen~RWSR)                        | 0.217                     |                                    |                          |             |
| <b>1.3 RWSR</b>  |                           |                                    | 0.554                    | + 184.48    |
| Outflow Chamber  | 0.079                     |                                    |                          |             |
| Outlet Pipe (RWSR~RW. Pump Sta.)                       | 0.129                     |                                    |                          |             |
| <b>1.4 Raw Water Pump Station</b>                      |                           |                                    | 0.554                    |             |
| Inlet Chamber  | 0.208                     |                                    |                          |             |
| Pump Well  |                           |                                    |                          | + 184.06    |
| <b>RW Pump Sta. ~ Receiving Tank Pump Transmission</b> |                           |                                    |                          |             |
| Raw Water Pump Head                                    | 10 m                      |                                    |                          |             |
| Loss of Piping around pump                             | 1.700                     |                                    |                          |             |
| Raw Water Transmission                                 | 0.320                     |                                    |                          |             |
| Loss of Flow control valve                             | 3.100                     |                                    |                          |             |
| <b>2 Water Treatment Facilities</b>                    |                           |                                    |                          |             |
| <b>2.1 Receiving Tank</b>                              | loss in treatment process | 5%                                 | 0.554                    |             |
| Receiving water level of Receiving Tank                |                           |                                    |                          | + 188.94    |
| Inlet loww   | 0.084                     |                                    |                          |             |
| Water Level of Receiving tank                          |                           |                                    |                          | + 188.86    |
| Loss of Rectifying wall                                | 0.008                     |                                    |                          |             |
| Weir   | hw                        | 0.123                              | + 188.73                 |             |
|  | hd                        | 0.225                              |                          |             |
|  | h                         | 0.348                              |                          |             |
| Interconnecting Pipeline                               | 0.153                     |                                    |                          |             |
| (Receiving tank ~ Flash Mixing tank)                   |                           |                                    |                          |             |
| <b>2.2 Flash Mixing Tank</b>                           |                           |                                    | 0.554                    |             |
| Water Level of Flash Mixing Tank                       |                           |                                    |                          | + 188.35    |
| Weir   | hw                        | 0.136                              | + 188.21                 |             |
|  | hd                        | 0.464                              |                          |             |
| <b>2.3 Flocculation Tank</b>                           |                           |                                    | 0.554                    |             |
| Inlet gate   | hg                        | 0.066                              |                          |             |
| Water Level of Flocculation Tank                       |                           |                                    |                          | + 187.68    |
| Baffle Plate   | hor1                      | 0.356                              |                          |             |
| Rectifying Wall  | hor2                      | 0.003                              |                          |             |
| <b>2.4 Sedimentation Tank</b>                          |                           |                                    | 0.554                    |             |
| Water Level of Sedimentation Tank                      |                           |                                    |                          | + 187.32    |
| Clarified water extraction                             |                           |                                    | + 187.22                 |             |
| Collecting pipe  | hcor+d+hd                 | 0.306                              |                          |             |
| Clarified water channel                                | ho-hc                     | 0.110                              |                          |             |
|  | hf                        | 0.415                              |                          |             |
| <b>2.5 Filter</b>                                      | loss in treatment process | 3%                                 | 0.543                    |             |
| Water Level of Inflow Channel of Filter                |                           |                                    |                          | + 186.91    |
| Inlet gate   | hg                        | 0.081                              |                          |             |
| Inlet weir   |                           |                                    | + 186.70                 |             |
| Head loss of Filter inlet                              | hi                        | 0.292                              |                          |             |
| Water Level of Filter                                  |                           |                                    |                          | + 186.54    |
| Loss of Filtration                                     | h                         | 1.600 including sand cloggong loss |                          |             |
| Loss of Filtered water pipes                           | hp                        | 0.667                              |                          |             |
| Filter effluent weir                                   | hw                        | 0.116                              | + 184.15                 |             |
|  | hd                        | 0.000                              |                          |             |
| Water level of Filter effluent chamber                 |                           |                                    |                          | + 184.15    |
| <b>2.6 Clear water Reservoir</b>                       |                           |                                    | 0.543                    |             |
| Interconnecting Pipeline                               | 0.370                     |                                    |                          |             |
| (Filter ~ Clear Water Reservoir)                       |                           |                                    |                          |             |
| Water Level of   | HWL                       |                                    |                          | + 183.78    |
| Clear Water Reservoir                                  | LWL                       | (effective water depth :4.5m)      |                          | + 179.28    |

### Attachment 3-1 Mixing Intensity of Flash Mixing Tank

$$G = (1/\mu * (\rho * g * q * hf / V))^{0.5} = 497 \text{ sec}^{-1}$$

where,

|  |         |                     |
|--|---------|---------------------|
| $\mu$ : viscosity (15 °C)                      | 0.00098 | kg/m/s              |
| $\rho$ : specific gravity of water             | 1,000   | kg/m <sup>3</sup>   |
| $g$ : gravity acceleration m/sec               | 9.8     | m/sec <sup>2</sup>  |
| $q$ : flow rate                                | 0.277   | m <sup>3</sup> /sec |
| $h$ : free fall depth below weir crest         | 0.532   | m                   |
| $hf$ : head loss (1/2*hw + hd)                 | 0.600   | m                   |
| $V$ : volume ( $W^3/0.8 * L^3/3.0 * D^2/2.8$ ) | 6.72    | m <sup>3</sup>      |
| $hw$ : overflow depth                          | 0.136   | m                   |
| $hd$ : free fall                               | 0.464   | m                   |

### Attachment 3-2 Mixing Intensity and GT-Value of Slow Mixing

| Descriptions              | unit              | Number of Row                                       |        |        |        | Total  |
|---------------------------|-------------------|---|--------|--------|--------|--------|
|                           |                   | No.1  | No.2   | No.3   | No.4   |        |
| No. of Baffle Walls       | nos.              | 5   | 5      | 5      | 5      | 20     |
| No. of Baffle Plates      | nos.              | 3   | 4      | 5      | 6      | 18     |
| Slit size of baffle plate | mm                | w <sup>300</sup> x h <sup>80</sup> x n <sup>4</sup> |        |        |        |        |
| Area of slit per baffle   | m <sup>2</sup>    | 0.29  | 0.38   | 0.48   | 0.58   | -      |
| Velocity at slit          | m/sec             | 0.481   | 0.361  | 0.289  | 0.241  | -      |
| Head loss of slit         | m                 | 0.164   | 0.092  | 0.059  | 0.041  | 0.356  |
| Volume of channel         | m <sup>3</sup>    | 68.9  | 66.0   | 64.3   | 63.3   | 263    |
| Width                     | m                 | 1.85  | 1.85   | 1.85   | 1.85   | -      |
| Length                    | m                 | 9.70  | 9.70   | 9.70   | 9.70   | -      |
| Water depth               | m                 | 3.84  | 3.68   | 3.58   | 3.53   | 3.66   |
| Detention time            | sec               | 497   | 476    | 464    | 456    | 1,893  |
| Mixing intensity          | sec <sup>-1</sup> | 57.4  | 44.0   | 35.7   | 30.0   | 43.4   |
| Energy dissipation        | G                 | 28,500  | 20,900 | 16,500 | 13,700 | 79,600 |


note: Mixing intensity is calculated by the following formula:

$$G = (1/\mu * (\rho * g * q * hf / V))^{0.5} \text{ sec}^{-1}$$

where,

|  |          |                     |
|--|----------|---------------------|
| $\mu$ : viscosity (15 °C)  | 0.00098  | kg/m/s              |
| $\rho$ : specific gravity of water                                 | 1,000    | kg/m <sup>3</sup>   |
| $g$ : gravity acceleration m/sec                                   | 9.8      | m/sec <sup>2</sup>  |
| $q$ : flow rate  | 0.1386   | m <sup>3</sup> /sec |
| $hf$ : head loss (hor = n x 1/C <sup>2</sup> x v <sup>2</sup> /2g) |          | m                   |
| C: orifice coefficient as 0.6                                      |          |                     |
| $V$ : volume   | variable | m <sup>3</sup>      |

### Attachment 3-3 Head Loss of Clarified Water Extraction



**Cross Section of Clarified Water Launder**

|  |  |                                 |
|--|--|---------------------------------|
| $h_p$ : loss of inflow to collector (orifice loss) |  | 0.039 m                         |
| $d$ : size of collector                            |  | 0.216 m                         |
| $h_d$ : free fall height                           |  | 0.051 m                         |
| $h_o$ : upflow water depth of launder              |  | 0.260 m                         |
| $h_c$ : critical water depth at effluent           |  | 0.150 m                         |
| $h$ : Head loss of clarified water intake          |  | 0.415 m                         |
| $(h_p + d + h_d + h_o - h_c)$                      |  |                                 |
| <b>Loss of Collector</b>                           |  |                                 |
| Flow per tank                                      |  | 0.139 m <sup>3</sup> /s         |
| Collector size                                     |  | 200 mm                          |
| number   |  | 8 nos.                          |
| Velocity of collector                              |  | 0.55 m/s                        |
| Number of slit holes (ctc 420mm)                   |  | 10 nos/collector<br>80 nos/tank |
| Size of slit hole                                  |  | 65 mm                           |
| Area of slit holes                                 |  | 0.265 m <sup>2</sup>            |
| Velocity   |  | 0.522 m/s                       |
| loss   | hor:   | 0.039 m                         |
| pipe dia.  | OD:  | 0.216 m                         |
| Freefall deth                                      | hd:  | 0.051 m                         |
| Total loss   | $(hor + OD + hd)$                                      | 0.306 m                         |
| <b>Loss of Launder</b>                             |  |                                 |
| Critical water depth                               | $h_c = (\alpha \times q^2 / (9.8 \times B^2))^{1/3} =$ | 0.150 m                         |
|  | where, $\alpha = 1.1$ $B =$                            | 0.8                             |
| Upstream water depth                               | $h_o = 1.732 \times h_c =$                             | 0.260 m                         |
| Loss of Launder                                    |  | 0.110 m                         |
| <b>Loss of Clarified Water Collection</b>          |  | 0.415 m                         |



## Attachment 3-4 Head Loss of Filter

### 1. Loss Filter Sand

|                           |                       |                          |
|---------------------------|-----------------------|--------------------------|
| Treatment Capacity        |                       | 46,900 m <sup>3</sup> /d |
| Number of Filter          |                       | 8 nos.                   |
| Filtration Rate of Filter | Filtration per Filter | 5,900 m <sup>3</sup> /d  |
|                           | Filter Bed Area       | 42.3 m <sup>2</sup>      |
|                           | Filtration Rate       | 139.0 m/d                |
| Loss of Sand Layer        |                       |                          |

$$h_s = 0.178 * C_d/g * v^2/p^4 * h = 0.323 \text{ m}$$

|        |                  |                               |                        |
|--------|------------------|-------------------------------|------------------------|
| where, | C <sub>d</sub> : | Drag coefficient              |                        |
|        | g :              | Acceleration of gravity       | 980 cm/s <sup>2</sup>  |
|        | v :              | Filtration rate (cm/s)        | 139.0 m/d = 0.161 cm/s |
|        | p :              | Void ration of sand layer     | 0.4                    |
|        | A :              | Surface area of sand particle |                        |
|        | V :              | Volume of sand particle       |                        |
|        | h :              | Thickness of sand layer       | 100 cm                 |

$$A/V = 6/\sigma d = 6/(0.81*0.09) = 82.3$$

|        |            |                               |         |
|--------|------------|-------------------------------|---------|
| where, | $\sigma$ : | Sphericity of sand particle   | 0.81    |
|        | d :        | Effective size of filter sand | 0.09 cm |

$$C_d = 24/Re + 3/\sqrt{Re} + 0.34 = 17.6$$

|        |      |                           |       |
|--------|------|---------------------------|-------|
| where, | Re : | Reynol's number (= v*d/n) | 1.609 |
|--------|------|---------------------------|-------|

|  |     |                       |                 |
|--|-----|-----------------------|-----------------|
|  | n : | Kinematic viscoursity | 0.009 (at 25°C) |
|--|-----|-----------------------|-----------------|


$$= 58.4 C_d * v^2$$

2. Loss of Supporting Gravel 0.001 m

3. Loss of Underdrain 0.001 m

### 4. Loss of Filtered Water Pipes


Fileted water pipe q: Flow of Filtered Water Pipe 0.0683 m<sup>3</sup>/d



$$h_{p1} = (f_i + f_v + f_o + f^*l/d) * v^2/2g = 0.217 \text{ m}$$

|        |                        |                           |   |
|--------|------------------------|---------------------------|---|
| where, | f <sub>i</sub> :       | inlet coefficient         | 0.5   |
|        | f <sub>v</sub> :       | valve coefficient         | 0.3   |
|        | f <sub>o</sub> :       | outlet coefficient        | 1.00  |
|        | f <sup>*</sup> l/d-1 : | friction coefficient (400 | 0.40 ((124.5*0.012 <sup>2</sup> /0.25 <sup>1/3</sup> ) * (3.5/0.2)) |
|        | v :                    | velocity                  | 1.392 (0.0683/(0.785*(0.25 <sup>2</sup> )))                         |

Filtered water main




| section | friction loss |        |       | minor loss |           |            |                | total loss |            |
|---------|---------------|--------|-------|------------|-----------|------------|----------------|------------|------------|
|         | $f^*l/d$      | q      | v     | hf         | h $\beta$ | h $\alpha$ | h $v$ & h $ge$ | h $o$      | $\Sigma h$ |
| 1 ~ 2   | 0.03          | 0.0683 | 0.136 | 0.000      | 0.068     | -          | -              | -          | 0.07       |
| 2 ~ 3   | 0.26          | 0.1366 | 0.272 | 0.001      | 0.072     | 0.003      | -              | -          | 0.08       |
| 3 ~ 4   | 0.03          | 0.2049 | 0.408 | 0.000      | 0.078     | 0.004      | -              | -          | 0.08       |
| 4 ~ 5   | 0.31          | 0.2731 | 0.544 | 0.005      | 0.086     | 0.006      | -              | -          | 0.10       |
| 5 ~ 6   | 0.03          | 0.3414 | 0.680 | 0.001      | 0.096     | 0.007      | -              | -          | 0.10       |
| 6 ~ 7   | 0.26          | 0.4097 | 0.816 | 0.009      | 0.107     | 0.009      | -              | -          | 0.12       |
| 7 ~ 8   | 0.03          | 0.4780 | 0.951 | 0.001      | 0.120     | 0.010      | -              | -          | 0.13       |
| 8 ~ 9   | 0.20          | 0.5463 | 1.087 | 0.012      | 0.135     | 0.011      | 0.013          | -          | 0.17       |
| 8 ~ 9   | -             | 0.5463 | 1.087 | -          | -         | -          | -              | 0.060      | 0.06       |

where,  $2*fb$  : 22 bend 0.22  
 $fo$  : outlet 1.0

Summary: Loss of Filtered Water Pipe and Main

| filter | filtered water pipe |       | filtered water main |       | loss of outlet section |       | total loss   |
|--------|---------------------|-------|---------------------|-------|------------------------|-------|--------------|
|        | hp1                 | hp2   | hf                  | hm    | 2 x hb                 | ho    |              |
| 1      | 0.217               | 0.068 | 0.029               | 0.049 | -                      | -     | 0.363        |
| 2      | 0.217               | 0.072 | 0.029               | 0.049 | -                      | -     | 0.367        |
| 3      | 0.217               | 0.078 | 0.028               | 0.047 | -                      | -     | 0.370        |
| 4      | 0.217               | 0.086 | 0.028               | 0.042 | -                      | -     | 0.374        |
| 5      | 0.217               | 0.096 | 0.023               | 0.037 | -                      | -     | 0.373        |
| 6      | 0.217               | 0.107 | 0.022               | 0.030 | -                      | -     | 0.376        |
| 7      | 0.217               | 0.120 | 0.013               | 0.021 | -                      | -     | 0.372        |
| 8      | 0.217               | 0.135 | 0.012               | 0.011 | -                      | -     | 0.376        |
| 9      |                     |       |                     |       | 0.013                  | 0.060 | <b>0.449</b> |

**Loss of Confluence**



$$H_\beta - H_\gamma = f_\beta \times V_\gamma^2 / 2g$$

$$f_\beta = -q_\beta^2 \times \{1.2x(1/\phi - 1) + 0.8(1-1/\phi^2)\} - (1-q_\beta) \times \{0.92 + q_\beta(2.92-\phi)\}$$

$$H_\alpha - H_\gamma = f_\alpha \times V_\gamma^2 / 2g$$

$$f_\alpha = -q_\beta^2 \times \{2.59-1.62\} - 0.62\phi - q_\beta(1.94-\phi) + 0.03$$

- where,
- $H_\alpha$ : Pressure of main pipe before confluence
  - $H_\beta$ : Pressure of branch pipe
  - $H_\gamma$ : Pressure of main pipe after confluence
  - $q_\beta$ :  $- Q_\beta / Q_\gamma$
  - $\Theta$ : Angle of branch to main pipe (90 deg)
  - $\phi$ : Section area of Main/Section area of Branch
  - $\rho$ :  $r/D$  (0)
  - $r$ : Radius of pipe connection between main and branch pipes (0)

**Loss of Confluence** Main pipe: 800 mm Branch pipe: 250 mm

**Loss of Branch Pipe:**  $H_\beta - H_\gamma = f_\beta \times V_\gamma^2 / 2g$

| node | $Q_\alpha$ | $Q_\beta$ | $Q_\gamma$ | $q_\beta$ | $\phi$    | $f_\beta$ | $v_\gamma$ | $h_\beta$ |
|------|------------|-----------|------------|-----------|-----------|-----------|------------|-----------|
| 1    | 0          | 0.0683    | 0.0683     | 1.00      | 0.0976563 | -72       | 0.136      | -0.068    |
| 2    | 0.0683     | 0.0683    | 0.1366     | 0.50      | 0.0976563 | -19.2     | 0.272      | -0.072    |
| 3    | 0.1366     | 0.0683    | 0.2049     | 0.33      | 0.0976563 | -9.2      | 0.408      | -0.078    |
| 4    | 0.2049     | 0.0683    | 0.2731     | 0.25      | 0.0976563 | -5.7      | 0.544      | -0.086    |
| 5    | 0.2731     | 0.0683    | 0.3414     | 0.20      | 0.0976563 | -4.07     | 0.680      | -0.096    |
| 6    | 0.3414     | 0.0683    | 0.4097     | 0.17      | 0.0976563 | -3.16     | 0.816      | -0.107    |
| 7    | 0.4097     | 0.0683    | 0.4780     | 0.14      | 0.0976563 | -2.60     | 0.951      | -0.120    |
| 8    | 0.4780     | 0.0683    | 0.5463     | 0.13      | 0.0976563 | -2.24     | 1.087      | -0.135    |

**Loss of Main Pipe:**  $H_\alpha - H_\gamma = f_\alpha \times V_\gamma^2 / 2g$

| node | $Q_\alpha$ | $Q_\beta$ | $Q_\gamma$ | $q_\beta$ | $\phi$    | $f_\alpha$ | $v_\gamma$ | $h_\alpha$ |
|------|------------|-----------|------------|-----------|-----------|------------|------------|------------|
| 1    | 0          | 0.0683    | 0.0683     | 1.00      | 0.0976563 | -          | -          | -          |
| 2    | 0.0683     | 0.0683    | 0.1366     | 0.50      | 0.0976563 | -0.66      | 0.272      | -0.003     |
| 3    | 0.1366     | 0.0683    | 0.2049     | 0.33      | 0.0976563 | -0.48      | 0.408      | -0.004     |
| 4    | 0.2049     | 0.0683    | 0.2731     | 0.25      | 0.0976563 | -0.37      | 0.544      | -0.006     |
| 5    | 0.2731     | 0.0683    | 0.3414     | 0.20      | 0.0976563 | -0.30      | 0.680      | -0.007     |
| 6    | 0.3414     | 0.0683    | 0.4097     | 0.17      | 0.0976563 | -0.25      | 0.816      | -0.009     |
| 7    | 0.4097     | 0.0683    | 0.4780     | 0.14      | 0.0976563 | -0.21      | 0.951      | -0.010     |
| 8    | 0.4780     | 0.0683    | 0.5463     | 0.13      | 0.0976563 | -0.19      | 1.087      | -0.011     |

#### **4. Distribution Center**



## 4. Distribution Center

### 4.1 Dimensions of Distribution Center I (Abudulah Pur)

|             |                          |                      |                       |                                |                         |                                  |                    |        |
|-------------|--------------------------|----------------------|-----------------------|--------------------------------|-------------------------|----------------------------------|--------------------|--------|
| (1)         | Water Demand             | Day Maximum Demand   |                       |                                | 8,060 m <sup>3</sup> /s |                                  |                    |        |
|             |                          | Peak Hourly Demand   | Co-efficient          | 1.5                            | 504 m <sup>3</sup> /h   |                                  |                    |        |
| (2)         | Distribution Center Site | Area                 |                       |                                | 816 m <sup>2</sup>      |                                  |                    |        |
|             |                          | Shape                | Width                 |                                | 17 m                    |                                  |                    |        |
|             |                          |                      | Length                |                                | 48 m                    |                                  |                    |        |
| Facilities  | Ground Reservoir         | Detention time       |                       |                                | 4 h                     |                                  |                    |        |
|             |                          | Volume               |                       |                                | 1343 m <sup>3</sup>     |                                  |                    |        |
|             |                          | Number of reservoirs |                       |                                |                         | 2 nos.                           |                    |        |
|             |                          | Dimension:           | Width                 |                                |                         | 7.5 m                            |                    |        |
|             |                          |                      | Length                |                                |                         | 15.5 m                           |                    |        |
|             |                          |                      | Effective water depth |                                |                         | 6.0 m                            |                    |        |
|             |                          | Volume               |                       |                                |                         | 698 m <sup>3</sup>               |                    |        |
|             |                          |                      | Inlet pipe            | Diameter                       |                         |                                  | 250 mm             |        |
|             |                          |                      |                       | Level controller (float valve) |                         |                                  | 250 mm             |        |
|             |                          | Overflow             | Diameter              |                                |                         | 200 mm                           |                    |        |
|             |                          | Drain pipe           | Diameter              |                                |                         | 150 mm                           |                    |        |
|             |                          | Pump / Electric room | Width                 |                                |                         |                                  | 7.5 m              |        |
|             |                          |                      |                       | Length                         |                         |                                  | 7.5 m              |        |
|             |                          |                      |                       |                                | Height                  | Pump room (below beam sofit)     |                    | 8.0 m  |
|             |                          |                      |                       |                                |                         | Electric room (below beam sofit) |                    | 3.0 m  |
|             |                          | Overhead Reservoir   | Detention time        |                                |                         |                                  | 1.5 h              |        |
|             |                          |                      |                       | Volume                         |                         |                                  | 504 m <sup>3</sup> |        |
|             |                          |                      |                       | Structure                      |                         |                                  |                    | RC     |
|             |                          |                      |                       | Dimension:                     | Diameter                |                                  |                    | 10.8 m |
|             |                          |                      |                       |                                | Effective water depth   |                                  |                    | 5.5 m  |
| Volume      |                          |                      |                       |                                |                         | 504 m <sup>3</sup>               |                    |        |
| LWL         | from Ground level        |                      |                       |                                |                         | 25 m                             |                    |        |
| Inlet pipe  | Diameter                 |                      |                       |                                |                         | 350 mm                           |                    |        |
| Outlet pipe | Diameter                 |                      |                       |                                |                         | 350 mm                           |                    |        |
| Yard piping | Inlet pipe               |                      |                       | Diameter                       |                         |                                  | 350 mm             |        |
|             |                          | Flow mete            | Type                  |                                | Electro magnetic        |                                  |                    |        |
|             |                          |                      | Diameter              |                                | 250 mm                  |                                  |                    |        |
|             | Flow control V.          | Type                 |                       | Butterfly valve                |                         |                                  |                    |        |
|             |                          | Diameter             |                       | 250 mm                         |                         |                                  |                    |        |
|             | Distribution             | Diameter             |                       |                                | 350 mm                  |                                  |                    |        |
|             | Main                     | Flow mete            | Type                  |                                | Electro magnetic        |                                  |                    |        |
| Diameter    |                          |                      |                       | 300 mm                         |                         |                                  |                    |        |

#### 4.2 Dimensions of Distribution Center DZ II (Madina Town No.2)


|             |                          |                      |                                |                                 |                                       |                      |        |
|-------------|--------------------------|----------------------|--------------------------------|---------------------------------|---------------------------------------|----------------------|--------|
| (1)         | Water Demand             | Day Maximum Demand   |                                |                                 | 15,460 m <sup>3</sup> /s              |                      |        |
|             |                          | Peak Hourly Demand   | Co-efficient                   | 1.5                             | 966 m <sup>3</sup> /h                 |                      |        |
| (2)         | Distribution Center Site | Area                 |                                |                                 | Madina Town 1<br>2,560 m <sup>2</sup> |                      |        |
|             |                          | Shape                | Width                          |                                 | 40 m                                  |                      |        |
|             |                          |                      | Length                         |                                 | 64 m                                  |                      |        |
| Facilities  | Ground Reservoir         | Detention time       |                                |                                 | 4 h                                   |                      |        |
|             |                          | Volume               |                                |                                 | 2,577 m <sup>3</sup>                  |                      |        |
|             |                          | Number of reservoirs |                                |                                 | 2 池                                   |                      |        |
|             |                          | Dimension            | Width                          |                                 |                                       | 13.1 m               |        |
|             |                          |                      | Length                         |                                 |                                       | 21.1 m               |        |
|             |                          |                      | Effective water depth          |                                 |                                       | 4.8 m                |        |
|             |                          |                      | Volume                         |                                 |                                       | 1,327 m <sup>3</sup> |        |
|             |                          | Inlet pipe           | Diameter                       |                                 |                                       | 300 mm               |        |
|             |                          |                      | Level controller (float valve) |                                 |                                       | 300 mm               |        |
|             |                          | Overflow             | Diameter                       |                                 |                                       | 200 mm               |        |
|             |                          | Drain pipe           | Diameter                       |                                 |                                       | 150 mm               |        |
|             |                          | Pump / Electric room | Width                          |                                 |                                       | 5.6 m                |        |
|             |                          |                      | Length                         |                                 |                                       | 17.2 m               |        |
|             |                          |                      | Height                         | Pump room (below beam sofit)    |                                       |                      | 6.20 m |
|             |                          |                      |                                | Electric room(below beam sofit) |                                       |                      | 3.0 m  |
|             |                          | Overhead Reservoir   | Detention time                 |                                 |                                       | 1.5 h                |        |
|             |                          |                      | Volume                         |                                 |                                       | 933 m <sup>3</sup>   |        |
|             |                          |                      | Structure                      |                                 |                                       | RC                   |        |
|             |                          |                      | Dimension                      | Diameter                        |                                       |                      | 14.7 m |
|             |                          |                      |                                | Effective water depth           |                                       |                      | 5.5 m  |
|             | Volume                   |                      |                                |                                 | 933 m <sup>3</sup>                    |                      |        |
| LWL         | from Ground level        |                      |                                |                                 | 25 m                                  |                      |        |
| Inlet pipe  | Diameter                 |                      |                                |                                 | 450 mm                                |                      |        |
| Outlet pipe | Diameter                 |                      |                                |                                 | 450 mm                                |                      |        |
| Yard piping | Inlet pipe               | Diameter             |                                |                                 | 400 mm                                |                      |        |
|             |                          | Flow mete Type       |                                |                                 | Electro magnetic                      |                      |        |
|             |                          | Diameter             |                                |                                 | 350 mm                                |                      |        |
|             | Flow control V.          | Type                 |                                |                                 | Butterfly valve                       |                      |        |
|             |                          | Diameter             |                                |                                 | 350 mm                                |                      |        |
|             | Distribution Main        | Diameter             |                                |                                 | 450 mm                                |                      |        |
|             |                          | Flow mete Type       |                                |                                 | Electro magnetic                      |                      |        |
|             |                          | Diameter             |                                |                                 | 350 mm                                |                      |        |

## Attachment 4-1 Capacity of Ground Reservoir (Detention Time)

### Conditions of Analysis

|                                      |     |
|--------------------------------------|-----|
| Peak hourlu Factor                   | 1.5 |
| Physical Loss of Distribution System | 20% |
| Minimum Night Flow (Consumption)     | 10% |

Detention Time of Ground Reservoir 15%  
3.6 hours



| Day Max. Distribution Flow |                      |                            | 2400 m <sup>3</sup> |                      |                            |         |                      |                            |
|----------------------------|----------------------|----------------------------|---------------------|----------------------|----------------------------|---------|----------------------|----------------------------|
| Hour                       | Rate per Ave. flow % | Hourly Flow m <sup>3</sup> | Hour                | Rate per Ave. flow % | Hourly Flow m <sup>3</sup> | Hour    | Rate per Ave. flow % | Hourly Flow m <sup>3</sup> |
| 0 ~ 1                      | 60                   | 60                         | 8 ~ 9               | 145                  | 145                        | 16 ~ 17 | 105                  | 105                        |
| 1 ~ 2                      | 50                   | 50                         | 9 ~ 10              | 150                  | 150                        | 17 ~ 18 | 135                  | 135                        |
| 2 ~ 3                      | 40                   | 40                         | 10 ~ 11             | 145                  | 145                        | 18 ~ 19 | 145                  | 145                        |
| 3 ~ 4                      | 35                   | 35                         | 11 ~ 12             | 125                  | 125                        | 19 ~ 20 | 135                  | 135                        |
| 4 ~ 5                      | 30                   | 30                         | 12 ~ 13             | 120                  | 120                        | 20 ~ 21 | 120                  | 120                        |
| 5 ~ 6                      | 70                   | 70                         | 13 ~ 14             | 110                  | 110                        | 21 ~ 22 | 100                  | 100                        |
| 6 ~ 7                      | 100                  | 100                        | 14 ~ 15             | 105                  | 105                        | 22 ~ 23 | 85                   | 85                         |
| 7 ~ 8                      | 120                  | 120                        | 15 ~ 16             | 100                  | 100                        | 23 ~ 24 | 70                   | 70                         |

Volume of Reservoir (7 ~ 22 時) 360 m<sup>3</sup>  
 Detention Time 1960 - 16 x 100 = 3.6 hours  
Rate to Day Max. Distribution Capacity: 15%

Detention time of ground reservoir is determined at 4 hours of Day Max. Distribution Capacity

## **5. Treated Water Transmission and Distribution System**



## 5. Treated Water Transmission and Distribution System

### 5.1 Brief Description of Treated Water Transmission and Distribution System

(1) Service Area

Service area under the Priority Project of Master Plan includes three distribution zones (DZs) located at city center. Under the present plan, two DZs (DZ I: Abdullahpur and DZ II: Madina Town) are selected out of three DZs.

The distribution center (DC) is selected at the existing Overhead Reservoir site in each DZ which will be demolished before construction of new facilities including a ground reservoir (GR) and a Overhead Reservoir (OHR).

Production capacity of new water treatment plant in Old JK WTP is determined at 45,500 m<sup>3</sup>/d or 10 mgd taking future requirement into account. 50% or 5 mgd of finished water in WTP is transmitted by pumps to the above two DZs, where received water in GR is pumped up to OHR for gravity distribution to respective DZs. Flow meters are provided for control of inflow into GR and for monitoring of distribution flow from OHR.

Each DZ is hydraulically independent service area from others and it is further divided into multiple district meter areas (DMAs). At the inflow point of DMA, district meter is provided to monitor distribution flow. Pressure gauge is also provided there for monitor of pressure conditions of DMA. The flow monitoring facilitate to grasp the tendency of demand and status of physical loss to compare consumption in respective DMA for loss abatement actions required. The electro-magnetic flow meter is planned taking the necessity of accurate flow measuring into account.

The size of DMA is set at approximately 2000 service connection. The size of DMAs (number of service connections and water demand estimated in Master Plan is presented in the table below.

**Number of Service Connections and Water Demand Forecast in DZ and DMA**

| Zone             | DMA      | 2023               |                             | 2028               |                             | 2033               |                             | 2038               |                             |
|------------------|----------|--------------------|-----------------------------|--------------------|-----------------------------|--------------------|-----------------------------|--------------------|-----------------------------|
|                  |          | Connection<br>unit | Demand<br>m <sup>3</sup> /d | Connection<br>unit | Demand<br>m <sup>3</sup> /d | Connection<br>unit | Demand<br>m <sup>3</sup> /d | Connection<br>unit | Demand<br>m <sup>3</sup> /d |
| DZ I<br>(DC22)   | I-1      | 970                | 2,460                       | 1,300              | 3,100                       | 1,670              | 3,710                       | 2,010              | 4,190                       |
|                  | I-2      | 890                | 2,270                       | 1,200              | 2,860                       | 1,540              | 3,430                       | 1,850              | 3,860                       |
|                  | subtotal | 1,860              | 4,730                       | 2,500              | 5,960                       | 3,210              | 7,140                       | 3,860              | 8,050                       |
| DZ II<br>(DC21)  | II-1     | 1,200              | 3,050                       | 1,590              | 3,770                       | 2,010              | 4,460                       | 2,350              | 4,910                       |
|                  | II-2     | 700                | 1,770                       | 920                | 2,180                       | 1,170              | 2,590                       | 1,370              | 2,820                       |
|                  | II-3     | 740                | 1,860                       | 980                | 2,360                       | 1,240              | 2,770                       | 1,450              | 3,050                       |
|                  | II-4     | 1,140              | 2,910                       | 1,510              | 3,590                       | 1,910              | 4,230                       | 2,230              | 4,680                       |
|                  | subtotal | 3,780              | 9,590                       | 5,000              | 11,900                      | 6,330              | 14,050                      | 7,400              | 15,460                      |
| DZ III<br>(DC18) | III-1    | 820                | 2,080                       | 1,090              | 2,610                       | 1,380              | 3,070                       | 1,610              | 3,360                       |
|                  | III-2    | 970                | 2,470                       | 1,280              | 3,030                       | 1,620              | 3,630                       | 1,900              | 3,960                       |
|                  | III-3    | 790                | 2,000                       | 1,040              | 2,460                       | 1,320              | 2,940                       | 1,540              | 3,230                       |
|                  | III-4    | 790                | 2,000                       | 1,040              | 2,500                       | 1,320              | 2,910                       | 1,550              | 3,230                       |
|                  | III-5    | 1,170              | 2,960                       | 1,550              | 3,680                       | 1,960              | 4,360                       | 2,290              | 4,770                       |
|                  | III-6    | 1,060              | 2,730                       | 1,400              | 3,360                       | 1,780              | 3,960                       | 2,080              | 4,320                       |
| subtotal         | 5,600    | 14,240             | 7,400                       | 17,640             | 9,380                       | 20,870             | 10,970                      | 22,870             |                             |
| Total            | 11,240   | 28,560             | 14,900                      | 35,500             | 18,920                      | 42,060             | 22,230                      | 46,380             |                             |

Note <sup>\*1</sup>: Present Plan includes DZ 1 and DZ 2.

<sup>\*2</sup>: Figures of service connections and water demand (day maximum) is based on the Master Plan study.

<sup>\*3</sup>: number of service connection is for domestic users estimated using household size of 7.15, 7.10 and 7.0 in year 2023, 2028 and 2038 respectively

(2) Design Criteria

1) Definition and Function of Treated Water Transmission and Distribution Mains

The system is composed of treated water transmission main and distribution main which is further divided into three categories of primary, secondary and tertiary mains.

The definitions and functions of above categories of pipelines are as follows:

**Transmission main:** The transmission main is pipeline only to transmit finished water from WTP to above mentioned three distribution centers. Therefore, no tapping water from the transmission main is allowed.

**Distribution main:** Distribution mains have a functions by respective pipe size rang.

**Primary Main:** Size of distribution primary main is ND 300~500mm, which covers entire service area of distribution zone (DZ).

**Secondary Main:** Size of distribution secondary main is ND 150~250 mm, which covers entire district meter area (DMA).

**Tertiary Main:** Size of distribution tertiary main is ND 75~100mm, from which tapping to consumer is allowed.

2) Hydraulic Design Criteria

a. Design Flow

The flow of transmission main is based on the day maximum demand, on the other hand the distribution flow is based on the peak hourly demand.

Peak hourly or peak flow is defined for categories of distribution mains as follows:

**Primary main:** 1.5 times of day maximum demand

**Secondary main:** 1.7 times of day maximum demand

**Tertiary main:** Simultaneous tapping rate of connections as 80%, where unit flow per connection is set at 18 l/min.

b. Head Loss Analysis

Head loss of pipelines is calculated based on Hazen-William formula, where the following loss co-efficient factor (C-value) is used.

|                     |     |
|---------------------|-----|
| Transmission Main:  | 130 |
| Distribution Mains: | 120 |

c. Minimum Pressure of Distribution System

The pressure of distribution system is determined so as to supply directly up to three stories buildings and houses in consideration that three stories houses and apartments are prevailing in Faisalabad-MC. The minimum pressure of each category of distribution main is presented as follows:

|                           |      |  |
|---------------------------|------|--|
| Tapping at Tertiary main: | 12 m |  |
| Secondary main:           | 14 m | (head loss of tertiary main as approx. 2m) |
| Primary main:             | 18 m | (head loss of secondary network as 4~5m)   |

3) Transmission and Distribution Pipelines

For design bases of transmission and distribution pipelines, the following criteria are applied:

a. Pipe Materials

The type of pipe materials is determined taking characteristic of pipe materials, cost and importance of pipelines as follows:

**Transmission main:** DCIP/HDPE size of pipelines is ranging from 350mm to 600mm in diameters. considering importance to maintain transmission flow and characteristics of pipe materials (strength and durability), HDPE is selected for size of pipeline ranging 250mm to 500mm and DCIP for 600mm pipeline.

**Distribution main:** HDPE considering advantage of low friction loss, high efficiency of pipe installation works and less cost comparing with DCIP for smaller size of pipeline, HDPE is selected. Size of pipe line will be in the range of 80 to 500mm.

b. Types of Valve

Following types of valve are preferable to be used by size of pipelines.

| <u>Size of pipeline</u>                             | <u>Type of valve</u>         |
|---|------------------------------|
| ND 80 ~ 250 mm (Tertiary and Secondary mains)       | Gate valve (non-rising stem) |
| ND 300mm or larger (Primary and Transmission mains) | Butterfly valve (short body) |

c. Earth Cover

The earth cover by size and category of pipeline is determined as follows:

|   |       |
|---|-------|
| Transmission main (350mm ~ 600mm)         | 1.2 m |
| Distribution primary main (300 ~ 500mm)   | 1.2 m |
| Distribution secondary main (150 ~ 250mm) | 0.9 m |
| Distribution tertiary main (75 ~ 100mm)   | 0.6 m |

d. Ground Reservoir and Overhead Reservoir

The structure, detention time and effective depth of reservoir is as follows:

|                        | Ground Reservoir (GR) | Overhead Reservoir (OHR) |
|------------------------|-----------------------|--------------------------|
| Structure:             | RC                    | RC                       |
| Detention time:        | 4 h                   | 1.5 h                    |
| Effective Water depth: | 4 ~ 6 m               | max. 6 m                 |

note 1: Detention time of reservoir of 4 hours is determined based on the peak hourly factor of 1.5 of day max. demand

2: Detention time of OHR as 1.5 hours is determined based on capacity of lift pump from GR as peak hourly demand with power supply failure of one hour.



## 5.2 Design of Transmission Mains


Hydraulic analysis is made based on the following conditions for treated water transmission main

| Parameter                        | DZ                          | DZ I<br>Abudullah Pur   | DZ II<br>Madina Town No.2 | DZ III (for Future)<br>Peoples Colony No.2 |
|----------------------------------|-----------------------------|-------------------------|---------------------------|--|
| JK WTP:                          | Water level of CW Reservoir |                         | HWL                       | + 183.78                                   |
|                                  |                             |                         | LWL                       | + 179.28                                   |
|                                  | Designed Delivery Head      |                         | Pump head                 | + 35 m                                     |
|                                  |                             |                         | Loss in WTP               | 2.3 m                                      |
|                                  |                             |                         | Delivery head             | + 211.98 m                                 |
| <b>Distribution Center</b>       |                             |                         |                           |  |
| Levels                           | Ground Level (FGL)          | 186.10 m                | 184.60 m                  | 186.20 m                                   |
|                                  | Water Level of GR           |                         |                           |  |
|                                  | HWL                         | + 187.60 m              | 186.10 m                  | 187.70 m                                   |
|                                  | LWL                         | + 181.60 m              | 181.30 m                  | 182.20 m                                   |
|                                  | Water Level of OHR          |                         |                           |  |
|                                  | HWL                         | + 216.60 m              | 215.10 m                  | 216.70 m                                   |
|                                  | LWL                         | + 211.10 m              | 209.60 m                  | 211.20 m                                   |
| <b>Demand for Year 2028</b>      |                             |                         |                           |  |
| Distribution Capacity (Day max.) |                             | 5,960 m <sup>3</sup> /d | 11,900 m <sup>3</sup> /d  | 17,640 m <sup>3</sup> /d                   |
|                                  |                             | 0.069 m <sup>3</sup> /s | 0.138 m <sup>3</sup> /s   | 0.204 m <sup>3</sup> /s                    |
| Peak Flow (hourly max.)          |                             | 373 m <sup>3</sup> /hr  | 744 m <sup>3</sup> /h     | 1,103 m <sup>3</sup> /h                    |
| (for primary network)            |                             | 0.104 m <sup>3</sup> /d | 0.207 m <sup>3</sup> /s   | 0.306 m <sup>3</sup> /s                    |
| <b>Demand for Year 2038</b>      |                             |                         |                           |  |
| Distribution Capacity (Day max.) |                             | 8,050 m <sup>3</sup> /d | 15,460 m <sup>3</sup> /d  | 22,870 m <sup>3</sup> /d                   |
|                                  |                             | 0.093 m <sup>3</sup> /s | 0.179 m <sup>3</sup> /s   | 0.265 m <sup>3</sup> /s                    |
| Peak Flow (hourly max.)          |                             | 503 m <sup>3</sup> /hr  | 966 m <sup>3</sup> /h     | 1,429 m <sup>3</sup> /h                    |
| (for primary network)            |                             | 0.140 m <sup>3</sup> /s | 0.268 m <sup>3</sup> /s   | 0.397 m <sup>3</sup> /s                    |



## (1) Hydraulic Analysis and Sizing of Transmission Main

Configuration of Transmission Main



Diameter of each section of transmission main is calculated as shown in the following table, where friction loss coefficient (C-value) of 130 is used included minor losses of fittings and valves.

- 1) Hydraulic Analysis for Day Max. Demand in 2028 - No supply to DC3

| DZ/DC:                           | 1     | 2      | 3      |
|----------------------------------|-------|--------|--------|
| Water Demand (m <sup>3</sup> /d) | 5,960 | 11,900 | 17,640 |
| (m <sup>3</sup> /s)              | 0.069 | 0.138  | 0.204  |

| Section | GL <sup>*3</sup> | WL <sup>*1</sup> | ND  | L     | q                 | v    | %    | hf   | Dinamic H <sup>*2</sup> | Res. Head |
|---------|------------------|------------------|-----|-------|-------------------|------|------|------|-------------------------|-----------|
|         |                  | m                | mm  | m     | m <sup>3</sup> /s | m/s  |      | m    | m                       | m         |
| 0       | 185.00           | 179.28           |     |       |                   |      |      |      | 212.58                  | 27.6      |
| 1       | 184.77           |                  | 600 | 985   | 0.207             | 0.73 | 0.85 | 0.84 | 211.74                  | 27.0      |
| 2       | 185.99           |                  | 450 | 640   | 0.207             | 1.30 | 3.46 | 2.22 | 209.52                  | 23.5      |
| GR1     | 185.92           | 187.60           | 350 | 63    | 0.069             | 0.72 | 1.55 | 0.10 | 209.43                  | 21.8      |
| 3       | 186.04           |                  | 450 | 1,087 | 0.138             | 0.87 | 1.63 | 1.78 | 207.75                  | 21.7      |
| GR2     | 184.24           | 186.10           | 400 | 1,312 | 0.138             | 1.10 | 2.90 | 3.81 | 203.94                  | 17.8      |
| 2'      | 185.0            |                  | 450 | 790   |                   |      |      |      |                         |           |
| GR3     | 184.8            | 187.70           | 450 | 1,180 |                   |      |      |      |                         |           |

note 1: Design water level of Distribution Reservoir is set at 1.5 m higher than FGL

GL is Formation Ground Level (FGL)

- 2: Pump head is designed as 35m, Piping loss around pumps is set at 1.5m, pipeline loss in WTP is set at 0.2m

Head Loss in WTP:

$$q = 0.207 \text{ m}^3/\text{s} \quad D = 600 \text{ mm} \quad L = 147 \text{ m}$$

$$i = 0.85 \text{ ‰} \quad hf = 0.13 \text{ m} \quad \text{rounded: } 0.2 \text{ m}$$

Loss of flow control valve at transmission pump station is set at 3 m.

$$\text{Loss of flow control valve (ND600)} \quad q = 0.207 \text{ m}^3/\text{s} \quad hv = fv \times v^2/2g = 3.00$$

$$v = 0.731 \text{ m/s} \quad fv = 110$$

- 3: Excess head at Distribution Center is adjusted by control valve set at inlet of Distribution Reservoir of each Distribution Center

- 4: Butterfly type of float valve is used at the inlet of Distribution Reservoir to prevent overflow, where head loss of 5 m is provided at inlet of Distribution Center as excess head

2) Hydraulic Analysis at Design Maximum Flow in 2028 - Include Supply to DC3

| DZ/DC:              | 1     | 2      | 3      |
|---------------------|-------|--------|--------|
| Water Demand (m3/d) | 5,960 | 11,900 | 17,640 |
| (m3/s)              | 0.069 | 0.138  | 0.204  |

| Section | GL <sup>*3</sup> | WL <sup>*1</sup> | ND  | L     | q     | v    | ‰    | hf   | Dinamic H <sup>*2</sup> | Res. Head   |
|---------|------------------|------------------|-----|-------|-------|------|------|------|-------------------------|-------------|
|         |                  | m                | mm  | m     | m3/s  | m/s  |      | m    | m                       | m           |
| 0       | 185.00           | 179.28           |     |       |       |      |      |      | 212.18                  | 27.2        |
| 1       | 184.77           |                  | 600 | 985   | 0.411 | 1.45 | 3.04 | 3.00 | 209.18                  | 24.4        |
| 2       | 185.99           |                  | 450 | 640   | 0.207 | 1.30 | 3.46 | 2.22 | 206.97                  | 21.0        |
| GR1     | 185.92           | 187.60           | 350 | 63    | 0.069 | 0.72 | 1.55 | 0.10 | 206.87                  | <b>19.3</b> |
| 3       | 186.04           |                  | 450 | 1,087 | 0.138 | 0.87 | 1.63 | 1.78 | 205.19                  | 19.2        |
| GR2     | 184.24           | 184.60           | 400 | 1,312 | 0.138 | 1.10 | 2.90 | 3.81 | 201.39                  | <b>16.8</b> |
| 2'      | 185.0            |                  | 450 | 1400  | 0.204 | 1.28 | 3.39 | 4.74 | 204.45                  | 19.4        |
| GR3     | 184.8            | 186.10           | 400 | 570   | 0.204 | 1.63 | 6.01 | 3.42 | 201.02                  | <b>14.9</b> |

note 1: Design water level of Clear Water Reservoir of WTP is taken as mid water level (+183.78-4.5/2)

Design water level of Ground Reservoir is set at 1.5 m higher than FGL

GL is Formation Ground Level (FGL)

2: Pump head is designed as 35m, Piping loss around pumps is set at 1.5m, pipeline loss in WTP is set at 0.5m.

Loss of flow control valve at transmission pump station is set at 3m.

Head Loss in WTP:

$$q = 0.411 \text{ m}^3/\text{s} \quad D = 600 \text{ mm} \quad L = 147 \text{ m}$$

$$i = 3.04 \text{ ‰} \quad hf = 0.45 \text{ m} \quad \text{rounded: } 0.5 \text{ m}$$

Loss of flow control valve at transmission pump station is set at 10m.

Loss of flow control valve (ND600)  $q = 0.411 \text{ m}^3/\text{s}$   $hf = fv \times v^2/2g = 10.0$

and Cabitation Factor  $v = 1.454 \text{ m/s}$   $fv = 93$

3: Excess head at Distribution Center is adjusted by control valve set at inlet of Distribution Reservoir of each Distribution Center

4: Butterfly type of float valve is used at the inlet of Distribution Reservoir to prevent overflow, where

3) Hydraulic Analysis of Transmission Main in 2038

| DZ/DC:              | 1     | 2      | 3      | Total  |
|---------------------|-------|--------|--------|--------|
| Water Demand (m3/d) | 8,050 | 15,460 | 22,870 | 46,380 |
| (m3/s)              | 0.093 | 0.179  | 0.265  | 0.537  |

Diameter of each section of transmission main is calculated as shown in the following table, where friction loss coefficient (C-value) of 130 is used included minor losses of fittings and valves.

Hydraulic Analysis at Design Maximum Flow in 2038

| Section | GL <sup>*3</sup> | WL <sup>*1</sup> | ND  | L     | q     | v    | ‰    | hf   | Dinamic H <sup>*2</sup> | Res. Head   |
|---------|------------------|------------------|-----|-------|-------|------|------|------|-------------------------|-------------|
|         |                  | m                | mm  | m     | m3/s  | m/s  |      | m    | m                       | m           |
| 0       | 185.00           | 179.28           |     |       |       |      |      |      | 211.98                  | 27.0        |
| 1       | 184.77           |                  | 600 | 985   | 0.537 | 1.90 | 4.99 | 4.91 | 207.07                  | 22.3        |
| 2       | 185.99           |                  | 450 | 640   | 0.272 | 1.71 | 5.76 | 3.69 | 203.38                  | 17.4        |
| GR1     | 186.10           | 187.60           | 350 | 63    | 0.093 | 0.97 | 2.70 | 0.17 | 203.21                  | <b>15.6</b> |
| 3       | 186.04           |                  | 450 | 1,087 | 0.179 | 1.13 | 2.65 | 2.88 | 200.50                  | 14.5        |
| GR2     | 184.60           | 186.10           | 400 | 1,320 | 0.179 | 1.42 | 4.71 | 6.21 | 194.29                  | <b>8.2</b>  |
| 2'      | 185.0            |                  | 450 | 790   | 0.265 | 1.67 | 5.47 | 4.32 | 202.74                  | 17.7        |
| GR3     | 184.8            | 187.70           | 450 | 1,180 | 0.265 | 1.67 | 5.47 | 6.46 | 196.29                  | <b>8.6</b>  |

note 1: Design water level of Ground Reservoir is set at 1.5 m higher than FGL

GL is Formation Ground Level (FGL)

2: Pump head is designed as 35m, Piping loss around pumps is set at 1.5m, pipeline loss in WTP is set at 0.8m

Head Loss in WTP:

$$q = 0.537 \text{ m}^3/\text{s} \quad D = 600 \text{ mm} \quad L = 147 \text{ m}$$

$$i = 4.99 \text{ ‰} \quad hf = 0.73 \text{ m} \quad \text{rounded: } 0.8 \text{ m}$$

3: Excess head at Distribution Center is adjusted by control valve set at inlet of Distribution Reservoir of each Distribution Center


4: Butterfly type of float valve is used at the inlet of Distribution Reservoir to prevent overflow, where head loss of 5 m is provided at inlet of Distribution Center as excess head

### 5.3 Distribution Main System

#### (1) Hydraulic / Network Analysis and Sizing of Distribution Primary Main (2038)

1) Hydraulic Analysis (DZ I Abddulahpur)

| Design Flow                | unit              | Future Plan (2038) |          |          |
|----------------------------|-------------------|--------------------|----------|----------|
|                            |                   | Zone I             | Zone I-1 | Zone I-2 |
| Day Max. Distribution Flow | m <sup>3</sup> /d | 8,050              | 4,190    | 3,860    |
| Peak Hourly Flow           | m <sup>3</sup> /h | 503                | 262      | 241      |
|                            | m <sup>3</sup> /s | 139.75             | 72.74    | 67.01    |



b. Hydraulic Analysis


| Section | Flow (l/s) | ND (mm) | L (m) | i ‰  | hf (m) | GL    | WL* (m) | Eff. Head (m) |
|---------|------------|---------|-------|------|--------|-------|---------|---------------|
| ①       | 140.0      | 350     | 630   | 6.64 | 4.18   | 186.1 | 210.60  | 24.5          |
| ②       | 67.0       | 300     | 100   | 3.60 | 0.36   | 186.3 | 206.42  | 20.1          |
| ③       |            |         |       |      |        | 185.1 | 206.06  | 21.0          |

Note \* LWL of OHR + 211.10  
loss in Distribution Center as 0.5m is assumed.

2) Network Analysis DZ II (Madina Town No.2)

| Design Flow        | unit               | Zone II | DMA II-1 | DMA II-2 | DMA II-3 | DMA II-4 |
|--------------------|--------------------|---------|----------|----------|----------|----------|
| Day maximum Demand | m <sup>3</sup> /d  | 15,460  | 4,910    | 2,820    | 3,050    | 4,680    |
| Peak Hourly Demand | m <sup>3</sup> /hr | 966     | 307      | 176      | 191      | 293      |
|                    | l/s                | 268.40  | 85.24    | 48.96    | 52.95    | 81.25    |

a. Network Layout



b. Network Analysis

Node Data

| Node No. | Type | Discharge<br>l/sec | WL* <sup>1</sup><br>m | GL<br>m | Eff. Head<br>m | Note |
|----------|------|--------------------|-----------------------|---------|----------------|------|
| 0        |      | -268.40            | 209.60                | 186.1   | 23.50          |      |
| 1        |      | 0.00               | 209.28                | 183.9   | 25.38          |      |
| 2        |      | 48.96              | 207.66                | 183.7   | 24.01          | DM 2 |
| 3        |      | 52.95              | 207.16                | 184.6   | 22.58          | DM 3 |
| 4        |      | 85.24              | 207.46                | 185.8   | 21.62          | DM 1 |
| 5        |      | 81.25              | 206.13                | 183.4   | 22.70          | DM 4 |

note \*: LWL of OHR + 209.60

Pipeline Data

| Up-stream | Dn-stream | Node Number | Dia.<br>m | Length<br>m | Friction<br>Co-efficient | Head Loss<br>m | Flow<br>l/sec | Velocity<br>m/sec | H. gradient<br>‰ |
|-----------|-----------|-------------|-----------|-------------|--------------------------|----------------|---------------|-------------------|------------------|
| 0         | 1         | 450         | 50        | 120         | 0.32                     | 268.40         | 1.69          | 6.51              |                  |
| 1         | 2         | 450         | 590       | 120         | 1.62                     | 169.54         | 1.07          | 2.78              |                  |
| 2         | 3         | 400         | 1520      | 120         | 0.50                     | 39.33          | 0.31          | 0.33              |                  |
| 3         | 4         | 300         | 1630      | 120         | -0.30                    | -13.62         | -0.19         | -0.19             |                  |
| 4         | 5         | 400         | 1010      | 120         | -1.82                    | -98.86         | -0.79         | -1.82             |                  |
| 4         | 2         | 300         | 300       | 120         | 1.52                     | -81.25         | -1.15         | -5.14             |                  |




**(2) Network Analysis and Sizing of Distribution Secondary Main**

1) Network Analysis (Abddulapur: DMA I - 1)

Day Maximum Demand : 4,190 m<sup>3</sup>/d      Peak Hourly Demand: 296.8 m<sup>3</sup>/h  
 82.44 l/s  
 (Peak Hourly Factor: 1.7 )

| Node. No.:       | 1     | 2     | 3      | 4     | 5      | 6      | 7      | Σq    |
|------------------|-------|-------|--------|-------|--------|--------|--------|-------|
| Discharge (l/s): | 3.62  | 4.90  | 15.81  | 13.91 | 13.61  | 14.23  | 16.36  | 82.44 |
| Ground level:    | 185.3 | 185.1 | 185.10 | 186.2 | 185.90 | 185.80 | 185.30 |       |
| Section:         | ①~②   | ②~③   | ③~④    | ④~⑤   | ⑤~⑥    | ⑥~⑦    | ⑦~①    |       |
| Diameter (mm):   | 200   | 150   | 150    | 150   | 150    | 150    | 150    |       |
| Length (m):      | 280   | 100   | 180    | 370   | 380    | 350    | 120    | 1,780 |

a. Network Layout



b. Network Analysis

Node Data

| Node No. | Discharge<br>l/sec | WL<br>m | GL<br>m | Eff. Head<br>m |
|----------|--------------------|---------|---------|----------------|
| 0        | -82.44             | 206.42  | 185.30  | 21.12          |
| 1        | 3.62               | 205.43  | 185.30  | 20.13          |
| 2        | 4.90               | 203.35  | 185.10  | 18.25          |
| 3        | 15.81              | 201.07  | 185.10  | 15.97          |
| 4        | 13.91              | 200.09  | 186.20  | 13.89          |
| 5        | 13.61              | 200.09  | 185.90  | 14.19          |
| 6        | 14.23              | 202.21  | 185.80  | 16.41          |
| 7        | 16.36              | 204.00  | 185.30  | 18.70          |

Pipeline Data


| Node Number |           | Dia. | Length | Friction     | Head Loss | Flow   | Velocity | H.Gradient |
|-------------|-----------|------|--------|--------------|-----------|--------|----------|------------|
| Up-stream   | Dn-stream | m    | m      | Co-efficient | m         | l/sec  | m/sec    | %o         |
| 0           | 1         | 250  | 78     | 120          | 0.99      | 82.44  | 1.68     | 12.84      |
| 1           | 2         | 200  | 280    | 120          | 2.09      | 34.40  | 1.10     | 7.55       |
| 2           | 3         | 150  | 100    | 120          | 2.27      | 29.50  | 1.67     | 23.08      |
| 3           | 4         | 150  | 180    | 120          | 0.99      | 13.69  | 0.78     | 5.58       |
| 4           | 5         | 150  | 370    | 120          | -0.00     | -0.22  | -0.01    | 0.00       |
| 5           | 6         | 150  | 380    | 120          | -2.12     | -13.83 | -0.78    | 5.68       |
| 6           | 7         | 200  | 350    | 120          | -1.79     | -28.06 | -0.89    | 5.18       |
| 7           | 1         | 200  | 120    | 120          | -1.43     | -44.42 | -1.41    | 12.12      |

2) Network Analysis (Abdulahpur: DMA I - 2)

Day Maximum Demand : 3,860 m<sup>3</sup>/d      Peak Hourly Demand: 273.4 m<sup>3</sup>/h  
 75.95 l/s  
 (Peak Hourly Factor: 1.7 )

| Node. No.:       | 1     | 2     | 3     | 4     | 5     | 6     | 7     | Σq    |
|------------------|-------|-------|-------|-------|-------|-------|-------|-------|
| Discharge (l/s): | 6.31  | 9.16  | 5.55  | 15.88 | 17.09 | 13.40 | 8.56  | 75.95 |
| Ground level:    | 185.1 | 185.2 | 185.4 | 185.9 | 186.1 | 185.5 | 185.1 |       |
| Section:         | ①~②   | ②~③   | ③~④   | ④~⑤   | ⑤~⑥   | ⑥~⑦   | ⑦~①   |       |
| Diameter (mm):   | 200   | 200   | 150   | 150   | 150   | 200   | 200   |       |
| Length (m):      | 140   | 220   | 380   | 310   | 90    | 180   | 340   | 1,660 |

a. Network Layout



b. Network Analysis

Node Data

| Node No. | Discharge<br>l/sec | WL<br>m | GL<br>m | Eff. Head<br>m |
|----------|--------------------|---------|---------|----------------|
| 0        | -75.95             | 206.06  | 185.30  | 20.76          |
| 1        | 6.31               | 205.06  | 185.10  | 19.96          |
| 2        | 9.16               | 204.17  | 185.20  | 18.97          |
| 3        | 5.55               | 203.43  | 185.40  | 18.03          |
| 4        | 15.88              | 200.35  | 185.90  | 14.45          |
| 5        | 17.09              | 200.34  | 186.10  | 14.24          |
| 6        | 13.40              | 201.00  | 185.50  | 15.50          |
| 7        | 8.56               | 202.01  | 185.10  | 16.91          |

Pipeline Data

| Node Number |           | Dia. | Length | Friction     | Head Loss | Flow   | Velocity | H.Gradient |
|-------------|-----------|------|--------|--------------|-----------|--------|----------|------------|
| Up-stream   | Dn-stream | m    | m      | Co-efficient | m         | l/sec  | m/sec    | %          |
| 0           | 1         | 250  | 90     | 120          | 1.00      | 75.95  | 1.55     | 11.03      |
| 1           | 2         | 200  | 140    | 120          | 0.89      | 31.60  | 1.01     | 6.46       |
| 2           | 3         | 200  | 220    | 120          | 0.74      | 22.44  | 0.71     | 3.43       |
| 3           | 4         | 150  | 380    | 120          | 3.08      | 16.89  | 0.96     | 8.22       |
| 4           | 5         | 150  | 310    | 120          | 0.01      | 1.01   | 0.06     | 0.04       |
| 5           | 6         | 150  | 90     | 120          | -0.67     | -16.08 | -0.91    | 7.51       |
| 6           | 7         | 200  | 180    | 120          | -1.01     | -29.48 | -0.94    | 5.68       |
| 7           | 1         | 200  | 340    | 120          | -3.05     | -38.04 | -1.21    | 9.10       |




3) Network Analysis (Madina Town: DMA II - 1)

Day Maximum Demand : 4,910 m<sup>3</sup>/d      Peak Hourly Demand: 347.8 m<sup>3</sup>/h  
 96.61 l/s  
 (Peak Hourly Factor: 1.7 )

|                  |       |       |       |       |       |
|------------------|-------|-------|-------|-------|-------|
| Node No.:        | 1     | 2     | 3     | 4     | 5     |
| Discharge (l/s): | 15.47 | 12.85 | 11.59 | 15.55 | 14.01 |
| Ground level:    | 185.6 | 186.8 | 184.6 | 184.6 | 184.9 |
| Section:         | ①~②   | ①~④   | ②~③   | ③~④   | ④~⑤   |
| Diameter (mm):   | 150   | 200   | 150   | 150   | 150   |
| Length (m):      | 420   | 570   | 520   | 390   | 360   |
| Node No.:        | 6     | 7     | 8     | Σq    |       |
| Discharge (l/s): | 14.10 | 6.47  | 6.57  | 96.61 |       |
| Ground level:    | 185.1 | 184.7 | 184.8 |       |       |
| Section:         | ⑥~①   | ⑥~⑦   | ⑦~⑧   | ⑧~⑤   |       |
| Diameter (mm):   | 150   | 150   | 150   | 150   |       |
| Length (m):      | 350   | 320   | 630   | 320   |       |

a. Network Layout



b. Network Analysis

| Node Data |                    |         |         |                |
|-----------|--------------------|---------|---------|----------------|
| Node No.  | Discharge<br>l/sec | WL<br>m | GL<br>m | Eff. Head<br>m |
| 0         | -96.61             | 207.46  | 185.8   | 21.66          |
| 1         | 15.47              | 206.44  | 185.6   | 20.84          |
| 2         | 12.85              | 202.18  | 186.8   | 15.38          |
| 3         | 11.59              | 201.51  | 184.6   | 16.91          |
| 4         | 15.55              | 201.89  | 184.6   | 17.29          |
| 5         | 14.01              | 199.60  | 184.9   | 14.70          |
| 6         | 14.10              | 199.99  | 185.1   | 14.89          |
| 7         | 6.47               | 199.36  | 184.7   | 14.66          |
| 8         | 6.57               | 199.31  | 184.8   | 14.51          |
|           | 96.61              |         |         |                |


| Pipeline Data |           |        |          |              |       |          |            |       |
|---------------|-----------|--------|----------|--------------|-------|----------|------------|-------|
| Node Number   | Dia.      | Length | Friction | Head Loss    | Flow  | Velocity | H.Gradient |       |
| Up-stream     | Dn-stream | m      | m        | Co-efficient | m     | l/sec    | m/sec      | %     |
| 0             | 1         | 250    | 60       | 120          | 1.02  | 96.61    | 1.97       | 17.21 |
| 1             | 2         | 150    | 420      | 120          | 4.26  | 19.08    | 1.08       | 10.31 |
| 2             | 3         | 150    | 520      | 120          | 0.67  | 6.23     | 0.35       | 1.30  |
| 3             | 4         | 150    | 390      | 120          | -0.38 | -5.36    | -0.30      | 0.98  |
| 4             | 5         | 150    | 360      | 120          | 2.29  | 14.82    | 0.84       | 6.46  |
| 5             | 6         | 150    | 600      | 120          | -0.39 | -4.35    | -0.25      | 0.67  |
| 6             | 1         | 150    | 350      | 120          | -6.45 | -26.33   | -1.49      | 18.70 |
| 1             | 4         | 200    | 570      | 120          | 4.55  | 35.73    | 1.14       | 8.10  |
| 6             | 7         | 150    | 320      | 120          | 0.63  | 7.88     | 0.45       | 2.01  |
| 7             | 8         | 150    | 630      | 120          | 0.05  | 1.41     | 0.08       | 0.08  |
| 8             | 5         | 150    | 320      | 120          | -0.29 | -5.16    | -0.29      | 0.92  |

4) Network Analysis (Madina Town: DMA II - 2)

Day Maximum Demand : 2,820 m<sup>3</sup>/d Peak Hourly Demand: 200 m<sup>3</sup>/h  
 55.49 l/s  
 (Peak Hourly Factor: 1.7)

|                  |       |       |       |       |       |       |
|------------------|-------|-------|-------|-------|-------|-------|
| Node. No.:       | 1     | 2     | 3     | 4     | 5     |       |
| Discharge (l/s): | 2.38  | 1.94  | 6.86  | 5.02  | 9.37  |       |
| Ground level:    | 183.5 | 183.4 | 183.9 | 183.8 | 185.0 |       |
| Section:         | ①~②   | ①~⑦   | ②~③   | ③~④   | ④~⑤   | ⑤~⑥   |
| Diameter (mm):   | 150   | 200   | 150   | 150   | 150   | 100   |
| Length (m):      | 310   | 140   | 380   | 460   | 240   | 480   |
| Node. No.:       | 6     | 7     | 8     | 9     | 10    | Σq    |
| Discharge (l/s): | 4.83  | 3.82  | 7.53  | 7.28  | 6.46  | 55.49 |
| Ground level:    | 184.1 | 184.0 | 184.3 | 184.6 | 184.4 |       |
| Section:         | ⑥~①   | ⑥~⑨   | ⑦~⑧   | ⑧~④   | ⑨~⑩   | ⑩~⑤   |
| Diameter (mm):   | 150   | 150   | 200   | 200   | 150   | 150   |
| Length (m):      | 500   | 290   | 160   | 280   | 520   | 280   |

a. Network Layout



b. Network Analysis

Node Data

| Node No. | Discharge<br>l/sec | WL<br>m | GL<br>m | Eff. Head<br>m |
|----------|--------------------|---------|---------|----------------|
| 0        | -55.49             | 207.66  | 183.7   | 23.96          |
| 1        | 2.38               | 207.15  | 183.5   | 23.65          |
| 2        | 1.94               | 206.12  | 184.0   | 22.12          |
| 3        | 6.86               | 205.26  | 183.9   | 21.36          |
| 4        | 5.02               | 205.21  | 183.8   | 21.41          |
| 5        | 9.37               | 203.90  | 185.0   | 18.90          |
| 6        | 4.83               | 204.19  | 184.1   | 20.09          |
| 7        | 3.82               | 206.42  | 184.0   | 22.42          |
| 8        | 7.53               | 205.78  | 184.3   | 21.48          |
| 9        | 7.28               | 203.60  | 184.6   | 19.00          |
| 10       | 6.46               | 203.59  | 184.4   | 19.19          |

55.49

Pipeline Data


| Node Number | Up-stream | Dn-stream | Dia.<br>m | Length<br>m | Friction<br>Co-efficient | Head Loss<br>m | Flow<br>l/sec | Velocity<br>m/sec | H.Gradient<br>‰ |
|-------------|-----------|-----------|-----------|-------------|--------------------------|----------------|---------------|-------------------|-----------------|
| 0           | 1         | 250       | 84        | 120         | 0.51                     | 55.49          | 1.13          | 6.17              |                 |
| 1           | 2         | 150       | 310       | 120         | 1.03                     | 10.44          | 0.59          | 3.37              |                 |
| 2           | 3         | 150       | 380       | 120         | 0.86                     | 8.50           | 0.48          | 2.31              |                 |
| 3           | 4         | 150       | 460       | 120         | 0.05                     | 1.64           | 0.09          | 0.11              |                 |
| 4           | 5         | 150       | 240       | 120         | 1.31                     | 13.67          | 0.77          | 5.56              |                 |
| 5           | 6         | 100       | 480       | 120         | -0.29                    | -1.44          | -0.18         | 0.62              |                 |
| 6           | 1         | 150       | 500       | 120         | -2.96                    | -14.27         | -0.81         | 6.02              |                 |
| 1           | 7         | 200       | 140       | 120         | 0.73                     | 28.41          | 0.91          | 5.30              |                 |
| 7           | 8         | 200       | 160       | 120         | 0.64                     | 24.59          | 0.78          | 4.06              |                 |
| 8           | 4         | 200       | 280       | 120         | 0.57                     | 17.06          | 0.54          | 2.06              |                 |
| 6           | 9         | 150       | 290       | 120         | 0.59                     | 8.00           | 0.45          | 2.06              |                 |
| 9           | 10        | 150       | 520       | 120         | 0.01                     | 0.72           | 0.04          | 0.02              |                 |
| 10          | 5         | 150       | 280       | 120         | -0.31                    | -5.74          | -0.33         | 1.12              |                 |

5) Network Analysis (Madina Town: DMA II - 3)

Day Maximum Demand : 3,050 m<sup>3</sup>/d      Peak Hourly Demand: 216 m<sup>3</sup>/h  
 60.01 l/s  
 (Peak Hourly Factor: 1.7 )

| Node. No.:       | 1     | 2     | 3     | 4     | 5     | 6     | Σq    |     |
|------------------|-------|-------|-------|-------|-------|-------|-------|-----|
| Discharge (l/s): | 15.00 | 15.00 | 10.25 | 10.25 | 4.75  | 4.76  | 60.01 |     |
| Ground level:    | 184.5 | 183.8 | 184.0 | 184.7 | 184.7 | 184.6 |       |     |
| Section:         | ①~②   |       | ①~⑤   | ②~③   | ③~④   | ④~①   | ⑤~⑥   | ⑥~② |
| Diameter (mm):   | 200   |       | 150   | 150   | 150   | 150   | 150   | 150 |
| Length (m):      | 670   |       | 330   | 710   | 710   | 670   | 600   | 300 |

a. Network Layout





b. Network Analysis

Node Data

| Node No. | Discharge<br>l/sec | WL<br>m | GL<br>m | Eff. Head<br>m |
|----------|--------------------|---------|---------|----------------|
| 0        | -60.01             | 207.16  | 184.6   | 22.56          |
| 1        | 15.00              | 206.18  | 184.5   | 21.68          |
| 2        | 15.00              | 204.14  | 183.8   | 20.34          |
| 3        | 10.25              | 202.78  | 184.0   | 18.78          |
| 4        | 10.25              | 202.95  | 184.7   | 18.25          |
| 5        | 4.75               | 204.96  | 184.7   | 20.26          |
| 6        | 4.76               | 204.17  | 184.6   | 19.57          |

Pipeline Data


| Node Number | Dia.      | Length | Friction | Head Loss    | Flow  | Velocity | H.Gradient |      |
|-------------|-----------|--------|----------|--------------|-------|----------|------------|------|
| Up-stream   | Dn-stream | m      | m        | Co-efficient | m     | l/sec    | m/sec      | ‰    |
| 0           | 1         | 250    | 140      | 120          | 0.99  | 60.01    | 1.22       | 7.13 |
| 1           | 2         | 200    | 670      | 120          | 2.03  | 21.20    | 0.68       | 3.08 |
| 2           | 3         | 150    | 710      | 120          | 1.36  | 7.75     | 0.44       | 1.94 |
| 3           | 4         | 150    | 710      | 120          | -0.17 | -2.50    | -0.14      | 0.24 |
| 4           | 1         | 150    | 670      | 120          | -3.22 | -12.75   | -0.72      | 4.89 |
| 1           | 5         | 150    | 330      | 120          | 1.22  | 11.06    | 0.63       | 3.76 |
| 5           | 6         | 150    | 600      | 120          | 0.79  | 6.31     | 0.36       | 1.33 |
| 6           | 2         | 150    | 300      | 120          | 0.03  | 1.55     | 0.09       | 0.10 |

6) Network Analysis (Madina Town: DMA II - 4)

Day Maximum Demand : Day Max. 4,680 m<sup>3</sup>/d Peak Hour: 332 m<sup>3</sup>/h  
 92.08 l/s  
 (Peak Hourly Factor: 1.7)

|                  |       |        |       |       |       |       |       |       |
|------------------|-------|--------|-------|-------|-------|-------|-------|-------|
| Node. No.:       | 1     | 2      | 3     | 4     | 5     | 6     | 7     |       |
| Discharge (l/s): | 0.00  | 4.60   | 3.68  | 8.29  | 5.53  | 10.12 | 8.29  |       |
| Ground level:    | 183.5 | 183.40 | 183.8 | 183.9 | 184.1 | 184.6 | 184.2 |       |
| Section:         | ①~②   | ②~③    | ③~④   | ④~⑤   | ⑤~⑥   | ⑥~⑦   | ⑧~⑫   | ⑦~⑧   |
| Diameter (mm):   | 250   | 200    | 150   | 150   | 150   | 150   | 150   | 150   |
| Length (m):      | 100   | 250    | 310   | 680   | 500   | 350   | 480   | 160   |
|                  |       |        |       |       |       |       |       |       |
| Node. No.:       | 8     | 9      | 10    |       | 11    | 12    | 13    | Σq    |
| Discharge (l/s): | 9.21  | 9.21   | 10.12 |       | 9.21  | 5.53  | 8.29  | 92.08 |
| Ground level:    | 184.4 | 184.3  | 183.8 |       | 183.8 | 194.6 | 185.0 |       |
| Section:         | ⑧~⑨   | ⑨~⑩    | ⑩~⑪   | ⑩~①   | ⑪~④   | ⑫~⑬   | ⑬~⑧   |       |
| Diameter (mm):   | 150   | 150    | 200   | 250   | 200   | 150   | 150   |       |
| Length (m):      | 290   | 360    | 290   | 380   | 320   | 350   | 310   |       |

a. Network Layout



b. Network Analysis

Node Data

| Node No. | Discharge<br>l/sec | WL<br>m | GL<br>m | Eff. Head<br>m |
|----------|--------------------|---------|---------|----------------|
| 0        | -92.08             | 206.13  | 183.4   | 22.73          |
| 1        | 0.00               | 205.15  | 183.5   | 21.65          |
| 2        | 4.60               | 204.87  | 183.4   | 21.47          |
| 3        | 3.68               | 203.22  | 183.8   | 19.42          |
| 4        | 8.29               | 201.59  | 183.9   | 17.69          |
| 5        | 5.53               | 199.29  | 184.1   | 15.19          |
| 6        | 10.12              | 198.86  | 184.6   | 14.26          |

| Node No. | Discharge<br>l/sec | WL<br>m | GL<br>m | Eff. Head<br>m |
|----------|--------------------|---------|---------|----------------|
| 7        | 8.29               | 199.88  | 184.2   | 15.68          |
| 8        | 9.21               | 199.34  | 184.4   | 14.94          |
| 9        | 9.21               | 199.90  | 184.3   | 15.60          |
| 10       | 10.12              | 202.85  | 183.8   | 19.05          |
| 11       | 9.21               | 201.36  | 183.8   | 17.56          |
| 12       | 5.53               | 198.51  | 184.6   | 13.91          |
| 13       | 8.29               | 198.52  | 185.0   | 13.52          |

Pipeline Data


| Node Number | Dia.      | Length | Friction     | Head Loss | Flow  | Velocity | H.Gradient |       |
|-------------|-----------|--------|--------------|-----------|-------|----------|------------|-------|
| Up-stream   | Dn-stream | m      | Co-efficient | m         | l/sec | m/sec    | %          |       |
| 0           | 1         | 250    | 63           | 120       | 0.98  | 92.08    | 1.88       | 15.75 |
| 1           | 2         | 250    | 100          | 120       | 0.28  | 36.79    | 0.75       | 2.89  |
| 2           | 3         | 200    | 250          | 120       | 1.65  | 32.19    | 1.03       | 6.68  |
| 3           | 4         | 200    | 310          | 120       | 1.63  | 28.51    | 0.91       | 5.34  |
| 4           | 5         | 150    | 680          | 120       | 2.30  | 10.55    | 0.60       | 3.44  |
| 5           | 6         | 150    | 500          | 120       | 0.43  | 5.02     | 0.28       | 0.87  |
| 6           | 7         | 150    | 350          | 120       | -1.02 | -9.73    | -0.55      | 2.96  |
| 7           | 8         | 150    | 160          | 120       | 0.55  | 10.60    | 0.60       | 3.47  |
| 8           | 9         | 150    | 290          | 120       | -0.56 | -7.81    | -0.44      | 1.97  |
| 9           | 10        | 150    | 360          | 120       | -2.96 | -17.02   | -0.96      | 8.34  |
| 10          | 11        | 200    | 290          | 120       | 1.49  | 28.15    | 0.90       | 5.21  |
| 10          | 1         | 250    | 380          | 120       | -2.30 | -55.29   | -1.13      | 6.13  |
| 11          | 7         | 200    | 280          | 120       | 1.48  | 28.61    | 0.91       | 5.37  |
| 11          | 4         | 200    | 320          | 120       | -0.23 | -9.67    | -0.31      | 0.72  |
| 6           | 12        | 150    | 480          | 120       | 0.35  | 4.63     | 0.26       | 0.75  |
| 12          | 13        | 150    | 350          | 120       | -0.01 | -0.91    | -0.05      | 0.04  |
| 13          | 8         | 150    | 310          | 120       | -0.81 | -9.20    | -0.52      | 2.67  |

**Reference: Distribution System for Requirement in Year 2028**

(1) Hydraulic / Network Analysis and Sizing of Distribution Primary Main

1) Hydraulic Analysis (DZ I Abdulahpur)

|                            | unit              | Present Plan (2028) |          |          |
|----------------------------|-------------------|---------------------|----------|----------|
|                            |                   | Zone I              | Zone I-1 | Zone I-2 |
| Design Flow                |                   |                     |          |          |
| Day Max. Distribution Flow | m <sup>3</sup> /d | 5,960               | 3,100    | 2,860    |
| Peak Hourly Flow           | m <sup>3</sup> /h | 373                 | 194      | 179      |
|                            | m <sup>3</sup> /s | 103.47              | 53.82    | 49.65    |



b. Hydraulic Analysis

| Section | Flow (l/s) | ND (mm) | L (m) | i (‰) | hf (m) | GL    | WL* (m) | Eff. Head (m) |
|---------|------------|---------|-------|-------|--------|-------|---------|---------------|
| (0)     |            |         |       |       |        | 186.1 | 210.60  | 24.5          |
| (1)     | 103.5      | 350     | 630   | 3.80  | 2.39   | 186.3 | 208.21  | 21.9          |
| (2)     | 49.7       | 300     | 100   | 2.07  | 0.21   | 185.1 | 208.00  | 22.9          |


Note \* LWL of OHR + 211.10  
 loss in Distribution Center as 0.5m is assumed.



2) Network Analysis (DZ II Madina Town No.2)

| Design Flow        | unit               | Zone II | DMA II-1 | DMA II-2 | DMA II-3 | DMA II-4 |
|--------------------|--------------------|---------|----------|----------|----------|----------|
| Day maximum Demand | m <sup>3</sup> /d  | 11,900  | 3,770    | 2,180    | 2,360    | 3,590    |
| Peak Hourly Demand | m <sup>3</sup> /hr | 744     | 236      | 136      | 148      | 224      |
|                    | l/s                | 206.60  | 65.45    | 37.85    | 40.97    | 62.33    |

a. Network Layout



b. Network Analysis

Node Data

| Node No. | Type | Discharge<br>l/sec | WL* <sup>1</sup><br>m | GL<br>m | Eff. Head<br>m | Note |
|----------|------|--------------------|-----------------------|---------|----------------|------|
| 0        |      | -206.60            | 209.60                | 186.1   | 23.50          |      |
| 1        |      | 0.00               | 209.40                | 183.9   | 25.50          |      |
| 2        |      | 37.85              | 208.40                | 183.7   | 24.75          | DM 2 |
| 3        |      | 62.33              | 207.47                | 183.4   | 24.04          | DM 4 |
| 4        |      | 40.97              | 208.09                | 184.6   | 23.51          | DM 3 |
| 5        |      | 65.45              | 208.29                | 185.8   | 22.45          | DM 1 |

note \*: LWL of OHR + 209.60

Pipeline Data

| Up-stream | Node Number | Dn-stream | Dia.<br>m | Length<br>m | Friction<br>Co-efficient | Head Loss<br>m | Flow<br>l/sec | Velocity<br>m/sec | H. gradient<br>‰ |
|-----------|-------------|-----------|-----------|-------------|--------------------------|----------------|---------------|-------------------|------------------|
| 0         | 1           | 1         | 450       | 50          | 120                      | 0.20           | 206.60        | 1.30              | 4.01             |
| 1         | 2           | 2         | 450       | 590         | 120                      | 1.00           | 130.55        | 0.82              | 1.72             |
| 2         | 3           | 3         | 300       | 300         | 120                      | 0.93           | 62.33         | 0.88              | 3.15             |
| 4         | 5           | 5         | 300       | 1630        | 120                      | -0.19          | -10.60        | -0.15             | -0.12            |
| 4         | 2           | 2         | 400       | 1520        | 120                      | -0.31          | -30.37        | -0.24             | -0.21            |
| 5         | 1           | 1         | 400       | 1010        | 120                      | -1.12          | -76.05        | -0.61             | -1.12            |


## (2) Network Analysis and Sizing of Distribution Secondary Main

### 1) Network Analysis (Abdullahpur DMA I-1)

Day Maximum Demand 3,100 m<sup>3</sup>/d      Peak Hourly Demand 219.6 m<sup>3</sup>/h  
 61.00 l/s  
 (Peak Hourly Factor: 1.7 )

|                  |       |       |        |       |       |       |       |
|------------------|-------|-------|--------|-------|-------|-------|-------|
| Node No.:        | 1     | 2     | 3      | 4     | 5     | 6     | 7     |
| Discharge (l/s): | 0.00  | 9.75  | 0.00   | 14.00 | 11.75 | 13.00 | 0.00  |
| Ground Level:    | 185.3 | 185.5 | 185.50 | 185.6 | 185.7 | 185.8 | 185.9 |
| Section:         | ①~②   | ②~③   | ③~④    | ④~⑤   | ⑤~⑧   | ⑧~⑦   | ⑦~⑧   |
| Diameter (mm):   | 200   | 200   | 150    | 150   | 150   | 100   | 100   |
| Length (m):      | 210   | 70    | 100    | 200   | 150   | 130   | 120   |
| Node No.:        | 8     | 9     | 10     | 11    | Σq    |       |       |
| Discharge (l/s): | 2.75  | 0.00  | 0.00   | 9.75  | 61.00 |       |       |
| Ground Level:    | 185.8 | 185.8 | 185.7  | 185.6 |       |       |       |
| Section:         | ⑧~⑨   | ⑨~⑩   | ⑩~⑪    | ⑪~②   |       |       |       |
| Diameter (mm):   | 250   | 250   | 150    | 150   |       |       |       |
| Length (m):      | 150   | 160   | 150    | 150   |       |       |       |

a. Network Layout



b. Network Analysis

Node Data

| Node No. | Flow<br>l/sec | WL<br>m | GL<br>m | Eff. Head<br>m |
|----------|---------------|---------|---------|----------------|
| 0        | -61.00        | 208.21  | 185.30  | 22.91          |
| 1        | 0.00          | 207.64  | 185.30  | 22.34          |
| 2        | 9.75          | 203.13  | 185.50  | 17.63          |
| 3        | 0.00          | 202.78  | 185.50  | 17.28          |
| 4        | 14.00         | 200.78  | 185.60  | 15.18          |
| 5        | 11.75         | 199.70  | 185.70  | 14.00          |
| 6        | 13.00         | 198.05  | 185.80  | 12.25          |
| 7        | 0.00          | 198.96  | 185.90  | 13.06          |
| 8        | 2.75          | 199.86  | 185.80  | 14.06          |
| 9        | 0.00          | 199.93  | 185.80  | 14.13          |
| 10       | 0.00          | 200.01  | 185.70  | 14.31          |
| 11       | 9.75          | 200.86  | 185.60  | 15.26          |

Pipeline Data


| Node Number         | Dia. | Length | Friction     | Head Loss | Flow   | Velocity | H.Gradient |
|---------------------|------|--------|--------------|-----------|--------|----------|------------|
| Up-stream Dn-stream | m    | m      | Co-efficient | m         | l/sec  | m/sec    | ‰          |
| 0 1                 | 250  | 78     | 120          | 0.57      | 61.00  | 1.24     | 7.35       |
| 1 2                 | 200  | 210    | 120          | 4.52      | 61.00  | 1.94     | 21.80      |
| 2 3                 | 200  | 70     | 120          | 0.35      | 27.56  | 0.88     | 5.01       |
| 3 4                 | 150  | 100    | 120          | 2.00      | 27.56  | 1.56     | 20.34      |
| 4 5                 | 150  | 200    | 120          | 1.08      | 13.56  | 0.77     | 5.48       |
| 5 8                 | 150  | 150    | 120          | -0.16     | -5.60  | -0.32    | 1.07       |
| 5 6                 | 100  | 130    | 120          | 1.65      | 7.41   | 0.94     | 12.90      |
| 6 7                 | 100  | 120    | 120          | -0.90     | -5.59  | -0.71    | 7.66       |
| 7 8                 | 100  | 120    | 120          | -0.90     | -5.59  | -0.71    | 7.66       |
| 8 9                 | 250  | 150    | 120          | -0.07     | -13.94 | -0.28    | 0.48       |
| 9 10                | 250  | 160    | 120          | -0.08     | -13.94 | -0.28    | 0.48       |
| 10 11               | 150  | 150    | 120          | -0.85     | -13.94 | -0.79    | 5.77       |
| 11 2                | 150  | 150    | 120          | -2.27     | -23.69 | -1.34    | 15.38      |

2) Network Analysis (Abdulahpur: DMA I - 2)

Day Maximum Demand : 2,860 m<sup>3</sup>/d      Peak Hourly Demand: 202.6 m<sup>3</sup>/h  
 56.3 l/s  
 (Peak Hourly Factor: 1.7 )

|                  |       |       |       |       |       |       |       |
|------------------|-------|-------|-------|-------|-------|-------|-------|
| Node. No.:       | 1     | 2     | 3     | 4     | 5     | 6     | 7     |
| Discharge (l/s): | 0.00  | 5.30  | 5.90  | 5.90  | 15.50 | 8.10  | 6.90  |
| Ground level:    | 185.1 | 185.2 | 185.4 | 185.9 | 186.1 | 185.5 | 185.5 |
| Section:         | ①~②   | ②~③   | ③~④   | ④~⑤   | ⑤~⑥   | ⑥~⑦   | ⑥~④   |
| Diameter (mm):   | 200   | 200   | 200   | 150   | 100   | 100   | 100   |
| Length (m):      | 270   | 70    | 180   | 340   | 150   | 70    | 150   |
| Node. No.:       | 8     | Σq    |       |       |       |       |       |
| Discharge (l/s): | 8.70  | 56.30 |       |       |       |       |       |
| Ground level:    | 185.4 |       |       |       |       |       |       |
| Section:         | ⑧~②   |       |       |       |       |       |       |
| Diameter (mm):   | 100   |       |       |       |       |       |       |
| Length (m):      | 190   | 1,390 |       |       |       |       |       |

a. Network Layout





b. Network Analysis

Node Data

| Node No. | Discharge<br>l/sec | WL<br>m | GL<br>m | Eff. Head<br>m |
|----------|--------------------|---------|---------|----------------|
| 0        | -56.30             | 208.00  | 185.10  | 22.90          |
| 1        | 0.00               | 207.51  | 185.10  | 22.41          |
| 2        | 5.30               | 202.51  | 185.20  | 17.31          |
| 3        | 5.90               | 201.83  | 185.40  | 16.43          |
| 4        | 5.90               | 200.54  | 185.90  | 14.64          |
| 5        | 15.50              | 197.43  | 186.10  | 11.33          |
| 6        | 8.10               | 197.17  | 185.50  | 11.67          |
| 7        | 6.90               | 196.86  | 185.50  | 11.36          |
| 8        | 8.70               | 197.15  | 185.40  | 11.75          |

Pipeline Data


| Node Number |           | Dia. | Length | Friction     | Head Loss | Flow   | Velocity | H.Gradient |
|-------------|-----------|------|--------|--------------|-----------|--------|----------|------------|
| Up-stream   | Dn-stream | m    | m      | Co-efficient | m         | l/sec  | m/sec    | %          |
| 0           | 1         | 250  | 78     | 120          | 0.49      | 56.30  | 1.15     | 6.34       |
| 1           | 2         | 200  | 270    | 120          | 5.01      | 56.30  | 1.79     | 18.79      |
| 2           | 3         | 200  | 70     | 120          | 0.68      | 39.60  | 1.26     | 9.80       |
| 3           | 4         | 200  | 180    | 120          | 1.29      | 33.70  | 1.07     | 7.27       |
| 4           | 5         | 150  | 340    | 120          | 3.11      | 18.05  | 1.02     | 9.30       |
| 5           | 6         | 100  | 150    | 120          | 0.26      | 2.55   | 0.32     | 1.79       |
| 6           | 7         | 100  | 70     | 120          | 0.31      | 4.20   | 0.53     | 4.51       |
| 6           | 4         | 100  | 160    | 120          | -3.37     | -9.75  | -1.24    | 21.44      |
| 7           | 8         | 100  | 150    | 120          | -0.29     | -2.70  | -0.34    | 2.00       |
| 8           | 2         | 100  | 190    | 120          | -5.36     | -11.40 | -1.45    | 28.65      |

3) Network Analysis (Madina Town: DMA II - 1)

Day Maximum Demand : 3,770 m<sup>3</sup>/d      Peak Hourly Demand: 267.0 m<sup>3</sup>/h  
 74.18 l/s  
 (Peak Hourly Factor: 1.7)

| Node No.:     | 1     | 2     | 3     | 4     | 5     | 6     | Σq    |
|---------------|-------|-------|-------|-------|-------|-------|-------|
| Demand (l/s): | 11.87 | 9.87  | 8.90  | 11.94 | 15.80 | 15.80 | 74.18 |
| GL:           | 185.6 | 186.8 | 184.6 | 184.6 | 184.9 | 185.1 |       |
| Section:      | ①~②   | ①~④   | ②~③   | ③~④   | ④~⑤   | ⑤~⑥   | ⑥~①   |
| ND:           | 150   | 200   | 150   | 150   | 150   | 150   | 150   |
| L:            | 420   | 570   | 520   | 390   | 360   | 600   | 350   |

a. Network Layout



b. Network Analysis

Node Data

| Node No. | Discharge<br>l/sec | WL<br>m | GL<br>m | Eff. Head<br>m |
|----------|--------------------|---------|---------|----------------|
| 0        | -74.18             | 208.29  | 185.8   | 22.49          |
| 1        | 11.87              | 207.67  | 185.6   | 22.07          |
| 2        | 9.87               | 205.04  | 186.8   | 18.24          |
| 3        | 8.90               | 204.62  | 184.6   | 20.02          |
| 4        | 11.94              | 204.85  | 184.6   | 20.25          |
| 5        | 15.80              | 203.40  | 184.9   | 18.50          |
| 6        | 15.80              | 203.78  | 185.1   | 18.68          |

Pipeline Data


| Node Number | Dia.      | Length | Friction     | Head Loss | Flow  | Velocity | H.Gradient |       |
|-------------|-----------|--------|--------------|-----------|-------|----------|------------|-------|
| Up-stream   | Dn-stream | m      | Co-efficient | m         | l/sec | m/sec    | %          |       |
| 0           | 1         | 250    | 60           | 120       | 0.63  | 74.18    | 1.51       | 10.56 |
| 1           | 2         | 150    | 420          | 120       | 2.63  | 14.70    | 0.83       | 6.36  |
| 2           | 3         | 150    | 520          | 120       | 0.41  | 4.83     | 0.27       | 0.81  |
| 3           | 4         | 150    | 390          | 120       | -0.23 | -4.07    | -0.23      | 0.59  |
| 4           | 5         | 150    | 360          | 120       | 1.45  | 11.56    | 0.66       | 4.08  |
| 5           | 6         | 150    | 600          | 120       | -0.38 | -4.24    | -0.24      | 0.64  |
| 6           | 1         | 150    | 350          | 120       | -3.89 | -20.04   | -1.13      | 11.28 |
| 1           | 4         | 200    | 570          | 120       | 2.82  | 27.57    | 0.88       | 5.02  |

4) Network Analysis (Madina Town: DMA II - 2)

Demand : Day Max. 2,180 m<sup>3</sup>/d Peak Hour: 154 m<sup>3</sup>/h  
 42.89 l/s  
 (Peak hourly Factor: 1.7 )

|               |       |       |       |       |       |       |
|---------------|-------|-------|-------|-------|-------|-------|
| Node No.:     | 1     | 2     | 3     | 4     | 5     |       |
| Demand (l/s): | 1.84  | 1.49  | 5.30  | 3.88  | 10.97 |       |
| GL:           | 183.5 | 183.4 | 183.9 | 183.8 | 185.0 |       |
| Section:      | ①~②   | ①~⑦   | ②~③   | ③~④   | ④~⑤   | ⑤~⑧   |
| ND:           | 150   | 200   | 150   | 150   | 150   | 100   |
| L:            | 310   | 140   | 380   | 460   | 240   | 480   |
| Node No.:     | 6     | 7     | 8     | 9     | 10    | Σq    |
| Demand (l/s): | 8.78  | 5.63  | 5.00  | 0.00  | 0.00  | 42.89 |
| GL:           | 184.1 | 184.0 | 184.3 | 184.6 | 184.4 |       |
| Section:      | ⑧~①   | ⑧~⑨   | ⑦~⑧   | ⑧~④   |       |       |
| ND:           | 150   | 150   | 200   | 200   |       |       |
| L:            | 500   | 290   | 160   | 280   |       |       |

a. Network Layout



b. Network Analysis

Node Data

| Node No. | Discharge<br>l/sec | WL<br>m | GL<br>m | Eff. Head<br>m |
|----------|--------------------|---------|---------|----------------|
| 0        | -42.89             | 208.40  | 183.7   | 24.70          |
| 1        | 1.84               | 208.08  | 183.5   | 24.58          |
| 2        | 1.49               | 207.47  | 184.0   | 23.47          |
| 3        | 5.30               | 206.96  | 183.9   | 23.06          |
| 4        | 3.88               | 206.94  | 183.8   | 23.14          |
| 5        | 10.97              | 206.25  | 185.0   | 21.25          |
| 6        | 8.78               | 206.51  | 184.1   | 22.41          |
| 7        | 5.63               | 207.59  | 184.0   | 23.59          |
| 8        | 5.00               | 207.25  | 184.3   | 22.95          |

Pipeline Data

| Node Number |           | Dia. | Length | Friction     | Head Loss | Flow   | Velocity | H.Gradient |
|-------------|-----------|------|--------|--------------|-----------|--------|----------|------------|
| Up-stream   | Dn-stream | m    | m      | Co-efficient | m         | l/sec  | m/sec    | %          |
| 0           | 1         | 250  | 84     | 120          | 0.32      | 42.89  | 0.87     | 3.83       |
| 1           | 2         | 150  | 310    | 120          | 0.61      | 7.89   | 0.45     | 2.01       |
| 2           | 3         | 150  | 380    | 120          | 0.51      | 6.40   | 0.36     | 1.37       |
| 3           | 4         | 150  | 460    | 120          | 0.02      | 1.10   | 0.06     | 0.05       |
| 4           | 5         | 150  | 240    | 120          | 0.69      | 9.62   | 0.55     | 2.90       |
| 5           | 6         | 100  | 480    | 120          | -0.26     | -1.35  | -0.17    | 0.55       |
| 6           | 1         | 150  | 500    | 120          | -1.57     | -10.13 | -0.57    | 3.20       |
| 1           | 7         | 200  | 140    | 120          | 0.50      | 22.03  | 0.70     | 3.31       |
| 7           | 8         | 200  | 160    | 120          | 0.34      | 17.40  | 0.55     | 2.14       |
| 8           | 4         | 200  | 280    | 120          | 0.32      | 12.40  | 0.40     | 1.14       |




5) Network Analysis (Madina Town: DMA II - 3)

Day Maximum Demand : 2,360 m<sup>3</sup>/d      Peak Hourly Demand: 167 m<sup>3</sup>/h  
 (Peak Hourly Factor: 46.44 l/s  
 1.7 )

|               |       |       |       |       |       |       |       |
|---------------|-------|-------|-------|-------|-------|-------|-------|
| Node No.:     | 1     | 2     | 3     | 4     | 5     | 6     | Σq    |
| Demand (l/s): | 15.28 | 15.28 | 7.94  | 7.94  | 0.00  | 0.00  | 46.44 |
| GL:           | 184.5 | 183.8 | 184.0 | 184.7 | 184.7 | 184.6 |       |
| Section:      | ①~②   | ①~⑤   | ②~③   | ③~④   | ④~①   | ⑤~⑥   | ⑥~②   |
| ND:           | 200   | 150   | 150   | 150   | 150   | 150   |       |
| L:            | 670   | 330   | 710   | 710   | 670   | 300   |       |

a. Network Layout



b. Network Analysis

| Node Data |           |        |       |           |  |
|-----------|-----------|--------|-------|-----------|--|
| Node No.  | Discharge | WL     | GL    | Eff. Head |  |
|           | l/sec     | m      | m     | m         |  |
| 0         | -46.44    | 208.09 | 184.6 | 23.49     |  |
| 1         | 15.28     | 207.48 | 184.5 | 22.98     |  |
| 2         | 15.28     | 205.58 | 183.8 | 21.78     |  |
| 3         | 7.94      | 204.94 | 184.0 | 20.94     |  |
| 4         | 7.94      | 205.14 | 184.7 | 20.44     |  |


| Pipeline Data |             |      |        |              |           |        |          |            |
|---------------|-------------|------|--------|--------------|-----------|--------|----------|------------|
| Up-stream     | Node Number | Dia. | Length | Friction     | Head Loss | Flow   | Velocity | H.Gradient |
| Node Number   | Dn-stream   | m    | m      | Co-efficient | m         | l/sec  | m/sec    | %          |
| 0             | 1           | 250  | 140    | 120          | 0.61      | 46.44  | 0.95     | 4.44       |
| 1             | 2           | 200  | 670    | 120          | 1.90      | 20.44  | 0.65     | 2.88       |
| 2             | 3           | 150  | 710    | 120          | 0.64      | 5.16   | 0.29     | 0.92       |
| 3             | 4           | 150  | 710    | 120          | -0.20     | -2.78  | -0.16    | 0.29       |
| 4             | 1           | 150  | 670    | 120          | -2.34     | -10.72 | -0.61    | 3.55       |

6) Network Analysis (Madina Town: DMA II - 4)

Day Maximum Demand : 3,590 m<sup>3</sup>/d Peak Hourly Demand: 254 m<sup>3</sup>/h  
 70.64 l/s  
 (Peak Hourly Factor: 1.7 )

|               |       |        |       |       |       |       |       |       |       |       |       |       |       |       |
|---------------|-------|--------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Node No.:     | 1     | 2      | 3     | 4     | 5     | 6     | 7     | 8     | 9     | 10    | 11    | 12    | 13    | Σq    |
| Demand (l/s): | 0.00  | 3.53   | 2.83  | 6.36  | 4.24  | 12.01 | 6.36  | 13.42 | 7.06  | 7.77  | 7.06  | 0     | 0     | 70.64 |
| GL:           | 183.5 | 183.40 | 183.8 | 183.9 | 184.1 | 184.6 | 184.2 | 184.4 | 184.3 | 183.8 | 183.8 | 194.6 | 185.0 |       |
| Section:      | ①~②   | ②~③    | ③~④   | ④~⑤   | ⑤~⑥   | ⑥~⑦   | ⑦~⑧   | ⑧~⑨   | ⑨~⑩   | ⑩~⑪   | ⑪~⑫   | ⑫~⑬   | ⑬~⑭   |       |
| ND:           | 250   | 200    | 150   | 150   | 150   | 150   | 150   | 150   | 150   | 200   | 250   | 200   | 150   |       |
| L:            | 100   | 250    | 310   | 680   | 500   | 350   | 480   | 290   | 360   | 290   | 380   | 320   | 310   |       |
| Node No.:     | 8     | 9      | 10    | 11    | 12    | 13    | Σq    |       |       |       |       |       |       |       |
| Demand (l/s): | 13.42 | 7.06   | 7.77  | 7.06  | 0     | 0     | 70.64 |       |       |       |       |       |       |       |
| GL:           | 184.4 | 184.3  | 183.8 | 183.8 | 194.6 | 185.0 |       |       |       |       |       |       |       |       |
| Section:      | ⑧~⑨   | ⑨~⑩    | ⑩~⑪   | ⑩~⑫   | ⑪~⑬   | ⑬~⑭   |       |       |       |       |       |       |       |       |
| ND (mm):      | 150   | 150    | 200   | 250   | 200   | 150   |       |       |       |       |       |       |       |       |
| L (m):        | 290   | 360    | 290   | 380   | 320   | 310   |       |       |       |       |       |       |       |       |

a. Network Layout



b. Network Analysis

Node Data


| Node No. | Discharge<br>l/sec | WL<br>m | GL<br>m | Eff. Head<br>m |
|----------|--------------------|---------|---------|----------------|
| 0        | -70.64             | 207.47  | 183.4   | 24.07          |
| 1        | 0.00               | 206.87  | 183.5   | 23.37          |
| 2        | 3.53               | 206.70  | 183.4   | 23.30          |
| 3        | 2.83               | 205.68  | 183.8   | 21.88          |
| 4        | 6.36               | 204.67  | 183.9   | 20.77          |
| 5        | 4.24               | 203.19  | 184.1   | 19.09          |
| 6        | 12.01              | 202.90  | 184.6   | 18.30          |
|          | 28.97              |         |         |                |

| Node No. | Discharge<br>l/sec | WL<br>m | GL<br>m | Eff. Head<br>m |
|----------|--------------------|---------|---------|----------------|
| 7        | 6.36               | 203.60  | 184.2   | 19.40          |
| 8        | 13.42              | 203.52  | 184.4   | 19.12          |
| 9        | 7.06               | 203.81  | 184.3   | 19.51          |
| 10       | 7.77               | 205.47  | 183.8   | 21.67          |
| 11       | 7.06               | 204.53  | 183.8   | 20.73          |
|          | 41.67              |         | 70.64   |                |

Pipeline Data

| Node Number<br>Up-stream Dn-stream | Dia.<br>m | Length<br>m | Friction<br>Co-efficient | Head Loss<br>m | Flow<br>l/sec | Velocity<br>m/sec | H.Gradient<br>‰ |
|------------------------------------|-----------|-------------|--------------------------|----------------|---------------|-------------------|-----------------|
| 0 1                                | 250       | 63          | 120                      | 0.60           | 70.64         | 1.44              | 9.65            |
| 1 2                                | 250       | 100         | 120                      | 0.18           | 28.37         | 0.58              | 1.78            |
| 2 3                                | 200       | 250         | 120                      | 1.02           | 24.84         | 0.79              | 4.14            |
| 3 4                                | 200       | 310         | 120                      | 1.01           | 22.01         | 0.70              | 3.31            |
| 4 5                                | 150       | 680         | 120                      | 1.48           | 8.31          | 0.47              | 2.21            |
| 5 6                                | 150       | 500         | 120                      | 0.29           | 4.07          | 0.23              | 0.59            |
| 6 7                                | 150       | 350         | 120                      | -0.70          | -7.94         | -0.45             | 2.04            |
| 7 8                                | 150       | 160         | 120                      | 0.08           | 7.98          | 0.45              | 2.05            |
| 8 9                                | 150       | 290         | 120                      | -0.29          | -5.44         | -0.31             | 1.01            |
| 9 10                               | 150       | 360         | 120                      | -1.67          | -12.50        | -0.71             | 4.71            |
| 10 11                              | 200       | 290         | 120                      | 0.94           | 22.00         | 0.70              | 3.30            |
| 11 7                               | 200       | 280         | 120                      | 0.93           | 22.29         | 0.71              | 3.38            |
| 11 4                               | 200       | 320         | 120                      | -0.14          | -7.35         | -0.23             | 0.43            |
| 10 1                               | 250       | 380         | 120                      | -1.40          | -42.27        | -0.86             | 3.73            |

# GENERAL LAYOUT OF WATER TREATMENT PLANT



App 7(5)-1

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD




DRAWING TITLE:  
GENERAL LAYOUT OF WATER TREATMENT PLANT

SCALE:  
1/1,000

DRAWING NO.:  
WTP-C-01



# LAYOUT OF INTAKE FACILITIES



App 7(5)-2




PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD

DRAWING TITLE:  
LAYOUT OF INTAKE FACILITIES

SCALE:  
1/500

DRAWING NO:  
WTP-C-02

# INTAKE MOUTH




App 7(5)-3

|   |                                |                 |                          |
|---|--------------------------------|-----------------|--------------------------|
| PROJECT TITLE:<br>THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD | DRAWING TITLE:<br>INTAKE MOUTH | SCALE:<br>1/100 | DRAWING NO.:<br>WTP-C-03 |
|---|--------------------------------|-----------------|--------------------------|

# CONNECTION FACILITIES OF STORAGE TANK

**Detail "A"**

S=1/100




Plan

B-B Section


**Detail "B"**

S=1/100




PLAN

Plane Section



A-A Section



C-C Section

App 7(5)-4


PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER  
TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD

DRAWING TITLE:  
CONNECTION FACILITIES OF STORAGE TANK

SCALE:  
1/100

DRAWING NO.:  
WTP-C-04


# SCREEN AND RAW WATER DISTRIBUTION VALVE CHAMBER




P L A N

B - B SECTION

C - C SECTION



A - A SECTION




PIPE SUPPORT

App 7(5)-5


|   |   |                         |                                 |
|---|---|-------------------------|---------------------------------|
| <p>PROJECT TITLE:<br/>THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD</p> | <p>DRAWING TITLE:<br/>SCREEN AND RAW WATER DISTRIBUTION VALVE CHAMBER</p> | <p>SCALE:<br/>1/100</p> | <p>DRAWING NO:<br/>WTP-C-05</p> |
|---|---|-------------------------|---------------------------------|




# RAW WATER PUMP STATION




Plan - Electric Room



A-A SECTION



Plan - Pump Station



B-B SECTION

App 7(5)-6





PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER  
TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD

DRAWING TITLE:  
RAW WATER PUMP STATION

SCALE:  
1/200

DRAWING NO.:  
WTP-C-06

# RECEIVING AND DISTRIBUTION TANK




App 7(5)-7

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER  
TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD

DRAWING TITLE:  
RECEIVING AND DISTRIBUTION TANK

|                 |                         |
|-----------------|-------------------------|
| SCALE:<br>1/100 | DRAWING NO:<br>WTP-C-07 |
|-----------------|-------------------------|

# COAGULATION, SETTLING TANK AND RAPID SAND FILTER (1)



App 7(5)-8


PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD

DRAWING TITLE:  
COAGULATION, SETTLING TANK AND RAPID SAND FILTER (1)


SCALE:  
1/200

DRAWING NO.:  
WTP-C-08


# COAGULATION, SETTLING TANK AND RAPID SAND FILTER (2)




A-A SECTION



B-B SECTION



C-C SECTION



D-D SECTION

App 7(5)-9

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD


DRAWING TITLE:  
COAGULATION, SETTLING TANK AND RAPID SAND FILTER (2)

SCALE:  
1/200


DRAWING NO:  
WTP-C-09




# COAGULATION, SETTLING TANK AND RAPID SAND FILTER (3)



E-E SECTION



G-G SECTION



F-F SECTION

App 7(5)-10


PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER  
TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD

DRAWING TITLE:  
COAGULATION, SETTLING TANK AND RAPID SAND FILTER (3)


SCALE:  
1/200

DRAWING NO.:  
WTP-C-10

# COAGULATION, SETTLING TANK AND RAPID SAND FILTER (4)



H-H SECTION



I-I SECTION

App 7(5)-11


PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD

DRAWING TITLE:  
COAGULATION, SETTLING TANK AND RAPID SAND FILTER (4)


SCALE:  
1/200

DRAWING NO.:  
WTP-C-11

# CLEAR WATER RESERVOIR AND TRANSMISSION PUMP STATION (1)




PLAN



STAIRS

Section +185.20      Section +181.23      Section +179.43



Pipe Arrangement

App 7(5)-12


PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD

DRAWING TITLE:  
CLEAR WATER RESERVOIR AND TRANSMISSION PUMP STATION (1)


SCALE:  
1/250

DRAWING NO:  
WTP-C-12


# CLEAR WATER RESERVOIR AND TRANSMISSION PUMP STATION (2)




A-A SECTION




C-C SECTION



B-B SECTION



Overflow Pipe



Stairs - Section

App 7(5)-13

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD


DRAWING TITLE:  
CLEAR WATER RESERVOIR AND TRANSMISSION PUMP STATION (2)

SCALE:  
1/250

DRAWING NO.:  
WTP-C-13

# WASTE WATER TANK (1)

PLAN




App 7(5)-14


|  |   |  |                 |                         |
|--|---|--|-----------------|-------------------------|
|  | PROJECT TITLE:<br>THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD | DRAWING TITLE:<br>WASTE WATER TANK (1) | SCALE:<br>1/100 | DRAWING NO:<br>WTP-C-14 |
|  |   |  |                 |                         |




# WASTE WATER TANK (2)




A - A SECTION



C - C SECTION



B - B SECTION



D - D SECTION

App 7(5)-15


PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER  
TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD

DRAWING TITLE:  
WASTE WATER TANK (2)


SCALE:  
1/100

DRAWING NO:  
WTP-C-15

# SLUDGE GRAVITY THICKENER



PLAN



SECTION A-A


App 7(5)-16

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER  
TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD


DRAWING TITLE:  
SLUDGE GRAVITY THICKENER

|        |              |
|--------|--------------|
| SCALE: | DRAWING NO.: |
| 1/100  | WTP-C-16     |


# SLUDGE TRANSFER PUMP STATION




P L A N



SECTION A-A



P L A N - Pump Room



SECTION B-B

App 7(5)-17






PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER  
TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISLABAD

DRAWING TITLE:  
SLUDGE TRANSFER PUMP STATION

SCALE:  
1/100

DRAWING NO:  
WTP-C-17

# SLUDGE DRYING BED



|   |                                     |        |              |
|---|-------------------------------------|--------|--------------|
| PROJECT TITLE:<br>THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD | DRAWING TITLE:<br>SLUDGE DRYING BED | SCALE: | DRAWING NO.: |
|   |                                     | 1/250  | WTP-C-18     |

# ADMINISTRATION BUILDING(1)

Layout Plan

S=1/150


App 7(5)-19

### Monitoring/Operation Room

| ID No. | NAME                                |
|--------|-------------------------------------|
| ①      | AB-ES-1 ENGINEERING STATION         |
| ②      | AB-OS-1 OPERATOR STATION            |
| ③      | AB-OS-2 OPERATOR STATION            |
| ④      | AB-PR-1 A4 COLOR LASER PRINTER      |
| ⑤      | AB-PR-2 A3 MONOCHROME LASER PRINTER |
| ⑥      | AB-PDB POWER DISTRIBUTION PANEL     |
| ⑦      | AB-TM TELEMETER PANEL               |
| ⑧      | AB-CS CAMERA SERVER                 |
| ⑨      | AB-GMP GRAPHIC MONITORING PANEL     |

### Laboratory - Chemical/Biological

|                 | Furniture         | Equipment/Testing  |
|-----------------|-------------------|--|
| Chemical Test   | (C1) Center Table | Water quality testing  |
|                 | (S1) Side Table   | pH meter,<br>Turbidity meter,<br>Conductivity,<br>Stirrer<br>Spectrophotometer |
|                 | (S2) Side Table   | Jar Tester   |
|                 | (B1) Sink Basin   |  |
|                 | (E2) Refrigerator |  |
| Biological Test | (C2) Center Table | Water quality testing  |
|                 | (B2) Sink Basin   |  |



- ±000 GL+
- Reinforced Concrete Pillar (500mm x 500mm)
- Brick Wall and Mortar Finish (total thickness 160mm)
- Partition Wall(Print Plywood)
- Roof Drain

P L A N

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD

DRAWING TITLE:  
Administration Building(1) - Layout Plan

SCALE:  
1/150


DRAWING NO:  
WTP-A-01




# ADMINISTRATION BUILDING(2)

Side View


S=1/150




FRONT VIEW  
(Entrance Facade)



SIDE VIEW  
(Eastwest)



BACK VIEW



Key Plan

App 7(5)-20

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD


DRAWING TITLE:  
Administration Building(2) -Side View

SCALE:  
1/150


DRAWING NO:  
WTP-A-02

# ADMINISTRATION BUILDING(3)


Section S=1/150



A-A SECTION



B-B SECTION



Key Plan

App 7(5)-21

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD

DRAWING TITLE:  
Administration Building(3) - Section


SCALE:  
1/150

DRAWING NO:  
WTP-A-03


# ADMINISTRATION BUILDING(4)

Sectional Details


S=1/50




SECTIONAL DETAIL A




SECTIONAL DETAIL B  
(Roof Drain)




Canopy  
Service Entrance



Step  
Entrance



Corridor



Key Plan

App 7(5)-22

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER  
TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD

DRAWING TITLE:  
Administration Building(4) -Sectional Details


SCALE:  
1/50

DRAWING NO:  
WTP-A-04

# CHEMICAL BUILDING

S=1/100

App 7(5)-23



## PLAN

| ID No.    | NAME                                   |
|-----------|--|
| ① CHB-MCC | MCC FOR CHEMICAL BUILDING              |
| ② CHB-RY  | AUX. RELAY PANEL FOR CHEMICAL BUILDING |
| ③ CHB-IP  | INSTRUMENTATION PANEL                  |


- ±0.00 GL+
- Reinforced Concrete Pillar (500mm x 500mm)
- Brick Wall (thickness 160mm)
- Roof Drain PVC ND80

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD


DRAWING TITLE:  
Chemical Building - Layout Plan

SCALE:  
1/100

DRAWING NO.:  
WTP-A-10



FRONT VIEW



SIDE VIEW

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER  
TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD


DRAWING TITLE:  
Chemical Building – Side View

SCALE:

1/100

DRAWING NO:

WTP-A-11



SECTION A-A


PROJECT TITLE:  
 THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER  
 TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD

DRAWING TITLE:  
 Chemical Building - Section(1)


SCALE:  
 1/100

DRAWING NO:  
 WTP-A-12






SECTION B-B



SECTIONAL DETAIL (Solution Tank Room)



SECTIONAL DETAIL (Roof Drain)



PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD

DRAWING TITLE:  
Chemical Building - Section(2), Sectional Detail

SCALE:  
1/100, 1/50

DRAWING NO:  
WTP-A-13

# GENERAL LAYOUT




App 7(5)-27


|  |   |                                  |                 |                          |
|--|---|----------------------------------|-----------------|--------------------------|
|  | PROJECT TITLE:<br>THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD | DRAWING TITLE:<br>GENERAL LAYOUT | SCALE:<br>1/200 | DRAWING NO:<br>DC#1-C-01 |
|--|---|----------------------------------|-----------------|--------------------------|

DC#1-01

# GROUND RESERVOIR (1)



P L A N



P L A N

App 7(5)-28

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER  
TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD


DRAWING TITLE:  
GROUND RESERVOIR (1)

SCALE:  
1/200


DRAWING NO:  
DC#1-C-02

DC#1-02


# GROUND RESERVOIR (2)




A - A SECTION



B - B SECTION



C - C SECTION



D - D SECTION

App 7(5)-29

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER  
TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD







DRAWING TITLE:  
GROUND RESERVOIR (2)

SCALE:  
1/200

DRAWING NO.:  
DC#1-C-03

DC#1-03

# OVERHEAD RESERVOIR (1)



App 7(5)-30

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER  
TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD




DRAWING TITLE:  
OVERHEAD RESERVOIR (1)

SCALE:  
1/200

DRAWING NO.:  
DC#1-C-05

DC#1-04

# OVERHEAD RESERVOIR (2)



Ventilation tower  
S=1/50

App 7(5)-31

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER  
TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD

DRAWING TITLE:  
OVERHEAD RESERVOIR (2)


SCALE:  
1/200

DRAWING NO:  
DC#1-C-06

DC#1-05



# GENERAL LAYOUT



App 7(5)-32

PROJECT TITLE:  
 THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER  
 TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD



DRAWING TITLE:  
 GENERAL LAYOUT

SCALE:  
 1/200

DRAWING NO:  
 DC#2-C-01

DC#2-01

# GROUND RESERVOIR (1)



App 7(5)-33


PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD

DRAWING TITLE:  
GROUND RESERVOIR (1)

|        |              |
|--------|--------------|
| SCALE: | DRAWING NO.: |
| 1/200  | DC#2-C-02    |

DC#2-02

# GROUND RESERVOIR (2)



SECTIONAL PLAN (2)

App 7(5)-34

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER  
TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD


DRAWING TITLE:  
GROUND RESERVOIR (2)

SCALE:  
1/200


DRAWING NO.:  
DC#2-C-02

DC#2-03

# GROUND RESERVOIR (3)



A - A SECTION



B - B SECTION

App 7(5)-35

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER  
TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD


DRAWING TITLE:  
GROUND RESERVOIR (3)

SCALE:  
1/200


DRAWING NO:  
DC#2-C-04

DC#2-04

# GROUND RESERVOIR (4)



C - C SECTION



D - D SECTION

App 7(5)-36

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD


DRAWING TITLE:  
GROUND RESERVOIR (4)

SCALE:  
1/200


DRAWING NO.:  
DC#2-C-05

DC#2-05

# GROUND RESERVOIR (5)



E - E SECTION



F - F SECTION

App 7(5)-37

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER  
TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD

DRAWING TITLE:  
GROUND RESERVOIR (5)

SCALE:

1/200





DRAWING NO.:

DC#2-C-06

DC#2-06



# OVERHEAD RESERVOIR (1)



App 7(5)-38

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER  
TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD


DRAWING TITLE:  
OVERHEAD RESERVOIR (1)

SCALE:  
1/200


DRAWING NO.:  
DC#2-C-09

DC#2-07


# OVERHEAD RESERVOIR (2)



**D - D SECTION**  
S=1/200



**PLAN**



**SECTION**



**Ventilation tower**  
S=1/50

PROJECT TITLE:  
THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER  
TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD

DRAWING TITLE:  
OVERHEAD RESERVOIR (2)

SCALE:  
1/200

DRAWING NO.:  
DC#2-C-10



| Water Level | Ground Elevations | Pipe Center Level | Pipeline (Diameter) | Cumulative Distance | Chainage |
|-------------|-------------------|-------------------|---------------------|---------------------|----------|
| 185.55      | 185.66            | 185.66            | 3.0 x 1.0           | 0                   | 000+0    |
| 185.55      | 185.66            | 185.66            | 3.0 x 1.0           | 12                  | +12      |
| 185.55      | 185.66            | 185.66            | 3.0 x 1.0           | 25                  | +25      |
| 185.55      | 185.66            | 185.66            | 3.0 x 1.0           | 50                  | +50      |
| 185.55      | 185.66            | 185.66            | 3.0 x 1.0           | 73                  | +73      |
| 185.55      | 185.66            | 185.66            | 3.0 x 1.0           | 75                  | +75      |
| 185.55      | 185.66            | 185.66            | 3.0 x 1.0           | 100                 | +100     |
| 185.55      | 185.66            | 185.66            | 3.0 x 1.0           | 119                 | +119     |
| 185.55      | 185.66            | 185.66            | 3.0 x 1.0           | 125                 | +125     |
| 185.55      | 185.66            | 185.66            | 3.0 x 1.0           | 150                 | +150     |
| 185.55      | 185.66            | 185.66            | 3.0 x 1.0           | 175                 | +175     |
| 185.55      | 185.66            | 185.66            | 3.0 x 1.0           | 185                 | +185     |
| 185.55      | 185.66            | 185.66            | 3.0 x 1.0           | 200                 | +200     |
| 185.55      | 185.66            | 185.66            | 3.0 x 1.0           | 225                 | +225     |
| 185.55      | 185.66            | 185.66            | 3.0 x 1.0           | 250                 | +250     |
| 185.55      | 185.66            | 185.66            | 3.0 x 1.0           | 275                 | +275     |
| 185.55      | 185.66            | 185.66            | 3.0 x 1.0           | 300                 | +300     |
| 185.55      | 185.66            | 185.66            | 3.0 x 1.0           | 325                 | +325     |
| 185.55      | 185.66            | 185.66            | 3.0 x 1.0           | 350                 | +350     |
| 185.55      | 185.66            | 185.66            | 3.0 x 1.0           | 360                 | +360     |

DRAWING TITLE: PLAN AND PROFILE OF TRANSMISSION MAIN (1)  
 PROJECT TITLE: THE PREPARATORY SURVEY FOR THE PROJECT FOR IMPROVEMENT OF WATER TREATMENT PLANT AND WATER DISTRIBUTION SYSTEM IN FAISALABAD  
 DRAWING NO: TM-001  
 SCALE: 1/1000, 1/400  
 TM-01