




**NIPPON KOEI**



# The battery system for mitigate the VRE output fluctuation


(Demonstration test with island as field of power system)

July 1, 2020

Chubu Electric Power Co., Inc.  
Nippon Koei Co., Ltd.

# 2030 year energy plan in Japan

In Japan, we are aiming to realize an “energy mix” toward the SDGs achievement in 2030.



In order to stably use the electric power obtained from wind power generation, etc., it is necessary to establish the operation technology of the electric power system.

**For that purpose, establishment of energy storage technology is important.**


# Object of verification test

(Demonstration of island power system in the field)

In Japan, demonstration test on a remote island simulating the energy mix of 2030

Output prediction and output control/suppression of wind power and solar power generation, coordinated operation control with existing power sources and energy storage such as storage batteries.

➔ Construction of a grid system capable of maximally accepting renewable energy by utilizing energy storage.




Source : NEDO Report

# Outline of verification test

Demand scale : 1,900~4,400kW  
 Diesel Generator : 7,700kW  
 Total of Renewable energy : 1.060kW  
 (WT: 600kW, PV460kW)  
 Storage battery : 1,000kWh

※Nii island and Shikine island  
 are connected by submarine cable



Source : NEDO Report

# Overview of demonstration equipment

- ① Wind power generation equipment  
(WT : 300kW×2units, Battery: 500kWh,  
PCS:500kW)
- ② Solar power generation equipment  
(PV : 318kW, PCS: 315kW)
- ③ Storage battery equipment  
( Battery: 500kWh×2  
PCS: 1,000kW×2units)
- ④ Small PV equipment +  
Storage battery equipment  
(PV:5kV~12kV, Battery: 12kWh, PCS:10kW)

PCS: Power Conditioner System



③ Storage battery equipment




④ Small PV equipment +  
Storage battery equipment

Source : NEDO Repot

# Object of battery control

We will verify the optimized control of the entire power system by effectively controlling the combination of renewable energy and storage battery equipment.

	Object	Contents of control	Device
Countermeasure of surplus power  <b>Comparison of pumped storage and storage battery</b>	Renewable energy output control Energy storage direct control	Renewable energy suppression control <b>Surplus power charging by energy storage</b>	Renewable energy generation + Storage battery equipment
	Demand shift when suppressing renewable energy	Renewable energy suppression control <b>Storage battery charge power control</b>	Renewable energy generation + Storage battery equipment
Mitigation of frequency fluctuations	Mitigating output fluctuations on the renewable energy side	<b>Storage battery charge power control</b>	WT/PV+ Storage battery equipment
	Frequency fluctuation suppression control to mitigate fluctuations in renewable energy and demand	Power consumption control	HP
Power generation plan	Imbalance compensation with power generation plan	<b>Storage battery charge power control</b>	WT/PV+ Storage battery equipment

HP: Heat Pump

Source : NEDO Report


# Control of short cycle/long cycle fluctuation

- Short cycle fluctuation control

For rapid fluctuations in renewable energy such as PV and WT, the frequency adjustment mode of the storage battery itself is used.

- Long cycle fluctuation control

For slow fluctuations in load, pumped storage power generation, storage batteries, etc. will be used to take measures against fluctuations.




EMS: Energy Management System

Source : NEDO Repot

# Storage system fluctuation suppression test results


## ① Frequency fluctuation suppression

- It will be charged when the system frequency exceeds the upper limit of 50.1Hz.
- It will be discharged when the system frequency falls below the lower limit of 49.9Hz.




## ② Peak cut

- It will be discharged when the system power demand exceeds the upper limit of 2500kW.
- It will be charged when the system power demand falls below the lower limit of 2450 kW.



Source : NEDO Report





# Studies on Stabilizing a Power System with Massive PV Penetration using VSG (VSG: Virtual Synchronous Generator)

November 4, 2020

Chubu Electric Power Co., Inc.  
Nippon Koei Co., Ltd.

01 | Introduction

02 | Details of Developed Prototype VSG


03 | Stability Studies using the Prototype VSG Model

04 | Conclusion

# 1.1 Introduction

Massive PV Penetration

Many conventional generating units are disconnected




- Voltage Problem
- Frequency Problem
- Stability Problem



A conventional generator's rotor

The rotational mass of conventional generators has an ability to absorb and supply energy due to its inertia.  
A PV doesn't have it.

## 1.2 Generator stability



When many conventional generating units are disconnected and replaced by PV, synchronizing and/or damping power tend to decrease as the PV doesn't have inertia.

The **synchronizing power** is the power to restore a rotor to the rated rotation speed and the **damping power** is the power to damp the rotor's swing as a damper.

# 1. 3 Synchronizing Power and Damping Power

To maintain stability,


- **Synchronizing Power ( $K_s$ )**  $[\Delta P / \Delta \delta]$

The power to restore original and stable position of synchronous generator against acceleration and de-acceleration in case of disturbance.

- **Damping Power ( $K_d$ )**  $[\Delta P / \Delta \omega]$


The power to damp generator oscillations in case of disturbance

① In case no synchronizing power and damping power . . .




# 1. 4 Synchronizing Power and Damping Power

## ② In case of Synchronizing Power only




## ③ In case of Damping power



# 1.5 Virtual Synchronous Generator (VSG)

④ Conventional Generators have both **Synchronizing Power (SP)** & **Damping Power (DP)**



Energy Storage & Release due to Inertia



Conventional Generator  
(Rotary synchronous generator)

## ■ Virtual Synchronous Generator (VSG)

A device that behaves in the same way as a rotary synchronous generator in response to system disturbances such as failures. This device consists of a power supply (storage battery) and an inverter, and by appropriately controlling these, it has synchronization power and damping power.



VSG prototype model is developed/ studied using regenerative type DC supply in lieu of a storage battery as a viable solution to stabilize power system

## 1. 6 Virtual Synchronous Generator (VSG)

---

In this study:




- ① The impact of different PV penetration levels on the dynamic and transient stability was evaluated.
- ② As a countermeasure, the prototype Virtual Synchronous Generator was developed and its effectiveness was checked experimentally using an analog simulator.

Where, Virtual Synchronous Generator (VSG)

- It consists of an inverter combined with some power sources (PV connected with battery, Battery only etc.).
- It behaves as a rotating type synchronous generator when a system disturbance occurs.




## 2.1 Basics of VSG



In this circuit, the power flows from DC supply to an analog simulator via an inverter unit. By using the regenerative supply, power can be absorbed and supplied.


## 2.2 Schematic Diagram of Prototype VSG



In this circuit, the power flows from DC supply to an analog simulator via an inverter unit. By using the regenerative supply, power can be absorbed and supplied.


MCCB: Molded Case Circuit Breaker

## 2.3 Details of VSG Model




$\ast$ These equations are modeled on RTDS™.

## 2.3 Control scheme of the VSG model



## 2.4 Specification of Prototype VSG



The main Specification of the Prototype VSG.


Category	Value
Rated frequency(AC)	60Hz
Rated capacity(AC)	10kVA
Rated output(AC)	10kW
Transformer Primary voltage(AC)	275V <sub>rms</sub>
PWM Carrier frequency	10kHz

Before a prototype was manufactured, the specifications were determined using a digital model.

# 3.1 Experimental System



275V System  
(275kV System)



※V : 1/1,000, I : 1/100, Z : 1/10, Output : 1/100,000

# 3.2 Experimental Conditions




TABLE. THE OUTPUT AT EACH PV PENETRATION LEVEL.

PV Penetration Level [%]	1G [kW]	2G [kW]	3G [kW]	4G [kW]	PV1 [kW]	VSG or PV2 [kW]
0.0%	3.0	4.0	4.0	2.0	-	-
15.4%	3.0	4.0	4.0	-	-	2.0
38.5%	-	4.0	4.0	-	-	5.0
69.2%	-	4.0	-	-	4.0	5.0

- We checked
  - The impact of the massive PV penetration
  - The effectiveness of the VSG
- We performed
  - Dynamic Stability Experiment
  - Transient Stability Experiment

## 3.3 Evaluation Method of Dynamic Stability Results


The dynamic stability is assessed using the criterion that synchronizing power coefficients  $K_S > 0$  and damping power coefficients  $K_D > 0$ . The  $K_S$ ,  $K_D$  are computed as follows. ※

$$K_S = \frac{dP}{d\delta} = \frac{M(\sigma^2 + \omega^2)}{\omega_0} \quad \begin{array}{l} M[s]: \text{inertia constant} \\ \omega_0[\text{rad/s}]: \text{rated angular frequency} \end{array}$$

$$K_D = \frac{dP}{d\omega} = -2M\sigma \quad (\sigma < 0)$$

※P.KUNDUR, Power System Stability and Control, 1994

Where, the eigenvalue ( $\sigma$  and  $\omega$ ) of a analysis result is estimated by the Prony analysis.





Eigen value

$$y(t) = Ae^{(\sigma + j\omega)t}$$

$y(t)$ : signal of interest,  $A$ : amplitude,  $t$ : time,  $\sigma$ : damping  
 $\omega$ : angular frequency of an oscillation mode.



## 3.4 Dynamic Stability Results



① With the increase of PV penetration level, the  $K_S$  and  $K_D$  decrease due to reduced number of the connecting synchronous generators.

②  $K_S$  and  $K_D$  are increased by using the VSG which has the ability to improve the dynamic stability.

# 3.5 Transient Stability Results


PV Penetration Level [%]	VSG Or PV2 with FRT on	Fault Duration				
		4cycle	6cycle	8cycle	10cycle	12cycle
0.0	-	○	○	○	○	×
15.4	PV2	○	○	○	○	×
	VSG	○	○	○	○	○
38.5	PV2	○	○	△	×	×
	VSG	○	○	○	○	○
69.2	PV2	×	×	×	×	×
	VSG	○	○	○	○	○

**Unstable**

○:Stable    △ : Oscillatory    × : Unstable (Out-of-step)

- ① With the increase of the PV penetration level, the generators tend to become unstable even when a fault duration is short.
- ② All the cases with VSG become stable.

# 3.6 Evaluation Method of Transient Stability Results





With the voltage phase difference  $\delta$  between Bus 1 and Infinite Bus, a transient stability is judged as follows.

Stable :  $|\delta| \leq 90 \text{ deg}$

Unstable :  $|\delta| > 90 \text{ deg}$

Where, measured time duration is 18 [sec]



## 4. Conclusion


---

- The impact of different PV penetration levels on the dynamic and transient stability was assessed by performing experiments using an analog simulator and PV models.
- The prototype VSG was developed and its effectiveness was checked experimentally to improve the dynamic and transient stability.
- In future studies, it is important to optimize the VSG capacity and its placement with respect to a realistic power system with massive PV penetration.*
- The field testing is also important to get more insight about practicality in the real world system.*



CHUBU  
Electric Power



**NIPPON KOEI**





# 2019fy PSPP Utilization and its purposes in Chubu Area

# 2019fy Data

	PSPP Total Capacity in Chubu	PSPP Total Generated Energy	PSPP Total Pumped Energy
① All PSPPs	3,880MW	1090GWh	810GWh (Energy for Generation $810 \times 70\% = 567\text{GWh}$ )
② Without run of river PSPPs that have inflow to reservoir	2,603MW	437GWh	611GWh (Energy for Generation $611 \times 70\% = 428\text{GWh}$ )




# PSPP Utilization Purposes

	Purpose	Note
Generation	Supply Capability	kWh distribution of Reservoir (See slide No.4)
	Upward Reserve Margin	
	 Load Frequency Control	Time Range < 5 min (From Stop Mode)
	Governor Free Capability	<ul style="list-style-type: none"> <li>• Time Range &lt; 10 sec (During Running)</li> <li>• Chubu Criterion = 3% × Area Demand (See slide No.5)</li> </ul>
Pump up	Downward Reserve Margin	
	 VRE Curtailment Reduction Keep Frequency in N-1 Contingency by Shedding PSPP	Time Range > 15 min(From Stop Mode)  <ul style="list-style-type: none"> <li>• Time Range ≐ instant (During Running)</li> <li>• Chubu Criterion = Keeping 59.5Hz in N-1 Contingency</li> </ul>
Pump up ↓ Generation	Economical Operation	Marginal Cost for Pumping up Divided by 70% vs Substituted Marginal Cost by PSPP Generation after Pumping up
Other	Voltage Control	Operation of Voltage Control Mode
	Black Start	—

## What is “kWh distribution of Reservoir and PSP Hydro”


- There is a kWh constraint of Reservoir and PSP Hydro, therefore they do not keep their nominal capacity all time.
- It is a common measure to evaluate their supply capability as distributing their kWh based on reservoir water level to each time to equalize reserve ratio against predicted demand in Japan.






## Generation in a day of 1st week. May 2020

- We utilize PSPP pump-up function to maximize the VRE generation in day time.
- Simultaneously another PPSP unit is started up for generation to keep enough Frequency Containment Reserve(Governor Free) and keep to run at minimum output.






# Outline of Storage battery

May 20, 2020

Chubu Electric Power Co., Inc.  
Nippon Koei Co., Ltd.

# Supply-demand Control

- If Renewable Energy output increases greatly when demand is low, **supply demand balance cannot be maintained** even if output of existing supply capabilities (thermal power) is controlled to the limit (power generation >> demand)



- Measures**
- Utilize **storage energy**
  - Utilize inter-regional transmission lines, control Renewable Energy output
  - Restriction of interconnected Renewable Energy

# Storage Energy


- Countermeasure to absorb fluctuation of Renewable Energy output
- Technology for stabilizing power flow

Technology of Storage Energy	Shape of storage	Method	Characteristic
Storage battery	Chemical energy	Lead, Ni, NaS Li, Redox	Charge and discharge repeatedly
(CAES : Compressed Air Energy Storage	Pressure energy	compress air at night, Use it daytime to generate power	Efficiency is high, because combustion energy is not necessary.
Hydrogen storage	Chemical energy	Use for fuel battery	Fuel battery vehicle
Pumped storage	Hydro energy	Pumping water with surplus electricity, Discharge when needed	Low running cost And Long-term usage

source: NEDO(new energy and industrial technology development organization) renewable energy technology white book ver.2

# Use of Storage batteries

蓄エネルギーシステムの導入先




Various storage energy depending on purpose and magnitude

source: NEDO(new energy and industrial technology development organization) renewable energy technology white book ver.2


# Absorbing fluctuation output (short term: frequency control)

## Output fluctuations of PV




PV generation output changes with time of day and weather

## Output fluctuations of wind power








Wind power generation output changes with wind forces

Storage Battery




Storage Battery absorbs fluctuation of Renewable Energy output, and keep frequency stable

# Storage battery type

Battery name	Energy density / Output density	Charge and discharge efficiency	Cycle longevity	Characteristics	Price
Lead storage 	○ / ○	○	○	Average charge is necessary	◎
NaS 	◎ / △	◎	○	Heater loss	◎
Ni hydrogen 	◎ / ○	○	◎	Average charge is necessary	○
Li 	◎ / △	◎	○	None	△
Vanadium redox flow 	○ / △	○	○	Pump loss	○

# Lead storage Battery





<b>Large capacity achievement</b>	<b>1MWh</b>
Charge and discharge speed	1C (1 hour from full charge to empty by rated current)
Efficiency of charge and discharge	75~87%
Longevity	4500cycle(15 years)
Energy density	Volume energy density: approx. 40~80Wh/L Weight energy density(theory):167Wh/kg Weight energy density(actual):35Wh/kg
Price	500\$/kWh, 2000\$/kW,
Technical level	practical

Recently **longevity becomes longer.**

source: NEDO(new energy and industrial technology development organization) renewable energy technology white book ver.2



# NaS Battery





Large capacity achievement	200MWh
Charge and discharge speed	0.2~0.5C
Efficiency of charge and discharge	90%
Longevity	4500cycle(15 years)
Energy density	Volume energy density: approx. 140~170Wh/L Weight energy density(theory):780Wh/kg Weight energy density(actual):110Wh/kg
Price	400\$/kWh, 2000\$/kW, 300~400\$/kWh in 2020
Technical level	practical

High energy density, **Large capacity** achievement


# NaS Battery

Assumption of Installed capacity : 500MWh(2020) 1,000MWh(2030)  
 Assumption of System price: 370USD/kWh(2020) 140USD/kWh(2030)



※Includes O&M costs and amortization costs.

# Ni hydrogen



Ni hydrogen (100kWh)



キガセル

×40直列1並列

電池スタック仕様	
定格容量	17.7 Ah
定格電圧	1.2V
エネルギー容量	2.1 kWh
外形寸法(L×W×H)	690×271×340mm
重量	約140kg

## Large capacity achievement

## Hundreds kWh

Charge and discharge speed

1~max 10C

Efficiency of charge and discharge

80~90%

Longevity

6000~8000 cycle(20 years)

Energy density

Volume energy density: approx. 40~100Wh/L  
 Weight energy density(theory):275Wh/kg  
 Weight energy density(actual):60Wh/kg

Price

3000\$/kWh, 1000\$/kW, 400\$/kWh in 2020

Technical level


practical

**Longevity is long**, but temperature management is necessary, expensive.

Li



ESS(Energy Storage System)





Large capacity achievement	Hundreds~thousands kWh
Charge and discharge speed	max 3C
Efficiency of charge and discharge	94~96%
Longevity	3500 cycle(10 years)
Energy density	Volume energy density: approx. 140~210Wh/L Weight energy density(theory):360Wh/kg Weight energy density(actual):120Wh/kg
Price	2000\$/kWh, 1500\$/kW, 500\$/kWh in 2020
Technical level	practical

**High energy density**, Short term fluctuation control, microgrid


source: NEDO(new energy and industrial technology development organization) renewable energy technology white book ver.2

Assumption of Installed capacity : 52.5MWh(2020) 347.5MWh(2030)  
 Assumption of System price : 1,380USD/kWh(2020) 1,040USD/kWh(2030)



※Includes O&M costs and amortization costs.

# Vanadium redox flow



Large capacity achievement	1000 kWh
Charge and discharge speed	max 1C
Efficiency of charge and discharge	80~90%
Longevity	20 years(electrolyte is usable permanently)
Energy density	Volume energy density: none Weight energy density(theory):103Wh/kg Weight energy density(actual):6~12Wh/kg
Price	600\$/kWh, 4000\$/kW
Technical level	practical



redox: reduction and oxidation

**Instant response** is useful for instant voltage drop. Energy density is small.

source: NEDO(new energy and industrial technology development organization) renewable energy technology white book ver.2

# Vanadium redox flow


Assumption of Installed capacity : 15MWh(2020) 105MWh(2030)  
 Assumption of System price : 500USD/kWh(2020) 260USD/kWh(2030)



※Includes O&M costs and amortization costs.

source: 平成27年度新エネルギー導入促進調査 再生可能エネルギー当の関連産業に関する調査 (平成28年3月 みずほ情報総研株式会社)


# Practical examples of using storage batteries in Japan ① (Buzen Storage Battery Substation (Kyushu Electric Power Company) )



Installation area	14,000m <sup>2</sup>
Demonstration period	2015-2016
Storage battery type	Nas battery
Output capacity	Output:50,000kW Capacity:300,000kWh
Purpose	Measures against frequency fluctuations



# Practical examples of using storage batteries in Japan ② ( Nishi Sendai Substation (Touhoku Electric Power Company) )



Installation area	6,000m <sup>2</sup> (100m×60m)
Demonstration period	2013-2017
Storage battery type	Li battery
Output capacity	Output:20,000kW Capacity:20,000kWh
Purpose	Measures against frequency fluctuations


# Capital and Operation costs (NAS)

Object	Costs	Other
<p>NAS 1200kW/ 7200kWh (6hours) (Container NAS Battery : 3600kWh + PCS : 600kW × 2 parts)</p>	<p>【Capital Cost】 2,880,000USD (2.88MUSD) (2,400USD/kW, 400USD/kWh)</p>	<p>(※) If you plan to replace only the deteriorated parts, you can reduce the inspection cost.</p> <p>The cost will change depending on the installation conditions and specifications.</p> <p>The cost of power loss due to charging and discharging is not included in the operation cost.</p>
	<p>【Operating Cost】 Total cost : 81,000 USD/year</p> <ol style="list-style-type: none"> <li>1 . Contract with a call center in the event of an abnormality : 6,000 USD / year (90,000 USD / 15 years) <ul style="list-style-type: none"> <li>• Check operation data (only when an abnormality occurs)</li> <li>• Accepting inquiries in the event of an abnormality, etc.</li> </ul> </li> <li>2 . Periodic inspection of NAS battery: 35,000 USD / year (525,000 USD / 15 years) <ul style="list-style-type: none"> <li>• Inspection every two years</li> <li>• Replace all items recommended by the manufacturer (※)</li> </ul> </li> <li>3 . Regular inspection of PCS: 40,000 USD / year (600,000 USD / 15 years) <ul style="list-style-type: none"> <li>• Inspection and replacement of all parts recommended by the manufacturer (※)</li> </ul> </li> </ol>	

# Capital and Operation costs (Lithium ion)

Object	Costs	Others
Li 5MW 30MWh (6hours)	<p>【Capital Cost】                      25,000,000USD (25MUSD)                      (5,000USD/kW, 833USD/kWh)</p>	<p>The cost will change depending on the installation conditions and specifications.</p> <p>The cost of power loss due to charging and discharging is not included in the operation cost.</p>
	<p>【Operating Cost】                      750,000USD/year                      Annual operating cost is about 3% of capital cost                      (Inspection, replacement of parts, etc.)</p>	





# PSPP Capacity Consideration in Sri Lanka and Japan

# Installed PSPP Capacity as Balancing Resources

(MW)


Control Area	(A) PSPP Capacity	(B) Peak Demand 2019fy	(C) Installed PV Capacity	(D) Installed WF Capacity	A/B	A/C+D
Hokkaido	800	4,940	1,880	480	16%	34%
Tohoku	460	14,170	5,760	1,580	3%	6%
Tokyo	11,400	55,090	14,720	430	21%	75%
Chubu	3,880*	25,370	8,970	370	15%	42%
Hokuriku	0	5,030	1,030	160	0%	0%
Kansai	4,880	28,160	5,720	120	17%	84%
Chugoku	2,120	10,750	4,930	360	20%	40%
Shikoku	690	5,010	2,750	280	14%	23%
Kyushu	2,350	15,620	9,440	580	15%	23%
Okinawa	0	1,480	350	14	0%	0%

\*The capacity includes PSPPs owned by other companies

Mar 2020 data

Source : OCCTO, METI


# Graph(2029 Condition of Sri Lanka )



<2029 data>

Control Area	(A) PSPP Capacity	(B) Annual Demand	(C) Installed PV Capacity	(D) Installed WF Capacity	A/B	A/C+D
Sri Lanka (Victoria)	1,400	4,655	1,110	803	30%	73%
Sri Lanka (Maha)	600	4,655	1,110	803	13%	31%

# Graph(2039 Condition of Sri Lanka )



<2039 data>

Control Area	(A) PSPP Capacity	(B) Annual Demand	(C) Installed PV Capacity	(D) Installed WF Capacity	A/B	A/C+D
Sri Lanka (Victoria)	1,400	7,155	2,210	1,323	20%	40%
Sri Lanka (Maha)	600	7,155	2,210	1,323	8%	17%



# Suggestion (Simulations of appropriate PSPP capacity)

Is it worthy for you to conduct simulations to calculate appropriate PSPP capacity?

## <Objective function>

Total Merit = (CO<sub>2</sub> emission price[USD/MWh] + thermal marginal cost[USD/MWh])  
× thermal generation reduction\*[MWh]


\*VRE curtailment reduction × 70% (PSPP efficiency)

## <What will C/P do?>

To conduct the following simulation on several patterns of installed PSPP capacity and output simulation result as VRE curtailment reduction **by cumulative MWh until 2030**.

If you agree with this suggestion, we would like to output the simulation result **prior to the next site survey planned in October**.

### Assessing VRE Curtailment Requirement



• Annual curtailed energy will be in the range of 1 - 1.5% of annual wind generation

### <Question>

Could you tell me the premises on which your simulations are based?

1. Thermal output in VRE Curtailment  
(Stop or minimum running output)  
→ minimum running output
2. How to consider PSPP reservoirs constraint (with SDDP possible?)  
→ Yes



# Simulation Premises and Output Image1

- When the simulations with various scenario are until 2030, **they are for battery installation** considering PSPP installation will be after 2030. Therefore, installed capacity is reduced from the original one, and it includes 50MW battery CEB planned to install in 2025.
- The time of battery installation is 2025**, considering CEB's 50 MW battery installation plan?


Installed Battery Capacity [MW]	Thermal Generation Reduction [cumulative MWh until 2030]	CO <sub>2</sub> Emission Reduction Merit [USD]	Thermal Generation Reduction Merit [USD]	Total Merit [USD]
50				
50+100				
50+200				
50+300				
50+400				
50+500				

# Simulation Premises and Output Image2

- If it is possible to conduct a simulation with only base case scenario from 2031 until 2039, **it is for PSPP & battery installation.**
- The installation time is 2030 considering PSPP construction period?
- Installed capacity includes 50MW + 100MW battery CEB planned to install in 2025 and 2030.
- Installed capacity is up to 150MW+1400MW considering constructions of both maha3 and Victoria in 2030 are not realistic.

Installed battery & PSPP Capacity [MW]	Thermal Generation Reduction [cumulative MWh until 2039]	CO <sub>2</sub> Emission Reduction Merit [USD]	Thermal Generation Reduction Merit [USD]	Total Merit [USD]
150+200				
150+400				
150+600				
150+800				
150+1000				
150+1200				
150+1400				


# Cost Benefit Evaluation of Reinforcement of Hokkaido-Honshu HVDC link



燃種 (燃料費, CO2コスト単価(円/kWh))
石油 (23.9, 3.9)
LNG (11.0~15.5, 2.0~2.8)
石炭※ (5.9, 4.5)
太陽光, 風力 (0, 0)

Fuel type (Marginal cost, CO2 emission price) [USD / MWh] @ JPY/USD = 106
Oil (225, 37)
LNG (104 - 146, 19 - 26)
Coal (56, 42)
VRE (0, 0)

Source : OCCTO




# Examination of storage battery introduction amount

December 16, 2021

Chubu Electric Power Co., Inc.  
Nippon Koei Co., Ltd.



# Examination of storage battery introduction amount



Calculate surplus power and consider the amount of storage batteries to be introduced.


Theme: It is necessary to introduce a battery with an appropriate capacity in consideration of economic efficiency and future potential.

- A large-capacity storage battery is required to determine the amount of storage battery to be introduced in consideration of Sunday, which is an excessive evaluation.
- It is necessary to determine the amount of storage batteries to be installed in consideration of the development of PSPP in the future..



# How to proceed with the examination of the amount of storage batteries introduced

Calculate the amount of storage battery installed from the surplus power.



## In case of proceeding with Proposal ①

Based on the Curtailment Requirement calculated by CEB, consider the amount of storage batteries introduced in consideration of PSPP.

### Merit

Compared to proposal②, the amount of work is small and evaluation doesn't take time.

### Demerit

It cannot be evaluated from various aspects such as suppression of thermal power generation because it is not judged by the power source composition,

## In case of proceeding with Proposal ②

Consider the amount of storage batteries to be installed by comprehensively judging the power source composition and power demand.

### Merit

Surplus power can be judged comprehensively based on the nature of each power source.


### Demerit

The amount of work is larger than that of proposal①, and it takes time and effort.


We would like to proceed with proposal①. What is your opinion from CEB?

## In case of proceeding with Proposal ①

VRE Curtailment Requirement



By the time and day of the week



Previous presentation material from CEB

- Please tell us the calculation conditions of the data provided above.
- Please tell us the forecast VRE Curtailment Requirement data for 2030 and 2040.




# Requests from JICA expert team②

## In case of proceeding with Proposal ②

We would like to receive the following information (data).

- ① Data for the maximum and minimum power demand curves for a day.
- ② Power generation configuration and the amount of power generated by each power generation in case①.
- ③ Suppressible power generation (MW) such as thermal power generation etc. according to solar / wind power generation.
- ④ The amount of solar and wind power targets introduced by 2025 and 2030. (equipment capacity: MW)

# Considering of storage battery introduction amount



With the target of achieving 70% renewable energy in 2030, calculate surplus power and consider the amount of storage batteries to be introduced.


- ① The surplus power and renewable energy introduction amount were calculated by SDDP simulations under the condition of the battery introduction amount of some patterns. (Including utilization of PSPP)
- ② Utilizing the results of SDDP simulations, we calculated the effect of reducing thermal fuel and CO<sub>2</sub>, and considered the amount of storage batteries to be introduced.

# ① SDDP simulation calculation result

## When not installing a storage battery

Total ORE Curtailments

RE Share:65%




	Total Thermal	LVPS 1	LVPS 2	LVPS 3	New CCY 1	New CCY 2	KCCP 1	KCCP 2	West Coast	Uthuru Janani	Kelanitis sa New GTs	Containerized Emergency Power Plant	Firm Thermal Power
Annual Fuel Cost (USD million)	581.03	86.72	105.20	74.82	81.27	86.18	13.39	6.66	92.33	2.07	0.45	0.88	31.06
Annual CO2 Emissions (Tons)	9150146	2369400	2874400	2044300	480260	509230	79106	39367	545590	15645	2649	7170	183029

Contents of discussion with CEB Aiming to introduce 70% of renewable energy in 2030, consider the optimum introduction amount based on the storage battery introduction cost, etc.

- SDDP simulation with a storage battery capacity of 5 patterns (500MW\*4h, 1,000MW\*4h, 1,500MW\*4h, 2,000MW\*4h, 2,500MW\*4h)
- Calculate the renewable energy ratio (%), surplus electricity, thermal fuel cost, and CO2 emissions.


# ① SDDP simulation calculation result

## ① In case of introduction of 500 MW storage battery



	Total Thermal	LVPS 1	LVPS 2	LVPS 3	New CCY 1	New CCY 2	KCCP 1	KCCP 2	West Coast	Uthuru Janani	Kelanitis sa New GTs	Containerize d Emergency Power Plant	Firm Thermal Power
Annual Fuel Cost (USD million)	546	83	106	75	77	81	15	7	90	2	0	1	9
Annual CO2 Emissions (Tons)	8,881,666	2,255,000	2,906,000	2,050,700	452,750	477,830	86,607	43,146	534,380	14,632	310	5,407	54,903

## ② In case of introduction of 1,000 MW storage battery




	Total Thermal	LVPS 1	LVPS 2	LVPS 3	New CCY 1	New CCY 2	KCCP 1	KCCP 2	West Coast	Uthuru Janani	Kelanitis sa New GTs	Containerize d Emergency Power Plant	Firm Thermal Power
Annual Fuel Cost (USD million)	522.22	77.11	106.32	74.87	80.82	74.83	13.02	5.59	86.43	1.29	0.00	0.11	1.82
Annual CO2 Emissions (Tons)	8619086	2106700	2904800	2045700	477570	442200	76933	33055	510720	9730	0	896	10782

# ① SDDP simulation calculation result

## ③ In case of introduction of 1,500 MW storage battery


RE Share:69%



	Total Thermal	LVPS 1	LVPS 2	LVPS 3	New CCY 1	New CCY 2	KCCP 1	KCCP 2	West Coast	Uthuru Janani	Kelanitis sa New GTs	Containerized Emergency Power Plant	Firm Thermal Power
Annual Fuel Cost (USD million)	507.53	72.22	106.26	75.20	67.68	70.08	10.60	7.35	93.08	1.77	0.02	0.24	3.02
Annual CO2 Emissions (Tons)	8434750	1973100	2903400	2054800	399930	414090	62661	43438	550010	13382	114	1991	17834

## ④ In case of introduction of 2,000 MW storage battery


RE Share:70%



	Total Thermal	LVPS 1	LVPS 2	LVPS 3	New CCY 1	New CCY 2	KCCP 1	KCCP 2	West Coast	Uthuru Janani	Kelanitis sa New GTs	Containerized Emergency Power Plant	Firm Thermal Power
Annual Fuel Cost (USD million)	499.63	68.98	106.50	75.19	74.37	67.49	10.91	5.51	86.66	1.22	0.00	0.02	2.77
Annual CO2 Emissions (Tons)	8322133	1884600	2909900	2054500	439480	398820	64493	32588	512070	9180	0	157	16345

# ① SDDP simulation calculation result

⑤ In case of introduction of 2,500 MW storage battery



	Total Thermal	LVPS 1	LVPS 2	LVPS 3	New CCY 1	New CCY 2	KCCP 1	KCCP 2	West Coast	Uthuru Janani	Kelanitis sa New GTs	Containerized Emergency Power Plant	Firm Thermal Power
Annual Fuel Cost (USD million)	497.33	68.97	106.05	75.11	65.20	77.11	11.12	2.20	88.09	1.26	0.00	0.10	2.13
Annual CO2 Emissions (Tons)	8297217	1884500	2897600	2052100	385290	455660	65719	12995	520500	9488	0	802	12564

Total Hydro	PSPP (Gen)	PSPP (Pump)	Battery Storage	Total ORE	Mini Hydro	Biomass	Wind	Solar	Total ORE Curtailments
212.589	0	-198	-282.06	1613.8	330	160	1123.8	0	0
212.589	65.964	-198	-144.52	1695.5	330	160	1205.5	0	0
264.04	44.229	-198	1211.4	394.86	130.56	6.0398	250.81	7.4504	1320.174
212.589	24.858	-198	-1047.7	2522.32	330	160	1216.3	816.02	0
212.589	154.17	-198	-1595.9	3310.8	330	160	1230.3	1590.5	0
310.964	184.36	-198	-2091.3	4044.8	330	160	1170.7	2384.1	0
317.789	151.25	-198	-2154.9	4226.8	330	160	1248.4	2488.4	0
317.961	197.96	-198	2159	0	0	0	0	0	4495.1
386.229	197.96	-198	-2463	4581.7	330	160	1181.4	2910.3	0
319.684	137.22	-198	1318.1	731.269	82.055	52.464	197.99	398.76	3075.79
289.269	197.96	-198	-1792.1	3897.8	330	160	1195.9	2211.9	0
291.873	193.39	-198	-1483.3	3585.4	330	160	1239.5	1855.9	0

The ORE curtailment includes battery discharge.



ORE curtailment capacity max affects the PCS installation burden of power generators.

## ② Optimal amount of storage batteries to be introduced

### 【Batteries introduction amount examination conditions and priorities】

- ① 70% introduction of renewable energy in 2030
- ② Storage battery introduction cost (storage battery, Inverter)
- ③ Reduction of fuel cost for thermal power generation
- ④ Reduction of CO2 emissions
- ⑤ PCS installation burden cost on the power generation side

Mn USD	Mn USD
Inverter price / MW	Battery price / MWh
0.3	1.04

Mn USD
CO2 price / Ton
0.000005

Mn USD
PCS price / kW
0.0003

%	Replacement cycle: 15 years					Replacement cycle: 10 years			
	MW	Hours	Mn USD	Mn USD	Tons	Mn USD	MW	Mn USD	Mn USD
RE percentage	Battery Capacity	Battery Duration	Battery Installation Cost(Yearly)	Thermal Fuel Cost	CO2 Emission	CO2 Emission Cost	RE Curtailment capacity max	PCS Installation Cost	Total Cost(Annual)
70	2500	4	743.3333333	497	8,297,217	41	4,495	135	1,417
70	2000	4	594.6666667	500	8,322,133	42	4,152	125	1,260
69	1500	4	446	508	8,434,750	42	3,545	106	1,102
68	1000	4	297.3333333	522	8,619,086	43	3,363	101	964
67	500	4	148.6666667	546	8,881,666	44	2,802	84	823

※ Battery price is assumed to be 2030 (lithium battery)  
 Storage battery: 1,040 USD / kWh Converter: 300 USD / kW Replacement cycle: 15 years

If 70% is the first priority in 2030, 2,000 MW storage battery will be introduced.

## ② Optimal amount of storage batteries to be introduced

### 【Cost-effectiveness of introducing storage batteries】


% RE percentage	Replacement cycle: 15 years						Replacement cycle: 10 years			
	MW	Hours	Mn USD	Mn USD	Tons	Mn USD	MW	Mn USD	Mn USD	
	Battery Capacity	Battery Duration	Battery Installation Cost(Yearly)	Thermal Fuel Cost	CO2 Emission	CO2 Emission Cost	RE Curtailment capacity max	PCS Installation Cost	Total Cost(Annual)	
70	2500	4	743.3333333	497	8,297,217	41	4,495	135	1,417	
70	2000	4	594.6666667	500	8,322,133	42	4,152	125	1,260	
69	1500	4	446	508	8,434,750	42	3,545	106	1,102	
68	1000	4	297.3333333	522	8,619,086	43	3,363	101	964	
67	500	4	148.6666667	546	8,881,666	44	2,802	84	823	



According to the SDDP simulation results, the renewable energy introduction rate increases by only about 1% for the introduction of 500 MW storage battery.

Consideration is needed to achieve the 70% renewable energy introduction target in 2030, such as cost effectiveness and further curbing of thermal power generation.







# 1st Technical Seminar

( Comparison of the cost merit between  
PSPP and storage battery )

15th December, 2020

Chubu Electric Power Co., Inc.  
Nippon Koei Co., Ltd.

# Purpose of power storage technology

Purpose	Explanatory diagram	Utilization contents
<p><b>Measures for frequency fluctuation</b></p>		<p><b>Imbalance between demand and supply could cause frequency fluctuation.</b>  <b>Utilizing storage technology can achieve minimization of frequency fluctuation by utilizing their high-speed response.</b></p>
<p><b>Measures for surplus electricity</b></p>		<p><b>It stores surplus electricity such as solar power generation and utilizes the stored electricity when needed.</b></p>

# Types of power storage technology

Technology of Storage Energy	Shape of storage	Method
Storage battery	Chemical energy	NAS, Li (Lithium-ion battery) Vanadium redox flow
CAES (Compressed Air Energy Storage)	Pressure energy	compress air at night, using it daytime to generate power
Hydrogen storage	Chemical energy	Use for fuel battery
PSPP (Pumped storage power plants)	Hydro energy	Pumping water with surplus electricity, discharge when needed

Comparison


We would like to propose the best method for Sri Lanka.

# Examination of Pros and cons of PSPP and Battery, Determining the Direction

There are some options as balancing power.

- Careful consideration of advantages and disadvantages for prospective options rather than PSPP is very important
- After thorough discussions with the C/P and JICA, final conclusions would be made regarding what should be the best balancing power source and reported at the 1st Technical Seminar.

Item	Merit	Demerit
PSPP	<ul style="list-style-type: none"> <li>➤ Large scale development</li> <li>➤ Low running cost</li> <li>➤ Long-term usage</li> </ul>	<ul style="list-style-type: none"> <li>➤ <b>Long development term</b> (5 years for construction, 5 years and over for land negotiation)</li> <li>➤ Require the resettlement</li> <li>➤ <b>Staged development is impossible.</b></li> <li>➤ <b>Initial investment is large and financing (loan) is difficult.</b></li> <li>➤ Development sites is limited</li> <li>➤ Operation is restricted by river law</li> <li>➤ Loss is bigger than storage battery: about 30%</li> </ul>
Battery	<ul style="list-style-type: none"> <li>➤ Short development term Total within 2 years( 6 months for design, 1 year for construction)</li> <li>➤ <b>Staged develop is possible</b></li> <li>➤ Low loss (5-15%)</li> <li>➤ <b>Significant price decline</b> (Expected to fall by 40% in the next 5 years) (Figure 3-4)</li> <li>➤ Charge and discharge can be switched without stopping</li> </ul>	<ul style="list-style-type: none"> <li>➤ Unit price of storage batteries is still high, but the rate of decline is large.</li> <li>➤ The standard life of the storage battery is about 10 years.</li> </ul>



- ✓ Battery innovation is remarkable, price drop is remarkable as well
- ✓ Reversal of construction costs would be real within 10 years

# Comparison of PSPP and Storage battery①

		PSPP (Assuming Maha3 (※1) )		Storage Battery (NAS)		
				Current	Around 2030 year	
①	Condition	Output:600MW Generation / Discharge Time: 6hours Storage capacity: 3,600MWh				
	Construction (MUSD)	720		1,080	378	
	Construction Cost (US cents/kWh)	20		32	11	
	Construction Cost/Replacement cycle (US cents/kWh/year) PSPP : 40year Storage Battery : 20year	0.5	○	1.6	△	0.6
②	Condition	Days of operation: 250day Times of operation: 1,500h/year				
	(A)Power generation cost for equipment (US cents/kWh) (Annual expense ratio: **%)	4.8 (6%)		12.0 (10%)		4.0 (10%)
	(B)Power generation cost for PSPP operation or Storage battery operation (US cents/kWh)	10.0		10.0		
	(C)Power generation efficiency (loss) (US cents/kWh)	3.0 (PSPP efficiency: 70%)		1.0 ( Storage Battery efficiency: 90%)		
	Power generation Cost (US cents/kWh): (A)+(B)+(C)	17.8	○	23.0	△	15.0

# Comparison of PSPP and storage battery②


		PSPP		NAS Battery		Li Battery		Redox flow			
③	Construction period (Year)	8~10		△		1~2		○			
④	Replacement cycle (Year)	40 (※2)		○		15	△	10~20	△	20	△
⑤	Advantages	<ul style="list-style-type: none"> <li>• Suitable for surplus electricity countermeasures.</li> <li>• Large scale development</li> <li>• Long-term usage</li> </ul>			<ul style="list-style-type: none"> <li>• Suitable for frequency fluctuation countermeasures.</li> <li>• Staged develop is possible</li> <li>• Low loss (10-30%)</li> <li>• Significant price decline</li> <li>• The construction period is short.</li> </ul>						
	Disadvantages	<ul style="list-style-type: none"> <li>• Development sites is limited.</li> <li>• Staged development is impossible.</li> <li>• Loss is bigger than storage battery: about 30%</li> </ul>			<ul style="list-style-type: none"> <li>• The replacement cycle of the storage battery (10~20 year) is shorter than PSPP.</li> </ul>						

## [Notices]

(※ 1) The comparison target of the storage battery was the PSPP of Maha3. Because Victoria Lake's investigation has many uncertainties.

(※ 2) The replacement cycle of PSPP (40year) is described from the Maha3 report.  
(Average 40year : Civil works 50year, Hydro-mechanical and electro-mechanical equipment 35year)

# Suggestion from JICA Expert Team



source: LONG TERM GENERATION EXPANSION PLAN (2020-2039) (March 2020 SriLanka)

- PSPP takes a lot of time to complete.
- Renewable energy will gradually increase.




(Recent years)  
When gradually introducing renewable energy, it is necessary to take measures against frequency fluctuations.  
**(Storage battery will be used as a measure against frequency fluctuations.)**



(10 years later)  
When a large amount introducing renewable energy, it is necessary to take measures against surplus electricity.  
**(PSPP will be used as a measure against surplus electricity.)**




**We would like to take measures against renewable energy by best mixing PSPP and storage battery.**



Thank you for attention





# Practical examples of using NAS battery in Japan (Buzen Storage Battery Substation (Kyushu Electric Power Company) )



Installation area	14,000m <sup>2</sup>
Demonstration period	2015-2016
Storage battery type	NAS battery
Output capacity	Output:50MW Capacity:300MWh
Purpose	Measures against frequency fluctuations


# NAS Battery





※Includes O&M costs and amortization costs.

source: 平成27年度新エネルギー導入促進調査 再生可能エネルギー当の関連産業に関する調査 (平成28年3月 みずほ情報総研株式会社)

# Practical examples of using Li battery in Japan ( Nishi Sendai Substation (Touhoku Electric Power Company) )



Installation area	6,000m <sup>2</sup> (100m×60m)
Demonstration period	2013-2017
Storage battery type	Li battery
Output capacity	Output:20MW Capacity:20MWh
Purpose	Measures against frequency fluctuations



※Includes O&M costs and amortization costs.

source: 平成27年度新エネルギー導入促進調査 再生可能エネルギー当の関連産業に関する調査 (平成28年3月 みずほ情報総研株式会社)

# Practical examples of using Vanadium redox flow battery in Japan ( Minamihayakita Substation (Hokkaido Electric Power Company) )





Exterior view of storage battery building



Electrolyte tank

Installation area	5,000m <sup>2</sup>
Demonstration period	2013-2019
Storage battery type	Vanadium redox flow battery
Output capacity	Output:15MW Capacity:60MWh
Purpose	Measures against frequency fluctuations


# Vanadium redox flow



※Includes O&M costs and amortization costs.



**NIPPON KOEI**



Democratic Socialist Republic of Sri Lanka

The Project for Capacity Development on the Power  
Sector Master Plan Implementation Program

Capacity of Battery Storage introduction

Sep 2022


Chubu Electric Power Co., Inc.  
Nippon Koei Co., Ltd.

- SDDP Calculation results(Review of the last meeting)
- Main ideas for improvement of the RE ratio
  - The effect of improving the renewable energy ratio from a supply side
  - Calculation method of the SNSP permission level
- Optimal capacity of storage battery introduction




# SDDP simulation calculation result

## ① In case of introduction of 2,000 MW storage battery



	Total Thermal	LVPS 1	LVPS 2	LVPS 3	New CCY 1	New CCY 2	KCCP 1	KCCP 2	West Coast	Uthuru Janani	Kelanitis sa New GTs	Containerize d Emergency Power Plant	Firm Thermal Power
Annual Fuel Cost (USD million)	499.63	68.98	106.50	75.19	74.37	67.49	10.91	5.51	86.66	1.22	0.00	0.02	2.77
Annual CO2 Emissions (Tons)	8322133	1884600	2909900	2054500	439480	398820	64493	32588	512070	9180	0	157	16345

## ② In case of introduction of 1,000 MW storage battery



	Total Thermal	LVPS 1	LVPS 2	LVPS 3	New CCY 1	New CCY 2	KCCP 1	KCCP 2	West Coast	Uthuru Janani	Kelanitis sa New GTs	Containerize d Emergency Power Plant	Firm Thermal Power
Annual Fuel Cost (USD million)	522.22	77.11	106.32	74.87	80.82	74.83	13.02	5.59	86.43	1.29	0.00	0.11	1.82
Annual CO2 Emissions (Tons)	8619086	2106700	2904800	2045700	477570	442200	76933	33055	510720	9730	0	896	10782

## ■ Supply side

- Thermal power
  - **Lower to the minimum output**
  - Daily start and stop during daytime
- PSPP, Battery
  - Charge during surplus power(SMP: cheap), discharge during peak time(SMP: expensive)
  - SOC
- VRE
  - Reduce curtailment

## ■ Demand side


- Demand side management
  - Electricity tariff (Time of Use)
  - Market incentive
- Create new demand such as hydrogen

## ■ Transmission side


- Interconnect with India

SMP: system marginal price

# Supply demand curve sorted by curtailment amount




**Largest**




Curtailment should be more smooth


PSPP(Pump up) and (generation) should not exist simultaneously




**2nd Largest**



LVPS thermal output should be decreased to 180MW when curtailment occurs



**3rd Largest**



Total ORE Curtailments




# Outline of SNSP(the System Non-Synchronous Penetration)

$$\text{SNSP}(\%) = \frac{\text{Non-Synchronous Power Output} + \text{Import(Direct current cooperation line)}}{\text{Demand} + \text{Export(Direct current cooperation line)}}$$

In Sri Lanka, SNSP level must be controlled by 65% or less.  
 In Ireland, SNSP level has already reached 75%.

Transition of SNSP (in Ireland)



At first , if SNSP exceeded 50%, it was expected that the simultaneous dropout of the renewable-energy power occurred.

They raised SNSP in these 5 years from 50% to 75% by carrying out measures for the renewable-energy introduction.  
 In addition, they plan to raise SNSP to 95% in 2030

(注) SNSP : The System Non-Synchronous Penetration

(出所) Shaping our electricity future Technical report (AirGrid、SONI 2021/2) に加筆

# Main countermeasures of grid

RE introduction rate

High



Low  
94

Issues	Countermeasures	Status
Decrease of short circuit capacity	<ul style="list-style-type: none"> <li>Review of the protection cooperation</li> </ul>	No introduction (For Off grid)
Inertial force dropout in the grid	<ul style="list-style-type: none"> <li>Establishment of the estimation technique of inertial power quantity in real time</li> <li>Development of PCS with the frequency maintenance function</li> </ul>	Under introduction examination in Ireland, UK, Texas etc..)
Fluctuation of short frequency	<ul style="list-style-type: none"> <li>Battery storage</li> <li>Governor free operation</li> <li>Load Frequency Control etc..</li> </ul>	Ancillary service market has been formed in some countries. (including Japan)
Fluctuation of long frequency	<ul style="list-style-type: none"> <li>Output control of PV</li> <li>Forecast of RE output</li> </ul>	
Lack of transmission capacity	<ul style="list-style-type: none"> <li>Connect &amp; Manage</li> <li>Conductor temperature management by dynamic rating</li> </ul>	
Voltage flicker	<ul style="list-style-type: none"> <li>Prevention of independent driving function</li> </ul>	
The voltage movement of the distribution line	<ul style="list-style-type: none"> <li>Development of the smart inverter</li> </ul>	No introduction

This project's target


# Main improvement measures of SNSP( in case of Ireland)

Subject	Concrete contents
Decrease of synchronous power output	The 2018 third-quarter : 23,000MWs The 2019 fourth-quarter : 20,000MWs The 2020 first-quarter : 17,500MWs
Reconsideration of RoCoF(Rate of Change of Frequency)	The 2018 third-quarter : 0.5HZ/s The 2019 fourth-quarter : 1.0HZ/s
Adoption of various kind of the ancillary service	In addition to 11 existing services, they introduce 3 following services The 2018 third-quarter : FFR (Fast Frequency Response) The 2019 third-quarter : DRR (Dynamic Reactive Response) and FPFAPR (Fast Post-Fault Active Power Recovery)
Modification of Grid Code	Consideration of modification of the following Grid Code About wind power, Voltage control at steady state and dynamic control of the active power and reactive power

These are similar with our activities in this project.  
we can raise an future SNSP permission level.

# Calculation method of the SNSP permission level

## 【Simulation image of SNSP】



## 【Requirements for analysis】


- Quantity of synchronization power supply dropout  
(Main thermal power plant output, ○○% of demand ...etc.)
- RoCoF (Defined by Grid Code, It can be improved by introduction of PCS )
- Frequency recovery limit (47.0-52.0Hz)



# Optimal capacity of storage battery introduction

## 【Cost-effectiveness of introducing storage batteries】

Terms	%	MW	Mn USD
	RE Ratio	Battery Capacity	Total Cost (Annual)
Base Case	69.8%	2500	1417
	68.1%	1000	964
	66.7%	500	823
Thermal Curtail	70.0%	2500	1410
	69.3%	1000	949
	68.7%	500	802



In case of 1000MW storage battery , by curtailing thermal output, the RE ratio improve from 68.1% to 69.3%, and we can reduce annual cost 15 Million USD.

We could considerably get rid of the differences of RE ratio between 1000MW and 2000MW, so we would like to conduct future consideration based on 1000MW introduction.



Democratic Socialist Republic of Sri Lanka

The Project for Capacity Development on the Power  
Sector Master Plan Implementation Program

Cost Evaluation

Nov 2022

Chubu Electric Power Co., Inc.  
Nippon Koei Co., Ltd.

# Battery Cost


NaS : 15,000¥/kWh × 4 = 400USD/kW

NaS battery is mainly made by Japanese manufacturers(NGK), so I referred to Japanese materials.

Li : 200USD/kWh × 4 = 800USD/kW

Li battery is mainly made by international companies, so I referred to NREL(National Renewable Energy Laboratory)

## 【 NaS 】



【出典：富士経済、エネルギー・大型二次電池・材料の将来展望2015 動力・電力貯蔵・家電分野編 P.127】

## 【 Li 】





Figure ES-2. Battery cost projections for 4-hour lithium ion systems.

【出典：National Renewable Energy Laboratory 「Cost Projections for Utility-Scale Battery Storage: 2021 Update」】

# Optimal capacity of storage battery introduction

1. Present continuous operation range is 49.5 – 50.5Hz in CEB Grid Code.
2. Assuming that system coefficient K is equal to 5%(Hz/MW) approximately, it would be frequently to violate 49.5Hz in 2030 under 70% RE situation.  
 Offpeak :  $2,000\text{MW} \times 5\% (\text{Hz/MW}) \times (0.5\text{Hz}/1\text{Hz}) = \underline{50\text{MW}}$  fluctuation leads to frequency violation (50MW out of  $\sim 1,000\text{MW}$  wind output)  
 Peak :  $3,500\text{MW} \times 5\% (\text{Hz/MW}) \times (0.5\text{Hz}/1\text{Hz}) = \underline{87.5\text{MW}}$  fluctuation leads to frequency violation (87.5MW out of  $\sim 1,000\text{MW}$  wind output &  $\sim 2,000\text{MW}$  solar output)


Breakdown (Li:90%,Nas:10%)



## Li battery capacity

**200MW** (50% SOC)

Capacity (MW)	Annualized Battery Cost (USD million)	Total Cost Saving (USD million)
0	0	0
500	62	69
1,000	124	117
1,500	186	143
2,000	247	153




# 1st Technical Seminar ( Issues of PSPP )


15th December, 2020

Chubu Electric Power Co., Inc.  
Nippon Koei Co., Ltd.


# Maha3 and Victoria Lake PSPP: Locations



# Maha3 PSPP: General Layout Image



# Victoria Lake PSPP: General Layout Image






# Key Features of Reservoirs

	Maha 3 PSPP		Victoria Lake PSPP	
	Upper Reservoir	Lower Reservoir	Upper Reservoir	Lower Reservoir
HWL	EL. 815 m	EL. 292.5 m	EL. 1160 m	EL. 438 m
LWL	EL. 794.4 m	EL. 276.4 m	EL. 1125 m	EL. 407 m
Drawdown	20.5 m	16.1 m	35 m	31 m
Gross Capacity	3.71 mil. m <sup>3</sup>	6.22 mil. m <sup>3</sup>	5.5 mil. m <sup>3</sup>	10.0 mil. m <sup>3</sup>
Available Capacity	3.15 mil. m <sup>3</sup>	3.20 mil. m <sup>3</sup>	5.1 mil. m <sup>3</sup>	5.1 mil. m <sup>3</sup>
Reservoir Area	0.22 km <sup>2</sup>	0.24 km <sup>2</sup>	0.17 km <sup>2</sup>	0.3 km <sup>2</sup>
Dam Height	59 m	74 m	40 m	42 m

# Maha3 PSPP: Longitudinal Profile of Waterway




Source: Development Planning on Optimal Power Generation for Peak Demand in Sri Lanka, 2015, JICA

# Issues of Geology on Maha 3 Site

Structures	Check points	Major considerable issues
Upper storage dam	<ul style="list-style-type: none"> <li>Safety of dam foundation</li> <li>Water tightness</li> </ul>	<ul style="list-style-type: none"> <li>Thick talus deposits/highly weathered rocks on left bank</li> <li>Impermeable layer seems to be deep on left bank (more than 50 m in depth)</li> </ul>
Reservoir	<ul style="list-style-type: none"> <li>Landslide risks</li> <li>Water seepage risks</li> </ul>	<ul style="list-style-type: none"> <li>No information, but daily fluctuation of water level might thick weather zone on the left bank might trigger landslides especially on left bank covered with thick overburden.</li> <li>No information, but seepage risks on left bank are anticipated.</li> </ul>
Water way	<ul style="list-style-type: none"> <li>Landslide risks of portals</li> <li>Rock condition along water ways</li> </ul>	<ul style="list-style-type: none"> <li>No information</li> <li>Geological structures nearly parallel to the waterway route.</li> <li>NE-SW lineaments (possible faults) were identified.</li> </ul>
Underground powerhouse	<ul style="list-style-type: none"> <li>Rock condition</li> </ul>	<ul style="list-style-type: none"> <li>Biotite gneiss according to existing geological map.</li> <li>No critical issues according to the Report (2015)</li> </ul>
Lower storage dam and reservoir	<ul style="list-style-type: none"> <li>Same as upper storage dam and reservoir (Safety of dam foundation, Water tightness, Landslide risks and Water seepage risks)</li> </ul>	<ul style="list-style-type: none"> <li>No critical issues according to the Report (2015)</li> </ul>

# Maha3: Layout of the Structures and Geological Issues




Source: Development Planning on Optimal Power Generation for Peak Demand in Sri Lanka, 2015, JICA, JICA

8 Study Team added the geological information.


# Maha3: Land Use and Location of Houses in Upper Reservoir



Home gardens are developed around the houses with some tea plantation.



# Victoria Lake PSPP: Longitudinal Profile of Waterway




Source: Project on Electricity Sector Master Plan Study in Democratic Socialist Republic of Sri Lanka, 2018, JICA

# Issues of Geology on Victoria Lake Site

Structures	Check points	Major considerable issues
Upper storage dam	<ul style="list-style-type: none"><li>• Safety of dam foundation</li><li>• Water tightness</li></ul>	<ul style="list-style-type: none"><li>• Possibility of landslide risks</li><li>• No information</li></ul>
Reservoir	<ul style="list-style-type: none"><li>• Landslide risks</li><li>• Water seepage risks</li></ul>	<ul style="list-style-type: none"><li>• Ditto</li><li>• No information</li></ul>
Water way	<ul style="list-style-type: none"><li>• Landslide risks of portals</li><li>• Rock condition along water ways</li></ul>	<ul style="list-style-type: none"><li>• No information</li><li>• One lineament (possibly fracture zone) crossing the tunnel.</li></ul>
Underground powerhouse	<ul style="list-style-type: none"><li>• Rock condition</li></ul>	<ul style="list-style-type: none"><li>• No information</li></ul>
Lower storage dam and reservoir	<ul style="list-style-type: none"><li>• Safety of dam foundation, Water tightness, Landslide risks and Water seepage risks</li></ul>	<ul style="list-style-type: none"><li>• No information</li></ul>

# Victoria Lake PSPP: Geological Lineament and Landslide



Lineaments (white line)




Upper reservoir and Possible landslide (black line)

Source: Project on Electricity Sector Master Plan Study in Democratic

12 Socialist Republic of Sri Lanka, 2018, JICA




# Victoria Lake PSPP: Protection Area



Victoria Randenigala Rantembe Sanctuary



Source: Project on Electricity Sector Master Plan Study in Democratic Socialist Republic of Sri Lanka, 2018, JICA

# Record of Francis Type Reversible Pump Turbine



Source: Development Planning on Optimal Power Generation for Peak Demand in Sri Lanka, 2015, JICA

# Victoria Lake PSPP: Lower Dam



# Issues of Maha3 and Victoria Lake PSPPs

	Maha3 PSPP	Victoria Lake PSPP
Source of Info.	<ul style="list-style-type: none"> <li>Development Planning on Optimal Power Generation for Peak Demand in Sri Lanka, 2015, JICA</li> </ul>	<ul style="list-style-type: none"> <li>Project on Electricity Sector Master Plan Study in Democratic Socialist Republic of Sri Lanka, 2018, JICA</li> </ul>
Geology	<ul style="list-style-type: none"> <li>Site investigation: in 2015</li> <li><b>Upper dam: thick deposit on the left bank of the talus</b></li> <li>Lower dam: no critical issue</li> <li>Waterway: layers nearly parallel to the water route</li> </ul>	<ul style="list-style-type: none"> <li>Site reconnaissance: in 2018</li> <li><b>Upper dam: possibility of existence of landslide</b></li> <li>Lower dam: unclear</li> <li>Waterway: lineament</li> </ul>
Environment	<ul style="list-style-type: none"> <li>Environmental study: in 2015</li> <li>Natural: out of the protection area</li> <li><b>Social: resettlement of 28 households within the inundated area.</b></li> </ul>	<ul style="list-style-type: none"> <li>Site reconnaissance: in 2018</li> <li><b>Natural: lower dam within the protection area.</b></li> <li>Social: direct impacts on the village may not be substantial.</li> </ul>
Technical Aspect		<ul style="list-style-type: none"> <li><b>Pumping head: more than 700m</b></li> <li><b>Lower dam: construction in the Victoria Lake</b></li> </ul>

# Project Cost of PSPP

	Installed Capacity	Project Cost Base Year 2014	USD per kW	Source
Maha3 PSPP	600MW	USD 638 mil.	USD 1,060/kW	2015, JICA
Victoria Lake PSPP	700MW (1 <sup>st</sup> Stage)	USD 590 mil.	USD 840/kW	2018, JICA

- Investigation is more advanced in Maha 3 PSPP compared to Victoria Lake PSPP, especially for geological information.
- For Victoria Lake PSPP, there are critical aspects on which further examination is needed in the next stage, such as upper reservoir geology, lower dam construction in Victoria Lake and construction in forest sanctuary.
- Therefore, at this stage it is adequate to consider the Maha3 PSPP's cost as the benchmark of PSPP cost for comparison with the battery option.
- The said Maha3 PSPP's cost is escalated with annual price escalation at 2% to obtain 2020 price; thus **USD 1,200/kW** is considered as the benchmark of PSPP cost for comparison with battery.

# Victoria Lake PSPP: Geological Investigation

#	Issue	Approach
1	Basic Sequence, Tasks and Schedule	CEB to confirm.
2	Permission for investigation in Sanctuary Area	JICA's policy is still being confirmed.
3	Counterpart in CEB	CEB to formulate.
4	Existing topographic maps (Grid No. 5521, scale 1:10,000 issued by Survey Department of Srilanka)	CEB to assist JICA Expert to obtain.
5	Subcontractor	JICA Expert to determine with bidding/quotation in accordance with JICA guideline.

# Progress to Date


Geo. Investigation Item	Maha 3	Victoria Lake
Topographic survey	Done	N/A
Geological mapping	Done (dam sites)	N/A
Geophysical prospecting	N/A	N/A
Core drilling	Done (dam sites)	N/A
Laboratory test	Done (dam sites)	N/A
Exploratory adit	N/A	N/A

# Step 1: Tasks


Step	Tasks	Remarks
<b>Step 1 Capacity Building (C/B) by JICA Expert</b>		
Geological investigation on Victoria Lake PSPP	<ul style="list-style-type: none"> <li>- Geological investigation by subcontractor                             <ul style="list-style-type: none"> <li>◆ Topographic survey</li> <li>◆ Geological mapping</li> <li>◆ Core drilling with site tests (SPT and permeability test) at upper &amp; lower dam sites</li> <li>◆ Laboratory tests</li> <li>◆ Preparation of geological investigation report</li> </ul> </li> <li>- Activities by JICA Expert                             <ul style="list-style-type: none"> <li>◆ Preparation of technical specifications</li> <li>◆ Procurement of subcontractor</li> <li>◆ Supervision of subcontractor's activities</li> <li>◆ Check of subcontractor's geological investigation report</li> <li>◆ Recommendation for further geological investigation for Victoria Lake PSPP</li> </ul> </li> </ul>	<ul style="list-style-type: none"> <li>- Same items &amp; levels of geo. inv. as done for Maha3 in 2015</li> <li>- Output of the activities is;                             <ul style="list-style-type: none"> <li>◆ Geological investigation Report for Victoria Lake PSPP prepared by the subcontractor and checked by JICA Expert</li> </ul> </li> <li>- The followings are <b>Not</b> included in the Scope 1:                             <ul style="list-style-type: none"> <li>◆ Geophysical prospecting (seismic prospecting and electrical resistivity prospecting)</li> <li>◆ Core drillings for underground powerhouse and underground tunnels</li> <li>◆ Underwater core drilling for lower dam at Victoria Lake</li> <li>◆ Review of Maha3's geology</li> <li>◆ Environmental survey</li> <li>◆ Layout study</li> <li>◆ Comparison &amp; prioritization among Maha3 and Victoria</li> </ul> </li> <li>- Activities at Lower Dam and Lower Reservoir area are subject to permission by CEB &amp; JICA, as they are within the protected area. If not permitted, investigations at these area shall be omitted from the scope of Step 1.</li> </ul>




# Basic Sequence



# Schedule



# Victoria Lake PSPP: General Layout Image



# Victoria Lake PSPP: Protection Area




Victoria Randenigala Rantembe Sanctuary

Source: Project on Electricity Sector Master Plan Study in Democratic Socialist Republic of Sri Lanka, 2018, JICA



**NIPPON KOEI**



Democratic Socialist Republic of Sri Lanka

The Project for Capacity Development on the Power  
Sector Master Plan Implementation Program


## 2<sup>nd</sup> Technical Seminar

Evaluation on Geological Investigation Result at Victoria PSPP site


December 22nd, 2021

Chubu Electric Power Co., Inc.  
Nippon Koei Co., Ltd.

# Basic Sequence of Overall Schedule




# Victoria Lake PSPP: Longitudinal Profile of Waterway



Source: Project on Electricity Sector Master Plan Study in Democratic Socialist Republic of Sri Lanka, 2018, JICA

# Geological Investigation: Plan of Mapping


Review and updating  
of existing geological map (20km<sup>2</sup>)



Detailed geological mapping  
on 1:1000 topo map (2.5km<sup>2</sup>)  
⇒ overlapping with 20km<sup>2</sup>-mapping




# Geological Mapping




Note: Geology between lower part of the penstock and outlet of the waterway including underground powerhouse site is not only Charnokitic gneiss but possibly composed of various type of gneisses due to its mineral compositions. The Charnokitic gneiss associated with powerhouse shows more acidic features. Geology and rock condition especially for underground powerhouse site need to be confirmed by core drilling survey in next stage.

# Geological Investigation: Plan of Core Boring



# Geological Sections A-A

GEOLOGICAL PROFILE ALONG THE PROPOSED UPPER DAM AXIS (A-A)



**LEGEND**


- BOUNDARY BETWEEN ROCK TYPES
- GROUNDWATER TABLE
- ROCK LAYER IDENTIFICATION SYMBOL
- Qtz - QUARTZITE
- ChGs - CHARNOKITIC GNEISS
- RS - RESIDUAL SOIL
- CWR - COMPLETELY WEATHERED ROCK

- Qtz - QUARTZITE
- ChGs - CHARNOKITIC GNEISS
- RS - RESIDUAL SOIL
- CWR - COMPLETELY WEATHERED ROCK

## Geological Section

PROJECT NAME		CENTRAL ENGINEERING CONSULTANCY BUREAU	
CLIENT		CHUBU ELECTRIC POWER CO., LTD.	
DESIGNER		CENTRAL ENGINEERING CONSULTANCY BUREAU	
DRAWN		T. YAMAMOTO	
CHECKED		S. YAMAMOTO	
DATE		2021.09.02	
SCALE		1:1000	
PROJECT NO.		C1793 / 600 / 2021 / 029 / 02	

ROCK CLASSIFICATION PROFILE ALONG THE PROPOSED UPPER DAM AXIS (A-A)



**LEGEND**



- BOUNDARY BETWEEN ROCK TYPES
- GROUNDWATER TABLE
- WEATHERING GRADE OF ROCKS
- FR - FRESH ROCK - CLASS I
- SWR - SLIGHTLY WEATHERED ROCK - CLASS II
- MWR - MODERATELY WEATHERED ROCK - CLASS III
- HWR - HIGHLY WEATHERED ROCK - CLASS IV
- CWR - COMPLETELY WEATHERED ROCK - CLASS V
- RS - RESIDUAL SOIL - CLASS VI
- MMF - MAN MADE FILL

- WEATHERING GRADE OF ROCKS**
- FR - FRESH ROCK - CLASS I
  - SWR - SLIGHTLY WEATHERED ROCK - CLASS II
  - MWR - MODERATELY WEATHERED ROCK - CLASS III
  - HWR - HIGHLY WEATHERED ROCK - CLASS IV
  - CWR - COMPLETELY WEATHERED ROCK - CLASS V
  - RS - RESIDUAL SOIL - CLASS VI
  - MMF - MAN MADE FILL

## Rock Classification



PROJECT NAME		CENTRAL ENGINEERING CONSULTANCY BUREAU	
CLIENT		CHUBU ELECTRIC POWER CO., LTD.	
DESIGNER		CENTRAL ENGINEERING CONSULTANCY BUREAU	
DRAWN		T. YAMAMOTO	
CHECKED		S. YAMAMOTO	
DATE		2021.09.02	
SCALE		1:1000	
PROJECT NO.		C1793 / 600 / 2021 / 029 / 02	

# Geological Sections B-B




Client: CHUBU ELECTRIC POWER CO., LTD.		Project: VICTORIA LAKE PUMPED STORAGE POWER PLANT		Contract: ROCK CLASSIFICATION SECTION ALONG THE LANDSLIDE AREA (B-B')		NIPPON KOEI CO., LTD.	
Design: A.N.K.E.I.	Checked: S.M.M.	Designed: S.M.M.	Checked: S.M.M.	Designed: S.M.M.	Checked: S.M.M.	Designed: S.M.M.	Checked: S.M.M.
Scale: 1:1000	Date: 10/20/2021	Sheet: 1	Total: 1	Scale: 1:1000	Date: 10/20/2021	Sheet: 1	Total: 1

# Geological Sections C-C



	株式会社 日本電気建設 建設部 岩体調査課 〒100-8355 東京都千代田区千代田 1-1-1 TEL: 03-5561-1111 FAX: 03-5561-1112 E-MAIL: info@nipponkoei.com	株式会社 日本電気建設 建設部 岩体調査課 〒100-8355 東京都千代田区千代田 1-1-1 TEL: 03-5561-1111 FAX: 03-5561-1112 E-MAIL: info@nipponkoei.com	株式会社 日本電気建設 建設部 岩体調査課 〒100-8355 東京都千代田区千代田 1-1-1 TEL: 03-5561-1111 FAX: 03-5561-1112 E-MAIL: info@nipponkoei.com	株式会社 日本電気建設 建設部 岩体調査課 〒100-8355 東京都千代田区千代田 1-1-1 TEL: 03-5561-1111 FAX: 03-5561-1112 E-MAIL: info@nipponkoei.com	株式会社 日本電気建設 建設部 岩体調査課 〒100-8355 東京都千代田区千代田 1-1-1 TEL: 03-5561-1111 FAX: 03-5561-1112 E-MAIL: info@nipponkoei.com
--	---	---	---	---	---

# Geological Sections D-D




Geological Section

# Evaluation of Investigation Result (1/3)

For upper area of Victoria PSPP site, fatal geological risks seem not exist, based on investigation results in this stage (2021)

- Possibility of landslide risks seem low around upper dam site and penstock areas → need final confirmation in F/S 1st stage

Possible landslides pointed out by JICA (2018)




Many fresh outcrops exists inside slope, without any disturbing direction of rock foliation



Large outcrop of fresh rock inside possible landslide block



No identical phenomena of landslide around slope



Encountering hard rock at shallow depth (10.60m) in drill No.BH-05




# Evaluation of Investigation Result (2/3)

However, some considerable issues are identified for upper area of Victoria PSPP site

- Basically, water permeability seems low around upper dam site and reservoir area, but possible minor seepage should be considered at right bank → need evaluation in F/S stage



Large outcrop of quartzite, forming cave with small water spring



Upstream-downstream cross section image around drilling BH-01 (DRAFT)



# Evaluation of Investigation Result (3/3)

- Quartzite around right bank of upper dam foundation seems fragile in core sample, while seems hard in outcrop. → caused by drilling operation inside tight-joint rich zone ? → difficult to estimate geotechnical parameters → **recommending adit observation with in-situ tests, such as rock shear test and loading test in F/S stage**





Fragile core sample (BH-02: 15-20m)



Hard outcrop of quartzite around right bank of upper dam site



EXAMPLE: adit in other project



# Conclusion (1/2)


Structures	Check points	Major conceivable issues	
		Focused by JICA (2018)	Based on this investigation (2021)
Upper storage dam	<ol style="list-style-type: none"> <li>1. Safety of dam foundation</li> <li>2. Water tightness</li> </ol>	<ol style="list-style-type: none"> <li>1. Possibility of landslide risks</li> <li>2. No information</li> </ol>	<ol style="list-style-type: none"> <li>1. Possibility of landslide risks seem low.</li> <li>2. Basically tight, but possible minor seepage at right bank.</li> <li>3 Quartzite at right bank seems moderately weak, need to check strength of quartzite.</li> <li>4 Original dam axis should be slightly shifted to upstream side in consideration of creep length and stability of foundation rock.</li> </ol>
Reservoir	<ol style="list-style-type: none"> <li>1. Landslide risks</li> <li>2. Water seepage risks</li> </ol>	<ol style="list-style-type: none"> <li>1. Possibility of landslide risks</li> <li>2. No information</li> </ol>	<ol style="list-style-type: none"> <li>1. No landslide risks.</li> <li>2. Seepage risks seem low, but need check narrow ridges condition surrounding reservoir.</li> </ol>
Upper water way	<ol style="list-style-type: none"> <li>1. Landslide risks of portals</li> <li>2. Rock condition along water ways</li> </ol>	<ol style="list-style-type: none"> <li>1. No information</li> <li>2. No information</li> </ol>	<ol style="list-style-type: none"> <li>1. Possibility of landslide risks seem low.</li> <li>2. No identified risks along penstock.</li> <li>3 Quartzite around intake seems moderately weak, need to check strength of quartzite.</li> <li>4 Possibility of minor water inflow.</li> </ol>

# Conclusion (2/2)

Structures	Check points	Major conceivable issues	
		Focused by JICA (2018)	Based on this investigation (2021)
Underground Powerhouse	1. Rock condition	1. No information	1. No information, but - possibly marble layer is not so thick, based on the regional geological mapping - weak and permeable sheared zone and anisotropic biotite gneiss described in published geological map
Lower water way	1. Landslide risks of portals 2. Rock condition along water ways	1. No information 2. Two lineaments (possibly fracture zone) crossing the tunnel.	1. No information 2. Two lineaments (possibly fracture zone) crossing the tunnel.
Lower storage dam and reservoir	Safety of dam foundation, water tightness, landslide and water seepage risks	No information	No information, but following issues are described in published geological map - permeable marble - weak and permeable shared zone - anisotropic biotite gneiss


No geotechnical investigation were conducted in this stage (2021)

# Basic Sequence of Overall Schedule



# Recommendation in Next F/S 1<sup>st</sup> Stage

## Proposed layout of geological investigation for Victoria Lake site in Next F/S 1<sup>st</sup> stage



Completed drilling location (2021):

- Drilling ( B-01 to 06 )
- ▭ Topographic survey & Geological mapping

---


Proposed layout of investigation for F/S 1<sup>st</sup> stage:

- Drilling ( BF- )
- / Seismic prospecting ( S- )
- / Electrical resistivity prospecting ( E- )
- / Test Adit ( A- )
- ▭ Topographic survey & Geological mapping



CHUBU  
Electric Power

***NIPPON KOEI***



# PSPP On-site Training in WG2 (Geology & Geological Investigations)

October 28, 2020

Chubu Electric Power Co., Inc.  
Nippon Koei Co., Ltd.

# Agenda of Today's Program


Time	Contents
9:30-12:00	✓ 2nd Meeting of WG2- PSPP(Pumped Storage Power Plant) On-site Training (Remotely, On the Desk)
9:30-9:40	Address by Dr. Suresh Chand Verma, WG2 Team Leader, JICA Expert Team
9:40-10:10	1. Issues of geology on Maha 3 and Victoria Lake PSPP development by Mr. WADA Masaki, JICA Expert Team 1-1 Upper and Lower Storage Dams 1-2 Upper and Lower Reservoirs 1-3 Waterways 1-4 Underground Powerhouse 1-5 Questions & Answers
10:10-10:40	2. Recommended scope and schedule of geological investigation at F/S level for Maha 3 and Victoria Lake PSPP that will be performed by CEB in the future by Mr. SHINGU Hirohisa, JICA Expert Team 2-1 Contents of Geological Investigation 2-2 Bill of Quantity 2-3 Schedule 2-4 Questions & Answers
10:40-10:55	Break
10:55-11:25	3. General guidance on each item of geological investigations for PSPP by CEB in the future by Mr. SHINGU Hirohisa, JICA Expert Team 3-1 Geophysical Surveys 3-2 Core Drilling 3-3 Field and Laboratory Tests 3-4 Questions & Answers
11:25-11:50	4. Discussion
11:50-12:00	Address by Mr. D. S. R. Alahakoon, WG2 Leader of Management, CEB



1.  
Issues of Geology on  
Maha3 and Victoria Lake PSPP Development


---

# Maha3 PSPP: Longitudinal Profile of Waterway



Source: Development Planning on Optimal Power Generation for Peak Demand in Sri Lanka, 2015, JICA

# Victoria Lake PSPP: Longitudinal Profile of Waterway



Source: Project on Electricity Sector Master Plan Study in Democratic Socialist Republic of Sri Lanka, 2018, JICA


# Issues of Maha3 and Victoria Lake PSPPs

	Maha3 PSPP	Victoria Lake PSPP
Source of Info.	<ul style="list-style-type: none"> <li>Development Planning on Optimal Power Generation for Peak Demand in Sri Lanka, 2015, JICA</li> </ul>	<ul style="list-style-type: none"> <li>Project on Electricity Sector Master Plan Study in Democratic Socialist Republic of Sri Lanka, 2018, JICA</li> </ul>
Geology	<ul style="list-style-type: none"> <li>Site investigation: in 2015</li> <li><b>Upper dam: thick deposit on the left bank of the talus</b></li> <li>Lower dam: no critical issue</li> <li>Waterway: layers nearly parallel to the water route</li> </ul>	<ul style="list-style-type: none"> <li>Site reconnaissance: in 2018</li> <li><b>Upper dam: possibility of existence of landslide</b></li> <li>Lower dam: unclear</li> <li>Waterway: lineament</li> </ul>
Environment	<ul style="list-style-type: none"> <li>Environmental study: in 2015</li> <li>Natural: out of the protection area</li> <li><b>Social: resettlement of 28 households within the inundated area.</b></li> </ul>	<ul style="list-style-type: none"> <li>Site reconnaissance: in 2018</li> <li><b>Natural: lower dam within the protection area.</b></li> <li>Social: direct impacts on the village may not be substantial.</li> </ul>
Technical Aspect		<ul style="list-style-type: none"> <li><b>Pumping head: more than 700m</b></li> <li><b>Lower dam: construction in the Victoria Lake</b></li> </ul>

# 1. Issues of Geology on Maha 3 Site

Structures	Check points	Major considerable issues
Upper storage dam	<ul style="list-style-type: none"> <li>Safety of dam foundation</li> <li>Water tightness</li> </ul>	<ul style="list-style-type: none"> <li>Thick talus deposits/highly weathered rocks on left bank</li> <li>Impermeable layer seems to be deep on left bank (more than 50 m in depth)</li> </ul>
Reservoir	<ul style="list-style-type: none"> <li>Landslide risks</li> <li>Water seepage risks</li> </ul>	<ul style="list-style-type: none"> <li>No information, but daily fluctuation of water level might thick weather zone on the left bank might trigger landslides especially on left bank covered with thick overburden.</li> <li>No information, but seepage risks on left bank are anticipated.</li> </ul>
Water way	<ul style="list-style-type: none"> <li>Landslide risks of portals</li> <li>Rock condition along water ways</li> </ul>	<ul style="list-style-type: none"> <li>No information</li> <li>Geological structures nearly parallel to the waterway route.</li> <li>NE-SW lineaments (possible faults) were identified.</li> </ul>
Underground powerhouse	<ul style="list-style-type: none"> <li>Rock condition</li> </ul>	<ul style="list-style-type: none"> <li>Biotite gneiss according to existing geological map.</li> <li>No critical issues according to the Report (2015)</li> </ul>
Lower storage dam and reservoir	<ul style="list-style-type: none"> <li>Same as upper storage dam and reservoir (Safety of dam foundation, Water tightness, Landslide risks and Water seepage risks)</li> </ul>	<ul style="list-style-type: none"> <li>No critical issues according to the Report (2015)</li> </ul>

# Maha3: Layout of the Structures and Geological Issues



Upper Reservoir (200MW*3units)		Lower Reservoir (200MW*3units)		Waterways (200MW*3units)	
Latitude	7°06'23"	Latitude	7°07'50"	Headrace Tunnel	
Longitude	80°28'40"	Longitude	80°28'40"	Tunnel Diameter	m
					5.60




Source: Development Planning on Optimal Power Generation for Peak Demand in Sri Lanka, 2015, JICA, JICA

8 Study Team added the geological information.

# Maha3: Geological Map of Upper dam

Figure A.12.1.3-1 (1) Drilling location on upper dam


Appendix A.12.1



Source: Development Planning on Optimal Power Generation for Peak Demand in Sri Lanka, 2015, JICA

# Maha3: Geological Section of Upper Dam (Original)

U1 - U1 Dam Axis  
 Geological Section Based on tentative Rock Mass Classification by CECB




CLASS	CONDITION OF ROCK
A	Fresh and hard, no deterioration in the rock - forming minerals. Crack spacing larger than about 30cm.
B	Fresh and hard. Weathering along clacks. Crack spacing larger than about 15cm.
C	Feldspar is deteriorated, but quartz particles are hard. When struck by hammer breaks into pieces. In the form of small pieces, rock pieces remain. No circular core.
Cw	Breaks when struck by hammer. Deterioration of feldspar developed. Clay is sandwiched along the opening face. Crack spacing smaller than 5cm.
D	Extremely soft. Very friable and tends to powderize. Residual soil form.

Source: Development Planning on Optimal Power Generation for Peak Demand in Sri Lanka, 2015, JICA



# Maha3: Geological Section of Upper Dam (Reviewed)

Another possibility of geological section along dam axis




Source: Development Planning on Optimal Power Generation for Peak Demand in Sri Lanka, 2015, JICA, JICA Study Team reviewed.

# Maha3: Geological Map of Lower Dam


Figure A.12.1.3-1 (2) Drilling location on lower dam

Appendix A.12.1




Source: Development Planning on Optimal Power Generation for Peak Demand in Sri Lanka, 2015, JICA

# Maha3: Geological Section of Lower Dam (Original)



Source: Development Planning on Optimal Power Generation for Peak Demand in Sri Lanka, 2015, JICA

# Maha3: Geological Section of Lower Dam (Reviewed)



It is noted that

- Charnokite sometimes occurs in association with limestone.
- There might be some fracture zones hiding beneath talus deposits.

Source: Development Planning on Optimal Power Generation for Peak Demand in Sri Lanka, 2015, JICA

# Maha3: Summary of Laboratory tests

Appendix A.12.1

Table A.12.1.5-2 Detailed results of laboratory tests

Borehole	total test depth section	rock type	Rock class (by CECB tentative classification)	dry density, Saturated density, water content for rock mass.			oven dry density, surface saturated density, absorption for coarse aggregate				UCS	tensile strength	soundness	alkali reactivity test (chemical method)	abrasion (Los Angeles)
				rock core	rock core	rock core	coarse aggregate from core				rock core	rock core	coarse aggregate from core	coarse aggregate from core	coarse aggregate from core
ASTM No.				D2216 moisture %	D2216 dry density kg/m <sup>3</sup>	D2216 saturated density kg/m <sup>3</sup>	C127 apparent specific gravity	C127 dry density kg/m <sup>3</sup>	C127 saturated density kg/m <sup>3</sup>	C127 absorption %	D7012 MPa	D3967 MPa	C88 loss %	C289 reduction of alkalinity mmol/l	C131 abrasion value % (100, 500 rev)
BHL01	8.7-10.7m	Biotite Gneiss	CM	0.1	2,844.16	2,853.70					40.58	1.61			
	10.7-12.6m	Biotite Gneiss	CH				2.73	2,620	2,660	1.4					
	15.75-22.58m	Biotite Gneiss	A	0.0	2,698.34	2,703.80	2.74	2,670	2,700	0.8	22.07	5.61	1	149.2	15, 53
	36.51-41.32m	Biotite Gneiss	A	0.0	2,731.22	2,739.15									
BHL02	2.35-3.05m	Biotite Gneiss	CH								23.00	4.71			
	4.32-8.5m	Biotite Gneiss	A	0.0	2,746.45	2,750.03	2.76	2,680	2,710	1.0	30.43	8.35			
	36.57-40.9m	Biotite Gneiss	A	0.0	2,686.41	2,690.61	2.78	2,710	2,730	0.8	25.89	7.08	1	185.7	13, 50
BHL03	5.12-9.90m	Biotite Gneiss	A	0.1	2,860.93	2,864.11	2.76	2,710	2,730	0.6	49.40	4.20			
	14.42-19.0m	Biotite Gneiss	A										2	52.1	27, 74
	20.0-28.14m	Biotite Gneiss	A	0.1	2,788.79	2,793.00	2.8	2,750	2,770	0.6	28.84	4.67			
BHU03	10.8-11.72m	Granitic Gneiss	B	0.1	2,628.64	2,634.83	2.65	2,570	2,600	1.0					
	11.72-12.77m	Granitic Gneiss	B								49.66	5.69			
	24.63-29.32m	Granitic Gneiss	A	0.1	2,706.79	2,711.64	2.69	2,630	2,650	0.7	67.14	7.28	2	50.1	13, 49
	38.01-42.63m	Biotite Gneiss	A	0.1	2,621.33	2,625.19	2.67	2,630	2,640	0.6	29.01	7.95			
BHU02	5.0-6.4m	Biotite Gneiss	B	0.1	2,722.04	2,726.41					26.80	6.30			
	10.7-15.9m	Granitic Gneiss	A	0.1	2,612.72	2,620.38	2.66	2,610	2,620	0.7	100.43	5.04			
	32.2-41.3m	Granitic Gneiss	A	0.1	2,607.02	2,611.49	2.66	2,600	2,620	0.8	68.96	7.41	1	53.3	11, 45
BHU01	27.800-37.500	Biotite Gneiss	CM	1.1	2,687.20	2,694.82	2.65	2,520	2,570	1.7	77.60	10.64			
	49.500-50.510	Biotite Gneiss	A	0.1	2,770.97	2,772.58	2.77	2,730	2,740	0.4	86.57	7.23			
	51.205-55.190	Biotite Gneiss	A	0.2	2,772.04	2,774.16	2.77	2,720	2,740	0.5	39.16	14.30			
Total No. of samples to be used				16	16	16	13	13	13	13	15	15	4	4	4

(Note: red letter samples were judged inappropriate thus omitted)

Physical properties seems to be suitable for concrete aggregates/rock materials. However, JICA report (2015) mentioned some of these tests were not conducted properly.

⇒ These rock parameters needs to be confirmed by proper laboratory tests in FS stage.

Source: Development Planning on Optimal Power Generation for Peak Demand in Sri Lanka, 2015, JICA


## 2. Issues of Geology on Victoria Lake Site

According to the JICA Study 2018 report,

- There are No detailed geological investigations in Victoria site.
- The project area is covered by metamorphic rocks.
- Four lineaments were identified by satellite image interpretation by use of google images

Structures	Check points	Major considerable issues
Upper storage dam	<ul style="list-style-type: none"> <li>• Safety of dam foundation</li> <li>• Water tightness</li> </ul>	<ul style="list-style-type: none"> <li>• Possibility of landslide risks</li> <li>• No information</li> </ul>
Reservoir	<ul style="list-style-type: none"> <li>• Landslide risks</li> <li>• Water seepage risks</li> </ul>	<ul style="list-style-type: none"> <li>• Ditto</li> <li>• No information</li> </ul>
Water way	<ul style="list-style-type: none"> <li>• Landslide risks of portals</li> <li>• Rock condition along water ways</li> </ul>	<ul style="list-style-type: none"> <li>• No information</li> <li>• One lineament (possibly fracture zone) crossing the tunnel.</li> </ul>
Underground powerhouse	<ul style="list-style-type: none"> <li>• Rock condition</li> </ul>	<ul style="list-style-type: none"> <li>• No information</li> </ul>
Lower storage dam and reservoir	<ul style="list-style-type: none"> <li>• Safety of dam foundation, Water tightness, Landslide risks and Water seepage risks</li> </ul>	<ul style="list-style-type: none"> <li>• No information</li> </ul>

# Victoria Lake PSPP: Geological Lineament and Landslide



Lineaments (white line)




Upper reservoir and Possible landslide (black line)

Source: Project on Electricity Sector Master Plan Study in Democratic

17 Socialist Republic of Sri Lanka, 2018, JICA



# Victoria Lake PSPP: Upper Dam



## Comment:

- Foundation condition needs to be further assessed. It may be required to provide sealing to cover the bottom of the reservoir also.
- Stability Dam failure, if occurred, may result in serious damage of the exposed penstock.

A - A' Section





2.  
Recommended Scope and Schedule  
of Geological Investigation at F/S level  
for Maha 3 and Victoria Lake PSPP  
that will be performed by CEB in the future

---

**Guideline and Manual for  
Hydropower Development Vol. 1  
Conventional Hydropower and  
Pumped Storage Hydropower**

March 2011

Japan International Cooperation Agency


Electric Power Development Co., Ltd.

JP Design Co., Ltd.

IDD
JR
11-019

- Introduction of Guideline and Manual by JICA
  - JICA has a guideline and manual for Hydropower development.
  - The document can be downloaded by the following URL:  
[https://openjicareport.jica.go.jp/pdf/12024881\\_01.pdf](https://openjicareport.jica.go.jp/pdf/12024881_01.pdf)
  - Based on this document, status and necessary geological investigation of Maha 3 and Victoria Lake by F/S level is proposed.

# Geological Investigations in Each Stage



# Progress to Date

## ■ *Maha3 is in F/S Stage, while Victoria Lake is in Pre-F/S Stage.*

Investigation Stage	Major Investigation Items	Maha 3	Victoria Lake
Pre-feasibility study (M/P, Pre-F/S)	Literature survey	Done	Done
	Topographic survey	Scale =1:5000, 1.14 km <sup>2</sup> Scale =1:1000, 1.0 km <sup>2</sup>	N/A
	Geological reconnaissance	Done	Done
Feasibility Study (F/S)	Geological mapping	Available at upper dam and lower dam site only	N/A
	Geophysical prospecting	N/A	N/A
	Exploratory drilling	Upper dam site: 3 drill holes Lower dam site: 3 drill holes	N/A
	Laboratory rock test	Done	N/A
	Exploratory adit (if necessary)	N/A	N/A
Detailed design Study (D/S or D/D)	Exploratory drilling	N/A	N/A
	Exploratory adit	N/A	N/A
	In-situ rock test	N/A	N/A
	Laboratory test	N/A	N/A
Geotechnical investigation during construction	Geotechnical investigation & recording of geological information during construction	N/A	N/A

## F/S: 1<sup>st</sup> Stage

- 1<sup>st</sup> stage geological investigation
- Layout study
- Determine to proceed or not



## F/S: 2<sup>nd</sup> Stage

### Full-Swing Level

- 2<sup>nd</sup> stage geological investigation
- Basic design
- Project feasibility

# Scope of Geological Investigation for Maha 3 to be conducted in 1<sup>st</sup> Stage of F/S

Major Investigation Items	Status	Scope of Geological Investigation in 1 <sup>st</sup> Stage of F/S
Literature survey	Done	-
Topographic survey	Scale =1:5000, 1.14 km <sup>2</sup> Scale =1:1000, 1.0 km <sup>2</sup>	-
Geological reconnaissance	Done	-
Geological mapping	Available at upper dam and lower dam site only	<b>Geological mapping of all the area is needed</b>
Geophysical prospecting	N/A	<b>Seismic and electric survey is required at the following;</b> <ul style="list-style-type: none"> <li>➤ <b>Upper Dam:</b> Thick overburden on left bank (Seepage risk)</li> <li>➤ <b>Waterway and Underground powerhouse:</b> No geological information is available.</li> </ul>
Exploratory drilling	Upper dam site: 3 drill holes Lower dam site: 3 drill holes	<b>Exploratory drilling with on-site test is required at the following;</b> <ul style="list-style-type: none"> <li>➤ <b>Upper Dam:</b> Thick overburden on left bank (Seepage risk)</li> </ul>
Laboratory rock test	Done	<b>To be additionally done</b>

# Assumed Quantities of Geological Investigation for Maha 3 to be conducted in 1<sup>st</sup> Stage of F/S

Item		Requirement		
		Specification	Q'ty	Unit
<b>Investigation</b>				
<b>Geological Mapping</b>				
G-01	Surface geological survey	1/10.000	10	km <sup>2</sup>
<b>Seismic Prospecting</b>				
S-01	Upper dam	1 profile & 2 axes	1.2	km
S-02	Waterway	center line	3.0	km
<b>Electrical Resistivity Prospecting</b>				
E-01	Upper dam	1 profile & 2 axes	1.2	km
E-02	Upper dam, ridge over left bank	1 section	0.5	km
E-03	Waterway	center line	3.0	km
<b>Core Drilling</b>				
B-01	Upper dam, left bank, upstream	vertical, soil	20	m
		vertical, rock	40	m
B-02	Upper dam, left bank, downstream	vertical, soil	20	m
		vertical, rock	40	m
<b>In-situ Test</b>				
T-01	Standard penetration test	core drilling	40	nos.
T-02	Permeability test	core drilling	16	nos.
<b>Laboratory Tests for Rock Cores</b>				
L-01	Water absorption and bulk specific gravity	rock core	10	test
L-02	Unconfined compression of rock core specimen	rock core	10	test
L-03	Tensile strength	rock core	10	test
L-04	Ultrasonic test of core sample	rock core	20	test
L-05	Los Angeles Abrasion	rock core	5	test
L-06	Soundness	rock core	5	test
L-07	Alkali reactivity	rock core	5	test

# Assumed Schedule of Geological Investigation for Maha 3 to be conducted in 1<sup>st</sup> Stage of F/S

Investigation Item	Unit	Qty	Month						
			1	2	3	4	5	6	7
Geological mapping	km2	10	■	■					
Seismic prospecting	km	4.2		■	■	■			
Electrical resistivity prospecting	km	4.7		■	■	■			
Core drilling (2 boreholes)	m	120				■	■	■	
Standard penetration test (SPT)	nos	40				■	■	■	
Permeability test	nos	16				■	■	■	
Laboratory tests (7 Types)	test	20						■	■
Preparation of Investigation report	L.S.	1							■



# Scope of Geological Investigation for Victoria to be conducted in 1<sup>st</sup> Stage of F/S

Major Investigation Items	Status	Scope of Geological Investigation in 1st stage of F/S
Literature survey	Done	-
Topographic survey	N/A	Topographic mapping of all the area is needed
Geological reconnaissance	Done	-
Geologic mapping	N/A	Geological mapping of all the area is needed
Geophysical prospecting	N/A	Seismic and electric survey is required at the following; <ul style="list-style-type: none"> <li>➤ Upper Dam and Lower Dam: Safety of dam foundation, landslide and seepage risks</li> <li>➤ Waterway and Underground powerhouse: No geological information</li> </ul>
Exploratory drilling	N/A	Exploratory drilling with on-site test is required at the following; <ul style="list-style-type: none"> <li>➤ Upper Dam: Safety of dam foundation, landslide and seepage risks</li> <li>➤ Lower Dam: Safety of dam foundation, landslide and seepage risks</li> </ul>
Laboratory rock test	N/A	To be done

# Assumed Quantities of Geological Investigation for **Victoria** to be conducted in **1<sup>st</sup> Stage of F/S**

Item	Requirement		
	Specification	Q'ty	Unit
<b>Investigation</b>			
<b>Topographic Mapping</b>			
T-01 Detailed mapping	1/1,000	2.5	km2
<b>Geological Mapping</b>			
G-01 Surface geological survey	1/10,000	20	km2
<b>Seismic Prospecting</b>			
S-01 Upper dam	1 axis & 2 profiles	1.2	km
S-02 Waterway	center line	6.0	km
<b>Electrical Resistivity Prospecting</b>			
E-01 Upper dam	1 profile & 2 axes	1.2	km
E-02 Waterway	center line	6.0	km
<b>Core Drilling</b>			
B-01 Upper dam, #1	vertical, soil	15	m
	vertical, rock	25	m
B-02 Upper dam, #2	vertical, soil	15	m
	vertical, rock	25	m
B-03 Upper dam/Intake, #3	vertical, soil	15	m
	vertical, rock	25	m
B-04 Upper dam/Penstock, #4	vertical, soil	15	m
	vertical, rock	25	m
B-05 Lower dam, #1	vertical, soil	20	m
	vertical, rock	40	m
B-06 Lower dam, #2	vertical, soil	20	m
	vertical, rock	40	m
<b>In-situ Test</b>			
T-01 Standard penetration test	bore-hole	100	nos.
T-02 Permeability test	bore-hole	36	nos.
<b>Laboratory Tests for Rock Cores</b>			
L-01 Water absorption and bulk specific gravity	rock core	30	test
L-02 Unconfined compression of rock core specimen	rock core	30	test
L-03 Tensile strength	rock core	30	test
L-04 Ultrasonic test of core sample	rock core	20	test
L-05 Los Angeles Abrasion	rock core	5	test
L-06 Soundness	rock core	5	test
L-07 Alkali reactivity	rock core	5	test

# Assumed Schedule of Geological Investigation for **Victoria** to be conducted in **1<sup>st</sup> Stage of F/S**

Investigation Item	Unit	Qty	Month										
			1	2	3	4	5	6	7	8	9	10	
Topographic mapping	km2	2.5	■	■	■								
Geological mapping	km2	20	■	■	■								
Seismic prospecting	km	7.2		■	■	■	■	■					
Electrical resistivity prospecting	km	7.2		■	■	■	■	■					
Core drilling (6 boreholes)	m	280				■	■	■	■	■	■		
Standard penetration test (SPT)	nos	100				■	■	■	■	■	■		
Permeability test	nos	36				■	■	■	■	■	■		
Laboratory tests (7 Types)	test	30										■	
Preparation of Investigation report	L.S.	1											■

# Geological Investigation for Maha3 and Victoria to be conducted in **2<sup>nd</sup> Stage of F/S**

Scope, quantities and schedule of geological investigation for Maha3 and Victoria to be conducted in 2<sup>nd</sup> stage of F/S will depend on the output of the geological investigation and layout study in 1<sup>st</sup> stage of F/S.

The following scope will be at least required.

Major Investigation Items	Status	Scope of Geological Investigation 2 <sup>nd</sup> stage of F/S
Exploratory drilling	Partly done in 1 <sup>st</sup> Stage	<p><b>Exploratory drilling with on-site test will be required at the following;</b></p> <p><b>For both Maha3 and Victoria</b></p> <ul style="list-style-type: none"> <li>➤ 1 drilling for underground powerhouse</li> <li>➤ 2 drillings for underground tunnel</li> </ul> <p><b>For Victoria only</b></p> <ul style="list-style-type: none"> <li>➤ 1 underwater drilling for lower dam</li> </ul>
Laboratory rock test	Partly done in 1 <sup>st</sup> Stage	To be done

# Check List for Geological Investigations at F/S Stage

Investigation Items	Contents
Literature survey	<ul style="list-style-type: none"> <li>➤ Following literatures are obtained?                             <ul style="list-style-type: none"> <li>- Geological map (scale 1/500,000 or more)</li> <li>- Aerial Photos</li> <li>- Seismic data</li> <li>- Other geological info (mines, springs, etc.)</li> </ul> </li> <li>➤ Seismic factor is analyzed (in case of seismic-prone area)?</li> </ul>
Geological reconnaissance Geologic mapping	<ul style="list-style-type: none"> <li>➤ The investigation area is covering entire planning area with sufficient marginal area of 300m or more?</li> <li>➤ Geological conditions are clarified?                             <ul style="list-style-type: none"> <li>- Stratigraphy and formation</li> <li>- Rock type and distribution</li> <li>- Age</li> </ul> </li> <li>➤ Faults are available at the planning area?                             <ul style="list-style-type: none"> <li>- Dip and Strike</li> <li>- Active or non-active</li> <li>- Associating with share zone with spring or fault breccia</li> </ul> </li> <li>➤ Any negative geological structure is identified? (e.g. dip slope)</li> <li>➤ Characteristics of recent river deposit at dam site are clarified?                             <ul style="list-style-type: none"> <li>- Grain size and packing</li> <li>- Permeability</li> </ul> </li> <li>➤ Weathering of rock is clarified at dam site?                             <ul style="list-style-type: none"> <li>- Talus deposit</li> <li>- Weathering at outcrops</li> </ul> </li> <li>➤ Is there any open cracks or joints available at dam foundation?</li> <li>➤ Any geohazard-prone area is clarified as landslide, collapse, rockfall, etc?</li> <li>➤ Any special rock are available at the area as limestone?</li> </ul>

Investigation Items	Contents
<b>Geological reconnaissance (Landslide survey)</b>	<ul style="list-style-type: none"> <li>➤ Interpretation of topography by topo-map and/or aerial photo is conducted?               <ul style="list-style-type: none"> <li>- Occurrence of Landslide and collapse with evaluation of their activity in entire planning area</li> </ul> </li> <li>➤ Site reconnaissance of landslide/geohazard survey is conducted?</li> </ul>
<b>Geophysical prospecting</b>	<ul style="list-style-type: none"> <li>➤ The contents of geological investigation is sufficient?               <ul style="list-style-type: none"> <li>- Geophysical prospecting at dam axis and underground powerhouse</li> </ul> </li> </ul>
<b>Exploratory drilling</b>	<ul style="list-style-type: none"> <li>➤ The contents of geological investigation is sufficient?               <ul style="list-style-type: none"> <li>- 3 to 5 exploration drillings at dam foundation</li> </ul> </li> </ul>

### 3. General Guidance on Each Item of Geological Investigations for PSPP by CEB in the future

---

# Contents

---

## 3-1 Geophysical Surveys

- Seismic Survey
- Electrical Sounding

## 3-2 Core Drilling

## 3-3 Field and Laboratory Tests


- Standard Penetration Tests (SPT)
- On-site permeable Tests (Lugeon test)

## 3-4 Questions & Answers




# 3-1 Geophysical Surveys

- Seismic Prospecting (video available)



# 3-1 Geophysical Surveys

- Result of seismic prospecting shows seismic velocity of ground
- Talus deposit, loosen part of foundation can be found



<http://www.ne.jp/asahi/refra/tansa/5.html>

Output (Geophysical Section)


# 3-1 Geophysical Surveys

## ● Electrical Sounding (Resistivity Survey)

- Ground resistivity is measured through electrodes
- Resistivity structure may contribute the interpretation of geological structure.



Survey Equipment



Output by inversion analysis

Source: [https://archive.epa.gov/esd/archive-geophysics/web/html/resistivity\\_methods.html](https://archive.epa.gov/esd/archive-geophysics/web/html/resistivity_methods.html)


# 3-2 Core Drilling and Sampling

(video available)



Source: <https://www.tohochikakoki.co.jp/>

Core drilling machine



Source: <http://hitec-homedoctor.co.jp/>

System and Equipment

# 3-2 Core Drilling and Sampling



Source: <http://www.soilssystem.jp/business/business1>

Core Drilling at site




Source: <http://hitec-homedoctor.co.jp/>

Drilled Core

# 3-3 Field and Laboratory Tests

## ● Standard Penetration Tests (SPT)



<https://geologyengineering.com/2019/08/standard-penetration-test/>

Test Procedure




[https://www.pwri.go.jp/team/geosearch/tech\\_01\\_02.html](https://www.pwri.go.jp/team/geosearch/tech_01_02.html)

Testing


# 3-3 Field and Laboratory Tests

## ● Permeability test “Lugeon test”



[http://www.geotesting.info/geotest/Lugeon\\_test.html](http://www.geotesting.info/geotest/Lugeon_test.html)

Test Equipment



<https://geolab-ikram.com/soil-investigation/>

Test at Drilled Borehole

## ■ Management of geological investigations

- Quality control
- Cost control
- Schedule control
- Safety control


■ Selection of qualified geotechnical company is most important.

■ Monitoring work progress

■ Periodical inspection at site



Thank you



**Democratic Socialist Republic of Sri Lanka  
The Project for Capacity Development on the Power Sector Master Plan  
Implementation Program  
(2nd Technical Seminar)**

**How to Proceed the Development of the Pumped Storage Power Plant**


---

**Transmission and Generation Planning Branch  
Transmission Division  
Ceylon Electricity Board  
Sri Lanka**

**December 22, 2021**

# Pumped Storage Hydropower Plant

---




## Firm Power Sources

Controllable



## Non-Firm Power Sources


Short time Variations



Storage

Firm Power

# Energy Balancing



# Advantages of Pumped Storage Hydropower Plants


---

- ENERGY BALANCING (PEAK POWER SUPPORT)
- FIRING OUTPUT OF INTERMITTENT RESOURCES
- STABILITY AND INERTIA (MECHANICAL)
- ANCILLARY GRID SERVICES
  - FREQUENCY CONTROL
  - SPINNING RESERVE (INCREMENTAL AND DECREMENTAL)

# MOST PROMISING SITES

## Maha3 Site (Aranayake)


Capacity (MW)	600
Rated Head (m)	486
Upper Pond (MCM)	3.94
Lower Pond (MCM)	6.33
Peak Time (H)	6.00
Capital Cost (US\$/kW)	1063



## Wewathenna-Victoria Site

Capacity (MW)	1400
Rated Head (m)	686
Upper Pond (MCM)	5.5
Lower Pond (MCM)	10
Peak Time(H)	6.00
Capital Cost (US\$/kW)	689

# PROPOSED LOCATIONS OF ARANAYAKA (MAHA 3) SITE





# PROPOSED LOCATIONS OF WEWATHENNA-VICTORIA SITE




# Proposed Plot Plan of Wewathenna-Victoria





# WAY FORWARD

## Aranayake (Maha3) Site



## Wewathenna-Victoria Site



Phase 1



Phase 2




## LIST OF PROPOSED EXPERTS FOR THE STUDIES


Project Manager/ Team Leader
Expert Geologist
Specialist Civil Engineering
Environmental Expert
Civil Eng. (Tunnelling & Underground works)
Civil Eng. (other structures and roads)
Civil Eng. (cost & quantities)
Civil Eng. (construction planning)
Hydro-Mechanical Engineer
Electro-Mechanical Engineer
Hydrologist
Economist
Geotechnical Engineer
Ecologist
Sociologist

Pumped Storage Specialist
Specialist Hydro-Mechanical
Specialist Electro-Mechanical
Specialist Power Systems

## PRESENT PROGRESS (CONSULTANCY PROCUREMENT)



# STUDY SCHEDULE



# Study Scope

- **TECHNICAL FEASIBILITY**
  - TOPOGRAPHICAL SURVEY
  - GEOLOGICAL, GEOTECHNICAL AND MATERIAL STUDIES
  - HYDROLOGICAL STUDIES
  - POWER SYSTEM STUDIES
- **ENVIRONMENTAL FEASIBILITY**
  - PHYSICAL, BIOLOGICAL & SOCIAL ENVIRONMENT
- **ECONOMIC/FINANCIAL FEASIBILITY**
- **FEASIBILITY LEVEL DESIGN**
- **IMPLEMENTATION PLANNING AND CONSTRUCTION SCHEDULE**

# Implementation Phases

- ENVIRONMENT & OTHER APPROVALS
- PROJECT FINANCING
- TENDERING
- DETAIL DESIGN
- CONSTRUCTION
  - CIVIL CONSTRUCTIONS (UPPER/LOWER RESERVOIRS, TUNNELS/PENSTOCKS, POWER HOUSE, ETC.)
  - MECHANICAL/ ELECTRICAL EQUIPMENT (PUMP-TURBINE, MOTOR-GENERATOR, AUXILIARY SYSTEMS, ETC)
  - TRANSMISSION INTERCONNECTION (TR. LINE AND SWITCH YARD)
- TESTING & COMMISSIONING



# CONTRIBUTION OF JICA ON PSHP STUDIES

**Sri Lanka  
Ceylon Electricity Board**

**Development Planning on Optimal Power  
Generation for Peak Demand in Sri Lanka**

**Final Report**

**February 2015**

**Japan International Cooperation Agency  
Electric Power Development Co., Ltd.**

IL
JET
15-021

Ministry of Power and Renewable Energy (MPRE)  
Ceylon Electricity Board (CEB)

**Project on Electricity Sector  
Master Plan Study in Democratic  
Socialist Republic of Sri Lanka**

**Final Report**

**March, 2018**

Japan International Cooperation Agency (JICA)

Tokyo Electric Power Company Holdings, Inc. (TEPCO HD)  
TEPCO Power Grid, Incorporated (TEPCO PG)  
Tokyo Electric Power Services Co., Ltd. (TEPSCO)


**THE PROJECT FOR CAPACITY  
DEVELOPMENT ON THE POWER SECTOR  
MASTER PLAN IMPLEMENTATION PROGRAM**

# TRAINING ON GEOLOGICAL INVESTIGATIONS

Session	Date
Online session	2020-10-28
Online session	2021-07-08
Site training	2021-10-26
Online session	2021-10-28



# TRAINING ON GEOLOGICAL INVESTIGATIONS



***THANK YOU***

